

BOOK100R

Notes:

"U(4.9) rads #6" on spine

Blank pages: inside cover sheet, 1, 22, 91-300, inside back cover sheets

-1 half sheet between cover sheets

-pages 3, 5, 6, 7, 19, 81(2), 82, 84(2), 86, 87, 89 have small drawing(s) attached to each page

-pages 19/20 have plastic clip at top

-page 54 has photo attached

-pages 77/78 have paper clip at top

Scanned by:

Sheila Finch

RSICC /Oak Ridge National Lab.

September 10, 1999.

14-2-1



NO. 64-6138 (168)

ACCOUNT BOOK

RULING: RECORD

300 PAGES • 10 IN. x 8¼ IN.

S.E.&M. VERNON CO., Elizabeth, N.J. 07208
A Division of THE MEAD CORPORATION

Log #6 5/21/73

0.3 rods, 2.05 sep.

1420 - - - - - 3

Concrete - Diagram 5

(Block dimensions, wpts, P/rod/ft)

Refracted lattices 7

spread from focus

Unclad concrete + diagram 19

wet concrete 20, 21

Vary refl. thickness

(no diagrams in log)

Clust w lattices, 42

Vary thickness 720"

0
0
0

2

0

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	3x10 ⁻¹²
		Fast ✓	2"	✓	"
K-2	3x10 ⁻¹²	Meter ✓	4"	✓	"
		Fast ✓	2"	✓	"
PM-1	700V ✓	Alarm ✓	.5"	✓	500V ✓
PM-2	1200V ✓	Low ✓	10"	✓	900V ✓
		Alarm ✓	2"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER B-80

START-UP CHECK LIST

Equipment checked by T.D.C. / AKM Personnel check by AKM

Instruments and safeties checked and reset by AKM

Source in checked by AKM # 4-M-93

Emergency equipment in control by AKM

Instruments in trip circuit: K-1-2 PM-2

Red light on by AKM Time 1235

Start-up OK'd by T.D.C. / AKM Date 5-21-73

2.050 cm separation c-c.
30 cm length.
130 rods.

Top of rods = 25.60 cm
H₂O only.

Have an 14 x 14 + 7 rods


Water ht = 42.00 cm
1 Per.

$T = 97.78 \text{ sec} = 10.1 \text{ f}$

1305 Water ht = 33.50 cm

37.70 25.00

System just critical
Drain.



T1 = 28.2 °C

T2 = 28.2 °C

Removed 1 rod. Total of 202 rods.

Water ht = 42.00 cm
2 Per.

$T = -325.95 \text{ sec} = -9.5 \text{ f}$

1325 Drain.

Temp °C

T1 = 28.2 °C

T2 = 28.2 °C

Added 1 rod. Repeat of first run. Total of 203 rods.

Water ht = 42.00 cm
3 Per.

$T = 95.61 \text{ sec} = 10.2 \text{ f}$

1350 Water ht = 33.50 cm

System just critical
Drain.

Temp °C

T1 = 28.2 °C

T2 = 28.2 °C

2.050 cm refer
30 cm length.
.30" rods.

14x14 array
1 cm 1 foot
203 rods
p-3 log #4

3

Top of rods = 25.60 cm
H₂O only.

Have an 14x14 + 7 array: Total of 203 rods.

Water ht = 42.00 cm
1 Per.

Temp °C
#1 = 29.2 °C
2 = 29.2 °C

$\tau = 97.78 \text{ sec} = 10.14$

1305 Water ht = 33.50 cm 37.70 25.7°C

System just critical
Drain.

Removed 1 rod: Total of 202 rods.

Water ht = 42.00 cm
2 Per

Temp °C
#1 = 29.2 °C
2 = 29.2 °C

$\tau = -325.95 \text{ sec} = -4.54$

1325 Drain.

Added 1 rod: Repeat of first run. Total of 203 rods.

Water ht = 42.00 cm
3 Per

Temp °C
#1 = 29.2 °C
2 = 29.2 °C

$\tau = 95.61 \text{ sec} = 10.24$

1350 Water ht = 33.50 cm

System just critical
Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3×10^{-12}	Meter ✓	4"	✓	3×10^{-12}
		Fast ✓	2"	✓	"
K-2	3×10^{-12}	Meter ✓	4"	✓	"
		Fast ✓	2"	✓	"
PM-1	700V	Alarm ✓	5"	✓	500V 700V
PM-2	1200V	Low ✓	10"	✓	900V 1200V
		Alarm ✓	2"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER B-80

START-UP CHECK LIST

Equipment checked by I.D.C. BKK Personnel check by I.D.C.
 Instruments and safeties checked and reset by BKK
 Source in checked by BKK Source No. 14-93
 Emergency equipment in control room checked by I.D.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by BKK Time 0950
 Start-up OK'd by I.D.C. BKK Date 5-22-73


w h L^{gth}

Non 4" X 8" X 16" Concrete block
 incased in an avg thickness of
 plexiglas of .116"

5

Block's wt before and after incasing:

	before	after	
# 4	17,950 Kg	19,100 Kg	= 1,150 Kg
5	18,050 Kg	19,225 Kg	= 1,175 Kg
7	17,800 Kg	18,900 Kg	= 1,100 Kg
19	18,000 Kg	19,150 Kg	= 1,150 Kg



Position of rods to concrete block's

6

2,050 cm separation c.c.
30 cm length.
30" rods.

Concrete blocks + H₂O. (See diagram)
Blocks spaced, 250" + ^{116"} cover thickness from array.
Have an 14 x 14 array. Total of 196 rods.

$\Delta L = 1.1 \text{ cm}$

Water ht = 32.80 cm

Temp °C

6 Per

#1 = 24.5 °C

$C = 76.05 \text{ sec} = 12.2 \text{ f} = 11.09 \text{ f/cm}$

2 = 24.5 °C

10:20 Water ht = 31.70 cm

System just critical
Drain.

Removed 2 rods. Have an 12 x 14 - 2 array.
Total of 194 rods.

$\Delta L = 8.00$


Water ht = 42.00 cm

2 Per

$C = 141.24 \text{ sec} = 7.5 \text{ f} = 94 \text{ f/cm}$

10:42 Water ht = 34.00 cm

System just critical
Drain.



Removed 1 rod. Have an 11 x 14 - array
Total of 193 rods.

Water ht = 42.00 cm

Temp °C

3 Per

#1 = 24.5 °C

$C = -347.68 \text{ sec} = -9.2 \text{ f}$

2 = 24.5 °C

10:55 Drain

Now have an 14x14-3 array. Total of 193 rods.
Concrete blocks maw in contact with array.
Deprecation = cover thickness = .116"

Water ht = 42.00 cm
4-Per
N.G.

Temp °
#1 = 29.5 °
2 = 29.5 °

1308 Drain

added 1 rod. Now an 14x14-2 array. Total of 192 rods.

Water ht = 42.00 cm
5-Per
C = -223.82 cm = -7.1 f


1326 Drain

added 1 rod. Now an 14x14-1 array. Total of 195 rods.

Water ht = 42.00 cm
6+per
C = 467.194 = 2.6 f = .42 f/cm

Temp °
#1 = 29.5 °
2 = 29.5 °

1404 Water ht = 35.80 cm
System just critical
Drain.



6

2,050 cm separation c-c.
30 cm length.
.30" rods.

Concrete blocks + H₂O. (See diagram)
Blocks spaced, 250" + "116" cover thickness from array.
Have an 14 X 14 array. Total of 196 rods.

$s = 1.1 \text{ cm}$

Water ht = 32.80 cm

Temp °C

1 Per

#1 = 29.5 °C

$C = 76.05 \text{ sec} = 12.2 \text{ f} = 11.09 \text{ f/cm}$

#2 = 29.5 °C

10:20 Water ht = 31.70 cm

System just critical
Drain.

14 X 14 array - 2
block in row.
Block separation

Removed 2 rods. Have a
Total of 194 rods.

.366"
+ total rods

194

Page 6 log # 6

$s = 8.00$

Water ht = 42.00 cm

Temp °C

2 Per

#1 = 29.5 °C

$C = 141.29 \text{ sec} = 7.5 \text{ f} = .94 \text{ f/cm}$

#2 = 29.5 °C

10:42 Water ht = 34.00 cm

System just critical
Drain.

Removed 1 rod. Have an 14 X 14 - 3 array.
Total of 193 rods.

Water ht = 42.00 cm

Temp °C

3 Per

#1 = 29.5 °C

$C = -347.68 \text{ sec} = -9.2 \text{ f}$

#2 = 29.5 °C

10:55 Drain

Now have an 14x14-3 array. Total of 193 rods.
Concrete blocks now in contact with array.
Separation = cover thickness = .116"

Water ht = 42.00 cm
4-Per
N:G.

Temp °C
#1 = 24.5 °C
2 = 24.5 °C

1308 Drain.

Added 1 rod. Now an 14x14-2 array. Total of 197 rods.

Water ht = 42.00 cm
5-Per
E = -223.82 cm = -7.1 f

1326 Drain

Added 1 rod. Now an 14x14-1 14x14 array - 1
concrete blocks
366" separation
total rods 195

Water ht = 42.00 cm
6-Per
E = 467.194 = 2.6 f = .42 f/cm

Page 7 Log #6

1404 Water ht = 35.80 cm
System just critical
Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3×10^{-12}	Meter ✓	4"	✓	3×10^{-12}
		Fast ✓	2"	—	"
K-2	3×10^{-12}	Meter ✓	4"	✓	"
		Fast ✓	2"	—	"
PM-1	7000	Alarm ✓	15"	✓	5000
PM-2	12000	Low ✓	10"	—	9000
		Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT RADIATION ALARM: A B C SOURCE NUMBER 0-80

START-UP CHECK LIST

Equipment checked by I.D.C. P.K.M. Personnel check by I.D.C.Instruments and safeties checked and reset by P.K.M.Source in checked by P.K.M. Source no. M-43Emergency equipment in control room checked by I.D.C.Instruments in trip circuit: K-1-2 PM-1-2Red light on by P.K.M. Time 0853Start-up OK'd by I.D.C. P.K.M. Date 5-23-73

2.050 cm separation c-c.
30 cm length.
130" rods.

9

Have an 14x14-2 array. Total 198 rods.
Concrete blocks now .100" from array.
+ thickness of cover: .116"

0923

Water ht = 42.00 cm
System just critical
Drain.

Temp °C
#1 = 29.5 °C
2 = 28.5 °C

Now have an 14x14-3 array. Total of 193 rods.
Concrete blocks now .500" from array.
+ thickness of cover: .116"

1007

Water ht = 42.00 cm
System just critical
Drain.

Temp °C
#1 = 29.5 °C
2 = 29.5 °C

Now have an 14x14-3 array. Total of 193 rods
Concrete blocks now .350" from array.
+ thickness of cover: .116"

Water ht = 42.00 cm
- Per

$T = -1151.69 \text{ sec} = -1.2 \text{ f}$

1312

Drain.

Temp °C
#1 = 29.7 °C
2 = 29.7 °C

over

added 1 rad. Total of 199 rods.

Water ht = 42.00 cm
²+Per

Temp °C

#1 = 24.8 °C

$E = 93.99 \text{ sec} = 10.4 f$

#2 = 24.8 °C

1330 Water ht = 33.20 cm.

System just critical
 Drain.

Now have an 14x14-2 array. Total of 199 rods.
 Concrete blocks rows .600" from array.
 + thickness of cover .116"

Water ht = 42.00 cm
³+Per

Temp °C

#1 = 24.8 °C

$E = 80.40 \text{ sec} = 11.7 f$

#2 = 24.8 °C

1438 Water ht = 33.20 cm

System just critical
 Drain.

Removed 1 rad. Total of 193 rods.

1458 Water ht = 42.00 cm

Temp °C

#1 = 24.8 °C

~~Per~~ System just critical
 Drain.

#2 = 24.8 °C

Have an 19x18-3 array; Total of 193 rods.
 Concrete blocks now 1.00" from array.
 + thickness of cover = .116"

Water ht = 42.00 cm

4-Per

$$E = -156.46 \text{ mm} = -11.4 \text{ f}$$

1536 Drain.

Temp °C

$$\#1 = 27.8^\circ \text{C}$$

$$\#2 = 27.8^\circ \text{C}$$

added 1 rod; Total of 194 rods.

Water ht = 42.00 cm

~~4-Per~~

System just critical

1558 Drain.

Temp °C

$$\#1 = 27.9^\circ \text{C}$$

$$\#2 = 27.9^\circ \text{C}$$

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3×10^{-12}	Meter ✓	4"	✓	3×10^{-12}
		Fast ✓	4"	✓	"
K-2	3×10^{-12}	Meter ✓	4"	✓	"
		Fast ✓	2"	✓	"
PM-1	7000	Alarm ✓	5"	✓	5000
PM-2	12000	Low ✓	10"	✓	9000
		Alarm ✓	2"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER 11-80

START-UP CHECK LIST

Equipment checked by A.K.H. Personnel check by F.D.C.

Instruments and safeties checked and reset by A.K.H.

Source in checked by A.K.H. Source No. 11-93

Emergency equipment in control room checked by F.D.C.

Instruments in trip circuit: K-1-2, PM-1-2

Red light on by A.K.H. Time 0845

Start-up OK'd by F.D.C., A.K.H. Date 5-28-73

2,050 cm separation c-c.
30 cm length.
.30" rods.

13

Have an 14x14-2 array. Total of 198 rods.
Concrete blocks now 1.50" from array.
+ thickness of cover. 1.16"

Water ht = 42.00 cm

Temp °C

1-Per

#1 = 24.8 °C

N.G

2 = 24.8 °C

0915 Drain.

added 1 rod. Total of 195 rods.

Water ht = 42.00 cm

Temp °C

2-Per

#1 = 24.8 °C

N.G

2 = 24.8 °C

0938 Drain.

added 1 rod. Total of 196 rods. (full 14x14 array)

Water ht = 42.00 cm

Temp °C

3-Per

#1 = 24.8 °C

C = -412.81 sec = -3.54

2 = 24.8 °C

0957 Drain.

added 2 rods. Total of 198 rods. 14x14+2 array.

Water ht = 42.00 cm

Temp °C

System just critical

#1 = 25.0 °C

1055 Drain.

2 = 25.0 °C

New lane on 14x14+5 array. Total 201 rods.
Concrete blocks new 2.0" from array.
+ thickness of cover. .116"

$$a_1 = 9.6 \text{ cm}$$

Water ht = 42.00 cm
4 + Per

Temp °C
#1 = 25.0°C

$$C = 52.15 \text{ mm} = 15.9 \text{ f}$$

2 = 25.0°C

1300 Water ht = 32.40 cm
System just critical
Drain.

Removed 1 rod. Total number of rods = 200

$$a_1 = 5.9 \text{ cm}$$

Water ht = 42.00 cm
5 + Per

Temp °C
#1 = 25.0°C

$$C = 669.28 \text{ mm} = 1.8 \text{ f}$$

2 = 25.0°C

1320 Water ht = 36.10 cm
System just critical
Drain.

Removed 1 rod. Total number of rods = 199

Water ht = 42.00 cm
6 - Per

Temp °C
#1 = 25.0°C

$$C = -152.11 \text{ mm} = -11.9 \text{ f}$$

2 = 25.0°C

1341 Drain.

Now have an $14 \times 14 + 7$ array. Total of 202 rods
 Concrete blocks now 2.50" from array.
 + thickness of cover. 1.16"

$$d_c = 9.85 \text{ cm}$$

Water ht = 42.00 cm
 7 + per

Temp $^{\circ}\text{C}$

$$T_1 = 25.0^{\circ}\text{C}$$

$$T_2 = 25.0^{\circ}\text{C}$$

$$C = 39.11 \text{ sec} = 19.2\phi$$

Water ht = 32.15 cm

System just critical
 Drain.

Removed 1 rod. Total number of rods = 201

$$d_c = 6.8 \text{ cm}$$

Water ht = 42.00 cm
 8 + per

Temp $^{\circ}\text{C}$

$$T_1 = 25.0^{\circ}\text{C}$$

$$T_2 = 25.0^{\circ}\text{C}$$

$$C = 393.33 \text{ sec} = 3.9\phi$$

1433 Water ht = 35.20 cm

System just critical
 Drain.

Removed 1 rod. Total number of rods = 200

Water ht =

9 - per

Temp $^{\circ}\text{C}$

$$T_1 = 25.0^{\circ}\text{C}$$

$$T_2 = 25.0^{\circ}\text{C}$$

$$C = -196.88 \text{ sec} = -8.9\phi$$

1445 Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	3x10 ⁻¹²
		Fast ✓	2"	✓	"
K-2	3x10 ⁻¹²	Meter ✓	4"	✓	"
		Fast ✓	2"	✓	"
PM-1	700v	Alarm ✓	5"	✓	500v
PM-2	1200v	Low ✓	10"	✓	900v
		Alarm ✓	2"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT.

RADIATION ALARM: A B C SOURCE NUMBER B-80

START-UP CHECK LIST

Equipment checked by ARKK Personnel check by F.D.C.

Instruments and safeties checked and reset by ARKK

Source in checked by ARKK Source No. A-93

Emergency equipment in control room checked by F.D.C.

Instruments in trip circuit: K-1-2 PM-1-2

Red light on by ARKK Time 0850

Start-up OK'd by F.D.C., ARKK Date 5-25-73

2,050 cm separation c-c.
30 cm length.
.30" rods.

17

Have an 14 X 14 + 5 array: Total of 201 rods.
Concrete blocks move 3.00" from array.
+ thickness of cover. 1 1/6"

Water ht = 42.00 cm

Temp °C

1 Per

#1 = 25.0 °C

$E = -239.03 \text{ mm} = -6.5 f$

2 = 25.0 °C

0920 Drain.

Added 1 rod: Total number of rods = 202

Water ht = 42.00 cm

Temp °C

2 + Per

#1 = 25.0 °C

$T = 130.38 \text{ mm} = 8.0 f$

2 = 25.0 °C

0940 Water ht = 33.55 cm

System just critical
Drain.

INSTRUMENT CHECK					
INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STATUS RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	3x10 ⁻¹²
		Fast ✓	2"	✓	"
K-2	3x10 ⁻¹²	Meter ✓	4"	✓	"
		Fast ✓	2"	✓	"
PM-1	700 ✓	Alarm ✓	5"	✓	500 ✓
PM-2	1200 ✓	Low ✓	10"	✓	900 ✓
		Alarm ✓	2"	✓	11

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER B-80

START-UP CHECK LIST

Equipment checked by ^{F.D.C.} RKL Personnel check by RKL
 Instruments and safeties checked and reset by RKL
 Source in checked by RKL Source No. M-93
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by RKL Time 1225
 Start-up OK'd by F.D.C. RKL Date 6-1-73

2.050 cm
30 cm les
.30 "nodes"

Unclad concrete
wt:

#1 = 17,800 Kg

2 = 17,650 Kg

3 = 18,100 Kg

4 = 17,925 Kg

Have an 19 x 19 - 6 array. Total of 190 nodes.
Unclad concrete blocks spaced .250" from
array. (1 on each face.)

1320 Water ht = 42.00 cm
System just critical
Drain.

Temp °
#1 = 24.8 °
2 = 24.8 °

after leaving blocks covered with water
for 1 hr.

Water ht = 42.00 cm
1 - Per
 $\epsilon = -2607.6 \mu = -.51 \%$

Temp °
#1 = 25.1 °
2 = 25.1 °

1432 Drain.

Blocks covered for 1 more hr.


over

2.050 cm separation
 30 cm length.
 .30" rods.

Unclad concrete blocks 4" x 8" x 16"
 w. HT Length.

- wt:
- #1 = 17,800 Kg
 - 2 = 17,650 Kg
 - 3 = 18,100 Kg
 - 4 = 17,925 Kg

Have an 19 x 19 - 6
 Unclad concrete
 trays (1 on each fa



Position of rods to concrete blocks

20 Water ht = 42.00 cm
 system just critical
 Drain.

- #1 = 24.8 °C
- 2 = 29.8 °C

after leaving blocks covered with water
 for 1 hr.

Water ht = 42.00 cm
 1 - Per
 $E = -2607.6 \text{ m} = -0.51 \%$

- Temp °C
- #1 = 25.1 °C
 - 2 = 25.1 °C

32 Drain.

Blocks covered for 1 more hr

see

Water ht = 42.00 cm
 2-Per

$C = 2151.27 \text{ cm} = -.61 f$

1540 Drain

Temp °C

#1 = 25.0 °C

2 = 25.0 °C

WT of concrete blocks after shave run:

Unclad concrete blocks:

#1 = 18.475 Kg self = .675 Kg

2 = 18.450 Kg " = .800 Kg

3 = 18.900 Kg " = .800 Kg

4 = 18.675 Kg " = .750 Kg

WT of unclad concrete blocks used in
 array's from p-29 to p. Block where
 spaced at cell boundary .250"

4" x 8" x 16"

concrete blocks:

Weight of block before placed in
 water. (see diagram) or position in array's

1 = 17.500 Kg 9 = 17.900 Kg 17 = 18.100 Kg

2 = 17.825 Kg 10 = 18.875 Kg 18 = 18.175 Kg

3 = 17.675 Kg 11 = 17.750 Kg 19 = 17.800 Kg

4 = 17.625 Kg 12 = 18.100 Kg 20 = 17.925 Kg

5 = 17.950 Kg 13 = 17.650 Kg 21 = 18.550 Kg

6 = 17.450 Kg 14 = 17.600 Kg 22 = 18.575 Kg

7 = 18.075 Kg 15 = 17.950 Kg 23 = 18.025 Kg

8 = 18.050 Kg 16 = 17.700 Kg 24 = 18.050 Kg

25 = 18,075 Kg	37 = 18,425 Kg
26 = 18,200 Kg	38 = 18,400 Kg
27 = 18,100 Kg	39 = 18,350 Kg
28 = 18,250 Kg	40 = 17,950 Kg
29 = 17,900 Kg	41 = 18,000 Kg
30 = 18,150 Kg	42 = 18,025 Kg
31 = 18,100 Kg	43 = 18,250 Kg
32 = 18,075 Kg	44 = 18,175 Kg
33 = 18,450 Kg	45 = 17,875 Kg
34 = 17,975 Kg	46 = 18,250 Kg
35 = 18,450 Kg	47 = 18,475 Kg
36 = 18,350 Kg	48 = 17,950 Kg

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3×10^{-12}	Meter	4'	/	3×10^{-12}
		Fast	2'	/	"
K-2	3×10^{-12}	Meter	2'	/	"
		Fast	"	/	"
PM-1	700V	Alarm			500V
PM-2	1200V	Low	10'	/	900V
		Alarm	2'	/	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT
 RADIATION ALARM: A B C SOURCE NUMBER 7-80

START-UP CHECK LIST

Equipment checked by E.V. [Signature] Personnel check by [Signature]
 Instruments and safeties checked and reset by E.V.
 Source in checked by [Signature] Source No. M-93
 Emergency equipment in control room checked by [Signature]
 Instruments in trip circuit: K-1-2 PM1-2
 Red light on by [Signature] Time 0920
 Start-up OK'd by E.V. [Signature] Date 6-29-73

24

2.050 cm separation c-c.
30 cm length.
130" rods.

4.0" ^{Wet} concrete reflector. see diagram

Have an 19 x 19 array. Total of 196 rods.
Concrete blocks spaced at cell boundary. 250"

1015 Water ht = 43.00 cm

System sub critical
Drain.

Temp °C
#1 = 25.1 °C
#2 = 25.1 °C

Added 4 rods. Have an 19 x 19 + 4 array.
Total 200 rods.

1040 Water ht = 42.50 cm

System sub critical
Drain.

Added 2 rods. Have an 19 x 19 + 2 array.
Total of 202 rods.

$\phi_1 = 4.8 \text{ cm}$

Water ht = 42.00 cm

+ Per

$C = 977.85 \text{ uw} = 1.34 = .27 \text{ f/cm}$

Temp °C
#1 = 25.5 °C
#2 = 25.5 °C

1121 Water ht = ~~36.00~~ 37.20 cm

System just critical
Drain.

7/2/73

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3 x 10 ⁻¹² amp	Meter ✓	9"	✓	3 x 10 ⁻¹²
		Fast ✓	2"	✓	"
K-2	3 x 10 ⁻¹² amp	Meter ✓	9"	✓	"
		Fast ✓	2"	✓	"
PM-1	700V	Alarm ✓	1.5"	✓	500V
PM-2	1200V	Low ✓	10'	✓	900V
		Alarm ✓	2'	✓	1'

LOG IN CALIBRATE OPERATE DUMP WELL PROBE LIGHT
 RADIATION ALARM: A B C SOURCE NUMBER B-60

START-UP CHECK LIST

Equipment checked by E.V. Personnel check by R.K.M.
 Instrument and detector checked and reset by E.V.
 Source checked by R.K.M. Source No. M-43
 Emergency equipment in control room checked by R.K.M.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by R.K.M. Time 0950
 Start-up OK'd by J.F. R.K.M. Date 7-2-73

26

2.050 cm separation c-c.
30 cm length.
130" rad.

Repeat of last run: p - 29

z/h = 6.74 cm

Water ht = 42.10 cm

+ Pr

$t = 395.51 \text{ sec} = 3.4 \text{ f} = .51 \text{ f/cm}$

0926 Water ht = 35.40 cm

System just critical
Drain

Temp °C

#1 = 25.3 °C

2 = 25.3 °C

125

133

14

Now have an 9x23-5 array. Total 202 rods.

1255	Water ht = 42.00 cm	Temp °C
	System sub critical	#1 = 25.2 °C
	Drain.	2 = 25.2 °C

Added 28 rods. Now have an 10x23 array. Total of 230 rods.

1330	Water ht = 42.00 cm	Temp °C
	System sub critical	#1 = 25.1 °C
	Drain.	2 = 25.2 °C

Added 5 rods. Now have an 11x23-18 array. Total of 235 rods.

	24 = 7.5 cm	
	Water ht = 42.00 cm	Temp °C
	2 + 2x	#1 = 25.2 °C
	$\epsilon = 182.53 \text{ sec} = 6.07 \text{ s} = .80 \text{ f/cm}$	2 = 25.2 °C

1418	Water ht = 34.50 cm
	System just critical
	Drain.

over:

Removed 1 rod: Have an 11x23-19 array.
 Total of 239 rods.

Water ht = 42.00 cm
³ - Per

$E_3 - 258.59 \text{ m} = -5.9 \text{ f}$

1437

Drain:

Temp °C

H1 = 25.2 °C

2 = 25.3 °C

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	1"	✓	3x10 ⁻¹²
		Fast ✓	1"	✓	"
K-2	3x10 ⁻¹²	Meter ✓	1"	✓	"
		Fast ✓	1"	✓	"
PM-1	7000 ✓	Alarm ✓	cont	✓	5000 ✓
PM-2	12000 ✓	Low ✓	8"	✓	9000 ✓
		Alarm ✓	cont	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER 0-88

START-UP CHECK LIST

Equipment checked by J.T. Hall Personnel check by J.T. Hall

Instruments and safeties checked and reset by B.K.R.

Source in checked by M-43 Source No. M-43

Emergency equipment in control room checked by B.K.R.

Instruments in trip circuit: K-1-2 PM-1-2

Red light on by B.K.R. Time 0940

Start-up GK'd by D.C. B.K.R. Date 7-3-73

2.050 cm separation c-c
 30 cm length.
 130° rods.

Repeat of last run; now have 8.0" of
 concrete on each face. (see diagram).
 Total of 234 rods.

Water ht = 42.10 cm

1st per

$E = 195.57 \text{ cm} = 6.9 \text{ ft}$

1020 Water ht = 34.60 cm

System just critical
 Drain

Temp °C

#1 = 25.9 °C

#2 = 25.9 °C

Repeat of above:

Water ht = 42.15 cm

2nd per

$E = 212.95 \text{ cm} = 5.3 \text{ ft}$

1259 Water ht = 34.70 cm

System just critical
 Drain

Temp °C

#1 = 25.5 °C

#2 = 25.5 °C

Removed 1 rod; Total of 233 rods.

1310 Water ht = 42.00 cm

3rd per

$E = -321.60 \text{ cm} = -4.6$

Temp °C

#1 = 25.6 °C

#2 = 25.5 °C

Repeat of last run. Now have 12.0" of concrete
on each face. (See diagram).
Total of 233 in.

Water ht = 42.00 cm

Temp °C

t-pr = -

H1 = 25.6 °C

C = -339.99 cm = -4.34

Z = 25.7 °C

1819 Drain

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-2	3×10^{-12}	Meter <input checked="" type="checkbox"/>	1"	<input checked="" type="checkbox"/>	3×10^{-12}
		Fast <input checked="" type="checkbox"/>	1"	<input type="checkbox"/>	"
K-2	3×10^{-12}	Meter <input checked="" type="checkbox"/>	1"	<input checked="" type="checkbox"/>	"
		Fast <input checked="" type="checkbox"/>	1"	<input checked="" type="checkbox"/>	"
PM-1	700v	Alarm <input checked="" type="checkbox"/>	cont	<input type="checkbox"/>	500v
PM-2	1200v	Low <input checked="" type="checkbox"/>	8"	<input type="checkbox"/>	900v
		Alarm <input checked="" type="checkbox"/>	cont	<input checked="" type="checkbox"/>	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT RADIATION ALARM: A B C SOURCE NUMBER 1-2-3

START-UP CHECK LIST

Equipment checked by F. H. C. Personnel check by ATL

Instruments and safeties checked and reset by ATL

Source in checked by ATL Source No. M-4-3

Emergency equipment in control room checked by ATL

Instruments in trip circuit: K-1-2 PM-1-2

Red light on by ATL Time 10:20

Start-up OK'd by ATL Date 7-5-73

2.050 cm separation e-e
30 cm lengths.
.30" rods.

33

Repeat of test run. p-31

Water ht = 42.50 cm

Temp °C

1-Per

#1 = 25.5 °C

$C = -695.36 \text{ sec} = -2.0 f$

2 = 25.5 °C

11:00 Drain:

added 1 rad: Have an 11x23-19 array. Total of
239 rods: 12" concrete reflector. (See diagram.)

Water ht = 42.30 cm

Temp °C

2+Per

#1 = 25.5 °C

$C = 236.86 \text{ sec} = 4.8 f$

2 = 25.5 °C

12:48 Water ht = 35.30 cm

System just critical
Drain.

over.

Now have 16" of concrete reflector. 11x23-19 array. Total of 234 rods. (See diagram.)

Water ht = 42.90 cm

Temp °

3 + Per

3, - Nabeu

#1 = 25.5 °C

$C = 388.97 \text{ m} = 3.14$

nat
with

2 = 25.5 °C

1393 Water ht = 36.10 cm

example.

System just critical
Drain.

Repeat of last run: p-34.

Water ht = 42.90 cm

1 Per

$E = 156.95 \text{ cm} = 6.9 \text{ f}$

Temp °C

#1 = 25.5° C

2 = 25.5° C

0846 Water ht = 34.90 cm

System just critical

Drain:

Repeat of above.

Water ht = 42.90 cm

2 Per

$E = 156.95 \text{ cm} = 6.9 \text{ f}$

Temp °C

#1 = 25.5° C

2 = 25.5° C

0902 Water ht = 34.90 cm

System just critical

Drain:

Removed load: Total of 233 rods:

Water ht = 43.00 cm

3 Per

$E = 484.58 \text{ cm} = -2.9 \text{ f}$

Temp °C

#1 = 25.5° C

2 = 25.5° C

Now have 12.0" concrete reflector. and a total of 239 rods.

Water ht = 42.20 cm
4 + Per

$$C = 247.72 \text{ sec} = 4.6 \text{ f}$$

Water ht = 34.80 cm

System just critical
Drain.

Temp °C

$$\#1 = 25.6^\circ\text{C}$$

$$2 = 25.6^\circ\text{C}$$

Now have 8.0" concrete reflector. and a total of 239 rods.

Water ht = 42.10 cm
5 + Per

$$C = 256.91 \text{ sec} = 4.5 \text{ f}$$

Water ht = 35.60 cm

System just critical
Drain.

Temp °C

$$\#1 = 25.6^\circ\text{C}$$

$$2 = 25.6^\circ\text{C}$$

Repeat of above:

Water ht = 42.40 cm
6 + Per

$$C = 271.62 \text{ sec} = 4.3 \text{ f}$$

Water ht = 35.60 cm

System just critical
Drain

Temp °C

$$\#1 = 25.6^\circ\text{C}$$

$$2 = 25.6^\circ\text{C}$$

and,

Now have 4.0" concrete reflector, and a total of 235 rods.

Water ht = 42.20 cm

+ Per

$E = 167.32 \text{ m} = 6.5 \text{ f}$

Temp °C

#1 = 25.6 °C

2 = 25.6 °C

11:12 Water ht = 34.60 cm

System just critical
Drain

Removed 1 rod. Total number of rods = 234
4.0" concrete reflector.

Water ht = 42.20 cm

⁸ - Per

$E = -291.18 \text{ m} = -5.2 \text{ f}$

Temp °C

#1 = 25.6 °C

2 = 25.6 °C

11:26 Drain

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter	4"	✓	3 x 10 ⁻¹²
		Fast	3"	✓	"
K-2	"	Meter	3 1/2"	✓	"
		Fast	2"	✓	"
PM-1	700v	Alarm	1/2	✓	500v
PM-2	1200v	Low	12	✓	900v
		Alarm	1	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER B-80

START-UP CHECK LIST

Equipment checked by ERR Personnel check by RKL

Instruments and safeties checked and reset by RKL

Source in checked by RKL Source No. M-93

Emergency equipment in control room checked by RKL

Instruments in trip circuit: K-1-2 PM1-2

Red light on by RKL Time 0810

Start-up OK'd by J.F.L. RKL Date 7-10-73

40

2.050 cm separation c.c.
30 cm length.
.30" rods.

4.0" concrete reflector on 4 sides.
Have on 23 X 23 array, with the 11, 12, 13 row
removed in 2 directions. Total of 400 rods.

0840 Water ht = 42.00 cm
System sub critical
Chain.

Temp °C
#1 = ~~25.5~~ 25.5
2 = 25.5 °C

Same array as above: Now have 16.0"
concrete reflector.

1023 Water ht = 42.30 cm
System sub critical
Chain.

Temp °C
#1 = 25.5 °C
2 = 25.5 °C

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	10×10^{-12}	Meter ✓	.5"	✓	3×10^{-12}
		Fast ✓	cont	✓	"
K-2	10×10^{-12}	Meter ✓	.5"	✓	"
		Fast ✓	cont	✓	"
PM-1	700v	Alarm ✓	.5"	✓	500v
PM-2	1200v	Low ✓	10"	✓	900v
		Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER B-80

START-UP CHECK LIST

Equipment checked by J.T. Personnel check by J.T.

Instruments and safeties checked and reset by ARK

Source in checked by J.T. Source No. M-93

Emergency equipment in control room checked by ARK

Instruments in trip circuit: K-1-2 PM1-2

Red light on by ARK Time 1910

Start-up OK'd by J.T. - ARK Date 7-11-72

2,050 cm separation e-c.
 30 cm length.
 .30" rod.

Now have an 23×23 array, with the
 4th, 8th, 12th, 16th, & 20th now removed
 in 2 directions. Total of 324 rods.
 Have 16.0" concrete reflector on 4 faces.

1450 Water ht = 42.30 cm
 System sub critical
 Drain.

Temp °C
 #1 = 25.3 °C
 2 = 25.3 °C

Now have an 23×23 array, with the 3rd, 6th,
 9th, 12th, 15th, 18th & 21st now removed in
 2 directions. Total of 256 rods. 16.0" concrete
 reflector on 4 faces.

1535 Water ht = 42.30 cm
 System sub critical
 Drain.

Temp °C
 #1 = 25.3 °C
 2 = 25.3 °C

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	3x10 ⁻¹²
		Fast ✓	1"	✓	"
K-2	3x10 ⁻¹²	Meter ✓	4"	✓	"
		Fast ✓	1"	✓	"
PM-1	700V	Alarm ✓	1/2"	✓	500V
PM-2	1200V	Low ✓	10"	✓	900V
		Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER B-7

START-UP CHECK LIST

Equipment checked by JRT-~~PKR~~-IDC Personnel check by IDC

Instruments and safeties checked and reset by JRT

Source in checked by JRT Source No. M-43

Emergency equipment in control room checked by JRT

Instruments in trip circuit: K1-2 PM1-2

Red light on by IDC Time 10:20

Start-up OK'd by JRT ^{F.I.D.C.} PKR Date 12 JULY 73

44

2.050 cm separation c.c.
 30 cm length.
 30" rods.

Have an 20×17 array, with the 7th & 14th row removed in 2 directions. Total number of rods = 270 rods. 16.0" concrete reflector.

11:10 Water ht = 42.20 cm
 System sub critical
 Drain.

Temp °C
 #1 = 25.1 °C
 2 = 25.1 °C

added 4 rods. Now have an 20×18 array with 14 rods removed from 18th row. Have the 7th & 14th row removed in 2 directions. Total number of rods = 274.

1303 Water ht = 42.20 cm
 System sub critical
 Drain

Temp °C
 #1 = 25.5 °C
 2 = 25.5 °C

added 2 rods. Now have an 20x18 array
with 10 rods removed from 18th row.
Have also 7th & 19th row removed in
2 directions. Total of 278 rods.

Water ht = 42.10 cm

1 + Per

$$C = 130.38 \text{ cm} = 8.0 \text{ f}$$

1340 Water ht = 34.05 cm

System just critical

Drain.

Temp °C

#1 = 25.6 °C

2 = 25.6 °C

Removed 1 rod from 18th row. Total of 277 rods.

1355 Water ht = 42.30 cm

System just critical

Drain.

Temp °C

#1 = 25.6 °C

2 = 25.6 °C

Removed 1 rod from 18th row. Total of 276 rods.

Water ht = 42.30 cm

2-Per

$$C = -191.22 \text{ cm} = -8.6 \text{ f}$$

1410 Drain

Temp °C

#1 = 25.6 °C

2 = 25.6 °C

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3×10^{-12}	Meter ✓	9"	✓	3×10^{-12}
		Fast ✓	2"	✓	"
K-2	3×10^{-12}	Meter ✓	9"	✓	"
		Fast ✓	2"	✓	"
PM-1	7000	Alarm ✓	15"	✓	5000
PM-2	12000	Low ✓	10"	✓	9000
		Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE BUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER B-80

START-UP CHECK LIST

Equipment checked by F.D.C. Personnel check by F.D.C.

Instruments and safeties checked and reset by R.K.M.

Source in checked by R.K.M. Source No. M-97

Emergency equipment in control room checked by F.D.C.

Instruments in trip circuit: K-1-2 PM-1-2

Red light on by R.K.M. Time 1910

Start-up OK'd by F.D.C., R.K.M. Date 7-13-73

leave an 22×21 array, with etc. 11th & 12th rows removed in 2 directions. Total of 364 rods (see diagram). 16.0" concrete reflector.

Water ht = 42.80 cm

Temp $^{\circ}$

7 per $C = 47.81 \text{ m} = 16.9 \text{ f}$

$T_1 = 25.6^{\circ}$

Water ht = 32.60 cm. just critical

$T = 25.1^{\circ}$

15:00 Drain

Removed 7 rods: Total of 362 rods. (see diagram).

Water ht: 42.20 cm

Temp $^{\circ}$

27 per

$T_1 = 25.6^{\circ}$

$C = 223.82 \text{ m} = 5.1 \text{ f}$

$T = 25.6^{\circ}$

Water ht = 34.90 cm

Systems just critical
Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	3x10 ⁻¹²
		Fast ✓	2"	✓	"
K-2	3x10 ⁻¹²	Meter ✓	4"	✓	"
		Fast ✓	2"	✓	"
PM-1	7000 ✓	Alarm ✓	15"	✓	5000
PM-2	12000 ✓	Low ✓	10"	✓	9000
		Alarm ✓	1"	✓	"

LOG-N CALIBRATE OPERATE DUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER B-80

START-UP CHECK LIST

Equipment checked by I.D.C. AKK Personnel check by F.P.C.

Instruments and safeties checked and reset by AKK

Source in checked by AKK Source No. M-43

Emergency equipment in control room checked by F.P.C.

Instruments in trip circuit: K-1-2 PM-2

Red light on by AKK Time 0855

Start-up OK'd by I.D.C. AKK Date 7-17-73

100
0

19
0

Reprot of lat men (p-47).

Water ht = 42.90 cm
+ Per

$T = 221.65 \text{ sec} = 5.1 \text{ f}$

Temp °

#1 = 25.0 °

#2 = 25.0 °

1008

Water ht = 35.00 cm

System just critical
Drain.

Same array as above: added 4.0" of
concrete. Now have a total of 20.0" of
concrete blocks. Total of 362 rods.

Water ht = 42.20 cm
+ Per

$T = 319.43 \text{ sec} = 3.7 \text{ f}$

Temp °

#1 = 25.2 °

#2 = 25.4 °

1410

Water ht = 35.50 cm

System just critical
Drain.

over.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3×10^{-12}	Meter ✓	9"	✓	3×10^{-2}
		Fast ✓	2"	✓	"
K-2	3×10^{-12}	Meter ✓	9"	✓	"
		Fast ✓	2"	✓	"
PM-1	700V	Alarm ✓	5"	✓	500V
PM-2	1200V	Low ✓	10"	✓	900V
		Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER B-8C

START-UP CHECK LIST

Equipment checked by AKM Personnel check by F.P.C.

Instruments and safeties checked and reset by AKM

Source in checked by AKM Source No. 19-93

Emergency equipment in control room checked by F.P.C.

Instruments in trip circuit: K-1-2 PM-1-2

Red light on by AKM Time 0855

Start-up OK'd by F.P.C., AKM Date 7-18-73

Repeat of last run (p - 49)

Water ht = 42.20 cm

1 - Run

$C = 375.93 \text{ mm} = 3.2 \text{ f}$

Temp °C

#1 = 25.0 °C

2 = 25.0 °C

10 19

Water ht = 35.60 cm

System just critical

Drain.

Removed 1 rad; total of 361 rods.

Water ht = 43.20 cm

2 - Run

$C = -291.18 \text{ mm} = -5.2 \text{ f}$

Temp °C

#1 = 25.2 °C

2 = 25.2 °C

10 40

Drain.

Repeat of run top of (P-51) Total of 362 rods

Water ht = 42.30 cm
3 + Per

$$C = 310.74 \text{ cm} = 3.8 \phi$$

Temp °C
#1 = 25.2 °C
2 = 25.6 °C

1339 Water ht = 35.60 cm
system just critical
Drain.

Some array as above: Now have 16.0" thick concrete reflector: (70 instruments have not been moved, same position as last run with 20.0" thick reflector. Instruments on lying horiz on the last row of blocks.)

Water ht = 42.30 cm
4 + Per

$$C = 305.06 \text{ cm} = 3.3 \phi$$

Temp °C
#1 = 25.2 °C
2 = 25.2 °C

1438 Water ht = 35.90 cm
system just critical
Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3×10^{-12}	Meter <input checked="" type="checkbox"/>	4"	<input checked="" type="checkbox"/>	3×10^{-12}
		Fast <input checked="" type="checkbox"/>	2"	<input checked="" type="checkbox"/>	"
K-2	3×10^{-12}	Meter <input checked="" type="checkbox"/>	4"	<input checked="" type="checkbox"/>	"
		Fast <input checked="" type="checkbox"/>	2"	<input checked="" type="checkbox"/>	"
PM-1	7000	Alarm <input checked="" type="checkbox"/>	.5"	<input checked="" type="checkbox"/>	5000
PM-2	12000	Low <input checked="" type="checkbox"/>	10"	<input checked="" type="checkbox"/>	9000
		Alarm <input checked="" type="checkbox"/>	1"	<input checked="" type="checkbox"/>	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER D-80

START-UP CHECK LIST

Equipment checked by ^{I.D.C} AKH Personnel check by F.D.C

Instruments and safeties checked and reset by AKH

Source in checked by AKH Source No. M-93

Emergency equipment in control room checked by F.D.C

Instruments in trip circuit: K-1-2 PM-1-2

Red light on by AKH Time 1240

Start-up OK'd by F.D.C AKH Date 7-19-73

Repeat of last run: Now have interments mounted in box for slave array, see photo.

Water ht = 42.20 cm

Temp °C

+Per

#1 = 25.2 °C


$E = 349.85 \mu W = 3.4 \mu$

#2 = 25.2 °C

1335 Water ht = 35.80 cm

system just critical

Drain



INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	3x10 ⁻¹²
		Fast ✓	2"	✓	"
K-2	3x10 ⁻¹²	Meter ✓	4"	✓	"
		Fast ✓	2"	✓	"
PM-1	7000	Alarm ✓	5"	✓	5000
PM-2	12000	Low ✓	10"	✓	9000
		Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER B-93

START-UP CHECK LIST

Equipment checked by I.P.C. Personnel check by I.P.C.
 Instruments and safeties checked and reset by AKL
 Source in checked by AKL Source No. M-93
 Emergency equipment in control room checked by I.P.C.
 Instruments in trip circuit: K-1-2 AM-2
 Red light on by AKL Time 0900
 Start-up OK'd by I.P.C. AKL Date 7-20-73

Same array as described on p - 47.
 Total of 362 rods: 20.0" of concrete. Instruments
 as shown of p - 54, 12

Water ht = 42.50 cm

Temp °C

+ Per

#1 = 25.2 °C

$C = 384.62 \text{ sec} = 3.1 f$

2 = 25.2 °C

1005 Water ht = 35.80 cm

System just critical
 Drain.

Moved the 2 rods in ~~7th~~ 21st row, 1 hole
 from the digress. 2nd

Water ht = 42.30 cm

Temp °C

+ Per

#1 = 25.2 °C

$C = 1021.31 \text{ sec} = 1.2 f$

2 = 25.2 °C

1340 Water ht = 37.90 cm

System just critical
 Drain.

Moved the 2 rods in the 21st row 1 more hole for
the digram. 3rd

Water ht = 42,20 cm

3 + Per

$E = 1608.00 \text{ cm} = 0.80$

Temp °C

#1 = 25.2 °C

#2 = 25.2 °C

1417 Water ht = 39,00 cm
System just critical
Drain.

Moved the 2 rods in the 21st row 1 more hole for
the digram. 4th

Water ht = 42,20 cm

4 + Per

$E = 1803.59 \text{ cm} = 0.71 \phi$

Temp °C

#1 = 25.2 °C

#2 = 25.2 °C

Water ht = 39,70 cm
System just critical
Drain.

Moved the 2 rods in the 21st row 1 more hole for
the digram. 5th

Water ht = 42,50 cm

5 + Per

$E = -4346.00 \text{ cm} = -0.31 \phi$

1526 Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	7"	✓	3x10 ⁻¹²
		Fast ✓	2"	✓	"
K-2	3x10 ⁻¹²	Meter ✓	7"	✓	"
		Fast ✓	2"	✓	"
PM-1	700V 5000	Alarm ✓	15"	✓	500V 700V
		Low ✓	10"	✓	900V
PM-2	1200V	Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER P-80

START-UP CHECK LIST

Equipment checked by F.I.C. Personnel check by F.I.C.

Instruments and safeties checked and reset by A.K.L.

Source in checked by A.K.L. Source No. M-43

Emergency equipment in control room checked by F.I.C.

Instruments in trip circuit: K-1-2 PM1-2

Red light on by A.K.L. Time 0900

Start-up OK'd by F.I.C. A.K.L. Date 7-23-73

Moved the 2 rods in the 21st row. 1 more hole for
see diagram. 6th

Water ht = 42.90 cm

¹-Per

$C = -1441.80 \text{ sec} = -0.93 \text{ f}$

1010 Drain

Temp °C

#1 = 25.2 °C

2 = 25.2 °C

Moved the 2 rods in the 21st row 1 more hole for.
see diagram. 7th

Water ht = 42.30 cm

²-Per

$C = -608.44 \text{ sec} = -2.3 \text{ f}$

1028 Drain

Temp °C

#1 = 25.2 °C

2 = 25.2 °C

Moved the 2 rods in the 21st row 1 more hole for.
see diagram. 8th

Water ht = 42.00 cm

³-Per

$C = -347.68 \text{ sec} = -4.2 \text{ f}$

1253 Drain

Temp °C

#1 = 25.2 °C

2 = 25.2 °C

over!

Moved the 2 rods in the 21st new 1 more hole for
see diagram. 1st

Water ht = 42.80 cm	Temp °C
4-Per	#1 = 25.5 °C
$C = -245.55 \text{ cm} = -6.3 \text{ f}$	2 = 25.5 °C

1310 Drain

Moved the 2 rods in the 21st new 1 more hole for.
see diagram. 10th

Water ht = 42.20 cm	Temp °C
5-Per	#1 = 25.5 °C
$C = -228.16 \text{ cm} = -6.9 \text{ f}$	2 = 25.5 °C

1320 Drain

Rods replaced in original pos. see p 47-54 &
56.

Water ht = 42.20 cm	Temp °C
6-Per	#1 = 25.5 °C
$C = -354.20 \text{ cm} = 3.0 \text{ f}$	2 = 25.5 °C

1500 Water ht = 35.80 cm
System just critical
Drain

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	3x10 ⁻¹²
		Fast ✓	2"	✓	"
K-2	3x10 ⁻¹²	Meter ✓	4"	✓	"
		Fast ✓	2"	✓	"
PM-1	700V	Alarm ✓	15"	✓	500V
PM-2	1200V	Low ✓	10"	✓	900V
		Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER M-43

START-UP CHECK LIST

Equipment checked by F.D.C. Personnel check by F.D.C.

Instruments and safeties checked and reset by ATML

Source in checked by ATML Source No. M-43

Emergency equipment in control room checked by F.D.C.

Instruments in trip circuit: K-1-2 PM1-2

Red light on by ATML Time 0925

Start-up OK'd by F.D.C. ATML Date 7-25-73

Removed 1 rod in 21st row. Total of 361 rods.
20.0" concrete refelute. Same array as
described on p-47.

Water ht = 42.20 cm

1-Per

$$C = 341.16 \text{ mm} = -4.3$$

Temp °C

$$\#1 = 25.2^\circ\text{C}$$

$$2 = 25.2^\circ\text{C}$$

1033

Drain.

Added 1 rod. Total of 362 rods. Same array
as above. Removed 4.0" of concrete. Total
thickness now = 16.0"

Water ht = 42.20 cm

2+Per

$$C = 380.27 \text{ mm} = 3.1 \text{ f}$$

Temp °C

$$\#1 = 25.2^\circ\text{C}$$

$$2 = 25.2^\circ\text{C}$$

1118

Water ht = 35.85 cm

System just critical
Drain.

13

15

Removed 1 rod. Total of 361 rods. 16.0" concrete self.

Water ht = 42.30 cm
³-Per

$$C = -310.79 \text{ new} = -4.8 \phi$$

Drain.

Temp °C

$$\#1 = 25.2^\circ \text{C}$$

$$2 = 25.2^\circ \text{C}$$

added 1 rod. Total of 362 rods. Removed 4.0" of concrete. Total thickness now = 12.0"

Water ht = 42.50 cm
⁴-Per

$$C = 367.23 \text{ new} = 3.2 \phi$$

1356 Water ht = 35.80 cm

system just critical
 Drain.

Temp °C

$$\#1 = 25.2^\circ \text{C}$$

$$2 = 25.2^\circ \text{C}$$

Removed 1 rod. Total of 361 rods. 12.0" concrete self.

Water ht = 42.20 cm
⁵-Per

$$C = -315.08 = -4.7 \phi$$

1432 Drain

Temp °C

$$\#1 = 25.2^\circ \text{C}$$

$$2 = 25.2^\circ \text{C}$$

added 1 rod. Total of 362 rods. Removed 4.0"
of concrete. Total thickness now = 8.0"

Water ht = 42.20 cm

6-Per

$T = 412.87 \text{ sec} = 2.9 \text{ f}$

1514 Water ht = 36.00 cm

system just critical
Drain

Temp °C

#1 = 25.5 °C

2 = 25.5 °C

Removed 1 rod. Total of 361 rods. 8.0" concrete left.

Water ht = 42.20 cm

7-Per

$T = -349.85 \text{ sec} = -4.2 \text{ f}$

1526 Drain

Temp °C

#1 = 25.5 °C

2 = 25.5 °C

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	3x10 ⁻¹²
		Fast ✓	2"	✓	"
K-2	"	Meter ✓	4"	✓	"
		Fast ✓	2"	✓	"
PM-1	700 ✓	Alarm ✓	5"	✓	500 ✓
PM-2	1200 ✓	Low ✓	10"	✓	900 ✓
		Alarm ✓	2"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER B-80

START-UP CHECK LIST

Equipment checked by F.P.C. [Signature] Personnel check by F.P.C.

Instruments and safeties checked and reset by [Signature]

Source in checked by [Signature] Source No. M-93

Emergency equipment in control room checked by F.P.C.

Instruments in trip circuit: K-1-2 PM1-2

Red light on by [Signature] Time 0915

Start-up OK'd by F.P.C. [Signature] Date 7-26-73

added 1 rod. Total of 362 rods. Remained 4.0"
of concrete. Total thickness now = 4.0"

Water ht = 42.20 cm

¹-Per

$$E = -321.60 \text{ sec} = -4.6 f$$

Temp °C

$$\#1 = 25.2^\circ \text{C}$$

$$\#2 = 25.2^\circ \text{C}$$

added 1 rod. Total of 363 rods.

Water ht = 42.20 cm

²+Per

$$E = 908.31 \text{ sec} = 1.4 f$$

Temp °C

$$\#1 = 25.2^\circ \text{C}$$

$$\#2 = 25.2^\circ \text{C}$$

1038

Water ht = 35.90 cm

System just critical
Drain.

Now have an 17x17 array, with the 9th row removed in 2 directions. Have 11 rods removed from 1 face. Have 4.0" concrete reflector. See diagram. Total of 295 rods

Water ht = 42.20 cm
³-Per
 N.G.
 1500 Drain

Temp °C
 #1 = 25.5 °C
 2 = 25.5 °C

added 3 rods. Total of 298 rods. 4.0 concrete refl.

Water ht = 42.20 cm
⁴-Per
 $t = 99.96 \text{ sec} = 9.9 \text{ d}$
 1532 Water ht = 33.70 cm
 system just critical
 Drain.

Temp °C
 #1 = 25.7 °C
 2 = 25.7 °C

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	3x10 ⁻¹²
		Fast ✓	2"	✓	"
K-2	3x10 ⁻¹²	Meter ✓	4"	✓	"
		Fast ✓	2"	✓	"
PM-1	700 ⁵	Alarm ✓	15"	✓	500 ⁵
PM-2	1200 ⁵	Low ✓	10"	✓	900 ⁵
		Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT
 RADIATION ALARM: A B C SOURCE NUMBER B-80

START-UP CHECK LIST

Equipment checked by E.V.C. Personnel check by E.V.C.
 Instruments and safeties checked and reset by AKAB
 Source in-checked by AKAB Source No. M-93
 Emergency equipment in control room checked by E.V.C.
 Instruments in trip circuit: K-1-2 PM1-2
 Red light on by AKAB Time 0500
 Start-up OK'd by E.V.C., AKAB Date 7-27-73

10

11

Remained 1 rad. Total of 247 rods. 4.0" concrete self.

Water ht = 42.20 cm

Temp °C

1-per

#1 = 25.2 °C

$E = -999.58 \text{ sec} = -1.3 \text{ f}$

2 = 25.2 °C

0851 Drain:

Same array on slope. but have moved array so that 2 faces are now at the cell ~~boundary~~ boundary. see diagram. Total of 249 rods. 4.0" concrete self.

Water ht = 42.20 cm

Temp °C

2-per

#1 = 25.2 °C

$E = -212.95 \text{ sec} = -7.5 \text{ f}$

2 = 25.2 °C

1059 Drain:

Added 1 rad. Total of 245 rods:

Water ht = 42.20 cm

Temp °C

3-per

#1 = 25.2 °C

$E = 760.55 \text{ sec} = 1.6 \text{ f}$

2 = 25.2 °C

Water ht = 37.70 cm

system just critical

1120

Drain.

avg. -

Added 4.0" of concrete: Total thickness = 8.0"
Total of 245 rods.

Water ht = 42.20 cm
4-Per

$$C = -121.69 \text{ mm} = -9.5 \text{ f}$$

Water ht = 33.60 cm

System just critical

1318 Drain.

Temp °C

$$\#1 = 25.8^\circ \text{C}$$

$$2 = 25.3^\circ \text{C}$$

Removed 1 rod. Total of 244 rods. 8.0" concrete self.

Water ht = 42.20 cm
5-Per

$$C = -825.74 \text{ mm} = -1.7 \text{ f}$$

1336 Drain

Temp °C

$$\#1 = 25.5^\circ \text{C}$$

$$2 = 25.5^\circ \text{C}$$

Added 4.0" of concrete: Total thickness = 12.0"
Total of 249 rods.

Water ht = 42.20 cm
6-Per

$$C = -808.35 \text{ mm} = -1.7$$

1408 Drain.

Temp °C

$$\#1 = 25.5^\circ \text{C}$$

$$2 = 25.5^\circ \text{C}$$

added 1 rad. Total of 245 rads. 12.0" concrete self.

Water ht = 42.20 cm
7 + Per

$$C = 113.0 \text{ sec} = 9.04$$

$$\text{Water ht} = 33.75 \text{ cm}$$

System just critical

1432 Drain

Temp °C

$$\#1 = 25.6^\circ\text{C}$$

$$2 = 25.6^\circ\text{C}$$

added 4.0" of concrete. Total thickness = 16.0"
Total of 245 rads.

Water ht = 42.20 cm

$$8 + \text{Per } C = 108.65 \text{ sec} = 9.34$$

$$\text{Water ht} = 33.80 \text{ cm}$$

System just critical

1506 Drain

Temp °C

$$\#1 = 25.6^\circ\text{C}$$

$$2 = 25.6^\circ\text{C}$$

Remained 1 rad. Total of 244 rads. 16.0" concrete self.

Water ht = 42.20 cm

9 Per

$$C = -2477.22 \text{ sec} = -0.534$$

1525 Drain

Temp °C

$$\#1 = 25.6^\circ\text{C}$$

$$2 = 25.6^\circ\text{C}$$

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3×10^{-12}	Meter ✓	4"	✓	3×10^{-12}
		Fast ✓	2"	✓	"
K-2	3×10^{-12}	Meter ✓	4"	✓	"
		Fast ✓	2"	✓	"
PM-1	700 ✓	Alarm ✓	.5"	✓	500 ✓
PM-2	1200 ✓	Low ✓	10"	✓	900 ✓
		Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER B-80

START-UP CHECK LIST

Equipment checked by ^{F.D.C.} AKM Personnel check by F.D.C.

Instruments and safeties checked and reset by AKM

Source in checked by AKM Source No. 19-43

Emergency equipment in control room checked by F.D.C.

Instruments in trip circuit: K-1-2 PM1-2

Red light on by AKM Time 0800

Start-up OK'd by F.D.C. AKM Date 7-31-73

Added 4.0" of concrete. Total thickness = 20.0"
Total of 244 rods.

Water ht = 42.20 cm
System just critical
Drain:

Temp °C
#1 = 25.2°C
2 = 25.2°C

Removed 1 rod. Total of 243 rods: 20.0" concrete ref.

Water ht = 42.20 cm
1 - Per
 $E = -167.32 \text{ sec} = -10.4 \phi$
Drain:

Temp °C
#1 = 25.2°C
2 = 25.2°C

Added 2 rods: Total of 245 rods: 20.0" concrete ref.

Water ht = 42.20 cm
2 + Per
 $E = 108.65 \text{ sec} = 9.3 \phi$
Water ht = 33.40 cm
System just critical
Drain:

Temp °C
#1 = 25.2°C
2 = 25.2°C

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3×10^{-12}	Meter ✓	4"	✓	3×10^{-12}
		Fast ✓	2"	✓	"
K-2	3×10^{-12}	Meter ✓	4"	✓	"
		Fast ✓	1"	✓	"
PM-1	700V	Alarm ✓	15"	✓	500V
PM-2	1200V	Low ✓	19"	✓	900V
		Alarm ✓	2"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT RADIATION ALARM: A B C SOURCE NUMBER B-73

START-UP CHECK LIST

Equipment checked by F.V.C. Personnel check by F.V.C.Instruments and safeties checked and reset by ARKLSource in checked by ARKL Source No. 19-43Emergency equipment in control room checked by F.V.C.Instruments in trip circuit: K-1-2 PM-1-2Red light on by ARKL Time 10:10Start-up OK'd by F.V.C. ARKL Date 8-8-73

Have on 14 x 14 + 7 array. Total of 203 rods.
 H_2O reflector only.

Water ht = 47.20 cm

1 + Per

$$E = 78.13 \text{ sec} = 11.9 f$$

Water ht = 33.30 cm

System just critical

1100 Drain

Temp °C

$$H1 = 25.5^\circ C$$

$$2 = 25.5^\circ C$$

Removed 1 rod. Total of 202 rods.

Water ht = 47.20 cm

2 - Per

$$E = -332.46 \text{ sec} = -4.7 f$$

1320 Drain

Temp °C

$$H1 = 25.5^\circ C$$

$$2 = 25.5^\circ C$$

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	2×10^{-12}	Meter ✓	9"	✓	3×10^{-12}
		Fast ✓	2"	✓	"
K-2	3×10^{-12}	Meter ✓	9"	✓	"
		Fast ✓	1"	✓	"
PM-1	700V	Alarm ✓	.5"	✓	500V
PM-2	1200V	Low ✓	14"	✓	900V
		Alarm ✓	1"	✓	"

LOG N CALIBRATE ✓ OPERATE ✓ DUMP WELL PROBE LIGHT

RADIATION ALARM A ✓ B ✓ C ✓ SOURCE NUMBER B-80

START-UP CHECK LIST

Equipment checked by ^{F.I.C.} AKM Personnel check by F.I.C.Instruments and safeties checked and reset by AKMSource in checked by AKM Source No. M-93Emergency equipment in control room checked by F.I.C.Instruments in trip circuit: K-1-2 PM1-2Red light on by A.K.M. Time 1405Start-up OK'd by F.I.C. AKM Date 8-9-73

Have an 14 x 14 - 2 array. Total of 194 rods.
4.0" concrete block reflector. (Concrete block
encased in plexiglas, avg thickness = .116")
Blocks spaced .100" + thickness of plexiglas.
su p - 9

Water ht = 42.20 cm
1 + Per

$$C = 65.19 \text{ su} = 13.6 f$$

Water ht = 33.05 cm

System just critical

1455

Drain.

Temp °C

$$T_1 = 25.5^\circ \text{C}$$

$$T_2 = 25.5^\circ \text{C}$$

Removed 1 rod. Total of 193 rods.

Water ht = 42.20 cm.

2 + Per

$$C = 749.68 \text{ su} = 1.7 f$$

Water ht = 36.60 cm

System just critical

1533

Drain.

Temp °C

$$T_1 = 25.5^\circ \text{C}$$

$$T_2 = 25.5^\circ \text{C}$$

Removed 1 rod. Total of 192 rods.

Water ht = 42.20 cm

3 + Per

$$C = -165.15 \text{ su} = -10.6 f$$

Drain.

1546

Temp °C

$$T_1 = 25.5^\circ \text{C}$$

$$T_2 = 25.5^\circ \text{C}$$

78

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	3x10 ⁻¹²
		Fast ✓	2"	✓	"
K-2	3x10 ⁻¹²	Meter ✓	4"	✓	"
		Fast ✓	2"	✓	"
PM-1	7005	Alarm ✓	5"	✓	5005
PM-2	12005	Low ✓	12"	✓	9005
		Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER 75-80

START-UP CHECK LIST

Equipment checked by ^{I.D.C.} AKL Personnel check by AKL

Instruments and safeties checked and reset by AKL

Source in checked by AKL Source No. M-93

Emergency equipment in control room checked by F.P.C.

Instruments in trip circuit: K-1-2 PM-1-2

Red light on by AKL Time 0930

Start-up OK'd by I.D.C. AKL Date 11-1-73

H_2O Feed rate = 5.4 cm/min
 3" Drain rate = 23.0 cm/min
 3" dump rate = 27.0 cm/min.

2.050 cm separation c-c.
 30 cm length.
 .30" rods.

I have an $14 \times 14 - 3$ array. Total of 193 rods.
 4.0" concrete block reflector on 2 opposite
 faces. (concrete blocks encased in plexiglas,
 avg thickness = .116") Blocks are in contact.

1047 Water ht = 42.3 cm Temp °C
 system sub critical $H_1 = 25.0^\circ$
 Drain $T = 25.0^\circ$

added 3 rods. Now have an full 14×14 array.
 Total of 196 rods.

1307 Water ht = 42.6 cm Temp °C
 system sub critical $H_1 = 25.0^\circ$
 Drain $T = 25.0^\circ$

over.

Added 3 rods. Now have an 19x19 + 3 array. Total of 199 rods.

Water ht = ~~42.3~~ 42.3 cm
 - Per
 $C = -226.0 \text{ m} = -7.0 \text{ f}$

Temp °C
~~25.3~~
 $\bar{x} =$
 $\#1 = 25.3 \text{ °C}$
 $\#2 = 25.3 \text{ °C}$

1991 Drain

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3×10^{-12}	Meter ✓	4"	✓	3×10^{-12}
		Fast ✓	2"	✓	"
K-2	3×10^{-12}	Meter ✓	4"	✓	"
		Fast ✓	2"	✓	"
PM-1	900 ✓	Alarm ✓	5"	✓	500 ✓
PM-2	1200 ✓	Low ✓	12"	✓	900 ✓
		Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER B-80


START-UP CHECK LIST

Equipment checked by I.P.C. Personnel check by AKM
 Instruments and safeties checked and reset by AKM
 Source in checked by AKM Source No. M-93
 Emergency equipment in control room checked by I.P.C.
 Instruments in trip circuit: K-1-2 P.M-1-2
 Red light on by AKM Time 0805
 Start-up OK'd by I.P.C. AKM Date 11-2-73

900


added 1 rod. Now have an 14.
 Total of 200 rods.

Water ht = 42.20 cm
 + Per
 $C = 78.2 \text{ sec} = 11.9 \text{ f}$



0900 Water ht = 33.30 cm
 system just critical
 Drain.

added 4.0" of concrete
 thickness = 8.0". to 10 4
 an 14 x 14 + 3-assy



Water ht = 42.80 cm
 + Per
 $C = 378.1 \text{ sec} = 3.2 \text{ f}$

Temp c
 $H1 = 25.0^{\circ}$
 $2 = 25.0^{\circ}$

0943 Water ht = 36.0 cm
 system just critical
 Drain.

ass:

START-UP CHECK LIST

Equipment checked by I.D.C. AKE Personnel check by AKM

Instruments and safeties checked and reset by AKM

Source in checked by AKM Source No. M-93

Emergency equipment in control room checked

Instruments in trip circuit: K-1-2 P

Red light on by AKM Time

Start-up OK'd by I.D.C. AKM Date

18-1-94 log
 0900 for 200 rods
 14x14 + 4
 61 - 4 rods removed
 (check in control)

added 1 rod. Now have an 14x14 + 4 array.
 Total of 200 rods.


Water ht = 42.20 cm
 + Per

Temp °C
 #1 = 25.0°C
 #2 = 25.0°C

$C = 78.2 \text{ m} = 11.9 f$

0900 Water ht = 33.30 cm
 System just critical
 Drain.

added 4.0" of concrete
 thickness = 8.0". to 10 4
 an 14x14 + 3 array



Water ht = 42.80 cm
 + Per

Temp °C
 #1 = 25.0°C
 #2 = 25.0°C

$C = 378.1 \text{ m} = 3.2 f$

0943 Water ht = 36.0 cm
 System just critical
 Drain.

and:

START-UP CHECK LIST

Equipment checked by FID.C. AMK Personnel check by AMK

Instruments and safeties checked and reset by AMK

Source in checked by AMK Source No. M-93

Emergency equipment in control room checked

Instruments in trip circuit: K-1-2-6

Red light on by AMK Time

Start-up OK'd by FID.C. AMK Date

Block in contact
 Beam pos on p-19
 14x14+3 array
 Total of 200 rods
 Log # 6-p-81

added 1 rod. Now have an 14x14+4 array.
 Total of 200 rods.

Water ht = 42.20 cm
 + Per

$C = 78.2 \text{ m} = 11.9 \text{ f}$

0900 Water ht = 33.30 cm

system just critical
 Drain.

Block in contact, same
 pos on p-19
 14x14+3 array, total of
 199 rods.

Log # 6-p-81

5.0°C

5.0°C

added 4.0" of concrete to 2 faces: total
 thickness = 8.0". Removed 1 rod. Now
 an 14x14+3 array. Total of 199 rods.

Water ht = 42.40 cm
 + Per

$C = 378.1 \text{ m} = 3.2 \text{ f}$

0943 Water ht = 36.0 cm

system just critical
 Drain.

Temp °C

#1 = 25.0°C

#2 = 25.0°C

avr:

Removed 1 rod. Now have an 19x19 + 2 array
 Total of 198 rods.

Water hts = 42.20 cm
³ - Per
 $C = -260.8 \text{ sec} = -5.9 \phi$
 Drain:

Temp °C
 $T_1 = 25.0^\circ \text{C}$
 $T_2 = 25.0^\circ \text{C}$

Added 4" of concrete to 2 faces. Total thickness
 = 12.0". Total of 198 rods.


Water hts = 42.20 cm
⁴ - Per
 $C = -232.5 \text{ sec} = -6.8 \phi$

Temp °C
 $T_1 = 25.0^\circ \text{C}$
 $T_2 = 25.0^\circ \text{C}$

1300 Drain

Added 1 rod:

Water hts = 42.3
⁵ + Per
 $C = 328.1 \text{ sec} = 3.6 \phi$



2°C
 2°C

1337 Water hts = 35.65 cm
 System just critical
 Drain.

6

Removed 1 rod. Now have an 14x14 + 2 rods
 Total of 198 rods.

Water ht = 42.20 cm
 3 - Per
 $C = -260.8 \text{ mm} = -5.9 f$
 Drain:

Temp °C
 #1 = 25.0 °C
 2 = 25.0 °C

Added 4" of concrete to 2 faces. Total thickness
 = 12.0". Total of 198 rods.

Water ht = 42.20
 4 - Per
 $C = -232.5 \text{ mm} = -$
 1300 Drain

Block in contact. Same per
 as p-19.
 14x14 + 3 rods. Total of 199 rods.
 Log # 6. p-82

0 °C
 0 °C
 0 °C

Added 1 rod. Total of 199 rods.

Water ht = 42.30 cm
 5 + Per
 $C = 328.1 \text{ mm} = 3.6 f$

Temp °C
 #1 = 25.2 °C
 2 = 25.2 °C

1337 Water ht = 35.65 cm
 System just critical
 Drain

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3×10^{-12}	Meter <input checked="" type="checkbox"/>	4"	<input checked="" type="checkbox"/>	3×10^{-12}
		Fast <input checked="" type="checkbox"/>	2"	<input checked="" type="checkbox"/>	"
K-2	3×10^{-12}	Meter <input checked="" type="checkbox"/>	4"	<input checked="" type="checkbox"/>	"
		Fast <input checked="" type="checkbox"/>	2"	<input checked="" type="checkbox"/>	"
PM-1	7000	Alarm <input checked="" type="checkbox"/>	Cont	<input checked="" type="checkbox"/>	5000
PM-2	12000	Low <input checked="" type="checkbox"/>	12"	<input checked="" type="checkbox"/>	9000
		Alarm <input checked="" type="checkbox"/>	1"	<input checked="" type="checkbox"/>	"

LOG CALIBRATE OPERATE DUMP WELL PROBE LIGHT RADIATION ALARM: A B C SOURCE NUMBER B-80

START-UP CHECK LIST

Equipment checked by ^{F.I.D.C.} B.M.V. Personnel check by ^{F.I.D.C.} B.M.V.Instruments and safeties checked and reset by B.M.V.Source in checked by B.M.V. Source No. M-43Emergency equipment in central room checked by F.I.D.C.Instruments in trip circuit K-1-2 PM-1-2Red light on by B.M.V. Time 0810Start-up OK'd by F.I.D.C. B.M.V. Date 11-7-73


Added 4.0" of
thickness = 10

Water ht = 4.1
1 + Per

$C = 217.30 \text{ cm} = 5.2 \text{ f}$

0956 Water ht = 35.45 cm

System just critical
Drain




Now have 4.0" of concrete
of plepigos encasement.

Water ht = 42.30 cm
2 + Per

$C = 608.9 \text{ cm} = 2.0 \text{ f}$

1312 Water ht = 36.50 cm

System just critical
Drain



thickness
199 rods

mp c

$z = 25.0 \text{ cm}$

$z = 25.0 \text{ cm}$

Blocks in contact. Same for as
on p-19.

14x14+3 array. Total of 199 rods

Log #6 - p-84

84

Added 4.0" of concrete to 2 faces. Total
thickness = 16.0". Total of 199 rods.

Water ht = 42.0 cm.

1 + Per

C = 217.30 sec = 5.2 f

Temp °C

#1 = 25.0 °C

#2 = 25.0 °C

0956 Water ht = 35.45 cm

System just critical
Drain.

Pos of rods to concrete
which same as on p-19.
14x14+3 array
Total of 199 rods.
Block spaced .10"
from rods.

Log #6 - p-84

Now have 4.0" of concrete spaced .10" + thickness
of flepigos encasement. (.116" avg). Total of 199 rods

Water ht = 42.30 cm

2 + Per

C = 608.4 sec = 2.0 f

Temp °C

#1 = 25.0 °C

#2 = 25.0 °C

1312 Water ht = 36.50 cm

System just critical
Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4.0 9.0"	✓	3x10 ⁻¹²
		Fast ✓	2"	✓	"
K-2	3x10 ⁻¹²	Meter ✓	4"	—	"
		Fast ✓	2"	✓	"
PM-1	7000	Alarm ✓	.5"	✓	5000
PM-2	12000	Low ✓	12"	✓	9000
		Alarm ✓	1	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER 1-80

START-UP CHECK LIST

Equipment checked by ^{I.P.C.} A.K.M. Personnel check by I.P.C.
 Instruments and safeties checked and reset by A.K.M.
 Source in checked by A.K.M. Source No. M-43
 Emergency equipment in control room checked by F.I.C.
 Instruments in trip circuit: K-1-2 PM1-2
 Red light on by A.K.M. Time 0800
 Start-up OK'd by F.I.C., A.K.M. Date 11-8-73

Remained 1 rod: Total of 198 rods.

Water ht = 42.40 cm
 1-Per
 $E = -210.78 \text{ mm} = -7.6 \text{ f}$

Temp °
 #1 = 25.0 °
 2 = 25.0 °

0900 Drain:

Added 4.0" of concrete to 2 faces: spaced .10", Total thickness now = 8.0". Total of 198 rods.


Water ht = 42.20 cm
 2-Per
 $E = -467.19 \text{ mm} = -3.0 \text{ f}$

Temp °
 #1 = 25.0 °
 2 = 25.0 °

0937 Drain

Added 1 rod: Total

Water ht = 42.30 cm
 3-Per
 $E = 147.76 \text{ mm} = 7.2 \text{ f}$



Temp °
 1 = 25.0 °
 2 = 25.0 °

01003 Water ht = 34.70 cm
 system feel critical
 Drain

Remained 1 rad.: Total of 198 rads.

Water ht = 42.90 cm

Temp °C

1-Per

#1 = 25.0 °C

$E = -210.78 \text{ m} = -7.6 \phi$

2 = 25.0 °C

0900 Drain:

Added 7.0" of concrete to 2 faces: spaced .10". Total thickness now = 8.0". Total of 198 rads.

Box of rads to concrete blocks.

Water ht = 42.20 c. same as p-19.

2-Per

14x14x3 array. Total of

Temp °C

199 rads. Block spaced

= 25.0 °C

$E = -467.19 \text{ m} = -3.0 \phi$

.10" from rads. P-86

= 25.0 °C

0937 Drain

Log # 6

Added 1 rad.: Total of 199 rads.

Water ht = 42.30 cm.

Temp °C

3 + Per

#1 = 25.0 °C


$E = 147.76 \text{ m} = 7.2 \phi$

2 = 25.0 °C

1003 Water ht = 34.70 cm

System feel critical
Drain

added 4.0" of sand
 Total thickness



Water ht = 42.30 cm
 4-per

$$C = 158.62 \text{ sec} = 6.8 \text{ f}$$

$$2 = 25.0^\circ \text{C}$$

1329 Water ht = 34.80 cm

System just critical
 Drain.

Removed 1 rod; Total of 198 rods.

Water ht = 42.30 cm
 5-per

Temp °C

$$\#1 = 25.0^\circ \text{C}$$

$$C = -493.27 \text{ sec} = -2.9 \text{ f}$$

$$2 = 25.0^\circ \text{C}$$

1350 Drain:

14x14+3 array. Total of 199 rods.
Rods spaced .10" from rods.
p-37
Log # 6

added 4.0" of concrete to 2 faces, spaced .10".
Total thickness now 12.0". Total of 199 rods.

Water ht = 42.30 cm
4-Per

Temp °C

#1 = 25.0 °C

#2 = 25.0 °C

C = 158.62 sec = 6.8 f

1329 Water ht = 34.80 cm

System just critical
Drain.

Removed 1 rod. Total of 198 rods.

Water ht = 42.30 cm
5-Per

Temp °C

#1 = 25.0 °C

#2 = 25.0 °C

C = -493.27 sec = -2.9 f

1350 Drain:

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3×10^{-2}	Meter ✓	4"	✓	3×10^{-12}
		Fast ✓	2"	✓	"
K-2	3×10^{-12}	Meter ✓	4"	✓	"
		Fast ✓	2"	✓	"
PM-1	700V	Alarm ✓	1.5"	✓	500V
PM-2	1200V	Low ✓	19"	✓	900V
		Alarm ✓	2"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT RADIATION ALARM: A B C SOURCE NUMBER B-80

START-UP CHECK LIST

Equipment checked by ^{F.D.C.} AKM Personnel check by F.D.C.Instruments and safeties checked and reset by AKMSource in checked by AKM Source No. M-93Emergency equipment in control room checked by F.D.C.Instruments in trip circuit: K1-2 PM1-2Red light on by AKM Time 0900Start-up OK'd by F.D.C. AKM Date 11-9-73

added 2.0" of concrete to 2 faces. Spaced .10"
 Total thickness now = 16.0". Total of 198 rods.

Water ht = 42.50 cm.

¹-Per

$$C = -497.61 \text{ sec} = -2.8 f$$

0955 Drain

Temp °C

#1 = 25.0 °C


#2 = 25.0 °C

added 1 rod

Water ht = 42,

²+Per

$$C = 141.24 \text{ sec} = 7.5 f$$



1019 Water ht = 34.30 cm.

system just critical
 Drain.

Repeat of experiment on top of page 84. Concrete
 in contact on 2 faces. Total of 16.0" & 199 rods.

Water ht = 42.10 cm

³+Per

$$C = 451.98 \text{ sec} = 2.5 f$$

Temp °C

#1 = 25.0 °C

#2 = 25.0 °C

1340 Water ht = 36.90 cm

system just critical
 Drain.

over

added 2.0" of concrete to 2 faces. Spaced .10"
 Total thickness now = 16.0". Total of 198 rods.

Water ht = 47.5

1-Per

$C = -497.61 \text{ sec} =$

0955 Davis

Area was 0.10 from area
 14x14 + 3 rods; total of 139 rods.
 Area of rods for concrete block
 61.0" of rods on p. 19.

added 1 rod. Total of 199 rods.

Water ht = 42.40 cm

2+Per

$C = 141.24 \text{ sec} = 7.5 f$

Temp °C

#1 = 25.0°C

2 = 25.0°C

1019 Water ht = 34.30 cm.

system just critical
 Davis.

Repeat of experiment on top of page 84. Concrete
 in contact on 2 faces. Total of 16.0" & 199 rods.

Water ht = 42.10 cm

3+Per

$C = 451.98 \text{ sec} = 7.5 f$

Temp °C

#1 = 25.0°C

2 = 25.0°C

1340 Water ht = 36.90 cm.

system just critical
 Davis.

Davis.

Removed 1 rod. Total of 198 rods.

Water ht = 92.4 cm
4 - Per

$G = 215.13 \text{ sec} = -7.4 f$

1907 Drain.

Temp $^{\circ}$
#1 = 25.0
2 = 25.0