

BOOK102R

Notes:

"U (4.89) rads Log #4" on spine

Blank pages: inside front cover sheets, 2, 59-308, inside back cover sheets

-1 half sheet between cover page and page 1

-pages having 1 drawing and 1 sticker on each page: 4, 7, 10, 12, 16, 17, 19, 20, 25, 27, 33, 34, 37,
41, 45, 48, 50, 54, 56, 57

Scanned by:

Sheila Finch

RSICC /Oak Ridge National Lab.

September 10, 1999

14-2-1



Account Book

No. S 149

NO UNITS

Journal

Ledger, Single Entry . .

Ledger, Double Entry .

Record Ruled (27 Lines)

Made in 150, and 300 Pages

MADE IN U. S. A.

TO REORDER, SPECIFY NUMBER,
RULING AND THICKNESS INDICATED
ON BACKBONE OF THIS BOOK.

Can from Log #3 p. 302 (5/8/69) 0.2 f B/L

0.2 f B/L in refl./back water: 0

6.516" rods, 2.82 cm sep, 2 rods 4

2.60 cm sep. 10

2.41 - - - - 17

0.3" rods, 2.05 cm sep. 22

2.455 - - - - 29

1.80 35

1.55 - - - - 42

1.30 52

(cont 5/26/69)

Log #4

Con. From Log #3 p. 30v

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-2}	Meter ✓	1"	✓	3×10^{-2}
"	"	Fast ✓	"	✓	"
K-2	"	Meter ✓	"	✓	"
"	"	Fast ✓	"	✓	"
R-1					
R-2					
PM-1	700v	Alarm ✓	5"	✓	500v
PM-2	1200v	Low ✓	10"	✓	900v
"	"	Alarm ✓	2"	✓	"

LOG IN CALIBRATE OPERATE SOURCE No. B-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by F.D.C. Personnel check by F.D.C.

Instruments and safeties checked and reset by A.K.M.

Source in checked by A.K.M. Source No. M-43

Emergency equipment in control room checked by F.D.C.

Instruments in trip circuit: K-1-2 PM-1-2

Red light on by A.K.M. Time 1025'

Start-up OK'd by F.D.C. M.K.J. Date 9-9-69

1516 rods.
2.82 cm separation c-c.
30 cm length

Have an 13x13 array. With 10 rods removed from each corner. Total of 129 rods.


1057 Water ht = 27.70 cm Temp °C
system sub critical 23.6 °C
Drain.

Added 4 rods. 1 to each corner. Have an 13x13 array, with 9 rods removed from each corner. Total of 133 rods.

Water ht = 27.60 cm $\Delta h = 7.05 \text{ cm}$ Temp °C
+ Per 23.7 °C
 $C = 245.55 \text{ sec} = 4.74 = .674/\text{cm}$.

1123 Water ht = 20.55 cm
system just critical
Drain.

9/9/69: 13x13 array with 9 rods removed from each corner. Total rods: 133. 0.516" rods. Separation 2.825 cm C-C. 30 cm length. p. 4



f-5

2
 Removed 1 rad. Now have on 13 x 13 array,
 with 9 rods removed from 3 corners, and
 10 rods removed from 1 corner. Total of
 132 rods.

Water ht = 27.60 cm

Temp °C

- Per.

23.8 °C

N. G.

1303

Drain:

Repeat with 132 rods: Now have on
 12 x 12 array, with 3 rods removed
 from each corner. Total 132 rods.

Water ht = 27.60 cm

Temp °C

System sub critical

23.8 °C

Drain.

over:

6

.516" rods.
2.825 cm separations c-c.
60 cm length.

Have an 11 x 11 array with 8 rods removed from each corner. Total of 89 rods.

Water ht = 42.35 cm $sh = .45$ Temp °C

³ + Per

$$C = 39.11 \text{ sec} = 19.34 = 42.9 \text{ ft/cm}$$

~~1515~~
1515

Water ht = 41.90 cm

System just critical
Drain

Removed 2 rods, 1 each from opposite corners.
Have an 11 x 11 array, with 8 rods removed from 2 corners and 9 rods removed from 2 corners. Total of 87 rods.

1543 Water ht = 57.60 cm Temp °C
System sub critical 23.9 °C
Drain

p-7

Added 1 rod. Now have an 11x11 array, with 8 rods removed from 1 corner, and 9 rods removed from 3 corners. Total of 88 rods.

$Ph = 4.0$

Water ht = 48.70 cm.
+ Per


Temp °
29.1 °

$C = 45.63 = 17.44 = 4.37/cm$

1606 Water ht = 44.70 cm

System just critical
Drain.

9-9-69 11x11 array w/
9 rods removed fr 3 corners & 8 fr 1 cor. Total
88 rods .516" rods 2.825
cm separation c-c .60 cm
length P-7



INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	LOWEST SCALE	ST	START-UP RANGE
K-1	3x10 ⁻¹²	Meter ✓	1"	✓	3x10 ⁻¹²
"	"	Fast ✓	"	✓	"
K-2	"	Meter ✓	"	✓	"
"	"	Fast ✓	"	✓	"
R-1					
R-2					
PM-1	700 V	Alarm ✓	5"	✓	500V
PM-2	1200 V	Low ✓	10"	✓	900V
"	"	Alarm ✓	2"	✓	"
LOG 'N' CALIBRATE		✓	OPERATE	✓	SOURCE No. B-80
DUMP WELL PROBE LIGHT					

START-UP CHECK LIST

Equipment checked by ^{F.I.C.} RKA Personnel checked by F.I.C.
 Instruments and safeties checked and reset by RKA
 Source in checked by RKA Source No. M-43
 Emergency equipment in control room checked by F.I.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by RKA Time 0815
 Start-up OK'd by F.I.C. RKA Date 9-10-69

1.516" rods.
2.825 cm separation c-c.
60 cm length.

9

Repeat of last experiment (p-7).
Have an 11x11 array, with 8 rods removed from
1 corner, and 9 rods removed from 3 corners.
Total of 88 rods.

Water ht = 47.65 cm $\Delta z = 2.85$ Temp $^{\circ}$
+ Per 23.9 $^{\circ}$

$$C = 60.84 \text{ sec} = 14.3 \text{ } \phi = 5.0$$

0908 Water ht = 44.80 cm
System just critical
Drain:

1.516" rods.
2.60 cm separation c-c
30 cm length.

Have an 13x14 array, with 11 rods removed
from 3 corners, and 10 rods removed from
1 corner. Total of 139 rods.

Water ht = 15.60 cm $\Delta z = .70$ Temp $^{\circ}$
+ Per 23.9 $^{\circ}$

$$C = 21.73 \text{ sec} = 27.3 \text{ } \phi = 39.0 \text{ } \phi/\text{cm}$$

1100 Water ht = 14.90 cm.
System just critical
Drain:

over:

.516" rods
2.60 cm separation c-c
30 cm length.

Removed 2 rods. Now an 13x14 array with 12 rods removed from 1 corner and 11 rods removed from 3 corners. Total of 137 rods.

Water ht = 16.80 cm $\delta h = 1.1$ cm Temp $^{\circ}$ C
3 + Per 24.0 $^{\circ}$ C

$\tau = 19.56 = 28.84 = 26.18$

1118 Water ht = 15.70 cm
system just critical
Drain.


Removed 3 rods. Now have an 13x14 array, with 12 rods removed from each corner. Total of 134 rods.

Water ht = 27.70 cm $\delta h = 9.5$ Temp $^{\circ}$ C
4 + Per 24.0 $^{\circ}$ C

$\tau = 49.98 = 16.44 = 1.7$

1300 Water ht = 18.20 cm
system just critical
Drain.

9-10-69 13x14 array w/
12 rds removed fr ea. cor
Total rods 134. .516" rds
2.60 cm separation c-c
30 cm length P-10



17c

1c

1.516" rods.
2.60 cm operation c-e 11
30 cm length.

Removed 2 rods. Have an 13 x 14 array, with
12 rods removed from 2 corners, and 13
rods removed from 2 corners. Total of
132 rods.

1408 - Water ht = 27.60 cm Temp °C
System rule critical 29.0°C
Drain:

Added 1 rod. Have an 13 x 14 array,
with 12 rods removed from 3 corners.
And 13 rods removed from 1
corner. Total of 133 rods.

Water ht = 27.60 Temp °C
5-Per 29.1°C

$$t = -278,14 \text{ sec} = -5,4 \text{ s}$$

1424 Drain:

Change array: Now have an 13 x 13 array, with
9 rods removed from each corner. Total
of 133 rods.

Water ht = 27.60 cm Temp °C
6-Per 29.1°C

$$t = 302,05 \text{ sec} = -4,9 \text{ s}$$

Drain:

over

12

.516" rods
2.60 cm separation c-c
30 cm length.

Added 1 rod. Have an 13 X 13 array, with
9 rods removed from 3 corners, and 8 rods
removed from 1 corner. Total of 139 rods.

Water ht = 27.60 $B_h = 8.95$
+ h₂

Temp °C
24.1°


$\tau = 67.36 \mu = 13.34 = 1.54/cm$

1513

Water ht = 18.65 cm

system just critical
Crain

9-10-69 13x13 array w/9
rds removed fr 3 corners
& 8 fr 1 corner Total
134 rds. .516" rods 2.60
cm separation c-c 30 cm
length P-12



.516"
 2.60 cm separation c-c
 60 cm length.

Have an 11x11 array, with 8 rods removed from each corner. Total of 89 rods.

10 22 Water ht = 57.60 cm
 System sub critical
 Rain.

Temp °C
 29.0 °C

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter ✓	1"	✓	3×10^{-12}
"	"	Fast ✓	"	✓	"
K-2	"	Meter -	"	✓	"
"	"	Fast ✓	"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	15"	✓	500V
PM-2	1200V	Low -	10"	✓	900V
"	"	Alarm ✓	2"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. B-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by _____ Personnel check by _____
 Instruments and safeties checked and reset by _____
 Source in checked by _____ Source No. _____
 Emergency equipment in control room checked by _____
 Instruments in trip circuit: _____
 Red light on by _____ Time _____
 Start-up OK'd by _____ Date _____

START-UP CHECK LIST

Equipment checked by F.P.C. Personnel check by F.P.C.
 Instruments and safeties checked and reset by A.P.L.
 Source in checked by A.P.L. Source No. M-43
 Emergency equipment in control room checked by F.P.C.
 Instruments in trip circuit: H-1-2 PNA-1-2
 Red light on by A.P.L. Time 0950
 Start-up OK'd by F.P.C. A.P.L. Date 9-11-69

.516" rods.
2.60 cm separation e-e
60 cm length.

15

Added 1 rod. Have an 11x11 array with 8 rods removed from 3 corners, and 7 rods removed from 1 corner. Total of 90 rods.

1057 Water ht = 57.60 cm
System sub critical
Drain

Temp °C
24.0°C

Added 2 rods. Have an 11x11 array with 8 rods removed from 1 corner, and 7 rods removed from 3 corners. Total of 92 rods.

Water ht = 44.60 cm
' + Per

$\Delta h = 2.05 \text{ cm}$

Temp °C
24.0°C

$$E = 26.09 = 24.04 = 12.0 \text{ off cm}$$

1172 Water ht = 42.55
System just critical
Drain.

avg.

.516" rods.
2.60 cm separation c-c
60 cm length.

Removed 1 rod. Have an 11x11 array, with
8 rods removed from 2 corners, and 7 rods
removed from 2 corners. Total of 91 rods.


Water ht = 57.60 cm $\Delta h = 12.3 \text{ cm}$ Temp $^{\circ}\text{C}$
+ P.W. 24.0 $^{\circ}\text{C}$

$\bar{v} = 56.50 \text{ cm} = 15.14 = 1.24/\text{cm}.$

1318 Water ht = 45.30 cm

System just critical
Drain.

9-11-69 11x11 array
w/8 rods rem'd fr 2 corners & 7 fr 2 corners
Total rods 91. .516"
rods .2.60 cm separation
c-c .60 cm lgth P-16



Samples:

Y-12 Reg # 684572

X-10 -12-1A

and for.

1. $g^{\text{rel}} = 0.204$
2. Density = 0.9972
3. Temp $^{\circ}\text{C} = 25^{\circ}$

$g^{\text{rel}} = 0.20$
Density = 0.9973
Temp $^{\circ}\text{C} = 25^{\circ}$

.516" rods,
 2.41 cm separation C-C.
 30 cm lengths.

I have an 13x14 array, with 10 rods removed from each corner. Total of 142 rods.


1.505 Water ht = 27.60 cm Temp °C
 System sub critical 24.0 °C
 Drain.

Added 1 rod. Have an 13x14 array, with 9 rods removed from 1 corner, and 10 rods removed from 3 corners. Total of 143 rods.

Water ht = 27.60 cm $p_h = 8.0 \text{ cm}$ Temp °C
 $^3 + \text{Pen}$ 24.1 °C

$E = 132.55 \text{ cm} = 7.94 = 1.90 \text{ off/cm}$

1.534 Water ht = 19.60 cm:
 System just critical
 Drain.



9/10/69

INSTRUMENT CHECK

9/10

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	FT	START-UP RANGE
K-1	3 x 10 ⁻¹²	Meter ✓ Fast ✓	1"	✓	3 x 10 ⁻¹²
K-2	3 x 10 ⁻¹²	Meter ✓ Fast ✓	1"	✓	3 x 10 ⁻¹²
R-1	—	—	—	—	—
R-2	—	—	—	—	—
PM-1	7000	Alarm ✓	1/2"	✓	5000
PM-2	12000	Low ✓ Alarm ✓	10" 2"	✓ ✓	5000
LOG N. CALIBRATE ✓		OPERATE ✓		SOURCE No. B-80	
DUMP WELL PROBE LIGHT —					

09

10

135

START-UP CHECK LIST

Equipment checked by IDC EJ Personnel check by IDC

Instruments and safeties checked and read by EJ

Source in checked by EJ Source No. M-43

Emergency equipment in control room checked by IDC

Instruments in trip circuit: K-1, K-2, PM-1, PM-2

Red light on by EJ Trip 0910

Start-up OK'd by EJ IDC Date 9/10/69

14

14

14

9/15/65

$\Delta h = 4.25 \text{ cm}$

Repeat of run reported end of p. 17.

0957

$H_2O @ 24.3 \text{ cm.} + \text{ Period } \#1 \quad \#1 \quad 23.2^\circ \text{C}$
 $E = 199.92 \text{ cm} = 5.6 = 1.3 \text{ f/cm}$

1317

$H_2O @ 20.05 \text{ cm. Critical.}$
 Drain

68 cm. High Lattice
 $\sim .41$
~~2.50~~ cm center separation
 0.516 rods

11x11 with 5 ant of 3 corners & 6 ant of 1.
 Total 100 rods. $\Delta h = 7.0 \text{ cm}$

1350

$W \text{ at } W @ 42.75 \text{ cm.} + \text{ Period } \#2 \quad \text{Temp. } 23.3^\circ \text{C}$
 $E = 97.78 \text{ cm} = 10.0 \text{ f} = 14.3 \text{ f/cm}$

1404

$W \text{ at } W @ 42.05 \text{ cm. Critical}$
 Drain


Removed 1 rod. Now have 5 ant of 2 corners & 6 ant of 2. Total 99 rods

1440

$W \text{ at } W @ 52.14 \text{ cm} + \text{ Period } \#3$
 $E = 32.59 \text{ cm} = 2.16 \text{ f} = 2.8 \text{ f/cm}$

1445

$W \text{ at } W @ 44.6 \text{ cm. Critical}$
 Drain.



9/15/65

$\Delta h = 4.25 \text{ cm}$

Repeat of run reported end of p. 17.

0957

 $H_2O @ 24.3 \text{ cm} + \text{Period} \#1$ ± 1 $23.2^\circ C$

$E = 199.92 \text{ cm} = 5.6 = 1.3 \text{ f/cm}$

1017

 $H_2O @ 20.05 \text{ cm}$ Critical.

Drain

6.8 cm. High Lattice

2.41

~~2.41~~ cm center separation

0.516 rods

11x11 with 5 unit of 3 corners & 6 unit of 1.

Total 100 rods. $\Delta h = .70 \text{ cm}$

1350

 $W \text{ on } W @ 42.75 \text{ cm} + \text{Period} \#2$ Temp. $23.3^\circ C$

$E = 97.78 \text{ cm} = 10.0 \text{ f} = 14.3 \text{ f/cm}$

1404

 $W \text{ on } W @ 42.05 \text{ cm}$ Critical

Drain

Removed 1 rod. Now have 50

6 unit of 2. Total 99 rods

$\Delta h = 7.8 \text{ cm}$

1440

 $W \text{ on } W @ 52.4 \text{ cm} + \text{Period} \#3$ Temp. $23.4^\circ C$

$E = 32.59 \text{ cm} = 2.16 \text{ f} = 2.8 \text{ f/cm}$

1445

 $W \text{ on } W @ 44.6 \text{ cm}$ Critical

Drain.

9/15/69: 11x11 array
 with 5 rods removed from
 2 corners & 6 from 2 cor-
 ners. Total rods: 99.
 0.516" rods. 2.41 cm
 separation C-C. 60 cm
 length. p. 19

22

9/10/69

30 cm Height
 2.05 cm center separation
 0.3 in. diam rods in 0.25 B/L

15x19 lattice, square pattern, with 23
 rods removed from each corner.

Total: 269 rods

1432

Water @ 27.7 cm. Subcritical. Temp. 23.5°C
 Drain.

Added 12 rods. Now lattice 15x19 with 20
 rods removed from each corner.

Total 281 rods

1512

Water @ 27.6 cm. Subcritical. Temp. 23.6°C
 Drain

Added 4 rods. Now lattice 15x19 with 15 rods
 removed from each corner. Total 285 rods.

1535

Water @ 27.7 cm. Subcritical. Temp. 23.7°C
 Drain.

Added 4 rods. Now lattice 15x19 with 18 rods
 removed from each corner. Total 289 rods.

1552

Water @ 27.7 cm. + Power #1 23.5°C
 $0.47 \times 9.25 \text{ cm} = 4.35 \text{ cm}$
 $0.7 \times 58.67 \text{ cm} = 41.07 \text{ cm} = 1.6 \text{ ft/cm}$

9/16/69

W & W @ 18.45 am. Critical

Dozin.

50

6

red

3.2

3

2

9/14/69

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE CONCEN	SET	START-UP PAR. NO.
K-1	3x10 ⁻¹²	Meter ✓	1"	✓	3x10 ⁻¹²
		F.W. ✓		✓	
K-2	3x10 ⁻¹²	Meter ✓	1"	✓	3x10 ⁻¹²
		F.W. ✓		✓	
P-1					
P-2					
P-3	700V	Alarm ✓	1/2"	✓	500V
P-4	1200V	Low ✓	10"	✓	900V
		Alarm ✓	2"	✓	

LOG IN CALIBRATE ✓ OPERATE ✓ SOURCE No. B-60

DUMP WELL FREE LIGHT ✓

START-UP CHECK SHEET

Equipment checked by EA, IDC Personnel check by IDC

Instruments and safeties checked and reset by EA

Source in checked by EA Source No. M-43

Emergency equipment in control room checked by IDC

Instruments in trip circuit: K-1, K-2, P12-1, P12-2

Red light on by EA Time 1403

Start-up OK'd by EA, IDC Date 9/14/69


20

9/15/69

Removed 1 rod. Now have 5 out of 1 corner,
6 out of 3 corners. Total 98 rods.

1545 water @ 57.8 km. Subcritical. 23.72
D₂₃₄

9/15/69: 11x11 array
with 5 rods removed from
1 corner & 6 from 3 cor-
ners. Total rods: 98.
0.516" diam. 2.41 cm
separation C-C. 60 cm
length. p.20



INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE	SET	START-UP RANGE
K-1	3×10^{-2}	Meter ✓	1"	✓	3×10^{-2}
"	"	Fast ✓	"	✓	"
K-2	"	Meter ✓	"	✓	"
"	"	Fast ✓	"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	0.5"	✓	500V
PM-2	1200V	Low ✓	10"	✓	900V
"	"	Alarm ✓	2"	✓	"
LOG N CALIBRATE		✓	OPERATE	✓	SOURCE No. B-80
DUMP WELL PROBE LIGHT _____					

START-UP CHECK LIST

Equipment checked by F.D.C. AKL Personnel check by I.O.C
 Instruments and safeties checked and tested by AKL
 Source in checked by AKL for 14-43
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit K-1-2 PM-1-2
 Red light on by AKL Time 1010
 Start-up OK'd by F.D.C. AKL Date 9-17-69

UNCLASSIFIED

2.05 cm separation C-C.
30 cm length.
0.3" rods.

25

Have an 19x19 array, with 19 rods removed from 1 corner, and 18 rods removed from 3 corners. Total of 288 rods.


Water ht = 27.60 cm $\Delta h = 7.65 \text{ cm}$ Temp $^{\circ}\text{C}$
+ Per. 23.6 $^{\circ}\text{C}$

$\tau = 176.01 \text{ sec} = 6.24 = .81 \text{ } \mu\text{m}$

1106 Water ht = 19.95 cm
System just critical
Drain.

Removed 1 rods. Have an 19x19 array, with 19 rods removed from 2 corners, and 18 rods removed from 2 corners. Total of 287 rods.

1116 Water ht = 27.60 cm
System just critical
Drain.



array

26

0.3" rods.
2.05 cm separation c-c.
60 cm length.

Have an 15x15 array, with 10 rods removed from each corner. Total of 185 rods.

Water ht = 43.55 cm $z_s = 1.1$ cm Temp °C
Flow 23.7 °C

$E = 58.67 \text{ sec} = 14.74 = 13.44 / \text{cm}$

1515 Water ht = ± 42.45 cm
System just critical
Drain.

16

Removed 4 rods, 1 from each corner. Have an 15x15 array, with 11 rods removed from each corner. Total of 181 rods.

1545 Water ht = 50.60 cm Temp °C
System sub-critical 23.7
Drain.

f-27

2 added 1 rod. Have an 15x15 array, with 10 rods removed from 1 corner, and 11 rods removed from 3 corners. Total of 182 rods.

DR = 9.6 cm

Water ht = 57.50 cm

Temp °C


3 + Per

23.5 °C

$C = 315.08 \text{ m} = 3.7 \text{ f} = .38 \text{ ft/m}$

16.14 Water ht = 47.90 cm

System just critical
Drain:



INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter ✓	1"	✓	10×10^{-12}
	"	Fast ✓	"	✓	"
K-2	"	Meter ✓	"	✓	3×10^{-12}
	"	Fast ✓	"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	15"	✓	500V
PM-2	1200V	Low ✓	10"	✓	1200V
	"	Alarm ✓	2"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. B-80

DUMP WELL PROSE LIGHT

START-UP CHECK LIST

Equipment checked by ^{I.D.C.} A.K.V. Personnel check by I.D.C.
 Instruments and safeties checked and reset by A.K.V.
 Source in checked by A.K.V. Source No. M-43
 Emergency equipment in control room checked by I.D.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by A.K.V. Time 0940
 Start-up OK'd by I.D.C. A.K.V. Date 9-18-69

0.30" rods.
2.05 cm separation c-c.
60 cm lengths.

29

Repeat of last run (p-27)

Have an 15 X 15 array, with 10 rods removed from 1 corner, and 11 rods removed from 3 corners. Total of 182 rods.

Water ht = 57.60 cm $\alpha = 9.6$ Temp $^{\circ}\text{C}$
+ Per 23.7 $^{\circ}\text{C}$

$\tau = 352.03 \text{ sec} = 3.47 = .35 \text{ Hrs}$

1040 Water ht = 48.00 cm

System just critical
Drain

0.30" rods.

2.453 cm separation c-c.

30 cm lengths.

Have an 22 X 22 array. With 21 rods removed from each corner. Total of 400 rods.

1347 Water ht = 27.60 cm

System sub critical
Drain

Temp $^{\circ}\text{C}$
23.7 $^{\circ}\text{C}$

30

0.30" rods.
 2.453 cm separation c-c.
 30 cm length

Added 24 rods. Have an 22 X 22 array,
 with 15 rods removed from each corner.
 Total of 424 rods.

1418 Water ht = 27.60 cm Temp °C
 System sub-critical 23.7°C
 Drain.

Added 60 rods. Have an 22 X 22 array.
 Total of 484 rods. (Full grid plate).

1445 Water ht = 27.70 cm Temp °C
 System sub-critical 23.8°C
 Drain.

0.30" mesh.
2,453 cm separation c-c.
60 cm lengths.

Have an 18 x 18 array, with 21 rods removed from each corner. Total of 240 rods.

0.850 Water ht = 39.40 cm Temp °C
System just critical 23.5 °C
Crain!

Removed 8 rods: 2 from each corner. Have an 18 x 18 array with 23 rods removed from each corner. Total of 232 rods.

Water ht = 44.80 cm Temp °C
+ Per 23.5 °C
 $\Delta h = 2.0 \text{ cm}$

$$G = 28.25 \text{ sec} = 23.54 = 11.74 \text{ /cm}$$

0.940 Water ht = 42.80 cm
System just critical
Crain.

Removed 4 rods: 1 from each corner. Have an 18 x 18 array, with 24 rods removed from each corner. Total of 228 rods.

Water ht = 57.65 cm Temp °C
+ Per 23.8 °C
 $\Delta h = 11.50$

$$G = 102.13 \text{ sec} = 9.74 = 1.84 \text{ /cm}$$

1035 Water ht = 46.15 cm
 System just critical
 Drain.

Removed 2 rods; 1 each from opposite corners. Have an 18 x 18 array, with 25 rods removed from 3 corners and 2 rods removed from 2 corners. Total of 226 rods.

1102 Water ht = 57.60 cm
 System sub critical
 Drain.

Temp °C
 29.0°

Added 1 rod. Have an 18 x 18 array, with 2 rods removed from 3 corners and 25 rods removed from 1 corner. Total of 227 rods.


Water ht = 57.60 cm

+ Per

$T = 484.58 \text{ sec} = 2.5 \text{ d} =$

Water ht = 48.60 cm

System just critical
 Drain.



9/19/69: 18x18 array with 24 rods removed from 3 corners & 25 from 1 corner. Total Rods: 227. 6.30" rods 60 cm length. 2.453 cm separation C-C
 p.33

1035 Water ht = 46.15 cm
 System just critical
 Drain.

Removed 2 rods; 1 each from opposite corners. Have an 18 x 18 array, with 25 rods removed from 2 corners and 29 rods removed from 2 corners. Total of 226 rods.

1102 Water ht = 57.60 cm
 System sub critical
 Drain.
 added 1 rod. Have
 24 rods removed from
 rods removed from
 227 rods.

Water ht = 57.60 cm

ht = 9.0 cm

Temp °C

+ Per

24.0 °C

$$G = 484.58 \text{ sec} = 2.5 \text{ f} = .29 \text{ f/cm}$$

Water ht = 48.60 cm

System just critical
 Drain.

cur

0.30" rods.
2.453 cm separation c-c.
60 cm length.


Have an 17x17 array, with 16 rods removed from 3 opposite corners and 15 rods removed from 2 corners. Total of 227 rods.

Water ht = 57.60 cm.
4-Pen

$E = 286.84 \mu = 4.14'$

1345 Water ht = 47.70 cm

System just critical
Drain.



9/19/69: 17x17 array with 16 rods removed from 3 corners & 15 from 2 corners. Total rods: 227. 0.30" rods 2.453 cm separation C-C 60 cm length. p.34

Removed 1 rod. Have 16 rods removed from 3 corners, and 15 rods removed from 1 corner. Total of 226 rods.

Water ht = 57.60 cm
5-Pen

Temp °C
24.2 °C

$E = -410.70 \mu = -3.54'$

1427 Drain!

34

0.30" rods.
2,453 cm sq
60 cm long

Have an 17x17 array,
from 3 opposite corners
from 2 corners. Tot

Water ht = 57.60 cm.

4-Pen

Temp °C

24.1°C

$\bar{v} = 286.84 \text{ sec} = 4.14 = .41 \text{ sec}$

1345 Water ht = 47.70 cm

System just critical
Drain.

Removed 1 rod. Have an 17x17 array with
16 rods removed from 3 corners, and 15
rods removed from 1 corner. Total of
226 rods.

Water ht = 57.60 cm

5-Pen

Temp °C

24.2°C

$\bar{v} = -410.70 \text{ sec} = -3.54$

1427

Drain.

0.30" rods
1.80 cm separation c.c.
30 cm length.

35

2
Have on 19 x 19 array, with 19 rods removed from each corner. Total of 285 rods.

Water ht = 16.70 cm $\Delta h = 1.0$ cm Temp °C
6 + per 29.2 °C

$$C = 23.99 \text{ sec} = 25.94 = 25.9 \text{ sec}$$

1540 Water ht = 15.70 cm

System just critical
Drain.

Removed 4 rods, 1 from each corner. Have on 19 x 19 array, with 20 rods removed from each corner. Total of 281 rods.

Water ht = 18.80 cm $\Delta h = 1.6$ cm Temp °C
7 + per 29.2 °C

$$C = 47.81 \text{ sec} = 16.94 = 16.6 \text{ sec}$$

1600 Water ht = ± 17.20 cm

System just critical
Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE	STARTUP RANGE
K-1	3×10^{-12}	Meter ✓	1"	10×10^{-12}
"	"	Fest ✓	"	"
K-2	"	Meter ✓	"	3×10^{-12}
"	"	Fest ✓	"	"
R-1				
R-2				
PM-1	700V	Alarm ✓	5"	1500V
PM-2	1200V	Low ✓	10"	900V
"	"	Alarm ✓	2"	"
LOG N CALIBRATE		✓	OPERATE	✓
DUMP WELL PROBE LIGHT		✓	SOURCE No.	B-80

START-UP CHECK LIST

Equipment checked by F.D.C. Personnel check by F.D.C.
 Instruments and safety checked and reset by A.K.H.
 Source in checked by A.K.H. Source No. M-93
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by A.K.H. Time 0830
 Start-up OK'd by F.D.C. A.K.H. Date 9-22-69

30" rods.
 1.80 cm separation C-C.
 30 cm length.

Repeat of last experiment (p-35).

Have an 19x19 array, with 20 rods removed from each corner. Total of 281 rods.

Water ht = 19.30 cm $z_h = 1.95$ cm Temp $^{\circ}$ C
 + Pex 23.2 $^{\circ}$ C

$\bar{c} = 47.81 \text{ sec} = 16.9 \text{ } \phi = 8.7 \text{ } \phi/\text{cm}$

0922 Water ht = 17.35 cm

System just critical
 Drain


Removed 2 rods, 1 each from opposite corners.
 Now have an 19x19 array, with 21 rods removed from 2 corners and 20 rods removed from 2 corners. Total of 279

Water ht = 27.60 cm
 + Pex

$\bar{c} = 130.38 \text{ sec} = 8.0 \text{ } \phi =$

0950 Water ht = 19.50 cm

System just critical
 Drain.



30° rods.
1.80 cm separation c-c.
30 cm length.

Repeat of last experiment (p-35).
Have an 19x19 array, with 20 rods removed
from each corner. Total of 281 rods.

Water ht = 19.30 cm $z_h = 1.95 \text{ cm}$
+ Per

$\bar{c} = 47.81 \text{ sec} = 16.9 \text{ ft} = 5.15 \text{ m}$

0922 Water ht = 17.35 cm
System just critical
Drain

Removed 2 rods, 1 in
New row on 19x1
removed from 2 corners
removed from 2 corners

Water ht = 27.60 cm $z_h = 8.1 \text{ cm}$
+ Per Temp °C
23.3 °C

$\bar{c} = 130.38 \text{ sec} = 8.0 \text{ ft} = .99 \text{ ft/cm}$

0950 Water ht = 19.50 cm
System just critical
Drain.

only

Removed 1 rod. Have an 19×19 array,
with 20 rods removed from 1 corner,
and 21 rods removed from 3 corners.
Total of 278 rods.

Water ht = 27.60 cm

Temp $^{\circ}\text{C}$

³ - Per

23.3 $^{\circ}\text{C}$

$$G = -1151.69 = -1.2 f$$

1017

Drain:

30 rods.

1.80 cm separation c-c

60 cm length.

Have an 15×15 array, with 11 rods
removed from each corner. Total of
181 rods.

1920

Water ht = 57.60 cm

Temp $^{\circ}\text{C}$

System sub critical

23.4 $^{\circ}\text{C}$

Drain.

2.30" rods.
1.80 cm separation c.c.
60 cm length.

39

Added 4 rods. Now an 15x15 array, with
10 rods removed from each corner. Total
185 rods.

1458 Water ht = 57.60 cm
System just critical
Drain.

Temp $^{\circ}$ C
23.5 $^{\circ}$ C

Added 11 rods. Now have an 16x16 array,
with 15 rods removed from each
corner. Total of 196 rods.

1533 Water ht = 37.50
System just critical
Drain.

Temp $^{\circ}$ C
23.7 $^{\circ}$ C

Removed 4 rods, 1 from each corner. Now
have an 16x16 array, with 16 rods
removed from each corner. Total of
192 rods.

Water ht = 41.55
System just critical
Drain.

Temp $^{\circ}$ C
23.8 $^{\circ}$ C

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE OF RANGE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter <input checked="" type="checkbox"/>	1"	<input checked="" type="checkbox"/>	10×10^{-12}
"	"	Fast <input checked="" type="checkbox"/>	"	<input checked="" type="checkbox"/>	"
K-2	"	Meter <input checked="" type="checkbox"/>	"	<input checked="" type="checkbox"/>	3×10^{-12}
"	"	Fast <input checked="" type="checkbox"/>	"	<input checked="" type="checkbox"/>	"
R-1					
R-2					
PM-1	700V	Alarm <input checked="" type="checkbox"/>	15 inch	<input checked="" type="checkbox"/>	500V
PM-2	1200V	Low <input checked="" type="checkbox"/>	10 inch	<input checked="" type="checkbox"/>	900V
"	"	Alarm <input checked="" type="checkbox"/>	2"	<input checked="" type="checkbox"/>	"
LOG N CALIBRATE <input checked="" type="checkbox"/>		OPERATE <input checked="" type="checkbox"/>		SOURCE No. B-80	
DUMP WELL PROBE LIGHT <input type="checkbox"/>					

START-UP CHECK LIST

Equipment checked by ^{F.P.C.} AKM Personnel check by F.P.C.

Instruments and safeties checked and reset by AKM

Source in checked by AKM Source No. M-93

Emergency equipment in control room checked by F.P.C.

Instruments in trip circuit: K-1-2 PM-1-2

Red light on by AKM Time 0805

Start-up OK'd by F.P.C. AKM Date 7-23-68

0.30" rods,
1.80 cm separation c-c,
60 cm length.

Have an 16x16 array with 17 rods removed from each corner. Total of 188 rods.


Water ht = 57.60 cm

+ Per

$$C = 528.09 \text{ cm} = 2.3 \text{ ft} = 1.25 \text{ ft}$$

0905 Water ht = 48.50 cm

System just critical
Drain.



Removed 1 rod: Now have an 16x16 array, with 18 rods removed from 1 corner. And 17 rods removed from 3 corners. Total of 187 rods.

0935 Water ht = 57.60 cm

System sub critical
Drain.

Temp $^{\circ}$ C
23.7 $^{\circ}$ C

arr.

130"
1.80 C.
60 cm

Have an 16 X 16 array
from each corner. Tot

Water ht = 57.60 cm ^{9.14} $\Delta h =$ Temp °C
+ Per 23.6 °C

$$5 = 528.09 \mu = 2.34 = .25 \text{ Hcm}$$

0905 Water ht = 48.50 cm

System just critical
Drain.

Removed 1 rod: Now have an 16 X 16 array,
with 18 rods removed from 1 corner. And
17 rods removed from 3 corners. Total
of 187 rods.

0935 Water ht = 57.60 cm
System sub critical
Drain.

Temp °C
23.7 °C

avr.

42

.30" rods.
1,536 cm separation c-c
30 cm length.

Have an 22 X 22 array, with 21 rods removed from each corner. Total of 400 rods.

1112 Water ht = 8.55 cm Temp °C
System just critical 23.7 °C
Drain.

Removed 16 rods. Have an 22 X 22 array, with 25 rods removed from each corner. Total of 384 rods.

1244 Water ht = 9.25 cm
System just critical
Drain.

Removed 20 rods. Have an 22 X 22 array with 30 rods removed from each corner. Total of 364 rods.

Water ht = 12.60 cm Temp °C
2 + Per dh = 2.5 cm 23.7 °C

$$G = 43.46 \text{ w} = 18.04 = 72.04 \text{ cm}$$

Water ht = 12.35 cm
System just critical
Drain.

p-43

1.30" rods
1.530 cm separation c-e
30 cm length.

43

Removed 8 rods, 2 from each corner. Have
an 22×22 array, with 32 rods removed
from each corner. Total of 356 rods.

Water ht = 13.35 cm

3 $\frac{1}{2}$ Per

04:30

Temp $^{\circ}$

24.0 $^{\circ}$?

$E = 39.11 \text{ cm} = 19.3 \phi = 64.3 \text{ ft/cm}$

1346 Water ht = 13.05 cm.

System just critical
Drain.

Removed 16 rods, 4 from each corner. Have
an 22×22 array, with 36 rods removed
from each corner. Total of 390 rods.

Water ht = 15.35 cm

4 Per

04:40

Temp $^{\circ}$

23.8 $^{\circ}$

$E = 58.67 \text{ cm} = 14.7 \phi = 36.7 \text{ ft/cm}$

1410 Water ht = 14.95 cm

System just critical
Drain.

aver:

44

.30" rods.
 1.530 cm separation c-c.
 30 cm length.

Removed 8 rods, 2 from each corner.
 Have an 22×22 array, with 38 rods
 removed from each corner. Total of
 332 rods.

$$D_4 = 1.05 \text{ cm}$$

Water ht = 18.35 cm
 5 - Per

Temp $^{\circ}$ 23.7 $^{\circ}$

$$C = 73.88 \text{ sec} = 12.4 \text{ f} = 11.8 \text{ f/cm}$$

1433 Water ht = 17.30 cm

system just critical
 Drain.

Removed 9 rods, 1 from each corner.
 Have an 22×22 array, with 39 rods
 removed from each corner. Total of
 328 rods.

Water ht = 27.60 cm

6 - Per

$$C = -1499.4 \text{ sec} = .89 \text{ f}$$

1455

Drain.

A. 95

1.30" rods.
1.530 cm separation e-e
30 cm length.

45


Added 1 rod. Have an 22x22 array, with
38 rods removed from 1 corner, and 39
rods removed from 3 corners. Total
of 329 rods.

Water ht = 27.60
+ Per

$C = 171.68 \text{ sec} = 6.31$

1517 Water ht = 19.95

System just critical
Drain.



Now have an 20x20
removed from each corner. Total of
328 rods.

Water ht = 27.60 cm

$d_h = 9.0 \text{ cm}$

Temp °C

+ Per.

24.1 °C

$C = 65.19 \text{ sec} = 13.64 = 1.5 \text{ f/cm}$

1552 Water ht = 18.60 cm

System just critical
Drain.

added 1 rod. 16

38 rods removed

rod removed from

of 329 rods.

$dh = 7.65 \text{ cm}$

Water ht = 27.60 cm

⁷ + Per

Temp °C

23.9 °C

$U = 171.68 \text{ cm} = 6.34 = .82$

1517 Water ht = 19.95 cm

system just critical

Drain.

Now have on 20x20 array, with 18 rods

removed from each corner. Total of

328 rods.

$dh = 9.0 \text{ cm}$

Water ht = 27.60 cm

⁸ + Per.

Temp °C

24.1 °C

$U = 65.19 \text{ cm} = 13.64 = 1.54/\text{cm}$

1552 Water ht = 18.60 cm

system just critical

Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SET	START-UP RANGE
K-1	3K10 ⁻¹²	Meter	1"	10K10 ⁻¹²
"	"	Fast	"	"
K-2	"	Meter	"	3K10 ⁻¹²
"	"	Fast	"	"
R-1				
R-2				
PM-1	700V	Alarm	1.5"	500V
PM-2	1200V	Low	10"	900V
"	"	Alarm	1"	"
LOG N CALIBRATE		OPERATE	SOURCE No.	B-90
DUMP WELL PROBE LIGHT				

START-UP CHECK LIST

Equipment checked by I. D. C. Personnel check by I. D. C.

Instruments and safeties checked and reset by A. K. M.

Source in checked by A. K. M. Source No. 19-43

Emergency equipment in cont. of probe checked by I. D. C.

Instruments in trip circuit: R-1-2 PM-1-2

Red light on by A. K. M. Time 0800

Start-up OK'd by F. D. C. A. K. M. Date 9-24-69

130" rods,
1,530 cm separation e-e,
30 cm length.

47

Repeat of last experiment (p-95).

Have an 20×20 array, with 18 rods removed from each corner. Total of 328 rods.

Water ht = 27.60 cm $\phi = 9.0$ Temp $^{\circ}$
+ Per 23.6° 23.6°

$$G = 60.8 \text{ f sec} = 14.3 \text{ f} = 1.6 \text{ f sec}$$

0843 Water ht = 18.60 cm

System just critical
Drain.

Removed 2 rods, 1 each from opposite corners.
Have an 20×20 array, with 18 rods removed from 2 corners, and 19 rods removed from 2 corners. Total of 326 rods.

Water ht = 27.60 cm Temp $^{\circ}$
+ Per 23.7°

$$G = -1673.2 \text{ sec} = -80 \text{ f}$$

0917 Drain

over:

21 1.530 cm separation C-C.
30 cm lengths.

added 1 rod. Now have an 20x20 array,
with 19 rods removed from 1 corner, and
18 rods removed from 2 corners. Total
of 327 rods.

$D_4 = 7.65$


Water ht = 27.60 cm
+ Per

Temp °C
23.7 °C

$T = 176.01 \text{ sec} = 6.2 \text{ f} = .81 \text{ f/cm}$

0940 Water ht = 19.95 cm

System just critical
Chain



9/24/69: 20x20 array
 (with 18 rods removed
 from 3 corners & 19 from
 1 corner. Total rods: 327
 1.53 cm sep-
 aration C-C. 30 cm
 length. p. 48

2) 100" rods.
1.530 cm separation c-c. 49
60 cm lengths.

Have an 18 X 18 array, with 15 rods removed from each corner. Total of 264

1300 Water ht = 25.60 cm Temp °C
System just critical 23.8°C
Drain.

Removed 24 rods. 6 from each corner.
Have an 18 X 18 array with 21 rods removed from each corner. Total of 240 rods.

1336 Water ht = 35.80 cm Temp °C
System just critical 23.7°C
Drain.

Removed 15 rods. Now have an 17 X 17 array with 16 rods removed from each corner. Total of 225 rods.

1419 Water ht = 57.60 cm Temp °C
System sub-critical 23.7°C
Drain

over:

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE RANGE	SET	START-UP RANGE
K-1	3×10^{-12}	MANUAL ✓	1"	✓	10×10^{-12}
"	"	" ✓	"	✓	"
K-2	"	MANUAL ✓	"	✓	3×10^{-12}
"	"	MANUAL ✓	"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	5"	✓	500V
PM-2	1200V	Low ✓	11"	✓	700V
"		Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. B-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by ^{F.O.C.} A.K.D. Personnel check by E.P.C.

Instruments and safeties checked and reset by A.K.D.

Source in checked by A.K.D. Source No. M-93

Emergency equipment in control room checked by F.O.C.

Instruments in trip circuit: R-1-2 PM-1-2

Red light on by A.K.D. TIME 1025

Start-up OK'd by F.O.C. A.K.D. Date 9-25-69

21 1.53" rods.
1.53 cm separation e-e
60 cm length.

Added 9 rods. Have an 17x17 array,
with 15 rods removed from each
corner. Total of 229 rods.


Water ht = 57.60 cm $b_s = 11.95 \text{ cm}$ Temp =
7.8°C 24.0°C

$t = 71.71 \text{ mm} - 12.74 = 1.14 / \text{cm}.$

1514 Water ht = 45.75 cm
System just critical
Drain.

Removed 1 rod. Have an 17x17 array
with 15 rods removed from 3
corners and 16 rods removed from
1 corner. Total of 228 rods

1537 Water ht = 57.55 cm
System just critical
Drain.



2) 103^{rd} rods.
 1.530 cm separation e-e
 60 cm length.

Added 9 rods. Have an 17×17 array,
 with 15 rods removed from each
 corner. Total of 229 rods.

Water ht = 57.60 cm $b_s = 11.85 \text{ cm}$ Temp $^{\circ}\text{C}$
 Flow 24.0°C
 $E = 71.71 \text{ cm} \sim 12.74 = 1.14/\text{cm}.$

1514 Water ht = 45.75 cm
 System just critical
 Drain.

Removed 1 rod. 16
 with 15 rods remain
 corners and 16
 1 corner. Total of

1537 Water ht = 57.55 cm Temp $^{\circ}\text{C}$
 System just critical 24.1°C
 Drain.

52

103 rods.
1.30 cm separation c-c.
30 cm length.

Have an 22×22 array, with 21 rods removed from each corner. Total of 400 rods.

1105 Water ht = 27.50 cm Temp °
System sub critical 23.6 °
Drain.

added 84 rods. Have an 22×22 array. with Total of 484 rods. (Full grid plate).

Water ht = 27.60 cm $dh = 9.15$ Temp °
' + RY 23.7 °

$47.81 \text{ mm} = 16.9 \phi = 1.8 \phi$

1255 Water ht = 18.45 cm
System just critical
Drain.

p-53

Removed 10 rods, 2 each from 2 opposite corners and 3 each from 2 opposite corners. Now have and 22x22 array with a total of 474 rods.

1320

Water ht = 27.65 cm
 System sub critical
 Drain

Temp °C
 23.8°

~~Added~~ Added 2 rods, 1 each to opposite corners. Now have an 22x22 array, with with 2 rods removed from each corner. Total of 476 rods.

Water ht = 27.60 cm
 2-per

Temp °C
 23.9°

1340

N.G
 Drain

act:


.03" rods.
1.30 cm separation C-C.
30 cm length.

added 2 rods, 1 each to opposite corners.
Now have an 22x22 array. With
1 rod removed from 2 corners and
2 rods removed from 2 corners. Total
of 478.

Water ht =
3 + Per

$$C = 1477.6 = .867$$

1409 Water ht = 2
feet
Drain.



9/25/69: 22x22 array
with 1 rod removed from
2 corners & 2 from 2 co-
ners. Total rods: 478
0.03" rods. 1.30 cm
separation C-C. 30 cm
length. p.54

Removed 1 rod
with 2 rods
and 1 rod removed from 1 corner.
Total of 477 rods.

1436 Water ht = 27.60 cm

4 - Per

Temp °C
24.0°C

$$C = -2542.4 \text{ sec} = -.52 \text{ f}$$

Drain:

added 2 rods
 Now have
 1 rod remain
 2 rods remain
 of 478.

Water ht = 27.60 cm $\delta h = 3.8$ cm Temp $^{\circ}$
 $^{\circ}$
 3 + Per 23.9 $^{\circ}$

$$E = 1477.6 = .86 f = .22 f/cm$$

1409 Water ht = 23.80 cm
 system just critical
 Drain:

Removed 1 rod. Now have an 22x22 array
 with 2 rods removed from 3 corners,
 and 1 rod removed from 1 corner
 Total of 477 rods.

1436 Water ht = 27.60 cm Temp $^{\circ}$
 4 - Per 24.0 $^{\circ}$

$$E = -2542.4 sec = -.52 f$$

Drain:

03" rods.
 1130 cm separations e.e.
 60 cm lengths.

55

Have an 18x18 array, with 12 rods removed from each corner. Total of 276 rods.

1545 Water ht = 57.60 cm
 System sub critical
 Drain.

Temp °C
 29.0°C

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE RANGE	SET	START-UP RANGE
K-1	3x10 ⁻¹²	Meter ✓	1"	✓	10x10 ⁻¹²
"	"	Fast ✓	"	✓	4"
K-2	"	Meter ✓	"	✓	3x10 ⁻¹²
"	"	Fast ✓	"	✓	1"
R-1					
R-2					
PM-1	700V	Alarm ✓	15"	✓	500V
PM-2	1200V	Low ✓	10"	✓	900V
"	"	Alarm ✓	1"	✓	"

LOG N CALIBRATE

OPERATE

SOURCE No.

15-00

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by ^{F.D.C} ATM Personnel check by F.D.C
 Instruments and safeties checked and reset by ATM
 Source in checked by ATM Source No. M-43
 Emergency equipment in control room checked by F.D.C
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by ATM Time 0825
 Start-up OK'd by F.D.C ATM Date 9-26-69

.03" rods
 1.30 cm separation c-e
 60 cm length.

New base on 20x20 array, with 21
 rods removed from each corner. Total
 of 316 rods. (all usable rods)


0903 Water ht = 57.60 cm Temp °C
 system sub critical 23.7 °C
 Drain.

Moved 2 end rods on each corner, to center of each corner, (see diagram).
(all rods)

Still have an 20×20 array, with 21 rods removed from each corner.

0955 Water ht = 57.10 cm
System sub critical
Drain.

Temp $^{\circ}\text{C}$
73.9 $^{\circ}\text{C}$



Sample: Y-12 Reg II 684573

X-10

13-1A

sub for.

$Z_{B/l} = 0.209$
Density = 0.9972
Temp $^{\circ}\text{C} = 25^{\circ}\text{C}$

sub for.

$Z_{B/l} = 0.20$
Density = 0.9974
Temp $^{\circ}\text{C} = 25^{\circ}\text{C}$

10-1-69 H₃BO₃ solution reanalysis.

#13

#11

obs for
 Reg # Y-12-684574
 $g/l = 0.208$
 density = 0.9972
 Temp °C = 25°

Reg # Y-12-684575
 $g/l = 0.202$
 density = 0.9974
 Temp °C = 25°

#13 - X-10 13-1A

#11 - X-10 11-1A

obs for
 $g/l = 0.207$
 density = .9977
 Temp °C = 25°

$g/l = 0.201$
 density = .9975
 Temp °C 25°

333
 ↓
 430/70
 # 3 P
 V D
 10