

BOOK 111R

Notes:

on front cover: "5296"

page 1 has red tab "Exponential (37 ½ %)"

page 9 has graph and 8.5x11 stapled to it

page 43 has 3 graphs attached

pages 47, 51, 82, 87, 155, 165, 169, 171, 173, & 271 each have 1 graph attached

page 57 has 2 graphs attached

page 63 has red tab "Solution 37 ½ %"

page 151 has red tab "37 ½ % Sol'n"

page 163 has green card attached

page 182 has small paper attached

page 198 has 2 small papers attached

page 199 has red tab "TSR-II Mockup"

page 296 has 1 graph attached and 1 sheet attached

Blank pages: 2, 16, 39, 62, 167, inside page opposite page 296

Scanned by:

Sheila Finch

RSICC /Oak Ridge National Lab.

March 2, 2001

~~SECRET~~

~~CONFIDENTIAL~~

EB Johnson

SOME INSTRUCTIONS FOR USE OF THIS NOTEBOOK

This notebook is assigned to personnel performing research and development work and must be used for all original calculations, notes and abstracts from reports.

Assignee is responsible for the safeguarding of this notebook in accordance with security regulations.

By authority of:

CG-W-5

This notebook must be returned to issuing office when completed, or upon termination of assignee.

ADC or ADD signature (first reviewer)

Date

ADD signature (final reviewer)

Date

Every page or entry should bear a date and the signature of the person who made the entry.

Entries should be made in ink whenever it is reasonable to do so.

Alteration or amplification of entries made on previous dates should be made as separate entries under their own dates and cross referenced to the previous entries.

Charts, drawings and graphs drawn on special paper should be glued or otherwise securely fastened in place and should individually bear a date and signature. Do not obscure any information.

The notebook should be periodically reviewed by one or more independent persons in the department and should be signed and dated by them. Likewise, they should make a statement that they have "read and understood the foregoing material." Witnessing stamps for this purpose are available in your department's office.

It is advisable to preface each new item, such as a heat treatment, process or reaction, etc., with a very brief description of the purpose, objective or approach.

Description of the invention or discovery should be complete enough to be understood by anyone skilled in the art.

Reference to name or catalogue number should be made when standard items are being discussed, i.e., Westinghouse pump.

In cases where work is conducted in cooperation with others, it is often necessary to meet with them from time to time and discuss new developments. The occurrences of such conferences should always be entered in your notebook regardless of recording elsewhere, giving the date, who was present (if possible), and an outline of the subjects discussed. This often will establish error in occasional claims of other parties that you have appropriated information from them revealed during an interview, and thus provide you with patent protection.

~~SECRET~~

~~CONFIDENTIAL~~

10-9-20

~~SECRET~~

~~CONFIDENTIAL~~

INV 62

ORNL PHYSICS LABORATORY
UNIVERSITY OF TENNESSEE
ORNL/PHYSICS/ENR COMPANY
A DIVISION OF UNION CARBIDE AND CARBON CORPORATION

INV 68

EX 7

INV 83

INV 60

~~This document consists of _____ pages.~~
~~No. _____ of _____ copies, Series _____~~
POST OFFICE BOX P 40
KNOX, TENNESSEE
NOTEBOOK NO. 5296

INV 58

5-29-85

Assigned to: E. B. Johnson
A. D. Callihan
Department: Physics Div
Location: Bldg 9213
Date: July 12, 1956

INV 63

INV 68

INV 88

INV 89

INVENTORIED FEB 27 1975

This notebook is assigned to personnel performing research and development work and must be used for all original calculations, notes and abstracts from reports.

Assignee is responsible for the safe-guarding of this notebook in accordance with security regulations.

RESTRICTED DATA

Assignee is to record all personal conferences.

~~This document consists of _____ pages.~~
~~No. _____ of _____ copies, Series _____~~

INV 92

This notebook must be returned to Laboratory Records-Bldg. 4500 when completed or upon termination of assignee.

~~CONFIDENTIAL~~

~~This document consists of _____ pages.~~
~~No. _____ of _____ copies, Series _____~~

INV 90

INV 91

Subject
Exponential Exp
Fuel dump valve timing + safety
37 1/2 % Soln Exp
BSR fuel elements for TDR

INV 85

63
66-86/151-
88-150

INV 85

INV 86

INV 87


8-5-91
8/24/88

RESTRICTED DATA


"This document contains restricted data as defined in the Atomic Energy Act of 1954. The disclosure of its contents in any manner to any person is prohibited."

~~SECRET~~

Exponential Experiment 37 1/2% Enrichment



18x18x36" built up 3" above A1 table
 on 3x3x36" square A1 tubes (.069" wall)
 1" square hole 9" up (edge) + 1" west of center
 for inserting 235 fission counter



Classification changed to: U
 (Level and category)
 by authority of: CG-W-5 Topic 931.2
 (classification guide)
 ADC or ADD signature (final reviewer): David C. Hamman Date: 3/31/00
 ADD signature (final reviewer): _____ Date: _____

Expt. 1-1 Time 9³⁵ AM PM Date 3-15 1957
 Purpose Experimental exp - making neutron
Critical
 Personnel: _____

START-UP CHECK LIST

Equipment Checked by BWM Personnel Check by BWM
 Instrument and Safeties Checked and Reset by BW
 "Source In" Checked by _____ Source No. _____
 Emergency Equipment in Control Room Checked by BW
 Red Light On by TAF
 Start-Up OK'd by BW Time 9³⁵ AM PM Date 3-15 1957

INSTRUMENT CHECK

Date 3-15 1957 Time _____ AM PM Source No. _____

Instrument	Trip Value	Scale	Source Distance	Start-Up Scale
DC-1				
DC-2	<u>80</u>	<u>20x10</u>		
Log N	<u>60</u>	<u>10x100</u>		
R-1	<u>1000</u>	<u>P</u>		
R-2	<u>8</u>	<u>100x1000</u>		
P. M.	<u>1"</u>	<u>750V</u>		

Shlyn for fission counter with 4 set so that 0 = 0
 or movable table = 3 layers fuel $\frac{2}{3}$ layers plastic ($\frac{3}{4}$ "")
 fuel = $2 \times 18 \times 18$ - fuel = $18 \times 18 \times 86$ "

	C ₁	C ₂	C ₄	F.C. x16	C ₅	Log N	Dial
with source Table Apart	67+29	640+20	2+15	0+9	.00042		
Counting rate together was too high (.0009) with source 213							
No Source Table Apart	52+35	55+63	0	0			
Tables Together	38+29	70+19	0	0			
No 214 Tables Together	44+61	613+21	0+4	0+5	.00038		~.952
No 214 Tables Apart	41+55	398+50	4	1	.00026		~

Loading 1 ea 2" fuel layer 3 ea 3/4" plastic layers

43+0 699+40 10 2 .00043

Replaced last 3" on Fixed table with 2" fuel and 3/4" plastic

∴ when tables Together reactor is 5 layers fuel + 4 ea 3/4" plastic

49+0 870+26 143 0+14 .00055

Added 1 ea layer of fuel and plastic (6 layers fuel

59+1 1186+61 0+12 1+7 .00078

Added 1 ea layer of fuel and plastic to movable table (7 fuel layer)

100+38 2361+8 2+0 2+14 .00165

Added 1 ea layer of fuel and plastic

On movable Table 7 fuel + 6 plastic

On Fixed table 1 plastic + 35" of fuel

Critical

relygm = 0.38"

Level

C1 2969 x64

C2 jammed } 6 min

C4 118+2

C5 195+10 } x15

In N .12

R-2 32 1500 x 1000

DC-2 72 x 10 x 100

DC-3 35 x 10 x 100

R-1 62 500 x 100

INSTRUMENT CHECK					
Date	3-18	1957	Time	9:00	AM
			Trip		Source No.
Instrument	Value	Scale	Source	Distance	Start-Up Scale
DC-1					
DC-2	76	10 X 20			
DC-3	55	10 X 100			
Log N	7.30				
R-1	10	1000			
R-2					
P. M.	750				

Removed top row back edge ^{of movable table} - a total of 6 enriched blocks and replaced them with 6 depleted blocks

Expr.	1-2	Time	9:10	AM	Date	3-18	1957
Purpose	Exponential experiment - trimmed reactor to get better table position.						
Personnel:	TAE DWM DFC						

Positive period at .690 on dial .39 on cal
 leveled at $\ln = .12$ at .678 on dial .44 on cal.

Expr.	1-3	Time	10:07	AM	Date	3-18	1957
Purpose	Same - removing 2 horiz & 2 vert rows of fuel from Sector - replacing with depleted						
Personnel:	TAE DWM DFC						

total ²⁴ fuel blocks approx center of last vertical layer.

11:05
 $\ln N$.122
 R_2 38 x 500 x 1000
 DC-2 96 x 10 x 100
 DC-3 78 50 x 10
 R-1 2 50 x 1000
 CRM (C-1) 40 scale
 30 ppm

pos period $\ln = .36$ dial = .721
 level $\ln = .42$ dial = .700
 $\frac{5 \text{ min}}{C_4 \times 14} = 146 \pm 8$
 $C_5 \times 16 = 222 \pm 11$

Expt. <u>1-4</u>	Time <u>11⁴² AM</u>	Date <u>3-18</u>	195 <u>2</u>
Purpose: <u>of total 54 blocks now free</u> <u>16 are enriched and depleted</u>			
Personnel: <u>VAP DAC</u>			

11⁴² AM

Selwyn = 0.305 dial .774 pos period

Ln N .12 level dial .750 above 0.36

R 2 36 500 x 1000

DC-2 83 10 x 100

5 min

DC-3 75 50 x 10

Cy x 16 147 + 6

R-1 1.9 50 x 100

Cy x 16 236 + 0 > 1.60

CRM 38 (9 x 10)

Expt. <u>1-5</u>	Time: <u>1:50 PM</u>	Date <u>3-18</u>	195 <u>2</u>
Purpose: <u>Remove 16 enriched blocks</u> <u>layers now "depleted".</u>			
Personnel: <u>DWM TAF</u>			

1⁰³ PM Pos. Period Selwyn 0.163 Dial 912

" " .20 Dial .896

Ln N .115

R-2 36 1500 x 1000

5 Min Count

DC-2 84 10 x 100

Cy x 16 159 + 6

3 74 10 x 50

C5 x 16 250 + 7

> 1.57₄

R-1 3.3 200 x 100

CRM 420 C/M

Ln N = 1.4

Dial 896

5 Min Count

R-2 Suppressed

Cy x 16 582 + 47

160

CRM 6000 C/M

C5 x 16 937 + 2

R-2

Expr.	2-1	Time	2 ¹⁵ PM	Date	3-18	1957
Purpose	Fission Counter Transm.					
	same system as 1-5 instruments					
	moved back -					
Personnel:	TAF DWM DFC					

Lag N = 0.1

P.M. - 1130V
Tripped

Counting Time (min)	Proc.	C4	C5	C5/64
2	0	128+0	204+2	1.593
"	1	134+45	137+11	1.018
"	2	131+3	98+40	.752
"	3	133+55	81+46	.610
3	4	194+29	101+29	.522
"	5	190+5	93+23	.439
4	6	263+49	101+49	.397
4	8	261+37	80+20	.307
6	10	395+63	94+25	.239
6	12	389+43	76+60	.197
	14			
8	16	528+49	63+62	.121
	18			
10	20	659+24	49+61	.076
	22			
15	24	1022+27	50+21	.0493
2	24 24	x256 348+106	x64 69+47	.0493
5	28	988+5	104+24	.0294
8	30	1070+79	91+59	.0215
8	32	1430+23	97+52	.0171
10	34	1775+182	450+57	.0634
5	33	874+76	101+22	.029

Scale

64

at pm (Lag N = .1) at 2:27 PM

at Lag N = 1.0 4⁰¹ PM

← Raised Power level
Lag N = .94

Tripped P.M. - 1130V.

Shutdown at 5:09

at 5:11.5 down by 1000

574

160

INSTRUMENT CHECK					
Date	<u>Mar 19</u>	195 <u>7</u>	Time	<u>10⁵⁰</u>	AM PM Source No.
Instrument	Trip	Value	Scale	Source Distance	Start-Up Scale
DC-1					
DC-2		<u>82</u>	<u>10.820</u>		
DC-3		<u>57</u>	<u>10.8100</u>		
Log N		<u>7 sec</u>			
R-1		<u>7</u>	<u>10.8150</u>		
R-2					
P. M.		<u>750V</u>			

Expt.	<u>R-2</u>	Time	<u>11⁰⁰</u>	AM PM	Date	<u>3-19</u>	195 <u>7</u>
Purpose	<u>Check second fission counter 5-2</u>						
	<u>against #5-3</u>						
Personnel:							

DC-3 not moved
R-2 and DC-2 have been moved and surrounded with lead
stopped to repair counter 5-2 started up 1²⁵ PM

1³⁴ Pos Period Dial .919

1⁴⁰ start leveling

Counter -2 zeroed in at plastic face

C-4 (#5-3)

C-5 (#5-2)

Ln M ~ 0.105

317 x 64 + 47

490 x 64 + 10 1.545

R-2 65 x 1000 x 100

1⁴⁶ Shut down

DC-2 60 x 10 x 100

Expt. <u>2-3</u>	Time <u>2:30</u> PM	Date <u>Mar 19</u> 1957
Purpose <u>Counting Rec of S-2 in app. chm.</u>		
Personnel: _____		

2" of lead (total of 4") added around DC-2 & R-2
 #S-2 counter on channel 5 (normal center)

Normalizing counter still 5-3 on channel 8

U-Foil 3/4" OD in approx center of reactor

Started foil exposure at 2:46

2:49 ~~3:49~~ Levelled at dial reading .880 $\mu N = 1.0$

Time	Counting min	Pos.	C4 "	C5 "	$\frac{C5}{C4}$	μN	
2:49	3:49	5	4.00"	886 ⁺²⁵	371 ⁺¹⁰	.0268	1.0
2:55	3:55	5	6.00	820 ⁺¹⁷	267 ⁺⁹	.0208	0.92
3:01		5	8.00	818 ⁺²¹	206 ⁺¹¹	.0155	.96
		5	10.00	836 ⁺²⁴	166 ⁺⁷	.0125	.98
3:14		8	12.00	1357	212 ⁺⁶	.00976	.98
3:24		10	16.02	1743	165 ⁺⁶	.00592	.99
3:35		15	20.00	2607 ⁺¹⁵	160 ⁺⁰	.00384	1.0
3:51		15	24.00	2539	101 ⁺¹²	.00249	1.0
4:04		15	28.00	2611	63 ⁺¹²	.00266	1.0

4:26 Shut down (100' exposure) @ $\mu N = 1.0$

Foil wgt = 0.5017 gm Area = 7.08 cm^2 at 67 hrs.

$$\frac{7.08 \text{ cm}^2}{0.149 (0.03732) (.56)} = \frac{7.08}{3.115 \times 10^{-3}} = 2.273 \times 10^3 \text{ disintegrations/cm}^2$$

$$\frac{2.273 \times 10^3 \text{ dis/cm}^2}{(1.72 \times 10^4) (.1467) (.063) (.5017) (3.1 \times 10^{10})} = 0.922 \times 10^{-3} \text{ watts/gm or } 2.86 \times 10^7 \text{ fissions/cm}^2 \text{ gm}$$

Assuming uniform flux $0.922 \times 10^{-3} \text{ watts/gm} \times 83 \times 10^3 \text{ gm} = 76.5 \text{ watts}$
 measured by Donkerney-

Absolute Power Determination West end

Run = 100 min

Area = 7.08 counts/sec at 67 hrs

Foil = 0.5017 gm

$$\frac{7.08 \text{ c/sec}}{(.149)(.03732)(.56)} = \frac{7.08}{3.115 \times 10^{-3}} = 2.273 \times 10^3 \text{ Disintegrations/sec. of } \text{La}_{140}$$

crystal efficiency for 1.6 MeV γ solid angle (geom. factor) 56% of 8's are 1.6 MeV

$$\frac{2.273 \times 10^3 \text{ D/sec}}{(1.72 \times 10^{-2})(.1467)(.063)(.5017)(3.1 \times 10^{10})} = \frac{2.273 \times 10^3}{2.465 \times 10^6} = 9.22 \times 10^{-3}$$


Decay constant N La-140 fusion yield La-140 foil weight fusion/area

$0.922 \times 10^{-3} \text{ WATTS/gm.}$ OR $2.86 \times 10^7 \text{ Fissions/sec-gm}$

Assuming uniform flux

$$0.922 \times 10^{-3} \text{ w/gm} \times 83 \times 10^3 \text{ gm} = 76.5 \text{ WATTS}$$


→ AH



INSTRUMENT CHECK				
Date	3-20	1957	Time	3:00 PM
		Trip		Source No.
Instrument	Value	Scale	Source Distance	Set-Up Scale
DC-1				
DC-2	74	10 X 20		
DC-3	55	10 X 100		
LOG N	7 sec			
R-1	7	10 X 1000		
R-2	Responds:			
P. M.	263 V			

Expr.	3-1	Time	3:10 AM	Date	3-20 1957
Purpose	Transverse in horizontal direction perpendicular to exponential dimension				
Personnel:	TAE DWM DFC				

Restacked for horizontal transverse novel counter drive. Monitor counter 8" from plastic in longitudinal dir.



west or east faces.

zeroed tip of counter to end of assembly
 Transversing counter is 5-2 - C5
 Normalizing counter is 5-3 - C4

3:20 Position period at .885 on dial and .20 on relay
 Start .37 on log N at 3:29:22
 3:32 Levelled at .859 on dial .25 on relay

Counting Time	Pos.	C ₄ (x256)	C ₅ (x64)	C ₅ /C ₄	Log N	Time
5 min	0	225 ⁺⁷²	253 ⁺²⁷	.282	1.0	3:32
"	1.00	226 ⁺⁷³⁰	271 ⁺¹²	.299	1.0	
4	2.00	183 ⁺⁷⁰	246 ⁺¹⁰	.336	1.0	3:46
3	3.00	135 ⁺⁸²	201 ⁺¹²	.372	1.0	3:49
3	4.00	186 ⁺²³	219 ⁺⁵³	.403	1.0	
3	5.00	134 ⁺²¹⁷	232 ⁺⁵¹	.433	1.0	3:58
3	6.00	184 ⁺¹⁰²	238 ⁺¹⁹	.445	1.0	4:01
3	7.00	133 ⁺²⁷⁴	283 ⁺⁴⁴	.455	1.0	4:05
3	8.00	183 ⁺²⁰³	240 ⁺¹¹	.449	1.0	
3	9.01	133 ⁺²¹¹	227 ⁺³²	.426	1.0	
3	10.00	131 ⁺²⁰²	213 ⁺²⁹	.405		
3	11.00	131 ⁺²⁰⁰	199 ⁺²¹	.378		
4	12.00 13.02	174 ⁺¹⁹³	234 ⁺²³	.335		
4	13.12	172 ⁺⁸³	199 ⁺⁴⁵	.290	.94	
5	14.00	208 ⁺¹⁷⁶	200 ⁺¹⁹	.240		
6	15.00	254 ⁺¹⁶⁴	200 ⁺⁴	.197	.96	
7	16.00	303 ⁺¹⁷⁰	300 ⁺¹¹	.247	.96	4:46
3	17.00	216 ⁺²¹¹	289 ⁺³⁰	.334	.97	4:55
3	18.00	132 ⁺²⁴²	183 ⁺⁶³	.346		
3	-1	134 ⁺¹⁵	198 ⁺²⁵	.370		
3	-3	136 ⁺²⁸	348 ⁺¹⁹	.64		
3	20.00	138 ⁺¹⁴	209 ⁺⁵³			

1 h.


4 p.

5:18 PM Scrammed manually to shut down -

INSTRUMENT CHECK				
Date	3-22	1957	Time	9:40
	Trip		Source	Y
Instrument	Value	Scale	Range	Scale
DC-1				
DC-2	72	10X20		
DC-3	55	100X10		
Log N	7 sec			
R-1	13	10X10		
R-2				
P. M.	1/2"	7500		

Expr.	4-1	9:45	3-22	1957
Purpose	Traverse in verticle dimension on cylindrical pile - surrounded on top and sides by cadmium			
Personnel:	TAF, B.F.C., B.W.M.			

Reattached for verticle traverse - monitor counter 8" from placis as in 3-1



- 850 Started moving table
- 905 On positio period dial - .866 - selcyn .21 (450 sec period)
- 910 Levelled at .834 on dial .28 on selcyn

Counting time	Poz	$C_4 (x 256)$	$C_5 (x 64)$	C_5/C_4	$\log N$	Time
3	18.05	168 ⁺¹¹	184 ⁺⁸	.278		9:11
3	16.04	166 ⁺²⁰²	231 ⁺⁹	.348		
2	14.01	111 ⁺⁴⁵	179 ⁺³⁸	.403	1.03	9:19
2	12.01	109 ⁺¹¹⁶	189 ⁺²⁰	.433	1.00	
2	10.97	107 ⁺²¹⁰	185 ⁺³⁶	.433		
2	10.01	101 ⁺²³⁴	171 ⁺⁴²	.423	.98	
3	8.02	148 ⁺¹⁷¹	227 ⁺⁸	.394	.95	
3	5.97 6.00	145 ⁺⁷	180 ⁺⁵¹	.312		
4	5.01	97⁺²⁵⁰	100⁺¹⁴	.255		
4	5.01	195 ⁺⁸⁸	201 ⁺⁵⁰	.259	.92	
5	3.99	248 ⁺⁴⁴	209 ⁺⁴²	.212	.94	
6	3.02	307 ⁺⁵¹	194 ⁺³⁶	.158	.92	
7	1.99	348 ⁺³⁴	188 ⁺⁴²	.135	.92	
7	0.99	341 ⁺²³²	205 ⁺²⁸	.155		10:00 10:00
6	0.00	289 ⁺⁸⁶	262 ⁺⁸	.227	.92	
2	13.00	94 ⁺¹⁵⁴	163 ⁺³⁶	.433		
2	12.00	96	164 ⁺⁵⁶	.428	.92	
2	12.00	94 ⁺¹⁰⁵	162 ⁺³	.428	.92	

Shut down at 10:24

Removed Cadmium for vertical traverse

Expr. 4-2	Time 1 ³⁰ AM	Date 3-22 1957
Purpose: Vertical traverse on Exp column		
Personnel: DWN TAF DFC.		

Monitor counter C-4 (#5-3)

Traversing Counter C-5 (#5-2)

1³⁰ Start tables Together.

1 ³⁵	$\ln N = .0001$	1 ⁴³	.01	80 sec P.	$\frac{2'55''}{\text{count}}$
1 ³⁹ ^{1/2}	$\ln N = .001$	1 ⁴⁶ ⁵⁵	.1	80 sec P.	

1⁵¹ $\ln N = 1.0$ start leveling
 On period delay 0.218

at Critical { 600 mR/HR at Door to 20/
 2 mR/HR at console in control Room
 6 mR/HR at window surface

1 MIN after Shutdown 40 mR/HR at Door to 20/
 .1 mR/HR at console.


counting time	Position	c ₄	c ₅	c ₄ /c ₅	ln N	R-1
		64				
4	17.99	716 ¹⁴	204 ⁶⁰	.286	0.86	4.0 x 1000 x 1000
4	2 ^{PM} 16.88	756 ²⁵	243 ²⁰	.321	.90	
4	16.02	709 ⁵⁹	253 ²⁷	.357	.86	
4	15.00	747 ⁶²	290 ⁵³	.376 ^{.389}	.89	
4	13.88	783 ²⁶	323 ²⁶	.414	.92	
3	13.01	618 ⁵⁰	267 ³¹	.432	.96	
2	11.99	402 ²¹	178 ⁵⁷	.445		
2	11.01	389 ²⁶	176 ¹⁸	.453	.94	
2	9.91	385 ¹⁸	168 ³⁵	.437	.92	
4	9.01	753 ²⁷	310 ⁺²	.411	.88	
4	8.02	741 ³²	291 ⁺⁵⁰	.394	.88	
4	7.00	741 ³⁵	262 ⁺⁹⁵	.354	.88	
4	6.00	729 ¹⁴	226 ⁺²⁸	.311	.86	
5	5.01	898 ³¹	238 ⁺⁴⁹	.271	.86	
5	4.01	884 ¹²	194 ⁺⁴²	.220	.84	
85	2.98	877 ³¹	163 ⁺⁴⁶	.187	.84	
7	2.00	1208 ²¹	358 ⁺⁴	.216 ^{.296}		
4	1.00	669 ⁴⁸	256 ⁺¹⁶	.383	.82	3.7 x 10 ⁶
4	.00	654 ⁰	259 ⁴²	.387		

Expt. 5 Time 10¹⁵ AM Date 4-29 1957
 Purpose Exponential Exp modeling of 18 1/2% using
see diag source reactor above
 Personnel: TAF DPK

INSTRUMENT CHECK

Date 4-29 1957 Time 1²⁰ AM Source No. 8

Instrument	Valve	Seals	Source Distance	Start-Up Scale
DC-1				
DC-2	<u>62</u>	<u>10x20</u>		
DC-3	<u>62</u>	<u>10x20</u>		
Log N	<u>True</u>			
R-1	<u>2 on 10 x 1000</u>			
R-2	<u>response</u>			
P. M.	<u>750V</u>			



Assembly on 3" square Al honeycomb on before last exponential is wrapped in Cadmium (60 mil)
 Center section of Exponential column built up of 2x2x2" increments in 1:1 ratio (enriched to depleted) with grosser elements on each end of same ratio but of 2x2x3" increment -

Column is 22" square with re-entrant tubes (3/4" ID) built in for horiz - vert & long transverse. Tubes in 1" holes built into assembly in center section (22x22x16") (over)

Instruments approximately same location
as Orig Exp 1
For Vertical traverse sleye reads 0.0 at
top of assembly.

2:15 PM - start telescoped = 6" / 35 sec

levelled at dial reading of .824 sleye .305

log $N = 4.4$ $R-1 = 3.75 \times 1000 \times 1000$

Comp log $N = .02$

G. M. Gurney reading at console 2 m/hr
1 min counting rates $C_4 = 36^{+164}$ $C_5 = 17^{+100}$

X 256

Counting time	pos. $\$4$	C ₄	C ₅	C ₄ /C ₅	Ln N	start time
5 min	0.01	176 ⁺¹⁷¹ _{.67}	84 ⁺⁵⁶ _{.22}	.477	4.8	3:21
5 min	1.99	190 ⁺⁵⁴ _{.21}	54 ⁺⁷⁴ _{.29}	.285	4.4	
5 min	3.99	203 ⁺²⁴ _{.10}	46 ⁺¹⁴⁶ _{.57}	.229	4.6	3:32
5 min	5.00	193 ⁺⁴¹ _{.16}	51 ⁺⁹ _{.04}	.264	4.6	
4 min	6.00	147 ⁺¹⁹	46 ⁺⁵⁴	.313	4	3:44
3 min	8.00	107 ⁺¹	43 ⁺¹⁶⁴	.402		3:49
2 min	10.04	69 ⁺¹¹⁹	32 ⁺¹⁸⁷	.472	4.3	
2 min	12.01	68 ¹³⁶	36 ⁸³	.531		
2 min	14.02	73 ⁺⁸	40 ⁺⁷⁷	.548	4.54	3:58
2 min	16.01	75 ⁺¹⁴⁸	39 ⁺²³⁰	.528		
3 min	18.01	120 ⁺¹⁶⁰	58 ⁺¹⁴	.479	4.6	4:04
3 min	20.05	121 ⁺³⁸	50 ⁺⁹⁰	.413	4	4:11
3 min	22.02	121 ⁺¹¹⁴	39 ⁺²⁵³	.33	4.8	
2 min	17.03	80 ⁺¹¹³	41 ⁺¹⁰²	.512		
2 min	11.02	81 ⁺⁰	41 ⁺¹²⁴	.506		
2 min	12.51	81 ⁺¹¹ _{.043}	42 ⁺²⁰⁷ _{.441}	.525		
2 min	13.00	80 ⁺¹⁰⁰ _{.591}	43 ⁺⁵³ _{.207}	.538		
2 min	13.51	80 ⁺¹⁴¹ _{.55}	44 ⁺¹⁷¹ _{.107}	.554		
2 min	14.15	79 ⁺¹⁶⁰ _{.625}	44 ⁺¹⁹³ _{.75}	.561		
2 min	15.07	79 ⁺²²⁴ _{.882}	43 ⁺¹²³ _{.481}	.544		
2 min	15.53	78 ⁺²¹⁹	43 ⁺⁶⁴ _{.25}	.549		
2 min	12.04	78 ⁺⁴² _{.164}	41 ⁺¹⁵⁹ _{.62}	.532		
2 min	14.04	79 ⁺⁷¹ _{.277}	43 ⁺⁷² _{.098}	.544		
2 min	14.52	78 ⁺¹⁷⁰ _{.665}	43 ⁺¹³⁵ _{.722}	.556		
2 min	14.52	77 ⁺⁴² _{.164}	42 ⁺¹²² _{.481}	.550	4.6	

Shutdown by manual screen at 4:45 PM

INSTRUMENT CHECK				
Date	4-10	1957	Time	9:45 AM
				Source No. 8
Instrument	Value	Scale	Source Distance	Quality Scale
DC-1				
DC-2	62	10x70		
DC-3	62	10x100		
Log N	7.0			
R-1	10	10x1000		
R-2				
P. M.	11			

Expt.	5-2	Time	9:45 AM	Date	4-10 1957
Purpose	Horizontal traverse of same assembly as 5-1.				
Personnel:	TAP D&C				

0.0 on relay is East face of assembly.

10³⁰ log N at 0.8 projected to 100m above at 0.25 dial at 840

10³⁵ level at 0.821 log N = 4.4 R-1 = 3.8

Time
starts counting

		Poo.	C ₄	C ₅	C ₄ /C ₅	log N	R _i (1000 x 1000)
10 ³⁷	5	0.0	194 ⁺⁷⁶ .295	41 ⁺⁶⁹ .27	.212	4.4	3-8
10 ⁴⁶	3	2.00	116 ⁺¹⁹² .75	32 ⁺⁸⁴ .355	.278	4.6	
10 ⁵¹	3	4.00	105 ⁺²⁹ .113	35 ⁺⁶⁷ .261	.335	4.3	
	3	5.01	104 ⁺³⁵ .137	38 ⁺⁶⁵ .254	.367	4.3	
	3	6.00	104 ⁺²⁰⁴ .793	41 ⁺²¹⁹ .85	.399	4.2	
	3	2.00	114 ⁺¹²⁶ .493	45 ⁺²³² .908	.401	4.5	
	2	8.01	79 ⁺²¹⁸ .87	33 ⁺⁸⁸ .304	.419	4.6	
	2	9.02	82 ⁺¹⁷² .672	34 ⁺²²⁷ .826	.422		
	2	10.01	83 ⁺²⁵³ .705	35 ⁺²⁷ .34	.421	4.7	4.1
	2	11.04	82 ⁺²⁰⁵ .798	33 ⁺²⁵¹ .251	.410	4.8	
	3	12.04	124 ⁺⁷⁷ .3	48 ⁺¹⁰ .10	.3865	4.7	
	3	13.00	122 ⁺²⁹² .37	45 ⁺¹⁵⁴ .63	.373	4.7	
	3	14.00	120 ⁺¹⁰⁹ .425	41 ⁺²⁴² .942	.348		
	4	15.01	155 ⁺²⁵⁴ .236	49 ⁺¹⁰⁸ .164	.317	4.6	
	4	16.02	152 ⁺¹²⁷ .922	42 ⁺⁰ .64	.280		
	5	17.01	182 ⁺⁷² .495	44 ⁺⁰ .0	.242		
	5	19.00	175 ⁺²³³ .282	29 ⁺²⁰¹ .785	.170		
	5	21.02	167 ⁺²³³ .91	49 ⁺¹⁹⁵ .74	.296	4.2	
	3	3.00	129 ⁺³¹ .121	39 ⁺²⁸⁰ .9	.309		
	3	7.50	92 ⁺¹⁰⁹ .425	39 ⁺²⁹ .113	.423		
	3	8.51	91 ⁺¹⁷ .044	38 ⁺²⁰⁷ .546	.423		
	3	9.50	87 ⁺¹³³ .52	37 ⁺¹⁶⁴ .25	.426		3.2
	4	10.50	113 ⁺²⁴⁶ .96	47 ⁺¹⁷⁹ .70	.418		
	4	10.50	107 ⁺¹⁶⁵ .642	45 ⁺³⁵ .136	.418		

Expr. 5-3 Time 10¹⁵ AM Date 4-11 1957
 Purpose Pulse ht analysis on channel 4
 Personnel: TAF D E McC BAC

*C₄ - fixed
at horiz transducer
11" in*

INSTRUMENT CHECK

Date 4-11 1957 Time 10¹⁵ AM Section No. 8

Instrument	Value	Scale	Serial No.	Range	Accuracy Scale
DC-1					
DC-2	<u>50</u>	<u>10x20</u>			
DC-3	<u>50</u>	<u>10x100</u>			
Log N	<u>2.00</u>				
R-1	<u>10</u>	<u>10x1000</u>			
R-2					
P. M.	<u>3"</u>				

*C₅ - transducer
in longitudinal
channel*

10³⁰
10⁴²
10⁴⁶

Start up -
Pos Period Selayer 0.25
limiting at log N = 0.1 dial = .819

log N limited at 0.038 - R-2 200 x 1000 = 60
 DC-2 - (50) 5x10
 DC-3 (27) 100 x 10
 R-1 (2) 200 x 1000
 C₅ x 256 @ +212 (3 min)

10⁵⁸ limiting log N = 1.0 dial = 0.819
 1/3 | C₅ = 10⁺⁹³

DC-2 = 47 on 10 x 100
 R-1 = 2.1 200 x 1000

Comp log N = .0015

11⁰² C₅ 10⁺⁶² 3 min on x 256 2622
 10⁰⁷ 9⁺²⁴⁴ 3 min 256 2538
 10¹¹ 10⁺¹⁰² 2462

$$\begin{array}{r} 2560 \\ 170 \\ \hline 3 \overline{) 2730} \\ +170 \end{array}$$
 11^{AM} 3 min C₅ + 256 10 + 170 (510) c/min

C₅ in long channel at 0.0 = edge of 2x2x3 transition element

11¹⁶ PHA on C₅ at 0.0 C₄ mountain
 C₄ | 3 min | 4 + 163 = 1187

11²⁵ C₅ at 0.0 C₄ x 256 (5 min) 7 + 101 = 1893

11³² C₅ at 6.00 C₄ x 256 | 3 min | 4 + 144 = 1168

11⁴¹ C₅ at 9.00 C₄ x 256 | 3 min | 4 + 78 = 1102

11⁴⁷ C₅ at 14.01 C₄ x 256 | 3 min | 3 + 235 = 1003

11⁵² AM C₅ at 3.01 C₄ x 256 | 3 min | 4 + 98 = 1202

12⁰⁰ Shut down -

24

4-12-57

675-4

Expt.	5-4	Time	2:45	PM	Date	4-12	1957
Purpose	Comprehensiv. traverse on same 18" exp. also 2 foil irradiated						
Personnel:							

INSTRUMENT CHECK					
Date	4-12	1957	Time	2:45	AM
					PM Source No.
			Trip		
Instrument	Value	Scale	Source	Distance	Start-Up Scale
DC-1					
DC-2	50	10 x 20			
DC-3	58	10 x 10			
Log N	7.2				
R-1	8	10 x 100			
R-2					
P. M.	1"				

U-25 foil # 595 wgt 0.4957 gm wrapped in Al foil & loaded in reactor in center fuel element - foil oriented vertically & horiz.

foil # 0 wgt .4570 gm on Exponential assembly



foil at interface between 6" source plate

+ 6" transition element.

3:50 Start

3:14:58 log N = 1 at start of foil Exp. -

	Pos	$\times 256$ C4	$\times 256$ C5	$c5/c4$	log N
3 ²¹	(2) 0.0	40 ¹⁴⁷	35 ⁺²¹⁴	2	2.5
		27 ⁺¹¹³	73 ⁺¹⁷¹	2.66	
3 ²²	4 1.0	28 ⁺¹⁴⁸	67 ⁺¹³⁶	2.36	2.6
	4 2.0	29 ⁺¹⁴¹	62 ⁺¹⁶⁰	2.14 2.14	2.65
3 ²⁵	4 4.0	29 ⁺¹⁸³	46 ⁺¹⁴⁷	1.59	
3 ⁴⁰	4 6.0	29 ⁺⁷¹	36 ⁺²⁰³	1.25	
3 ⁴⁶	5 8.0	36 ⁺¹⁹⁴	36 ⁺¹³⁷	0.995	
	5 10.00	86 ⁺¹⁶⁴	28 ⁺⁷⁹	.773	
	7 12.00	51 ⁺¹⁴⁷	29 ⁺¹³⁵	1.572	
	10 14.00	74 ⁺¹⁸⁷	32 ⁺¹⁸⁶	1.423	
	12 16.02	91 ⁺⁶	28 ⁺¹⁹⁷	1.305	2.8
4 ²⁷	2 18.00	89 ⁺⁹¹	18 ⁺¹⁵⁷	1.208	
	4 3.00	28 ⁺¹⁹⁷	52 ⁺²⁴⁵	1.84	

Shutdown at 4:44:58 PM = 90 min Exp.

$$\text{avg } \gamma/m \text{ C}_4 = \frac{55259 \times 256}{75} = \frac{141,46304}{75} = 1,88614/m$$

INSTRUMENT	
Date	4-15 1957 Time 1:00
Instrument	Tube
DC-1	
DC-2	90 X 10 X 20
DC-3	60 X 10 X 100
Log N	1 sec
R-1	10 X 100 X 1000
R-2	
P. M.	750 V

Expt.	5-5	Time	1:15	Date	4-15 1957
Purpose	Comparison of U-235 and U-238 fission counters by making longitudinal traverse with U-238 counter S-2				
Personnel:	JAF	DEC	DWM		

U-238 fission counter S-2 used for traverse along longitudinal dimension of exponential pile.

140 Positive period at 0.845 on dial delay at 0.27
 157 Levelled at $\ln N = 3.4$ and 0.823 on dial
 R-2: 65 X 1000 X 100
 Compensated $\ln N = .008$

	P_{00}	C_4	C_5	c_5/c_4	$\log N$
1.5 (5)	1.0	42^{+123}	2^{+153}	} .0648	3.4
(5)	1.0	44^{+236} 87^{+103} 40^{+56}	2^{+245} 5^{+144}		3.6
		$X 64$	$X 16$		
<u>2.08</u> (10)	2.00	430^{+23} $(21,540)$	95^{+9} (1529)	.0555	3.5
<u>2.20</u> (10)	3.00	411^{+28} (26330)	81^{+12} (1308)	.0497	3.4
<u>2.30</u> (10)	4.01	417^{+63} (26750)	70^{+10} (1170)	.0423	3.5
<u>2.41</u> (10)	5.005	441^{+42} (28210)	63^{+14} (1032)	.0362	3.6
<u>2.52</u> (10)	6.00	462^{+1} $(29,570)$	67^{+10} (1072)	.0363	3.8
<u>3.03</u> (10)	7.00	444^{+32} (28480)	53^{+9} (857)	.0301	3.8
<u>3.4</u> (15)	8.00	595^{+44} $(36,100)$	59^{+6} (950)	.0249	3.7
<u>3.32</u> (20)	10.00	775^{+37} $(49,600)$	62^{+10}	.0209	
<u>3.51</u> (10)	2.01	397^{+261} (255)	88^{+3} (411)	.0554	
<u>4.02</u> (10)	6.00	393^{+60} (2521)	58^{+2} (850)	.0337	
(10)	7.00	396^{+32} (254)	47^{+11} (763)	.0302 .0302	
		35 3094			

2 min after shut down: 40 m/s at door & Pen 201

$$C_4 \frac{353,094}{135} = 2615.5 \text{ c/min avg}$$

To normalize Pen 5-5 to 5-4 multiply 5-5 values by 0.721

INSTRUMENT CHECK

Date 5-2 1957 Time 12³⁰ ^{AM} PM Source No. _____

Instrument	Trip Value	Scale	Source Distance	Start-Up Scale
DC-1				
DC-2	95	10x10		1x5
DC-3	60	10x100		1x5
Low P.	7000 <i>per cent</i>			
R-1				100 x 10
R-2				100 x 10
P. M.	750V			750V

*vertical 0.0 = all out
28.0 = all in*

*C-4 - 5-3
disc. - 20 Gain 16*

*C-5 = 5-2 (longitudinal)
0.0 = all in
disc. - 20 Gain 16*

Expr: 6-1 Time _____ AM PM Date 5-2 1957

Purpose Epp - 1'1" rate - 4x4x4" units
2.8" with 3" now 37 1/2%

Personnel: DWM, DRC

START-UP CHECK LIST

Equipment Checked by DR Personnel Check by DWM


Instrument and Safeties Checked and Rec'd by DR

"Source In" Checked by _____

Emergency Equipment in Control Room Checked by DR

Red Light On by DWM

Start-Up OK'd by _____ Time 1⁰⁰ PM Date 5-2 1957



to state ~~rate~~ dial = 1.026" at limit Sec in

Since face of Egg is 28×28 "
 Source reactor changed to 22×18 "^{hi} $\times 10$ "^{fuel} + 5 " ($3/4$ " plastic)
 22×18 " face opposite 28×28 " Egg column face
 3960 in^3 fuel on movable table $\times 19.45 \text{ g/in}^3 = 76.9 \text{ Kg}$ 25
 4" of depleted on back face -
 Plastic face on fixed table $3/4$ " $\times 28 \times 28$ " (between Reactor &
 3" source layer.


Super critical -- approaching
 stopped at 2.47 inches.

Removed 1 layer of fuel + 1 layer of
 plastic from moving table.

Dial 0.285 0.80 + 200 sec
 period
 (Too much excess k.)

3⁰⁰ PM - rebuilding source reactor 24 "^{wide} $\times 22$ "^{hi} $\times 6$ "^{fuel} plus $1/2$ " plastic
 2" 4 " depleted on back - no plastic between fuel & depleted -

3²⁵ PM dial .645" "Critical" DC-3 70 (102100) log k_0 .026
 C₄ $\times 14$ 5min 94⁺⁸
 C₅ $\times 16$ 5min 258⁺²¹



INSTRUMENT CHECK					
Date	May 1957	Time	9 ⁰⁰ AM	Source No.	Ra ①
Trip					
Instrument	Value	Scale	Source Distance	W	Scale
DC-1					
DC-2	95	110 x 20			
DC-3	55	110 x 100			
Log N	700				
R-1	77	110 x 100			
R-2					
P. M.	740	V			

C-4 = 5-3 (Vert)
C-5 = 5-2 (Long)



Expt.	6-8-2	Time	9 ²⁵ AM	Date	5-3 1957
Purpose	Vertical traverse with pinion counter				
	28" x 28" x 32" E40 aluminum Cad wrapped				
Personnel	DWM etc				

9⁵⁵ .653 dial 0.45 along - pos print about 100m

10⁰⁷ AM log N 0.53 dial 0.6454

on C-4 (Vertical) 28.00" is bottom.

10⁴⁰ AM approx 1 m/hr (2610) at canopy, corridor outside door to cor 9 m/hr
Near door to ~~201~~ just past S well 250 m/hr
door 201 600 m/hr



C₅ at 0.03 (normalized)

Time	Pos. (C ₄)	C ₄ x	C ₅ + 256	C ₄ /C ₅	log N	
10 ¹⁰	28.0	911 ⁺¹⁷ x16	321 ⁺¹³⁸	.177	0.53	5 min
10 ¹³	27.03	588 ⁺³ x16	192 ⁺²⁰⁵	.191	.44	3
10 ¹⁸	27.03	152 ⁺⁴³ x4	795 ⁺¹ x4	.192		3
10 ²²	26.02	122 ⁺⁵⁹ x4	558 ⁺²⁶ x4	.205		2
	25.03	144 ⁺⁶⁰	575 ⁺⁵⁷	.252		2
10 ²³	24.02	157 ⁺²⁷	567 ⁺⁵³	.277	.48	2
	23.02	170 ⁺⁵³	553 ⁺⁵²	.308		
	22.02	178 ⁺⁹	534 ⁺⁵³	.333		
	20.96	187 ⁺³	523 ⁺³⁸	.356		
	20.02	189 ⁺¹⁶	515 ⁺⁵⁴	.368		
10.40	19.01	188 ⁺²⁶	493 ⁺³⁴	.381	.42	
	18.01	191 ⁺³⁵	476 ⁺⁴⁶	.401		
	17.00	192 ⁺²⁸	481 ⁺⁵⁷	.399		
	16.00	195 ⁺⁸	486 ⁺³	.401		
	15.01	196 ⁺⁴⁶	501 ⁺⁶⁰	.391		
	14.05	201 ⁺⁶	514 ⁺¹⁹	.391		
	12.99	200 ⁺⁴³	527 ⁺³⁸	.384		
	11.98	188 ⁺⁴¹	538 ⁺⁸¹	.368		
	11.01	192 ⁺¹⁰	556 ⁺⁹²	.345		
11.05	10.00	184 ⁺¹¹	568 ⁺¹⁰	.3245	.475	
	9.01	167 ⁺³³	550 ⁺⁴⁶	.304		
	8.02	143 ⁺⁷	527 ⁺²⁵	.249	.2715	
	7.00	123 ⁺⁴⁰	502 ⁺⁴² x205	.244		2 min
	6.01	161 ⁺¹²	746 ⁺⁵⁸	.216		3 min
	5.00	137 ⁺¹	749 ⁺³⁷	.183		
11.20	4.00	114 ⁺⁶³	772 ⁺²³	.149		log N = .43

11 ²⁴	2.98"	C4 91 ⁺³¹	786 ⁺²⁷	.1165	3 min
	2.00	66 ⁺³³	798 ⁺²⁵	.0708	
	1.00	81 ⁺³³	811 ⁺²⁶	.1005	

Beginning ~~by~~ long. transect $\log N = 0.45$

11 ³⁵	15.995	223 ⁺⁵⁹	563 ⁺⁵⁵	2.515	2 min
C.5 = 1.00		226 ⁺⁴⁹	533 ⁺⁹	2.35	
11 ⁴¹ AM	2.00	229 ⁺⁴³	486 ⁺²⁰	2.15	
	3.00	230 ⁺³⁴	452 ⁺²³	1.955	
	4.00	236 ⁺⁶¹	416 ⁺²⁵	1.755	
	5.00	231 ⁺⁴⁷	381 ⁺¹³	1.644	
	6.00	225 ⁺²⁰	339 ⁺¹⁰	1.505	
	7.00	221 ⁺⁵⁴	301 ⁺¹	1.36	
	8.00	217 ⁺⁴⁵	275 ⁺¹⁷	1.265	
	9.00	208 ⁺⁶³	248 ⁺¹³	1.186	
	10.00	212 ⁺²³	222 ⁺⁷	1.045	
	11.00	206 ⁺¹³	195 ⁺⁵⁵	.947	2.5 min
	12.00	251 ⁺²²	220 ⁺³⁰	.876	2.5
	13.00	252 ⁺²⁸	198 ⁺²⁸	.785	
	14.00	245 ⁺⁶¹	177 ⁺⁶³	.723	
	15.00	295 ⁺⁴⁴	191 ⁺³¹	.646	3 min
	16.00	295	176 ⁺⁴⁰	.602	
	17.01	295 ⁺¹²	160 ⁺⁶¹	.546	
	18.01	294 ⁺⁸⁸	140 ⁺¹⁹	.474	
	19.01	395 ⁺²⁵	160 ⁺³³	.406	4 min
12 ³⁵ PM	20.00	502 ⁺⁴¹	175 ⁺⁸	.349	5 min
	21.	611 ⁺⁹	182 ⁺⁶⁰	.300	



		C ₄	C ₅		
12 ⁴⁵ PM	22.05 22.05	531 ⁺³²	135 ⁺²	.254	
	23.02	548 ⁺⁴⁵	119 ⁺⁵³	.218	5 min
	24.00	525 ⁺⁴	96 ⁺⁵	.183	
	25.01	452 ⁺¹³	74 ⁺⁵	.1635	
	25.60	455	81 ⁺⁶²	.180	
1 ¹⁵	6.00	197 ⁺³⁰	300 ⁺⁴⁹	1.523	[.44] 2 min

Shut down at 1:17¹/₂ PM

May 8, 1957

Crown Cross and Sym restacked exponential assembly to consist of 2:1 depleted enriched ratio with $2 \times 2 \times 2$ blocks:

3" layer of fuel is still on fixed table
Exponential is $30'' \times 28 \times 28$



INSTRUMENT CHECK

Date May 8 1957 Time 8:45 AM 213
 Source No. ~Y

Inst. no. _____ Make _____ Style _____ Range Distance _____ Start-Up Scale _____

D-1 _____
 D-2 90 10 x 20
 I-2 53 10 x 100
 Log. 7 sec (r)
 R-1 7 10 x 1000
 R-2 _____
 P. M. 730 v (r)

C₄(5-3) Vertical
 C₅(5-2) Longitudinal

START-UP CHECK LIST

Equipment Checked by DFC Personnel Check by DWM
 Instrument and Safety Checked and Reported DWM
 Source In? Checked by X X
 Emergency Exit to Plant Room Checked by DWM
 Red Light On by DWM AM _____
 Start-Up OK'd by DFC Time _____ PM Date _____ 1957

Expr. 7-1 Time _____ AM _____
 Start Date 5-8 1957
 Purpose 2:1 ratio v 12% exponential
 Personnel: DWM etc

9:22 AM
 9:50

Sub-Critical -

adding more voided to reactor (2 rows on top plus photo
 now 24" high

10:15
 10:21
 10:25
 10:27

align 0.59 dial .448
 1st dial .452 align 0.585
 dial .443 brief log v .0/7
 Shut down -

36

Exp - 7-2

12³⁰ Re start after lunch for ~~transmission~~
dial = 0.450 slope 0.585 (pos. period)

1⁰⁰ dial .441* slope 0.625 log N 0.80

C₄ at 16.00 "

C₅/C₄

164 N
.85

counting
2

12 ⁴⁸/₁₀₀ C₄ ²⁵²/₁₀₀ C₅
0. - 83 ¹⁶⁷/₁₀₀

made calc.

Time	C ₄ (C ₄ at 16.00)	C ₅ (C ₅ at 16.00)	C ₅ /C ₄	164 N	counting
0.00	74 ²⁵⁵ .995	169 ⁴⁰² .40	2.26	2.259	2
1.00	76 ¹¹⁷ .07	157 ¹⁰⁷ .42	2.07	2.069,75	2
2.00	79 ¹⁷⁹ .19	152 ²¹⁷ .85	1.93	1.930	
3.00	83 ²²⁰ .86	144 ²³² .12	1.715	1.719	
4.00	83 ²²⁰ .86	128 ²²⁴ .09	1.545	1.543	
5.00	80 ¹⁶⁶ .26	106 ²²³ .87	1.33	1.332	
6.00	76 ¹³² .51	90 ¹⁴⁵ .57	1.183	1.184	
7.00	80 ¹⁵² .20	268 ⁶³ .25	.906	0.906	
10.00	292 ²⁵ .10	214 ⁸⁰ .08	.732	0.733	
12.00	296 ⁷ .04	170 ⁴² .16	.578	0.575	
14.00	303 ³⁹ .15	129 ¹ .32	.425	0.426	
16.00	313 ⁴⁶ .18	99 ¹⁷ .07	.295	0.316	
18.00	327 ²⁹ .11	73 ⁷⁰ .03	.222	0.222	
20.00	513 ⁶² .24	91 ⁴⁶ .18	.1784	0.178	3 min
22.00	518 ⁴⁷ .19	118 ⁵⁴ .21	.210	0.228	
23.00	535 ⁴⁴ .17	129 ²⁵ .10	.242	0.241	
15.00	357 ⁵⁴ .21	130 ² .01	.364	0.364	2 min
17.00	343 ⁵⁹ .23	91 ⁵⁶ .22	.267	0.266	
13.00	334 ⁶⁰ .23	164 ²² .09	.491	0.491	
11.00	314 ¹⁹ .04	201 ⁵¹ .21	.643	0.641	

Vertical traverse

C₅ at 11.60"

Time 2 ⁰⁰ PM	C ₄ ⁺⁶⁴	C ₅ ⁺⁶⁴	(slide) Ruler	Cor. N. (ed. mark)	4	Min
28.00	272 ⁺³³ .5	365 ⁺¹ .02	.748	.747		
26.00	264 ⁺³⁴ .5	290 ⁺²⁵ .39	.908	.911		3 min
25.00	306 ⁺⁶ .1	296 ⁺⁴⁵ .70	1.03	1.032		
24.02	348 ⁺⁵ .1	298 ⁺⁴ .1	1.15	1.151		
23.04	386 ⁺⁷ .1	308 ⁺⁶¹ .95	1.248	1.250		
22.01	428 ⁺⁹⁶ .70	312 ⁺¹⁷ .9	1.368	1.370		
21.01	394 ⁺⁴⁹ .75	272 ⁺⁵⁸ .92	1.44	1.447		
19.98	363 ⁺³⁴ .5	242 ["] .17	1.50	1.501		
18.01	366 ⁺⁴⁵ .7	239 ⁺³ .05	1.53	1.534		
18.00	386 ⁺²⁶ .4	243 ⁺¹³ .83	1.58	1.585		
17.00	417 ⁺⁴⁵ .7	253 ⁺²⁴ .52	1.64	1.648		
15.98	445 ⁺³⁷ .58	270 ⁺³⁹ .6	1.645	1.647		
15.01	458 ⁺³⁸ .6	280 ⁺²⁷ .6	1.655	1.634		
14.02	427 ⁺⁴¹ .62	263 ⁺³¹ .5	1.622	1.623		
12.99	413 ⁺²² .34	267 ⁺²⁴ .21	1.545	1.547		
12.01	407 ⁺⁴ .01	268 ⁺¹⁹ .3	1.516	1.517		
11.00	398 ⁺² .0	274 ⁺²¹ .33	1.450	1.451		
9.99	385 ⁺⁴⁹ .75	275 ⁺² .03	1.40	1.403		
9.00	362 ⁺⁴⁷ .74	283 ⁺² .12	1.28	1.281		
8.00	337 ⁺²⁶ .4	292 ⁺¹⁵ .23	1.154	1.131		
7.03	306 ⁺⁴⁹ .75	298 ⁺² .03	1.027	1.029 (log N = 0.8)		
6.02	263 ⁺⁷ .1	292 ⁺²³ .36	.902	.900		
3 ²⁰ PM	5.01	228 ⁺³⁷ .66	290 ⁺²⁹ .48	.777	.787	
	4.01	188 ⁺³⁴ .53	285 ⁺⁴⁶ .73	.664	.660	
	3.00	149 ⁺¹⁴ .21	289 ⁺⁴³ .67	.514	.515	
	2.00	118 ⁺¹⁰ .15	283 ⁺¹⁵ .23	.418	.417	
	1.00	143 ⁺⁶³ .98	285 ⁺² .07	.506	.505	

3²⁰PM shut down

air sample
0.8 d/m/cm³

Expr. 8-1 Time 1⁰⁰ AM Date 5-13 1957
 Purpose Critical Exp - 3/4" plastic
37% error
 Personnel: BWm DHC

INSTRUMENT CHECK

Date 5-13 1957 Time 1⁰⁰ AM PM Source No. Y

Instrument	Trip	Value	Scale	Source	Distance	Start-Up	Scale
DC-1							
DC-2		<u>90</u>	<u>10x20</u>				
DC-3		<u>50</u>	<u>10x100</u>				
Log N		<u>7.00</u>					
R-1		<u>10</u>	<u>10x100</u>				
R-2							
P. M.		<u>750V</u>					

START UP

Equipment Checked by DHC _____
 Instrument and _____
 "Source In" _____
 Emergency _____
 Red Light On by _____
 Start-Up OK'd by DHC _____ 1957

1⁰⁵ PM

3 layers with 3/4" plastic between 2" layers of fuel

(7 layers 3" wide on movable Table)

C₁ x64 C₂ x64 } tables apart

5 min 93⁺¹⁸

15⁺²⁴

12.63
1.2 kg/layers

Tables in contact 0.920 on dial

5 min { 77⁺⁴⁹

16⁺¹²

76⁺⁴

15⁺¹²

12 Tables apart 77⁺

14⁵⁸

~~77~~

~~15~~

(-6.3)

(15.5)

1³³ PM Tables Apart - 5 layers ~~Tables~~ 15" x 18" x 2" layers (3/4" plastic)
76⁺⁴² 15⁺¹³

1⁴⁵ Tables together
78⁺⁴ .98 18⁺¹¹ .83 63.1Kg

1⁵⁵ 6 layers = 18 x 18 x 16 1/2" dial = 0.926
85⁺³⁸ .895 24⁺¹⁸ .63 75.7Kg

2¹⁰ 7 layers dial 0.922 18 x 18 x 17 1/4 88.3
98⁺⁵⁷ .713 39⁺¹⁴ .395

2³⁷ 15.6 Kg / 20 x 20" layers 109 Kg
20 x 20" layers, 7 layers tall - 109 Kg
Evidently would be super unit when together (melt > 1000 at 0.68")

2⁵⁰ Removed 9 x 2 x 20" fuel 101.98 Kg (net)
286⁺²⁵ 222⁺¹¹ .07 (Sub unit)

3⁰⁷ added 10 2 x 2 x 20"

definitely Super unit at 0.25" separation
- 3²⁵ Removed 2 x 2 x 20" = 1.56 Kg net = 100.42 Kg
still super

3³⁵ Removed 3 x 2 x 20 2.34 Kg net = 98.08 Kg
Seals unit in contact at high melt.

3⁴⁷ adding 1" x 2" x 20" now = 0.78 Kg 98.86 Kg net
Penhouse now 10 x 20"

3⁵⁵ contact on period in 2000

Expr. 8-2	Time 4 ¹⁰ AM	Date 5-13	1957
Purpose <u>Change dimensions of 2-1</u>			
<u>3/4" plastic mod</u>			
Personnel: <u>DWM DFC</u>			

4¹⁰ PM Base now is 19x20 7 layers hi
 Mass now 103.5 Kg 25
 Pos period .806 dial down 0.18
 4³⁰ PM Level .779 dial log N = .0095

INSTRUMENT CHECK				
Date	May 14	1957	Time 8 ³⁰ AM	Source No. 8
Instrument Trip Scale Source Distance Start-Up Scale				
DC-1				
DC-2	9.5	10x20		
DC-3	5.7	10x200		
Log N		sec		
R-1		10x10x1000		
R-2				
P. M.	730 v			

Air sample
 5-14-57
 17.6 g/m³

Expr. 8-3	Time	AM	Date 5-14	1957
Purpose <u>Crit Mass detn</u>				
Personnel: <u>DWM DFC</u>				

Removed 1" x 8 1/4 x 20"
 from movable table
 (3 layers 1" x 20")
 30 (2x2x1.5)

8-3a 8⁵⁰ Subcritical as described above with table at .02
 Added one row 1" x 20 x 2 3/4" 10 (2x2x1.5).
 8-3b 9¹⁰ ~~Critical~~ On positive period with tables together
 Dial reading = 0.924 period ≈ 100 sec.
 9¹⁵ Levelled at 0.898 on dial log N = .01
 Final stack 19 x 20 x 19 1/4" high with corner cut 1" x 5 1/2 x 20"

Move To
 1" x 5 1/2"
 4

.000

.0001

.001


.01


.1

Epp 8-2

TED IN U.S.A.








Plastic wgt = 3779 kg net

$$\text{Mass} = \frac{420}{50} \frac{2+2+3}{2+2+1} = \frac{97.108}{3.895}$$



$$\frac{97.108}{3.895} = 101.003 \text{ kg}$$

$$H/t = \frac{7.03}{.07} = 7.10$$



Expt. <u>8-4</u>	Time <u>1¹⁵</u> AM	Date <u>5-14</u> 195 <u>7</u>
Purpose <u>Evaluate Al plate by placing 1" Al on top of system</u>		
Personnel: <u>TAF BSC</u>		

7 layers with 1" Al on top + bottom



A 135


Pos period at relay = 0.25"

Removed 6 - 2x2x1 blocks across top of end
End face now 13 3/4 X 12" X 1"

B 155

Pos period at relay = 0.17"

2⁰⁷ Removed 5 2x2x1's & re-arranged blocks on N end of movable table



C 2¹⁵ tables in contact apparently level at $\log N = .0002$

Added 2 (2x2x1's) near & center on 1" layer

D 2²² tables in contact apparently level at $\log N = .0003$

E 2⁴² added 3 2x2x1's, 1" layer now is 10" x 16 $\frac{1}{2}$ "
contact $\log N = .00045$

F 3⁰⁵ Added 1 more layer - now 1" x 10" x 19 $\frac{1}{4}$ " ($\frac{1}{2}$ layer)
at & contact $\log N$ leveled at .00075

3²⁵ Altered 1" layer to a 8" x 19 $\frac{1}{4}$ x 1"
centered horizontally on 20" x 19 $\frac{1}{4}$ " face of
movable table


G 3³⁵ Positive period at dial reading of 0.914 (contact)
Leveled at 0.837 on dial (Period \approx 49 sec)

H 3⁴⁵ Removed 4 blocks from top of 1" layer (now 8" x 16 $\frac{1}{2}$ " x 1")
3⁵⁵ Positive period at dial reading of 0.914 (contact)
Leveled at 0.760 on dial (Period \approx 73 sec)

J Removed 4 more blocks from top
 1" layer now consists of 20 blocks ($8" \times 13\frac{3}{4}" \times 1"$)
 centered horizontally but toward bottom edge

405 Tables in contact at 0.915 on dial

420 Barely critical, very long period
 longer than a 1200 sec period



K 425 Restacked to $6" \times 19\frac{1}{4}"$ section centered (21 blocks)
 430 Tables in contact at 0.916 on dial
 Subcritical $\log N = .00045$ after 10 min.

Running table bars to 0.57 on dial & then together
 gives 12 sec pseudoperiod -


Mass of U-235 in 8-4 J

$$420 - 2 \times 23 = 97.108$$

$$20 - 2 \times 2 \times 1 = 1.558$$

$$98.666 \text{ kg}$$

PLATE 480 PRINT



9

.0001

.001
8-4J

.01

.0001

.001

.01

73.2

8-4H

.0001


.001

.01

8-4G 49

PLATE 460 PRINTED IN U.S.A.

A B C D E F G H I J K L M N O P Q R S T U V W X Y Z



INSTRUMENT CHECK

Date 5-15 1957 Time 11¹⁵ AM PM Source No. _____

Instrument	Value	Scale	Source Distance	Start-Up Scale
DC-1				10 x 1
DC-2	85	10 x 20		10 x 1
DC-3	55	10 x 100		7 ²⁰⁰
Log N	7 ²⁰⁰			100 x 10
R-1	10	10 x 1000		
R-2				
P. M.	1"			

air sample
11.1 / 100 / 3

START-UP CHECK LIST

Equipment Checked by DAC Department Checked by CC

Instrument and Safety Check used checked by DAC

"Source In" Checked by _____ Source No. _____

Emergency Equipment in Control Room Checked by DAC

Red Light On by DAC AM

Start-Up OK'd by DAC Date _____ 1957

Expt. 9-1 Time 1:15 AM PM Date 5-15 1957

Purpose 3/4" plastic in 2 dimensions

Personnel: DAC TAF

Friped table - 4 layers high 1 layer = 6 x 4 (on frind)
movable each layer = 6 2 x 2 x 1's 6 2 x 2 x 3's

11²⁰ Friped table only 5 min count

$$\begin{matrix} C_1 & C_2 \\ 91^{+36} & 11^{+46} \end{matrix}$$

base total = 16 x 15 3/4 ~~78~~ 4 layers tall when together

table together

$$\begin{matrix} 80^{+21} & 13^{+38} & .89 \end{matrix}$$

11⁴⁰ 5 layers fuel + plastic = $16 \times 15\frac{3}{4} \times 13\frac{3}{4}$
 11⁴⁵ tables together
 81^{+35} 19^{+36} .615


Added 1 layer to fixed table now 6 layers on both.
 1⁴⁰ PM Start table together. ($16 \times 15\frac{3}{4} \times 16\frac{1}{2}$)
 1⁴⁶ Tables Together.
 161^{+42} 84^{+37} (.129)

Added plastic to West face
 2⁰⁶ PM Tables started together $\left\{ \begin{array}{l} E-W = 16\frac{1}{2} \\ N-S = 16 \\ H-1 = 16\frac{1}{2} \end{array} \right.$
 2²¹ PM Rising on Period dial .800 Selsyn 0.173
 2²³ Start to level
 2²⁶ Level dial dial .785 Selsyn 0.21

Critical

Movable table -- removed 12 ea $2 \times 2 \times 1$ pc. of fuel and associated plastic.

Fuel 5×36 $2 \times 2 \times 3$
 24 $2 \times 2 \times 1$



Expr. 9-2	Time 2 ⁵⁵ PM	Date 5-15 1957
Purpose Crit mass det.		
Personnel:		

Pos. period table at all
 level Coy N = .002 when 0.15 dial = 0.855

Expt. <u>9-3</u>	Time <u>3⁰⁵ AM</u>	Date <u>5-15-1967</u>
Purpose <u>Removal vertical row of</u>		
<u>6-2x2x1's</u>		
Personnel: _____		

180 2x2x3's plus 18 2x2x1's
 3' table in contact did 0.9365" per period = 60 sec

Furrows counted 6" inside on center line (in plastic) 5-3

58⁺¹⁰ x 64 3 min

57⁺³ x 64 3 min
 59⁺³⁰ x 64 3 min

level log N = .0085 did at 0.809 always 0.07

Plastic wgt = 39.13 Kg

A = 180 2x2x3's + 231.21 41.618

18 2x2x1's + 77.89 1.402

Net 4225 43.020

H/t = ~~12.10~~ 12.10

final assembly = $15 \times 16\frac{1}{2} \times 15\frac{3}{4}$
 plus $1 \times 15\frac{3}{4} \times 8\frac{1}{4}$ " (on North face)

.0001

.001

.01

9-3

.0001

.001

.01

PRINTED IN U.S.A.


PLATE 480

9-2

.0001



.001

.01



Expr. 10-1 Time 12³⁰ AM Date 7-10 1957
 Purpose 1:1 ratio 18.8% slab -
48" long x 14" x 2 1/2" H/H - 14 (3/4" plastic
in 2nd dimension
 Personnel: TAF DC

START-UP CHECK LIST
 Equipment Checked by DC Person to check by DC
 Instrument and Safeties Checked and " " TAF DC
 "Source In" Checked by _____
 Emergency Equipment in Control Room Checked by DC
 Red Light On by none AM
 Start-Up OK'd by 1³⁰ PM Time PM Date 7-10 1957



10-minute counts on way to critical

C ₄ x 64	C ₅ x 64
13 + 60 (14)	31 + 14 (31)
15 + 17	31 + 13
18 + 56	29 + 41
22 + 15	30 + 36

No blocks stacked
 4 layers (2 + 3 1/4") on fixed table
 6 layers (16 1/2" total) on fixed table
 6 layer on fixed + movable (tables together)

4³⁰ PM

shut down for day

Expr. <u>10-1 B</u>	Time <u>12⁵⁵ PM</u>	Date <u>7-11</u>	195 <u>7</u>
Purpose <u>Cont. Exp 10-1</u>			
Personnel: <u>TAF DTC, DM, 3 others</u>			

START-UP CHECK LIST	
Equipment Checked by <u>DK</u>	Personnel Check by <u>CE</u>
Instrument and Safeties Checked and Reset by <u>DK</u>	
"Source In" Checked by <u>DK</u>	Source No. <u> </u>
Emergency Equipment in Control Room Checked by <u>DK</u>	
Red Light On by <u>DK</u>	
Start-Up OK'd by <u>DK</u>	Time <u>12⁵⁵ PM</u> Date <u>7-11</u> 195 <u>7</u>

12⁵⁵ PM Tables together 6 layers - base - 48 x 14" (16 $\frac{1}{2}$ " tall)
 C₄ C₅ 64 (10 min)
 22⁺³² 30⁺¹²

INSTRUMENT CHECK				
Date <u>7-11</u>	195 <u>7</u>	Time <u>1¹⁰ AM</u>	PM	Source No. <u>8</u>
Trip				
Instrument	Value	Scale	Source Distance	Start-Up Scale
DC-1				
DC-2	<u>28.10 ± 20</u>			
DC-3	<u>45.7 ± 10.7 ± 6</u>			
Log N				
R-1	<u>78</u>	<u>10 ± 1000</u>		
R-2				
P. M.	<u>750V</u>			

1³⁰ PM Total stack now 8 layers (48 x 14) (22" tall)
 C₄ C₅
 (10 minutes) 34⁺²⁷ 0.412 34⁺³⁵ .897

Added 2 layers - assembly now 10 layers (27 $\frac{1}{2}$ " tall)
 3²⁵
 (5 minutes) 29⁺¹² .289 22⁺¹⁰ .70

Added 2" ~~to~~ the back face of the assembly
Base area now 48" x 16" still 27 1/2" high

4¹⁵

Positive period at

dial reading = .2005

selsyn at 0.79

4²²

Levelled at

.182

on dial

selsyn at

0.855

4²³

Shut down

INSTRUMENT CHECK

Date 7-12 1957 Time 8³⁰ AM
 Instrument Trip Source No. 8
 Values Scale Source Distance Start-Up Scale

High	75	10x20
Mid	50	10x100
Low	75	10x1000
R-L	470	10x1000
D-C		
P. M.		

Expr. 10-2 Time 8³⁰ AM Date 7-12 1957
 Purpose detain Crit with 18.880 (1:1)
3/4" plastic 11x14 base = 48x16"
 Personnel: JWA DKL

Fuel removed
 down to 24 3/4" tall
 on fixed table
 27 1/2" on movable station -
 approx 13.95 kg 25/layer

START-UP CHECK LIST



Equipment Checked by DKL Personnel Check by DKL
 Instrument and Station Checked and Reset by DKL Fuchs
 Source Initials Station No.
 Emergency Equipment and Items Checked by DKL
 Red Light On by DKL
 Start-Up OK'd by DKL Time 8³⁰ AM Date 7-12 1957

8⁵⁰ AM C4 C5
 191 + 33 .073 108
 mm 13.7 Sub Crit

9⁰⁰ Added 1in to fixed set plus 1/4" plastic
 using 2x2x1" blocks + 1x1x1 + 1x1x2 -
 26" tall movable still 27 1/2" tall
 Would be super together - level at 0.38" on layer ± .01"

10⁰⁰ AM

Removed 2" fuel $\frac{3}{4}$ " plastic from movable
plus 1" x 20" x 5" fuel + 1" x 1" x 48"





10²⁵ AM

1" layer has $\frac{1}{4}$ " plastic on top.
Critical $\log N = .012$

Sealant = 0.165" dial 0.869 slightly open
.864 level

2" width of 1" layer + plastic removed from
back



11⁰⁵

Table in contact dial = 0.938 sealant = .02"

$\log N = .01$

dial .908 just crit

CHA

— Grid

5mm/sec paper speed

Manual Scan →

BRUSH ELEC

CHART NO. 3L 903


Scan

25mm/sec

BRUSH ELECTRONICS COMPANY

PRINTED IN U.S.A.

12 ³⁰/_{1m} Removed 2" x 1" x 48" row



12 ⁴⁰/_{1m} table in contact 0.944


apparently leveled off at $\log N = .0055$
 very high power level
 C₁ C₅

144 x 256 + 60 5min 72 ⁺²¹ x 256

M⁻¹ = .0136 MM 73

144 x 256 + 144 76 ⁺¹²² x 256

Final Assembly
 built on 1" Al plate



Est Mc = 13.95Kg x 9 = 125.55
 + 72 2221 = 5.608

not in 25 in depth blocks 131.16Kg + 900gms
 Wgt Plastic = 10.67Kg 1/4 = 14.57

INSTRUMENT CHECK


Date 7-23 1957 Time 10⁵⁵ AM
 Trip _____ Source No. 8

Instrument	Value	Scale	Source	Distance	Start-Up Scale
DC-1					
DC-2	<u>85</u>	<u>10x20</u>			
DC-3	<u>45</u>	<u>10x100</u>			
Log N	<u>1200</u>	<u>period</u>			
R-1					
R-2					
P. M.	<u>750</u>				

Expr. 11-1 Time _____ AM
 PM Date 7-23 1957

Purpose 24x48 x? slab approx 12x36 4x14
(1/2" plastic dimensions)


Personnel: JKF, JWB, JMC, JR



avg ~~36~~ 64 unmirrored blocks/layers. (4x14)
 10x20 → 1

12³⁰ PM

6 layers fuel = 15" tall assembly



Cy Amin
 10⁺¹¹ x 256

C5 10min
 10⁺²³⁰ x 256

Expr. 11-2 Time 8²⁰ AM Date 7-24 1957

Purpose continue 11-1

Personnel: _____

8²⁵

Tables apart
 7 layers

Cy Amin
 10⁺⁰ x 256

C5
 9⁺²⁸ x 256
 9⁺¹⁶⁰ x 256

24.415g
 34.415g

Table together

10⁺²⁴

Personnel

Exp. Purpose

Time AM PM Date

1957

INSTRUMENT CHECK

Date 7-24 1957 Time 8:40 AM Source No. 7

Instrument	Value	Scale	Source Distance	Start-Up Scale
D-1	84	10 x 20		1 x 10
D-2	55	10 x 100		1 x 20
L-1	150			
R-1	70	10 x 1000		
R-2				
P.M.	750V			

9:20 ^{31.46} 9 layers C₄ 9+227 C₅ 9+233 apart
 44-25 9+233 9+272 together

10:05 Source PN 213 on top center of stool
 2 min count
 1 table apart
 10:35 AM 11 layers 38.773 54.12
 assembly together = 24 x 48 x 27 1/2"

C ₄	0 +167	.65	0.69	C ₅	2 +252.1	.55
	+110				+165	
	0 +15				1 .64	
	0 +110				2 +167	.74

11:00 AM together
 11:20 12 layers on fixed 44.9
 11:35 12 layers together 57.04
 1:00 PM 13 layers 45.2 67.76

	0 +180			4 +0	.4
	0 170			3 +178	
	0 105			2 +160	
	0 .41			2 .41	.68
	1 +33	.13	.375	6 +92	.258
	109			2 +72	

Source removed high mill.
 Salays at 0.31 in diam in log N - .01 to .04 (1/100 mm)
 Critical (over)

2⁰⁰pm

Removing top 2" layer (2x12x48) from final section
 $\begin{matrix} 0.253 \\ 6 \end{matrix}$

Sub. Cut-

2¹⁵pm



Re-stacked top layer - so that a 12" wide section centered when section together
 top 2" now 12x48 centered. Sub Cut

$\begin{matrix} C4 & 2 \text{ min} & C5 & 2 \text{ min} \\ 3 \frac{3}{4} & & 19 \end{matrix}$

3¹⁵pm

added 2" duct now 24" long 3" wide to front half
 Symm. Critical with approx 100mm. period

at contact



El

top section = 36 blocks	width	72	depth
12 layers remainder = 768	" "	1536	" "
	$804 \times 231.26 \text{ gm}$		$1608 \times 1.295 \text{ gm}$
	185.893 Kg		1.945 Kg
	+ 1.945		
	187.838		
	- .472 gm		
	187.366		$\pm 0.5 \text{ Kg}$

Weighed Plastic = 138.105 Kg

H/H = ~~13.92~~^{13.92} avg wgt 12 x 48 x 1/2" = 5.386 kg (avg of 8)

on basis of Emulsion only = "H" = 13.97 "

185.893


- .472

185.421 ± 0.5 Kg²⁵ (no depleted counted)


top 2" x 12" x 48" + 2 x 3 x 24"

9-20-57

Setup in Well for 37 1/2% salt step -
Superstructure modified:




Variable speed DC motor is mechanism mounted
on L iron on top - Probe moved to 4 tubes
on balcony



Permanent probe drive.

Solution system installed (3 parallel 6" pipes)



Dump valve (3" Grinnell Saunders-
epit air vent opened to 1" & a Ross Mod 7 valve
used. Dump valve opening time now 140 msec
vers 8-900 msec. approx 500 ms for water to
fall 1" in 12" vented. At 50# gage air valve.

9-23-57

Apparently solenoid valve does not operate properly under 50# pressure
 or at 55# pressure water standing
 in 12" reactor from 2:47 PM Fri to 8:45 AM Mon
dropped from 56.78 to 56.60"

feed rate (full pump) = 20" in 2.58 min = ~~20~~
 or 7.7 in/min = 14.35 liter/min no bypass.
 at 36" head
 probe travel = 21.85 in/min -

dump time from 56 in = $\begin{array}{r} 120 \\ 110 \\ 110 \text{ ms} \\ \hline 4145 \\ 112 \text{ msec avg.} \end{array}$
 resumed from dump on
 to break probe contact

dump time from 0.0 in = $\begin{array}{r} 150 \\ 160 \\ 150 \\ 120 \\ 130 \\ \hline 7698 \\ 138 \text{ msec avg.} \end{array}$

1-20-58

Measured holdup volume = 1" in 12" diam cyl.

\approx 1.853 liters - (includes amt in probe sight glass)
system worked with de-ionized water and drained
drain plug installed in pump casing - lowest point
in storage system.

of the dead volume all but 450cc can be pumped
into the reactor - but air bubbles come in -

INSTRUMENT CHECK

Date 1-22 1958 Time 3:00 PM Source No. 8

Instrument	Trip Value	Scale	Range	Units	Zero	Span	Rate
DC-1							
DC-2	<u>40</u>	<u>10x20</u>					
DC-3	<u>40</u>	<u>10x50</u>					
Log N	<u>7.00</u>						
B-1	<u>1000</u>						
R-2	<u>1000</u>						
P. H.	<u>1000</u>						

START-UP CHECK LIST

Equipment Checked by _____ Personnel Check by _____

Instrument and Safeties Checked and Reset by _____

"Source In" Checked by _____ Source No. _____

Emergency Equipment in Control Room Checked by _____

Red Light On by _____

Start-Up OK'd by _____ Time 3:00 PM Date 1-22 1958

START-UP CHECK LIST

DK JKR Equipment Checked by _____ Personnel Check by DK

Instrument and Safeties Checked and Reset by DK

"Source In" Checked by DK Source No. 213

Emergency Equipment in Control Room Checked by DK

Red Light On by DK

Start-Up OK'd by DK Time 3:00 PM Date 1-22 1958

total = 35.3 ^{Ku}
13.14 ^{Ku}

Avg analysis = 4456 ± 37.2% total

Put in	37.34%	37.48%	37.28% avg
# 1500 37.21%	1501	1502	1503 = 37.33 1503
G- 21625	20950	22600	21775
T 1911	1953	1884	1934
N 19714	18997	20716	19844
Reg 394019	394020	394056	394057
4544 gm4/gm	394055	43644	4400 4
ratio .9788	4.4504	.4523	.07093 F
.07133 gm7/gm	F .07174	.07191	1.0051 Rem
	Rel-.9934	.9852	1.9928
	Sy 2.0522	Sy 1.9890	Sy 1.9928

Expr. 1-1	Time 3 ³⁰ AM	PM Date 1-22 1968
Purpose 37 1/2% silica in 12" 55 wgl - and water wgl - on well -		
Personnel: ADC, JSC, JRF, WJG		

Probe level set at 99997 for zero -

	Fuel	C ₁	C ₂	2 min counts -
4 ²⁰ PM	3.12"	31 1/4	15 1/4	
4 ²⁵	6.02"	42 3/4	15	
4 ³⁰	9.08"	65 1/2	13 1/2	
4 ³⁵	11.03"	179 1/2	54	log N almost on scale

Tested safety + count - system responds as it should -

271.9

4⁵¹ 11.825 Sub Crit Source out

11.83 Super Crit (very slightly)

Critical between 11.82+ and 11.83

Crit volume = ~~39.205~~ Liters 2,904 = 7.3 kg U²³⁵
19.96 kg U

Fuel Inventory = .35, 342 gms U 13.22 kg U²³⁵

Expr. 1-2 Time 9⁰⁰ AM Date 1-27 1958
 Purpose Repeat of 1-1 for reproducibility
37 1/2 90 volts
 Personnel: DHC JKF

INSTRUMENT CHECK

Date 1-27 1958 Time 9²⁵ AM Source No. 8
 Trip _____
 Instrument _____
 DC-1 _____
 DC-2 _____
 DC-3 55 20x10 contact 5
 Log N 700 printed contact 10x1
 R-1 _____
 R-2 resistor 1x10
 P. M. 200V 200V

START-UP CHECK

Equipment Checked by DHC Inspected by DHC
 Instrument and Safeties Checked by DHC
 "Source In" Checked by DHC
 Emergency Equipment in Cust. of DHC
 Red Light On by DHC
 Start-Up OK'd by DHC Time 9³⁰ Date 1-27 1958

9³⁵ AM probe zero re-checked and set at ~~0.05~~ 0.03
9⁴⁰ .02 9⁵⁰ .025 (probably drop on end of wire)

10¹⁵ A fuel 11.825" prob just crit - or slightly super -
 11.82 auto -

10²⁰ fuel added to 11.89" period in 100 sec

10²⁵ fuel 11.84" sub crit at log Nn .0045

10²⁷ 11.845 super (detectable on limit - auto)

10³⁷ fuel 11.89" per period

10³⁵ fuel 11.84" log Nn .016 just crit -
 PM trips at 200V at this level -

10 ⁴⁰ AM

Fuel at 11.87" to sub DC 2 tier (put pencil)

from 20 on 10x20 to 63 on 10x20

10⁴¹

System swarmed as planned.

Inst readings -

R-1 - 63 1000 x 200

DC-2 - 53 20 x 10

DC-3 - 100 on 100 x 10

R-2 - 3035 1000 x 1000

log N - .028

Fuel Δ" Period log N

11.82 - 11.89 | .05" | 102.4 on 0.00022 to 0.005

11.84 - 11.89 | .05" | 103.2 0.05 to 0.022

11.84 - 11.87 | .03" | 217.3 on 0.018 to 0.028

→ evidently crit Ht was low due to source & low power level

Expr. <u>1-3</u>	Time <u>1⁴⁰</u>	PM Date <u>1-27</u>	195 <u>8</u>
Purpose <u>Reflected 12" SS cyl.</u>			
Personnel: <u>DK & RF</u>			

START-UP CHECK LIST	
Equipment Checked by <u>DK</u>	Checked by <u>DK</u>
Instrument and Safeties Checked and Reset by <u>DK</u>	
"Source In" Checked by <u>DK</u>	
Emergency Equipment in Control Room Checked by <u>DK</u>	
Red Light On by <u>DK</u>	
Start-Up OK'd by <u>DK</u>	Time <u>1⁴⁰</u> PM Date <u>1-27</u> 195 <u>8</u>

Relocated safety - now 15" wide 20" long unichrome coated Cadmium sheet - in reflector touching cylindrical water reflector up 24" above tank floor -

DC-3 and log N moved to opposite (fl) of reactor
Source moved to locate near base of cyl.

2³⁵ PM Set fuel at 1.04" - temp limit set too high = 47.51" (reads too high)
2⁴⁰ " " 2.04 - temp touches at 46.82"
temp zero at 48.86" temp = 45.79"
Fuel at 3.03 temp = 45.79"

2⁵⁵ PM Fuel at 5.10 Temp at ~~47.71~~⁴³
3⁰⁵ Fuel at 5.86 Temp at 42.95 - add to 43.08 (0.13" below indicated level before no change in reactivity)
3¹⁰ 6.18" fuel Temp at 42.50 temp out, source out

3 ²⁰/_{PM} 6.15 temp at 42.72 approx cont.
 Period assumed (top temp measured to fact.)

3 ⁴⁵/_{PM} Safety blade reset - water pumped back in
 starting to pump fuel -

3 ⁵⁰/_{PM} fuel at 6.12 temp at 40.79" same in

3 ⁵⁵/_{PM} temp down - contact at 42.75"

critical at 42.77" on TT

4 ⁰⁰/_{PM} just critical TT at 42.91" fuel at 6.04" (See Summary #5602 P.107)

top temp at 5.95" .09" of TT immersed -

top temp has irregular base -

Note: - top temp sensor should be slowed down - valve now set at 3.0

Q-11-63	Tempers	2.04	46.82	= 48.86	
		3.03	45.79	48.82	
		5.10	43.71	48.81	
1-11	2 report	5.86	42.95	48.81	
	CH 5.95 in.	6.18	42.50	48.68	} Maybe not in contact
	US 5.955 in.	6.15	42.72	48.87	
		6.12	42.73	48.85	
				48.83	
		6.04	42.91	42.91	
				<u>5.92</u>	

Fuel Annulus = .12 in.

Expt. 1-28 4 Time 9:30 AM Date 1-28 1958
 Purpose 12" SS. Cyl reflected request for top
 Personnel: JKF DHC

START-UP CHECK LIST
 Equipment Checked by DHC Personnel Checked by DHC
 Instrument and Safeties Checked and DHC
 Source DHC checked by DHC
 Emergency Equipment in Control Room DHC
 Red Light On by JKF
 Start-Up OK'd by DHC Time 9:30 AM Date 1-28 1958

INSTRUMENT CHECK

Date 1-28 1958 Time 9:30 AM Source No. 8

Instrument	Value	Scale	Source	Start-Up Scale
DC-1				
DC-2	<u>50</u>	<u>10x20</u>		
DC-3	<u>55</u>	<u>10x50</u>		
LOG N	<u>7m</u>			
R-1	<u>10</u>	<u>10x1000</u>		
R-2				
P. M.	<u>-900</u>			

Water reflection set at 25 cm above base

10⁰⁵ A fuel 7.41 in water 20 cm above base

10¹⁰ A ~~7.47~~ 7.47" 20.9 cm just with water

10¹⁵ A 7.50" 19.7 cm " "

7.53 19.2 cm slightly above
 19.0 cm slightly below

2³⁰ PM Sample taken 136 gms net Reg 635325

see page 83

Expr. 1-25 Time 5:40 AM PM Date 1-28 1968
 Purpose Repeat of 1-4
Partially inflated 12" 55ml
 Personnel: JKT DK

START-UP CHECK LIST
 Equipment Checked by DK Personnel Check by DK
 Instrument and Safety Checked and Reset by DK
 "Source In" Checked by DK Source No. 19 213
 Emergency Equipment in Control Room Checked by DK
 Red Light On by DK
 Start-Up OK'd by DK Time 3:10 AM PM Date 1-28 1968

INSTRUMENT CHECK

Date	196	Time	AM	PM	Source No.	
Instrument	Trip	Valve	Scale	Source	Distance	Start-Up Scale
DC-1						
DC-2						
DC-3						
Log N						
R-1						
R-2						
P. M.						

Water ht 19.1 cm

7.53" full 19.1 cm H₂O

7.55" w. suspended mass - 73 cm -

ht DC-3 swim at 55 on 10x50

log N = .0068

15
4 PM

Expr. 1-6 Time 8³⁰ AM Date 1-31 1958
 Purpose 12" 55 wfl - water wfl. plane
1.3 layers of 1/8" 5 steel on lateral surface
 Personnel: _____

Shells one
 3 ft long - 1/8" dia

INSTRUMENT CHECK

Date 1-31 1958 Time 8³⁰ AM Source No. 8
 Trip _____
 Instrument Value Scale Source Distance Start-Up Scale
 DC-1 _____
 DC-2 45 10x20 _____
 DC-3 45 10x50 _____
 Log N 7000 _____
 R-1 1000 10x10000 _____
 R-2 _____
 P.M. 81.0V _____

START-UP CHECK LIST

Equipment Checked by btc Personnel Check by btc
 Instrument and Safeties Checked and Reset by btc
 "Source In" Checked by btc Source No. 10213
 Emergency Equipment in Control Room Checked by btc
 Red Light On by btc
 Start-Up OK'd by btc Time 8³⁰ AM Date 1-31 1958

Water at 56.7 core

8⁵⁷ A With ^{fuel} pump off & fuel valve closed
 and in hot kept rising - possible in-leakage
 of water? fuel meter from 1.33 to 1.53

9¹⁵ cause - pump foaming liquid - air in pump
 from pipe - filling operation before starting

9³⁵ A 54.1 ^{mm} water reflector, upland -

9⁴⁵ fuel out at 1.57 ⁱⁿ - remained there for 10 min.

10⁴⁰ Fuel 6.04 TT at 42.9% (Sub Crit)

10⁵⁵

Fuel 6.09"

JT - 92.85

→ just critical
optimal position

Shutdown -

42.85
<u>6.09</u>
48.94

42.85
<u>48.83</u>
5.98

6.09

5.98

.11

Expr. 1-7 Time 2:45 PM Date 2-3 1958
 Purpose 3/8" S. Steel lateral infl. with water infl on 12" infl (38)
 Personnel: SWH - JHC

START-UP CHECK LIST
 Equipment Checked by JHC Person to check by JHC
 Instrument and Safeties Checked and OK
 "Source In" Checked by JHC Time 2:13
 Emergency Equipment & Control Room checked by JHC
 Red Light On by JHC Time 2:45
 Start-Up OK'd by JHC Time 2 PM Date 2-3 1958

fuel inlet pump discharge leaks at seal fitting

INSTRUMENT CHECK
 Date 2-3 1958 Time 2:45 PM Source No. 7
 Trip _____
 Instrument Value Scale Source Distance Start-Up Scale
 DC-1 _____
 DC-2 45 10x20
 DC-8 50 10x50
 Log N 7
 R-1 7 10x1000
 R-2 _____ negands
 P. M. 5000 ✓

3:45 PM water at 57.5 cm

Selen Probe	Top Tamper *		
3.37"	45.51"	48.88	
5.15"	43.57"	48.72	
<u>3:45</u> 6.08"	42.85"	45.93	sub. crit logW just on scale
6.11"	42.71"	48.82	sub. crit " " " "
6.13"	42.69"	48.82	" " " "
6.18"	42.65"	48.83	" " " "

* Selen reading when top tamper is just in contact with fuel. Maximum reactivity occurs ~.1" lower.

	Soln Probe	Top Tamper *		Log W
	6.22"	42.61	48.83 sub. crit.	100 @ 2
4 ¹⁰	6.25"	42.58	48.83 " "	1000 @ 2 4
	6.31 6.32	42.50	48.82 sub. crit.	

(Exp. discontinued for lack of time)

R-1 *expands*
 DC-3 52 on 10x50
 PM *trip*
 DC-2 65 on 10x20

Expr. 1-7 (Cont.)	Time 3 ²⁰ ^{AM}	PM Date 2/4	1958
Purpose 5/8" S. Steel lateral ref. with water ref. on 12" cyl. (S.S.)			
Personnel: D. F. C., J. W. S.			

START-UP CHECK LIST	
Equipment Checked by <input checked="" type="checkbox"/>	Personnel Checked by <input checked="" type="checkbox"/>
Instrument and Safeties Checked and Reset by <input checked="" type="checkbox"/>	
"Source In" Checked by <input checked="" type="checkbox"/>	Source No. _____
Emergency Equipment in Control Room Checked by <input checked="" type="checkbox"/>	
Red Light On by <input checked="" type="checkbox"/>	
Start-Up OK'd by <input checked="" type="checkbox"/>	Time 3 ¹⁰ ^{AM} PM Date 2/4 1958

H₂O ht. = 55.5 cm

Soln Probe	Top Tamper	
2.35 +	46.51	48.86
5.11	43.73	48.84
6.31 +	42.50	48.81 sub. crit.
6.35	42.45	48.80
6.34	42.49	48.83 Crit. optimum top tamper setting = 42.58"

water above 6.04"

130" more with 5/8" steel (laterally only)
 104" " " 1 5/8" steel (" ")

Expr. 1-8 Time 9⁰⁰ AM Date 2-7 1958
 Purpose 1/2" S.S. lateral infl. on 13" infl
in water well
 Personnel: JWH & JAL

Top Tamper reads
 .03" higher
 than soln.

START-UP CHECK LIST
 Equipment Checked by OK Done by OK
 Instrument and Safety Checked and OK
 "Source In" Checked OK PW 213
 Emergency Equipment in Control Room Checked by OK
 Red Light On by JWH at 9 AM
 Start-Up OK'd by OK Time 9 AM Date 2-7 1958

INSTRUMENT CHECK
 Date 2-7 1958 Time 9⁰⁰ AM Source No. Y
 Instrument Name Description Range Scale
 DC-1 40 10x20
 DC-2 45 10x50
 Log N 7.24
 R-1 100 10 x 1000
 R-2 response
 P. M. 2000

	Fuel	Top Tamper	H ₂ O	
	2.86			
	<u>2.89</u>	<u>2.89</u>	<u>51.5 cm</u>	<u>.03</u>
	<u>5.075</u>	<u>5.105</u>	"	<u>.03</u>
	6.33			<u>.04</u>
	<u>6.36</u>	<u>6.40</u>		<u>.10</u>
				<u>.06</u>
<u>10¹⁰</u>	<u>6.39</u>	<u>6.45</u>	<u>- Crit TT dumped to 6.33 optm</u>	

zds

DC-2 240 10x20
 Log W trip
 DC-3 45 10x50
 R-1 trip
 R-2 responds
 PM trip

Expr. 1-9 Time 10²⁵ AM PM Date 2/7 1958
 Purpose: 3/8" s. steel lateral reflector
on 12" cyl. in H₂O ref.
 Personnel: D.F.C., G.W., G.

START-UP CHECK LIST
 Equipment Checked by ✓ _____ Check by ✓ _____
 Instrument and Settings checked and _____
 "Source in" checked by ✓ _____ No. PM 213
 Emergency Readings in control room _____
 Red Light on by ✓ _____ AM
 Start-Up OK'd by ✓ _____ Time _____ PM Date _____ 195

Soilh	Top Tamper	H ₂ O	
4.10	4.14	.04	52.8 cm
6.04	6.11	.07	
6.22	6.31	.09	
6.36	6.41	.05	sub. crit
6.38+	6.44	.06	crit

optimum top tamper position = 6.33
 Temp. = 23° C by thermocouple

zds

Expr. 1-10 Time 12^{40 AM} PM Date 2-7 1958
 Purpose 1/4" SS on 12" wgl
water wgl.
 Personnel: SWIS OK

START-UP CHECK LIST

Equipment Checked by OK Person Relied by OK
 Instrument and Safeties Checked and Relied by OK
 "Source In" Checked by OK No. PH 513
 Emergency Equipment in Control Room Checked by OK
 Red Light On by OK
 Start-Up OK'd by OK Time 12^{45 AM} PM Date 2-7 1958

Refl water set at: 52.5cm

Salen	Top Tamper	
5.10	5.15	
6.16	6.21	sub.
6.24 6.34	6.29 6.33	sub.
6.27+	6.33	sub.
	6.42	
6.37+	6.44 6.42	crit.

optimums tamper position = 6.32

Expr. 1-11	Time 7 PM	Date 2-7	1958
Purpose: 1/8" S Steel on 12" cyl Ref -			
Personnel: <u>Swab etc</u>			

START-UP CHECK LIST	
Equipment Checked by _____	check by _____
Instrument and Safety checked by _____	_____
"Source In" checked by _____	_____
Emergency Equipment checked by _____	_____
Red Light On by _____	_____
Start-Up OK'd by <u>etc</u>	Time 2:01 PM Date 2-7 1958

Water gap between stainless steel shell +
stainless reaction as much as 1/8" in places -
shell is not round - (10)

Water ht. = 51.5 cm

Solu ht.	Top tamper	
6.02	6.08	sub. crit.
6.09	6.14	sub. crit.
6.20	6.29	sub.
6.24	6.31	super
6.24+	6.20 6.29	crit

optimum temperature = 6.20

Expt. <u>K11 (Repeat of 1-3)</u>	Time <u>2:30</u>	Date <u>2/7</u>	195 <u>8</u>
Purpose: <u>completely reflected (H₂O)</u>			
<u>12" cyl.</u>			
Personnel: <u>DFC & W &</u>			

H₂O ht. = 51 cm

Solu wt top tamber

6.04 6.10 super

6.02+ 6.09 crit.


optimum position of top tamber = 5.95

20
H_c inches
(Exp 1-1)

Critical H_t
vs
Lateral Stiffness Steel Reff.
(Complete external Water Reff.)

2- 12" radius wall (1/16" ss.)

Steel shell inches



50
2
4
.6
.8
1.0
1.2
1.4
1.6
1.8

Sample Reg 635325

0.44359 gm U/gm sample 2.0079 Sp. Gr. @ 25.0°C

Assay = 60.96% 238

0.31% 236

38.78% 235

0.25% 234

~~H/f = 73.1~~ 64.4, 10.2

was above 8 1/2% assay

V (.37, 3) 29 11/4/67

Spec results in ppm in U₃O₈ from ignited sol'n (kindly by 2.66 to get ppm/m cell)

Be < .3

Fe 30

Ni 40

Cu < 2

Zn 30

Cr 6

Si < 10

Ca < 50

Li 2

Ba < 10

P 150

B < 1

Na 20

Al 13

Mn 5

Ag < 1

Mg < 5

K < 50

START-UP CHECK LIST

Equipment Checked by JKF Personnel Check by JKF
 Instrument JKF
 "Source in" JKF Source No. DN 213
 Emergency JKF
 Red Light JKF
 Start-Up Order JKF 10⁴⁰ Date 2-21 1958

INSTRUMENT CHECK

Date 2-21 1958 Time 10³⁵ AM Source No. 8
 Trip _____
 Instrument _____
 DC-1 _____
 DC-2 48 10x50
 DC-3 52 10x50
 Log B. 7m 7m
 R-1 80 10x1000
 R-2 misplaced
 P. M. 1" 800V

Probe zero = 0.04"
tangen same

g' Expt. 2-1 Time 10⁴⁰ AM Date 2-21 1958
 Purpose 6 1/2 RI reflected
 Personnel: JKF JKF

Start up postponed to 12⁵⁰ PM (water tanks leak)
12⁵⁰ PM Water reflector 85.8cm (boil milk)
1⁰⁵ PM Water 85.7cm Fuel 12.35"

	Fuel	Water	Temp
	<u>30.12"</u>	<u>85.4cm</u>	<u>30.25"</u>
	<u>C₁</u>	<u>C₂</u>	<u>C₄</u>
<u>Intermittent</u>	<u>2⁴⁵</u>	<u>3⁴⁵</u>	<u>3⁴⁶</u>
	<u>1⁴²</u>	<u>3⁴³</u>	<u>3</u>
<u>monitored C₁ →</u>	<u>7⁴¹</u>	<u>11³⁸</u>	

~~water~~
Fuel TT Water

1⁴⁰ PM 30.12" 30.25" 85.3 am

10 min counts C₁ x 64 C₂ x 64 C₄ x 16 C₅ x 16
34⁺⁵⁷ 53⁺⁴⁸ ~~17~~⁺¹⁵ 15"

1⁵²

~~2³²~~ PM 25.85" 25.88" 85.2 am

10 min counts C₁ x 64 C₂ x 64 C₄ x 16 C₅ x 16
35⁺⁴⁸ 59⁺²³ 16⁺¹ 17⁺⁵

2⁰⁵

~~2³⁵~~ PM 20.39" 20.27" 85.0 am w

10 min C₁ C₂ C₄ x 16 C₅ x 16
16 34⁺⁵⁴ 62⁺³⁸ 17⁺⁸ 20⁺²

2⁴⁸

15.17" 15.14" 85.0 am w
32⁺²⁸ 56⁵⁷ 16⁺¹¹ 18⁺⁶

2³⁰

9.80" F 9.80" TT 84.8
29⁷⁰ 44⁵⁴ 16⁺⁵ 18⁺¹

2⁴²

5.10" 5.07 84.8
24²⁶ 61⁵⁵ 17⁺³ 18⁺⁸

2⁵⁵

0.04" F 1.04" TT
18⁺³³ 70⁺² 17⁺¹³ 16⁺¹⁴

Some moved (see next page)

3²⁰ PM Source 1" off centre of reactor ~~with~~ radially approx 4" up from bottom initially -

3³¹ Fuel (TT in contact) Counter 4 & 5 moved about 2 ft from Cyl in tank
 5.50" C1 +61 C2
 29⁺⁶¹ (3.0) / min 749⁺³ 831⁺⁹ 20.8
 X64 74.9/min 83.1/min X64 +135

30.01" .442 33⁺⁶⁰ 5 min .745 26⁺⁵ 5 min 365⁺²² 5 min
 " .429 20⁺⁴⁸ 3 min .774 210⁺⁵² 2 min 147⁺⁶⁰ 2 min
 .178 .295

4⁰⁰ 25.05" .442 34⁺¹⁰ 5 min .185 506⁺⁵⁴ 5 min 364⁺¹⁹ 5 min
 0.285


20.01 .492 32⁺³⁵ " .202 463⁺⁵ 346⁺¹⁴ 0.301

4¹⁵ PM 15.04 .527 28⁺⁴⁰ .263 3589 290⁺⁶¹ .409

4²² 10.04 .682 21⁺⁵⁶ .42 223⁺⁴⁹ 216⁺³⁹ .483

Exp 2-1 (6 1/2" g/l) p. 24-26

H/10 ~ 65 → 70




p-88-150

BSR fuel Element Egg

88
5-3-59

Temperature Coefficient Test of BSR fuel elements alone and with boron and ~~tin~~ lead slabs as symmetrical opposing slabs 7.6" apart (edge of element to edge of element).

Initial loading 2" wide prism (cd) blade




Element	U	X	Element	U	X
A-69	143.95	139.09	A-25	146.30	137.19
A-79	150.31	140.02	I-115	150.58	140.28
A-68	148.79	138.92	A-78	150.31	140.02
A-71	143.95	134.09	B-134	150.86	140.53
B-122	150.19	140.99	B-150	150.88	140.54
B-130	151.02	140.68	A-23	147.74	138.54
S-17	150.31	140.08	A-64	149.14	139.20
A-77	150.31	140.02	A-56	148.25	138.43
B-144	150.34	140.06	B-148	150.88	140.54
B-123	150.81	140.49	A-75	150.28	139.99

Element	U	X
A-67	149.31	138.43
B-137	150.74	140.44
A-59	148.91	139.07

			U	X
A-80	150.42	140.13	A-55	148.25 138.43
A-60	148.91	139.07	A-29	148.83 139.95
A-76	150.31	140.02	Z-121	150.70 140.43
S-28	150.56	140.33	A-32	147.80 138.10
I-113	150.25	140.01	B-145	150.29 139.98
A-61	148.91	139.07	A-81	150.31 140.02
A-73	143.87	134.17	A-70	143.95 134.09
B-138	150.74	140.44		
I-116	150.74	140.43		
B-143	150.45	140.17		
A-57	148.66	138.87		
I-117	150.52	140.26		
B-124	150.81	140.49		
B-135	150.86	140.53		
B-121	150.19	140.99		
I-114	150.26	140.01		
B-141	150.80	140.49		

heavy
Control Rod →

Motor #4 Cd blade (2" wide .025" thick 24" long Cd)
mounted as shown on page 88 (OD of blade = 2 3/4" x 28")



Safety → Motor #3 Cd Safety blade mounted a 1/2" from fuel
in center hole - out approx 4" above top of fuel
70-50 ma current adequate for holding + pickup
drops at 40 ma min holding = 50 ma
North face
Clearest 1/2 in

Safety → Motor #2 Cd Safety on APPR rod mounted over
1/2" from fuel South face of center hole out is approx 6" above fuel
70-50 ma current adequate for holding + pickup
still holds at 40 ma Selwyn reads -0.15" all up.
in = 23.69"

small
Control Rod → Motor #1 Cd blade (2" wide .025" x 24" Cd) in
S steel mandrel (OD = 2 3/4" x 28") mounted as shown
on page 88. Bottom of blade 1 3/4" above fuel level
selwyn out at 22.08" all in out = -0.20

Same Drive mounted as same goes in
EW channel approx center

INSTRUMENT CHECK

Date 3-5 1958 Time 2⁰⁰ PM Source No. 8

Instrument	Value	Scale	Source Distance	Start-Up Scale
DC-1				
DC-2	<u>44</u>	<u>20x100</u>		
DC-3	<u>45</u>	<u>50x100</u>	<u>50x10</u>	
Log N	<u>6.7</u>	<u>10x1000</u>		
R-1	<u>responds</u>			
R-2	<u>800V</u>	<u>800V</u>		
P. M.				

under Well
west edge of well
platform under well
south side of well
south side of well on floor

Trip changed to 86 on 50x100
50x10

START-UP CHECK LIST

Equipment Checked by JKE Personnel Check by JKE, DFC

Instrument and Safeties Checked and Reset by JKE, DFC

"Source In" checked by JKE Source No. PN 213

Emergency Equipment in Control Room Checked by JKE

Red Light On by JKE AM

Start-Up OK'd by JKE Time _____ PM Date 1958

Expr. 1-1 Time 2⁰⁰ PM Date 3-5 1958

Purpose Room temp. test of BSR fuel elements with 8" channel sup. 88

Personnel: _____

2⁵⁰ PM
3²⁵

Control Rods out Safeties up Source IN
Personnel: Cronin, Fox, Rohrer, Gilley
Back scale set to read zero when water level is at top of support grating (2 1/2" below fuel)

quantity of H₂O in west tank approx. 100 gal. more than enough to fill Well to 93cm

Water raised to 87 cm. Water level is same as top edge of fuel elements.

Temp.: Thermocouple # 13 24.5° C

Water level is 93 cm ^{when} water is at level of bottom of heater

Sub. critical (no apparent M² from instruments) when water ht. = 87 cm (flooded).

Expr. 1-2 Time 9⁰⁰ AM Date 3-6 1958
 Purpose Fuel elements added to orig array
as in diry
 Personnel: JKF WRR JWA JFC

START-UP CHECK LIST
 Equipment Checked by JKF Check by JWA
 Instrument and Scale JKF JWA
 Source in % JKF No. PN 213
 Emergency Equipment and Records checked by JFC
 Red Light On by JKF
 Start-Up OK'd by JFC Time 10³⁰ AM Date 3-6 1958

INSTRUMENT CHECK
 Date 3-6 1958 Time 10¹⁰ AM Source No. Y
 Instrument _____ Scale _____
 DC-1 25 10x50
 DC-2 50 10x50
 Log N. 7mm
 R-1 7 10x1000
 R-2 measured
 P. M. 800V

added:
 B-140
 B-125

	B 131	S 17	B 136	S 122	A 71	A 58	A 79	A 69
B-140	B 150	B 134	A 78	I 115	A 25	B 123	B 144	H 77
B-125	A 59	B 137	A 67	A 75	B 148	A 56	A 64	A 23

W →

added
 B-139
 B-133

	B 139	B 136	A 73	A 61	I 113	S 28	A 76	A 60	A 80
	B 133	I 114	B 121	B 135	B 124	I 117	A 57	B 145	I 116
	A 70	A 81	B 145	A 32	I 121	A 29	A 55	A 141	B

B-140 u x W
 150.79 140.48
 B-125 150.81 140.49

u x
 B-139 150.74 142.44
 B-133 150.86 140.53

total added = 561.84 gms as shown

Water ht. = 91 cm, system not critical.

Very small M' indicated by instruments

Shim blades and control ~~to~~ blade
as well as safety blades were operated. Shim
is less valuable than safeties


At a water ht. of 92.6 cm heaters and
stirrers come on

When the stirrers come on a small
amount of air was ejected from element.


~~Top~~ Top of fuel is 66.4 cm above grating
i.e. zero on back scale.

Expr. 1-3 Time 1:30 ^{AM} PM Date 5-6 1958
 Purpose addition of fuel to org. assembly
now a full (3x9) x 2 plus 4 partial
elements
 Personnel: Cronin, Fox, Holland, ~~Clifford~~, Gilley

added elements



#	U	X
B136	150.46	140.37
B142	150.45	140.17
B128	75.38	70.22
A 92	117.71	109.65
A 40	86.43	80.82
B 129 P	117.29	109.26



~ 1:45

Begin feeding water

Rod #1 moved west ~1"; is now behind element T 121

2:15

~~System~~ H₂O Rod #2 Rod #1
 67.9 sub
 68.0 super

2:30

76.1 cm 12.01" 4.5" cut

Expt.	1-4	Time	2 ³⁷ AM	Date	3-6	1958
Purpose	Removal of 2 partial fuel elements					
Personnel:	same					

Removed A-40 + B128-P

3³⁵ PM Water at 92.5cm (sterionon - no heat)
elements covered @ Rod #2 at 11.4" Sub Crit

3⁴⁰ PM Rod out - Log N = .00023 Source at max
Water at 92.5cm - Sub Critical

Error	1-5	8 ³⁵	3/7	1958
Purpose	Element B-12 8 added to last array (previous position)			
Personnel	W.C. J.E., Reedy etc.			
Equipment Checked by	_____			
Instrument used	_____			
Source	_____			
Emergency	_____			
Red Light	_____			
Start-Up	_____			

+70.22gm 25

DC-3 50 10x50
 DC-2 87 10x20
 R-1 trip
 PM "
 2N "
 R-2 responds

9⁰⁰ AM Water 68.8 cm same as last - Cuit at Room temp
 23.5°C on #13 Thermocouple - no rods

9:17
 TC #13 - 23.5°C Steves on water at 92.5 cm
 #11 - 24.0
 #12 - 24.0
 #14 - 24.0
 #15 - 24.0

Room Temp 77°F

9⁴⁰ AM Rod #2 7.775" Log N .0019 Water at 92.5 cm
 Rod #1 999.87 R-1 62 on 100x100
 DC-2 34 on 50x1
 DC-3 42 on 5x1

9⁴³ AM HTV's on to ~ 80°F both 21Kw + 18Kw

9⁵⁰ Instruments slightly rising but less than at start

9⁵⁰
 DC-2 39 50x1
 DC-3 51 5x1
 R-1 72 100x100
 LN 10024

9⁵³ Instruments indicate downward trend

#13 thermocouple 26°C @ 9⁵⁵
 #12 " " "
 #16 " " "
 #14 " " "
 #15 " " "

9⁵⁰ - Temperature Equilibrating

10¹³ Temp 26°C by Thermocouples (all)

10³⁰
 " #11 29°C
 " 12 29°C } 30°
 " 13 29°C } 30°
 " 14 29°C } 29°
 " 15 29°C } 29°
 " 16 27°C } 28°

10⁴⁰ AM Evidently Temp coming up -
 18Kw cut off Variac set back to 50 (100 = max)

10⁴⁵ AM

Rod #2 at 7.30"

Log N = .009

R. 55 on 50x1000
 DC-2 56 10x10
 DC-3 329 1x20

TC	°C	} 86°F
11	30°	
12	30°	
13	30°	
14	30°	
15	30°	

10⁵²

Notes (at 12Kw) remains on longer to maintain temp.
 Rod #2 at 7.28" very slight increase in activity ~~not~~

TC #11		} 2w6
12	30.5°	
13		
14		
15		

10⁵³

Rod went to 7.29"

TC #11	30.5°	} 87.8°F
#12	31°	
#13	30.5°	
#14	30.5°	
#15	31°	

11⁰⁰ AM }
 11⁰⁵

11¹⁰
 11¹¹
 11¹⁵

All Stes on - 24Kw + 18Kw Demand set for 125°F
~~monitors~~ level rising on R-1 Rod at 7.29"
~~#12~~ #12 TC } 32°C R-1 at 60 on 50x1000

13	}
11	
14	
15	

11¹⁶

11²⁰

R-1 level dropping back after initial rise.
 R-1 back to orig level 55 on 50x1000 (Rod #2 at 7.29")

11 ²⁵	Rod #2 moved to 7.22"		
11 ²⁴	" " " " 7.13	Temp ~ 34°C	
11 ²⁹			
11 ³¹	7.06	Temp ~ 36°C	DC-2, DC-3, level
	7.06		
11 ²⁷	6.89	34.5°C	
11 ⁴³	6.78	37.5°C	
11 ⁵⁰	6.68	39°C	
11 ⁵⁷	6.50	40	
11 ⁵⁹	6.41	41	
12 ⁰⁷	6.29	41	
12 ¹²	6.00	42	
12 ³⁰	5.66	42.5°C	
12 ⁴⁵	5.15	48°C	
1 ⁰⁰ PM	4.84	49.5°C	
1 ⁰³ PM	4.63	50°C	
1 ⁰⁷ PM	4.52	51°C	
1 ¹⁸	3.98	53	
1 ³⁰	3.15	53.1	
1 ⁴⁰	3.15	54	Heaters off
1 ⁴⁸	2.55	55.5	
2 ⁰⁵		56.0	
2 ⁰⁷	R ₁	56.0	#14 + #13
2 ¹⁰	2.10"	56.0	#14
2 ¹⁴	28 on 50x1000 2.2# .15 .0044	56.0	#14
2 ¹⁵	Rod out to 0.385" in 200 sec period		
2 ²²	Rod #1 in 12"	log N	56.0 #14
		.065 (slight + period)	56°

2:30 PM Rod #1 15.53" Rod #2 0.385 (out) log N .07 Temp 55.5°C #14
55.5°C #15
55.5°C #13
15.53" of Rod #1 \approx 1.7" of Rod #2 from $\frac{2.1}{0.39}$ away 131.9°F

2:33 Controller set for new temp demand - 130°F (actually 135)

3:00 PM Temp. Equilibrium at 59.2°C
3:17 PM Temp 60°C Rod #1 (out) Rod #2 = 0.88 log N n.07
3:21 PM TC #11 = 60°C #14 = 60°C
3:26 PM TC #11 = 60°C #14 60°C R-1 going up
Rod #2 down to n 1.08 momentarily level.
3:31 Rod #2 at 0.88 R-1 started down no temp change -
3:37 PM TC #11 = 61.5°C #14 = 61°C R-1 still going down
Rod #2 at 0.88 (Rod 1 out)
3:44 PM #011 = 61.5°C #14 = 61°C
3:48 PM #4 #14 = 61.5°C
3:50 PM #11 = 61.5°C
3:57 PM #11 = 61.5°C #14 = 61.5°C
3:57 PM #11 = 61.0°C #14 = 61.0°C
4:02 All rods out System just Crit.
Temp. #11 = 60.5°C #13 = 60.5°C #15 = 60.5°C
#12 = 60.5°C #14 = 60.5°C
60.5 \approx 140.1°F
Control with about 12 Kw of Atus

4¹⁰ Shut down (dropped safeties)
 4¹⁵ Radiation level at tank water in = 11 m_r/hr.
 50 m_r/hr at top of fuel elements -
 note: on 3-10-58 water in West downy tank is 29°C

Conclusion:

Critical at room temp (24°C)
 with Rod #2 at 7.775" Rod #1 out


Critical at 30.5°C Rod #2 at 7.29" Rod #1 out

Critical at 60.5°C Rod #2 out Rod #1 out

System showed a momentary increase in reactivity when first hit on followed by a decrease in activity much more pronounced. Net temp coeff is negative.

Exp. 2-1 Time 2:30 Date 3-10 1958
 Purpose: Boral plates inserted into water channel between fuel tubes.
 Personnel: JKF Rudy JWB DC

TC #11 bottom of B-145
 #14 inside near top of B-145



total U^{235} in system = 7.964 Kg

Location of thermo-couples:

- #11 bottom of B-145
- #14 inside near top of B-145
- #13 in South East corner about 3 ft up from floor and 1 foot from walls Taped to TC from Symphylax
- #15 inside A-71 2-3" down into fuel
- #12 about center on NE corner of water channel

PN 213

Source moved from between helms to outside North side between B-145 and B-189P

START-UP CHECK LIST

Equipment Checked by JKP GLEB Instrument Check by J.G. G. Instrument and Safety Checked and Ready by J.K. Safety Fall Gear Checked by J.K. Instrument No. PN-213/P-15 Instrument Checked by J.K. Start-Up OK'd by J.K. Time 3:20 PM Date 3-10-1958

Plat-Bc source from Sid also installed to be in on South face pump and dump shifted to East water tanks

Rod # 2 (Motor # 4) speed control set at 1.5 on Variac

INSTRUMENT CHECK

Instrument	Trip Value	Seals	Source Distance	Start-Up Scale
	86	10 x 50		
	49	10 x 50		
	7	10 x 1000		
	1"	800V		

3:35 PM } 6.3 cm water #11 } 24.5°C
3:40 PM } 92.8 cm water #12 }
Sub-Critical
Log N = .00026

INSTRUMENT CHECK				
Date	3-11	1958	Time 12 ⁰⁰	PM Source No. 8
Trip				
Instrument	Value	Scale	Source Distance	Start-Up Scale
DC-1				
DC-2	88	10250		
DC-3	53	10250		
Log N	7m			
R-1	7.2	1021000		
R-2	response			
P. M.	"	800V		

START-UP CHECK LIST				
Equipment Checked by	JKF	Personnel Check by		
Instrument set up, checked and set by	JKF			
Source checked by	JKF	Source No.	PM 2nd Pu Be	
Emergency equipment in control room checked by				
Red light on by	JOC			
Start-Up OK'd by	JKF	Time 1 ⁰⁶	PM Date 3-11	1958

Expt.	2-2	Time 1 ⁰⁶	PM Date 3-11	1958
Purpose	3" of Al between valves in water channel to increase reactivity some more			
Personnel:	RKR, JKF, JWB, JOC			

1⁵⁰ PM


Sub Critical Water at 92.5 cm 24.5°C
 Log N = .00038

3-11-58

after checking with Leo Halland
decided:

1. Most important to have slab geometry as regular - no protrusions = 2 - 3 x 9's
2. Helms may be adjusted closer (up to 5" apart) to maintain criticality
3. Boral plates may range from $\frac{3}{8}$ " to 2.5" from edge of elements.
4. Partial elements may be placed in 3 x 9 row to lower reactivity
5. If necessary partial elements on outer face of 3 x 9's
6. If still sub-critical change system to a 4 x 8 (3 x 8 - plus partial's in 4th row)

3/12/58



Note: All fuel elements in 3x9's are full elements

Thermocouples: [Cu-Constantin]

#15 water chem/ 2 to down 8" up from grating - 13" in from E

#14 In element B 141 ~ 4" from top of fuel

13 still in outer reflector SE corner 3ft up 1ft in

12 In element A 78 ~ 4" from top of fuel

11 north edge of array at center of bottom, (outside)

INSTRUMENT CHECK

Date 3-12 1958 Time 1:50 ^{AM} PM Source No. 8

Instrument	Trip Value	Scale	Source Distance	Start-Up Scale
DC-1				
DC-2	<u>84</u>	<u>10 x 50</u>		
DC-3	<u>50</u>	<u>10 x 50</u>		
Log N.	<u>full</u>	<u>paid</u>		
R-1	<u>7.5</u>	<u>10 x 1000</u>		
R-2	<u>response</u>			
P. M.		<u>800V</u>		

START-UP CHECK LIST

Equipment Checked by _____ Personnel Check by _____

Instrument and Safeties Checked and Reset by JWG, etc

"Source In" Checked by DK Source No. PH213-PA30

Emergency Equipment Control Room Checked by etc

Red Light on by JWG

Start Up OK'd by DK Time 2:00 PM Date 3-12 1958

Expr. 3-1 Time 2:00 ^{AM} PM Date 3-12 1958

Purpose achieve grid in 3 x 9's by moving closer - opening between tubes now 5.6" between edges of slants. 1/8" thick boron plates as shown in diag.

Personnel: JKF, JWA, etc


2:15 pm

Sub Critical Water at 89cm all rods out

Exp. 3-2 Time 2:50 PM Date 3-12 1968
 Purpose 2" between boron plates & edge of element
leaving 1 1/8" water gap between Boron plates
 (Same fuel loading)
 Personnel: LW G, Rudy, JKF

very little multiplication at
 92.5 cm H₂O

Drawing for 3-13-58
 Exp 3-3



- DC-3 trip 50 X 500
- DC-2 " 83 X 500
- R-1 " 7
- R-2 responds

Thermocouple locations are approximately
 same as noted on page 106

Expt.	3-34-1	Time	10 ⁰⁰	Date	3/13	1958
Purpose	1/8" between boron plates. Boron plates are 2" from face of elements					
Fuel loading	is given on page 108					
Personnel:	P.F.C. J.K.F., Reedy, J.W.S.					

10¹⁵ AM. H₂O ht. = 50.5 cm. Since reactivity was sufficient to be critical well below effective as reflector, experiment was discontinued to make changes.

Expt.	K-2	Time	2 ⁰⁰	PM	Date	3-13	1958
Purpose	Boron plates moved in to 1" from face of elements						
Personnel:	P.F.C. J.W.S. J.K.F.						

H₂O ht. 65.5 cm Both control rods "in" (Rod #1 is 22.18, Rod #2 is 21.34)

Fuel Element Weights

Element	Weight W-235
A19	30.81 gms
C2	69.87
C4	69.81
C5	69.94
	<u>240.43</u>

3/14/58

Restacking of Elements for uniform loading.

I 113	A 70	A 81	B 145	B 142	Z 114
X 117	Z 116	B 138	B 135	A 55	A 32
A 80	B 143	A 61	B 124	B ⁽¹⁾ 141	Z 121
S 28	A 57	A 73	B 139	B 121	A 29

3.348Kg 235



(15)

A 64	A 56	B 148	A 75	A 67	B 137
B 141	B 123	A 35	Z 115	A ⁽²⁾ 77	B 134
A 79	A 58	A 71	B 122	B 130	S 117
A 69	B 125	B 136	B 131	B 150	A 59

← 5.6" edge to edge
1/4" borax plates
1" from edge of elements

3.345Kg 235

Expt.	5-1	Time	3-14-1958
Purpose	Loading as shown above		
Personnel	L.W.G., R.B.P., J.K.T.		

R-1 Trips
PM "
LN "
DC-3 - 50x500
DC-2 - 80x500

crit at H₂O at 65.5 with rods out
67.1 #2 rod at 8.65
68.1 " 21.35

DC-1	85	10 x 50			
DC-2	85	10 x 50			
DC-3	50	10 x 50			
LOG	7				
R-1	1				
R-2	1				
R-3	1				
Instrument	Value	Scale	Source	Distance	
INSTRUMENT CHECK					
Date	3-17	1958	Time	8:30 AM	
Source No.	2				

Expr.	5-2	Time	9:00 AM	Date	3-17 1958
Purpose	Same loading - boron plates moved in to 1 3/8" of fuel elements				
Personnel	JWA, RKR, DKL				

9:07 System slightly sub-critical with water at ~92 cm and with both control blades "out".

Expr.	5-3	Time	AM	Date	3-17 1958
Purpose	Boron plate moved out to 3/4" spacing from elements				
Personnel	JWA, RKR, DKL				

11:45 CR# 2 Water at 92.5 cm water
 water temp (stabilized at ±0.5°C)
 #15 22.5°C
 #12 22.5°C

11:55 CR# 2 8.15 ± 0.05" CR# log N = .009
 Shut down by dropping safety blades.

Exp. 5-4 Time 3:45 PM Date 3-17 1958
 Purpose Repeat of 5-3 after
arriving local plots move firmly
 Personnel: 3 w/3 DL RKR

3:45
PM

Thermocouple #12 + #15 = 23°C

Crit. Water at 92.0 C.M.

CR #2 at 7.70" ± .05

Crit Log at .0024

Shut down - water dumped

INSTRUMENT CHECK

Date 3-18 1958 Time 8¹⁵ AM Source No. 8

Instrument	Value	Scale	Source Distance	Start-Up Scale
DL-1				
DL-2	<u>45</u>	<u>10x50</u>		
DL-3	<u>700</u>			
R-1				
R-2	<u>response</u>			
P. M.	<u>1"</u>			

START-UP CHECK LIST

Equipment Checked by DL Checked by DL RKR

Instrument and Scale Checked and DL PN213

Pressure Ind. Checked by DL DL

Emergency Stop and Start Checked by DL

Rot. Inert Unit DL 8:30 AM

Start-Up OK by DL Time 8:30 AM Date 3-18 1958

Expt. 5-4	Time 8 ³⁰ AM	Date 3-18 1958
Purpose Beginning of temp run using heater from West tanks - East tanks used for 5-4		
Personnel: JWB, RKR, etc		

9⁰⁰

Water 92.5 cm critical
temp: #15 23°C

9⁰⁵ CR at 6.74" per period9¹⁰ CR # at 7.75" level log N at 0.019¹⁵ Htrs on (18+24 kVA)9³⁰ Htr TC locked out - Htrs set back to 12 kVA
initial rise followed by long drop in reactivity9⁴⁰ CR #2 at 6.74" per period9⁴⁵ CR #2 5.50" per period10⁰⁰ CR #2 at 6.95" same level by Nat. 0.1 temp #15 = 26°C10⁰⁷ Htr demand set to 37°C full heat (18+24 kVA)10¹⁰ #15 TC 29°C #12 29.0°C10²⁰ #12 30°C #15-30.5°C CR set at 5.50"10²⁵ #15 33.5°C10⁵⁸ Heaters turned off momentarily (equilibrating).11⁰¹ # 12, 14, 15 @ 34°C (thermocouple)11⁰⁵ #15 - 37°C Rod at 3.70" (just above level)12²⁰ All thermocouples read 42.5°C, control Rod # 2
is out, system is critical.

3-18-58

2" lead face covered with 1/4" Boral on outside (North South)
face of each section - array otherwise same
as before.

Expt. <u>6-1</u>	Time <u>10¹⁰</u> AM	Date <u>3-19</u> 195 <u>8</u>
Purpose <u>Criticality check on lead boral shielded array</u>		
Personnel: <u>for Ready Room</u>		

START-UP CHECK LIST		
Equipment Checked by <u>RKR</u>	Personnel Check by <u>RKR</u>	
Instrument and Settings Checked and Reset by <u>JH</u>		
"Source In" Checked by <u>JH</u>	Source No. <u>PN213</u>	
Emergency Equipment in Control Room Checked by <u>JH</u>		
Red Light On by <u>JH</u>	Time <u>10²⁰</u> AM	
Start-Up OK'd by <u>JH</u>	Time <u>10</u>	PM Date <u>3-19</u> 195 <u>8</u>

INSTRUMENT CHECK				
Date <u>3-19</u> 195 <u>8</u>	Y	Time <u>10¹⁰</u> AM	PM	Source No. <u>Y</u>
	Trip			
Instrument	Value	Scale	Source Distance	Start-Up Scale
DC-1				
DC-2	<u>82</u>	<u>10x50</u>		
DC-3	<u>18</u>	<u>10x50</u>		
Log N	<u>7m</u>			
R-1	<u>8.2</u>	<u>10x1000</u>		
R-2	<u>response</u>			
P. M.		<u>800V</u>		

10⁵⁰A Water 92.5 cm - system sub critical Rods out
Water temp #15 } 23°C Log N u.001
 #14 }


Expt. 6-2 Time 12⁴⁵ AM Date 3-17 1958
 Purpose Same array with Boral
 Plates now 7/8" from fuel elements
 Personnel: For Rudy Curran

- 7/8" ± 1/32

1:50 PM
 2:05

Water at 92.5 cm Temp 23°C
 Rods out very slow period (593 cm) 1.34
 Rod #2 - 1.24" level log N at .0008

Expt. 6-3 Time 3⁴⁵ AM Date 3-19 1958
 Purpose Lead Boral on outside spaced 1/2" from
 full elements
 Personnel: For Rudy Curran



4:25 PM

CR #2 18.53" Water at 92.5 cm slight plus
 18.60 plus 18.80 plus 19.00 + 19.56 +
 #15 = 23°C 20.00 - 19.75 +
 (all in = 21.34")
 Critical with Rod #2 at 19.875 ± .125"

Expr. 6-4	Time 8 ²⁵ AM	Date 3-20 1958
Purpose: <u>Continual 6-3 with temperature changes.</u>		
Personnel: <u>JKR RKR SK</u>		

START-UP CHECK LIST		
Equipment Checked by <u>RKR</u>	Personnel Check by <u>RKR</u>	
Instrument and Safeties Checked and Reset by <u>SK RKR</u>		
"Source In" Checked by <u>SK</u>	Source # <u>PN 213</u>	
Emergency Equipment in Control Room checked by <u>SK</u>		
Red Light On by <u>SK</u>	Time 8 ³⁵ AM	
Start-Up OK'd by <u>SK</u>	Time 8 ³⁵ AM	Date 3-20 1958

- 9¹⁵
9²⁵ CR#2 at 10.50" water 92.5cm per period. 141 sec 7.9g
temp readings #15, 14, 13, 12, 11 28°C - 28.2°C
- 9⁴⁰ CR#2 at 12.50 by N .055 + level
9⁴⁴ Steries turned on.
9⁴⁶ All kites on - demand set at 40°C
9⁴⁷ Beginning of very slight rise on R-1
9⁵² Starting down on R-1
9⁵² CR#2 out 12.00"
10⁰² #11 = 31.5°C #15 = 31.5°C
10¹² #15 = 33°C
~~10²²~~ #15 35°C
10²⁴ #11 37.25°C
10³⁸ #11 38°C
10⁴⁸ #11 39.75°C #15 39.75°C

- 11⁰⁵ 42.25°C #15 CR#2 at 5.60"
 11¹⁴ #11 44.0
 11²⁵ #11 45.25°C CR at 4.48"
 11²⁹ #11 46°C #15 46°C
 11²⁹ #14 46°C #15 46.25°C
 11³⁷ #13 47.5°C
 11³⁹ #13 48°C #14 48°C #15 48.5°C
 #11 48.75°C
 11⁴¹ Variance at 50% 18Kw Hbm off.
 11⁵⁰ #11 48.5°C #14-48.5°C #15 48.5°C
 11⁵² Variance out at 75%
 11⁵³ #13 48°C #11-48.5°C
 11⁵⁵ Variance at 75% 18Kw Hbm 0V
 11⁵⁷ #11-48.25°C
 12⁰⁰ #15-48.25°C #14 48.25°C Rod at 1.46" +
 12⁰³ #11 48.25°C Rod at 1.55" +
 12⁰⁵ Rod #2 at 1.65" #11 48.25°C slight +
 12¹⁰ #13 ~~47.75°C~~ 47.75°C Rod₁ at 1.70" -
 12¹⁵ Rod #2 at 1.67
 12¹⁸ #13 47.75°C #15 48.75°C #11 48.50°C
 12²¹ #15 48.50°C #12 48.25°C #14 48.25°C
 12²⁴ #15 48.50°C #11 48.25°C
 12²⁸ #11 48.25°C
 Rod #2 1.37" ± .05" level by N at 0.036
 12³¹ Rod #2 Out (-99999)
 12³³ #14 48.0°C #15 48.25°C

12⁴⁰

Shut down (water dump)
 Period Rod out = 434.6 sec 2.754
 avg temp = 48.25°C

Sample taken of lead for analysis -
 scrapings from 15 of 28 pieces used.

START-UP CHECK LIST	
Equipment Checked by	RKR Personnel Check by RKR
Instrument and Safeties Checked and Reset by	DK RKR
"Source In" Checked by	DK Source No. PN 213
Emergency Equipment in Control Room Checked by	JKF
Red Light On by	DK 45 AM
Start-Up OK'd by	DK Time 8 PM Date 3-21-1958

Expt.	6-5	Time	8 ⁴⁵ AM	PM Date	3-21-1958
Purpose	Critical with no lead/brass outside - inside brass plates				
	7/8" from fuel				
Personnel:	JKF	RKR	DK		

9¹⁰

Water at 40cm #11 TC = 23.5°C

9²⁰

67.45cm water Super 67.35 Sub

Crit Rod out at 67.4 cm 23.5°C

9²⁷

76.5cm water Rod #2 at 21.34" (slight Super)

9⁴⁰

Crit Rod #2 21.34" Rod #1 at 2.61

92.5cm water

Time	Cont Rod #1 inches	Cont Rod #2 inches	Pressure	g
9 ⁴⁰	0.0	21.34"	+ 136.5	9.2
9 ⁴⁷	2.81	21.34	level	
9 ⁴⁸	2.81	16.00	too slow	
9 ⁵⁰	2.81	15.00	+ 168	6.4
9 ⁵⁸	4.05	15.00	level	
10 ⁰⁰	4.05	13.00	+ 245	4.0
10 ⁰⁸	4.76	13.00	level	
10 ⁰⁰	5.46	13.00	- 260	5.8
10 ¹⁸	4.76	13.00	level	
10 ¹⁹	4.76	12.00	+ 377.5	3.2
10 ²⁵	6.54	12.00	- 145.5	12.8
10 ³⁵	5.27	12.00	level	
10 ³⁶	5.27	11.00	+ 258	4.4
10 ⁴¹	7.02	11.00	- 147.5	12.4
10 ⁵¹	5.85	11.00	level	
10 ⁵²	5.85	10.00	+ 210	5
11 ⁰²	7.12	10.00	- 302	4.9
11 ⁰⁸	6.60	10.00	level	
11 ⁰⁹	6.60	9.00	+ 163	6.0
11 ¹²	8.00	9.00	- 282	6.4
11 ¹⁴	9.00	9.00	- 134.5	8.8
11 ¹⁹	7.45	9.00	level	
11 ²⁰	7.45	8.00	+ 134.5	7.4
11 ²⁸	10.00	8.00	- 178	8.8
11 ³⁵	8.64	8.00	level	
11 ³⁶	8.64	7.00	+ 99.8	9.6

all TC
23.25°C

23.25°C

23.25°C

Time	Rod #1	Rod #2	Period	+
11 ³⁸	11.05	7.00	-	
11 ³⁹	12.05	7.00	-	-195.5 8.2
11 ⁴²	13.0 7 02	7.00	-	-147.5 12.4
11 ⁴⁷	10.45	7.00	level	
11 ⁵⁴	10.45	6.00	+	97.6 9.8
11 ⁵⁷	15.00	6.00	-	-314 4.6
11 ⁵⁵	17.00	6.00	-	-199.5 8.2
12 ⁰³	13.31	6.00	level	
12 ⁰⁴	13.31	4.50	+	60.7 14.1
12 ⁰⁶	22.17	4.50	+	269 4.4
12 ⁰⁸	11.01	4.50	-	-99.6 2.9
12 ¹²	11.01	4.50	level	
12 ¹⁷	11.01	3.00	+	108.5 9
12 ²²	11.01	3.00	-	-167 10.3
12 ³⁹	11.01	3.00	level	
12 ⁴⁰	11.01	0.00	+	95.7 10.4

* safety #2 = Rod #3

Temp #15 23.2°C too #14 & 11

12⁴⁵ Shut down by allowing DC-2 to Swam
 DC-2 = 87 on 10x50
 log N = 0.56

108.53 d = Rd 2
 from 21.34" to 0.0

Expr. 6-6 Time 2²⁰ PM Date 3-21 1958
 Purpose Temperature rise on source assembly on 6-5 (no outer lead-bowl)
 Personnel: JKE, RKR, DK

START-UP CHECK LIST
 Equipment Checked by RKR DK Personnel Check by RKR
 Instrument and Safeties Checked and Reset by RKR DK
 "Source In" Checked by DK RKR Source N° PN213
 Emergency Equipment in Control Room Checked by DK
 Red Light On by DK
 Start-Up OK'd by DK Time 2⁰⁰ AM Date 3-21 1958

2²⁰ Start Rod #1 13.74 Rod #2 21.34 Safeties all out
 temp #11 32.25° (at 55 cm water) 32.75°
 #12 23° (at ⁶⁵50 cm water) 26.50°
 #15 33.5° (at 85 cm water)

2³⁵ Rod #1 out Rod #2 13.35" level log V = .001
 #11 33.0° #15 33.25° #14 33.50° 88.1 g/gms

2⁴⁵ Stopper Out - no change

2⁴⁶ Ht on - 24 + 18 kVA

2⁴⁸ noted initial rise from 35 on R-1 to 40 (200 x 10 rods)
 #15 - 39.75° #14 53.75° (at peak of rise)

3⁰¹ PM #14 37.25° #15 - 35.25°

3⁰² PM #14 35.00° #15 - 35.50°

3¹³ PM level log V = .0016 Rod #2 11.36" Rod #1 out
 #14 36.75° #15 - 37.3°

3²² level log V = .0015 Rod #2 10.36" Rod #1 out
 #14 ^{38.0}37° #15 39.75°

3³⁵ 41.50° #14 #15 - 42.25°

3⁴⁴ 43.25° #15 #14 - 42.5°

3⁵⁰ 44.0° #15 43.75° #14 Rod at 8.27 + level log V = .03
 (over)

4⁰⁴

Rod #2 = ~~7.35~~ 7.35" Log N = .042
 #14 1.85 45.75°C #15 1.891 46.75°C

4¹⁵ PM

Log N = .041 Rod #2 = 6.91" level
 #15 ^{MV} 1.927 47.75°C
 #14 1.90 — 47.0°C
 #13 1.914 47.25°C
 #12 1.9250 47.5°C
 #11 1.927 47.75°C

4³⁰ PM

#15	1.958	48.50°C	} level Log N = .042 Rod #2 = 6.66"
#14	1.937	47.75°C	
#13	1.944	48.0°C	
#12	1.955	48.25°C	
#11	1.955	48.25°C	

4³⁸

#15	1.951	- 48.25°C	} level Log N = .042 Rod #2 = 6.70"
#14	1.943	- 48.0°C	
#13	1.934	- 47.75°C	
#12	1.941	- 48.0°C	
#11	1.944	- 48.0°C	

4⁴⁶

#15	1.955	48.25°C	} Log N = .042 Rod #2 = 6.70"
#14	1.947	48.2°C	
#13	1.935	47.75°C	
#12	1.945	48.1°C	
#11	1.945	48.1°C	

4⁵⁵ PM After Op. — Slight rise on R-1 37 to 38 on 50 x 100 miles
 #15 1.978 49°C
 #14 1.944 48.1°C
 #13 1.966 48.70°C
 #12 1.978 49°C
 #11 ~~1.9885~~ 49.25°C

4⁵⁷ PM R-1 level falling —
 5⁰⁵ #15 2.1765 — 53.25°C
 #14 2.0945 49.5
 #13 2.1065 49.5
 #12 2.10955 49.5
 #11 ~~2.116~~ - 49.50°C

Rod 5.17"
 log N = .016

5²⁷ #15 2.226 54.5°C
 #14 2.163 53.0°C
 #13 2.175 53.25°C
 #12 2.185 53.50°
 #11 2.207 54.00

5⁴⁰ #15 2.242 55°C
 #14 2.205 54.0°C
 #13 2.192 53.5
 #12 2.212 53.50
 #11 2.207 54.0°C

log N = .016
 Rod = 4.15"

5⁴³ #14 2.207
 5⁴⁵ Rod #2 Out (1st min = 67.2 sec 13.4
 last 2 min = 97.8 sec 9.84 avg = 11.4

Shutdown by using R-1 to trip

avg = 92.5 sec
 11.24

4/11/69 3-11-69

Expt. 6-7 Time 2³⁵ PM Date 3-24 1958
 Purpose Check of Reproducibility
also test of interchange temp.
 Personnel: DWM RKR DFC

START-UP CHECK LIST
 Equipment Checked by RKR Personnel Check by RKR
 Instrument and Safety Checked and Ready by DFC
 Source in Control Room by DFC Source N: PN 113
 Emergency Equipment in Control Room ready by DFC
 Red Light On by DFC
 Start-Up OK'd by DFC Time 235 PM Date 3-24 1958

Bottle #2 gross wgt H₂O only 156.507gms
 entire container filled with water.
 Bottle on motor #1 - zero - top of quartz -

3¹⁵_P

Water 92.5 cm Rod #1 4.19^{cm} in } Source in
 Rod #2 16.00^{cm} in } sub cont.

Water temp 23.25°C all thermocouples (0.905)

3²⁰

Rod #1 4.19" #2 13.39" 100 μ rad 282mV 44

3²⁵

Rod #1 4.19" #2 12.00" 100 μ rad 128mV 84

3³⁵

Rod #1 5.27 #2 12.00 level by N = .0011

R-1 66 (50x1000)

3⁴⁰

Rod #1 2.98 #2 21.34 by N .00075 } level

R-1 65 (50x1000)

3⁴⁵

Temp 23.0°C all thermocouples 0.902 mV

3⁵³


Rods next to Rod #1 5.27" Rod #2 12.00"

very slight upward trend on R-1

Rod #1 at 5.30" Rod #2 12.00" slightly sub on R-1

4⁰⁰ PM Rod #1 5.29 Rod #2 11.98 level
 Read #1 70 (50x1000) log N .0012

4⁰⁰ PM Bottle set at ~~11.00~~ 11.00 on sledge (fuel = 24" long
 base of fuel approx 2" up from grating)



4¹² Period too ^{large} ~~small~~ to measure
 Bottle mouth = 0.284 (Rod #1 at 5.29 Rod #2 12.05" at Crit.)

4²⁰ Bottle out - slight negative (38.96" up)
 Rod #1 at 5.29 Rod #2 11.98" Critical

Expt.	6-8	Time	4 ¹² AM	Date	3-24 1958
Purpose	Repeat of 6-7 with 4-235 in 3-4 gms in same bottle				
Personnel	DGM JFC				

Gross wgt bottle #2 (with) 160.899 gm

40 ml of soln pt in #2

60 ml " " put in Sample bottle Reg No

5¹⁴ Water at 92.5 cm for period. Bottle at 11.00
 5²⁰ Bottle out temp 18.99 mvarny Rod #1 at 5.29
 level log V = .001 P-1 = 65 on 50x1000 Rod #2 at 11.98
 R-1 = 5.29 "
 R-2 = 11.98 "

(over)

5⁴⁰ PM Bottle replaced at 11.00"

System level at 5.29" on Rod #1

12.70" on Rod #2

log N .001

R-1 66 (50 x 1000)

Thermocouples #11 .886

#12 .887

#13 .888

#14 .872

#15 .888

.8882

} 22.75°C avg

Period = 401 sec (level at 11.00 rods at 5.29 - 11.98

≡ 3 ♣

Expt. 6-9 Time 9⁰⁰ AM Date 3-25 1958
 Purpose Same array - bottle now
has 80 ml of soln of UO_2F_2 (ca. 6.4 gms)
 Personnel: R G RRF BK

START-UP CHECK-LIST

Equipment Checked by BK Personnel Check by BK
 Instrument and Light Checked and Reset by BK
 "Source In" Checked by BK Source No. PN213
 Emergency Exits in Control Room Observed by BK
 Red Light On by BK
 Start-Up OK'd by BK Time 9¹⁰ AM Date 3-25 1958

Bottle # 2 emptied, rinsed and + refilled
 with 80 ml of UO_2F_2 soln + water + replaced in reactor

10⁰⁷ Water at 92.5°C cm Rd #1 22.17" Rd #2 21.34" Sol. out.

T.C. #11 .893

#12 .882

#13 .890

#14 .890

#15 .882 ✓

22.75°C

10²³ Sol. out Rd1 at 5.289 Rd2 at 11.98" Water at 92.5 cm

slight prep period - 256 sec 4.5 d

10³⁰ $\log N = .0001$ R-1 = 66 (50x100)

10⁴⁰ #11 .8915

#12 .838

#13 .843

#14 .845

#15 .848

note only ice in thermos
no dumping

10⁴¹ Bottle removed to 38.56" Rd #1 = 5.29 } slight prep
 leveled at 11.93 on Rd #2 } period
 5.29 on Rd #1 } $\log N = .001$

11⁰⁰ A Both re-mounted at $\log N = .001$ Rd1 = 5.29
 263 sec 4.4 d Rd2 = 11.9893

11⁰⁵ Thermocouples all read .920 mV 23.50°C

11¹² bottles removed at Log V = 2.01 to 38.5"

11¹⁶ Thermocouples all 0.920 mV

11²⁰ # 2 Safety run in = 23.70" - 110 psi

11²⁶ Thermocouples all 0.920 mV

11²² AM Manual system to shut down

~~388~~
~~165.5715~~ Bottle wgt full = 165.3 grams

3-25-58

1^{KE}
1 PM

#2 162.9375 gm (60 ml sol'n)

Note: Zero of relayon Motor #1 is $0.78''$ with bottle and filled carrier. so actual position of all measurements to date at nominal $11.00''$ is actually $10.27''$ $10.07''$ $0.93''$

Expt. 6-10	Time 2 ⁰⁰ AM	PM Date 3-25 1958
Purpose Same as prev - bottle now with 60 ml of sol'n		
Personnel: R.A. RKR		

START-UP CHECK LIST	
Equipment Checked by RKR	Personnel Check by JSC
Instrument and Settings Checked and Rec'd by JSC	
"Source In" Checked by BK	Source No. BN 113
Emergency Equipment in Control Room Checked by JSC	
Red Light On by JSC	
Start-Up OK'd by BK	Time 2 ⁰⁸ PM Date 3-25 1958

2³⁰ PM Zero of bottle + carrier rechecked with 27 cm of water in tank = $-0.18''$

2³⁷ Recheck with water out of tank = $0.90''$

3⁰⁵ Bottle at $38.5''$ Rd 1 = 5.29 Rd 2 = $11.00''$ nominal 2.90 mV 4%

3¹⁵ all Thermocouples = 0.920 mV

3²⁵ Level Log N .00017 R-1 = 28 (25 x 1000)

Rd #1 = 5.29 Rd 2 = $11.85''$

3²⁵ Thermocouples = 0.918 mV

3²⁹ Bottle in - nominal Rd 1 = 5.29 Rd 2 = 11.85 to $11.00''$ 3.07 mV 3.8%

3³⁵ Level Bottle out Rd 1 = 5.29 Rd 2 = 11.85 Log N = .001

3³⁶ Rd1 = 5.29 Rd2 = 11.85" Bottle at 12.00" 321^{mm} 3.64

3⁴⁴ Rd1 = 5.29 Rd2 = ~~17.98~~ 17.98 Bottle at 12.00

3⁴⁵ Bottle at 10.00 Rd1 = 5.29 Rd2 = 11.85" 346^{mm} 3.44

Thermocouples all at 0.920 mm

3⁵² Sensing Log N 10035

Rd #1 at 5.29 Bottle at 10.00"

Rd #2 at 12.68"

3⁵⁷ Shut down

Recheck of bottle + carrier zero (water drained out) = 1.09"

3-26-58

8²⁵/_A Bottle filled with water - 157.900 gms.

START-UP CHECK LIST	
Equipment Checked by <u>RKR/OK</u>	Personnel Check by <u>RKR</u>
Instrument and Safeties Checked and Reset by <u>RKR/OK</u>	
"Source In" Checked by <u>OK</u>	Source No. <u>14213</u>
Emergency Equipment in Control Room Checked by <u>OK</u>	
Red Light On by <u>OK</u>	Time <u>8³⁰</u> AM
Start-Up OK'd by <u>OK</u>	Time <u>8</u> PM Date <u>3-26</u> 195 <u>8</u>

Expt. <u>6-11</u>	Time <u>8³⁰</u> AM	PM Date <u>3-26</u> 195 <u>8</u>
Purpose <u>Repeat of exp 6-7</u>		
Personnel: <u>RA RKR OK</u>		

9³⁰/_A Rd #1 5.29 Rd 2-10.62" bottle out per period water 92.5 cm

9⁴⁰ Rd 1 = 5.29 Rd 2 = 11.80 water 92.5 cm
 bottle at 38.5" R-40 (25x1000) / log N .00025

#11 0.925 #13 0.928 #15 0.928

#12 0.925 #14 0.931

9⁵⁰ R-1 - 40 (²⁵20x1000) / log N .00025

Rd 1 = 5.29 Rd 2 = 11.80 level

9⁵⁴ Bottle placed at 11.00" Rd 1 = 5.29 Rd 2 = 11.80"


10²⁰ Rd 1 = 5.29 Rd 2 = 11.85" bottle at 11.00"

R-1 50 (25x1000) / log N .00032

temp. 0.925 mv all thermocouples } level

10³⁵ Shut down.

Expt: 6-12	Time 2:30 AM	PM Date 3-26	1958
Purpose: <u>Perlin Foil appx 3/16" foil</u>			
Personnel: <u>JRF, RRR, JPC</u>			



NT foil on strainer
 appx 20" down from top
 of spot on element.
 measured $19\frac{1}{4}$ "
 - $7\frac{3}{4}$ "

$\frac{11.5"}{11.5}$ into fuel


2:55 PM water at 92.5 cm Rd#1 at 5.29 Rd#2 at 21.34 Sud Cnt

2:58 PM Rd 1 at 5.29 Rd 2 at 10.62 Slight + Period

$\frac{3:10:54}{3:15:54}$.00037 on log N (25 on R1 (50x1000))
 shut down from log N = .001 R-1 = 60 (50x1000)

foil counted 300 c/min on SA-1 400 c/min SA-2
 (after subtracting background)

Expt. 6-13 Time 3:58 PM Date 3-26 1958
 Purpose: Foil run as loaded
 Personnel: JKF PKR JRC



4⁰⁰ PM fails located between elements 12" ± 1/2" down from top of fuel

4¹² Water at 92.5 cm Rods + Sensor In temp 23°C

4²⁵ Rd #1 out Rd 2 12.00 per period in 100 min

4³¹ PM .0074 on log N

4³² PM level on log N .019 R-1 = 49 (1000 x 1000)
 Rd 1 out Rd 2 = 16.00"

4⁵¹ PM Shut down

Foil	g/min	Foil	g/min
156	2966 4750	150	31558 35036
151	8824	124	32455
155	29828	129	37602
122	4750 7966	174	31558

out

Expr. 7-1 Time 2³⁰ ^{AM} PM Date 3-27 1951
 Purpose Two 3x9 arrays separated by 5.6" of water edge to edge
 Personnel: RRR & WJA DFL

START-UP CHECK LIST

Equipment Checked by WJA Personnel Check by RRR
 Instrument and Safeties Checked and Reset by DFL & WJA
 "Source In" Checked by DFL Source No. PV213
 Emergency Equipment in Control Room Checked by DFL
 Red Light On by DFL Time 2³⁰ ^{AM}
 Start-Up OK'd by DFL Time 2 PM Date 3-27 1951

A-76	A-23	B-140		B-133	A-60	A-77
A-79						I-117
A-58						I-116
A-71						B-138
B-172						B-135
B-130						A-55
S-17				A-29		A-32
B-131	B-150	A-59		I-114	B-142	B-145
A-69	B-125	B-136		A-81	A-70	I-113

Z →

E
 ↓
 5.6"
 ↑

3⁰⁰P Sub Critical as limit log N max = .0015
Water at 92.5 cm

temp #11 .911 23°C
#12 .913 mv
#13 .914
#14 .911
#15 .91

Expr. 8-1 Time 1⁰⁰ AM PM Date 3-28 1958
 Purpose 3x9 arrays 4" apart (edge to edge)
 Personnel: RKR GWA DK

START-UP CHECK LIST
 Equipment Checked by DK Personnel Check by RKR
 Instrument and Supplies Checked and found by DK
 "Source In" Checked by DK License No. PN213
 Emergency Control Room Checked by DK
 Red Light On by DK Time 1⁰⁰ PM Date 3-28 1958
 Start-Up OK'd by RKR Time 1⁰⁰ PM Date 3-28 1958

A	I	A	B	B	A	A	B	A
77	117	73	138	131	32	81	145	55
A	A	A	A	B	B	A	I	A
60	80	57	61	124	141	29	113	70
B	S	B	I	B	B	I	B	I
133	28	143	116	138	135	121	142	117

Safety →

B							A	B
140							59	136
A							B	B
23							150	125
A	A79	A	A	B	B	S	B	A
76		58	71	122	130	17	131	69

4" edge to edge

CR#2

1²⁵ PM Water at 65.6cm Rod #2 all in 21.34"
 Source out just Curt - log N = .008 - R, 38 (100x100)
 temp #11 } .911 = 23.25°C
 #12 }
 #15 }

1³⁰ PM Water at 62.2cm Rod #2 all out - just Curt

Expt. <u>9-1</u>	Time <u>2</u> ^{AM}	Date <u>3-28</u> 195 <u>8</u>
Purpose <u>3 x 8 arrays 4" apart</u>		
6 elements removed from 8-1		
Personnel: <u>RKR IUM SK</u>		


- A-76
- A-23
- B-140
- B-133
- A-60
- A-77

2²³ pm Water at 68.7cm Super Coil }
 " " 68.5cm Sub Coil } Rod out

2 ²⁵	tamp 23.25°C			
	Rod out	water 68.85cm	+ Peroid 121.6in	8.24
	4.70"	"	level log 1.031	
	9.00"	68.85cm	- 86.9in	- 404(?)
2 ³⁵	9.00	74.8 cm	+ 71.7in	12.34
	11.05	74.8	level log N = .046	(79 (25x100))
	13.00	74.8	112.8	- 214
2 ⁵⁴	13.00			
	12.24	92.5cm	level log N = .0085	69 (50x100)
	water temp	23.25°C		
	11.05	92.5cm	147.8	74

total excess rod = 67.24

Three copies



START-UP CHECK-LIST

Equipment Checked by DK Personnel Check by DK
 Instrument and Safety checked and ready by DK
 "Source In" checked by DK Case No. PN-213
 Emergency Equipment in contact room checked by DK
 Red Light On by DK 4:55 AM
 Start-Up OK'd by DK Time 10:45 AM Date 3-31-1958

Expt. 9-2 Time 10:45 AM Date 3-31-1958
 Purpose Rept of 9-1 with changing temp.
 Personnel: JWK RPK DK

Rod #1 inserted between A-61 and B-138. roughly equivalent to Rod #2

11¹⁵ #15 TC = 0.910 mv } 23.5°C
 #12
 #11

11²⁰ water left at 30cm safety blade in -
 12^{40 PM} stand up again

12⁴⁷ Water at 68.2cm Rods out Source out temp = 0.920mv
 Critical 68.2 ± 0.1 cm

12⁵⁵ Rods out water 68.8cm temp 88.9 ± 0.1 °C
 #15 0.927 mv #12 0.928 #11 0.929

Rd #1 0.0 Rod 2 5.45 (E:05) Water 68.8cm level (by 11) = ...
 Rd #1 6.96 Rod 2 out " " "
 " 6.96 " " " " 69.4 ± 0.2 " 79.2 cm 116 ±
 Rod #1 6.96 " 5.60 " 69.4 level

1²⁰ Water at 97.5cm Rd #1 Rd #2
 6.96 10.59 level
 6.96 9.59 + 169.6 cm 6.6 ±
 8.30 9.59 level

1³⁰
 Rd#1 10.29
~~8.50~~ ~~9.50~~ 9.59 135.5m -12.8d
 10.29 7.75 level
 10.29 5.45 + 83.5m 11.2d
 12.18 5.45 level
 12.18 0.00 + 65.1m 13.4d
 14.42" 0.00 level log N = .18 R, 62 (40x1000)
 1⁵⁵ 17.00 0.00 - 140m. 13.6d
 14.42" 0.00 level
 0.00 12.97" level temp 0.919mv #11
 #12

log N = 0.05 R-1 = 42 (50x1000) .927mv #15

2²⁵ Sterns on no change #15 = 0.925mv (23.5°C)

2²⁷ Water on Riv in

2²⁹ Riv on R-1 from 43 to 45 (50x1000)

2³⁰ R-1 = 49 (50x1000)

2³² Rod #2 moved to 13.21" R-1 at 50 (50x1000) Rd#1 out

2³⁴ approx level temp #15 0.976mv #12 0.972mv

2³⁷ Rd1 = 2.49" Rd2 = 12.97 level

2⁵² temp #12 = 1.12mv 28.5°C #11 1.164mv 29.5°C

Rd#1 = 2.14" Rd2 = 12.97"

3⁰⁸ temp #11 1.257mv 31.75°C Rod 1 at 2.05" Rd2 12.97"
 #12 1.249 31.25°C
 #15 1.267 32.0°C

3²⁰ Rd#1 = 1.08" Rd2 = 12.97" (slight +)

3²⁵ temp 11 - 1.392 34.90°
 12 - 1.362 34.25°C
 15 - 1.366 34.25°C
 Rd#1 = 1.75" } level
 Rd#2 = 12.97" } log N = .07

3⁴⁶ PM Rd#1 out Rd#2 12.97" almost level log N = .05
 temp #11 1.577 - 39.25°C
 #12 1.532 - 38.25°C
 #15 1.554 - 38.75°C

4²⁰ PM Rd#1 out Rd#2 12.63" almost level log N = .04
 temp #11 - 1.830 mtr 45.25°C
 #12 - 1.779 44.25°C
 #13 - - -
 #15 - 1.794 44.5

Dir Rod #2 to 12.39"

Rod #2 at 12.97" = 57.4¢ = Rod #1 at 14.42"

5⁰³ PM Rd#1 out Rd#2 at 12.00 log N = .04
 #11 2.137 52.5°C
 #12 2.080 51.25°C
 #13 1
 #15 2.145 52.75°C

5²⁷ PM 55.25°C 6.26 me

5⁴⁰ pm phone call from Holland began leveling - (temp = rods.)

Thermo couples
 #15 2.341 57.2°C Rod #2 11.36"
 #12 2.27 55.5°C
 #11 2.34 57.2°C

5⁵⁰ PM #11 2.33 57.0°C } Rod #2 11.51"
 #12 2.285 56.25°C }
 #13 2.332 57.0°C }
 #15 2.346 57.3°C }
 26 49.2¢

6⁰⁰ PM

#11 - 2.357

#12 - 2.294 56.25°

#13 - 2.345

#15 - 2.360 57.7°C

level 11.43" #2 Rod

492d

6⁰⁹ PM

#11 2.33

#12 2.29 56.25

#13 2.34

#15 2.36 57.7°C

#2 Rod 11.42 ± .05

log W .02

R-1 27 50 x 1000


level

6⁰⁵ PM

Shutdown

Expt. 10-1 Time 1¹⁰ ^{AM} PM Date 4-1 1958
 Purpose 8x8 array with a 3x3 hole
off center as shown -
 Personnel: _____

START-UP CHECK LIST
 Equipment Checked by RKR Personnel Check by TWA
 Instrument and Safeties Checked and Reset by PR
 "Source In" Checked by DK Source No. PA 3C
 Emergency Equipment in Control Room Checked by RKR
 Red Light On by DK 10 AM
 Start-Up OK'd by DK Time 1 PM Date 4-1 1958



H₂O

52.0 cm

cut

52.1 cm

super

52.6 cm

Rod # 1 in @ 22.17 cut

54.1 cm

Rod # 2 in @ 21.34 cut

Temp. # 11 .885 mv

Expt. 10-2 Time 2¹⁵ PM Date 4-1 1958
 Purpose Remained 3 inner elements
on west face (A-81, A-80, A-55)
 Personnel: _____

Safety position unchanged

- Rod #1 and #2 unchanged

H₂O

63.9 cm

64.0 cm

89.6 cm

sub. { both rods out
super

rod #2 = 17.07, just crit.

305
 Temp #11 378
 #12 "
 #13 "
 #14 "
 #15 "

1.024 *4000*

	Safety	Rod #1	Rod #2		log W
	5.54	0.00	17.07	crit	.00048
	"	0.00	16.04	9.34	
	"	22.17 (in)	16.04	~ level	.004
	7.80	Safety	16.04	~ level	
	7.80		15.04	9.64	
3 ²¹ PM	10.50		15.04	level	.033
3 ²⁴	11.90		15.04	neg period	
	10.50		15.04	~ level	
3 ²⁸	10.50		14.04	11.94	
	12.35		14.04	level	.05
	14.36		14.04	neg per.	
	12.35		14.04	level	

Exp. 10-2 cont

	Safety	Rod #2		Log N
	12.35	13.04	11.94	
3 ⁴⁰ P.M.	All thermocouple	18.65	22 °C	
	13.80	13.04	level	.05
	15.80	13.04	neg. period	
3 ⁵² P.M.	13.75 (best value)	13.04	level	.01
	13.75	12.04	12.74	
	15.02	12.04	level	.04
reduce power level	17.05	12.04	neg. per.	.01
4 ⁰⁴	15.02	12.04	level	
	15.02	11.04	12.24	
	15.85	11.04	level	.05
	18.02	11.04	neg. p.	
	15.85	11.04	level	.01
4 ¹⁶ P.M.	15.85	10.04	14.14	
4 ¹⁷ P.M.	All Thermocouples	= 19.23	= 23.5 °C	
	17.10	10.04	level	.05
	19.04	10.04		
	17.05	10.04	level	.006
	17.05	9.04	7.94	
4 ³⁰	18.07	9.04	level	
	20.00	9.04	neg. p.	
	18.07	9.04	level	
	18.07	7.60	12.74	
	18.93	7.60		.04
	23.70	0.0 (out)	still neg	

Expr. <u>10-3</u>	195
Purpose <u>Same array as 10-2</u>	
<u>Here water is pre-heated (from exp 10-2)</u>	
to ~	
Personnel: <u>Cronin, Callahan, Gilley</u>	

5¹⁵ PM. Thermocouple #11 1.517

#12 1.393

5¹⁹ PM #11 1.529 all out

5²⁰ Water 92.5 cm Rod 2 - 21.34 Sub Cool

Stevens Rec -

5²² PM #11 1.525

5²³ PM #12 1.521 #15 1.522

5²⁴ PM #14 1.524 #13 1.518

5²⁴ PM #11 1.518 #12 1.510

5²⁸ #11 1.520

~~5²⁹ Rod #2~~

5³⁰ PM #11 1.514 38°C

5³² ~~#~~ #11, 1.513 #12, 1.515 #13, 1.516

#14, 1.515 #15 1.519

Rod #2 Rod #1 Safety

H₂O 92.5 16.11 0.0 5.54


5³⁵ PM 15.11 0.0 5.54 91.3 sec 10.4 &

just crit.

~ 9.3 decrease

Expt. 10-4	Time 1:30 AM	Date 4/2 1958
Purpose Same array of elements as exp # 10-2		
Personnel: Cowin, Gilley		

NOTICE: This drawing is in error. There should be 3 rows of elements on the south side, same as fig. in exp. 10-1



lead is 2" thick

1/2" spacing between elements and lead

Temp. 1:45 #11, 920 #12, 910 #13, 940 #14, 915 #15, 912

5:17 P.M. Rod #1 0.0 Rod #2 0.0 Safety 5.54 (out) H₂O 63.15 ± 0.5

Temp by thermocouple #11, 916 : #12, 917 : #13, 920 : #14, 923 : #15, 923

Thermocouple locations:

- # 15 in water channel ~ 1/2 way up
- # 14 between lead & fuel on ^{East} face ~ 1/2 way up
- # 13 Southeast corner ~ 4' off floor
- # 12 in element S 28 ~ 1/2 way down
- # 11 ~ 1 ft outside array, at the base

log W	Rod #1	Rd #2	safety	H ₂ O	P
	0.0	20.40	5.54	92cm	crit
	0.0	21.34	5.54	"	neg. 258mm
.0015 + .003	"	20.40	"	"	level
	"	19.00	"	"	8¢ + 126 mm
.013	15.81	19.00	"	"	I
	15.81	18.00	"	"	7.2¢ + 147.5 mm
	22.20 (in)	18.00	"	"	4.2¢ + {still} 273.2 mm
.07 ⁴¹ 2 ^{PM}	22.20	18.00	9.05	"	I
	"	16.50	"	"	12.7¢ + 69.5 mm
.7 3 ⁰⁸ PM	"	16.50	11.51	"	I
	"	18.00	"	"	- 146.5 mm
.1	"	16.50	"	"	I
	"	15.50	"	"	10¢ + 95.6 mm
.6	"	15.50	12.69	"	I
	"	16.50	"	"	- 165 mm
.15 3 ³⁷ PM	"	15.50	"	"	I
	"	14.50	"	"	11 + 84.6 mm
Thermocouples all read .921 @ 3 ⁴¹ PM 23.75 °C					
	"	14.50	13.92	"	I
	"	15.50	"	"	- 141 mm

total power crit at 14.5" Rd 2 = 97.8¢ [48.9¢ Rd 2 48.9¢ safety plus rd]

4⁰⁰ PM Water drained, 8.5" cd safety blade placed in assembly between two rows of elements (on north side of elements A61, B125, B124. Rod #1 was removed,

margin = approx 44.7¢

Log N Rod #2 Safety * H₂O P
 .005 9.05 " I

5⁰⁰

Water drained. 3" water control rod (#1) placed in assembly as shown in fig. on page 149

System critical (approximately) with safety at 5.55 and with control #2 = 0.00


5²⁵

8 1/2" blade removed from reactor. Rod #1 moved ~ 3" East of position shown in fig. on p 149

5⁴⁵

21.34	5.55			
12.25	5.55	85.4	I	
11.50	5.56	10.54	+ 88.9mc	
11.50	10.54	"	I	
10.50	10.54	12.6	+ 70.5mc	
10.50	12.39	"	I	
6 ⁰⁸ PM	10.50	13.94	- 117.8mc	
	10.50	12.39	I	
	9.50	12.39	11.44 + 80.3mc	
	9.50	13.59	I	
6 ²⁰ PM.	11.54	13.59	- 86.8mc	
	9.50	13.59	I	
	8.50	13.59	11.50 + 79.2mc	
	8.50	14.70	I	
6 ³³ PM	10.50	14.63	- 88.9mc	
	8.50	14.63	I	

Temperature at 5⁴⁵
 #11 .922
 #12 .922
 #13 .925
 #14 .927
 #15 .914
 #20 ± 23.25 °C



Lead and board on four sides of assembly placed as shown.

E_{cut}

E _{cut}				Temp.	
Rod #2	Safety	H ₂ O	e	#11	#12
				.923	
7.50	14.43	" 10¢	+ 95.6	#12	.921
6 PM 7.50	15.48	"	I	#13	.923
9.50	15.48	"	- 95.6	#14	.923
7.50	15.48	"	I	#15	.913
6.00	15.48	" 13.2¢	+ 67.3		
6.00	16.50	"	I		
8.50	16.50	"	- 84.7		
6.00	16.50	"	I		
4.00	16.50	" 12.4¢	+ 74.9		
4.00	17.38	"	I		
7.50	17.38	"	I		87.9
4.00	17.38	"			
0.00	17.38	" 11.2¢	+ 84.6		

4-7-58

Sample of Reflection water for ppm & spec -
Reg 354915 (composite of both tanks (1 gal))


.02 ppm

Spec on 5 ml of sample -

element	ppm
Bc	<.001
Ni	.1
Si	8
Li	.05
Na	9
Mn	<.1
Mg	40
Kc	<1
Cu	.1
Cr	.2
Ca	25
B	.05
Al	.6
Cd	.03
Co	<.1
V	<.1

6th

Expt. 3-1 Time AM Date 4-28 1958
 Purpose 12" SS cyl no reflector (see exp 1-1)
cyl on stand on floor - 8 ft from
insulated wall
 Personnel: _____



bottom of cyl approx 3 ft from plywood floor [29"]

4:00 PM • Exp not run - much difficulties.
 cont on next page

Expt. <u>3-1</u>	Time <u>10</u> ⁰⁰ AM	Date <u>4-29</u> 195 <u>8</u>
Purpose <u>12" E.S. outside cell</u> <u>on floor - no reflector</u>		
Personnel: <u>JWB RM - JH</u>		

START-UP CHECK LIST	
Equipment Checked by <u>JH</u>	Personnel Check by <u>EKA</u>
Instrument and Safety checked and reset by <u>JH</u>	
Source Int. checked by <u>JH</u>	Source No. <u>DL PN 213</u>
Emergency Equipment in Control Room checked by <u>JH</u>	
Red Light On by <u>JH</u>	Time <u>10</u> ⁰⁰ AM
Start-Up OK'd by <u>JH</u>	Date <u>4-29</u> 195 <u>8</u>

Probe zero (just in bottom of reactor) = 0.04 on relay -
 Previous Hc = 11.84" (inside cell no other reflector)

10²⁰ AM First detectable change (on DC 3n 290) at 7.27"

10⁴⁰ Level B reactor (had tilted) -

drain back - zero on probe now 0.00.

12⁵⁵ PM Re start - solution gas [inside 1/2 the radius
 of reactor (bottom is tapered)] = 0.05 on relay -

1²⁰ PM at 11.88 super critical k_{eff} .008

at 11.87 sub critical.

at 11.99⁴ per period, 130.4 revs.

at 11.91 critical k_{eff} .12

Critical Conditions

HT

11.91

-.05

11.86 inches

.03 inch = 130.4 sec period.

START-UP CHECK LIST

Equipment Checked by DJK Personnel Check by RKR
 Instrument and Safeties Checked and Reset by RKE
 "Source In" Checked by OK Source No. AN 213
 Emergency Equipment in Control Room Checked by DJK
 Red Light On by DJK
 Start-Up OK'd by DJK Time 8:40 AM PM Date 5-5 1958


Expt. 4-1 Time 8:40 AM PM Date 5-5 1958
 Purpose 10" Al cyl no reflector
out on floor of Rm 201
 Personnel: Smith, RKR, DJK

Probe set at .00

9⁰⁰ 19.00" fuel substituted by N from .001 to .0025

9³⁰ 20.87" fuel max available

	Fuel Wt.	2 min. count	
		C ₄	C ₅
<u>9⁵⁰ AM</u>	20.87"	.508 16 ² x16 +15 527	730 23 ⁺² x14 22 ⁺⁸ .313
"	19.12"	.567 15 ⁺⁵ 14 ⁺⁴ 473	623 18 ⁺¹² 20 ⁺³ .367
"	18.18"	.581 14 ⁺⁹ 14 ⁺⁵ 462	599 18 ⁰ 19 ⁺² .385
<u>10¹¹ AM</u>	16.27"	.674 12 ⁺¹¹ 12 ⁺³ 398	520 16 ⁺¹⁰ 15 ⁺¹⁴ .44
"	11.70"	.756 10 ⁺¹⁵ 11 4 355	383 10 ⁺⁸ 9 3 .732
"	10.69	.826 10 ⁺² 10 3 325	257 9 3 7 12 8 5 .89
"	10.68		



155

$10 \frac{34}{A}$

9.06''

0.00

$8 \frac{+7}{92} \} 281$

72

$7 \frac{10}{6}$

6

$16 \frac{13}{}$

229

Expt. <u>5-1</u>	Time <u>9¹⁵</u> AM	Date <u>5-7</u> 195 <u>8</u>
Purpose <u>10" AI reactor (36" dia) with water reflector</u>		
Personnel: <u>JWA RNR DH</u>		

START-UP CHECK LIST	
Equipment Checked by <u>DH</u>	Personnel Check by <u>DH RNR</u>
Instrument and Safety Checked and Reset by <u>DH RNR</u>	
Source Int. Checked by <u>DH</u>	Source Int. Checked by <u>RN 217</u>
Emergency Interlocks Checked by <u>DH</u>	
Red Light On by <u>DH</u>	Checked by <u>DH</u>
Start-Up OK'd by <u>DH</u>	Time <u>2:35</u> AM
	Date <u>5-7</u> 195 <u>8</u>

9³⁰ Probe zero
 leaks in solution flange caused by
 using 2 gaskets by mistake -
 10³⁰ Leak checking began -

2⁰⁵ Re zero probe - 999.98

2¹² Solution set at 1.01 = 20.99" Top tongue out of 0.99"

3³⁵ PM Sol = 7.43" TT sol = 7.54"
 R-1 DC-2 DC-3 R-2
 35-38 (10x100) 53 (1x20) 32 (1x50) 50-55 (10x100)

3⁴⁰ Solution dumped

3⁴⁵ Solution returned to probe = 7.43" TT still at 7.54"

R-1 DC-2 DC-3 R-2
 3⁵⁰ PM 18-20 (10-100) 44 (1x20) 19 (1x50) 40-45 (10x100)

3⁵² Solution dumped

Expr. 5-2 Time 8²⁰ AM Date 5-8 1956
 Purpose Repeat last part of 5-1
to check reason for apparent
change in conductivity
 Personnel: J. W. D. R. K. R. B. K.

START-UP CHECK LIST
 Equipment Checked by DK Back by RKR
 Instrument DK
 Source In DK 14213
 Emergency DK
 Red Light RKR
 Start-Up OK'd by DK Time 8²⁰ AM Date 5-8 1956

8²² Water ht still 57.6 cm after sitting all night -
 with empty sol cyl - evidently no major in-leakage
8³⁵ Fuel ht at 7.43" TT at 7.54"

<u>8⁴⁵</u>	R-1	DC-2	DC-3	R-2
	45-50	57	36	50-52
	(10x100)	(1x20)	(1x50)	(10x100)

8⁵⁸ Sol'n dump + re-circulation started.

9⁰⁰ Stopped circulation + allowed to cool

9¹² Opened feed valves -

9³⁵ Fuel 7.43" TT at 7.54"
 R-1 DC-2 DC-3 R-2

<u>9⁴³</u>	28 (10x100)	46 (1x30)	22 (1x50)	42 (10x100)
-----------------------	-------------	-----------	-----------	-------------

9⁵⁰ Recirculating fuel

9⁵⁰ stopped

10⁰² started feeding again

10²⁰ Fuel at 7.43" TT at 7.54" (never removed)

	R-1	DC-2	DC-3	R-2
	32 (10x100)	49 (1x20)	25 (1x50)	47 (10x100)

Crit. Condition

10:38A

Fuel

TT

7.23

6.90 contact sub

7.69

6.88 super

.46 →

probe level up when TT is contact

TT left at 6.88

Fuel dumped

10⁵⁵

Fuel brought back to 7.69 on probe - Sub crit. (7.23" actually)

10⁵⁷

Fuel at 7.25 TT at 6.90" = contact sub

probe at 7.96 TT at 6.87" just sub -

" 8.50

6.84 super

11⁰⁷

Dumped

Expt.	5-3	Time	12 ⁴⁵	PM	Date	5-7	1958
Purpose	Repeat to check reproducibility						
	10" RI reflected						
Personnel	JWM RKR DFC						

35
6.87
7.96
7.22

12⁵⁵

Water at 57.6 cm

RI DC-2 DC3 R-2

32(10x11) 49(1x24) 26(1x50) 86-48(10x100)

Fuel at 7.43" TT at 7.54"

1⁰⁵

Fuel at 7.23" TT at 6.87" = contact

probe TT

probe 7.48"

Fuel dump -

7.90 6.85 super.

7.89 6.82 crit

8.12 6.81 super

120

ndre	TT	
8.34	6.80	super
7.99	6.80	sub
8.60	6.77	super
8.46	6.77	super
8.39	6.77	super crit
8.24	6.77	sub.
8.53	6.75	super
8.33	6.75	sub
8.75	6.74	super
8.75	6.72	super
8.77	6.71	sub
8.80	6.70	super
9.23	6.67	super
9.33	6.65	sub
9.69	6.63	super
10.00	6.61	super
10.59	6.56	sub
10.19	6.59	just crit.
9.80	6.61	just crit. sub crit just crit.
8.82	6.66	sub crit
7.71	6.71	sub. crit.
7.08	6.81	sub. crit.
7.11	8.05	"
7.11	9.06	"
7.11	6.74	contact

no solution added or subtracted
 hence,

over:

Coil Cond

Solution Ht w top temp just in contact = 7.11"

Top temp when reading = 6.75" diff $\frac{6.74}{0.37}$
 at optimum top temp position

D.W. 7-20

9.5" Fuel = 10.19" TT = 6.61"

3.08" of fuel between sides of TT + cyl
 connected just Coil fuel lit (no clearance for top temp
 = 6.88"

3³³ P.M. Probe zero at ~~999.96~~ 99.99 Water out
 " " " 99.94 " 14

3³⁵ P.M. Sample taken from system 26 0.33
 Reg 655326 G 84.6449 25 - 37.3870
 T 19.5580 W - 0.2690
 N = 65.0869 gm U - 6203

Duplicate held back G 144.5788 - loss of weight 5/15/58
 T 19.7780 B. 144.5770 gm
 124.6008 gm

Reg 635327 Re sample of Reg 635326
 G - 69.4866
 T 19.8367
 N 49.6499

see page 167

My phone Sp 5 = 2.0064
 .44/34 gm U/air
 Imp = 140 gm FC
 6 mg rest are 2 listed.
 4 CU

Expt. 6-1 Time 10¹⁵ AM Date 5-16 1958
 Purpose 8" Al cyl. Annular type
water reflected
 Personnel: DFC, RKR, JRF, WA Pyrov

START-UP CHECK LIST
 Equipment Checked by DFC Personnel Check by RKR
 Instrument and Safety Check by DFC
 Source Int. Checked by DFC PN 213
 Emergency Equipment in Control Room OK
 Red Light On by RKR W.A.P.
 Start-Up OK'd by DFC Time 10 AM Date 5-16 1958

10¹⁵ Water at 47.6 cm above reactor bottom

John P.	Tamper R	C ₁	C ₂	C ₄	C ₅
3.22	1 st contact 3.27				
6.02	6.09	60	290	4.2	1.4
		60	280	3.2	2.0

11 ⁰⁰ / 11 ¹⁵	8.01	8.09	80	320	3.2	1.2
			50	300	3.0	2.0

Dumped water to move instr. ~~closer~~ closer

Raised H ₂ O → to 47.8 cm	6.01	6.08	70	280	16.7	5.8
	8.02	8.09	70	280	12.5	7.7
	10.05	10.12	110	290	14.0	8.2
	12.01	12.10	170	380	14.7	9.6 ⁰⁷³
	12.61	12.69	sub.			
	12.69 ⁵	12.77	"			
	12.92	13.01	"			
	13.09	13.20 (Not-1 st cont)	sl. super			
	13.04	13.14	"			
	12.96	13.10 cont.	"			
13.00	12.92	13.07	"			
	12.93	12.93	just crit			

162

5/20/58

Re-sample of system - salm simulated for 45 min before sampling - Reg 635328

G = 77.3862 0.4410 gm/gm
T 17.9214 2.004 gm/gm
N 57.4748 gm

Duplicate held back

Results from Reg 635326 + Reg 635327

U = 0.441340 SpG = 2.0064 at 25°C

Spec.

Ni < 25	Cu 4	Al < 7
	Cr < 6	Ag < 1
Sn 40	Ca < 50	
Si < 10	Mn < 10	
Mg 6	B < 1	
Fe 140	Cl < 50	

Assay

W = 0.26	234
X = 37.38	235
V = 0.33	236
Q = 62.03	238

6-25-58/

Salvage

#1 11 liters #2 8 liters

Reg 635329 (89.2 gm sample) Reg 635330 (80 gm sample)

PLUTONIUM IDENTIFICATION TAG

NO. 1910

PART 1 OF 1 PARTS

DATE 5-19-58 MATERIAL TYPE 1337

SOURCE UO₂Pu

WEIGHT GROSS 31.430

TARE 2.909

NET 28.726

OPERATION OPERATOR

U 12.320 gms LIMIT U Safe limit

ASSAY 37.5 Pu x LIMIT X Safe limit

REQUISITION 394629

DISPOSITION for shipment to 7-10

REMARKS awaiting analysis

2.37 — 2.26

16.76

soln

(counter)

START-UP CHECK LIST

Equipment Checked by SK Checked by RKR
 Instruments and Supplies Checked and OK
 "Source Int'l. License" by SK PN 213
 Emergency Equipment Checked and OK
 Red Light: On by SK 45
 Start-Up OK'd by SK Time 7-15 PM Date 7-15 1958

Expr. 7-1 Time 7:45 PM Date 7-15 1958
 Purpose Continue Exp 4-7 (10" Al exp)
no reflector - in Well - much more
solvent - previous extrapolation = 30-35 " sol'n
 Personnel: FWD, RKR, SK

Time	Probe	West reactant tube	South wall on floor	Under tank	H. Button { on opposite side from source
		C ₁	C ₂	C ₃	
7.94	6.00	1240	1450	6 ⁺⁷ x 64	115 @ 880 units
"	"	1160	1440	6 ⁺³⁴ x 64	
"	"	1140 } 1152	1430 } 1433	7 ⁺⁴ x 64	
"	"	1170	1420	7 ⁺⁷ x 64	
9.96	10.0	2310 } .498	2430 } .588	4 ⁺³² x 64	300 .383
"	"	2280 } .525	2340 } .612	7 ⁺¹⁹ x 64	
"	"	2370 } .485	2380 } .402	6 ⁺⁵³ x 64	
11.98	12.0	3030 } .380	2860	8 ⁺¹ x 64	415 .277
"	13.00	2200 } .360	2840 } .505	8 ⁺¹⁹ x 64	
12.98	13.00"	3490 } .33	3040 } .470	9 ⁺¹⁰	C ₄ 4 428 (1 min)
"	"	3480 } .33		8 ⁺⁵⁴ x 64	
15.99	14.0	4800 } .24	3690 } .38	9 ⁺⁴⁶ x 64	.189 → 75 ⁺¹³ x 16 (2 min)
19.95	19.95	6820 } .169	4810 } .298	11 ⁺¹⁶ x 64	.145 → 99 ⁺¹³ x 16
24.02	24.02	9400 } .125	6150 } .233	13 ⁺⁴⁹ x 64	.117 → 123 ⁺² x 16
"	"		6110 } .234	15 ⁺¹⁶ x 64	117 ⁺⁴ x 16

L.L	Probe	C ₁	C ₂	C ₃	H. Button
27.96	28.00	12520 .092	7520 .19	15 ⁶³ x14	.098 → 145 ⁺¹⁰ x14
29.96	30.00	14060 .082	8480 .168	17 ⁺⁵³ x14	.092 → 156 ⁺⁵ x14
31.98	32.01	16430 .07	9580 .149	20 ⁴ x16	.083 → 173 ⁺¹⁴ x14
33.90	34.00	19240 ^{.064} .059	11060 .128	22 ⁺⁶ x14	.076 → 188 ⁺¹² x14

Entropy between 44-45 inches

8
 10
 11
 12
 13
 14
 15
 16
 17
 18
 19
 20
 21
 22
 23
 24
 25
 26
 27
 28
 29
 30
 31
 32
 33
 34
 35
 36
 37
 38
 39
 40
 41
 42
 43
 44
 45
 46
 47
 48
 49
 50
 51
 52
 53
 54
 55
 56
 57
 58
 59
 60
 61
 62
 63
 64
 65
 66
 67
 68
 69
 70
 71
 72
 73
 74
 75
 76
 77
 78
 79
 80
 81
 82
 83
 84
 85
 86
 87
 88
 89
 90
 91
 92
 93
 94
 95
 96
 97
 98
 99
 100

Exp 7-1

7-15-58

10" AI cyl

NO T diff Inside Well

99-185841

11
10.8
10.7
10.6
10.5
10.4
10.3
10.2
10.1
10



8 10 12 14 16 18 20 22 24 26 30 32 34 36 38 40 42
42/125

START-UP CHECK LIST

Equipment Checked by RIK Personnel Check by RIK
 Instrument and Safeties Checked and Reset by JKE
 "Source In" Checked by _____ Source No. PN213
 Emergency Equipment in Control Room Checked by JKE
 Red Light On by JKE AM
 Start-Up OK'd by 9:30 Time _____ PM Date 7-16 1968

Expt. 8-1 Time 9:30 AM PM Date 7-16 1968
 Purpose Repeat of Expt # 5
10" Al wgl regulated with water (annular type wgl
pressure = 6.98" fuel (fuel = 7.11" H₂O 6.74")
 Personnel: JKE RIK JAC

Time	Water	Fuel Man.	Top Tamper	Probe	Q
10 ¹⁵	68 cm	.001	+	.07	.04
10 ¹⁸	"	1.96 .35	2.3 / contact	2.03 .32	1.99
10 ²⁷	"	4.04 .35	4.42 "	4.12 .34	4.08
10 ³²	"	4.90 .45	5.35 "	5.04 .38	4.97
10 ³⁵	"	5.66 .66	6.32 "	5.99 6.045	
10 ⁴³	"	6.66 6.94 .38	7.32 "	7.01 .34	6.98
10 ⁵²	"	6.99 .41	7.40 "	7.10 .35	7.05
	"	7.06	7.32 Max. P	"	
10 ⁵⁵	"	7.13, 7.15	7.49 contact	7.20	
	"		7.41 Max. P		
11 ⁰⁴	"	7.16	7.62 Super crit.	7.30	
11 ⁰⁸	"	7.14 .41	7.57 contact	7.22	
	"		Super crit		
11 ¹⁵		7.20	7.48 max P	7.255	just crit.

$$\begin{array}{r} 7.48 \\ - .35 \\ \hline 7.13 \end{array}$$

H_c

DWA
14 Sept 68

Expt. 8-1 Time 00 AM Date 7-16 1957
 Purpose Repeat of Expt 4-5
10" Alarm by reflection with water.
 Personnel: Fox, D.F.C., R.K.R.


Time	Water	S-Monometer	Fuel Probe	Fuel Top-Tank
1.12 PM	6.8 Am	<u>DW</u> 1.09	1.09	
1.23 ..		14 Sept 66 2.02	2.06	
		2.99	3.01	
		3.98	4.00	
		5.00	5.01	
1.20 PM		6.00	6.01	
	Δ	6.99	6.50	
	.32	6.96	6.98	7.30 cont.
		6.99	7.225	7.53 "
		7.18	Sup. crit. (7.225)	7.44 Pmax
		7.17	" "	{ 7.54 contact
		7.21	7.24	{ 7.45 - P max
		7.23	7.30	7.60 contact
			Super crit	Pmax
		7.24	7.245 7.25	Pmax 7.45
				Same as
				8-1 9 ⁰⁰ AM
				DW

Exp. 9-1 Time 8:15 AM Date 7-18 '88
 Project 10" Bone AI cyl outside
 on floor
 RKR & WJZ etc

H. Button is against
 wall of cyl. 15" up
 from bottom

START-UP CHECK LIST
 Equipment Checked by RKR Personal Check RKR
 Instrument and Safety Check OK
 "Sound" OK
 "Start" OK
 "Stop" OK
 "Run" OK
 "Reset" OK
 "Time" OK
 "Date" OK
 "Time" 8:15 AM
 "Date" 7/18 '88

Time	L.L.	Probe	C ₁	C ₂	C ₃	H Button
8:30 AM	6.275	6.275	310	360	2 ¹⁴ x 64	5 ⁺¹¹ x 14
	"	"	350	390	2 ¹⁵ x 64	4 ⁺¹³ x 16
	"	"	310	370	2 ¹⁷ x 44	4 ⁺⁷ x 16
8:45 AM	12.13	12.13	400	450	1 ⁵³	6 ⁺⁴⁺² x 16
			390	430	2 ⁺²	5 ⁺⁸ x 14
9:05 AM	18.50	18.30	480	550	2 ⁵⁴	24 x 16
	11	11	560	570	2 ⁺⁴⁶	23 ⁺¹⁰ x 14
			500	540	3 ⁺¹²	
9:15	23.95	23.95	640	710	2 ¹⁴⁴	42 x 16
			610	660	2 ⁺⁶²	42 ⁺¹⁴ x 16
9:30	30.22	30.22	880	910	3 ³ x 64	61 ⁺² x 14
			850	880	3 ²⁶	61 ³
9:42	34.02	34.02	1030	1070	4 ²⁵	68 ³
			1050	1010	4 ¹³	65 ⁺¹²
9:55 AM	38.02	38.02	1300	1380	4 ⁴⁵	83 ¹²
			1240	1320	4 ⁴¹	90 ¹³



	LiLi Probe	C ₁	C ₂	C ₃	H Bottom
10 ¹⁰	42.0	1510 } ⁵⁵⁵ 1600 } ²⁰⁸	1680 } ¹⁷⁴⁵ 1810 } ²¹⁴	5 ³⁴ } ³⁵¹ 5 ²⁴ } ³⁹	104 ⁵ } ¹⁶⁸⁰ 105 ¹¹ } ¹⁶⁷⁸

DC-2 resumed - at 1120 am - no other instrument can ~~not~~ suggestivity.

10⁵⁰ A.M. Probe become faulty - no longer usable for this experiment. Monometers to be raised for higher readings
 Liquid level monometer reads 10.001" before moving
 " " " " 10.005 after moving
 and resetting system.

	<u>Selected Reading</u>				
11 ⁰⁰ A.M.	10.005	700 (4 min)	830 (4 min)	6 ³³ (4 min)	10 (4 min)
	28.02	730 (2 min)	850 (2 min)	3 ³⁵ (2 min)	47 (2 min)
	"	740	800	3 ³⁴	50 ³
11 ²⁰ A.M.	39.97	1300 } ¹³³⁵	1390 } ¹³⁸⁵	17 ¹⁷	82 } ³⁴⁹
		1370 } ²⁴²	1380 } ²⁶⁹	4 ¹⁸ } ²⁷⁴	88 } ¹⁰⁵⁸⁶
11 ³⁰	44.00	1680 } ¹⁶⁹⁰	1730 } ¹⁷⁹⁰	6 ²⁵ } ³⁷⁶	108' } ¹⁷⁶⁰
		1700 } ¹⁹¹	1810 } ²⁰⁹	5 ²⁴ } ³⁶⁵	112 ⁵ } ¹⁰⁴⁵⁵
11 ⁴³ A.M.	50.02	2740 } ²⁷⁸⁰	2289.0 } ³⁰⁹⁵	9 ⁺⁸ } ⁵⁸⁴	174 ¹¹ } ²⁷³⁶
		2890 } ¹¹⁶	3100 }	9 ⁺⁸ }	168 ⁴ } ¹⁰²⁹
		2710 }	3090 } ¹²⁰⁵	9 ⁺¹³ } ²³⁴	
12 ⁰⁰	53.31	4520 } ⁴⁶⁶⁰	5100 } ⁵¹⁴⁰	15 ⁻⁹ } ⁹⁷²	272 ¹¹ } ⁴²⁰⁸
	11	4800 } ¹⁰⁶⁹²	5180 } ¹⁰⁷²⁵	15 ⁻¹⁴ } ¹¹⁴¹	254 ⁹ } ¹⁰¹⁹

2 ²⁰/_{PM} Float on liquid level manometer stuck -
probe in pulled out -


Re-zeroed probe + servomanometer

Servo Probe { this is a check
7.81 7.91 { an agreement of h.l. and probe

Solution circulating - by-pass closed to gain
additional volume

Time	h.l. Probe	C ₁	C ₂	C ₃	H Button
2 ³⁴/_{PM}	12.01	12.05			

Exp 9-2
10" Bare Al cyl



Exp. No.	9-2	Date	7/18 1958
Purpose	10" al. cyl. bare (outside on floor)		
Personnel	JRF, JHC		

5 Minute Counts

Time	L.L. Probe	C ₁	C ₂	C ₃	H. Button
2 ³⁴	12.01-12.05	1020	1180	4 ⁶¹ / ₆₄	13 ⁰ / ₁₆
2 ⁴⁹	20.01-20.01	1360 .75	1550 .76	6 ⁺³¹ .77	17 ⁺³ .77
3 ⁰¹	29.99, 29.99	1980 .514	2260 .522	7 ⁵⁰ / ₆₂₅	137 ³ .095
3 ²⁰	40.05 40.06	3250 .315	3610 .327	11 ⁵⁶ / ₄₁₇	215 ¹ .0605
3 ²⁷	43.96 43.99	3870 .264	4290 .275	14 ⁶ / ₃₄₈	250 ¹¹ .0504
	47.97 47.98	5200 .196	5560 .212	17 ⁵⁸ / ₂₇₈	316 ³ .041
	50.04 50.08	6360 .161	7070 .167	20 ⁴⁸ / ₂₄₄	585 ³ .0337
3 ⁵²	52.07 52.09	8000 .128	8740 .135	26 ⁶² / ₁₈₅	464 ¹⁴ .028
	54.02 54.04	10820 .0944	12020 .0982	34 ²¹ / ₁₄₆	614 ⁵ .0212
4 ^{22 PM}	54.80 54.81	13020 .0785	(3320)	41 ¹⁹ / ₁₂₂	716 ⁴ .0181

this is all of solution that can be pumped to cyl. = 70.54 Liters

4³⁷ 13020 14,840 .0785 42⁺¹² .117

64.696 Kg U 23.94 Kg X in 70.54 liters Volume


7/21/58 S/n sampled - 58.7 gm sample Reg 635331
 0.44750 gm U/gm
 S/n = 2.0495

Expt. 10-1 Time 1⁰⁰ AM PM Date 7-22 1958
 Purpose 7" Al cal. water reflector
no top reflection at present
 Personnel: JRF DK

START-UP CHECK LIST
 Equipment Checked by DK Personnel Check by UCF
 Instrument and Safeties Checked and Reset by DK
 "Source In" Checked by DK Source No. 14213
 Emergency Equipment in Control Room Checked by _____
 Red Light On by DK _____
 Start-Up OK'd by DK Time 1⁰⁰ PM Date 7-22 1958

Water set at 182 cm (full)

	Source	Probe	C ₁	C ₂	C ₃	78
<u>1⁰⁵ PM</u>	0.009 6.962	0.05 7.050	140	340 330	1 ⁺¹⁴ 1 ⁺¹⁵	x 6x
<u>1²⁷</u>	12.026	12.10	190.84	500.48	1 ⁺⁵	
	18.059	18.135	stopped to locate system for suspected leaks -			
<u>1⁵⁵ PM</u>	18.050	18.18	250.44	1190.286	1 ⁺¹⁹	94
<u>2¹³</u>	19.954	20.06	300.53	1570.217	1 ⁺²²	
	24.06	24.16	340.47	3450.099	1 ⁺³⁵	
<u>2³³</u>	25.975	24.04	420.38	5570.061	2 ⁺⁰	.79
<u>2⁴³</u>	28.959	29.00	770.208	17.830	1 ⁺⁵⁸	.61
	Drained due to stuck probe drive to ~ 22"					
<u>3¹⁷</u>	31.198	31.25	slightly super crit			
	31.144	31.16	very sl. super			
	31.15	31.15	just crit			
	31.04	31.08	slightly sub.			



94
79
18
0

3⁵⁴ PM 175 cm

START-UP CHECK LIST

Equipment Checked by JTC Personnel Check by JWJ
 Instrument and Safeties Checked and Reset by JTC
 "Source in" Checked by JTC
 Emergency Equipment in Control Room Tested by AK
 Red Light Check JWJ
 Start-Up OK'd by JTC Time 3¹⁰ PM Date 7-23 1958

Exp. 10-2 Time 3¹⁰ PM Date 7-23 1958
 Purpose 7" Al cyl with top reflector
 Personnel: JWJ, JTC, PRR

3³⁰ P.M. ~~servo~~ Servo = 0.00 at zero H₁ D
 Probe = 0.09 " " 149.5 cm (side scale)

no top tamper used here; i.e. repeat of exp. 10-1 →

Servo	Probe	
31.137"	31.21"	" sub
31.272"	31.36"	slightly super
31.208	31.28	just crit.

Servo	Probe	Tamper	
17.52 17.45	17.57		
21.234	21.31	(above limit switch)	
26.06	26.09	5.20	[tamper just in contact]
31.123	31.19		
29.94	30.07	8.92	[29.81 by probe] Top tamper at point of max. reactivity

Readings with top tamper raised

$$8.92 - 5.20 = 3.72$$

$$26.09 - .09 = 26.00$$


$$29.72$$

%

Expr. 11-1 Time 11⁰⁰ AM Date 7-29 1958
 Purpose 12" Al cyl no refl. outside tank on floor - compare with 1-1
 3-1
 Personnel: RRR IWB-DK

1-5/16" Au foil on outside of cyl n 6" up

START-UP CHECK LIST
 Equipment Checked by DK Personnel Check by RRR
 Instrument and Safeties OK
 "Source In" Checked by DK No. PN213
 Emergency Equipment in Control Room Checked by DK
 Red Light On by HUPD
 Start-Up OK'd by DK Time 11⁰⁰ AM Date 7-29 1958



12.555
 12.525
 12.607
 566

Source zero Probe zero
 23.082 0.0006

12.61

The purpose of this exp. is to determine appropriate power level to expose Au foils.

Time	Probe	LL	R-1	DC-3	H. Button	Log N	
11 ²⁴	12.59	35.687	10	251000	30 on 1X.D	46%	slightly sup
	12.585	35.689	"	"	"	.0006	just crit.
11 ⁴⁵	(235) fission counter a 12" x 16 for 5min count at height.						
	Log N = .0006						
	12.595 (recheck of probe)						

Probe LL R-1 D-C3 H:Button Log W

11:52 12.67 35.731 ~50 sec period

Starting time for exposure = 11:54:54

12:00 12.605 35.662 76 100x1000 35 on 10K50 78 on 10⁶ .1 crit

[4.235 counter = 73⁺¹⁴ x 16 for 2 min count at Log W = .1]

Shut down time = 12:04:54 #127 ~112c/min

Expt.	11-2	12" Al. c/j	no ref	1958
Purpose	foil exposure (Au) for flux traverse			
	Gene Au foils foils positioned along vertical axis			
Personnel:				

see page 183 for data

Probe 2.545 ^{Sum} 25.447

- 47 0-1"
 - 46 0-1"
 - 45 0-1"
 - 44 0-1"
 - 43 0-1"
 - 42 0-1"
 - 41 0-1"
 - 40 0-1"
- } 2 1/2"

2:10 4.235 fission counter turned on and solution began feeding

2:15 PM 10.47 33.415 instruments stable not crit.

11.91 ^{34.86} 34.76

2:30 PM 12.63 35.508 Log W = .0005 slightly super

2:36 PM 12.67 ^{0.9} ~200 ~100 sec period

Probe LL ~~R-1~~ ~~D-C3~~ ~~H:Button~~ ~~Log W~~

Starting time for exposure = 2:49:34

12.655 | 35.559 | 55 1000x1000 | — | 10c-3 | 45 (10x100) | Log W = 1 } just crit.

Shutdown 3:09:34 PM

F.C. 406+130 (x250) #5 channel attenuator = 32

Gain = x16 .87 m

pf Gain = 15 on linear amp - #505

Expt. <u>11-3</u>	Time <u>3⁴⁵</u>	PM Date <u>195</u>
Purpose <u>Cd covered Au foil exposure</u> <u>foils positioned along vertical axis</u>		
Personnel: <u>DFC, Reedy, Ellis, Gilley</u>		

see page 183 for data -
 U-235 fission counter being used for normalization
 (integrated counts from start-up to shut down)

Probe start up 3⁴⁵

Probe LL R-1

3⁵⁷

12.675 35.628

12.705 ~~35.661~~

slightly super
pos. period

foil exposure began at 4:06:50

- # 39 0
 - # 38 0
 - # 36 0
 - # 34 0
 - # 32 0
- ↓ 2 1/2"
bottom of cyl.

Probe	R-1	Log W	DC-3
12.675	58 on 1000 x 100	.95-1.1	85

crit

foil exposure shut down 4:26:50 (20 min)

U-235 fission counter = $450 \times 254 + 67$

Note: #38 + 39 must have been transposed - (from flux data)

Expr. 11-4 Time AM Date 7-31 1968
 Purpose 12" Al wgl base
with fissile counter set for special traverse
FC (1235)
 Personnel: _____

Normalizing
 Fission Counter #5-3

START-UP CHECK LIST
 Equipment Checked by _____ Personnel Check by _____
 Instrument and Safeties Checked and Reset by _____
 "Source In" Checked by _____ Source No. _____
 Emergency Equipment in Control Room Checked by _____
 Red Light On by _____ AM _____
 Start-Up OK'd by _____ Time _____ PM Date _____ 1968

Scaler #5

Linear Amp

Traversing counter is
 1/2" off center

Fission Counter #5-2

Scaler #4

Linear Amp

9³² Solen zero Sensor = 22.645 Probe = 0.10 counter
 24.964 2.18 2.14

Time	Solen zero	Probe	Counter LN	Counting	Traverse	Ratio
				LN [5-3] Normaly	C 4 16	C 5-25 G
10 ⁰⁵	32.331	9.48				
10 ¹²	34.438	11.58				
10 ²²	35.484	12.58				
10 ³⁵	35.504	12.61				
				slightly super		
10 ⁴⁰	35.435	12.585	2.14	.10 just crit.	69 ¹¹ .69	268 ²³⁴ .89 3.87
	"		4.05	.095	62 ⁶ .375	286 ¹²⁰ .452 4.66
			4.53	.10	69 ⁵ .31	297 ¹¹⁷ .44 4.30
			5.04	.10	68 ¹¹ .69	300 ⁸² .31 4.38
			5.55	"	65 ⁰ .0	295 ²⁴³ .91 4.55
			6.02	"	69 ⁵ .31	288 ¹ 0 4.15
			6.54	"	64 ¹⁵ .94	280 ⁵³ .20 4.32
			"		71 ² .18	288 ¹³⁵ .52 4.05
			"		73 ⁵ .5	289 ⁶³ .23 3.93
			"		69 ⁵ .5	279 ²⁰⁴ .77 4.03
			"		67 ⁴ .25	267 ¹⁶⁸ .63 3.91

NG 9-18-63
 DWM
 ↓

1117

H.B. Reed
 6.54 LN
 39.5(10⁶) 71 (100/1000) 11 095 Lowered Power 67².13 266 188.71
 40.5(10⁵) 71 (100/100) a. 008 67⁵.5 260 188.70
 " " " " " 67⁷.44 24 168.13
 " " " " " 513.82 24 93.35

Expt. 11-5 Time AM Date 195
 Purpose Rpt of 11-4 with added counters
C.C. for normalizing, FISSI-RN CTR
 Personnel: 105 256

Traversing counter is approx 1" off center at 6.54! 2 min counts

Time	Rate	C ₃	C ₁	C ₂	(S-3) F.C.	(S-2) TFC	TFC/C ₁	TFC/C ₂	TFC/FC	LN
1:45	6.54	23 ¹³⁵	95,960	31,410	1 ⁵ .31	3 ²²⁹ .89				.011
"	"	174 ¹²⁹	70,680	282,770	9 ² .12	35 ²⁸ .1				.011
2:00	"	179 ²³¹	71,430	282,880	10 ⁶ .38	35 ²⁸² .85				"
"	"	313 ⁴⁰⁴	3,201,409	2,336,120	69 ¹² .75	300 ⁷¹ .28			4.31	.11
10 min counts										
"	"	1576 ⁴⁶	16,469,140	12,085,040	366 ⁸ .5	1482.76			4.04	"
2 min counts										
"	8.50	320 ⁷⁷	3,347,890	2,299,300	74 ⁸ .5	217 ¹⁹² .76			2.84	"
"	10.00	338 ⁷¹	3,454,909	2,417,808	76 ³ .19	120 ¹²³ .61			1.58	"
2:35	6.54	822 ³¹²	8,614,530		195 ⁵ .3	785 ⁴⁵ .18			4.03	"
"	5.50	796 ¹⁹²	8,538,280		190 ¹² .35	815 ⁸¹ .52			4.27	"
2:51 PM	4.52	760 ²⁹³	8,389,770		173 ⁹ .56	777 ²⁰⁶ .84			4.48	.10
"	3.49	752 ⁸⁹⁸	8,372,200		169 ¹⁴ .5	741 ²⁰⁰ .84			4.38	.09
3:00	2.15	629 ⁴⁸³	7,420,160		144 ¹² .75	545 ² .01			3.77	.08
1240.11										

A
 NG
 R. A. A.
 9-11-63

Expt. 11-7 Time 2nd AM PM Date 8-7 1958
 Purpose 12" Al - beam - with counter #5-1
as traversing counter -
 Personnel: JWA RKR BFC

START-UP CHECK LIST
 Equipment Checked by JK Personnel Check by RKR
 Instrument and Safeties Checked and Reset by JWA
 "Source In" Checked by JK Source No. PN213
 Emergency Equipment in Control Room Checked by BFC
 Red Light On by JWA
 Start-Up OK'd by RKR Time 2 PM Date 8-7 1958

Time	LL	Probe	Traverse counter position	Traverse counter	Cs	Log W
2 ⁵⁰	35.336	12.51		127.57 x256	- Critical Cs/Cs .10	
	"	"	1.47	610 236.89 x256	11 ^{244.95} x256 [5 min. count 5] .10	
3 ⁰⁵	"	"	2.00	577 236.89 x256	10 ^{+101 1395} x256	5.55 .08
3 ¹²			3.50	602 24.137 x256	9 ⁵⁰ x256	6.56 .075
3 ²⁰			4.50	741 183.172 x256	11 ⁵⁴ x256	6.61 .10
3 ²⁵ P.M.			5.0	777 112.144 x256	11 ¹⁶⁵ x256	6.67 .10
3 ³²			5.5	751 54.121 x256	11 ¹¹⁹ x256	6.55 .10
3 ³⁸			4.0	716 213.183 x256	11 ⁷² x256	6.35 .9
3 ⁴⁵ P.M.			6.5	636 5 x256	10 ¹¹⁴ x256	6.09 .9
3 ⁵¹			8.5	476 238.193 x256	11 ¹³⁷ x256	4.13 .1
3 ⁵⁸			10.00	226 132.151 x256	10 ⁸⁹ x256	2.19 .9
	35.308	12.53	17.0		slightly 78.86 sub	.9
	35.359	12.535	17.0		super	.9

NG - DWM
 9-11-63

Expr. 11-8 Time 10⁰⁵ AM Date 8-8-1958
 Purpose Repeat of 11-7 with a calibration (1 mile + 3" steel over end of counter not covered)
 Personnel:

START-UP CHECK LIST
 Equipment Checked by _____ Personnel Check by _____
 Instrument and Supplies Checked and Ready by _____
 Source of _____
 Emergency Telephone Number Checked by _____
 Red Light _____ AM
 Start-Up OK'd by _____ Time _____ PM Date _____ 1958



time 10⁵⁵ A Probe 300 0.03 (5-1) 4 units 5
0.03 22.5553
2.05 24.619 2.07

Suspended operation to fix instruments $\frac{11-7}{11-8} = \frac{75.06}{73.7} = 1.058$

~~1:55~~ PM
2:23

NG-DWM
 9-11-63

12.75	35.386	slightly super			
12.78	35.404	first coil log N = .09 (5 min. counts)			
12.76	35.366	2.07	252	11 ²²⁴ / ₁₈₈	2.13 x f = 2.25
12.80	35.455	3.51	238 ²³⁴ / ₁₉₁	9 ²³⁴ / ₁₉₁	2.41 2.55
"	"	"	224 ²⁰⁴ / ₈₀	9 ¹³ / ₁₃	2.12 2.56
		4.51	219 ⁸⁰ / ₃₁	8 ²¹² / ₁₈₄	2.18 2.62
		"	217 ¹⁷⁰ / ₆₆	8 ¹⁸⁷ / ₁₇₃	2.19 2.64
12.81		5.00	251 ⁴⁴ / ₁₁₇	10 ⁰ / ₀	2.51 2.66
		"	270 ¹²³ / ₇₁	11 ¹⁴⁴ / ₅₆	2.34 2.48
		5.51	256 ⁴ / ₄	10 ¹⁴⁴ / ₅₆	2.42 2.56
		6.50	217 ⁹³ / ₃₆	9 ¹⁶⁶ / ₁₆₆	2.40 2.51
		8.72	163 ¹⁸ / ₁₈	10 ²¹⁰ / ₃₂	1.51 1.61
		10.00	116 ¹⁸⁷ / ₇₃	13 ¹⁸¹ / ₁₂₄	73.71 86 1.93

182 Egypt 11-8 cont.

Probe	LL	Tr. Ctr	
12.64"	35.298	17.0"	Cr. t.
12.63		"	Sub.

8-15-58

Sample taken from pump drain -

Req 635 332

G = 71.1

.44997 g/cm

$\frac{20.0}{51.1 \text{ gm}}$

Sp. Nr. 20452

No

Req. No. 635332

N.C.		PYRO		AVG.
Be	<30	Be		
Ni	<25	Ni		
Sn	25	--	--	
Si	<10	Si		
Li	<2	Li		
P	<100	P		
Na	11	Na		
Mo		--	--	
Mn	<5	Mn		
Mg	<5	Mg		
K	<50	--	--	
Fe	150	Fe		
Cu	<2	Cu		
Cr	<6	Cr		
Ca	<50	Ca		
Ba	<10	--	--	
B	<1	B		
Al	<7	Al		
Ag	<1	--	--	

U₀₂ F₂
 Comp.
 Spec.
 1538 Mat.

Cd	
Co	
V	
Hg	
In	
C	
F	

T67
 2744

156 ppm

Spectrographic Report
 All results in ppm.

12" diam Al cyl - no refl.

183

Exp 11-²7, 11-³2 Carr + Cd count the foil see page 175, 176

Normalized data Vertical traverse

Pos.	base	Cd		
#40 2.65"	5.08 ^{#40}	3.70 ^{#32}	1.373	C.R.
#41 3.65"	6.01 ^{#41}			
#42 4.65"	6.74 ^{#42}	4.81 ^{#34}	1.401	
5.65	6.98 ^{#43}			1.389
6.65	7.00 ^{#44}	5.02 ^{#36}	1.394	
7.75	6.63 ^{#45}			
8.75"	6.06 ^{#46}	2.98 ^{#38}	⊗ 2.034	
9.75"	5.08 ^{#47}			

Exp 11-5 11-6 = 238 counts #8-3
12.65" unit

Normalized 35 min count 1240.11 737.21 (same counter #5-3 on analog C-5 x256)

Position	C x256 ratio	T/N	Pos.	TC x256	T/N	Power Normal
6.54"	200.28	4.31	6.50	6.06	0.245	.413
"	1482.76	4.04	6.50	23.97	0.23	.387
			2.0	34.54	0.321	.540
8.50	217.76	2.84	3.5	37.73	0.359	.664
			4.5	36.67	0.372	.627
10.00	120.61	1.58	5.5	37.06	.383	.645
			6.5	37.15	.335	.648
6.54	785.18	4.03	8.5	34.90	.308	.518
			10.0	16.8	.141	.237
5.50	815.32	4.27				
4.52	777.82	4.48				
3.49	741.82	4.38				
2.15	545.01	3.77				

Expt. <u>12</u>	Time	AM	Date <u>8-26</u>	1958
Purpose <u>14.42" diam Al sphere</u> <u>in Nell - no other reflectors</u>				
Personnel: _____				
START-UP CHECK LIST				
Equipment Checked by _____	Personnel checked by _____			
Instrument and Settings checked and Reset by _____	_____			
Source in _____ checked by _____	_____			
Emergency Equipment in Control Room checked by _____	_____			
Red Light On by _____	Time <u>2:02</u>	PM	Date <u>8/26</u>	1958
Start-Up OK'd by <u>F.C.</u>	_____			

Probe = 0.07 at sol'n 2 < v0

Moist = .023 " " "

Probe Moist	Moist Probe
11.19	11.079
11.185	11.079
11.115	11.056

slightly super
" - sub

3 ¹⁰pm Reg 635333

G = 70.05
T 20.0
N = 52.05 gm

0.449207 gm/l/gm
2.09545 m.

H/1000 = 64.4

Re-check you on probe

① 0.225
② 0.208
0.216

Moist
999.925
000.035
0.010

Dry 36.7m

Quality 25.746

This experiment and 13-2, 13-3, 185
 14-1, 14-2 and 14-3 were with
 a fully reflected sphere.

11/2/64

Expt. 13 Time 9⁰⁰ AM Date 8-28 1958
 Purpose approx 12" sphere (36" diameter)
 Personnel: JCF OK

12" sphere*
 calibrated
 at 14.350 g

START-UP CHECK LIST
 Equipment Checked by OK Personnel Checked by RWR
 Instrument and Safeties Checked and OK by WJC
 Source Int. Checked by P1213
 Emergency Equipment in Control Room Checked by OK
 Red Light On by WJC Time 9²⁰ AM Date 8-28 1958
 Start-Up OK'd by WJC

Probe zero is 0.03" Servo - .07

Probe	Servo	
8.75"	8.45"	slightly super
8.74	8.40	
<u>03</u>	<u>-07</u>	" out.
8.71	8.67	


8.69 in. = 22.1 cm

* Actual Dia 11.37 in
 28.9 cm

Calculated 14.350 g.

Expt. 14 Time 1:04 AM PM Date 8-28-58
 Purpose Crit. Test on TSR Elements
See ORNL print # E-52500 - (Element sections
rearranged for closest packing.)
 Personnel: Cronin, Reedy, Fox

with 14 kg pump
section -
2.8 kg total



START-UP CHECK LIST

Equipment checked by Personnel Check by
 Instrumentation (checked and ready)
 Fuel (checked and ready) LPN-213
 Source (checked and ready)
 Start-Up OK'd by Date 8-28-58 Page 155

Water ht. 152.5 cm Not critical
 Activity drops off sharply when
 source is withdrawn.

9-15-58 2:40 PM Pump turned on to circulate fuel -
 3:30 PM Pump off.
 Reflector tank around sphere filled with fresh deionized water.

Expt. 13-2 Time 7⁴⁰ AM PM Date 9/22 1958
 Purpose Repeat of 13-1
 Personnel: R.R.K.

Sum
 45.851
 97.473
 98.233

START-UP CHECK LIST
 Equipment Checked by SK Personnel Check by SK
 Instrument and Safety Checked and Reset by SK
 "Source In" Checked by RPK Source No. PN 213
 Emergency Equipment in Control Room Checked by SK
 Red Light On by SK
 Start-Up OK'd by SK Time 7:45 PM Date 9/22 1958

probe zero = 0.27

998.95
 997.55
 998.47
 998.31

probe zero = 0.30 (just on edge of mold head)
 sum = 0.

0.30
~~0.58~~
 0.29

Shut down at 7⁵⁰ PM - DC-2 out of order
 Log N questionable DC-3 erratic
 R-2 erratic - R-1 and PM seem to work -

Expt. 13-3 Time 4¹⁵ AM PM Date 9-24 1958
 Purpose Rpt 13-1
 Personnel: R.R.K. SK

START-UP CHECK LIST
 Equipment Checked by SK Personnel Check by R.R.K.
 Instrument and Safety Checked and Reset by SK
 "Source In" Checked by SK Source No. PN 213
 Emergency Equipment in Control Room Checked by SK
 Red Light On by SK
 Start-Up OK'd by SK Time probe PM Date 1958

re-check	8.926	0.21	} probably best value is n 0.1
	.178	.01	
4.51 P.W.	8.98	8.77	
9.53	8.98	8.775	Super Crit.
9.54	8.98	8.77	Sub Crit.

Expt. 14-1 Time 5³⁰ AM Date 9-24 1958
 Purpose detonation to make 12" sphere
just Crit - u 10 liter fuel
with 5 liter water added
 Personnel: D.F.C. R.K.R.

12" sphere
calibrat = 14.350" J

START-UP CHECK LIST

Equipment Checked by DK Personnel check by RKR
 Instrument and Safety Checked and Rec'd by DK
 "Source Is" Checked by DK PVU3
 Emergency Equipment in Control Room Checked by
 Red Light On by DK Time 5³⁰ Date 9-24 1958
 Start-Up OK'd by DK

fuel allowed to circulate for 30 min
before "blowing" out monometer -

^{6⁰⁰ PM} Servo = 3.177 Probe = 2.92
 $\frac{2.92}{.25 \text{ diff}}$ precision = .21
^{6²⁰ PM}
 8.95 8.735 Super Crit
 8.95 8.72 Sub Crit

Expt. 14-2 Time 6⁰⁰ AM Date 9-24 1958
 Purpose Repeat of Expt 14-1
 Personnel: D.F.C. R.K.R.

Servo Probe
 .426 0.21
 8.97 8.71 Super Crit
 8.97 8.70 Sub Crit
~~8.95 8.72~~

Expt. 14-3 Time 6:25 AM Date 9-29 1958
 Purpose Report of Expt 14-1
 Personnel: E. F. C. R. K. R.

7⁰⁰ P.M. Levee Probe
 0.926 0.21
 7⁰⁰ P.M. 8.95 8.71 Super Crit
 8.95 8.70 Sub Crit

START-UP CHECK LIST
 Equipment Checked by DK Personnel Check by DK
 Instrument set up and Buret by DK
 "Source In" checked by DK Source No. PN 213
 Emergency Stop Button in Control Room checked by DK
 Red Light on by DK
 Start-Up Order by DK Time 11:45 AM PM Date 9/25 1958

note (expir value set in zero manometer)

Expt. 15-1 Time 4:35 PM Date 9/25 1958
 Purpose 7" PL w/ no top ryl
 water surrounding
 Personnel: J. W. Y. DK

Expt 10-1
 - previous exp
 = 31.15"
 - .05
31.10

zero .00" probe zero = -.03"

water hit set at 150 cm
 4 4:47 10.885 10.93 +04
 4 4:50 15.41 15.53 +12
 4 4:55 19.903 19.94 +04
 5 5:12 PM 29.315 29.35 +04 Source Crit Sub
 29.347 29.38 +04 almost just Crit
 29.368 29.40 +04 super crit
 Crit 29.35" 29.38
 +03
 29.41"


10-22-58

Startup with new instruments -

Re-check of zero - liquid column about 1/2 of bottom probe = $-.04''$.

Instruments checked + safeties operate thru complete cycle.

16-1 Time 9:35 AM Date 10-22 1958
 7" Al w/ reflected with top reflector having Al plates →
 necessity noted
 D.J.C. R.K.R.



START-UP CHECK LIST

Equipment Checked by DJC Personnel Check by RKR
 Safeties and Altimeters Checked and Reset by DJC RKR
 Control Room Checked by DJC Source No. M-43
 Emergency Equipment in Control Room Checked by DJC
 Red Light On by DJC
 Start-Up OK'd by RK Time 10:30 AM Date 10-22 1958

Probe = $-.04$ LL = $+1.009$ } Top temp set 0 ± 0
 4.86 4.88

Water ht in cm above base of reactor = 120.7cm

Fuel = 4.80" (with water in tank -) LL = 4.83

Probe	L.L.	Notes
29.38	29.13	Slightly Super Crit.
29.32	29.13	" " "
29.25	29.05	S. Sub Crit. > 400cm (-)
29.07	29.90	"
29.29	29.11	Super Crit.
29.26	29.07	Just Crit.

Log M = 10

Probe
28.61

L.C.

T.T.

29.95

29.25

28.69. (in contact)

28.58

Optimum Pos.

.11

LOG N = 2

28.66

K_{eff} = 5.98 x 10⁻¹⁰{ 29.92
just Crit.

29.9 (drifting)

28.58

28.43

36.14 (no contact)

Critical Conditions:

no Top Refl = $29.26 \pm .04 = 29.30''$ fuel

Top reflector plus Al plate (1/2") = 28.58'' fuel

top reflector adjusted for optimum reactivity

= 28.66 fuel level = $29.92 \pm .04 = 29.96''$ fuel annulus = $\frac{28.58 - 28.66}{1.38''}$

1.37

11⁴⁷ AM Fuel drained

Expt. 16-2	Time 1:30	PM Date 10-22 1958
Purpose Same conditions as 16-1 - With 1" top Al. plate removed -		
Personnel: RRR JTC		

Probe	S. Level.	T. Temp.	Water ht. 120.76m
6.00	5.992	60.00	.06 diff
20.23	19.992	" "	
25.06	24.785	" "	
28.58	28.295	" "	
Subst → 28.58		27.69 - in contact	
28.60	28.902	28.27	

T.T at Optimum. Source out.

Probe	S.L.	T.T.	Lag n = 008
2:10 P.M. 30.14	29.905	27.61	K-1 = 20 3x10 ⁻¹⁰

TT in contact

2:15 P.M. Very slow drift up on K-1 and top N (> 400m (+) previal)

Probe	S.L.	T.T.
Subst → 28.59	28.910	35.00 (out of contact)

Sub Crit.

Probe	S.L.	T.T.
23.96	23.820 Δ = .78"	23.00 (in contact)
18.97	18.85	18.08 (in contact)
	18.08	
	Δ = .77"	

Expt. 16-3	Time 2:25	PM Date 10-22 1957
Purpose: Same conditions as 16-1, 16-2 without AL plates.		
Personnel:		

Probe	L. L.	T. temp water h.
6.21	6.35 - .21 = .14	6.35 4.96 (in control) 20.7 Cms. 1.89" diff - (from orig setting) 1.75
20.13	19.92	18.44 Δ 1.69
29.27	29.00	38.00

3:15 PM System shut down.

4:00 PM Expt 16-3 continued.

Probe	L. L.	Top temp.
29.57	29.29	38.19 just exit.
29.54	29.295	38.19 just exit (with exhaust fan on.)

T. T. at optimum = 26.49 "just exit."

	30.98	30.775	26.94
fuel lit \rightarrow temp out	28.43	28.258	36.00 sub exit.

Expt. 16-4	Time 300	Date 10-23 1958
Purpose: Request of 16-3 Supply fan 40		
Personnel: RKR JSL		

Reflector water ht = 124 cm

Probe	L.S.	Top Temper	"
6.00	6.000	36.00	"
	5.911		"
	.089		"

3.32 PM	25.00	29.771	"	"
3.35 PM	29.46	29.205	50" just crit.	"
	29.50	29.245	50" super crit	Water Temp 22°C
	29.34	29.145	50" sub crit	"

3.45 PM

~~Tap Temper = 26.43 Optimum~~
 Tap Temper = 26.40 Optimum, just crit
 Lag $\tau = .01$

28.29 28.078. Fuel level at crit
 with tap temper out.

3.50 PM

Shut down.

Expt. 16-5 Time 2³³ AM Date 10-28 1958
 Purpose Repeat of 16-3, 16-4 after
air conditioning + duct repair
 Personnel: _____

START-UP CHECK LIST
 Equipment Checked by DK Personnel Check by _____
 Instrument and Safeties Checked and Reset by DK CER
 "Source In" Checked by DK Source No. M-43
 Emergency Equipment Control Room Checked by DK
 Red Light On by _____ AM _____
 Start-Up OK'd by _____ Date _____ PM Date _____ 1958

8⁴⁵ AM Starting water temperature 22°C Water ht = 120.0 cm

9⁴⁵ starting fuel feed - top tamper out (at 50.20")

Probe	I.L.	Diff	
6.46	6.263	.197	
10.15	9.951	.199	
15.02	14.81	.210	
19.78	19.578	.210	
24.95	24.739	.211	
29.98	29.286	.194	= Very slightly super crit.

10⁰² AM Log $\eta = .02$
 KI = 47 10×10^{-10}

TEMP No 2 = 23°C } Center of reflector tank.
 " 4 = 23°C } (Well)

10⁰⁴ AM K-I = 50 } fuel = 29.48"
 Log $\eta = .025$

10⁰⁸ AM 29.46 29.301 Diff ".159" "just crit"

10²⁴ AM 30.78 \rightarrow ^{high fuel annulus} TOP TAMPER at optimum 26.39 just crit.

10²⁹ AM 28.29 28.159 50.0 } Top tamper out.
 shut down. \leftarrow fuel level at critical

Expt.	16-6	Time	10 ⁰⁵ AM	Date	10-26	1958
Purpose	Same soln reflected 7" Cyl					
TT	has 1 1/2" Al plate on bottom					
Personnel:	R.H.H. D.H.					

Water ht = 120 cm
Temp = 22°C

	Probe	L.L.	T.T	
10 ⁵⁵	6.23	6.105	63.72"	
				diff
11 ⁰⁷ / _{AM}	20.02	19.831	63.7	source out
	29.58	29.380	63.7	sub crit.
	29.64	29.427	63.7	Probably sub crit
	29.69	29.996	63.7	Super crit.
11 ¹⁹ / _{AM}				
	29.96	29.265	28.91	at optimum (just crit)
	28.77	28.644	63.7	Top temp act. (sub crit)
				Water Temp = 22.5°C
11 ²⁴ / _{AM}	29.68	29.501	63.7	Super Crit
Log $\eta = .02$	29.59	29.958	63.7	" "
	29.53	29.387	63.7	" "
	29.45	29.307	63.7	Sub Crit.
11 ³⁷ / _{AM}	29.72	29.548	63.7	Super Crit
11 ⁴⁰ / _{AM}	29.46	29.326	63.7	just Crit
				Log $\eta = .1$

Run	Crit Ht	fuel needed TT	TT	+ .04 zero count	corr Ht
16-1	29.26"		none		29.30
	28.58	29.92 28.58 1.34"	TT plus 1/4" AI		28.62
16-2	28.59	30.14 28.59 1.55"	TT plus 3/4" AI		28.63"
16-3	28.54	30.98 28.54 2.44"	TT only		28.58
16-4	29.46		no TT		29.50"
	28.29		TT only		28.34"
16-5	29.46"		no TT		29.50
	28.29	30.647 28.29 2.357"	TT only		28.33"
16-6	29.65"		no TT (at 60"		29.69"
	28.77 28.77	29.46 28.77 .69"	TT plus 1/2" AI		28.81
	29.46		no TT		29.50"

	TT only	TT plus 1/2" AI	No TT	diff	TT + 1/2" AI diff no TT
16-3/	28.58"	28.62	29.30"		- 0.68"
16-4	28.34"	28.81"	29.50		
16-5	28.33"	28.77	29.50		
	29.30 28.58 .72"	29.50 28.33 1.17"	28.81 .69		- .69"
		1.16"			

Top temp only = 1.16" decrease in Crit Ht over no TT (16-4 / 16-5)
 with 1/2" AI = 0.68" decrease in Crit Ht over no TT (16-1 16-3/6)
 due to 1/2" AI = .48" more fuel need to be added to
 maintain criticality. 3/4" AI = no apparent diff from 1/2" AI

194
29.709

10-28-58

Zero check top temperature water dumped

Probe = -.02 LL = 99.898 Bottom almost covered

-.04 LL = 99.897 Bottom still wet spot marked

-.06 LL = 99.879

10-29-58

Sample from Pump housing -

Reg 635336

G - 132.2

T 20

N 112.2 gms sol'n

also for X-10 sample G - 144

T 20

N = 124

Cooper

U = 0.4326 gm U/gm

U = 0.43088

D = 1.9721 gm/mol

D = 1.9745

pH = 0.6

pH = 3.2

Req. No. 635336

N.C.		PYRO		AVG.
Be	<1.30	Be		
Ni	25	Ni		
Sn	40	--	--	
Si	<10	Si		
Li	<2	Li		
P	<100	P		
Na	18	Na		
Mo		--	--	
Mn	28	Mn		
Mg	25	Mg		
K	<50	--	--	
Fe	5000	Fe		
Cu	3	Cu		
Cr	156	Cr		
Ca	<50	Ca		
Ba	<10	--	--	
B	1.8	B		
Al	25	Al		
Ag	<1	--	--	

5164
1900
~~NO 51460~~
MBA

Spectrographic Report
All results in ppm.

Cd	
Co	
V	
Hg	
In	
C	
F	

Req. No. 635336

N.C.		PYRO		AVG.
Be	<.30	Be		
Ni	<25	Ni		
Sn	60	--	--	
Si	<10	Si		
Li	<2	Li		
P	<100	P		
Na	14	Na		
Mo		--	--	
Mn	<5	Mn		
Mg	<5	Mg		
K	<50	--	--	
Fe	115	Fe		
Cu	<2	Cu		
Cr	8	Cr		
Ca	<50	Ca		
Ba	<10	--	--	
B	<1	B		
Al	60	Al		
Ag	2	--	--	

P.S. 2811
1500
UC


Cd	
Co	
V	
Hg	
In	
C	
F	


Spectrographic Report
All results in ppm.

Expt. 17-1 Time 8⁰⁰ AM Date Nov. 3 1958
 Purpose Test of Term Shielding Reactor loading - full with Cadmium plate in
 Personnel:

See also 186

START UP CHECK LIST
 Equipment Checked by DAC/RCR Personnel Check by RCR
 Instrument OK OK ERR
 Source OK M-43
 Emergency OK
 Red Light on by OK
 Start-Up OK'd by OK Time 8²⁰ AM Date 11-3 1958



Center has 3 3/16" Spacers made of brass wires  to hold center brines apart - holes in circles to allow water thru
 Thermocouples approx at center line of sphere -

Loading Cd plate slot 17 except for safety + CR #1 slot 15
 Starting condx all Rods in except for Safety

9¹⁵ AM Top of plastic table 9 3/4" from bottom - Sphere resting on table
 28.0 cm on fixed right from side.

All water in S. B. - 132.5 cm LL = 52.2"
 Log W start .004 log N now .0114
 K-1 start 30 K-1 now 68
 (over)

9²⁵ AM

all movable rods out

Log N

K-1 3×10^{-12}

.014

76 (annals)

Safety IN

.011

54

9³⁰ AM

CR#2 IN

.013

72

CR#1 IN

.011

68

temperature on TC

23.5°C (8, 10, 12)

Δ on SG cm

LL in

Δ in

132.4

52.550

2.79 32.5m 99.9

40.175 12.375

8 30.0 69.9

29.587 10.588

85 19.9 50.0

21.823 7.764

$$\left. \begin{array}{r} 104 \\ 25 \\ \hline 76 \end{array} \right\} 29.9''$$

Expt. 17-2 Time 9⁴⁵ AM PM Date 11-3 1958
 Purpose 3 Cd plates removed (opposed equal)
 Personnel: RKR ERK ADC

S.G. S.S. (off) Log N K-1

9⁵⁵ CR land 2 = 0.0 S.G. 42.0 cm 17.035 in
 9⁵⁸ " " " S.G. 69.9 cm shut off
 10⁰² water at 132.5 cm CR-1 = 0.0 CR2 = 0.0 Safety 17.2
 K-1 (10 x 10⁻¹²) Log N
 28 .02
 10¹⁰ CR-1 = 16.64 out CR2 = 0.0
 K-1 = 34 (10 x 10⁻¹²) log N = .025
 10¹² CR-1 out CR-2 15.07 (out)
 K-1 = 38 (10 x 10⁻¹²) log N = .028
 10¹⁵ water = 104 cm = top of plate

Expt. 17-3 Time 10⁰⁰ AM PM Date 11-3 1958
 Purpose all fitted cadmium plates removed
 Personnel: RKR ERK ADC - etc

10⁴⁴ AM Water at 123 cm
 10⁴³ CR#2 = 15.87 sub crit
 CR#1 = 16.66 sub crit
 10⁴⁷ same out sub crit
 CR1 = 16.66 CR2 = 15.87
 K-1 (10 x 10⁻¹¹) log N
 35 0.25
 temp 24°C

11-3-88

1193 Same in - Rools 1 & 2 in.

Adding water -


Bottom of sphere - 27.8 cm

Center - 66.9 cm

Top of outer fuel element - 72.5 cm

Top of elements - 103.7 cm

Top of sphere - 104.3 cm



104.3	103.7	66.9	17.5
<u>27.8</u>	66.9	<u>27.8</u>	.5
76.5	<u>36.8</u>	39.1	11.0
		<u>36.8</u>	.5
103.7		75.9	.75
<u>72.5</u>		74.4	30.25
31.2			

START-UP CHECK LIST

Equipment Checked by RKR Personnel Check by DL

Instrument checked and certified by DL ERR

Source in DL Source No. M-43


Emergency DL Checked by DL

Red Light on DL

Start-Up OK'd by 830 time 8:30 AM

Run Date 11-9 1968

Exp. 18-1
 Purpose: attempt to make TSP critical by moving water hemisphere 1" down
 Personnel: RKR & CRR
 Time: 8:11 AM
 Date: 11-4 1956



8:30 AM top of table = 27.7 cm on left hand side
 starting CR1 = 0.0 CR2 = 0.0 Safety 17.2"

9 AM water at 120.7 cm LL 47.830 CR1 = 0.0 CR2 = 0.0 safety 17.2
 Sub critical (source partly out)

CR#2
 9:02 AM source out, softy auto. ~~out~~ Water temp 8, 10, 12 = 24°C
 C.R.#1 = 0.0
 C.R.#2 = 1.35 just crit K-1 52 10x10-11
 Log n = .26

9:07 Period by C.R.#2 only. Log n = .26 start
 C.R.#2 = 6.00 Log n = 2.6 finish.

9:11 C.R.#2 = 1.35 system crit. Log n = 2
 K-I 38 10x10-10

9:12 C.R.#2 = 3.00
~~C.R.#1 = 1.41~~ Log n = 2 start
 C.R.#2 = 1.41 system crit. Log n = 4.0 finish
 K-I from 2 to 71
 on 10x10-9

9:27 Lowering softy. Water Temp 8, 10, 12, = 24°C

9:28 Dropped softy.

9:29 shut down.

Expt. 18-2	Time 9 ⁴⁵ AM	Date 11-9 1958
Purpose Report of 18-1 with one (1) cell plate in east orange pool		
Personnel: D.F.C. R.T.R. C.R.R.		

Filling in	
S.G. unit	L.L
37.0	14.840
50.3	21.94
69.3	27.580
82.5	32.674
91.9	39.519
120.3	47.750

log N moved approx 18" to NW corner of Hill

Starting

C.R.#1 = 0.0 K-1 16 (10x10")
 C.R.#2 = 0.0 K-2 45 (3x10⁻¹²)
 Soften = 17.2
 Source in.

Water temp 8,10,12 = 24°C

10²⁰ AM Water at 120.3 CR#1 0.0 CR#2 0.0 softy 17.2 (see crit source in)

10²³ C.R.#2 = 15.87 Sub crit other vals the same.

10²⁶ Crit cond Source out. Water temp 8,10,12 = 24°C
 C.R.#2 = 15.87 KI = 89 3x10⁻¹⁰
 C.R.#1 = 6.87 Log n = .008 just Crit

10³⁴ C.R.#1 = 8.00 other cond same.
 10⁴⁰ C.R.#1 = 6.87 Log n = .09 sub crit.

10⁴⁶ C.R.#1 = 6.88 just crit. (water temp 8,10,12, = 24°C)

10⁴⁷ C.R.#1 = 8.00 just Crit. Log n = .09
 C.R.#2 = 14.26

10⁴⁹ C.R.#1 = 8.50 Log n = .48
 C.R.#2 = 13.55 KI = 51 3x10⁻⁸ just Crit.

11 ⁰³ Period
CR# 9.15 CR2 # 13.55 log N .48 to 2.6 Water temp 8,10,12 = 29°C

11 ¹⁵ C.R.#1 = 9.15 K-I = 79 ^{10 x 10⁻⁸}
C.R.#2 = 12.74 log n = 2.6

2610 reads 26 M.R. per hr at console
hammer rate meter = 70 ^{x 10} 980 V

$$R1 = 68.5 \quad 100-5$$

$$R2 = 80 \quad 100-5$$

$$P.M. 2 = 46 @ 680 V$$

$$K-2 = 6.6 \times 10^{-11}$$

neg Period

just crit.

11 ¹⁹ C.R.#1 = 8.00
C.R.#2 = 12.74

11 ²⁴ Pos Period.

$$C.R.#1 = 10.01$$

$$\log n = .16 \text{ to } 1$$

$$C.R.#2 = 12.74$$

Water temp 8,10,12 = 24°C

11 ³⁸ C.R.#1 = 10.01 log n = 1

$$C.R.#2 = 11.70 \quad K-1 = 32 \quad 10 \times 10^{-8}$$

just crit

11 ⁴⁰ Neg Period.

$$C.R.#1 = 8.00$$

$$\log n = 1 \text{ to } .12$$

$$C.R.#2 = 11.70$$

Water temp 8,10,12 = 24.2°C

11 ⁴⁴ Pos Period

$$C.R.#1 = 12.00 \quad \log n = .12 \text{ to } 2.2$$

$$C.R.#2 = 11.70 \quad K-1 = 66 \quad 10 \times 10^{-8}$$

$$C.R.#2 = 9.33 \quad \text{just crit.}$$

11:55 neg period
 C.R.#1 = 8.00 Log $n = 2.2$ to .1

C.R.#2 = 9.33

11:59 Post period

C.R.#1 = 13.52 Log $n = .1$ to 1.8

C.R.#2 = 9.33 $K-1 = 52 \cdot 10 \times 10^{-8}$

C.R.#1 = 13.52

C.R.#2 = 7.50 just crit Log $n = 1.8$

$K-1 = 52 \cdot 10 \times 10^{-8}$

12:09 PM

neg period

Log $n = 1.8$ to .1

C.R.#1 = 8.00

C.R.#2 = 7.50

12:13 PM

Pos period

Log $n = .1$ to 1.35

C.R.#1 = 15.34

$K-1 = 41 \cdot 10 \times 10^{-8}$

C.R.#2 = 7.50

~~just crit~~

12:19

C.R.#1 = 15.34

Log $n = 1.35$

C.R.#2 = 5.45

$K-1 = 41 \cdot 10 \times 10^{-8}$

just crit

~~12:20~~

12:20

Pos period

Log $n = 1.35$ to .7

C.R.#1 = 16.63 = out

$K-1 =$

C.R.#2 = 5.45

12:27

C.R.#1 = 16.63

Log $n = .7$

C.R.#2 = 4.00

$K-1 = 55 \cdot 3 \times 10^{-7}$

just crit

neg Period.

$$12^{20} \text{ PM } C.R. \#1 = 16.63$$

$$C.R. \#2 = 0.0$$

$$\log n = 7 \text{ to } .75$$

$$12^{35} \text{ PM } C.R. \#1 = 6.87$$

$$C.R. \#2 = 15.87$$

$$\log n = .75$$

$$K-1 = 72 \quad 3 \times 10^{-8}$$

Water temp
8, 10, 12 = 29.2°C

just crit.

12³⁷ PM

neg Period.

$$C.R. \#1 = .09$$

$$C.R. \#2 = 15.87$$

$$\log n = .75 \text{ to } .11$$

12⁴³ PM

$$C.R. \#1 = 16.63$$

$$C.R. \#2 = 15.87$$

$$\log n = .11$$

$$K-1 = 76 \quad 3 \times 10^{-9}$$

$$\text{Softy} = 5.96^{75}$$

just crit.

12⁴⁷ PM

Pos period.

$$C.R. \#1 = 16.63$$

$$C.R. \#2 = 15.87$$

$$\log n = .11$$

$$K-1 = 7 \quad 3 \times 10^{-8}$$

$$\text{Softy} = 5.78 \text{ to } 10.00$$

12⁵³ PMSystem ^{allowed to} screen by P.M. #2 @ 850V

$$\log n = .8$$

$$K-1 = 85 \quad 3 \times 10^{-8}$$

Reading of 10 R at surface of coil.
reading at door 10 m.R.

Exp.	CR-1	CR 2	period secs	costs
18-1	0.0	1.35	∞	0
		6.00	43.94	17.6
		3.00	226	54
from LCRM		3.00	208.4	5.354
18-2	6.87	15.87 (cont)	∞	0
	8.00	"	141.3	7.4
	8.00	14.26	∞	—
	8.50	"	317.2	3.70
	8.50	13.55	∞	—
	9.15	"	252	4.35
	9.15	12.74	∞	—
	8.00	12.74 (-)	217.2	7.35 (-)
	10.01	12.74	180.4	6.05
	10.01	11.70	∞	—
	8.00	11.70 (-)	147.6	12.3 (-)
	12.00	11.70	163	6.65 6.55
	12.00	9.33	∞	—
	8.00	9.33 (-)	139.6	4.65 (-)
	13.52	9.33	91.2	9.2 9.4
	13.52	7.50	∞	—
	8.00	7.50 (-)	115.1	7.45 21.8 (-)
	15.34	7.50	89.1	3.65 9.5
	15.34	5.45	∞	—
	16.63 out	5.45	163	6.65 6.55
	16.63	9.00	∞	—

CR-1	CR-2	Safety	period	cents
16.63 ^{out}	0.0	17.2 ^{out}	(-) 141.2	13.5 (-)
6.87	15.87	17.2	∞	-
.09	15.87	17.2 (-)	160.9	11.0 (-)
16.63	15.87	5.78	∞	-
16.63	15.87	10.00	30.41	20.5

$$\begin{aligned} \text{CR1 from } 6.87 \text{ to } 16.63 &= 53.5¢ \\ \text{from avg period } 6.87 \times 0.09 &= 11.0 \\ \hline &64.5¢ \end{aligned}$$

$$\begin{aligned} \text{CR2 from } 15.87 \text{ to } 4.00 &= 53.5¢ \\ \hline &- 13.5 \\ \hline &67.0¢ \end{aligned}$$

$$\begin{aligned} \text{Safety from } 17.2 \text{ to } 5.78 &= (-) 53.5¢ \equiv \text{CR1 from } 6.87 \text{ to } 16.63 \\ \text{from } 5.78 \times 10.00 &= 20.5¢ \end{aligned}$$

Assuming Cd plate on East face is equivalent to avg of CR-1 & CR-2 is 65¢

$$\frac{P_k}{B_i} = P_k$$

$$\begin{aligned} B_i &= .0073 \\ P_k &= 65 \times .0073 = .474 \end{aligned}$$

then 1 plate = 65¢

$$\begin{aligned} \text{plus CR-1 } & \frac{53.54}{118.5 (.0073)} = .864 \end{aligned}$$

S.G.	LL in
27.8	—
40.1	16.080
71.3	28.365
99.5	39.468
123.5	49.062
123.5	↓
	has 15" more travel left

Expt. 19-1 Time 8³⁰ AM - PM Date 11-5 1958
 Purpose FSR - opening between vertical sections was 3 3/16" - 1 1/2" = 2 1/16"
 other readings same as 18-1
 Personnel: RKR DK

START-UP CHECK LIST
 Equipment Checked by DFC Personnel Check by RKR
 Instrument and Settings Checked and Passed by CRR
 Source H²¹⁸ Th²³² Source No. M-43
 Emergency Equipment Control Room Checked by DFC
 Red Light On by DFC
 Start-Up OK'd by DFC Time 8⁴⁵ AM PM Date 11-5 1958

Starting Conditions: CR1 = 0.09 in
 CR2 = 0.00 in } No other cl plates
 Safety = 17.19 unit
 Source 1N
 K-1 ³² on 3 x 10⁻¹¹ K-2 45 on 3 x 10⁻¹²

log N .006 Reads x1 range x6 (R₁=3.7 R₂=2.5)
 PM2 45 on 1100V

9¹² Water ht = 123.5 cm. 49.062" (sub crit with above cond)

9¹⁷ C.R#2 = 15.87 sub crit.

9¹⁹ C.R#1 = 7.52

source out
 C.R#2 = 15.87 pos period. (+) 152 μ 6.94

9³⁰ C.R#1 = 6.13

C.R#2 = 15.87 just crit Log n = .018
 K-I = 58 10 x 10⁻¹⁰

9³⁴ C.R#1 = 0.08 neg period.

C.R#2 = 15.87 (-) 200 μ (-) 8.14 Water temp 8, 10, 12. 24.2°C

9³⁷ C.R#1 = 8.51 pos period Log n = .036

C.R#2 = 15.87 (+) 78.2 μ K-F40 3 x 10⁻⁹ (+) 11.6 μ

9⁴⁵ C.R#1 = 8.51

C.R#2 = 12.92 just crit Log n = .04
 K-1 = 46 3 x 10⁻⁹

9⁴⁶ CR#1 = 8.51 neg period. Water temp 8,10,12 = 24.2°C
CR#2 = 11.01 (-) 152m (-) 12d

9⁵⁰ CR#1 = 10.00 pos period. Log n = .05
CR#2 = 12.92 + (123.8m) K-I = 55.3 x 10⁻⁹ 9.65d

9⁵⁵ CR#1 = 10.00 Log n = .05 just exit
CR#2 = 11.31 K-I = 55.3 x 10⁻⁹

9⁵⁷ CR#1 = 10.00 neg period. (-) 204m (-) 8d
CR#2 = 10.00

10⁰⁴ CR#1 = 11.83 pos period Log n = from .012 to .051
CR#2 = 11.31 (+) 93.4m K-I = 59.3 x 10⁻⁹ + 10.2d

10⁰⁸ CR#1 = 11.83 just exit. Log n = .051
CR#2 = 9.37 K-I = 59.3 x 10⁻⁹

10¹⁰ CR#1 = 11.83 neg period Log n = .051 to .013
CR#2 = 7.37 (-) 180.3m (-) 9.4d

10¹⁵ CR#1 = 14.01 pos period. Log n = .013 to .062
CR#2 = 9.37 K-I = (+) 80.4m (+) 11.2d

10²⁰ CR#1 14.01 just exit Log n = .062 Water temp 8,10,12 = 24.2
CR#2 ~~7.20~~ 7.20 K-I = 69.3 x 10⁻⁹ Water ht = const.

10²³ CR#1 = 11.83 neg period. Log n = .062 to .0125
CR#2 = 7.20 (-) 167.4m (-) 10.4d

10³⁰ CR#1 = 16.62 pos period. Log n = .0125 to .07
CR#2 = 7.20 K-I = 73.3 x 10⁻⁹ 91.3m 10.4d

10³⁵ CR#1 = 16.62 just exit Log n = .07
CR#2 = 4.95 K-I = 73.3 x 10⁻⁹

10³⁷ CR#1 = 16.62 Log = .07 to .014
 CR#2 = 0.0 neg period (-) 126m (-) 16.44

10⁴⁰ CR#1 = 6.13 neg period ~~Log~~ Water Temp 8,10,12 = 29.2°C
 CR#2 = 4.95 Log n = .014 to .005
 (-) 43.44m

10⁴⁵ Shut down.
 K-I = 35 10×10^{-11}
 Log n = .015
 P.M.#2 = 780V - 25 peaks on Recorder
 K-2 = 50 3×10^{-12}
 R-1 = 1×6^{-5}
 R-2 = $1 \times 6^{-6.5}$
 source (ant)

Expt.	10-1	Time	11:20 AM	Date	11-5	1958
Purpose	Same as Expt 19-1 except full plug in battery.					
Personnel	D.F.C. R.R.R.					

11³⁹ starting cond. K-1 = 16×10^{-11} source in water ht
 K-2 = 45×10^{-12} CR#1 = 0.08 48.877 123.2 cm.
 CR#2 = 0.0
 Log n = .008 height = 17.19 Water Temp 8,10,12, = 29.3°C
 P.M.#2 = ~~780V~~
 880V

11⁴² CR#1 = .09 Log n = .005 to .037
 CR#2 = 15.87 pos period. 229.2m 4.94

11⁵³ CR#1 = .09 just crit Log n = .037
 CR#2 = 14.58 K-I = 46.3×10^{-9}

11 ⁵⁴ C.R.#1 = 6.13 just crit Log $\eta = .095$
 $K-L = 47 \quad 3 \times 10^{-9}$

C.R.#2 = 10.10 Estimated worth of plug = 25¢

12 ^{50 PM}

Shut down.


P.M.-2 = ~~880V~~ 35 peab on monitor.
 880V

Expt. 20-2	12 ⁵⁰ PM	11-5	1953
Purpose Same as 20-1 with 2 fuel plates added.			
Personnel: D.F.C. R.H.A.			

Water ht L.S. S.S.
 49.02" 123.3 cm

Water temp 8, 10, 12
 29.5°C

Plate #1 in one section from safety
 Plate #2 in one section from C.R.#2
 Plates one in second row in each section.



12 ^{30 PM}

C.R.#1 = 6.13 just crit Log $\eta = .0041$
 $K-L = 38 \quad 3 \times 10^{-10}$
 C.R.#2 = 9.50

12 ³⁰

C.R.#1 = 6.13 just period. Log $\eta = .0041$ to .016
 C.R.#2 = 10.10 369.5 cm 3.15 d

12 ⁴⁰

C.R.#1 = 6.13 just crit Log $\eta = .016$
 $K-L = 52 \quad 10 \times 10^{-11}$
 C.R.#2 = 9.50 Water temp 8, 10, 12 29.3°C


12 ⁴¹

Shut down
 P.M.-2 880V 17 peab on monitor.

addition of two small fuel plates = 3.15¢ excess

START-UP CHECK LIST

Equipment Checked by DTC Personnel Check by RKR
 Instrument and Tables Checked and Reset by DTC
 Source Inlet Checked by DTC Source No. M-43
 Emergency Stop Checked by DTC
 Red Light On by RKR
 Start Up OK'd by DTC Time 9⁰⁰ AM Fall Date 11-6 1958



pr. 21-1 Time 9⁰⁰ AM Date 11-6 1958
 Purpose Inoculation of void (16³ 4x4x1" Al bones)
hitman enters - loading same as 20-1
 Cuit = #1 .07 #2 14.58 #1 6.13 #2 10.10
 Personnel:

Starting K-1 (10x10⁻¹²) R-1 X1
 38
 K-2 34 (3x10⁻¹²) R-2 X1
 PM 2 700V

9²⁵/AM Water ht, LL = 49.197" Water Temp 8,10,12 = 24.3°C


C.R.#1 = .07
 C.R.#2 = 14.58 *pro period* Log n = .005 to .04
 82.6 sec = 11.34

9³⁵/ C.R.#1 = .07 *just emit* Log n = .04
 C.R.#2 = 12.10 K-L = 53 3x10⁻⁹ } 24.3°C water temp

9³⁷/ Shut down.

LL set at 9.757" at table top → actual water ht
 manometer stops at 8.943"

Expt.	22	Time	3 ⁵⁰ AM	Date	11-7-1958
Purpose	Foil Exp with 2 "1/4" spacing in center back Bone + cd covers				
Personnel:	RKR DFL				



Bone Au internal
Foil location as per sheet

4¹⁵ PM Water ht = 49.411"

Water Temp 8, 10, 12 = ~~23.5~~
(23.5°C)

4²² C.R.#1 = 2.35 slightly super

C.R.#2 = 15.87

Log $\pi = 1.2$ to 1

4²⁵ C.R.#1 = 4.16 pos period

C.R.#2 = 15.87

4²⁶ at power, Log $\pi = 1$

4³⁰ C.R.#1 = 1.41 just crit.

C.R.#2 = 15.87

4³¹ Shut down. (pull out one foil)
Counts 250 (Counts per min)

4³⁷ Start up on foil men.

4⁴⁹ Water ht = 49.787" Water Temp = ^{8, 10, 12} 23.5°C

4⁵⁹ C.R.#1 = 4.74 pos period.

C.R.#2 = 15.87

5¹² at power, Log $\pi = 35$ Water Temp ^{8, 10, 12} 23.5°C

5¹⁴ C.R.#1 = 1.47 Log $\pi = 35$

C.R.#2 = 15.87 K-1 = 35 3×10^{-7}

K-2 = 45 10×10^{-11}

P.M.#2 = 620 V 18 scale on recorder.

5³² Shut down. (Shut down peak on P.M.#2)
620 V - 50 scale on recorder.

Fail location	relative activity
W-37 41M (inside)	1.3831
W-41 41M outside	1.3817
W-33 42F	1.2648
W-46 44G	1.1260
W-44 47M	1.0548
N W-45 50G	1.0000
W-43 54F ^{recount} 0.9990	0.30186
W-32 63A	0.82360
W-42 66C	0.82312
W-34 69B	0.89518
W-35 70L	0.93517
W-40 71M (outside)	1.0271
W-39 3/16" from 71M ^{outside plate}	1.2062
W-47 on outside plate	1.1380
W-36 5/8" from outside plate	1.2899
W-31 1 1/8" " " "	1.2674
W-38 2 1/4" " " "	0.87926
W-series = 47.6 mg Au	
inside water gap on stringer	
Z 43 inside surface of cyl	1.2483
Z 34 1/4" from cyl	1.4876
Z 37 1/2" " " "	1.6514
Z 35 3/4" " " "	1.7623
Z 45 2" " " "	1.6992
Z 32 5" " " "	0.82660

Z series = 47.9 mg

Fail location	relative activity
Y-43 41D (inside)	0.31000
Y- 37 37 41D (outside)	0.30473
Y-41 42Q "	0.53518
Y-49 50M	0.39275
Y-48 51F	0.38794
Y-40 52G	0.37702
Y-42 53K ^{recount} 0.5544	0.55169
Y 31 60P	0.33265
Y-36 66N	0.27478
Y-35 69P	0.42025
Y-33 71H	0.26598
Y-38 outside plate	0.20606
Y-51 1 1/16" from outer plate	0.13239
Y-39 3/8" " " "	0.18755
Y-32 1 1/2" " " "	0.11312
inside water gap on stringer	
Y-34 cyl surface	0.29270
Y-50 1/4" from cyl surface	0.28420
Y-44 1/2" " " "	0.26242
Y-47 3/4" " " "	
Y-45 2" " " "	0.17353
Y-46 5" " " "	0.58574
Y series = 47.8 mg	

Exp. 23 Time 8⁰⁰ AM Date 11-11 1958
 Purpose: System loaded on a rod with approx 100gms U-A1 alloy strips - 2 1/16" center going
 Personnel: RICR DTC all checked

START-UP CHECK LIST
 Equipment Checked by RICR Personnel Check by RICR
 Instrument and Safeties Checked and Reset by DTC
 "Source In" Checked by DTC Source No. M-40
 Emergency Equipment in Control Room Checked by DTC
 Red Light On by DTC
 Start-Up OK'd by DTC Time 8⁰⁰ AM Date 11-11 1958

Starting Scales

K-1	85	3×10^{-12}	log N = .002
K-2	45	3×10^{-12}	
R-1	6	6x1	
R-2	1	6x1	
PM-2	1	800V	

8³⁰ AM Water 49.0" K-1 60 10×10^{-11} } Source in
 log N .017 } CR's in subcrit

8⁴⁰ AM C.R.#1 = .07 pos period. Water temp 8,10,12, = 23°C
 C.R.#2 = 11.38

8⁴⁵ C.R.#1 = .07 just crit.
 C.R.#2 = 9.23

8⁵³ Seen to be some drift in activity. Moved C.R.#2 from 9.20 to 8.40 to remain crit.

9⁰⁰ C.R.#1 = .07 just crit log N = .16
 C.R.#2 = 8.56 K-1 = 60 10×10^{-11}

9⁰⁰ shut down.

Reactivity change apparently caused by loosening of tape holding U-A1 strips.

Expt. 23-2	Time 12 ³⁵ PM	Date 11-11 1956
Purpose: Rpt 23-1 with U-AI strips more securely attached - same way as before - on rubber from center SE.		
Personnel: RKR - JFC		

To be compared with exp 20-1 CR#1 = .09 CR#2 = 14.58
(20-1) same meter but with out after U-AI strips.
Water ht = 50.455 Temp 8, 10, 12 = 23.2°C

1⁰⁸ PM CR#1 = .07 just exit Log n = .017 to .09
CR#2 = 11.35 R-1 = 59 10 x 10⁻¹¹

1⁰⁹ PM CR#1 = 2.50 pas period. Log n = .017 to .09
CR#2 = 11.35

1¹⁵ PM CR#1 = 2.50 just exit Log n = .09 Water Temp
CR#2 = 10.11 8, 10, 12 = 23.2°C

1¹⁹ PM C.R.#1 = 3.50 pas period Log n = .02 to .05
C.R.#2 = 10.11 394 m

1²⁵ PM C.R.#1 = 3.50 just exit Log n = .05
C.R.#2 = 9.98

1³⁰ PM C.R.#1 = 9.50 pas period. Log n = .013 to .05
C.R.#2 = 9.98 243.3 m

1³⁶ PM C.R.#1 = 9.50 just exit Log n = .05
C.R.#2 = 8.68

1³⁷ PM C.R.#1 = 6.00 pas period. Log n = .013 to .06
C.R.#2 = 8.68 147.7 m 7.24

1⁴⁶ PM C.R.#1 = 6.00 just exit Log n = .06
C.R.#2 = 7.42

Exp. 24-1	Time 10 ³⁰ AM	Date 11-12-1988
Purpose leading curve as 23-2 except all strips loaded on same diameter as 4-11 strips + in same manner		
Personnel: R.R. S.C.		

Starting { K1 65 (3×10^{-12}) $\log N = .0008$
K2 30 (3×10^{-12})

Previous Critical -

20-1 C.R.#1 .09 C.R.#2 14.58 (no extra U)

1054 23-2 .07 11.35 [Extra U = 14.8]

Water ht = 49.921

Water temp 8,10,12 = 23.2°C

Log $\eta = .013$

KI = 40 10×10^{-11}

1057 C.R.#1 = .08 just crit. Log $\eta = .02$
C.R.#2 = 12.85

1064 C.R.#1 = .08 post period. Log $\eta = .02$ to .11
C.R.#2 = 14.58 115.1m 8.8 d

1105 C.R.#1 = .08 just crit Log $\eta = .11$
C.R.#2 = 12.75

1107 C.R.#1 = .08 neg period Log $\eta = .11$ to .03
C.R.#2 = 11.35 239m (-) 6.5 d

1112 C.R.#1 = 2.50 just crit Log $\eta = .03$
C.R.#2 = 11.32

1113 C.R.#1 = 3.50 post period Log $\eta = .03$ to .09
C.R.#2 = 11.32 395m 3 \ water temp 8,10,12 = 23.2°C

1121 C.R.#1 = 3.50 just crit Log $\eta = .09$
C.R.#2 = 10.80

1123 Shut down,

	CR1	CR2		
20-1 =	.09	14.58	no added fuel	
23-2	.19	11.35	= +14.8¢	
24-1	.08	14.58	+8.8¢	6.0¢ diff
	.08	11.35	-6.5¢	
CR-1 from 2.50 - 3.50			23-2 =	3.85¢ } possible depression -
			24-1 =	3.0¢ } due to Alating

Effect of Al alone = 6¢ neg
 " " 4-Al = 14.8¢
 " " u " = 20.8¢

Expt. 24-3	Time 8 ³⁰ AM	Date 1-13-1958
Purpose: Rpt 24-2 with U-Al alloy strips staggered on orange fuel		
Personnel: D.R.C., E.R.R.		

9⁰⁵ A water ht 49.13" 23°C

9¹⁰ Critical Condition $\log N = .05$ $K-1 = 58$
 CR-1 - .08 Safety 17.2
 CR-2 11.24

9¹² Positive period $\log N .05$ to $.45$
 CR-1 .08
 CR-2 12.75 130.5 sec 7.8 d

9²² Pos. Period $\log N .1$ to $\log N-1.2$
 CR1 .08
 CR2 14.58 50 sec 16.2 d

9²⁴ Shut down
 Staggering fuel = 16.2 d total
 alone 7.8 d
 Optin fuel worth 14.8
 6.
 28.6 d

Exp#	24-4	Time	11:00 AM	Date	11-13 1958
Purpose	Fuel strips staggered thru 1 1 quadrant so that any strip is at least 2" from wires				
Personnel:	RKR, JSH				

11¹⁶ Water ht = 49.112 Water temp 8,10,12, = 23.2°C

11²⁰ C.R.#1 = .08 pos period Log n = .02 to .2

C.R.#2 = 12.75 478 sec 16.5 d

11²⁴ C.R.#1 = .08 just Crit Log n = .2

C.R.#2 = 9.74

11²⁵ C.R.#1 = .08 pos period Log n = .2 to .7

C.R.#2 = 11.24 124 sec 8.2 d

11³¹ C.R.#1 = ~~.08~~ .08 pos period Log n = .05 to 1

C.R.#2 = 14.58 26.1 sec 23.4 d

11³⁸ C.R.#1 = .08 pos period ~~Log n = .05 to 1~~

C.R.#2 = 14.58 26.1 sec 23.4 d

11³⁹ Shut down.

Optimizing fuel = 8.2 d more.

~~20.8~~ 14.8

~~35.8~~ total 8.2

.6

check = 23.4 d 28.0 d

6 d

29.4 d

Expt. 24-5	Time 1 ¹⁰ PM	Date 11-13 1958
Purpose Same loading but Al strips distributed over sphere uniformly		
Personnel: RKR JFL		

- 1³⁰ PM Water ht = 99.205 Water temp 8, 10, 12 = 23.2°C
- 1³⁴ C.R.#1 = .05 post period Log $n = .02$ to .07
C.R.#2 = 12.75 65.2 on
- 1³⁸ C.R.#1 = .08 just exit Log $n = .07$
C.R.#2 = 10.23
- 1⁴⁰ C.R.#1 = 1.14 just exit Log $n = .07$
C.R.#2 = ~~9.74~~ 9.74
- 1⁴² C.R.#1 = 1.14 postive period Log $n = .07$ to .15
C.R.#2 = 10.23 509 on
- 1⁴⁷ Shut down.

Expt.	24-6	Time	2 ⁰⁰ AM	PM Date	11-13	1958
Purpose	Al strips removed U-Al strips still in					
Personnel:	JCF DK					

2¹⁸ PM Water hft 49.217 Temp 23.2°C
Crit. Cond

2²³ CR-1 .08 just exit Log N = .02
CR-2 = 8.95

2²⁴ C.R. 1 = .07 pos period Log N = .02 to .14
C.R. 2 = 10.23 104.2 sec = 9.44

2²⁶ shut down.

Expt.	24-7	Time	2 ⁰⁰ AM	PM Date	11-13	1958
Purpose	U-Al strips removed same as earlier - 20-1 - .09 #1 #2 (10.58) crit 6.13 #2 (10.10)					
Personnel:	P. R. K. DK					

3¹² PM Water 49.2" temp 23°C

Pos. Period 369 sec

3¹⁸ PM CR-1 .07 log N .015 to log N .035
CR-2 15.86

Crit Cond

3²⁶ CR-1 .07 log N = .035

CR-2 14.80
crit cond
CR-1 3.47

3³¹ CR-2 - 12.50

Pos. Period 91.2 sec = 10.44

3³³ CR-1 = 3.47 } log N = .035 to log N 0.2
CR-2 = 14.80 }

(over)

3³⁵ Neg Period 139 sec
 CR-1 = 3.47 CR-2 = 10.23 13.7¢ (-)

3⁴² Critical
 CR-1 = 5.91 CR-2 = 10.23 log N = .07

3⁴³ Pos. Period 82.5 sec 13.2¢
 CR-1 5.91 CR-2 - 12.50 log N = .07 to 0.5

3⁴⁶ Neg Period 169 sec (-) 10.2¢
 CR-1 5.91 CR-2 - 8.45 log N 0.5 to

Critical CondX
 3⁵⁵ PM CR-1 7.78 CR-2 8.45 log N = 0.12

3⁵⁶ Pos Period 104 sec 9.4¢
 CR-1 7.78 CR-2 10.23 log N 0.12 to log N = 0.7

Critical CondX
 4⁰⁵ PM CR-1 7.78 CR-2 8.45 log N = 0.6

Shutdown

Summary	Rate	
	#1	#2
loaded with A1 + U-A alloy	.08	10.23
loaded with U-A alloy	.08	8.45 - 9.4¢
no loading	.08	14.80 = 32.0¢
worth of U alone		42.4¢

#

Expt.	25-1	Time	1 ²⁰ AM	Date	11-14	1958
Purpose	12/4" sphere (solid Al) in center of void space (2 1/16" spacing between support lugs) - 6 cadmium plates added to sphere					
Personnel:	RKR JFC					

START-UP CHECK LIST	
Equipment Checked by	RKR
Instrument used	JFC
Source	M43
Emergency stop	JFC
Red Light On	JFC
Start-Up OK	JFC
Time	1 ²⁵
Date	11-14 1958

1⁴² PM Water ht = 49.195" Water temp 8,10,12 = 23.2°C

1⁴⁴ PM CR^{#1} & CR^{#2} out: Sub Crit:

Expt.	25-2	Time	1 ⁵⁰ AM	Date	11-14	1958
Purpose	3 Cd plates removed					
Personnel:	RKR JFC					

2⁰⁵ PM Water 49.2" Water temp 23°C

CR-1 16.63 } slightly dryer 1260 sec

2⁰⁹ PM CR-2 11.98 }

Crit Cond

2¹⁹ PM CR-1 16.63 } log N = .02

CR-2 10.82 }

Expt. 25-3	Time 2:21 AM	Date 11-14 1954
Purpose: 2 plates of plates fixed in metal at least 1 orange peel away from next		
Personnel: RKR JHC		

2:45 PM Water 49.2 inches

2:48 #1 3.53 Pos. Period 336.6 sec
~~2.76~~ } Pos. Period log V = .0015 to log N = .02
 R#2 15.87

note from Exp 24-1 Rd1 2.50 → 3.50 = 3d
 23-2 2.50 3.50 = 3.85d

Critical Conditions

3:00 PM #1 - 2.57 #2 15.87 log V = .02
 Pos. Period 121.6 sec 5.45d

3:07 #1 - 4.50 #2 15.87 log V .02 to .2

Crit Cond

3:15 #1 4.50 #2 14.31 100%

3:16 #1 5.50 #2 14.31 Pos. period log N = 1.2 to 1.3
 217.2 sec 6.15

3:22 #1 5.50 #2 13.50 just crit log N = 1.3

3:24 #1 6.50 #2 13.50 Pos. period log V = .3 to 208.5 sec 6.35

3:28 #1 6.50 #2 12.72 just crit log V = .9

3:45 #1 7.50 #2 12.72 pos period log N = .07 to 5.80
 199.0

3:46 #1 7.50 #2 11.95 just crit

Shutdown

Expt.	25-4	Time	9 ^{AM}	Date	11-14	1958
Purpose	Continuation of CR calibration (25-3)					
Personnel	RRR JSC					

9⁵⁵ AM Water 49.2" 23.0°

10⁰⁵ #1 5.50 #2 15.86 Pa. Pined 73.8 sec 12.24
LN=0.11 8.2

10¹² #1 2.79 #2 15.86 level by N 0.14

10¹⁵ #1 5.50 #2 13.65 level by N 0.16

10²⁵ #1 7.50 #2 13.65 pa. pined by N .16 - .17 84.7 sec 11.4

10³⁰ #1 7.50 #2 12.05 level by N = 0.7

10³² #1 8.50 #2 12.05 pa. pined by N 0.7 - 186.7 sec 5.85

10³⁹ 8.50 11.29 level by N = 1.9

10⁴⁰ #1 2.79 #2 11.29 pa. pined by N 1.9 - 82.5 sec

10⁴⁸ 8.50 11.29 level by N = .03

10⁴⁹ 9.50 11.29 pa. pined .03 to .15 171.6 sec 6.35

10⁵⁵ 9.50 10.50 level by N .15

11⁰⁰ 10.51 10.50 pa. pined 173.8 sec 6.25

11⁰⁷ 10.51 9.75 level by N .45

11⁰⁸ 11.51 3.50 pa. pined -69.5 sec

11¹³ 12.50 9.75 pa. pined 71.7 sec 12.6

11¹⁸ 12.50 8.29 level by N = .19

11¹⁹ 14.50 8.29 pa. pined 84.7 sec 11

11²⁵ 14.50 6.87 level by N = .7

11²⁶ 16.57 6.87 pa. pined 129.4 sec

16.57 5.73 level by N 2.1

(over)

230

	#1	#2	
11 ³²	16.57	0.0	my point by #2 → -80.4mm
			water temp 23°C
11 ³⁷	Shutdown		

worth of CR1 from 2.5 to 16.57 = 75.15¢

est. from 2.5 to 0 = 5¢

so each Cd plate = n 78¢

2 plates = 1.56

+ CR-1 = .73

[express with oprene] # 2.29 =

no oprene CR-1 = 6.13 CR-2 = 11.87 no fixed plates - n 17¢ ^{on #1} less ~~value~~
56¢ of Calin

Est. value of oprene = \$1.73 ± 20%

START-UP CHECK LIST

Equipment Checked by DK Personnel Check by RKR
 Instrument and Reagents Checked and Replenished by DK
 Source of Instrument M-43
 Emergency Rep. in Control Room DK
 Ref. Count DK
 Start-Up OK'd by DK Time 8⁰⁰ Date 11-18 1958

Expt. 26-1 Time 8³⁵ AM Date 11-18 1958
 Purpose 1 cd plate added to system
note - all cd plates operated by
1 orange pul. evaluate fitted plate -
 Personnel: RKR DK

8⁵⁵ 49" water at 23°C

CR-1 CR-2

9⁰⁰ 16.59 out 15.87 (out) Sub Cont

Expt. 26-2 Time 9⁰⁰ AM Date 11-18 1958
 Purpose 1 cd plate removed from SE section
 Personnel: RKR DK

9³⁵ Water = 49.190 at 23°C

9⁴⁰ C.R.F.1 = 5.50 per period

C.R.F.2 = 15.87

C.R.F.1 = 2.35 just exit. by n. 1

9⁴⁷ C.R.F.2 = 15.87

Shut down.

Expt. 26-3 Time 9⁴⁵ AM Date 11-18 1958
 Purpose cd plate moved from NE section
to SE - 1 orange pul. from CR-2 (in 2nd pul)
 Personnel: RKR DK

10⁰⁰ Water 49" temp 23°C

10⁰⁵ C.R. 16.50 CR 2 15.87 per period

over

232

10⁵⁷

C R 1 7.50 C R 2 15.87 for pins

1013:

C R 1 5.91 C R 2 15.87 level by N = .05

Expt. 26-4	Time 10 ⁴⁵ AM	Date 11-18 195
Purpose #3 Cd plate mounted in cart (6N)		
orange pul & SE Cd plate removed		
Personnel: RKR JSC		

Blotting paper wrapped around dead cables
 in 75% of path particularly where in forced air draft -
 including junction box.

11⁰⁴ water at 49.2" temp 23°C11¹⁰ C R 1 4.50 C R 2 15.87 for pins11¹⁵ C R 1 2.80 C R 2 15.87 Coil by N = .05
 note Gen 4 appears much more stable

Expt. 26-5	Time 11 ⁰² AM	Date 11-18 195
Purpose NW Cd plate moved to SE		
orange pul. note: Cd plate mounted - placed Cd in NE pul		
Personnel: RKR JSC		

11²⁴ Blotting paper taken off junction box only
 water at 49" temp 23°C11⁴⁰ C R 1 4.35 C R 2 15.87 just end by N = .0211⁴⁷ Shutdown

Expt. 27-1	Time 8 ³⁰ AM	Date 11-15 1958
Purpose Internal expansion 1/2" more = 3 3/4"		
2 Cd plates in + Al sphere =		
Personnel: R.K.R. etc		

8⁴⁰ AM 49.153" water 23°C

8⁴⁹ C.R.#1 = 16.63 sub crit.
C.R.#2 = 15.87

Expt. 27-2	Time 8 ⁵⁰ AM	Date 11-19 1958
Purpose Same 1 fixed plate removed SE corner		
Personnel: D.F.C. R.K.R.		

9⁰¹ water ht = 49.182 at 23°C

9⁰⁵ C.R.#1 = 9.50 for periods
C.R.#2 = 15.87

9¹³ C.R.#1 = 7.53 just crit
C.R.#2 = 15.87

9¹⁴ shut down

CRI = +25d

plate = 73d

loss of reactivity = 298d

47.9
47.3

Foil loading -

Base Normality = $\bar{Z} = 31$ on plate 50 $\bar{Z} = 47.9$ mg ea.

Foil	plate		on plastic spacer (upper)
253	41	.35616	clockwise in front of each reel
36	42	.7447	
38	43	.363	
39	44	.42161	
40	45	.38725	
41	46	.38804	
42	47	.39493	
44	48	.3964	
46	49	.408	
47	50	.3947	
48	51	.3965	
49	52	.40343	

C (47.0 mg) factor = 1.019

- 1 = CR#2 1.6207
- 2 1.6049
- 3 1.4750
- 4 CR#1 1.2946
- 5 1.5039
- 6 1.6522
- 7 1.6998
- 8 1.7911
- 9 1.7482
- 10 1.8187
- 11 1.7276
- 12 (D) = 47.3 mg (f = 1.013) 1.4900 = 1.72

A (42.4 mg) [factor = 1.01]

53	53	.394	.398
54	54	.3863	
55	55	.38698	.396
56	56	.41164	.421
57	57	.37104	.375
58	58	.41848	.423
59	59	.4029	.417
60	60	.36671	.370
61	61	.3433	.346
62	62	.53571	.542
63	63	.3237	.328
64	64	.32608	.330

A-65 = .3149
B-65 = .3612

B (47.3 mg) [factor = 1.013]

65	66	.31667	.321
67	67	.29352	.298
68	68	.46523	.473
69	69	.2933	.297
70	70	.25726	.261
71	71	.22976	.232
72	72	.54728	.555

- 73 (on compressed inside) - .334 .339
- 74 0" inside w/ - .328 .333
- 75 1/4" " " .31351 .318
- 77 1" " " .24405 .2475
- 76 0" inside w/ (base) 1.5651 = 1.59

Expt.	28-1	Time	4 ³⁰ AM	Date	11-19 1958
Purpose	Foil Run - 2 "1/16" spacing Base & covered Au as shown				
Personnel:					

Loading of foils in orange ped.

41 R	51 L	61 R	71 C
42 C	52 C	62 C	72 R
43 L	53 R	63 L	#50 base foil in
44 R	54 L	64 R	n.c. orange ped mat
45 C	55 R	65 C	to softy.
46 L	56 C	66 L	
47 R	57 L	67 R	
48 L	58 R	68 L	
49 C	59 L	69 C	
50 R	60 C	70 R	

5⁰⁷ PM Water ht = 49.219 at 23°C

5⁰⁹ C.R.#1 = 2.75 joint crit. Log N = .011

C.R.#2 = 15.87

5¹⁰ CR1 = 5.13 for print

CR2 = 15.87

5²² started to level.

C.R.#1 = 2.75

softy = 17.2"

C.R.#2 = 15.87

P.M.#2 = 620V bon number.

P.M.#1 = .58

K-1 = 36 3×10^{-7}

K-2 = 9 3×10^{-10}

Log η = 36

R-1 = 3.8 5×10^0

R-2 = 2.8 5×10^0

assn

5⁴⁵ shut down. water temp = 23°C

Expt. 29-1	Time 10 ³⁰ AM	Date 11-25 1958
Purpose: Test Cd safety plate internal Rod # 2 removed - all UP = 10.00		
Personnel: J.W. H. O.H. S.H. C.C.		

cd plate
8 1/2" x 8 1/2"
sphere ignored

11²⁰ AM Water level monometer faulty. Water level measured with sight-glass.

11³⁰ Instrument scram (K-1). Exact cause not determined. System was not critical.

	H ₂ O ht (cm)	Rod 1	Safety	Rod 2	
11 ⁴⁵ AM	106.3	0.08	out	4.00	slightly super
	106.0	"	"	"	critical
	106.0	"	"	6.5	sub crit
	107.0	"	"	6.5	critical
	129 (flooded)	"		7.29	out
	"	"		7.23	super ^{just} critical
12 ⁰⁰ AM	"	3.11		8.00	critical

~~8.5~~

10.08 (out)

15.68

At 10.08 the cd is in contact with the inner surface of upper hemisphere

12⁰⁸ Water Temp = 24°C

All measurements made between log M = .01 and log M = .02

90 d
~~90 d~~

12¹⁰ PM pos. period Rod 1 = 15.68 , Rod 2 = 9.85

Log N = .1 Rod 1 = 13.48 , Rod 2 = 9.85 level

pos period Rod 1 = 13.48 ; Rod 2 = 9.64

Log N = .3 Rod 1 = 11.94 , Rod 2 = 9.64 level

pos period Rod 1 = 11.94 , Rod 2 = 9.20

Log N = .4 Rod 1 = 9.04 , Rod 2 = 9.20 level

12³² PM pos period Rod 1 = 9.04 , Rod 2 = 8.50

Log N = .6 Rod 1 = 5.51 , Rod 2 = 8.50 level

pos period Rod 1 = 5.51 , Rod 2 = 7.50

Log N = 1 Rod 1 = 1.5 , Rod 2 = 7.50 level

pos period Rod 1 = 1.5 , Rod 2 = 2.00

from 200" to 10.08"

83.6
~~88.1 d~~

10.08
- 5.1

4.98

Sept Control plate inserted to work on
lower segment - contact with legs =
-.04" overage - limit set at +.15"
legs extend $\approx \frac{7}{16}$ " up from fuel (same as top segment)

Expt.	30-1	Time	4:05 AM	Date	11-25	1956
Purpose	Test control plate (CP#2) on lower segment of internal sphere					
Personnel	RKR DFC					

- 4.31 pm Water ht = 99.2 Temp = 29°C
4.38 C.R.#1 = 10.01 just crit. Log n = .05
C.R.#2 = 0.15
- 4.39 C.R.#1 = 10.01 poor period. Log n = .05 to .15
C.R.#2 = 0.96 10.2 on 9.6 d
- 4.41 C.R.#1 = 8.37 just crit. Log n = .15
C.R.#2 = 0.96
- 4.49 C.R.#1 = 8.37 poor period. Log n = .15 to .6
C.R.#2 = 0.96 73.9 on 12.4 d
- 4.54 C.R.#1 = 5.98 just crit. Log n = .6
C.R.#2 = 0.96
- 4.56 C.R.#1 = 5.98 poor period. Log n = .6
C.R.#2 = 1.46 115 on 8.6 d
- 5.03 C.R.#1 = 4.00 just crit. Log n = 1.8
C.R.#2 = 1.46
- 5.10 C.R.#1 = 1.12 just crit. Log n = .7
C.R.#2 = 2.46

5¹¹ C.R.#1 = 9.01 *five periods top 1.1 to 2.0*
 C.R.#2 = 2.46 95.6 sec 10¢

5¹⁵ C.R.#1 = 1.12 *just cut top 1 = 2.0*
 C.R.#2 = 2.46

5¹⁷ C.R.#1 = 1.12 *five periods top 1 = 2.0 to 5.0*
 C.R.#2 = 5.96 174 sec 6.2¢

~~C.R.#1 =~~

~~C.R.#2 =~~

5¹⁹ PM *Shut down*

CR-2 = 0.15 to 0.46 = 9.6¢

.46 .96 12.4

.96 - 1.46 8.6¢

1.46 2.46 10.0

2.46 5.96 24.2

46.8¢


Rd 2 all in = Rd 1 at 10.01" 0
 (0.15")

starting cut in 31¢

77.8¢

11-26-58 set up for liting tanks.

10⁴⁵ 8, 10, 12, 29°C 24 + 18 Kw ~~14~~ on -
N ↑



liters set to operate only if water is at 50.6" (42" above center cyl in sphere)

10⁴⁵ temp demand 100°F

11⁰⁴ #8 = 26°C #10, 12 26.5°C

11¹² #8 = 27.5° #10, 28.0 #12 28.0°C

11¹⁵ demand set back to 90°F

11²¹ control - operated 8 - 10 - 12 29°C

Expt. 31-1	Time 8:30 AM	Date 11-28 1958
Purpose - <u>carry coeff 75R</u>		
Personnel: <u>RKR & AC</u>		

9:37 Water Temp (mixer on) Water ht = 131.5 cm.

K-3 = 22.25°C, 865 mV.

Brown #8 = 25.25°C #10 = 25.25°C #12 = 25.25°C

9:45 Water Temp same or above.

9:47 C.R.#1 = 3.15 Brown = 25.25°C

9:55 C.R.#2 = 2.46 K-3 = 857 mV

9:57 C.R.#1 = 4.15 pos period Log $\pi = .03$

C.R.#2 = 2.46

10:00 C.R.#1 = 5.15 pos period by N. 1.088.

C.R.#2 = 2.46

10:05 C.R.#1 = 3.15 just exit Log $\pi = .22$

C.R.#2 = 2.46 Water Temp = same or above.

10:06 System made sub crit. (copper in) contact read in.

C.R.#1 = .07

C.R.#2 = .13

10:08 Heaters on, temp set on ~~30~~ 35°C.

11:18 C.R.#1 = 5.15 pos period Log $\pi = .03$ to .13

C.R.#2 = 2.46

11:25 C.R.#1 = 3.78 just exit Log $\pi = .13$

C.R.#2 = 2.46

Brown = 39.8°C

K-3 = 1.278 mV

over.

Log $n = .12$

11⁴⁰ C.R.#1 = 4.34 ^{just} Brown = 34.6 °C
 C.R.#2 = 2.46 ^{exit} K-3 = 12.78

11⁵⁵ C.R.#1 = 4.78 ^{just exit} Brown = 34.6 °C
 C.R.#2 = 2.46 K-3 = 1,300 mV

Log $n = .11$

(There has been a drift in exit positions
 in post half-hour.)

11⁵⁷ C.R.#1 = 5.15 ^{Log $n = .11$ to}
 C.R.#2 = 2.46 ^{pro} ^{found}

12⁰⁰ C.R.#1 = 07 (same in.)

C.R.#2 = 13 (system shut down to ~~imperfect operation~~
 imperfections)

12¹⁰ ^{demand} Temp increased to 45 °C.

2²⁰ PM ^{remained} at 45 °C

2³⁰ PM Water Temp K-3 = 1830 mV Brown 8,10,12 = 47 °C

2⁵⁴ PM C.R.#1 = 7.83 } ^{Temp} ¹⁸²⁴ = 45.25 °C
 C.R.#2 = 2.46 } ^{Room} 46.5 °C

3⁰² PM (C.R.#1 & C.R.#2 are in) (same in) sub unit.
 shut down,

Water dumped - (to remove air bubbles
 clinging to sphere)

3²⁰ PM Water back in to 120 cm (ashtat no stirrer)
 air bubbles not evident

3.27 C.R.F₁ = 1.60 just crit. Water temp
 C.R.F₂ = 2.96 K-3 = 1.750
 Brown 8, 10, 12 = 45.5°C

3.35 shut down,

Note = bubbles may be causing the position effect!

Exp: 31-2	Time 8:30 AM	Date 12-1	1958
Purpose Cont. temp exp - stirrer blades			
repaired to prevent an being crushed in by stirrer -			
Personnel:			

9¹⁰ AM Water Hd - 130.1 cm Temp = 23.5°C

9²⁰ C.R.F₁ = 1.31 just crit. Log n = .08

C.R.F₂ = 2.46 Brown = 24.2°C
 Temp = K-3 = .8534 mV.

9²⁵ shut down to inspect system

Stirrers operating - no evidence yet of ingassing

Brown = 24.0°C K-3 = .910 mV (via both coming to equilibrium)

9⁵⁵ C.R.F₁ = 1.31 just crit. Log n = .08

Temp Brown = 23.6
 K-3 = .905 mV.

C.R.F₂ = 2.46 with stirrer operating.

9⁵⁶ shut down to inspect system.

9⁵⁷ all heaters on, Temp set at 45°C.

11¹¹ temp = 34.9°C 8, 10, 12 || K₃ = 1.373 mV 34.5°C

11²⁰ C.R.F₁ = .06 just crit Temp = K₃ = 1.373

C.R.F₂ = 2.77 Log n = .08 Brown = 34.9°C

C.R.F₂ = 2.19

11²⁵ C.R.#1 = 1.31 *pos period* $\log \eta = .07$ to .22
 C.R.#2 = 2.96 $\frac{206.5 \text{ sec}}{38} \approx 5.44$
 Temp K-3 = 1.373
 Brown = 34.9°C

11³⁷ C.R.#1 = .07 *just crit* $\log \eta = .22$
 C.R.#2 = 2.19
 Temp K-3 = 1.373
 Brown = 34.5°C

11⁴⁰ Shutdown - still no evidence of air bubble
 on reactor - draining water then feed valves + pump -
 Same IN CR1 .07 } K-1 = 60 on 10x10" scale -
 CR2 .12 }

Exnr. 31-3	Time 12 ⁵⁰ PM	Date 12-1	1958
Purpose cont. temp run.			
Personnel:			

1³⁰ PM TC, 8, 10, 12 = 34.5°C water = 130 cm
 K-3 1.373 mV

1³⁷ C.R.#1 = 1.31 *pos period* 217. sec period
 C.R.#2 = 2.96

1⁵¹ PM C.R.#1 = .07 *just crit* Temp K-3 = 1.373
 C.R.#2 = 2.21 $\log \eta = .2$ T.C. 8, 10, 12 = 34.5°C

1⁵⁸ Temp demand set to 45°C. K-Z = 65 10x10"
 Shutdown, same in. $\log \eta = .02$

3¹⁵ Temp TC 8, 10, 12 = 45.2°C
 K-3 = 1.822

3¹⁴ C.R.#1 = 1.31 *pos period* $\log \eta = .05$ to .2
 C.R.#2 = 2.96 208.5 sec.

3²⁷ C.R.#1 = .07 *just crit* $\log \eta = .2$
 C.R.#2 = 2.26 Temp 8, 10, 12 = 45.1°C
 K-3 = 1.820 mV

3³⁰ PM Temp demand set to 60°

Note: from response of K-1 temp coeff. pointer up to $\approx 40^\circ\text{C}$
 + begins neg from there - at 48°C definitely negative -
 Visual examination of reactor - air bubble formation
 on metal plate - [past history of reflector water evidently
 makes a difference].

12-2-58

top center sections (4) removed from T.S.P.
 to heat water safely - dist. on - safety set &
 source in - Starting Temp Pressure 8,10,12 = 36°C
 - K-3 = 1.377
 - K-4 set to 65°C


11³⁰ AM temp 55°C some evidence of bubbles at 45°C

2⁰⁷ PM temp 68.5°C draining back thru pump to
 avoid putting in air -

Expt. 31-4 Time 4⁰⁰ ^{AM} ~~PM~~ Date 12-2 1958
 Purpose cont. temp. over after outgassing (water htd to 68.5°C)
CR-2 rods
 Personnel: RKR BPC

(water htd to 68.5°C)
 + drained back

CR# 2 (coated plate no-zinc)



Selayn on CR2 set to read 0.55"
 approx distance of plate from fuel

- 4¹⁹ Water ht = 130 cm. Brown = 9/10/12 = 58.5°C
- 4⁴² K-3 = 2.9275 58.7°C Brown = 59°C
- 4⁵⁵ C.R#1 = .07 fuel crit Log n = .18
- C.R#2 = 2.35
- 5⁰⁰ C.R#1 = 5.14 Log n = .16
- C.R#2 = 1.50 fuel crit.
- 5²⁵ C.R#1 = 10.82 fuel crit Log n = .15
- C.R#2 = 0.55
- 5⁴⁰ Shut down,

TC
 #10 59.5°C
 K3 2.456 mV

Expt. 31-5	Time 8 ⁴⁵ AM	Date 12-3-1958
Purpose Cont. Temp. run, after water cooled.		
Personnel: D.J.C. R.K.R.		

9⁰⁵ AM Water ht = 129 cm. Temp. at 40°C

$$\log N = .02 \quad K_3 = 65 \text{ on } 10 \times 10^{-11}$$

9³³ AM Temp Brown 41.5°C $K_3 = 1.700$ MV

9³⁵ AM CR-1 .07 CR-2 2.50 pos. Period

9⁴¹ C.R.#1 = .07 just crit $\log n = .2$

$$C.R.\#2 = 1.97$$

9⁴⁵ C.R.#1 = .07 - pos period $\log n = .2$ Brown = 41.7°C
 $K_3 = 1.700$

$$C.R.\#2 = 2.31$$

~~C.R.#1~~

~~C.R.#2~~

9⁴⁷ Shut down, Reset temp to control at 45°C

Expt. 31-6	Time 10 ³⁰ AM	Date 12-3-1958
Purpose new Temp ~ 48°C		
Personnel: D.J.C. R.K.R.		

10³⁶ Water ht = 129 cm. Brown = 48°C

$$246 \text{ on } 4.69 \quad K_3 = 1.960$$

10³⁶ C.R.#1 = .07 pos period, $\log n = .1 \text{ to } .35$

$$C.R.\#2 = 2.31$$

10⁴³ C.R.#1 = .07 just crit $\log n = .35$

$$C.R.\#2 = 2.05 \quad K_3 = 1.960$$

10⁴⁴ Shut down, cooling off system -

1:25 PM Cold water from faucet added to system in 8" well
water at 23°C

Expt. 31-7	Time 2:48 AM	PM Date 12-3-1958
Temp. 35°C		
Personnel: D. C. R. Kelly		

2:48 PM Water ht = 130 cm. Temp Brown = 35°C
K-3 = 35°C

2:59 C.R.#1 = .07 ^{195.5 mm} for period. Log n = 1.15-1.19 5.7¢
C.R.#2 = 2.78

2:59 C.R.#1 = .07 ^{28.2} for period Log n = .19 to .26 11.16¢
C.R.#2 = 3.50

3:07 C.R.#1 = .07 just crit Log n = .6
C.R.#2 = 2.33

3:10 C.R.#1 = .07 ~~10~~ Log n = .6
C.R.#2 = 3.50 ~~just crit.~~ and

Net Sopley from 17.20 to 14.74

3:12 C.R.#1 = .07 ^{228.5} for period. Log n = .6 to 1 4.8¢
C.R.#2 = 4.50

Sopley from 17.20 to 14.74

3:17 C.R.#1 = .07 just crit Log n = 1
C.R.#2 = 4.50

Sopley from 17.20 to 14.00

3:25 C.R.#1 = .07 ^{1520 mm} ~~8.5 mm~~ for period. Log n = .1 4.4¢
C.R.#2 = 6.50 Brown = 35°C
K-3 = 1.415

Sopley from 17.20 to 14.00

329 C.R.#1 = 0.7 ^{1850m} ~~875m~~ ^{Log n = .15 to} < 14
C.R.#2 = 8.50 ^{post period}

336 ^{Softy from 17.20 to 19.00}
C.R.#1 = 4.83 ^{just crit Log n = .12}
C.R.#2 = 1.50

337 ~~Softy from 17.20 to 19.00~~ ^{Softy is out = 17.20}
C.R.#1 = 4.83 ^{46.8m post period Log n = .12 to .5} 17 ~~17~~
C.R.#2 = 2.33
Softy = 17.20

342 C.R.#1 = 7.81
C.R.#2 = 1.00 ^{feed crit Log n = .7}
Softy = 17.20

344 C.R.#1 = 7.81 ^{54.7m} ^{Log n = .7 to} 15.3 ~~15.3~~
C.R.#2 = 1.50 ^{post period}
Softy = 17.21

347 C.R.#1 = 10.43
~~C.R.#2 = 0.55~~ ^{just crit Log n = .8}
Softy 17.21

349 C.R.#1 = 10.43 ^{43m} ^{Log n = .8 to 1.8} 18 ~~18~~
C.R.#2 = 1.00 ^{post period}
Softy = 17.21
Brown = 3.5°C
K-3 = 1.4-1.5

350 Shut down.

Expt. 31-9	Time 10 ³⁵ AM	Date 12-9	1958
Purpose: Room temp; Cont. Temp runs at about 20°C			
Personnel: D.F.C. R.H.H.			

10⁵⁰ Water ht = 129.5 cm temp 29.5°C
slight ht added-

11²⁰ K-3 = 1.2075 mV Brown = 29.8°C
30.50°C

11³⁵ C.R.#1 = .08 Log n = .2

C.R.#2 = 2.14 just crit. Brown
Sofley = 17.20 K-3

11³⁵ Brown temp = 29.9°C K-3 = 1.2075 mV

11⁴⁰ Shutdown

Expt. 31-9	Time 8 ²⁰ AM	Date 12-5	1958
Purpose: Room temp same system Stimulation			
Personnel: PRR DFC			

8⁴⁵ Water ht = 130 cm Brown = 25°C
K-3 = 0.993

8⁵⁴ C.R.#1 = .08 } just crit Log n = .13
C.R.#2 = 2.55

8⁵⁹ C.R.#1 = 10.77 just crit Log n = .13
C.R.#2 = 0.54

9⁰⁰ C.R.#1 = 13.03 Log n, .13 to .5
C.R.#2 = 0.54 postperiod 58.6 sec period. 11.54
Sofley = 17.19

9⁰¹ C.R.#1 = 13.03 just crit Log n = .5
C.R.#2 = 0.54
Sofley = 14.25

9⁰² C.R.#1 = 11.02 34.7 sec period
 C.R.#2 = 0.54 pow period 244

Log₁₀ = 14.25

9¹⁰ Shut down

Replaced sticking or release valve on Well -

Expr.	31-10	10 ⁰² AM	Date	12-5	1958
Purpose	Remand C.R.#2 plate left in well auto. & wahre.				
Personnel:	P.K.R. Dir. C.				

10¹⁷ Water ht = 129.3 cm. Brown = 29.8°C
 K-3 = 0.985

10²⁵ C.R.#1 = 13.53

C.R.#2 = 0.54 (just rad.) just crit Log₁₀ n = .013

Log₁₀ = -.32

10³² C.R.#1 = .075

C.R.#2 = 0.54 just crit Log₁₀ n = .09

Log₁₀ = 13.50

10³⁵ C.R.#1 = .075

C.R.#2 = 8.50 1410 sec pow period Log₁₀ n = .09 to

Log₁₀ = 13.50

Brown = 29.8°C
 K-3 = 0.985

10⁴⁰ C.R.#1 = .075

C.R.#2 = 8.50 just crit Log₁₀ n = .051

Log₁₀ = 13.30

10⁴⁵ C.R.#1 = .075

C.R.#2 = 8.50 43.4 sec pow period Log₁₀ n = .051 to .55

Log₁₀ = 17.21

10⁴⁶ Shut down

Expt. 32-1	Time 3 ¹⁰ PM	Date 12-29 1956
Purpose Repeat of temp exp on TSR		
Personnel:		

Water pre-heated to 65°C and dumped (degenerating)

Center section of TSR out during heating - .51

Replaced C-2 contact on bottom of 0.75 on #4 noted

3²⁰ m Water at 130 cm

temp - Brown = 60.75°C

K-3 = 2.505 mV = 60.75°C

3⁴⁵ / C.R.#1 = .07 just crit log $\eta = .1$

C.R.#2 = 2.16

3⁵² / C.R.#1 = 5.14 (See log 31-4)

C.R.#2 = ~~1.39~~ just crit log $\eta = .15$
1.39

4⁰⁰ m C.R.#1 = ~~10.82~~ 10.37 temp #4 + 10 59.9°C

C.R.#2 = 0.50 K₃ = 2.471

4⁰⁰ Shutdown by dumping

Expr. 32-2	Time 8:30 AM	Date 12-8-10 1958
Purpose cont temp run		
Personnel: D.J.C. R.K.R.		

8⁴² water ht = 129.5 cm.

9¹⁰ CR-1 .075 CR-2 1.81 crit. log N = 0.15

Temp K-3 1.647 mV Brown 40.8°C

9²⁴ C.R.#1 = 8.86 just crit log N = .2

C.R.#2 = .55

9²⁷ shut down.

9⁵⁰ Water dumped + pumped back = 39.8°C very little cooling

9⁵² Draining back thru pump -

Expr. 32-3	Time 10:30 AM	Date 12-10 1958
Purpose Dry Ice put in open end tubes to cool system		
Personnel:		

11³⁰ Water at 80 cm while cooling
Temp = 37 1/2°C

1³⁴ PM Water ht = 129.5 cm. Temp Brown 39°C
K-3 = 1.368 mV.

1⁴⁵ CR#1 = .08 just crit log N = .2

C.R.#2 = 1.95

33.9°C

1⁵⁰ #1 = 9.60 Crit log N = 0.2

#2 0.55

Temp = 1.368 mV

- 1st temp demand set at 35°C
 2nd K-3 = 1.400 mv = 35°C Brown - 35°C
 2nd PM CR#1 = 9.53 #2 0.55 Temp = 35°C
 3rd PM Ice cubes in 100# ground from cafeteria
 & dumped in tanks - temp of 70 cm water = 32°C

Expr. 32-4	Time 10 ³⁵ AM	Date 12-11 1958
Purpose run after cooling all night temp 22.5°		
Personnel: R.K.R. etc		

- 10⁵⁰ AM Water ht = 129.5' Cmi. Temp Brown = 27°C
 K-3 = 1.054
 11⁰⁷ CR#1 = 9.85
 C.R.#2 = 0.55 just crit. Log n = .2
 note: 9.85#1 slightly super in 150cm 9.80#1 slightly sub-
 11³² C.R.#1 = .08 just crit Log n = .2
 C.R.#2 = 2.03
 11³³ Shut down.

Expr. 32-5	Time 1 ⁵⁵ AM	Date 12-11 1958
Purpose Temp Run		
Personnel: D.F.C.R.K.R.		

- 1⁵⁵ PM Water ht = 129.5 Temp Brown = 26.5°C
 K-3 1.030

2 PM #1 10.78 #2 0.55 proc period 200. sec period.

$\frac{2:00}{2:09}$ C.R.#1 = 9.83 Sub Crit.
C.R.#2 = 0.55

$\frac{2:00}{2:14}$ C.R.#1 = 9.85 Sub Crit
C.R.#2 = 0.55

$\frac{2:14}{2:17}$ C.R.#1 = 9.91 just crit $\log \kappa = .14$
C.R.#2 = 0.55

$\frac{2:19}{2:20}$ C.R.#1 = .08 just crit $\log \kappa = .10$
C.R.#2 = 2.05 $\text{Temp} = 26.4^\circ\text{C}$ $\kappa-3 = 1.03/\text{MV}$
Brown

$\frac{2:20}{2:20}$ shut down.

Expt. 32-6	Time 2:00 AM	Date 12-11-1958
Purpose Temp Run.		
Personnel: D.C. R.K.R.		

2:40 PM Water ht = 129.5. Temp demand set for 30°C.

$\frac{3:10}{3:15}$ C.R.#1 = 10.75 proc period.
C.R.#2 = 0.55

$\frac{3:15}{3:21}$ C.R.#1 = 9.81 just crit 31°C Brown $\kappa_3 = 1.228$
C.R.#2 = 0.55 $\log \kappa = .2$

$\frac{3:21}{3:24}$ C.R.#1 = .08 just crit $\log \kappa = .12$
C.R.#2 = 2.05 Brown Temp = 31.2°C
 $\kappa-3 = 1.230$

$\frac{3:30}{3:31}$ shut down.

Expt. 33-1	Time 9:20 AM	Date 12-15 1958
Purpose: <i>Leaky Run</i> <i>(after changing water and water pump)</i>		
Personnel: <i>D.S.C. R.K. Reedy</i>		

9⁵⁵ AM water 130 cm K-3 = .0510 Brown = 14°C

K-1 = 48 cm $\times 10^{-10}$ log μ = .015

9⁴¹ C.R.#1 = 13.50 Log μ = .03 to .16

C.R.#2 = 0.55 *pow period* 80.36 cm 11.44 5.614/m

9⁵⁰ C.R.#1 = 11.47 just end Log μ = .16

2.03

C.R.#2 = 0.55

K-3 = .0510

Brown = 14°C

9⁵¹ C.R.#1 = 11.97

pow period Log μ = .16 to .5

C.R.#2 = .88

91.224 cm

10.44

10⁰⁰ AM C.R.#1 = 9.53 just end

Log μ = .5

9.4 5.1374/m

C.R.#2 = .88

10⁰¹ shut down. (Set temp demand to 65°C)

12³⁵ PM

Copious bubbles in tank (on metal surfaces) temp = 36°C

3⁴⁸ PM

Brown
temp 65°C K-3 = 2.665

Expt. 33-2	Time 4 ¹⁰ AM	Date 12-15-58
Purpose Temp Run after heating water to 65°C + holding for 1 hr (trying to stop)		
Personnel:		

- 4³⁰ PM Still some fine air bubbles on reactor surfaces -
- 4³⁰ C.R.#1 = 13.51 pos period $\log \eta = .18$ to .5
 C.R.#2 = 0.55 $K-3 = 2.667$
 Brown = 64.9°C
 91.2 sec
 10.44
- 4³² C.R.#1 = 11.64 just crit $\log \eta = .18$
 C.R.#2 = 0.55
- 4³⁶ C.R.#1 = 13.50 pos period $\log \eta = .18$ to .5
 C.R.#2 = 0.55 $K-3 = 2.667$
 Brown = 65.5°C
- 4³⁸ Shut down
- 4⁴⁵ Trying to drop temp about 10°C
- 5²⁴ Still air bubbles at 55°C so water dumped + pumped back to scavenge reactor surface
- 5³⁰ C.R.#1 = 13.50 pos period $\log \eta = .1$ to .4
 C.R.#2 = 0.55 $K-3 = 2.128$
 23.9 sec
 25.94
- 5³⁵ CR#1 = 9.28 } crit $\log \eta = 0.4$ $K-3 = 2.128$
 CR#2 = 0.55 } Brown 52.3°C
- 5³⁷ C.R.#1 = 11.64 pos period $\log \eta = .9$ to 1.2
 C.R.#2 = 0.55 $K-3 = 2.128$
 56.5 sec
 14.94
- 5³⁹ Shut down
- Note 6⁰⁰ temp 47.5°C. K-1 sealed while temp dropped (at 78 mm 10 x 10")
 K-3 = 4.930
- 6⁰⁵ C.R.#1 = 11.64 pos period $\log \eta = .1$ to .4
 C.R.#2 = 0.55 50 sec

6¹² C.R.#1 = 9.05 just crit $\log n = .5$
C.R.#2 = 0.55

6¹³ shut down. (Heat exchanger on.)

6⁵⁵ Brown = 40°C K-3 = 1.610

6⁵⁸ C.R.#1 = 11.65 $\log n = .05$ to .18
C.R.#2 = 0.55 pos period 45.6 sec = 171

7⁰⁵ C.R.#1 = 8.97 just crit $\log n = .18$
C.R.#2 = 0.55

7⁰⁶ shut down (Heat exchanger on)

7³² K-3 = 1.430 Brown = 35.5°C

7³⁶ C.R.#1 = 11.65 pos period $\log n = .02$ to .15
C.R.#2 = 0.55

7⁴⁰ C.R.#1 = 9.05 just crit. $\log n = .15$
C.R.#2 = 0.55

7⁴⁴ shut down (Heat exchanger on)

8²⁷ K-3 = 1.165 Brown = 30°C

8²⁹ C.R.#1 = 11.47 pos period $\log n = .05$
C.R.#2 = 0.55 ~~12.5 sec~~ 78.2 sec
~~12.2 sec~~ 11.6 sec

8³⁶ C.R.#1 = 9.36 just crit $\log n = .18$
C.R.#2 = 0.55

8³⁷ shut down (Heat exchanger on)

9⁰⁵ temp 25.2°C K-3 0.975 mV

9²⁵ CR-1 11.46 pos period ~~100 sec~~ 100 sec
CR-2 0.55 $\log n = .05$ to ~~100 sec~~ 9.6 sec


9³¹ C.R.#1 = 9.74 just crit $\log n = .2$
C.R.#2 = 0.55

9³⁸ shut down.

12-18-58

N

.259



Setup similar to Exp 25-3 (11-14-58)
 CR-1 = .08 to Cd plate put in clear there
 CR-2 = -.02 to 16.05 fuel slot & seal on table
 Safety = 17.20 (outs)

All Cd plates in same peripheral ring -
 & at least 1 fuel element apart -
 Upper section = 2 1/16" spacing from lower section center -
 Well is centered

Exp. 34-1	Time 11:45 AM	Date 12-18-1958
Purpose See above - plus more with styrofoam patch on bottom of sphere - this more is zero min - seal patch -		
Personnel:		

12³⁵ PM Water ht = 129.5 cm Temp Brown = 23°C
 Exp K-3 = 0.871
 Stirrer on (no heat)
 12⁴⁷ CR#1 = 9.98 just exit Log K = 0.17
 CR#2 = 16.05
 12⁵³ CR#1 = 9.921 just exit Log K = 0.15 Temp = Brown = 23°C
 CR#2 = 16.05 K-3 = 0.871
 12⁵⁷ Stirrer off - 1 min - then on no change -

Expt. 34-2	Time 3:55 AM	Date 12-18 1958
Purpose Styrofoam pellets 2" dia on bottom of 11 sphere - volume = 1,360 cm ³ in 1 cm depth field		
Personnel:		

9²⁵ PM Water ht = 123.5 cm Temp Brown = 23°
 CR #1 5.07" K-3 = 0.871
 CR #2 = 16.05" Critical at log N = 0.16

4³⁰⁻³⁵
 4^{5:45} CR-1 6.07 pro. print log N = 0.16 to 1.3
 #2 16.05

4^{5:45} CR-1 6.07 crit log N = 1.3
 CR-2 14.45

4^{5:55} CR-1 - 7.50 pro. print log N 1.3 to 1.9
 CR-2 - 14.45

5⁰⁵ CR-1 - 7.50 crit log N = 1.9
 CR-2 12.39

5⁰⁵ Temp K-3 = 0.871 MV Brown = 23°C
 CR-1 8.66 pro. print log N = .2 to 1.7
 CR-2 12.39

5¹⁵ CR-1 8.66 level log N = 1.7
 CR-2 10.75


CR-1 9.94 pro. print log N 0.2 - 1.8
 CR-2 10.75

5²⁵ PM CR-1 9.94 level log N 1.8
 CR-2 8.90

CR-1	CR-2	Kettley log #	d	LCRM	261
		print		print	d
5.07	16.05	—	—		
6.07	16.05	134.6 m	7.7	134.6 m	7.6 d
6.07	14.45	—	—		
7.50	14.45	78.2	11.6	80.3	11.3
7.50	12.39	—	—		
8.66	12.39	93.4	10.3	97.7	9.8
8.66	10.75	—	—		
9.94	10.75	82.5	11.4	80.3	11.3
9.94	8.90	—	—		4.0.0 d

Bubble worth = 41.0 d

Expt. 34-3 Time 9¹⁵ Date 12-19 1958
 Purpose Cd plate on outer surface of styrofoam
 Personnel: _____



Cd in 8 1/2" diam plate - folded to fit sphere radius -
 wgt Cd = 222.5 gms - 0.0476" thick.


9⁴⁵/_A 123 gm water 22.5°C

CR-1 15.04 100 print by N=0.07
 CR2 16.05 153 m 8.8 d

10⁰⁰ CR1 - 13.77 crit. by N = .07 n 20 d less than 34-2.1
 CR2 - 16.05 n 60 d less than 34-2

~~corrected~~
 34-2

Personnel:	
Purpose:	
Time	Date
AM	PM
198	
Expt. 34-4	Time 10 ⁴⁵ AM
Purpose	Date 12-19-1958
Personnel: RRR 29C	



11⁰⁴ 123cm water 22.5°C K-3 = 1871 mV

11⁰⁷ #1 13.77 pos. period log N .05 to 0.20

#2 16.05

11¹⁵ #1 11.47 } Coil log N = 0.20

#2 16.05

11¹⁶ #1 12.76 } pos. period log N .20 to 2.0

#2 16.05

11²⁰ #1 9.95 } neg. period log N 2.0 to

#2 16.05

#1 ~~13.77~~ print of p. 4

13.77 39.2 18.8 34.7 20.4

12.76 80.2 11.5 86.88 10.8

9.95 - ~~130~~ 130 15.5 - 130 15.5

by ~~neg~~ pos. period plate = ~~194~~ 194 diff between
outer face & inner face

neg period plate on inside to no plate = 15.5 d

" " plate on outside to no plate = ~~194~~ 160 d

plate motion measured = 19 d

Expt. 34-5	Time 8 ³⁰ AM	Date 12-22-1958
Purpose Styrofoam removed - Cd plate at surface of sphere		
Personnel: D.J.C. R.K.R.		

9¹⁵ Water ht = 129.5 cm Temp Brown = 21.9°C
K-3 = 0.820

9²² CR-1 13.77 *no print* 139.9 *in*
CR-2 16.05 7.74

9³⁵ CR-1 12.85 } Critical by N 0.2
CR-2 16.05 } ^{11.97}

9³⁹ shut down.

Expt. 34-6	Time 9 ⁵⁰ AM	Date 12-22-1958
Purpose Cd plate dropped to rest on loop - above fuel		
Personnel:		

10¹⁵ Water ht = 125 cm Temp Brown = 21.9°C
K-3 = 0.845

10²³ C.R. #1 = 16.59
C.R. #2 = 16.05 *sub crit.*

Expt. 34-7	Time 10 ³⁰ AM	Date 12-22-1958
Purpose N.E Cd plate removed		
Personnel: D.J.C. R.K.R.		

11⁰⁷ Water ht = 123 cm. Temp Brown = 21.9°C
K-3 = 0.845

11²⁰ C.R. #1 = 7.1²⁰ *just crit*
C.R. #2 = 16.05 *log 2.05*

11²⁵ shut down.

Expt. 34-8	Time 11 ³⁰ AM	Date 12-22 1958
Purpose Control blade making on legs		
Personnel: D.C. R.K.R.		

- 11⁵⁵ Water ht = 123 cm Temp Room = 22°C
X-3 = 0.895.
- 12⁰⁶ C.R.#1 = 8.55 just crit
C.R.#2 = 16.05 Log₁₀ n = .05
- 12⁰⁷ Shut down. Diff between plate and control plate is 11.7

Expt. 35-1	Time 9 ³⁰ AM	Date 12-24 1958
Purpose Styrofoam on Al ball all chewing		
To observe compare with 34-2		
(Cd plate in same position 2 plate)		
Personnel:		

- 8⁵⁵ Water ht = 123 cm Temp = 22.6°C
- 9⁰⁷ C.R.#1 = 2.85 just crit Log₁₀ n = .09
C.R.#2 = 16.05
- 9¹⁴ C.R.#1 = 5.07 just crit Log₁₀ n = .14
C.R.#2 = 13.00
- 16.5¢ more than Expt 34-2.
- 9¹⁵ C.R.#1 = 5.07 per period.
C.R.#2 = 16.05 52.2 cm 16 d

1-5-59

Cd plate moved into contact with fuel -
 6 gms Cd removed (slots) to make room
 for legs - Styrofoam in place - on bottom of Al. sphere -

Expr. 35-2	Time 05 AM	Date 1-5-59 1959
Purpose Cd plate in contact with fuel - Styrofoam in place, on bottom of Al. sphere		
Personnel: D. J. C. R. K. R.		

3:35 Water ht = 123 cm Temp = 23.2°C

3:49 C.R.#1 = 13.49
 C.R.#2 = 16.05
 just exit Log $\eta = .14$

3:50 shut down.

Expr. 35-3	Time 1:20 PM	Date 1-6 1959
Purpose Same Cd plate moved into contact with sphere - Styrofoam between fuel & sphere - in contact with fuel		
Personnel: D. J. C. R. K. R.		

1:58 Water ht = 123.5 cm Temp = 23.2°C

2:05 C.R.#1 = 11.31
 C.R.#2 = 16.05
 for period. 91.2 sec 10.4 d

2:18 C.R.#1 = 10.17
 C.R.#2 = 16.05
 just exit Log $\eta = .17$

2:21 C.R.#1 = 11.31
 C.R.#2 = 13.97
 just exit Log $\eta = .16$
 Log $\eta = .16$ to .6

2:23 C.R.#1 = 12.54
 C.R.#2 = 13.97
 for period. 89 sec 10.6 d

aver.

$$2^{27} \text{ C.R.} \#1 = 12.54 \text{ joint crit } \text{Log } n = .6$$

$$\text{C.R.} \#2 = 12.15$$

$$2^{27} \text{ C.R.} \#1 = 13.49 \text{ for period } \text{Log } n = .6 \text{ to } 2$$

$$\text{C.R.} \#2 = 12.15 \quad 130.5 \text{ m} - 7.9 \text{ d}$$

$$2^{34} \text{ C.R.} \#1 = 13.49 \text{ joint crit } \cdot \text{Log } n = 2$$

$$\text{C.R.} \#2 = 10.85$$

on dumping water - all inst rose - safety dropped

2⁴⁵ Water back at 123 m = source in

Safety withdrawn - to report Crit Cond

on dumping water - inst up - because of
removal of shielding -

Effect of moving C from fuel to cell thru sphere

$$\begin{array}{r} 10.4 \\ 10.6 \\ 7.9 \\ \hline = 28.9 \text{ d} \end{array}$$

Expt. 36-1	Time 11:45 AM	Date 1-7 1959
Purpose Al ball (12" dia) in center 3 3/16" opening between upper & lower section - Cd plate on No 1 and No 2 in same position as in Expt No 34-1.		
Personnel: D.F.C. R.K.R.		

11⁴⁵ AM Water ht = 123 cm Temp = 23.2 °C

11⁵³ C.R. #1 = 17.16 sub crit.

C.R. #2 = 16.05

1³⁰ PM Cd plate No 2 removed. (see Expt No 34-1)

Expt. 36-2	Time 1:40 AM	Date 1-7 1959
Purpose Same as Expt 36-1. But with Cd plate No 2 removed.		
Personnel: D.F.C. R.K.R.		

1⁴⁰ PM Water ht = 123 cm Temp = 23.2 °C

2⁰⁶ C.R. #1 = 9.75 just crit Log η = .14

C.R. #2 = 16.05

Expt. 37-1	Time 3:42 AM	Date 1-7 1959
Purpose Water between 12" Al sphere and fuel replaced by styrofoam - 3 3/16" opening - Cd plate No 2 replaced		
Personnel: D.F.C. R.K.R.		

3⁴³ PM C.R. #1 = 08 Water ht = 87.5 Log η = 0.02

C.R. #2 = 01 just crit.

Expt. 37-2	Time 3:50 AM	Date 1-7 1959
Purpose Same as 37-1. but with 2 more Cd plates added. 1 in S.W. corner and 1 in N.W. corner.		
Personnel: D.F.C. R.K.R.		

4⁰⁵ C.R. #1 = 08 Water ht = 93.8 Log η = 0.18
C.R. #2 = 01 just crit.

Expt.	37-3	Time	1 ³⁵ AM	PM	Date	1-8	1959
Purpose	More Cd strips added - total of 6 fixed strips now in T.S.R.						
Personnel:	RRR DK						

2¹⁷ PM water ht = 100.2 cm Temp = 23°C

C.R.#1 and C.R.#2 ~~5~~ in. just exit.

log₁₀ = 17.21

2⁴⁵ water ht = 109.5 cm

C.R.#1 and C.R.#2 in just exit.

log₁₀ in.

Expt.	37-4	Time	3 ³⁰ AM	PM	Date	1-8	1959
Purpose	3 strips of Cd only added (small amount) all slots must safety filled = 9 fixed plates						
Personnel:	RRR DK						

9⁰⁰ water ht = 123 cm Temp. 23°C

4¹⁶ C.R.#1 = 17.16 just exit log₁₀ = 2.06

C.R.#2 = 4.89

Expr. <u>37-5</u>	Time <u>9⁰⁵ AM</u>	Exp Date <u>1-9</u>	195 <u>9</u>
Purpose <u>Rpt 37-4 to calibrate Rad</u>			
Personnel: <u>D.C. RKR</u>			

269

9⁰⁵ water ht = 123.4 cm Temp = 22.5°C

9¹³ C.R.#1 = 17.16 for period Log n = .02 to .07
C.R.#2 = 6.00

9²⁰ C.R.#1 = 17.16 just exit Log n = .07
C.R.#2 = 4.50

9²⁴ C.R.#1 = 14.52 just exit Log n = .08
C.R.#2 = 6.00

9²⁵ C.R.#1 = 14.52 for period Log n = .08 to .23
C.R.#2 = 7.50

9³⁰ C.R.#1 = 12.98 just exit Log n = .24
C.R.#2 = 7.50

9³¹ C.R.#1 = 12.98 for period Log n = .24 to
C.R.#2 = 8.50

9⁴⁰ C.R.#1 = 11.33 just exit Log n = .7
C.R.#2 = 8.50

9⁴² C.R.#1 = 11.33 for period Log n = .7 to 2.5
C.R.#2 = 9.91

9⁵⁰ C.R.#1 = 10.36 just exit Log n = 2.5
C.R.#2 = 9.91

10⁰⁰ C.R.#1 = 10.36 for period Log n = .13 to .8
C.R.#2 = 10.50

10⁰⁶ C.R.#1 = 9.31 just exit Log n = .8
C.R.#2 = 10.50

10⁰⁹ C.R.#1 = 9.31 for period Log n = .8 to
C.R.#2 = 12.01

$$10^{22} \text{ C.R.}\#1 = 7.95 \quad \text{Log } n = 2$$

$$\text{C.R.}\#2 = 12.01 \quad \text{just exit}$$

$$10^{22} \text{ C.R.}\#1 = 7.95 \quad \text{pos period Log } n = 1.5 \text{ to } 1.6$$

$$\text{C.R.}\#2 = 13.51$$

$$10^{27} \text{ C.R.}\#1 = 6.78 \quad \text{just exit Log } n = .6$$

$$\text{C.R.}\#2 = 13.51$$

$$10^{29} \text{ C.R.}\#1 = 6.78 \quad \text{pos period Log } n = .6 \text{ to } 1.8$$

$$\text{C.R.}\#2 = 15.03$$

$$10^{32} \text{ C.R.}\#1 = 5.75 \quad \text{just exit Log } n = 1.8$$

$$\text{C.R.}\#2 = 15.03$$

$$10^{43} \text{ C.R.}\#1 = 5.75 \quad \text{pos period Log } n = 2 \text{ to } 2.5$$

$$\text{C.R.}\#2 = 16.05$$

$$10^{50} \text{ C.R.}\#1 = 5.21 \quad \text{just exit Log } n = 2$$

$$\text{C.R.}\#2 = 16.05$$

$$10^{52} \text{ C.R.}\#1 = .08 \quad \text{neg period}$$

$$\text{C.R.}\#2 = 16.05$$

$$11^{02} \text{ C.R.}\#1 = 17.16 \quad \text{pos period} \quad \text{water temp} = 22.5$$

$$\text{C.R.}\#2 = 7.00$$

$$11^{06} \text{ C.R.}\#1 = 17.16 \quad \text{just exit Log } n = 1.9$$

$$\text{C.R.}\#2 = 9.85$$

$$11^{07} \text{ C.R.}\#1 = 17.17 \quad \text{neg period}$$

$$\text{C.R.}\#2 = 0.0$$


Note: water gap of $1\frac{7}{16}$ " or diameter between styrofoam sections -

$$\text{Note - OD styrofoam w ball} = 18.35"$$

$$\text{OD " " w/out ball} = 17.25"$$

$$\text{OD of ball} = 12.25" \quad \frac{1.10"}{1.10"} \text{ diff}$$

Exp 37-5



	#1	#2		
0	17.16	6.00	95.7 m	9.84
	17.16	9.50	∅	
9.84	14.52	6.00	∅	
	14.52	7.50	91.2 m	10.44
20.2	12.48	7.50	∅	
	12.48	8.50	145.5 m	7.2
27.4	11.33	8.50	∅	
	11.33	9.41	165.3 m	7.5 6.5
33.9	10.36	9.41	∅	
	10.36	10.50	137. m	7.6
41.5	9.31	10.50	∅	
	9.31	12.01	100 m	10.6
52.1	7.95	12.01	∅	
60.9	7.95	13.51	113 m	8.8
↳	6.78	13.51	∅	
6	6.78	15.03	128 m	8.0
68.9	5.75	15.03	∅	
	5.75	16.05	260 m	4.4
73.3	5.21	16.05	∅	
20	0.08	16.05	-84.8	
	17.16	7.00	56.5 m	15.2
	17.17	4.90	∅	
	17.17	0.0	-121.8 m	17.84
Est worth	73.3		¢	
	20.0		±5¢	

38-1

Expt. 37-5	Time 10 ⁰⁰ AM	Date 1-13 1959
Purpose Similar to 37-4-5	Styrofoam hemisphere now fit closely to H ₁ sphere - 9 fixed plates of Al in neutron	
Personnel: D.F.C. R.K.R.		

11⁰⁰

102.5 cm Crit Rd #1 in 0.07 log K = 0.2
Rd #2 in 0.0

temp = 21.5°C

11¹²

113.2 cm Crit log K = 0.2
all Rds in encircling safety
in 7 cm of water more needed for
infinite reflected - in 10 & more -
12 rds in = 904 each = $\beta/0.08$

Excess reactivity = $\beta/10$
From #38-5 at 113.2 cm =
5 d ~~to~~ flooded
at 107.5 cm = 1.148 flood

Expt. 38-2	Time 1 ¹⁵ PM	Date 1-13 1959
Purpose Two styrofoam hemisphere 17.5" O.D. and 12" I.D. (Water void) 9 fixed plates of Al in.		
Personnel: D.F.C. R.K.R.		

1⁴⁰ water ht = 123.5 cm temp = 22°C

1⁴⁵ C.R.#1 = 17.18 sub-crit.

C.R.#2 = 16.05

Expr. 38-3	Time 1 ⁵⁰ AM	Date 1-13 1959
Purpose same as 38-2 but with only 5 ch. fixed plates in.		
Personnel: D.F.C. R.K.R.		

2¹³ 100 cm water crit $\log \eta = .011$
 #1 Rd at .05 #2 at 0.0
 9.7.8 sec = net crit

Expr. 38-4	Time 2 ²⁰ AM	Date 1-13 1959
Purpose same as 38-2, but with 7 ch. fixed plates in.		
Personnel: D.F.C. R.K.R.		

2⁴¹ PM Water ht = 123 cm temp = 22°C
 2⁵³ C.R.#1 = 17.16 just crit $\log \eta = .02$
 C.R.#2 = 5.09 7 plates vs 12 plates =

Expr. 38-5	Time 2 ⁵⁵ AM	Date 1-13 1959
Purpose same as 38-2, but with 6 1/2 ch. fixed plates in.		
Personnel: D.F.C. R.K.R.		

5 plates = 4.65
 plus .05
 4.70 less
 reaction

3¹⁰ Water ht = 123 cm temp = 22°C
 3¹⁸ C.R.#1 = .08 for period $\log \eta = .008$ to
 C.R.#2 = 16.03 192 sec 5.7 d
 3²⁵ C.R.#1 = .08 just crit $\log \eta = .02$
 C.R.#2 = 14.25
 3²⁶ C.R.#1 = 2.53 for period $\log \eta = .02$
 C.R.#2 = 14.25 115 sec 9.9
 3³¹ C.R.#1 = 2.53 just crit $\log \eta = .14$
 C.R.#2 = 12.19
 3³³ C.R.#1 = 4.89 for period $\log \eta = .14$
 C.R.#2 = 12.19
 over. 78.1 sec 11.6 d

3³⁷ C.R.#1 = 4.89 just exit $\log n = .5$
 C.R.#2 = ~~9.14~~ = 9.65

3⁴⁰ C.R.#1 = 11.95 just exit $\log n = .5$
 C.R.#2 = 00

3⁴⁵ C.R.#1 = 9.14 just exit $\log n = .4$
 C.R.#2 = 4.50

3⁴⁷ water drained to 113.3 cm = n 50
 C.R.#1 = 9.14 just exit $\log n = .4$
 C.R.#2 = 5.00

3⁵² water drained to 102.5 cm
 C.R.#1 = 16.01 just exit $\log n = .08$
 C.R.#2 = 16.05 = n 1.14

Expr. 39-1	Time 9 ⁰⁰ AM	Date 1-14 1959
Purpose 17 1/2" Styrofoam ball in reactor 9 fixed Cd plates in fuel slots		
Personnel: DFC RKR		

9⁴⁰ 95.1 cm water at 22.5°C
 Crit log N = .01 all Rhoin present safety -
 from previous exp = need 4 more fixed plates to
 flood system -

94.8 cm water Sub Critical -

Expr. 40-1	Time 10 ⁴⁰ AM	Date 1-15 1959
Purpose 2 1/2" Styrofoam with Al ball covered with 40 mil Cd - 9 fixed Cd plates in slots		
Personnel: DFC JWB CB		

Water Temp = 23 °C # 10 + 4
 H₂O ht. = 123 cm
~~to~~ # 1 control rod = 17.17
 # 2 " " = 16.05
 Log N = .001 Sub. crit.

Expr. 40-2	Time 11 ¹⁵ AM	Date 1-15 1959
Purpose Same as 40-1 with only 1 fixed plate in reactor		
Personnel: DFC JWB CB		

11³⁰ 92.5 cm Crit - #1 .08 log N = .01
 #2 .00

Expt. <u>40-3</u>	Time <u>11:30</u> AM	Date <u>11/15</u> 195 <u>9</u>
Purpose <u>Same as 40-1 except 6 fixed Cd plates in reactor</u>		
Personnel: <u>Cranin, Gilley</u>		

Rod #1 = 6.34

Rod #2 = 16.03

H₂O ht. = 123.5 cm

Log N = .02 Crit.

#3.98 poison more than ex 34-1

2-3-59

16.5" Al ball covered with boron plates
 in TSR - spacing between upper + lower shells
 = $3\frac{3}{16}$ " (uniform circular cavity of 17.5" —)
 No fixed Cd blades inserted —

Expr.	41-1	Time	2:04 PM	Date	2-3 1959
Purpose	see above —				
Personnel:	RKR etc				

3²⁵ AM Water ht 45"

Temp 22.5°C

3²⁷ #1 Rod 16.74 } out
 #2 " 16.03 } Sub Crit ~~out~~

Log N = 1.006

K-1 = 40 on 3×10^{-11}

Expr.	41-2	Time	10:00 AM	Date	2-9- 1959
Purpose	to remove half of boron plates removed from top section of Al spare				
Personnel:	D. C. R. K. R. P.				

3/4 of boron
on10²³ AM Water ht = 45"

Temp = 22.5°C

10²⁹ AM C.R.#1 = 16.71

just crit

Log N = 1.03

C.R.#2 = 11.8

K-1 = 6.5 on 10×10^{-11}

Expr. 41-3	Time 12 ⁴⁰ AM	Date 2-4 1959
Purpose: Grit Bonded clad exp - 1/2 boron in alternate segments removed 2 - Cd plates inserted		
Personnel: AKR DFC		

1⁰⁵ PM Water ht = 45" Temp 21.5°
 1¹⁸ PM C.R. #1 = 16.76 joint crit: Fog 1.03
 C.R. #2 = 12.20 K-1 = 58 cm 10 x 10⁻¹¹

Expr. 41-4	Time 2 ⁴⁰ AM	Date 2-4 1959
Purpose: all bond removed from 16.5" sphere - total of 6" fixed Cd plates inserted		
Personnel: AKR DFC		

Expr. 41-4	Time 2 ⁴⁵ AM	Date 2-4 1959
Purpose: all bond removed from 16.5" sphere - total of 6" fixed plate		
Personnel: AKR DFC		

3:26 Water ht = 33.2"
 all C.R. in joint crit.

Expr. 41-5	Time 3 ¹⁵ AM	Date 2-4 1959
Purpose: all bond removed from 16.5" sphere - total of 9 fixed plates in		
Personnel: AKR DFC		

3³² PM Water ht = 45.1" Temp = 22.5°
 3³⁷ PM C.R. #1 = 16.80 joint crit Fog 1.005
 C.R. #2 = 9.25

Expr. 42-1 Time AM Date 2-5 1957
 Purpose 16.5" Al ball with 1/2" styrofoam
around it - 9 fixed Cd blades
 Personnel: _____

Temp. 22.3 °C (#'s 4 & 10)

Water ht. = 45.03"

#1 Rod .07 #2 Rod 0.0 Safety
 run in from 16.60"
 to 12.80

log N .015 Crit

Check water drain time:

Drain for 1 min. Height decreased
 from 45.03 to 43.66

START-UP CHECK LIST

Equipment Checked by SK Personnel Check by SK
 Instrument and Safety Checked and Reset by SK
 "Soured Is" Checked by _____ Source No. M-43
 Emergency Stop Control Room Checked by SK
 Red Light OK by SK
 Start-Up OK'd by SK Time 9:50 AM Date 2-6 1957

Expr. 41-6 Time 9:50 AM Date 2-6 1957
 Purpose 1/4 of board plates on sphere
9 fixed blades
 Personnel: F.B.H. SK L.V.B.

¹⁵ Water ht. = 45" Temp = 22.5 °C
 10 AM C.R.#1 = 16.85 Log N = .001
 C.R.#2 = 16.05 sub crit

Expt.	41-7	Time	10 ³⁰ AM	Date	2-6	1959
Purpose	1/4" lead plates on sphere 6 fixed blades					
Personnel	RRR, D.F.C., I.D.C.					

11¹⁵ AM Water ht = 45" Temp = 22.5°C
 11³⁰ AM C.R. #1 = 16.83 just crit. Log $\eta = 0.025$
 C.R. #2 = 12.70

Expt.	43	Time	3 ⁵⁵ AM	Date	2-6	1959
Purpose	1/4" styrofoam around bell with lead plates on bell - dangles gaps (vertical) in styrofoam cover 6 blades in					
Personnel	RRR, D.F.C., D.F.C.					

2¹⁰ PM Water ht 52" Temp = 22.5°C
 2²¹ PM C.R. #1 = 16.85 sub crit.
 C.R. #2 = 16.05

Expt.	43-2	Time	2 ²¹ AM	Date	2-6	1959
Purpose	Same as above. Expt. #3. but with 2 fixed blades in					
Personnel	D.F.C., I.D.C., RRR					

2⁴⁵ PM Water ht = 45" Temp = 22.5°C
 2⁴⁷ PM C.R. #1 = 16.72 sub crit.
 C.R. #2 = 16.05

Expt. <u>43-3</u>	Time <u>2⁵⁰</u> AM	Date <u>2-6</u> 195 <u>9</u>
Purpose <u>All fused plates removed</u>		
<u>Same as Expt 42.</u>		
Personnel: _____		

20 Water ht = 45" Temp = 22.5°C
 23 C.R.#1 = 16.84 Sub Crit Log n = .003
 C.R.#2 = 16.03

STARTUP CHECK LIST	
Equipment Checked by <u>D.F.C. RKR</u>	Check by <u>RKR</u>
Instrument _____	_____
Source _____	_____
Emergency _____	No. <u>M-43</u>
Red Light _____	_____
Start-Up On _____	Date <u>2-9</u> 195 <u>9</u>

Expt. <u>43-4</u>	Time <u>1⁰⁰</u> PM	Date <u>2-9</u> 195 <u>9</u>
Purpose <u>1/4" styrofoam around ball with</u>		
<u>1/4" total, 1 bond removed, all from top</u>		
<u>of all sphere, all fused plates removed.</u>		
Personnel: <u>D.F.C. RKR</u>		

total of 5 bond plate removed.

17 PM Water ht = 45" Temp. 22.5°C
 21 PM C.R.#1 = 16.83 Log n = .006
 C.R.#2 = 16.05 Sub Crit.

Expt. <u>43-5</u>	Time <u>1⁵⁵</u> AM	Date <u>2-9</u> 195 <u>9</u>
Purpose <u>Same as Expt 43-4, but</u>		
<u>with 1 bond plate removed from</u>		
<u>bottom of all sphere, total of 6 bond plate removed.</u>		
Personnel: <u>D.F.C. RKR</u>		

20 PM Water ht = 45" Temp = 22.5°C
 21 PM C.R.#1 = 16.85 Sub Crit Log n = .012
 C.R.#2 = 16.05

START-UP CHECK LIST

Equipment Checked by DTC Personnel Check by SWD
 Instrument and Safeties Checked and Reset by DTC
 "Source In" Checked by DK Source No. M-43
 Emergency Equipment in Control Room Checked by DK
 Red Light On by _____ AM
 Start-Up OK'd by _____ Time _____ PM Date _____ 1959

Expt. 43-6 Time _____ AM
 PM Date 2-10 1959
 Purpose Total of 7 bond plates removed
5 from 2 bottom of sphere,
 Personnel: Cronin, Gilley

Temp = 22.5 °C 4 + 10 thermocouples

4:20 PM Rod 1 Rod 2 H₂O Log W
 16.83 16.01 45" 1028.035 sub. crit

START-UP CHECK LIST

Equipment Checked by RKR Personnel Check by RKR
 Instrument and Safeties Checked and Reset by DTC
 "Source In" Checked by RKR Source No. M-93
 Emergency Equipment in Control Room Checked by DTC
 Red Light On by RKR AM
 Start-Up OK'd by DTC RKR Time 9:20 PM Date 2-11 1959

Expt. 43-7 Time 9:20 AM
 PM Date 2-11 1959
 Purpose Total of 8 bond plates removed
5 from top, 3 from bottom
 Personnel: D.T.C. RKR. Fild.C.

9:49 AM Water = 45" Temp = 22.5 °C
9:59 AM C.R.#1 = 16.82 Log n = 0.025
 C.R.#2 = 9.50 just crit.

Expt. 44-1	Time 11 ⁵ AM	Date 2-11 1959
Purpose	8 loose plates off of ball (5 top - 3 bottom) no stop from 3 1/4" opening between supports	
Personnel:	R.K.R. etc	

note
4 fixed cd
plates in

11²⁹ AM Water ht = 95.1" Temp = 22.5°
 11³¹ AM C.R. #1 = 16.83 Log n = .0018
 C.R. #2 = 16.02 Sub Crit.

Expt. 44-2	Time 12 ³³ AM	Date 2-11 1959
Purpose	Same as above, but with only 2 fixed cd plates in.	
Personnel:	D.F.C. R.K.R. I.D.C.	

12⁵⁹ PM Water ht = 95" Temp = 22.5°
 1⁰⁹ PM C.R. #1 = 16.83 Log n = .006
 C.R. #2 = 16.02 Sub Crit.


Expt. 44-3	Time 1 ¹³ PM	Date 2-11 1959
Purpose	Same as above, but with out any fixed cd plates in.	
Personnel:	D.F.C. R.K.R. I.D.C.	

1³¹ PM Water ht = 95.9" Temp = 22.5°
 1³⁵ PM C.R. #1 = 12.20 just crit Log n = .02
 C.R. #2 = 0.0 (in)

Expt. 44-4	Time 2 ⁰⁰ AM	Date 2-11 1959
Purpose	5 plates off ball 2 top + 3 bottom essentially 14 total bars (3 1/4" opening see 41-2)	
Personnel:	D.F.C. R.K.R. I.D.C.	

20³⁰ PM 44.9" water 23°
 #1 Rod = 16.81 #2 Rod 16.03
 Barely Sub Crit with some out
 resp. in 400 sec

2-13-59



Expt. 45-1	Time 1 ⁰⁰ AM	Date 2-13 1959
Purpose: overlap effect of boron plate		
1/2 total boron on ball		
2 fine plates on		
Personnel: J.W.K. B.H.		

170

45.03" water 23°C
 CR#1 = 16.82 } log N = .007
 CR#2 = ~~16.03~~ 16.03 } Sub crit.

Expt. 45-2	Time 7 ¹⁰ AM	Date 2-13 1959
Purpose: same - no fine plates		
Personnel: D.F.C. R.R.V.		

2²⁶ PM Water ht = 46.9" Temp = 23°C
 2²⁹ PM C.R.#1 = 4.⁵³ } just crit log N = .03
 C.R.#2 = 0.0

#1 16.82 23.3°C 42" water


#2 ~~8.78~~ 8.49

log $\eta = 0.16$

η 25¢ more reactive than 46-1

11¹⁰/_A shut down -

Expt. 46-3	Time 1 ⁰⁰	Date 2-17 1959
Purpose see sketch		
Personnel: RKR Jfc		




41.6" water water temp = 22.5°C

1.10 PM C.R. #1 = 16.82 log $\eta = 0.02$

C.R. #2 = 0.25

η 50¢ more reactive than 46-2

Expt. 46-4	Time 9 ¹⁵ AM	Date 2-18 1959
Purpose see sketch		
Personnel: G.F.C. RKR		




Water ht = Temp = 23°C

9³⁰ AM 45.1"

9³⁹ AM C.R. #1 = 16.82 just cool

C.R. #2 = 6.12 log $\eta = 0.22$

Expt. 46-5 Time 10:10 AM Date 2-18 1959
 Purpose See sketch
 Personnel: BFC, L. Holland



BSR-II Boron Steel Rod
 This Region Same 46-4

Water Temp. 23.2°C

CR #1 16.85

CR #2 9.15

This is approximately 25% less critical than 46-4

Expt. 46-6 Time _____ AM Date _____ 1959
 Purpose Same as 46-5 with Cd plate same size as B₁₀ rod in same location
 Personnel: _____

Water Temp. 23.0°C

CR #1 16.82

CR #2 8.90

Crit. log $K = .02$

water = 44.7"

Expt. 46-7 Time 9:00 AM Date 2-18 1959
 Purpose see below
 Personnel: L. W. BFC

water = 44.7"
 22.5°C

Same as 46-4 except 50 g. Boron Plate

2 1/2" wide. Inserted 6" in top central element.

4/30


CR1 = 16.85% Critical log $K = .015$

CR2 = 9.77

n = 27% poison

289

Expr. 46-8	Time	AM	Date 2-19	1959
Purpose B-0 plate inserted thru center fuel to top of fuel plate				
Personnel: JH DHC				




Water Temp. 22.7°C Level: 42

CR # 1 - 16.85" } Log H at .02
CR # 2 - 13.8" }

n 554 poison

Expr. 47-1	Time 11:37	AM	Date 20 Feb	1959
Purpose				
Personnel:				

Radius 25-26 Plate
50gm Poison
Blade



Added fixed Cd blade.

Water Temp 22.3°C

Water Height 44.8 in

Styrafom
2" thick

Both rods out - subcritical

Removed fixed blade


CR # 1 16.83" out

CR # 2 3.00"

Expr. 47-2 Time 12:46 AM Date 26 Feb 1959
 Purpose _____
 Personnel: _____

Water Height 42.0 cm.
 CR # 1 12.25"
 CR # 2 - 0
 Log N .016
 diff between 47-1 & 47-2
 23¢ (47-2 more reactive)

Boron Plate
 50 gm.
 2"
 Styrofoam



Person
 Between Plates 28-29

Expr. 47-3 Time 11:40 AM Date 24 Feb 1959
 Purpose _____
 Personnel: JH JAC

Water Temp. 22.8°C
 Level - 43.5"

CR #1 16.83"
 CR #2 5.20"
 Source Out

Log Nat .02

Boron
 Two Plates Between
 25 & 26
 Arrangement as
 Above.

Expt.	47-4	Time	12:22 ^{PM}	Date	24 Feb 1959
Purpose	Same as 47-3 except one boron plate removed.				
Personnel:					

Water: Level 43.3" Temp 22.8°C

CR #1 12.50" } Source Out
 CR #2 0.0" } Log N

Expt.	47-5	Time	12:39 ^{PM}	Date	24 Feb 1959
Purpose	Same as 47-3 except removed both boron plates and added 1 cd blade				
Personnel:					

Water Level 43.5" Temp 22.8°C

CR #1 out - 16.83" } Source Out
 CR #2 8.10" } Log N .02


Expt.	47-6	Time	4 ^{PM}	Date	2-24 1959
Purpose	Report of 47-5 Except Cd blade has been removed.				
Personnel:					

Water Level 43.3 Temp.

C.R #1 4.78" } Log N .02
 CR #2 0.0" }

Expr. 48-1 Time 4⁰⁰ ^{AM} ~~PM~~ Date 2-25 1959
 Purpose _____
 Personnel: JMT DFC LN


7.5
 12.25
 5.25
 2.67
 2.42



Water Height. 43.8" Temp. 22.7°C
 Rod #1 10.0" } Source Out N \$3.15 excess
 Rod #2 0.0" } Log N at .02

Expr. 48-2 Time 11:30 ^{AM} ~~PM~~ Date 26 Feb 1959
 Purpose 2 fixed Cd plates
 Personnel: DFC, LBN

See page 295



Water Temp. 22.8°C
 Level 43.7" Five Boron Plastic Dishes ~8.5" diam.

Plates Wash
 ~3.55
 ~1.35%

Sub Crit by Nover = .005
 12:11P Removed One Fixed Cd. Blade

Rod #1 Out } Source Out \$1.30 excess
 Rod #2 9.5" } Log N .02 1.30

Expr. 48-3 Time 12:30 ^{AM} ~~PM~~ Date Feb. 26 1959
 Purpose Same as 48-2 except both Cd blades removed. - Calibration Point.
 Personnel: _____

See Report 295

3.15
 1.49
 1.66 plate wash
 1.2%

Water Level 43.7" Temp 22.8°C

CR #1 7.4" } Source Out
 CR #2 All In 0.0" } Log N - .02


Shows Excess 1.49
 1.09%

Expt. 48-3A	Time 4:11 ^{PM}	Date 26 Feb. 1959
Purpose Moved Boron Plates 48-3 1-1/4" Closed to fuel. - No fixed Cd.		
Personnel: DFC LBH		

Water Level 43.7" Temp. 22.8°C

CR #1 Out.

CR #2 12.90"



Expt. 48-4	Time 11:36 ^{AM}	Date 27 Feb. 1959
Purpose Same as Above 48-3 except spacing from alum. ball is 13/16"		
Personnel: DFC LBH		

Safety Out. Source In.

Water Temp 23°C Level 43.7"

CR #1 Out } Source Out

CR #2 4.2" } Log N .02

Expt. 48-5	Time 4:10 ^{PM}	Date 27 Feb. 1959
Purpose Removed All But Bottom Boron Plate from 48-4. Inserted 2 Fixed Cd Blades.		
Personnel: DFC LBH		

Safety Out. Source In.

Water Level 43.8" Temperature 23.0°C


CR #1 16.82"

CR #2 2.0"

See Page 296 Repeat

Expt. 49-1 Time 11:43 AM Date 2 Mar. 1959
 Purpose on Fixed Cd Blades
 Personnel: DFC L.B.H.

Water Level 123 cm. Temp. 23.1°C
 CR #1 16.83" Out } Source Out
 CR #2 2.25" } Log N .02



See 50 Page

See New Book 5062 Exp 51-1

Expt. 49-2 Time 3:55 AM Date 2 Mar. 1959
 Purpose Moved Boral; Spacing to Fuel 13/16"
 Otherwise Same as 49-1
 Personnel: DFC L.B.H.

Water Level 123 cm. Temp 23°C
 CR #1 16.25 } Source Out
 CR #2 0.0" } Log N .02

1/4 Spacers ~1" Boral 6 Boron dishes

Expt. 49-3 Time 4:40 AM Date 2 Mar. 1959
 Purpose Moved Boral; Spacing to Fuel 13/16"
 Otherwise Same as 49-1
 Personnel: DFC L.B.H.

Water Level 123 cm. Temp. 23°C
 #1 10.70 } Source Out
 #2 0.0 } Log N = .02

See Page

See Page 2

See
50-1
Page 296

Expr. 48-6 Time 5:10 PM Date 2 Mar. 1959
 Purpose See Run 48-5 - 2" ~~Depth~~
Boral 1/4" From Fuel
One Cd. Blade
 Personnel: DFC LBH

Water Level 123 cm Temp 23°C

#1 14.1 } Source Out
 #2 0.0 } Log N. .02

Expr. 48-7 Time 5:55 PM Date 2 Mar 1959
 Purpose Same as 48-6 - Except Added
2" Styrofoam Behind Boral.
 Personnel: DFC LBH

Water Level 123 cm.

Water Temp 23°C

#1 10.2 } Source Out
 #2 0.0 } Log N.

See
Page 292

Expr. 48-2 Time 11:30 AM Date 3 Mar. 1959
 Purpose Repeat Run
 Personnel: DFC LBH

Water Level 123 cm Temp. 23.2°C

CR#1 16.86 } Source Out
 CR#2 13.24 } Log N. .02

See Page
292

Expr. 48-3 Time 12:00 AM Date 3 Mar. 1959
 Purpose Repeat Run
 Personnel: DFC LBH

Water Level

Water Temp.

CR#1 11.02 #1 0.0

CR#2 0.0 #2 18.61

See Page 294

Expt.	49H	Time	4:15 ^{PM}	Date	3 Mar 1959
Purpose	Repeat				
Personnel	DPC LBH				

Water Level 123 cm. Temp. 23.2°C
 CR #1 16.83 } Source Out { CR #1 10.5
 CR #2 1.00 } Log N .02 { CR #2 9.3

Expt.	49-4	Time	4:55 ^{AM}	Date	3 Mar 1959
Purpose	Same as 49-1 But with 1 1/2" thick Styrofoam behind boron plastic				
Personnel					


Water level 123 cm. Temp. 23.2°C
 CR #1 14.38" } Source Out { CR #1 10.5
 CR #2 0.0 " } Log N .02 { CR #2 6.5

See 48-6 p 293

Expt.	50-1	Time	4:25 ^{AM}	Date	4 Mar 1959
Purpose	Also duplicates 48-6				
	Rod Calibration				
Personnel	DPC LBH				

Water Level 123 cm. Temp.
 CR #1 11.78 } Source Out Fixed Blade 180° From CR #1
 CR #2 0.0 } Log N 0.2
 Put Fixed Blade 30° C.C. From Safety Removed Blade 180° from CR #1
 CR #1 12.85 } Source Out
 CR #2 0.0

Exp 50-1
Exp 50-1



Exp 50-1

#1	#2	Safety	P	d	#2	#1	d	
11.78	0.0	16.60	∞	0				
12.85	0.0	16.60	60.9	14		0.06	0	
15.70	0.0	13.20	∞	0		3.10	8.4	
16.83	0.0	13.20	243.5	4.6		5.50	11.7	20.1
12.85	0.0	16.60	∞			8.06	13.1	33.2
12.85	2.0	16.60	132.6	7.8		10.20	11.7	44.9
11.79	2.0	16.60	∞			11.79	9.5	54.4
11.79	4.0	16.60	104.4	9.5	17.3	12.85	7.8	62.2
10.20	4.0	16.60	∞			15.70	14	76.2
10.20	6.0	16.60	78.3	11.7	29.0	16.83	4.6	80.8
8.06	6.0	16.60	∞					
8.06	8.0	16.60	67.4	13.1	42.1			
5.50	8.0	16.60	∞					
5.50	9.50	16.60	78.3	11.7	53.8			
3.12	9.50	16.60	∞					
0.06	10.65	16.60	∞					
3.10	10.65	16.60	119.5	8.4	62.2			
0.06	12.35	13.20		18.64	$\frac{15.6}{20.8}$			
0.06	14.00	13.20	74.0	12.4	76.6			
0.06	16.02	10.65	69.6	12.6	82.2			
					105.8			
		Safety 13.20 - 16.60 = 18.64						