

## **BOOK 118R**

*Notes:*

on spine: "No. 1773 Scott"  
on front "CA 8&9"

Blank pages: inside front cover sheet, 4-6, 96-98, 216-295, 297-300

page 16 has big graph paper taped

page 96 has 3 sheets stapled

page 187 has calendar sheet stapled (9/20/51)

pages 199, 202, 205, and 212 have one graph taped to each  
small sheet of paper between pages 202 and 203

page 208 has sheet stapled

page 212 also has 1 sheet of paper stapled (faded green ink, hard to read)

page 215 has 2 long graphs stapled

calendar sheet between pages 266 and 267 (10/16/51)

inside back cover sheet has 1 big graph stapled

backside of that sheet has 1 sheet stapled to it

*Scanned by:*

*Sheila Finch*

*RSICC /Oak Ridge National Lab.*

*May 8, 2001*

**RESTRICTED DATA**  
This document contains restricted data as defined in the Atomic Energy Act of 1946.

**SECRET** *CAF*  
**SECURITY INFORMATION**



This document consists of 313 pages.  
No. 1 of 1 copies, Series A.

*5-25-60*  
**Account Book**

**No. S 149**

NO UNITS

- Journal . . . . .
- Ledger, Single Entry . . . . .
- Ledger, Double Entry . . . . .
- Record Ruled (27)



Made in 150, 200 and 300 Pages

**CLASSIFICATION CANCELLED**  
DATE 5-27-60  
*Edgar J. Murphy*  
CO-ORDINATING ORGANIZATION DIRECTOR  
TO REORDER, OAK RIDGE NATIONAL LABORATORY  
RULING AND SPECIFY NUMBER  
AUTHORITY DERIVED BY AEC 5-14-47  
ON BACKBONE OF THIS BOOK. *EJM*

MADE IN U. S. A.

This document consists of 300 pages.  
No. 1 of 1 copies, Series A.

**SECRET**  
**SECURITY INFORMATION**

**RESTRICTED DATA**  
This document contains restricted data as defined in the Atomic Energy Act of 1946.

10-9-21

LABORATORY RECORDS  
1954



TECHNICAL INFORMATION CENTER  
Y-12 PLANT  
CARBIDE AND CARBON CHEMICALS COMPANY  
A DIVISION OF UNION CARBIDE AND CARBON CORPORATION  
OAK RIDGE, TENNESSEE



TECHNICAL INFORMATION CENTER  
Y-12 PLANT  
CARBIDE AND CARBON CHEMICALS COMPANY  
A DIVISION OF UNION CARBIDE AND CARBON CORPORATION  
P. O. BOX P  
OAK RIDGE, TENNESSEE



Notebook No. Y-NB-1773

Assigned to: A. D. Callahan  
Department: 3405  
Building: 9735  
Date: 8.14.52



SECRET  
SECURITY INFORMATION

Rod 1	<del>30.605</del>	30.595 <sup>10-13-58</sup>
Rod 2	34.945	
Rod A	35.396	
Rod B	<del>33.678</del>	33.580 <sup>10-13-58</sup>

Samples 5/8 al  
 1/2 al  
 Iron tube  
 A - Nickel Rod

SECRET  
SECURITY INFORMATION

SECRET  
SECURITY INFORMATION

SECRET  
SECURITY INFORMATION

Exp 1	Start-up	19
2.	Rod calibration	16
3.	Evaluation of aluminum fuel tube	61
4.	Calibration of ARE Regulation Rod	65
5.	Evaluation of pressure shell	
6.	Evaluation of fuel vs. radius.	
7.	Fuel tube vs. void importance	
8.	Foil activation vs power level.	
9.	Axial traverse. 13 bore (in) foils.	
10.		

Exp no.

CA-9

- 1 Initial Loading
- 2 To obtain criticality with central control rod.
- 3 Calibration of central control rod.
- 4 Danger Coef. at several radii of CA-8 type fuel element.
5. Foil irradiation
6. Danger Coef.
7. Calibration of ARE safety rod (207)
8. Danger Coef

SCOTT  
CALVIN

7  
8/15/52.

C.A. ~~A-8~~ 8    Expr. 1    Run 1  
 Sheet \_\_\_\_\_ Date 8/15 1952 Time 1:00 AM  
 PM  
 Purpose Initial loading

1:00P

Pi-Pa source v-1 in BCO assembly.  
 Background - Cd rods up, no fuel or reflector  
 MULTIPLICATION coolant in BCO -

Scaler	Bk/5 min.	BG/5 min.	Mult.	1/M
1	$(91 \times 16) + 15$ $(84 \times 16) + 2$	$(94 \times 16) + 3$	$(96 \times 16) + 11$	301.7 c/min - avg. Bg
2	$(1348 \times 16) + 13$ $(1244 \times 16) + 10$	$(334 \times 16) + 3$	$(3470 \times 16) + 8$	1121 c/min
3				

Loaded Safety Rod #2 - see diagram - (7 tubes)

4:05P

MULTIPLICATION

Scaler	c/5 min.	Bg/5 min.	Mult.	1/M
1	$(113 \times 16) + 9$ $(119 \times 16) + 10$	$(117 \times 16) + 9$	374.1 c/min	0.81
2	$(392 \times 16) + 9$	$(388 \times 16) + 12$	1250 c/min	0.90
3				

(Cd rod #1 probably in BCO)

4:35P Shut down. Channels D & C showed decrease as rods were lifted.

8/16/52. 9A

Repeat count of 4:07P 8/15.

Conditions: Safety = 2 (loaded with fuel) up  
 " = 1 (C<sub>2</sub> only) up.


C <sub>1</sub>	C <sub>2</sub>	
$\frac{c}{\text{min}}$	$\frac{c}{\text{min}}$	
$(122 \times 16) + 4$	$(389)(16) + 4$	$c/5 \text{ min}$

Dropped Safety = 1 (C<sub>2</sub> only).

$(122 \times 16) + 4$	$(388 \times 16) + 11$
-----------------------	------------------------

Loading #2, i.e. 4 control rod tubes & central tube

11 AM



MULTIPLICATION				
Scaler	$\frac{c}{\text{min}}$	m.n. BG/	1 min.	Multi. 1/M
1	<del>122</del> (129 × 16) + 8 (130 × 16) + 7		301.7	415.6 0.73
2	(407 × 16) + 11 (404 × 16) + 5		1121	1299 0.86
3				



8/16/52

Third loading: Safety Rod #1, Tubes. (Total loading: 19 tubes)

MULTIPLICATION				
Scaler	c/	min. BG/	1 min. Att.	1/M
1	(141x16)+0	(142x16)+4	301.7	453.2/min 0.67
2	(399x16)+4	(403x16)+4	1121	1284 0.87
3				

8/17 - 5:30A - At least one leg of power to 9213 out from same time eve of 8/16 (probably 8-9PM based on temp. recorder Pen 108) until ~ 4AM 8/17 - we not notified until after restoration. (Some clocks only 20 min slow). C & E <sup>found</sup> tripped. No other apparent symptoms of trouble. D.C.

8/18 Repaired coupling Control rod A  
Coupling on Rod 2 slipped - repaired

10

0.504<sup>OD</sup> x 0.020 wall x 35.3125 long

16

8/19

Clean 5 reflector coolant tubes & Reels -  
 Install 5 coolant tubes as follows -

	Tube #	Gross	Position net	TUBE/Pos.	gross	net
1.952	1 = 5-11	340	191			
1.911	2 = 4-10	340	187	24 = 1-3	342	193 1.972
1.957	3 = 4-9	343.5	192.5	25 = 12-9*	346	194 1.983
1.952	4 = 3-8	345	194.0	26 = 2-2	347	193 1.972
1.983	5 = 3-9	347	194.0	27 = 13-2	338	189 1.932
1.947	6 = 2-8	343.5	190.5	28 = 5-2	342	188 1.924
1.972	7 = 2-7	347	193	29 = 4-8	343	191 1.952
1.942	8 = 3-7	342	190	30 = 14-2	342	189 1.932
1.942	9 = 2-6	341	190	31 = 15-4	344	191 1.952
1.952	10 = 2-5	345	191	32 = 8-1	347	194 1.983
1.911	11 = 2-4	340	187	33 = 8-12	342	190 1.942
1.972	12 = 3-6	346	193	34 = 9-13	346	192 1.962
1.962	13 = 3-4	345	192	35 = 11-10	348	194 1.983
1.942	14 = 3-3	343	190	36 = 5-1	348	194 1.983
1.932	15 = 13-8	342	189	37 = 14-3	344	192 1.962
1.942	16 = 13-9	345	190	38 = 12-1	346	193 1.972
1.983	17 = 13-7	348	194	39 = 12-3	340	189 1.932
1.952	18 = 13-4	344	191	40 = 7-13	342	190 1.942
1.942	19 = 1-4	344	190	41 = 4-11	345	192 1.962
1.932	20 = 3-2	343	189	42 = 8-13*	344	191 1.952
1.924	21 = 13-3	341	188	43 = 15-3	343	190 1.942
	22 = 4-2			44 = 7-12	341	190 1.942
1.942	23 = 4-1	343	190	45 = 12-2	343	190 1.942

16.387  $\frac{cc}{cm^3}$

Vol of tube = 97.847 cu. cc

	Tube / Pos	Shoes	net	
	46 = 14-8	338	189	1.932
	47 = 14-6	341	189	1.932
X	48 = 14-4	342	190	1.942
	49 = 5-12	342	190	1.942
1.972	50 = 14-5	344	190	1.942
1.983	51 = 11-12	342	190	1.942
1.972	52 = 11-1	340	190	1.942
1.932	53 = 12-10	338	189	1.932
1.924	54 = 10-3	343	188	1.924
1.952	55 = 9-3	342	189	1.932
1.932	56 = 11-12	340	190	1.942
1.952	57 = 9-12	343	191	1.952
1.983	58 = 10-12	342	189	1.932
1.942	59 = 11-11*	342	190	1.942
1.962	60 = 12-11	343	192	1.962
1.983	61 = 6-12	344	191	1.952
1.983	62 = 10-2	342	192	1.962
1.962	63 = 9-2	344	191	1.952
1.972	64 = 6-2	345	192	1.962
1.932	65 =	346	194	1.983
1.942	66 = 7-2	342	191	1.952
1.962	67 = 7-3			

65  $\frac{126.72}{1.950}$  Average

Ret- added with 4' fast loading -

\* Tube is up-side down because of bulged end.

1.942  
1.942  
1.942

12

8/20/52

Scott

ELLIS

CALLIHAN

INSTRUMENT CHECK					
Time	8:30 AM		Source PB 267		
	PM				
	Channel				
	A	B	C	D	E
Range	10 <sup>1000</sup>		10 <sup>-18</sup>	10 <sup>1000</sup>	2001
Source Dist.	2'	OK	15"	5"	6"
% F.S. Trip	50		95	30	40
	Counts 102 OK				

Repeat of count of 811c after adding coolant tubes -

MULTIPLICATION				
Scaler	c/5	m	35/11'	Mult. 1/M
1	(132116) + 14	[(124116) + 11]	302	422 0.715
2	(384116) + 11	(387116) + 6	1121	1235 0.91
3				

Fourth loading: Removed pipe structure - added nine coolant tubes + 9 fuel tubes -  
 Total loading - 28 tubes. (~ 5.8 # = 2.6 kg)

13  
8/20-

MULTIPLICATION				
Scaler	c/	min. BG/	min.	Mult. 1/M
1	$189 \times 6) + 10$ $184 \times 6) + 6$ $446 + 10$		30	$598 \frac{c}{min}$ <u>0.51</u>
2	$439 \times 6) + 15$		<del>1121</del> 1419	<u>0.79</u> <u>0.87</u>
3				

5" loading - 8 tubes - total of 36 ( $\approx 7.5" = 3.4 \text{ kg}$ )

MULTIPLICATION				
Scaler	c/	min. BG/	min.	Mult. 1/M
1	$387 + 1$ $361 + 0$		302	$2$ <u>0.24</u>
2	$518 + 13$ $510 + 11$		$1121$ $79$	<u>0.68</u>
3				

6" loading 6 tubes - total of 42 ( $\approx 8.7" = 3.95 \text{ kg}$ )

MULTIPLICATION				
Scaler	c/	min. BG/	min.	Mult. 1/M
1	$382$ $399 + 4$			<u>0.23</u>
2	<del>544</del> $582$ $588 + 1$			<u>0.60</u>
3				

8/20/52 7" loading - 8 tubes - Total 50

MULTIPLICATION			
Scaler	c/ <u>5</u> min.	BG/ <u>1</u> min.	Mult. 1/M
1	$696 \times 16$ <u>670</u>	302	$\frac{146}{146}$ <del>146</del>
2	$803 \times 16$ <u>796</u>	1121	$\frac{435}{435}$ <del>435</del>
3	_____	_____	_____

8" Loading - 7 tubes Total 57

MULTIPLICATION			
Scaler	c/ <u>5</u> min.	BG/ <u>1</u> min.	Mult. 1/M
1	$553 \times 64 + 22$ <u>526 \times 64 + 54</u>	302	0.04
2	$494 \times 64 + 44$ <u>482 \times 64 + 40</u>	1121	0.18
3	_____	_____	_____

15  
8/21/52  
Scott  
Callihan

9" loading - 4 tubes - Total 61  
( $\sim 12.6^{\circ} = 5.75 \text{ kg}$ )

INSTRUMENT CHECK					
Time: <u>7</u>	AM	Source: <u>PB267</u>			
	PM	Channel			
Range	A	B	C	D	E
	$\frac{10}{1000}$		$10^{-16}$	$\frac{10}{1000}$	900V
Source Dist:	<u>2'</u>	OK	<u>16"</u>	<u>5'</u>	<u>2"</u>
% F.S. Trip	<u>40</u>		<u>100<sup>+</sup></u>	<u>25</u>	<u>100</u>
<u>Constants 1+2 OK</u>					

NOT CRITICAL-

10" Loading - 3 tubes Total 64  
( $\sim 13.216 = 6 \text{ kg}$ )

CRITICAL POSITIONS			<u>8 AM 8/21/52</u>	
CA <u>8A</u>	Expr. <u>1</u>	Run <u>1</u>		
Table Pos.	L	T	R	
Control Rod	Channel			
<u>1A</u> <u>14.295</u>	A	<u>83 x 100 / 100</u>		
<u>B</u> <u>In</u>	B	<u>0.0022</u>		
<u>1</u> <u>0.070 (In)</u>	C	<u>3.5 x 5.6 x 10<sup>-10</sup></u>		
<u>2</u> <u>In</u>	D	<u>67 x 1000 / 50</u>		
	E	<u>1.4 @ 900v</u>		
Tim Crit. <u>8:00</u>	AM	Duration <u>17</u>	min.	

16

8/21/52

Approximate control rod reactivity measurement —

Raised Rod A from 14.295 → 13.995  
B<sub>i</sub> increased from 0.0022 → 0.006

CRITICAL POSITIONS	
C.A. <del>1</del> 8	Exp. 2 Run 1
Table Pos.	I T P
Control Rod	Channel
A 14.275	A 50 x 1000 / 50
B In	B 0.006
3 Infinite Cam	C 5.0 x 2.5 x 10 <sup>-10</sup>
4	D 89 x 1000 / 100
	E 4.4 @ 900V.
Tim Crit. 8:25	AM PM Duration 8 min.

In the above period measurement Rod A consisted of two fuel tubes —



Page 16

CA - A-1 Eq 2 Run 1 Strips  
ROD A  
Raises 14.295" → 13.995"

$$\frac{L_B}{N} = 170 \times 2.17 = 368.9 \text{ sec}$$


$$N_L = 3.2 \text{ } \phi \text{ for } 0.3" \text{ depth.}$$

$$= 10.7 \text{ c/inch}$$

0000 00 00

0000 00 00

0000 00 00



17.0 dec

1

2

One fuel tube was removed from Rod A is was<sup>re</sup> inserted in the original position being supported by three S.S. plate (#72 in 9-8) #74 in 9-7 on mechanism

C.A. ~~A-8~~ Expr. 1 Run 2  
 Sheet \_\_\_\_\_ Date 8/21 1952 Time 2:46 AM  
 Purpose To go critical with Rod A having only <sup>one</sup> fuel tube.

CRITICAL POSITIONS

C.A. ~~A-8~~ Expr. 1 Run 2  
 Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
1. 0.075	A. 64 x 1000 / 25
2. 99.950	B. 0.0035
A. 22.890	C. 2.9 x 2.5 x 10 <sup>-10</sup>
B. 99.96	D. 53 x 1000 / 100
	E. 2.4 @ 900v

Tim Crit. 3:20 AM PM Duration \_\_\_\_\_ min.

18

8/21/52

Remove <sup>Tube</sup> Rod 64 from position 3-5  
Total loading 63 tubes -

CRITICAL POSITIONS

C.A. ~~A~~ 8    Expr. 1    Run 3

Table Pos. \_\_\_\_\_

Control Rod	Channel
1 0.075	A 5.5 x 100 / 200
2 99.948	B 0.003
A 15.655	C 2.3 x 2.5 x 10 <sup>-10</sup>
B <del>99.96</del> 99.956	D 4.5 x 1000 / 100
	E 2.0 @ 900V

Tim Crit. 4.00 ~~PM~~ Duration 8 min.

8/22/52

Remove tube 56 from position 13-6  
Total loading 62 tubes ←

C.A. ~~A~~ 8    Expr. 1    Run 4

Sheet \_\_\_\_\_ Date 8/22 1952 Time \_\_\_\_\_ AM  
-PM

Purpose Continue geometry improvement

\_\_\_\_\_

\_\_\_\_\_

19  
8/24/52

### INSTRUMENT CHECK

Time	8:45 AM PM	Source	PB 267				
		Channel	A	B	C <sup>-10</sup>	D	E
Range			10/1000	1	10	19/1000	900V
Source Dist.			18" OK	1'	5"	6"	
% F.S. Trip			45	90	25	90	
	Counts 152 OK						

### CRITICAL POSITIONS

C.A.	A-18	Expr.	1	Run	4
Table Pos.		L	T	R	
	Control Rod			Channel	
1	0.070	A		46 x 1000 / 100	
2	99.950	B		<del>82 x 10</del> 0.015	
A	<del>0.007</del> 0.7780	C		4.4 x 5 x 10 <sup>-10</sup>	
B	99.963	D		62 x 1000 / 200	
		E		1.6 @ 750V	
Tim Crit.	9:10	AM PM		Duration	10 min.

8/2/52

Filled all strips (probably 25) 30" x 3/4" x 1/16"  
between Bed blocks and incomb  
sheet to tighten assembly.

CRITICAL POSITIONS

C.A. ~~A-78~~    Expr. 1    Run. 5

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
1 <u>0.072</u>	A <u>36</u> <u>100/500</u>
2 <u>999.950</u>	B <u>.005</u>
A <u>10.700</u>	C <u>3.4</u> <u>2.5 x 10<sup>-10</sup></u>
B <u>999.959</u>	D <u>68</u> <u>100/1000</u>
	E <u>.005</u> <u>3.3</u> <u>900V</u>

Tim Crit. 1:03    <sup>AMP</sup> PM    Duration 12 min.

Raised level  
to check  
reproducibility  
of rod position.

CRITICAL POSITIONS

C.A. ~~A-78~~    Expr. 1    Run. 5a

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
1 <u>0.073</u>	A <u>58</u> <u>100/1000</u>
2 <u>999.950</u>	B <u>.021</u>
A <u>10.696</u>	C <u>5.5</u> <u>5 x 10<sup>-10</sup></u>
B <u>999.958</u>	D <u>45</u> <u>1000/500</u>
	E <u>6.2</u> <u>840V</u>

Temp. 1.358 MV

Tim Crit. 1:23    <sup>AMP</sup> PM    Duration \_\_\_\_\_ min.

See Log N Chart

Withdraw rod A one in. (from 10.696 to 11.696) inserted source and allowed reactor to drift to equilibrium  $B_1 = .005$

Withdraw source and allowed reactor drift down.

Reached equilibrium  $B_1$  at .0004

3:25 P.M.

See Log N Chart

Removed tube No 25 from 13-5.

Total loading 61 tubes.

System not critical with all rods in.  
 $B_1 = .0015$

22  
8-25-52

INSTRUMENT CHECK					
Time	11-25	AM	Source	PB 267	
		PM			
	Channel				
	A	B	C	D	E
Range	$10^4$		$10^{10}$	$10^4$	900V
Source Dist.	16"	OK	14"	5'	6"
% F.S. Trip	40		100 <sup>+</sup>	30	100 <sup>+</sup>
	Counts 142 OK				

CA	A-8	Exp.	2	Run	2
Sheet		Date	8-25		AM
					PM
Purpose	T. Get Reaction Ready for Control Rod Calibration				

Replaced tubes 64 in 3-5  
56 in 13-6  
25 in 13-5

Added tubes 20 in 6-4  
24 in 11-3

Tube total now 66.



CRITICAL POSITIONS			
C.A.	<del>A-18</del>	Expr.	2 Run 2
Table Pos.		L	T R
	Control Rod		Channel
1	0.075	A	49 m $\frac{1000}{25}$
2	99.947	B	.003
A	37.106	C	4.6 m $10^{-10}$
B	13.540	D	74 m $\frac{1000}{50}$
		E	1.4 m 900V
Tim Crit.	1:05	AM PM	Duration 10 min.

P.O.T. rod A in and sealed off with rod B

CRITICAL POSITIONS			
C.A.	<del>A-18</del>	Expr.	2 Run 3
Table Pos.		L	T R
	Control Rod		Channel
1	0.078	A	52 m $\frac{1000}{25}$
2	99.947	B	.0031
A	0.017	C	5.0 $10^{-10}$
B	73.786	D	81 $\frac{1000}{50}$
		E	1.4 m 900V
Tim Crit.	1:15	AM PM	Duration 35 min.

1:10 P

Temp

1.4347 MV

24

8/25/52

Inserted rod B from 23.246 to 22.740 and levelled with A

CRITICAL POSITIONS		
CA	A-18	Exp. 2 Run 4'
Table Pos. _____		
	Control Rod	Channel
1	Saw	* 63 $\frac{1000}{100}$
2	Saw	B. 022
A	5.805	C 4.7 $5 \times 10^{10}$
B	22.742	D 45 $\frac{1000}{500}$
		E 2.7 $750 \checkmark$
Time Crit.	1:50	AM PM Duration 23 min.

with draw rod B from 22.742 to 24 inch to reduce level

~~with draw rod~~ Levelled with rod B.

25  
9/25/52

CRITICAL POSITIONS

C.A. ~~#18~~ 8    Expr. 2    Run 5

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
1 <u>Same</u>	A <u>40</u> <u>1000/25</u>
2 <u>Same</u>	B <u>.0021</u>
<u>#</u> <u>5.815</u> <u>5.805</u>	C <u>.5</u> <u>5x10<sup>-10</sup></u>
<u>0</u> <u>22.845</u>	D <u>57</u> <u>1000/50</u>
	E <u>1.0 at 900V</u>

Tim Crit. 2:13 ~~2:28~~ <sup>AM</sup> PM    Duration 33 ~~22~~ min.

I mounted B for positive period and level with H

Temp  
3:00 P  
1.35°C

CRITICAL POSITIONS

C.A. 8 ~~#18~~ #1    Expr. 2    Run 6

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
1 <u>Sam</u>	A <u>58</u> <u>1000/100</u>
2 <u>Sam</u>	B <u>.022</u>
<u>A</u> <u>7.140</u> <u>7.410</u>	C <u>4.3</u> <u>5x10<sup>-10</sup></u>
<u>B</u> <u>22.350</u>	D <u>42</u> <u>1000/500</u>
	E <u>1.0</u> <u>750V</u>

Tim Crit. 2:45 <sup>AM</sup> PM    Duration 23 min.

Reduced level with B and then leveled with B

CRITICAL POSITIONS		
C.A. <u>A=18</u>	Expr. <u>2</u>	Run <u>7</u>
Table Pos. _____		
Control Rod		Channel
1 <u>same</u>	A <u>35</u>	<u>1000/25</u>
2 <u>same</u>	B <u>.0018</u>	
A <u>7.410</u>	C <u>.4</u>	<u><math>5 \times 10^{-10}</math></u>
B <u>22.785</u>	D <u>48</u>	<u>1000/50</u>
	E <u>.9</u>	<u>at 900 V</u>
Tim Crit. <u>3:08 PM</u> Duration <u>24</u> min.		

Inserted rod B to 21.985 for positive period leveled with A.

CRITICAL POSITIONS		
C.A. <u>A=18</u>	Expr. <u>2</u>	Run <u>8</u>
Table Pos. _____		
Control Rod		Channel
1 <u>same</u>	A <u>55</u>	<u>1000/100</u>
2 <u>same</u>	B <u>.02</u>	
A <u>8.697</u>	C <u>4.0</u>	<u><math>5 \times 10^{-10}</math></u>
B <u>21.985</u>	D <u>40</u>	<u>1000/500</u>
	E <u>2.0</u>	<u>750 V</u>
Tim Crit. <u>3:32 PM</u> Duration <u>23</u> min.		

Reduce level with B and then leveled with B.

CRITICAL POSITIONS			
C.A.	<del>A=18</del>	Expr.	2 Run 9
Table Pos.		L	T R
	Control Rod		Channel
1	same	A 36	1000/25
2	same	B .0018	
A	8.697	C	4 x 5x10 <sup>-10</sup>
B	22.180	D	49 1000/50
		E	1.0 on 900V
Tim Crit.	3:55	<del>AM</del> PM	Duration 13 min.

Inserted rod B to 21.680 for positive period, leveled with A.

4:20 P

Temp.

1.3435 mV

CRITICAL POSITIONS			
C.A.	<del>A=18</del>	Expr.	2 Run 10
Table Pos.		L	T R
	Control Rod		Channel
1	same	A 56	1000/100
2		B .02	
A	9.616	C	4.1 5x10 <sup>-10</sup>
B	21.680	D	40 1000/500
		E	1.8 750 ✓
Tim Crit.	4:08	<del>AM</del> PM	Duration 27 min.

INSTRUMENT CHECK					
Time	9:00 AM		Source PB267		
	<del>PM</del>				
	Channel				
	A	B	C	D	E
Range	$\frac{10}{100}$	1	$10^{-10}$	$10/100$	900V
Source Dist.	18"	OK	6"	5'	6"
% F.S. Trip	40	1	100 <sup>+</sup>	18	100 <sup>+</sup>
	Compta 152 OK				

C.A.	AST 8	Expr.	2	Cur	11
Sheet		Date	8/26/52		11:00 AM
					<del>PM</del>
Purpose	Continuation of Control rod A Calibration.				

29  
8/26/52

CRITICAL POSITIONS			
CA	<del>A</del> 8	Expr.	2 Run 11
Table Pos.		L	T R
	Control Rod		Channel
1	99.945	A	42 $1000/25$
2	99.945	B	.002
A	9.616	C	.5 $5 \times 10^{-10}$
B	21.697	D	.60 $1000/50$
		E	1.0 on 900V
Tim Crit.		11:15	AM PM Duration _____ min.

I inserted rod B to 21.2 to produce positive period. Level with Rod A.

Temp 11:25A  
1.319mR

CRITICAL POSITIONS			
CA	<del>A</del> 8	Expr.	2 Run 12
Table Pos.		L	T R
	Control Rod		Channel
1	99.945	A	63 $\times 1000/100$
2	99.945	B	0.02
A	10.940	C	4.7 $\times 5 \times 10^{-10}$
B	21.200	D	45 $\times 1000/500$
		E	2.2 @ 750V
Tim Crit.		11:33	AM PM Duration 11 min.

Lower level by withdrawing B to 24.

30  
8/2/52

Level by inserting B -

CRITICAL POSITIONS	
CA. <del>A-F</del> 8	Expr. <u>2</u> Run <u>13</u>
Table Pos. _____ I _____ T _____ R _____	
Control Rcd	Channel
1 <u>99.945</u>	A <u>9 x 1000/100</u>
2 <u>99.945</u>	B <u>0.0015</u>
A <u>10.940</u>	C <u>0.4 x 5 x 10<sup>-9</sup></u>
B <u>21.350</u>	D <u>47 x 1000/50</u>
	E <u>0.8 @ 900V</u>
Tim Crit. <u>11:56</u>	<del>AM</del> Duration <u>3</u> min.

Insert B to 20.8 to give + period

Level with A.

Temp.  
12:20 P  
1.326 mV

CRITICAL POSITIONS	
CA. <del>A-F</del> ✓	Expr. <u>2</u> Run <u>14</u>
Table Pos. _____ I _____ T _____ R _____	
Control Rcd	Channel
1 <u>99.945</u>	A <u>59 x 1000/100</u>
2 <u>99.945</u>	B <u>0.020</u>
A <u>11.850</u>	C <u>4.4 x 5 x 10<sup>-10</sup></u>
B <u>20.840</u>	D <u>43 x 1000/500</u>
	E <u>1.9 @ 750V</u>
Tim Crit. <u>12:12</u>	<del>AM</del> Duration <u>8</u> min.



Lowered the level by withdrawing B and then leveled off with the same rod

31

CRITICAL POSITIONS			
C.A.	<del>A-F</del> 8	Expr.	2 Run 15
Table Pos.		L	T
	Control Rod		Channel
1		A	39 $\frac{1000}{25}$
2		B	.0019
A	11.848	C	0.4 $5 \times 10^{-10}$
B	20.940	D	55 $\frac{1000}{50}$
		E	0 750
Tim Crit.	12:20	AM	PM Duration 21 min.

Insert B to 20.30 to give positive signal  
Level with A

Temp  
1.3292

CRITICAL POSITIONS			
C.A.	<del>A-F</del> 8	Expr.	2 Run 16
Table Pos.		L	T
	Control Rod		Channel
	99.945	A	70 $\frac{1000}{100}$
	99.945	B	.024
A	13.143	C	5.4 $5 \times 10^{-10}$
B	20.300	D	51 $\frac{1000}{500}$
		E	2.5 on 750V
Tim Crit.	12:41	AM	PM Duration 18 min.

~~Withdraw~~ rod B to reduce level and leveled with B.

CRITICAL POSITIONS		
CA <del>A</del> 8	Expr. 2	Run 17
Table Pos. _____ L _____ T _____ R _____		
Control Rod	Channel	
1 same	A 36	1000/25
2 same	B .0018	
A 13.145	C .4	$5 \times 10^{-10}$
B 20.450	D 50	1000/50
	E 0	750V
Tim Crtt. 1:15	<del>AM</del> PM	Duration 7 min.

Insert rod B to 19.750 To produce positive period. Leveled Rod A.

1:25 P  
Temp  
1.3280

CRITICAL POSITIONS		
CA <del>A</del> 8	Expr. 2	Run 18
Table Pos. _____ L _____ T _____ R _____		
Control Rod	Channel	
1 same	A 65	1000/100
2 same	B .022	
A 14.425	C 4.8	$5 \times 10^{-10}$
B 19.750	D 47	1000/500
	E 2.3	750V
Tim Crtt. 1:22	<del>AM</del> PM	Duration 12 min.

withdrew rod B to reduce level and leveled with B. 33

CRITICAL POSITIONS			
C.A. <del>A-7</del> 8	Expr. 2	Run 19	
Table Pos.	L	T	R
Control Rod		Channel	
1. same	A 39	1000/25	
2. same	B .002		
A 14.425	C .4	5X10 <sup>-10</sup>	
B 19.887	D 56	1000/50	
	E 0	750V	
Tim Crit. <del>1:34</del> 1:34	PM	Duration 14	min.

I insert rod B to 19.385 to produce positive period, leveled rod A.

2:10 P.M.

Temp.  
1.3306

CRITICAL POSITIONS			
C.A. <del>A-7</del> 8	Expr. 2	Run 20	
Table Pos.	L	T	R
Control Rod		Channel	
1. same	A 57	1000/100	
2. same	B .02		
A 15.245	C 4.2	5X10 <sup>-10</sup>	
B 19.385	D 41	1000/500	
	E 2.0	750V	
Tim Crit. 1:48	<del>1:19</del> PM	Duration 24	min.

withdrew rod B to reduce level leveled with B.

CRITICAL POSITIONS		
<del>A 18</del>	Expr. <u>2</u>	Run <u>21</u>
Table Pos.	L	T R
Control Rod	Channel	
1. <u>same</u>	A <u>34</u>	<u>1000/25</u>
2. <u>same</u>	B <u>.0018</u>	
A <u>15.245</u>	C <u>2.3</u>	<u>10<sup>-10</sup></u>
B <u>19.560</u>	D <u>47</u>	<u>1000/50</u>
	E <u>.8</u>	<u>900V</u>
Tim Crit. <u>2:12</u>	<del>AM</del> PM	Duration <u>16</u> min.

Insert rod B to ~~19.75~~ 19.000 to produce a positive period. Leveled with rod A.

2:42 P.M.

Temp

1.3306

CRITICAL POSITIONS		
<del>A 18</del>	Expr. <u>2</u>	Run <u>22</u>
Table Pos.	L	T R
Control Rod	Channel	
1. <u>same</u>	A <u>58</u>	<u>1000/100</u>
2. <u>same</u>	B <u>.021</u>	
A <u>16.080</u>	C <u>4.3</u>	<u>5 x 10<sup>-10</sup></u>
B <u>19.000</u>	D <u>42</u>	<u>1000/500</u>
	E <u>1.8</u>	<u>750V</u>
Tim Crit. <u>2:28</u>	<del>AM</del> PM	Duration <u>24</u> min.

T.  
E  
1

withdrew rod B to reduce level  
 leveled with B.

CRITICAL POSITIONS

C.A. ~~A=18~~ <sup>8</sup>    Expr. 2    Run 23

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
1 <u>same</u>	A <u>36</u> <u>1000/25</u>
2 <u>same</u>	B <u>.0018</u>
A <u>16.090</u>	C <u>2.5</u> <u>10<sup>-10</sup></u>
B <u>19.130</u>	D <u>35</u> <u>1000/25</u>
	E <u>0.8</u> <u>900V</u>

Tim Crit. 2:52 <sup>AM</sup> PM    Duration 24 min.

I insert rod B to 19.50 To produce a  
 positive period. Level with rod A.

CRITICAL POSITIONS

C.A. ~~A=18~~ <sup>8</sup>    Expr. 2    Run 24

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
1 <u>same</u>	A <u>56</u> <u>1000/100</u>
2 <u>same</u>	B <u>0.020</u>
A <u>17.140</u>	C <u>4.2</u> <u>5x10<sup>-10</sup></u>
B <u>18.500</u>	D <u>43</u> <u>1000/500</u>
	E <u>1.9</u> <u>750V</u>

Tim Crit. 3:24 <sup>AM</sup> PM    Duration 12 min.

Temp.  
 3:32 P.M.  
 1.3311

withdrew rod B to reduce level leveled with B.

CRITICAL POSITIONS			
C.A. <del>A-1</del> 8	Expr. 2	Run 25	
Table Pos.	L	T	P
Control Rod	Channel		
1 same	A 36	1000/25	
2 same	B .0018		
A 17.140	C 0.8	5 x 10 <sup>-10</sup>	
B 18.652	D 50	1000/50	
	E 1.0	900V	
Tim. Crit. 8:36	AM	Duration 15	min.

Insert rod B to 18.150 to produce a positive period. Level with rod A

Temp 4:14 P.M.  
1.3293

CRITICAL POSITIONS			
C.A. <del>A-1</del> 8	Expr. 2	Run 26	
Table Pos.	L	T	P
Control Rod	Channel		
same	A 60	1000/100	
same	B .02		
A 17.894 17.905	C 4.4	5 x 10 <sup>-10</sup>	
B 18.150	D 43	1000/500	
	E 2.0	750V	
Tim. Crit. 8:51	AM	Duration 26	min.

37

8/27/57

INSTRUMENT CHECK

Time <sup>8:15</sup> 9:30 AM ~~PM~~ Source PB267

	Channel				
	A	B	C	D	E
Range	<u>10/1000</u>		<u>10<sup>-10</sup></u>	<u>10/1000</u>	<u>900V</u>
Source Dist.	<u>2'</u>	<u>OK</u>	<u>15"</u>	<u>5'</u>	<u>6"</u>
% F.S. Trip Counter 1 & 2 OK	<u>44</u>		<u>100+</u>	<u>18</u>	<u>100</u>

C.A. 8    Expr. 2    Run \_\_\_\_\_

Sheet \_\_\_\_\_    Date 8/27 195  Time \_\_\_\_\_ AM ~~PM~~

Purpose Continue Control Rod Calibration

\_\_\_\_\_

\_\_\_\_\_

8/27/50

withdrew rod B to reduce level  
 leveled with B.

10:46 AM  
 Temp  
 1.8299

CRITICAL POSITIONS			
C.A. <u>A-18</u>	Expr. <u>2</u>	Run <u>27</u>	
Table Pos. _____	L _____	T _____	R _____
Control Rod	Channel		
1 <u>99.945</u>	A <u>3.8</u>	<u>1000/25</u>	
2 <u>99.945</u>	B <u>.0018</u>		
A <u>17.905</u>	C <u>0.9</u>	<u>2.5 x 10<sup>-10</sup></u>	
B <u>18.170</u>	D <u>5.4</u>	<u>1000/50</u>	
	E <u>1.0</u>	<u>900V</u>	
Tim Crit. <u>10:36</u>	<del>PM</del> <sup>AM</sup>	Duration <u>10</u>	min.

Inserted Rod B to 17.670 to produce a  
 positive period. Leveled with Rod A

11:03 AM.  
 Temp  
 1.3306

CRITICAL POSITIONS			
C.A. <u>A-18</u>	Expr. <u>2</u>	Run <u>28</u>	
Table Pos. _____	L _____	T _____	R _____
Control Rod	Channel		
1 <u>same</u>	A <u>6.1</u>	<u>1000/100</u>	
2 <u>same</u>	B <u>.02</u>		
A <u>17.670</u> <u>18.890</u>	C <u>4.5</u>	<u>5 x 10<sup>-11</sup></u>	
B <u>17.670</u>	D <u>4.4</u>	<u>1000/500</u>	
	E <u>4.4</u>	<u>810V</u>	
Tim Crit. <u>10:46</u>	<del>PM</del> <sup>AM</sup>	Duration <u>21</u>	min.



withdrew rod B to reduce level  
 leveled with B.


CRITICAL POSITIONS

AT 8 Expr. 2 Run 29

Table Pos. \_\_\_\_\_ I \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod Channel

1 <u>same</u>	A <u>41</u>	<u>1000/25</u>
2 <u>same</u>	B <u>.0021</u>	
A <u>18.890</u>	C <u>0.5</u>	<u>5x10<sup>-10</sup></u>
B <u>17.762</u>	D <u>60</u>	<u>1000/50</u>
	E <u>.2</u>	<u>810V</u>

Tim Crit. 11:07  Duration 22 min.

Inserted rod B to 17.260 To produce a  
 positive period. Leveled with rod A

11:46A  
 Temp  
 1.3300


CRITICAL POSITIONS

AT 8 Expr. 2 Run 30

Table Pos. \_\_\_\_\_ I \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod Channel

1 <u>Saw</u>	A <u>63</u>	<u>1013/100</u>
2 <u>Saw</u>	B <u>.021</u>	
A <u>19.740</u>	C <u>4.7</u>	<u>5x10<sup>-10</sup></u>
B <u>17.260</u>	D <u>46</u>	<u>1013/500</u>
	E <u>4.6</u>	<u>910V</u>

Tim Crit. 11:29  Duration 27 min.

Withdraw B to lower the level  
Levelled with K

CRITICAL POSITIONS			
C.A.	<del>A-18</del>	Expr.	2 Run 31
Table Pos. _____			
	Control Rod	Channel	
1	Saw	A 37	$\frac{1000}{25}$
2	S	B .0018	
A	19.740	C 0.5	$5 \times 10^{-10}$
B	17.378	D 52	$\frac{1000}{50}$
		E 0.2	810 ✓
Tim Crit. <u>11:56</u> <sup>AM</sup> / <sub>PM</sub> Duration <u>31</u> min.			

Insert B to 16.88 to get positive period  
Level with rod H

12:47 PM  
Temp  
1.3360

CRITICAL POSITIONS			
C.A.	<del>A-18</del>	Expr.	2 Run 32
Table Pos. _____			
	Control Rod	Channel	
1	Saw	A 60	$\frac{1000}{100}$
2	S	B .02	
A	20.548	C 4.4	$5 \times 10^{-10}$
B	16.880	D 43	$\frac{1000}{500}$
		E 4.4	810 ✓
Tim Crit. <u>12:27</u> <sup>AM</sup> / <sub>PM</sub> Duration <u>20</u> min.			

Will draw  $\rho$  to lower the level  
sample with B

41

8/27/52

CRITICAL POSITIONS	
C.A. <u>18</u>	Expr. <u>2</u> Run <u>33</u>
Table Pos. _____ L _____ T _____ R _____	
Control Rod	Channel
1 <u>Same</u>	A <u>38 x 1000/25</u>
2 <u>Same</u>	B <u>0.002</u>
A <u>20.548</u>	C <u>0.4 x 5 x 10<sup>-10</sup></u>
B <u>16.940</u>	D <u>52 x 1000/50</u>
	E <u>0.2 @ 810v</u>
Tim Crit. <u>12:47</u> <del>AM</del> PM	Duration <u>26</u> min.

Insert B to ~16.6", + period, level with A

Temp 1:40P  
1.23/mv

CRITICAL POSITIONS	
C.A. <u>8</u>	Expr. <u>2</u> Run <u>34</u>
Table Pos. _____ L _____ T _____ R _____	
Control Rod	Channel
1 <u>Same</u>	A <u>64 x 1000/100</u>
2 <u>Same</u>	B <u>0.021</u>
A <u>21.217</u>	C <u>4.7 x 5 x 10<sup>-10</sup></u>
B <u>16.590</u>	D <u>46 x 1000/500</u>
	E <u>4.6 @ 810v</u>
Tim Crit. <u>1:26</u> <del>AM</del> PM	Duration <u>15</u> min.

42  
8/27/5-

Lower <sup>power</sup> level with B; Level with ~~B~~ A

CRITICAL POSITIONS	
C.A. <u>8</u>	Expr. <u>2</u> Run <u>35</u>
Table Pos. _____	L _____ T _____ R _____
Control Rod	Channel
1 <u>Same</u>	A <u>39 x 1000 / 25</u>
2 <u>Same</u>	B <u>0.00</u>
A <u>21.218</u>	C <u>0.4 x 5 x 10<sup>-10</sup></u>
B <u>16.707</u>	D <u>55 x 1000 / 50</u>
	E <u>0.2 @ 820V</u>
Tim Crit. <u>1:45</u>	<del>AM</del> PM Duration <u>17</u> min.

+ period by inserting B to ~ 16.1, level with A

CRITICAL POSITIONS	
C.A. <u>8</u>	Expr. <u>2</u> Run <u>36</u>
Table Pos. _____	L _____ T _____ R _____
Control Rod	Channel
1 <u>Same</u>	A <u>63 x 1000 / 100</u>
2 <u>Same</u>	B <u>0.021</u>
A <u>22.335</u>	C <u>4.6 x 5 x 10<sup>-10</sup></u>
B <u>16.106</u>	D <u>45 x 1000 / 500</u>
	E <u>4.5 @ 810V</u>
Tim Crit. <u>2:10</u>	<del>AM</del> PM Duration <u>12</u> min.

Lower ~~Raised~~ level with B; Flatten with A-B

43

CRITICAL POSITIONS	
CA	8
Expr.	✓
Run	37
Cable Pos.	L T R
Control Rod	Channel
1 Same	A $37 \times 1000/25$
2 Same	D $52 \times 1000/50$
A	22.337
B	0.002
B	16.228
E	$0.3 \times 5 \times 10^{-10}$
	E $0.2 @ 810^\circ$
Tim Crit.	2:27 <del>AM</del> PM
Duration	23 min.

+ period by inserting B to -15.6; Level with A.

CRITICAL POSITIONS	
CA	8
Expr.	✓
Run	38
Cable Pos.	L T R
Control Rod	Channel
1 Same	A $63 \times 1000/100$
2 Same	B 0.021
A	23.550
C	$4.6 \times 5 \times 10^{-10}$
B	15.630
D	$45 \times 1000/500$
E	$4.5 @ 810^\circ$
Tim Crit.	2:57 <del>AM</del> PM
Duration	13 min.

44

Deconv with B; level with B.

CRITICAL POSITIONS	
C.A. <u>8</u>	Expr. <u>2</u> Run <u>39</u>
Table Pos. _____	
Control Rod	Channel
1 <u>same</u>	A <u>26</u> $\frac{1000}{25}$
2 <u>same</u>	B <u>.0009</u>
A <u>23.550</u>	C <u>.8</u> $\times 10^{-10}$
B <u>15.878</u>	D <u>31</u> $\frac{1000}{50}$
	E <u>.4</u> at 900V
Tim Crit. <u>3:17</u>	<del>AM</del> PM Duration <u>17</u> min.

Temp at 3:25 P.M.  
1.33255Inserted B to 15.3 to produce positive period.  
Level with A.

CRITICAL POSITIONS	
C.A. <u>8</u>	Expr. <u>2</u> Run <u>40</u>
Table Pos. _____	
Control Rod	Channel
1 <u>same</u>	A <u>61</u> $\frac{1000}{100}$
2 <u>same</u>	B <u>.021</u>
A <u>24.423</u>	C <u>4.5</u> $5 \times 10^{-10}$
B <u>15.300</u>	D <u>44</u> $\frac{1000}{500}$
	E <u>4.4</u> 810V
Tim Crit. <u>3:34</u>	<del>AM</del> PM Duration <u>30</u> min.

Temp at 4:06 P.M.  
1.3327

INSTRUMENT CHECK

820  
Time 10:15 <sup>AM</sup>/<sub>PM</sub> Source PB 267

	Channel				
	A	B	C	D	E
Range	$\frac{10}{1000}$		$10^{-10}$	$\frac{10}{1000}$	900V
Source Dist.	<u>18" OK</u>		<u>8"</u>	<u>5'</u>	<u>3"</u>
% F.S. Trip	<u>45</u>		<u>100+</u>	<u>30</u>	<u>100+</u>

Counter 1+2-OK

C.A. 8    Expr. 2    Run 41

Sheet \_\_\_\_\_    Date 8/28/52 1952 Time 10:15 <sup>AM</sup>/<sub>PM</sub>

Purpose Continuation of rod calibration

\_\_\_\_\_

\_\_\_\_\_

8/28/52

CRITICAL POSITIONS		
C.A. <u>8</u>	Expr. <u>2</u>	Run <u>41</u>
Table Pos. _____ I _____ T _____ R _____		
Control Rod	Channel	
1 <u>99.947</u>	A <u>37</u>	<u>1000/25</u>
2 <u>99.945</u>	B <u>.002</u>	
A <u>24.423</u>	C <u>.4</u>	<u>5X10<sup>-10</sup></u>
B <u>15.344</u>	D <u>51</u>	<u>1000/50</u>
	E <u>.6</u>	<u>810V</u>
Tim Crit. <u>10:35</u> <sup>AM</sup> / <sub>PM</sub> Duration <u>13</u> min.		

*Insert rod B to 14.743 to produce a positive period. Level with A.*

CRITICAL POSITIONS		
C.A. <u>8</u>	Expr. <u>2</u>	Run <u>42</u>
Table Pos. _____ I _____ T _____ R _____		
Control Rod	Channel	
1 <u>same</u>	A <u>59</u>	<u>1000/100</u>
2 <u>same</u>	B <u>.02</u>	
A <u>26.164</u>	C <u>4.4</u>	<u>5X10<sup>-10</sup></u>
B <u>14.742</u>	D <u>42</u>	<u>1000/500</u>
	E <u>4.8</u>	<u>810V</u>
Tim Crit. <u>10:48</u> <sup>AM</sup> / <sub>PM</sub> Duration <u>17</u> min.		



withdraw rod B to reduce level  
level with B.

47

8/28/52

CRITICAL POSITIONS	
C.A. <u>8</u>	Expr. <u>2</u> Run <u>43</u>
Table Pos. _____	I _____ T _____ R _____
Control Rod	Channel
1 <u>Same</u>	A <u>38. x1000/25</u>
2 <u>Same</u>	B <u>0.00v</u>
A <u>26.163</u>	C <u>0.4 x 5 x 10<sup>-10</sup></u>
B <u>14.825</u>	D <u>54 x1000/50</u>
	E <u>0.6 @ 810v</u>
Tim Crit. <u>11:05</u> <sup>AM</sup>	<del>PM</del> Duration <u>25</u> min.

Draw B to 14.2 level with A

CRITICAL POSITIONS	
C.A. <u>8</u>	Expr. <u>2</u> Run <u>44</u>
Table Pos. _____	I _____ T _____ R _____
Control Rod	Channel
1 <u>Same</u>	A <u>57 x 1000/100</u>
2 <u>Same</u>	B <u>0.02</u>
A <u>28.240</u>	C <u>4.3 x 5 x 10<sup>-10</sup></u>
B <u>14.224</u>	D <u>40 x 1000/500</u>
	E <u>4.5 @ 810v</u>
Tim Crit. <u>11:40</u> <sup>AM</sup>	<del>PM</del> Duration <u>10</u> min.

B removed - level with B

9/15

CRITICAL POSITIONS			
C.A.	8	Expr.	✓ Run 45
Table Pos.		I	T R
	Control Rod		Channel
1	Sam	A	51 x 100/100
2	Sam	B	0.0014
A	28.240	C	0.3 x 5 x 10 <sup>-10</sup>
B	14.360	D	40 x 1000/50
		E	0.5 @ 810V.
Tim Crit.	11:55	<del>PM</del> AM	Duration 17 min.

Insert B for 13.75 - level with A

Temp. @  
12:31 P  
1.3323 mV

CRITICAL POSITIONS			
C.A.	8	Expr.	2 Run 46
Table Pos.		I	T R
	Control Rod		Channel
1	Sam	A	56 1000/100
2	"	B	.02
A	31.050	C	4.0 5 x 10 <sup>-10</sup>
B	13.750	D	39 1000/500
		E	4.4 810V
Tim Crit.	12:12	<del>PM</del> AM	Duration 21 min.

Rec  
ris  
rod  
den  
and  
lin  
w.  
abr

Be removed - Seal with B

49

CRITICAL POSITIONS			
C.A.	8	Expr.	2 Run 47
Table Pos.		L	T R
	Control Rod		Channel
1	Same	A 39	$\frac{1500}{25}$
2	"	B .002	
A	31.050	C 0.4	$5 \times 10^{-10}$
B	13.872	D 50	$\frac{1000}{50}$
		E 0.6	810V
Tim Crit.	12:33	AM	PM Duration 26 min.

Insert B to 13.270 Seal with A

Reactor still rising with rod A. Out. Level was reduced and the lower limit switch was changed about 2 in.

CRITICAL POSITIONS			
C.A.	9	Expr.	2 Run 48
Table Pos.		L	T R
	Control Rod		Channel
1	Same	A	
2	"	B	
A		C	
B		D	
		E	
Tim Crit.	12:57	AM	PM Duration min.

CRITICAL POSITIONS		
CA <u>8</u>	Expr. <u>2</u>	Run <u>48</u>
Tube Pos. _____	L _____	T _____
Control Rod	Channel	
1 <u>same</u>	A <u>39</u>	<u>1000/25</u>
2 <u>same</u>	B <u>.002</u>	
A <u>31.050</u>	C <u>.4</u>	<u>5x10<sup>-10</sup></u>
B <u>13.860</u>	D <u>.52</u>	<u>1000/50</u>
	E <u>.6</u>	<u>810V</u>
Tim Crit. <u>1:25</u>	<del>AM</del> PM	Duration <u>10</u> min.

*Insert rod B to 13.400 To produce positive period level with A.*

CRITICAL POSITIONS		
<u>8</u>	Expr. <u>2</u>	Run <u>49</u>
Tube Pos. _____	L _____	T _____
Control Rod	Channel	
<u>same</u>	A <u>58</u>	<u>1000/100</u>
<u>same</u>	B <u>.021</u>	
A <u>35.380</u>	C <u>4.2</u>	<u>5x10<sup>-10</sup></u>
B <u>13.500</u>	D <u>.39</u>	<u>1000/500</u>
	E <u>4.5</u>	<u>810V</u>
Tim Crit. <u>1:35</u>	<del>AM</del> PM	Duration <u>24</u> min.

*1:55 P.M.*

*Temp.*

*1.3306*

INSTRUMENT CHECK

Time 1:55 ~~AM~~ PM Source PB267

	Channel				
	A	B	C	D	E
Range	<u>10/1000</u>		<u>10<sup>-10</sup></u>	<u>10/1000</u>	<u>900V</u>
Source Dist.	<u>15"</u>	<u>OK</u>	<u>1"</u>	<u>5'</u>	<u>5"</u>
% F.S. Trip	<u>55-</u>	<u>1</u>	<u>100+</u>	<u>26</u>	<u>100+</u>

C.A. 8      Expr. 2/1      Run 6

Sheet \_\_\_\_\_      Date 7/29 1952      Time \_\_\_\_\_ ~~AM~~ PM

Purpose To measure excess reactivity  
with full 70 tube  
loading.

Temp 2:15P  
 1.329 mV.

Added	Tube	to	Location
	54		10-11
	23		5-10
	51		5-3
	29		6-3

70 tube loading

CRITICAL POSITIONS	
C.A. <u>8</u>	Expr. <u>1</u> Run <u>6</u>
Table Pos. _____ I _____ T _____ R _____	
Control Rod	Channel
1 <u>99.947</u>	A <u>65 x 100 / 100</u>
2 <u>99.934</u>	B <u>0.002</u>
<sup>81.4%</sup> <u>26.522</u>	C <u>7.5 x 5 x 10<sup>-11</sup></u>
<u>33.676 (out)</u>	D <u>52 x 1000 / 50</u>
	E <u>1.7 @ 900V</u>
Tim Crit. <u>2:25</u> <sup>AM</sup> <del>PM</del>	Duration <u>20</u> min.

Removed tubes 29 from 6-3, 23 from 5-10, and ~~6 from 12-6~~. Total loading 68 tubes.

Value of two tubes  
56.6%

Temp at 4:15 P.M.  
1.3282

CRITICAL POSITIONS	
C.A. <u>8</u>	Expr. <u>1</u> Run <u>7</u>
Table Pos. _____ I _____ T _____ R _____	
Control Rod	Channel
1 <u>99.948</u>	A <u>76</u> <u>100 / 100</u>
2 <u>99.933</u>	B <u>0.0021</u>
<sup>85.2%</sup> <u>12.877</u>	C <u>8.5</u> <u>5 x 10<sup>-11</sup></u>
<u>33.675</u>	D <u>60</u> <u>1000 / 50</u>
	E <u>1.6</u> <u>900V</u>
Tim Crit. <u>3:50</u> <sup>AM</sup> <del>PM</del>	Duration <u>23</u> min.

Rod A withdrawn and levelled with Rd B 53

CRITICAL POSITIONS			
CA	8	Expr	1
		Run	8
Table No.		L	T R
	Control Rod		Channel
1	99.948	A 73	100/100
2	99.932	B .0021	
A	35.383	C 8.3	5x10 <sup>11</sup>
B	20.334	D 58	1000/50
		E 1.5	900V
Tim Crit.	4:13	<del>AM</del> PM	Duration 10 min.

2 Sept

INSTRUMENT CHECK							
Time	9:30 AM	Source	PB267				
	<del>PM</del>						
		Channel	A	B	C	D	E
Range	$\frac{10}{1000}$		10 <sup>-10</sup>	$\frac{10}{1000}$	900V		
Source Dist.	14"	OK	8"	5'	3"		
% F.S. Trip	45	100%	25	100%			
	Counts 142	OK					

C.A. 8    Expr. 1    Run 99  
 Sheet \_\_\_\_\_    Date 9/2/1952    Time 9:44 <sup>AM</sup>  
 Purpose To measure excess readings with full 70 tube loading.

Temp. 10:14 AM  
1.3289

repeated run 8

CRITICAL POSITIONS

C.A. 8    Expr. 1    Run 99  
 Table Pos. \_\_\_\_\_

Control F. J	Channel
<u>1 99.945</u>	A <u>68</u> <u>100/100</u>
<u>2 99.930</u>	B <u>0.0021</u>
<u>A<sup>99.7</sup> 35.383</u>	C <u>6.0</u> <u>5x10<sup>-11</sup></u>
<u>B 20.358</u>	D <u>54</u> <u>1000/50</u>
	E <u>1.7</u> <u>900 V</u>

Tim Crit. \_\_\_\_\_    AM  
 PM    Duration \_\_\_\_\_ min.



62.0<sup>th</sup>

Removed Rods

25 from 13-5

64 from 3-5

~~54 from 10-11~~  
total loading = 66 tubes

55

Temp 11:10 AM

1.3271

CRITICAL POSITIONS			
8	Expt	1	Run 10
		I	T R
Control Rod	Channel		
1 98.840 in	A	72	100/100
2 99.933	B	0.0022	
30.7 A 14.176	C	7.8	5X10 <sup>-11</sup>
B 20.358	D	57	1000/50
	E	1.5	900V
Tim Crit. 11:00	AM	PM	Duration 15 min.

~~removed tubes 54 from 10-11, 51 from 5-3~~

total loading @ 64 tubes withdrew rod A to

35.383

level with B

Temp. 12:40 P.M.

1.3290

CRITICAL POSITIONS			
8	Expt	1	Run 11
		I	T R
Control Rod	Channel		
1 98.960	A	63	100/100
2 99.930	B	.002	
30.7 A 35.383	C	6.9	5X10 <sup>-11</sup>
B 14.080	D	50	1000/50
	E	1.4	900V
Tim Crit. 12:42	AM	PM	Duration 15 min.

56

65.7

removed tubes 54 from 10-11 and  
51 from 5-3.  
total loading 64 tubes

CRITICAL POSITIONS			
CA	8	Expr	1
		Run	12
Table Pos.		L	T
	Control Rod		Channel
1	98.952 in	A	65 100/100
2	99.930	B	0.002
220 A	13.296	C	6.9 5x10 <sup>-11</sup>
B	14.080	D	50 1000/50
		E	1.3 900V
Tim Crit.	1:13	<del>PM</del> PM	Duration 9 min.

Withdrawn A To ~~with~~ and ~~with~~  
~~with~~ B. inserted B(in)

Temp 1:30 P.M.  
1.3285

CRITICAL POSITIONS			
CA	8	Expr	1
		Run	13
Table Pos.		L	T
	Control Rod		Channel
1	98.953	A	67 100/100
2	99.930	B	0.002
43 A	27.360	C	7.4 5x10 <sup>-11</sup>
B	99.954	D	52 1000/50
		E	1.3 900V
Tim Crit.	1:27	<del>PM</del> PM	Duration 7 min.

646 } Remained tubes 24 from 11-03, and 20 from 6-11  
 total loading 62 tubes. 57

Temp 1:59 P.M.  
 1.3294

CRITICAL POSITIONS

CA 8 Expt 1 Run 14

Table      T      R     

Channel

98.975	65	100/100
99.933	0.002	
<sup>19.2</sup> A 11.305	7.0	5X10 <sup>-11</sup>
B 99.953	52	1000/50
	1.3	900V

Tim Crit. 1:49 <sup>AM</sup>/<sub>PM</sub> Duration 12 min.

\$2.69 <sup>2 spec</sup>  
 with  
 70 tubes  
 1\$ = .008052  
 \* 2.2%

Replaced tubes 24 = 11-3 and 20 = 6-11  
 Removed tubes 58 from 8-7  
 Tubes replaced 54 in 10-11 and 51 in 5-3

indication  
 on slider  
 on Rod A  
 & slipping

CRITICAL POSITIONS

CA 8 Expt 1 Run 15

Table      T      R     

Channel

98.955	58	100/100
99.930	.002	
<sup>19.2</sup> A <del>15.643</del> 14.44	6.6	5X10 <sup>-11</sup>
B 99.953	47	1000/50
	1.2	900V

Tim Crit.      <sup>AM</sup>/<sub>PM</sub> Duration      min.

58

9-2-52

4:00 P.M.

Instrument shut-down procedure followed

~ 4:30 P.M. To 6:30 P.M. Power OFF

7:00 P.M.

Instrument start-up procedure followed

8:00 P.M.

Compressor in Room 212 started

**INSTRUMENT CHECK**

Time 9:15 AM ~~PM~~ Source P.B. 267

	Channel				
	A	B	C	D	E
Range	$\frac{10}{1000}$		$10^{-10}$	$\frac{10}{1000}$	900V
Source Dist.	12"	OK	9"	5'	4"
% F.S. Trip	60		100*	28	100*
Counts 1 + 2 OK					

Removed relay on control rod A. <sup>Drive.</sup> Cleaned grease from relay's brushes to restore it to operation. Replaced relay to rod A.

Repeat of Run 15 to check error <sup>rod</sup> disposition.

**CRITICAL POSITIONS**

8 Expt. 1 Run 16

Channel

98.895	A	60	$\frac{100}{100}$
99.930	B	.002	
16.650	C	69	$5 \times 10^{-11}$
99.952	D	49	$\frac{1000}{50}$
	E	1.3	900V

Tim Crit. 11:19 ~~PM~~ AM Duration 9 min.

Temp 11:28 AM  
1.3223

64.6  
65.7  
130.3  
23.1  
107.2  
42.3  
19.2  
23.1  
↑  
Value #58  
in 8.7

Removed tubes            24 from 11-3  
                                   20 from 6-11  
                                   54 from 10-11  
                                   51 from 5-8

Replaced tube 58 into 8-7  
 Total loading 62 tubes

Repeat of run 14 To check for selection error

CRITICAL POSITIONS		
8	Expr. 1	Run 17
Tube Pos.		
Control Rod	Channel	
0.025	61	100/100
99.930	.002	
19 <sup>3</sup> A 11.341	C 6.3	5x10 <sup>-11</sup>
B 99.955	D 50	1000/50
	E 1.2	900V
Tim Crit. 2:47	<del>AM</del> PM	Duration 1.0 min.

Removed from 8-7 rod 58 and  
 replaced it with rod 80 (aluminum tube)

C.A. 8    Expt. 3    Run 1  
 Sheet \_\_\_\_\_    Date 9/3/1952    Time 3:00 PM  
 Purpose Evaluation of Aluminum fuel tube

CRITICAL POSITIONS  
 C.A. 8    Expt. 3    Run 1

Channel	Value
Channel	0.025
A	99.928
B	0.005
C	35.402
D	5.964
E	

Tim Crit. 3:17 AM    Duration \_\_\_\_\_ min.

5.964 inches  
 with 6.44  
 by pilot period

92.7  
 -19.3  
 ---  
 73.4  
 6.4  
 ---  
 79.80

Removed tube 80 from 8-7  
 Replaced tube 58 into 8-7  
 Removed tube 72 from 9-8 and replaced it  
 with tube 80. Total loading 62 tubes.

ube)

CRITICAL POSITIONS

CA 8 Expr. 3 Run 2

Tube P. \_\_\_\_\_

Tube P.	Channel	Value
1	A	0.025
2	B	99.930
A	C	<del>29.285</del> 29.285
B	D	99.950
	E	1.2

Channel: 100/100  
5X10<sup>-11</sup>  
100%/50  
900V

Tim Crit. 3:47 ~~PM~~ Duration 9 min.

87.6  
-19.3  
-----  
68.3

87.6

Removed tube 32 from 10-8  
 Moved tube 80 from 9-8 to 10-8  
 Replaced tube 72 in 9-8. Total 62 tubes

CRITICAL POSITIONS

CA 8 Expr. 3 Run 3

Tube P. \_\_\_\_\_

Tube P.	Channel	Value
	A	0.025
	B	99.928
A	C	22.780
B	D	99.952
	E	1.3

Channel: 100/100  
5X10<sup>-11</sup>  
100%/50  
900V

Tim Crit. 4:09 ~~PM~~ Duration 7 min.

69.6  
-19.3  
-----  
50.3

69.6

Temp at 4:20 PM

1.3180 mV



Sept. 4.

INSTRUMENT CHECK					
Time	9:00 AM		Source PB267		
	Channel				
	A	B	C	D	E
Range	$\frac{10}{1000}$		$10^{-10}$	$\frac{10}{1000}$	900V
Source Dist.	15" OK		7" 6'	3"	
% F.S. Trip	35		90	22	100 <sup>+</sup>
	Counts 1+2 OK				

C.A.	8	Expr.	3	Run	4
Sheet		Date	Sept 4 1952	Time	9:00 AM PM
Purpose	Continuous Evaluation of Cl. fuel tubes				

Temp. 9:35 AM.  
1.3336

CRITICAL POSITIONS					
	8	Expr.	3	Run	4
	Channel				
	0.024	A	69	$\frac{100}{100}$	
	99.930	B	.002		
A	22.780	C	7.4	$5 \times 10^{-11}$	
B	99.953	D	57	$\frac{1000}{50}$	
		E	1.3	900V	
Tim Crit.	9:25	AM PM	Duration	15	min.

64

Removed Tube 63 from 11-8  
 moved tube 80 from 10-8 to 11-8  
 Replaced tube 32 into 10-8

## CRITICAL POSITIONS

CA 8 Expt 3 Run 5

ACIS Pos. \_\_\_\_\_

Control Pos.

Channel

Temp. 10:10 AM

1.3336

$$\begin{array}{r} 53.4 \\ 19.3 \\ \hline 34.1 \end{array}$$

53.4

Control Pos.	Channel
1 0.025	A 70 100/100
2 99.928	D .002
A 19.084	C 7.6 $5 \times 10^{-11}$
B 99.953	D 56 1000/50
	E 1.4 900V

Tim Crit. 9:56 <sup>AM</sup> ~~PM~~ Duration 13 min.

Removed Tube 28 from 12-8  
 moved tube 80 from 11-8 to 12-8  
 Placed tube 63 back in 11-8

## CRITICAL POSITIONS

8 Expt 3 Run 6

Channel

Temp. 10:33 AM

1.3319

$$\begin{array}{r} 39.2 \\ 19.3 \\ \hline 19.9 \end{array}$$

39.2

Control Pos.	Channel
0.025	71 100/100
99.928	.002
A 15.960	C 7.6 $5 \times 10^{-11}$
B 99.952	D 56 1000/50
	E 1.3 900V

Tim Crit. 10:30 <sup>AM</sup> ~~PM~~ Duration 10 min.

Removed tube 80 from 12-8  
Placed tube 28 into 12-8

65

Sept. 5

INSTRUMENT CHECK					
Time	8:50 AM		Source PR 267		
	Channel				
	A	B	C	D	E
Range	$\frac{10}{1000}$		$10^{-10}$	$\frac{10}{1000}$	900V
Source Dist.	16"	OK	6"	7'	4"
% F.S. Trip	35		100	18	100 <sup>+</sup>
	counts 172 OK				

Removed tube 58 from 8-7 107.2¢  
 Replaced tubes 24 To 11-3 } 64.6  
 20 To 6-11 } 65.7  
 54 To 10-11 } Total loading 65  
 51 To 5-3 } Tubes

C.A.	8	Expr.	4	Run	1
Sheet		Date	195	Time	AM PM
Purpose	Calibration of A.R.E. Regulating rod.				

Thermal-couple displaced from center  
by one hex block.

66

64.6  
65.7  
130.3  
128.2  
107.1  
10.3  
93.2

CRITICAL POSITIONS

8      4      1

Table Pos. \_\_\_\_\_

0.024	63	100/100
99.930	.0019	
A 16.710	7.1	5x10 <sup>-11</sup>
B 99.953	52	1000/50
	E 1.2	900V

Tim Crit. 9:45 ~~AM~~ ~~PM~~ Duration 10 min.

Temp at 9:52 AM  
1.3342

42.5

Removed column of BeO from 8-7 (6 blocks)

CRITICAL POSITIONS

CA \_\_\_\_\_

Table Pos. \_\_\_\_\_

1 \_\_\_\_\_

2 \_\_\_\_\_

3 \_\_\_\_\_

4 \_\_\_\_\_

E \_\_\_\_\_

Tim Crit. \_\_\_\_\_ ~~AM~~ ~~PM~~ Duration \_\_\_\_\_ min.

*not critical*

Tubes replaced:

29 into 6-3 } 56.6  
 23 into 5-10 }  
 25 into 13-5 } 62.0  
 64 into 3-5 }

total loading 69 tubes

10:50 AM.

Not Critical.

$B_1 = 0.0003$

50.34

Removed no. 32 from 10-8 and inserted tube 80 (Aluminum) into 10-8. | 68.55  
 1 al

11:09 A.M. Not Critical.

$B_1 = 0.0005$

62.17

Tube no 49 removed from 6-7 and aluminum tube no. 81(al) inserted into 6-7.

67.55  
 2 al

CRITICAL POSITIONS

8 Exp. 4 Run 2

Temp. 1:30 P.M.  
 1.3388

	Channel	
0.024	A 64	100/100
99.923	B .002	
A <sup>110</sup> 8.780	C 7.1	5x10 <sup>-11</sup>
B 99.950	D 52	1000/50
	E 1.4	900V

42.5  
 11.0  
 31.5  
 56.6  
 62.0  
 50.3  
 62.17  
 231.07  
 31.5  
 262.574  
 ↑  
 value 8-7 BeO

12:53 PM Duration min.

68

2:45 AM Crane in 108 stopped. Electricians found dirt on the 440 volt sliding conductors. Back in operation at 3:40 PM

4 half shells (1/8 in. thick) placed around reactor. total thickness 1/4 in.

45.5  
11.0  
34.5

CRITICAL POSITIONS		
C.A. <u>8</u>	Expr. <u>5</u>	Run <u>1</u>
Table Pos.		
Control Rod		Chemical
<u>10.024</u>	A <u>66</u>	<u>100/100</u>
<u>99.923</u>	B <u>.0018</u>	
<u>17.322</u>	C <u>7.2</u>	<u>5X10<sup>-11</sup></u>
B <u>99.950</u>	D <u>52</u>	<u>1000/50</u>
	E <u>1.4</u>	<u>900V</u>
Tim Crit. <u>4:05</u>	<del>AM</del> PM	Duration <u>13</u> min.

C.A. <u>8</u>	Expr. <u>5</u>	Run <u>1</u>
Sheet _____	Date _____ 195	Time <u>3:55</u> PM
Purpose	<u>Evaluation of pressure shell mockup</u>	

added 4 half shells ( $\frac{1}{8}$  in thick) around reactor. Total thickness  $\frac{1}{2}$  inch.

9 Sept

INSTRUMENT CHECK					
Time	8 <sup>20</sup>	AM	Source	PB267	
		PM			
			Channel		
	A	B	C	D	E
Range	$\frac{10}{1000}$		$10^{-10}$	$\frac{10}{1000}$	900V
Source Dist.	15" OK		1"	6'	4"
% F.S. Trip	40		100	24	100+
	Counts #2 OK				

C.A.	8	Expr.	5	Run	2
Sheet	—	Date	9 Sept 1952	Time	8 <sup>20</sup> AM
Purpose	Continue pressure shell evaluation.				

CRITICAL POSITIONS

C.A. 8      Expr 5      Run 2

Table Pos. \_\_\_\_\_

Control	Channel
1 <u>0.018</u>	<u>69</u> <u>100/100</u>
2 <u>99.924</u>	<u>.0018</u>
A <u>21.980</u>	<u>7.4</u> <u>5x10<sup>-11</sup></u>
B <u>99.950</u>	<u>55</u> <u>1000/50</u>
E <u>1.7</u>	<u>900V</u>

Tim Crit. 9:56 <sup>AM</sup> ~~PM~~      Duration 10 min.

Temp 9:15 AM  
1.300

66.5  
45.5  
21.0

↑  
value of second  
1/4" of Pressure Shell

ARE thinks  
Added three tubes to 8-7 }

CRITICAL POSITIONS

C.A. \_\_\_\_\_ Expr \_\_\_\_\_ Run \_\_\_\_\_

Table Pos. \_\_\_\_\_

Control	Channel
1 _____	A _____
2 _____	B _____
3 _____	C _____
4 _____	D _____
	E _____

Tim Crit. \_\_\_\_\_ <sup>AM</sup> ~~PM~~      Duration \_\_\_\_\_ min.

not critical



Pressure shell removed  
 3 tubes removed from 8-7  
 BeO returned to 8-7  
 Tube 58 put into 8-7  
 81 removed from 6-7  
 49 inserted in 6-7  
 80 removed from ~~8~~-8  
 82 inserted in ~~8~~-8  
 25 removed from 13-5  
 64 " from 3-5  
 29 " from 6-3  
 23 " from 5-10  
 (total loading 66 tubes)

C.A. 8 Expr. 6 Run 1  
 Date Sep. 9, 1952 Time 2:00 PM  
 Purpose evaluation of fuel tube  
vs. radins.

temp 2:25 PM.  
 1.300

14" Rod B worth  
 ~ 56.8%

CRITICAL POSITIONS		
CA	Exp	Run
8	6	1
Channel	Count	Rate
A	66	100/100
B	.001	
C	7.9	5X10 <sup>-11</sup>
D	57	1000/50
E	1.7	900V
Time Crit.	2:15	PM
Duration	8	min.

72

Sept. 11

**INSTRUMENT CHECK**

Time 10<sup>10</sup> AM Source PB 267  
PAA

Range	Channel				
	A	B	C	D	E
	<u><math>\frac{10}{1000}</math></u>		<u><math>10^{-11}</math></u>	<u><math>\frac{10}{1000}</math></u>	<u>900V</u>
Source Dist.	<u>7" OK</u>		<u>8"</u>	<u>6'</u>	<u>3<math>\frac{1}{2}</math></u>
% F.S. Trip	<u>100</u>		<u>90</u>	<u>20</u>	<u>100</u>
Counts	<u>1<math>\frac{1}{2}</math> OK</u>				

Tube 58 removal from 8-7 (65 tubes)

C.A. 8 Exor. 7 Run 1

Sheet \_\_\_\_\_ Date Sept. 11 1952 Time 10:35 ~~AM~~ PM

Purpose Fuel tube Va. void importance.

**CRITICAL POSITIONS**

8 Exor. 7 Run 1

Count	Channel
<u>0.010</u>	A <u>64</u> <u>100/100</u>
<u>99.926</u>	B <u>.002</u>
A <u>16.620</u>	C <u>7.3</u> <u><math>5 \times 10^{-11}</math></u>
B <u>99.940</u>	D <u>53</u> <u>1000/50</u>
	E <u>1.5</u> <u>900V</u>

Tim Crit. 10:40 ~~AM~~ PM Duration 8 min.

92.6  
42.2  
50.4  
56.8  
107.2

42.2

Ter

104.7<sup>4</sup>

returned no. 58 to 8-7 and removed  
no. 72 from 9-8. (65 tubes)

CRITICAL POSITIONS

CA 8 Exp 7 Run 2

Tube Pos. \_\_\_\_\_ T \_\_\_\_\_

Temp at 11:20 AM

1.2805

Channel

0.010 A 64 100/100

99.925 B .001

44.7  
42.25  
2.5  
A 17.173 C 5.6 5X10<sup>-11</sup>

B 99.924 D 53 1000/50

E 1.4 900V

Tim Crit. 11:15 ~~AM~~ PM Duration 6 min.

107.2  
2.5  
104.7

44.7  
42.25  
2.5

79.8<sup>4</sup>

replace no 72 into 9-8 and removed  
no 32 from 10-8. (65 tubes)

CRITICAL POSITIONS

8 Exp 7 Run 3

Channel

(1) 0.010 A 64 100/100

(2) 99.927 B .001

186  
A 22.760 C 5.7 5X10<sup>-11</sup>

B 99.924 D 5.2 1000/50

E 1.4 900V

Tim Crit. 12:46 ~~AM~~ PM Duration 9 min.

107.2  
27.4  
79.8  
69.6  
42.2  
27.4

74

51.2 Replaced no 32 into 10-8 and removed no 63 from 11-8.

65.7  $\phi$  → Tube 54 removed from 10-11, 51 from 5-3 (63 tubes)

65.7

42.2  
32.5  
9.7

CRITICAL POSITIONS	
8	Exp. 7 Run 4
	I T R
	Channel
0.010	67 100/100
Temp at 1:27 PM. 99.926	B .002
1.2838	A 14.572 C <del>58</del> 58 5X10 <sup>-11</sup>
	B 99.924 D 54 100/50
	E 1.4 900V
Tim Crit. 1:16	PM Duration 9 min.

return 63 to 11-8 and removed 28 from 12-8.

37.0  $\phi$

(63 tubes)

CRITICAL POSITIONS

8      Expt      7      Run      5

T      R

Channel

0.006	A	65	100/100
99.925	B	.002	
46.7 17.600	C	5.6	5X10 <sup>-11</sup>
99.922	D	52	1000/50
	E	1.3	900 V

Crit. 2:36      ~~AM~~ PM      Duration 15 min.

temp. 2:48 P.M.  
1.2847

(returned) → Tube # 34 inserted into 10-11, tube 51 into E-3, and 63 into 11-8. Tube 32 removed from 10-8. (65 tubes)  
This is a check pt.

65)

65.7  
37.0  
102.7      69.7  
79.8      46.7  
22.9      23.04

CRITICAL POSITIONS

8      Expt      7      Run      6

T      R

Channel

1. 0.005	A	68	100/100
2. 99.925	B	.002	
A. 46.7 22.800	C	6.0	5X10 <sup>-11</sup>
B. 99.923	D	55	1000/50
	E	1.5	900 V

Crit. 3:25      ~~AM~~ PM      Duration 7 min.

69.7  
 4.5  
 65.2

tube 54 removed from 10-11 }  
 tube 51 removed from 5-3 } This run  
 is to check the value of this pair of tubes.  
 (63 tubes)

CRITICAL POSITIONS			
C.A.	8	Expr.	7
		Run	7
Table Pos.	_____		
	Control Rod		Channel
1	0.005	A	69 100/100
2	99.927	B	.002
A <sup>13</sup>	5.842	C	6.1 5x10 <sup>-11</sup>
B	99.923	D	57 (.45) 1000/50
		E	1.6 900 V
Tim Crit.	3:48	PM	Duration 9 min.

Temp. 4:02 P.M.  
 1.2863

tube 54 returned to 10-11  
 tube 51 returned to 5-3  
 (65 tubes)

8:30 AM

77

Chamber  
A not working.  
ca. Put in order  
at 10:15 AM.

**INSTRUMENT CHECK**

Time 8:50 AM PM Source PB267

Range	Channel				
	A	B	C	D	E
<u>10</u> <u>1000</u>	<u>1</u>	<u>10</u> <sup>-10</sup>	<u>10</u> <sup>-10</sup>	<u>1000</u>	<u>9000</u>
Source Dist.	<u>15</u>	<u>OK</u>	<u>7"</u>	<u>5'</u>	<u>3"</u>
% F.S. Trip	<u>50</u>	<u>1</u>	<u>90</u>	<u>24</u>	<u>100</u>
Counts	<u>142</u>	<u>OK</u>			

AU. IN.  
6C & C4 in 9-7- $\phi$

AU. IN.  
S-9 & C43 in 14-7- $\phi$

C.A. 8 Expr. 8 Run 1

Sheet \_\_\_\_\_ Date 12 Sept 1952 Time 8:50 AM PM

Purpose Foil activation vs Power level

\_\_\_\_\_

\_\_\_\_\_

**CRITICAL POSITIONS**

C.A. 8 Expr. 8 Run 1

Table Pos. \_\_\_\_\_ I \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
<u>99.980</u>	A <u>59</u> <u>1000/200</u>
<u>99.925</u>	B <u>.043</u>
A <u>22.430</u>	C <u>8.3</u> <u>5x10<sup>-10</sup></u>
B <u>99.923</u>	D <u>93</u> <u>1000/500</u>
	E <u>5.5</u> <u>750V</u>

Tim Crit. 10:45 <sup>45</sup> AM 60 min Duration 20 min.

tube 32 returned to 10-8 (66 tubes)

## INSTRUMENT CHECK

Time 10<sup>00</sup> AMSource PR 267

	Channel				
	A	B	C	D	E
Range	<u>10</u> <u>1000</u>		<u>10<sup>10</sup></u> <u>1000</u>	<u>10</u> <u>1000</u>	<u>1000</u>
Source Dist.	<u>15"</u>		<u>6"</u>	<u>4'5"</u>	<u>3"</u>
% F.S. Trip	<u>45</u>		<u>100</u>	<u>300</u>	<u>100</u>
Counts	<u>152</u>				

Fuel tubes removed: 54 from 10-11  
 51 from 5-3  
 24 from 11-3  
 20 from 6-11

Foils placed in reactor:

(Bare)

C-42 in 8-7-18-(21)- $\frac{7}{8}$   
 C-36 in 10-8-18-(4)- $\frac{7}{8}$   
 C-30 in 11-8-18-(E)- $\frac{7}{8}$   
 C-28 in 12-8-18-(F)- $\frac{7}{8}$   
 C-23 in 12-8-18-(A)- $\frac{5}{8}$   
 C-21 in 13-8-18-(D)- $\frac{7}{8}$   
 C-15 in 13-8-18-(B)- $\frac{7}{8}$   
 C-9 in 13-8-18-(4)- $\frac{5}{8}$   
 C-2 in 14-8-18-(F)- $\frac{7}{8}$

Normalizing foil AU. 201 in 5-7-24-(21)- $\frac{1}{4}$



C.A. 8 Exp. 8 Run 2  
 Sheet \_\_\_\_\_ Date Sep. 15, 1952 Time 10:20 <sup>AM</sup> ~~PM~~  
 Purpose radial traverse from center of the reactor

CRITICAL POSITIONS

8 Exp. 8 Run 2  
 I T R \_\_\_\_\_

Critical Pos	Channel
<u>99.938</u>	A <u>61</u> <u>1000/200</u>
<u>99.925</u>	B <u>.047</u>
A <u>11.342</u>	C <u>4.4</u> <u>10<sup>-9</sup></u>
B <u>99.918</u>	D <u>85</u> <u>1000/500</u>
	E <u>5.9</u> <u>750V</u>

Tim Crit. 10:32 <sup>AM</sup> ~~PM~~ Duration 20 min.

~~Tubes placed in reactor:~~  
~~54 into 10-11~~  
~~51 into 5-3~~  
~~24 into 11-3~~  
~~20 into 6-11~~

-1/4

Foils placed in Reactor (cd. covered):

C-39 into 8-7-18 (4) -  $\frac{7}{8}$

C-38 into 10-8-18 (4) -  $\frac{7}{8}$

C-35 into 11-8-18 (4) -  $\frac{7}{8}$

C-34 into 12-8-18 (4) -  $\frac{7}{8}$

C-29 into 12-8-18 (4) -  $1\frac{5}{8}$

C-30 into 13-8-18 (1) -  $1\frac{3}{8}$

C-13 into 13-8-18 (4) -  $\frac{7}{8}$

C-19 into 13-8-18 (4) -  $1\frac{5}{8}$

C-1 into 14-8-18 (4) -  $1\frac{3}{8}$

Normalizing foil A0.202 into 5-7-24 (1) -  $\frac{1}{4}$

CRITICAL POSITIONS		
8	Expr. 8	Run 3
0.033	A 62	1000/200
99.925	B .048	
A 8.870	C 8.6	$5 \times 10^{-10}$
B 99.922	D 85	1000/500
	E 5.9	750 V
Tim Crit. 2:25 $\frac{35}{60}$ PM	Duration 20 min.	

INSTRUMENT CHECK					
Time	9:45 AM		Source PB 267		
	PM				
	Channel				
	A	B	C	D	E
Range	$\frac{10}{1000}$		$10^{-10}$	$\frac{10}{1000}$	900V
Source Dist.	14"	OK	7"	5'	3"
% F.S. Trip	50		90	25	100
Counts	142				

Bare foils placed in reactor. (Im.)

21 into 8-7-0-(1) -  $\frac{7}{8}$

23 into 8-7-6-(1) -  $\frac{7}{8}$

28 into 8-7-12-(1) -  $\frac{7}{8}$

29 into 8-7-18-(1) -  $\frac{7}{8}$

30 into 8-7-24-(1) -  $\frac{7}{8}$

35 into 8-7-30-(1) -  $\frac{7}{8}$

36 into 8-7-36-(1) -  $\frac{7}{8}$

Normalizing foil AU 209 into 5-7-24-(1)  $\frac{1}{4}$

Bare im.

9 into 10-8-24-(1) -  $\frac{7}{8}$

13 into 10-8-30-(1) -  $\frac{7}{8}$

15 into 10-8-36-(1) -  $\frac{7}{8}$

1 into 12-8-24-(1) -  $\frac{7}{8}$

2 into 12-8-30-(1) -  $\frac{7}{8}$

3 into 12-8-36-(1) -  $\frac{7}{8}$

C.A. 8      Expt. 9      Run 1  
 Sheet \_\_\_\_\_ Date 9/16/1952 Time 10:00 ~~PM~~ <sup>AM</sup>  
 Purpose: ~~axial traverse~~ axial traverse  
bare indium 13 fails

CRITICAL POSITIONS

C.A. 8      Expt. 9      Run 1  
 Date \_\_\_\_\_ Time \_\_\_\_\_  
 Channel

T. <u>0.010</u>	A. <u>61</u>	<u>1000/200</u>
<u>99.925</u>	B. <u>.050</u>	
A. <u>11.590</u>	C. <u>8.5</u>	<u>5x10<sup>-10</sup></u>
B. <u>99.918</u>	D. <u>85</u>	<u>1000/500</u>
	E. <u>6.2</u>	<u>750V</u>

Tim Crit. 10:16 <sup>50</sup> ~~60~~ <sup>AM</sup> ~~PM~~ Duration 20 min.

(IN)  
Cd. covered fails added to reactor:

18 into 8-7-0-①- $\frac{7}{8}$

20 into 8-7-6-①- $\frac{7}{8}$

22 into 8-7-12-①- $\frac{7}{8}$

24 into 8-7-18-①- $\frac{7}{8}$

25 into 8-7-24-①- $\frac{7}{8}$

26 into 8-7-30-①- $\frac{7}{8}$

33 into 8-7-36-①- $\frac{7}{8}$

Normalizing fail A02 into 5-7-24-①- $\frac{1}{4}$

14 into 10-8-24-①- $\frac{7}{8}$

16 into 10-8-30-①- $\frac{7}{8}$

17 into 10-8-36-①- $\frac{7}{8}$

5 into 12-8-24-①- $\frac{7}{8}$

8 into 12-8-30-①- $\frac{7}{8}$

10 into 12-8-36-①- $\frac{7}{8}$

CRITICAL POSITIONS

Exp. 8 Run 9 2

Control Res. \_\_\_\_\_ Channel \_\_\_\_\_

0.002	A	64	1000/200
99.925	B	.051	
A 8.310	C	8.6	$5 \times 10^{-10}$
B 99.920	D	86	1000/500
	E	6.3	750V

Tim Crit. 2:33<sup>00</sup> <sup>AM</sup> ~~PM~~ Duration 20 min.

INSTRUMENT CHECK

Time 8:36 <sup>AM</sup> ~~PM~~ Source PB267

	A	B	C	D	E
Range	$\frac{10}{1000}$	1	$10^{-10}$	$\frac{10}{1000}$	900V
Source Dist.	15"	OK	6"	4 1/2"	3"
% FS Trip	50	1	95	90	100
Counts	142	OK			

C.A.	<u>8</u>	Expt.	<u>Continue 3</u>	Run	<u>7</u>
Sheet		Date	<u>9/17/1952</u>	Time	<u>9:15</u> AM
Purpose	<u>Evaluation of Aluminum fuel tube. (81)</u>				

CRITICAL POSITIONS					
C.A.	<u>8</u>	Expt.	<u>3</u>	Run	<u>7</u>
Table Pos.		I	T	R	
Control Rod				Channel	
<u>0.135</u>				A <u>73</u>	<u>100/100</u>
<u>99.928</u>				B <u>.0021</u>	
<del>A #872</del> <u>11.970</u>	<u>21.6%</u>			C <u>6.6</u>	<u>5X10<sup>-11</sup></u>
<u>B 99.917</u>				D <u>54</u>	<u>1000/50</u>
				E <u>1.5</u>	<u>900V</u>
Tim. Crit.	<u>9:32</u>			AM PM	Duration <u>8</u> min.

Moved tube no. 49 from 6-7, and inserted 81<sup>(Al)</sup> into 6-7, 62.17%

83.77  
21.60  
62.17

CRITICAL POSITIONS			
C.A.	8	Expr.	3
		Run	8
Table Pos.			
Control Rod	Channel		
1	0.090	A	71
			100/100
2	99.927	B	.0021
A	27.303	C	6.4
	<del>83.779</del>		$5 \times 10^{-11}$
B	99.918	D	52
			1000/50
		E	1.5
			900V
Tim Crit.	9:57	AM	Duration 10 min.

Temp. 10:05 AM.  
1.300

removed tube 81 from 67, returned tube 49 to  
67. Placed tubes 54 into 10-11  
51 into 5-3  
24 into 11-3  
20 into 6-11

C.A.	8	Expr.	10	Run	1
Sheet		Date	9/17, 1952	Time	10:15 AM
Purpose	Comparison of positive and negative pions for rod calibration.				



CRITICAL POSITIONS		
8	Expr. 10	Run 1
	L	T R
Control Rod	Channel	
0.010	A 84	1000/100
99.927	B 0.0027	
29.250	C 7.3	$5 \times 10^{-11}$
14.920	D 60	1000/50
	E 1.7	900V
Tim Crit. 10:27	AM	Duration _____ min.

Inserted rod A to 26.800 to produce positive period. at  $B_1 = .03$  <sup>Withdrawn</sup> inserted rod A to 35.395 (out). At  $B_1 = .0025$  returned rod A to 26.800 and leveled rod B.

CRITICAL POSITIONS		
9	Expr. 10	Run 2
	L	T R
Control Rod	Channel	
0.010	A 82	1000/100
99.927	B .0027	
A 26.800	C 4.5	$4 \times 10^{-11}$
B 15.458	D 59	1000/50
	E .5	750V
Tim Crit. 11:26	AM	Duration _____ min.

Insert rod A to 25.05 produce (+) period. at B, ~~0.03~~ .03 withdraw rod A to 29.25 to produce (-) period at B, -.003, insert Rod A 25.05 leveled with rod B.

CRITICAL POSITIONS	
C.A. <u>8</u>	Expr. <u>10</u> Run <u>3</u>
Table Pos. _____	L _____ T _____ R _____
Control Rod	Channel
1. <u>0.010</u>	A. <u>44 1000/25</u>
2. <u>99.927</u>	B. <u>.0028</u>
A. <u>25.050</u>	C. <u><math>3.3 \times 10^{-10}</math></u>
B. <u>15.990</u>	D. <u>61 1000/50</u>
	E. <u>.5 @ 750V</u>
Tim Crtt. _____	AM _____ PM _____ Duration _____ min.

Insert rod A to 23.6 to produce (+) period at B, .03 withdraw rod A 26.78 to produce (-) period at B, .003 inserted Rod A to 23.6 leveled with rod B.

CRITICAL POSITIONS					
CA	8	Expr.	10	Run	4
Table Pos.		L		T	
	Control Rod			Channel	
1	0.010	A	45	1000/25	
2	99.927	B	.0028		
A	23.600	C	3.2	$\times 10^{-10}$	
B	16.494	D	62	1000/50	
		E	.5	750V	
Tim Crit.		AM		PM	Duration
					min.

Insert rod A to 22.25 to produce a (+) period. At B, 1.03 withdrew rod A to 25.05 to produce (-) period. at B, 1.003 inserted rod A to 22.25 leveled with rod B.

CRITICAL POSITIONS					
CA	8	Expr.	10	Run	5
Table Pos.		L		T	R
	Control Rod			Channel	
1	0.010	A	44	1000/25	
2	99.927	B	.0028		
A	22.250	C	3.3	$10^{-10}$	
B	17.030	D	61	1000/50	
		E	.5	750V	
Tim Crit.		AM		PM	Duration
					min.

I insert rod A to 21.07 to produce (+) period.  
 at B, .03 withdraw rod A to 23.6 to produce  
 a (-) period. ~~at B, = .003 insert rod A to  
 leveled with rod B.~~

Temp. 2:03 P.M.

1.3070

C.A.	8	Expt.	11	Run	1
Sheet		Date	9/17, 1952	Time	3:00 PM
Purpose	Evaluation of reflector coolant tubes.				

87  
2  
6

Removed all coolant tubes except  
 the ones in the following locations:

(removed 53 tubes)

(63 total tubes  
 13 remaining)

- |       |      |     |     |
|-------|------|-----|-----|
| 10-12 | 6-12 | 9-3 | 6-2 |
| 9-12  | 10-2 | 8-1 |     |
| 9-13  | 10-3 | 7-2 |     |
| 8-13  | 9-2  | 7-3 |     |

Removed fuel tubes:

- 54 from 10-11
- 51 from 5-3
- 24 from 11-3
- 20 from 6-11

CRITICAL POSITIONS

8      Expt. 11      Run 1

L      T      R

Control Point	Channel
0.010	A 88 100/100
99.928	B .003
A 29.230	C 4.3 10-10
B 99.917	D 64 1000/50
	E 1.6 900V

Tim Crit. 3:15      ~~AM~~ PM      Duration 8 min.

87.6  
21.6 Page 85  
66.0

C.A. 8      Expt. Continue 10      Run 6

Sheet      Date 9/17 1952      Time 3:25 ~~AM~~ PM

Purpose comparison of (+) and (-) period for rod calibration.

I inserted rod A to 27.60 to produce (+) period.  
Level at B, .01 with rod A.

CRITICAL POSITIONS

CA 8      Expr. 10      Run 6

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ F \_\_\_\_\_

	Control Rod		Channel
1	<u>0.010</u>	A	<u>69</u> <u>1000/50</u>
2	<u>99.928</u>	B	<u>.01</u>
A	<u>29.110</u>	C	<u>2.6</u> <u>5X10<sup>-10</sup></u>
B	<u>99.917</u>	D	<u>56</u> <u>1000/200</u>
		E	<u>2.4</u> <u>750V</u>

Tim Crit. \_\_\_\_\_ AM  
 \_\_\_\_\_ PM      Duration \_\_\_\_\_ min.

*Reduced Level*

CRITICAL POSITIONS

CA 8      Expr. 10      Run 7

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ F \_\_\_\_\_

	Control Rod		Channel
1	<u>0.010</u>	A	<u>82</u> <u>100/100</u>
2	<u>99.928</u>	B	<u>.0028</u>
A	<u>27.600</u>	C	<u>3.3</u> <u>10<sup>-10</sup></u>
B	<u>5.077</u>	D	<u>58</u> <u>1000/50</u>
		E	<u>1.4</u> <u>750V</u>

Tim Crit. \_\_\_\_\_ AM  
 \_\_\_\_\_ PM      Duration \_\_\_\_\_ min.

Inserted Rod A to 26.40 to  
 produce positive period  
 level on B, at .01 with Rod A

Temp @ 4:30 P  
 1.304 mV

CRITICAL POSITIONS				
C.A.	8	Expr.	10	Run 8
Table Pos.			L	T
	Control Rod			Channel
1	0.010	A	68	$\frac{1000}{50}$
2	99.928	B	.01	
A	27.310	C	2.4	$5 \times 10^{-10}$
B	5.078	D	55	$\frac{1000}{200}$
		E	2.4	750V
Tim Crt.		AM PM	Duration	min.

Reduced level

CRITICAL POSITIONS				
C.A.	8	Expr.	10	Run 9
Table Pos.			L	T
	Control Rod			Channel
1	0.016	A	47	$\frac{1000}{25}$
2	99.928	B	.003	
A	29.320	C	3.5	$10^{-10}$
B	3.390	D	65	$\frac{1000}{50}$
		E	1.4	750V
		AM PM	Duration	min.

Inserted Prod A to 26.40 to produce + period  
Level on B, at .01 with prod A

CRITICAL POSITIONS			
C.A.	8	Expr.	10 Run 10
Table Pos.		L	T R
	Control Read		Channel
1	0.010	A	52 $\frac{1000}{100}$
2	99.928	B	.02
A	28.945	C	3.2 $5 \times 10^{-10}$
B	3.390	D	84 $\frac{1000}{200}$
		E	3.3 750V
Tim Crit.		AM PM	Duration: _____ min. <input type="checkbox"/>



Sept 19

30 Fuel tubes returned to 9212 for new loading  
(0.2138 gm/cc U<sup>235</sup> or 19 lbs. U<sup>235</sup> in Core)

30 Fuel tube returned to 9212

Sept 22

12 Fuel tubes returned to 9212

Sept 26  
3:30 P

30 Fuel tubes received from 9212

# INTER-COMPANY CORRESPONDENCE

(INSERT NAME) COMPANY CARBIDE AND CARBON CHEMICALS COMPANY LOCATION Post Office Box P OAK RIDGE, TENN.

TO A. D. Callihan  
LOCATION

DATE October 3, 1952

ATTENTION  
COPY TO Dunlap Scott, W. R. Grimes,  
file

ANSWERING LETTER DATE

SUBJECT Fuel Slugs

... covering this date of slugs fabricated for the ARK Cold Critical experiment. Each slug is individually wrapped in 0.00025 inch aluminum foil. Some pertinent properties of these slugs are given below.

93.2 x 22 x 16.8 x 7.58  
235-  
34

Slug No.	Length Including Foil Wrapper	Weight* Grams
1	2-7/16"	126.94
2	3-9/16	183.92
3	2-15/16	151.49
4	4	212.50
5	1-3/4	90.32
6	1-5/16	67.46
7	4-15/16	253.54
8	3-1/4	174.98
9	3-15/16	204.58
10	5-1/16	271.27
* 11	1-5/8	78.80
12	1-3/4	94.43
13	1-1/2	80.50
14	3-1/16	158.55
	41-1/8"	2149.28

Analysis: U (~~as 235~~) - 6.83 wt. % UF<sub>4</sub> - 9.05 wt. %  
 Zr - 40.5 " ZrF<sub>4</sub> - 74.2 "  
 Total U content = 146.80 grams  
 Total UF<sub>4</sub> " = 194.42 grams

\* Estimated by deducting actual foil weight from actual slug plus foil weight.

C = 3.75 g/cc

dc

238 g-<sup>235</sup>/<sub>cc</sub>

D. R. Cuneo  
D. R. Cuneo

L. G. Overholser  
L. G. Overholser

227.7 gm UF <sub>4</sub>	} L.A. Overholser
1410 gm ZrF <sub>4</sub>	
443 gm NaF	
<u>2580.7 gm total</u>	

7/2/53

8.823% wt % UF<sub>4</sub>  
 6.664% wt % U  
 6.204% wt % U<sup>235</sup>  
 74.0 wt % ZrF<sub>4</sub>  
 17.17 wt % NaF

Assay 93.1

$$\frac{311.24}{235.08} = \frac{1.323975}{1.323404} = 1.00643$$

143.3 gm U

2068.78 gm total in tube

$$2068.78 \times 6.2 \text{ wt \% } U^{235} = \underline{128.2 \text{ gm } U^{235} \text{ in tube}}$$

$$\frac{35.62 \text{ inch Core}}{40 \text{ in in tube}} \times 128.2 \text{ gm } U^{235} = \underline{\underline{114.2 \text{ gm } U^{235}}}$$

### Cast Fuel

Total Mat'l 2149.28 gm  
Sloss #13 - 80.50 gm  
Mat'l in Tube 2068.78 gm

	We. Per Cent	
	Actual	Specified
U <sup>25</sup>	6.83	8.82
UF <sub>4</sub>	9.05	8.82
ZrF <sub>4</sub>	74.2	74.0
NaF	16.75	17.15
		0.248 gm U <sup>25</sup> /g

$$2068.78 \times \frac{6.83}{100} = 141.3 \text{ gm U}^{25} \text{ in Tube}$$

$$\frac{35.62 \text{ inch core}}{40 \text{ inch Tube}} = 125.9 \text{ gm U}^{25} \text{ in Core}$$

Compared to 132.7 gm U<sup>25</sup> in Core for Powder

Sept 29

99

INSTRUMENT CHECK

Time 9:25 AM ~~PM~~ Source PB 267

Channel

	A	B	C	D	E
Range	$\frac{10}{1000}$		$10^{-10}$	$\frac{10}{1000}$	900V
Source Dist.	15"	OK	5"	5'	2"
% F.S. Trip	42		100	22	100+
Counts	1+2	OK			

C.A. 9 Expr. 1 Run 1

Sheet \_\_\_\_\_ Date 9-28 195\_\_ Time \_\_\_\_\_ AM  
PM

Purpose Initial Loading

#1 No fuel  
1+2 Cadmium  
out

MULTIPLICATION

Scaler	c/	min.	B.G.	min.	Mult.	I/M
1	$6 \times 16 + 1$	} 6.5				
	$6 \times 16 + 11$					
2	$9 \times 16 + 9$	} 9.5				
	$9 \times 16 + 14$					
3						

#2 Safety lead  
loaded 7 tubes  
#1 Cadmium  
out

MULTIPLICATION

Scaler	c/	min.	B.G.	min.	Mult.	I/M
1	$9 \times 16 + 2$	} 10				0.65
	$10 \times 16$					
2	$9 \times 16 + 11$	} 10.7				0.59
	$10 \times 16 + 4$					
3						0.45

100  
9/29/52

Rod A One full tube  
in 9-7 DA 12/11/52

2nd loading  
(See chart)  
2 control Rods  
& Center tube added  
(12 tubes)

MULTIPLICATION					
Scaler	c/	5	min. BG/	min.	Mult. 1/M
1	50x16 + 2	53x16 + 8	103.9		0.64
2	48x16 + 2	47x16 + 8	9.6		0.99
3					

3rd Loading - 19 tubes total

1:50P

MULTIPLICATION					
Scaler	c/	5	min. BG/	min.	Mult. 1/M
1	78x16 + 5	62x16 + 15			0.44
2	44x16 + 12	50x16 + 14			0.95
3					

3:35P

4th Loading - 28 tubes total

6.5  
9.5

MULTIPLICATION					
Scaler	c/	5	min. BG/	min.	Mult. 1/M
1	118x16 + 13	125x16 + 15	23.7	24.4	6.5 .266
2	66x16 + 1	65x16 + 15	13.2	13.2	9.5 .719
3					

**CRITICAL POSITIONS**

C.A. \_\_\_\_\_ Expr \_\_\_\_\_ Run \_\_\_\_\_  
 Table Pos \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ P \_\_\_\_\_  
 Control Rod \_\_\_\_\_ Channel \_\_\_\_\_  
 1 \_\_\_\_\_ A \_\_\_\_\_  
 2 \_\_\_\_\_ B \_\_\_\_\_  
 3 \_\_\_\_\_ C \_\_\_\_\_  
 4 \_\_\_\_\_ D \_\_\_\_\_  
 \_\_\_\_\_ E \_\_\_\_\_  
 Tim Crit. \_\_\_\_\_ AM \_\_\_\_\_  
 \_\_\_\_\_ PM Duration \_\_\_\_\_ min.

Just  
 Optimism  
 ←  
 D. Scott.

5th loading 33 tubes total.

**MULTIPLICATION**

Scaler	c/ 5 min	BG/ 1 min	Mult.	1/M	
6.5	198x16+7	39.7	40.4	6.5	.161
9.5	206x16+1	41.2	18.4	9.5	.516
	90x16+10	18.1			
	93x16+12	19.7			
3					

102

9-30-52

INSTRUMENT CHECK

Time 8:40 AM  
PM

Source PB267

	A	B	C	D	E
Range	$\frac{10}{1000}$		$10^{-10}$	$\frac{10}{1000}$	900V
% F.S. Trip	50	OK	100*	22	120*
Source Dist	15"		2"	5'	2"
Counters	1#2 - OK				

6<sup>th</sup> loading - 38 tubes

9:05 AM

MULTIPLICATION

Scaler	cf	m.n.	mult	T/M
1	557x16+2	111.7	6.5	.061
2	174x16+14	35	9.5	.262
3				



7<sup>th</sup> loading, 42 tubes

CRITICAL POSITIONS			
CA	9	Expr	1
		Run	1
Left R.S.		Channel	
1	0.005	A	5.9 100/200
2	3.000	B	.0036
A	9.500 ~ 15¢	C	4.9 10 <sup>-10</sup>
B	99.937	D	92 1000/50
		E	2.3 900V
Time Crit.	10:34	AM PM	Duration 9 min.

$$\frac{42 \text{ Tubes} \times 19 \text{ lbs}}{70 \text{ Tubes}} = 11.4 \text{ lbs}$$

9.5 inches on Rod A is approximately 15¢ using  
C.A.8



plus

10-10  
10-4  
6-4  
6-10  
7-3

Oct 1<sup>st</sup>

Tube # 58 Removed from 8-7

36" BeO Removed from 8-7

3 Inconel Tubes placed in 8-7

"Weak" A/E Regulating Rod placed in 8-7 and mounted on Control Rod B Drive mechanism.

It was mounted so that in the ~~out~~ "in" position the bottom of the rod is flush with the top of the BeO. Total travel 33.34 inches.

Tubes # 75<sup>7-7</sup> & 73<sup>7-8</sup> were disconnected from Rod B drive and mounted in their respective holes.

Tube # 72 of 9-8 was reconnected to Control Rod A drive.

Summary: 41 tubes

"Weak" Regulating Rod in 8-7

CA. <u>9</u>	Expr. <u>2</u>	Run : _____
Sheet _____	Date <u>Oct 1, 1952</u>	Time _____ AM PM
Purpose	<u>To reach critical point with control rod in center of reactor.</u>	

10-2-52  
 Ellis  
 Scott

INSTRUMENT CHECK					
Time	8:30 AM		Source PB267		
	Channel				
	A	B	C	D	E
Range	$\frac{10}{1000}$	(	$10^{-6}$	$\frac{10}{1000}$	900V
Source Dist.	15"	OK	6"	6'	2"
% F.S. Trip	35		100	25	100
	Counts 142 OK				

2 3.00  
 A 2.50

MULTIPLICATION					
Scaler	c: 5	1 min		Mult.	1/M
1	$211 \times 16 + 14$	42.4	42.7	6.5	.152
2	$132 \times 16 + 11$	26.5	25.7	9.5	.369
3	$124 \times 16 + 7$	24.9			

9th loading - 46 tubes

MULTIPLICATION					
Scaler	c: 5	1 min		Mult.	1/M
1	$586 \times 16 + 10$	79		6.5	.082
2	$138 \times 16 + 5$	27.6		9.5	.34
3	$137 \times 16 + 7$				

10<sup>th</sup> Loading 51 Tubes

10:30 AM

MULTIPLICATION				
Scaler	c/5	min	1 min	Mult. 1/M
1	269X16+51	215.8	217.2	6.5
	273X14+31	218.6		.03
2	308X16+0	61.6	61.4	9.5
	305X16+13	61.1		15
3				

11<sup>th</sup> Loading 55 tubes

CRITICAL POSITIONS		
Exp	2	Run 1
Control Post		Channel
0.005	A 88	1000/25
3.000	C .0045	
A 2.500	C 7.8	10 <sup>-10</sup>
B 16.000 <sup>54.54</sup>	D 78	1000/100
	E 3.4	900 V
Tim Crit. 11:05	AM	Duration min.

Tube #64 into 10-11

56 tubes

CRITICAL POSITIONS			
C.A.	<u>9</u>	Expr.	<u>2</u> Run <u>2</u>
Table Pos.		L	T R
	Control Rod		Channel
1	<u>0.005</u>	A	<u>47 1000/25</u>
2	<u>2.500</u>	B	<u>:0021</u>
	<u>A 2.500</u>	C	<u>3.8 10<sup>-10</sup></u>
	<u>B 22.860</u> <sup>103.7</sup>	D	<u>75 1000/50</u>
		E	<u>2. 1.5 900V</u>
Tim Crit.	<u>2:06</u>	<del>AM</del> PM	Duration _____ min.

Rod B inserted to 0.08, Rod A withdrawn to ~ 15 in.  
 Rod A was then adjusted to 16.332 to produce positive period.  
 Levelled with Rod B.

CRITICAL POSITIONS			
C.A.	<u>9</u>	Expr.	<u>3</u> Run <u>1</u>
Table Pos.		L	T
	Control Rod		Channel
1	<u>0.005</u>	A	<u>69 1000/100</u>
2	<u>2.500</u>	B	<u><del>52</del> .01</u>
	<u>A 16.332</u>	C	<u>4.3 5 X 10<sup>-10</sup></u>
	<u>B 8.033</u>	D	<u>52 1000/100</u>
		E	<u>2.7 750 V.</u>
Tim Crit.	<u>2:35</u>	<del>AM</del> PM	Duration _____ min.

108

Withdraw rod A to ~~18.033~~ to produce level.  
 Level with rod A. <sup>18.033</sup>

CRITICAL POSITIONS			
C.A.	9	3	Run 2
Table Pos.			
	Control Rod		Channel
1	0.005	A	37 1000/20
2	2.500	B	.0015
A	16.420	C	3.8 10 <sup>-10</sup>
B	<del>18.033</del> 8.033	D	56 1000/50
		E	.4 750 V
Tim Crit.	2:55	PM	Duration min.

Inserted rod A to 15.820 to produce (+) period  
 Levelled w/rod B.

CRITICAL POSITIONS			
C.A.	9	Expr. 3	Run 3
Table Pos.			
	Control Rod		Channel
1	0.005	A	67 1000/100
2	2.500	B	.02
A	15.820	C	4.1 5 x 10 <sup>-10</sup>
B	9.670	D	51 1000/100
		E	2.7 750 V
Tim Crit.		PM	Duration min.

withdrew rod A to 17.82 to reduce level  
 leveled w/rod A. 109

CRITICAL POSITIONS			
C.A. <u>9</u>	Expr. <u>3</u>	Run <u>4</u>	
Table Pos. _____		L _____ T _____ R _____	
Control Rod	Channel		
1 <u>0.005</u>	A <u>32</u>	<u>1000/25</u>	
2 <u>2.500</u>	B <u>.0011</u>		
A <u>15.960</u>	C <u>2.6</u>	<u>10<sup>-10</sup></u>	
B <u>9.670</u>	D <u>46</u>	<u>1000/50</u>	
	E <u>.3</u>	<u>750V</u>	
Tim Crit. _____		AM PM	Duration _____ min.

Inserted rod A 15.420 to produce (+) period.  
 leveled w/rod B.

CRITICAL POSITIONS			
C.A. <u>9</u>	Expr. <u>3</u>	Run <u>5</u>	
Table Pos. _____		L _____ T _____ R _____	
Control Rod	Channel		
1 <u>0.005</u>	A <u>84</u>	<u>1000/100</u>	
2 <u>2.500</u>	B <u>.025</u>		
A <u>15.420</u>	C <u>4.0</u>	<u>5 x 10<sup>-10</sup></u>	
B <u>10.690</u>	D <u>64</u>	<u>1000/500</u>	
	E <u>3.4</u>	<u>750V</u>	
Tim Crit. <u>4:06</u>		AM PM	Duration _____ min.

110 Upper Limit Switches on Rods 1 + 2 adjusted to stop at ~ 2.50 inches. Needle Rods not changed.

#1 - 2.615

#2 - 2.553

INSTRUMENT CHECK					
Time	8:30 AM		Source PB267		
	Channel				
	A	B	C	D	E
Range	$\frac{10}{1000}$	1	$10^{-10}$	$\frac{10}{1000}$	900V
Source Dist.	15"	OK	6"	5'	3"
% F.S. Trip	45	1	100*	18	100*
Counts 1+2 OK					

C.A.	9	Expr.	3	Run	6
Sheet		Date	10-3	1952	Time 8:45 AM
Purpose	Continuation of Rod B Calibration (Weak ARE Reg. Rod)				



CRITICAL POSITIONS

CA 9    Expt 3    Run 6

Table             T             R         

Control Pos.	Channel
1 <u>2.615</u>	A <u>65</u> <u>100/100</u>
2 <u>2.553</u>	B <u>.0015</u>
A <u>15.487</u>	C <u>4.2</u> <u>5x10<sup>-11</sup></u>
B <u>10.690</u>	D <u>54</u> <u>1000/50</u>
	E <u>1.1</u> <u>900V</u>

Tim Crit. ~~9:10~~ 8:50 <sup>AM</sup> <sub>PM</sub>    Duration 20 min.

*Inserted A to 14.990 to produce positive period level with B*

*Temp. at 9:20 AM  
1.3964*

CRITICAL POSITIONS

CA 9    Expt 3    Run 7

Table             T             R         

Control Pos.	Channel
1. <u>2.615</u>	A <u>53</u> <u>1000/100</u>
2. <u>2.553</u>	B <u>.012</u>
A <u>14.990</u>	C <u>3.4</u> <u>5x10<sup>-10</sup></u>
B <u>11.750</u>	D <u>40</u> <u>1000/500</u>
	E <u>1.9</u> <u>750V</u>

Tim Crit. 9:10 <sup>AM</sup> <sub>PM</sub>    Duration 17 min.

112

withdrew rod A to 16,990 to reduce level.  
Level with A.

CRITICAL POSITIONS					
CA	9	Expr.	3	Run	8
Tube Pos.		I	T	R	
Control Rod		Channel			
1	2.615	A	34	1000/25	
2	2.553	B	.0012		
A	15.052	C	3.7	10 <sup>-10</sup>	
B	11.750	D	99	1000/25	
		E	.3	750V	
Tim Crit.	9:27	<del>PM</del> AM	Duration		min.

Insert rod A to 14.652 to produce (+) period.  
Level B.

Temp. 10:57 AM.  
1.3954

CRITICAL POSITIONS					
CA	9	Expr.	3	Run	9
Tube Pos.		I	T	R	
Control Rod		Channel			
1	2.615	A	52	1000/100	
2	2.553	B	.012		
A	14.650	C	3.2	5X10 <sup>-10</sup>	
B	12.475	D	39	1000/500	
		E	2.1	750V	
Tim Crit.	9:52	<del>PM</del> AM	Duration	25	min.

~~Inserted~~ withdrawn rod A to 16.650 to  
reduce level.  
Level with A.

CRITICAL POSITIONS			
C.A.	9	Expr.	3 Run 10
Table Pos.		I	T R
Control Rod		Channel	
	2.615	A	32 1000/25
	2.552	B	.0010
A	14.740	C	3.4 10 <sup>-10</sup>
B	12.477	D	91 1000/25
		E	.4 750V
Tim Crit.	10:17	AM PM	Duration 34 min.

Inserted rod A to ~~14.652~~ 14.240 to produce  
a positive period. Level B.

iod.

Temp. at 10:55AM.  
1.3933

CRITICAL POSITIONS			
C.A.	9	Expr.	3 Run 11
Table Pos.		I	T R
Control Rod		Channel	
	2.615	A	53 1000/100
	2.552	B	0.011
A	14.240	C	3.3 5x10 <sup>-10</sup>
B	13.260	D	39 1000/500
		E	2.2 750V
Tim Crit.	10:51	AM PM	Duration 20 min.

withdrew rod A to 16.240 to reduce level.  
Level with A.

CRITICAL POSITIONS					
C.A.	9	Expr.	3	Run	12
Table Pos.		L	T	R	
	Control Rod		Channel		
1	2.615	A	34		$\frac{1000}{25}$
2	2.552	B	.0010		
A	14.342	C	3.6		$10^{-10}$
B	13.260	D	96		$\frac{1000}{25}$
		E	0.4		750V
Tim Crit.	11:11	<del>PM</del> AM	Duration	22	min.

Insert Rod A to 13.840 to produce + period  
Sealed with B

CRITICAL POSITIONS					
C.A.	9	Expr.	3	Run	13
Table Pos.		L	T	R	
	Control Rod		Channel		
1	2.615	A	53		$\frac{1000}{100}$
2	2.552	B	.017		
A	13.840	C	3.2		$5 \times 10^{-10}$
B	13.935	D	40		$\frac{1000}{500}$
		E	2.2		750V
Tim Crit.	11:33	<del>PM</del> AM	Duration	22	

Shot down at 11:55 A

Started up at 1:00 PM.

Put at 13.935 level with H (low level) 115

CRITICAL POSITIONS			
CA	9	Expr.	3 Run 17
Table Pos.		L	T R
	Control Rod		Channel
1	2.615	A	34 $10^{+25}$
	2.552	B	.0012
A	13.910	C	3.2 $10^{-10}$
B	13.935	D	97 $10^{+25}$
		E	1.1 900V
Tim Crit.	1:00	<del>AM</del> PM	Duration 19 min.

3 next rod at to 13.410 to produce positive period. Send with KS

CRITICAL POSITIONS			
CA	9	Expr.	3 Run 15
Table Pos.		L	T R
	Control Rod		Channel
1	2.615	A	52 $1000/100$
	2.552	B	.011
A	13.410	C	3.2 $5 \times 10^{-10}$
B	14.630	D	39 $1000/500$
		E	2.1 750V
Tim Crit.	1:19	<del>AM</del> PM	Duration 16 min.

116

withdrew rod A to 15.410 to reduce level.  
level with A.

## CRITICAL POSITIONS

9      Expr. 3      Run 16

Control Rod

Channel

2.615

A 32 1000/25

2.552

B 0.0010

A 13.505

C 3.7  $10^{-10}$ 

B 14.630

D 92 1000/25

E 0.4 750V

Tim Crit. 1:35      ~~AM~~ PM Duration 15 min.

Inserted rod A to 13.020 to produce (+)  
period. Level with B.

## CRITICAL POSITIONS

C.A. 9      Expr. 3      Run 16 (M)

Table Pos.

Control Rod

Channel

1 2.615

A 56 1000/100

2 2.552

B .012

A 13.020

C 3.5  $5 \times 10^{-10}$ 

B 15.210

D 43 1000/300

E 2.4 750V

Tim Crit. 1:50      ~~AM~~ PM Duration 24 min.

Withdraw rod A to 15.02 To reduce level.  
level with A.

117

CRITICAL POSITIONS			
C.A.	9	Expr.	3 Run 17
Table Pos. _____			
Control Rod		Channel	
1	2.615	A	33 1000/25
2	2.552	B	.0011
A	13.140	C	3.9 10 <sup>-10</sup>
B	15.210	D	96 1000/25
		E	.4 750V
Tim Crit.	2:14	<del>AM</del> PM	Duration 17 min.

Inserted rod A to 12.640 To produce (+)  
period. Level with B.

CRITICAL POSITIONS			
C.A.	9	Expr.	3 Run 18
Table Pos. _____			
Control Rod		Channel	
1	2.615	A	52 1000/100
2	2.552	B	.012
A	12.640	C	4.0 5x10 <sup>-10</sup>
B	15.746	D	40 1000/50
		E	2.1 750V
Tim Crit.	2:31	<del>AM</del> PM	Duration 27 min.

118

Withdrew rod A to 14.640 to reduce level.  
Level with A.

CRITICAL POSITIONS		
CA	9	Expr. 3 Run 19
Table Pos		I T F
Control Rod		Channel
1	2.615	A 31 $10^{00}/25$
2	2.552	B .001
A	12.810	C 3.7 $10^{-10}$
B	15.747	D 90 $10^{00}/25$
		E .4 750V
Tim Crit.	2:58	PM Duration _____ min.

Inserted rod A to 12.310 to produce (+)  
period. Level with B.

CRITICAL POSITIONS		
CA	9	Expr. 3 Run 20
Table Pos		I T F
Control Rod		Channel
	same	A 52 $10^{00}/100$
	same	B .012
A	12.310	C 3.2 $5 \times 10^{-10}$
B	16.183	D 97 $10^{00}/200$
		E 2.2 750V
Tim Crit.	3:21	PM Duration 21 min.



Withdraw rod A to 14.310 to reduce level.  
Level with A.

119

CRITICAL POSITIONS			
C.A.	9	Expr.	3 Run 21
Table Pos.		L	T R
	Control Rod		Channel
1	2.615	A	33 $\frac{1000}{25}$
2	2.552	B	.0011
A	<del>4.4</del> 12.440	C	3.7 $10^{-10}$
B	16.184	D	92 $\frac{1000}{25}$
		E	.4 750 V
Tim Crit.	3:42	<del>AM</del> PM	Duration 28 min.

Temp at 4:19 P.M.

3.4054

(+) Inserted rod A to 11.84 to produce (+) period.  
Level with B.

CRITICAL POSITIONS			
C.A.	9	Expr.	3 Run 22
Table Pos.		L	T R
	Control Rod		Channel
1	2.615	A	56 $\frac{1000}{100}$
2	2.552	B	.013
A	11.840	C	3.4 $5 \times 10^{-10}$
B	16.780	D	43 $\frac{1000}{500}$
		E	2.3 750 V
Tim Crit.	4:10	<del>AM</del> PM	Duration 32 min.

INSTRUMENT CHECK

Time	8:30 AM		Source P8262		
	Channel				
	A	B	C	D	E
Range	$\frac{10}{1000}$		$10^{-10}$	$\frac{10}{1000}$	900V
Source Dist.	18	OK	8"	6'	3"
% F.S. Trip	40		100 <sup>+</sup>	20	100 <sup>+</sup>
	Counters 1+2 OK				

C.A.	9	Expr.	3	Run	23
Sheet		Date	10-4-1952	Time	8:45 AM
Purpose	Continuation of Rod B Calibration.				
	(Weak ARE Reg. Rod)				

CRITICAL POSITIONS			
C.A.	<u>9</u>	Expr.	<u>3</u> Run <u>23</u>
Table Pos.		L	T R
	Control Rod		Channel
1	<u>2.615</u>	A	<u>34</u> <u>1000/25</u>
2	<u>2.552</u>	B	<u>.0012</u>
A	<u>11.855</u>	C	<u>3.8</u> <u>10<sup>-10</sup></u>
B	<u>16.780</u>	D	<u>98</u> <u>1000/25</u>
		E	<u>.9</u> <u>900 V.</u>
Tim Crit.	<u>9:57</u>	<del>PM</del> <sup>AM</sup>	Duration _____ min.

Inserted A to 11.255 to produce (+) period.  
Levelled with Rod B.

CRITICAL POSITIONS			
C.A.	<u>9</u>	Expr.	<u>3</u> Run <u>24</u>
Table Pos.		L	T R
	Control Rod		Channel
1	<u>2.615</u>	A	<u>51</u> <u>1000/100</u>
	<u>2.552</u>	B	<u>.011</u>
A	<u>11.255</u>	C	<u>3.2</u> <u>5X10<sup>-10</sup></u>
B	<u>17.460</u>	D	<u>95</u> <u>1000/200</u>
		E	<u>3.8</u> <u>810 V.</u>
Tim Crit.	<u>9:04</u>	<del>PM</del> <sup>AM</sup>	Duration _____ min.

122

withdrew Rod A to 13.255 to reduce level.  
 Levelled with A.

CRITICAL POSITIONS			
C.A.	9	Expr.	3 Run 25
Table Pos.			
	Control Rod		Channel
1	2.615	3.2	1000/25
2	2.552	B	.0011
A	11.350	C	3.6 10 <sup>-10</sup>
B	17.460	D	95 1000/25
		E	.4 810 V.
Tim Crit.	9:21	AM PM	Duration min.

Inserted Rod A to 10.750 to produce (+) period  
 Levelled with Rod B.

CRITICAL POSITIONS			
C.A.	9	Expr.	3 Run 26
Table Pos.			
	Control Rod		Channel
1	2.615	A	50 1000/100
2	2.552	B	.011
A	10.750	C	3.0 5 x 10 <sup>-10</sup>
B	18.010	D	93 1000/200
		E	3.6 810 V.
Tim Crit.	9:45	AM PM	Duration min.

l. withdraw Rod A to 12.750 to reduce level.  
 Levelled with A. 123

CRITICAL POSITIONS			
C.A.	9	Expr.	3 Run 27
Table Pos.		L	T R
	Control Rod		Channel
1	2.615	A	33 1000/25
2	2.552	B	.0011
A	10.850	C	3.4 10 <sup>-10</sup>
B	18.010	D	94 1000/25
		E	.5 810V.
Tim Crit.	10:03	AM PM	Duration _____ min.

Inserted to Rod A to 10.250 to produce (+) period. Levelled with Rod B.

CRITICAL POSITIONS			
C.A.	9	Expr.	3 <del>3</del> Run 28
Table Pos.		L	T R
	Control Rod		Channel
1	2.615	A	50 1000/100
2	2.552	B	.011
A	10.250	C	2.9 5x10 <sup>-10</sup>
B	19.540	D	92 1000/200
		E	3.5 810V
Tim Crit.	10:36	AM PM	Duration _____ min.

Withdrew Rod A to 12.250 to reduce level.  
Levelled with Rod A.

CRITICAL POSITIONS					
C.A.	9	Expt.	3	Run	29
Table Pos.					
	Control Rod		Channel		
1	2.615	A	34	1000/25	
2	2.552	B		.0012	
A	10.410	C	3.4	10 <sup>-10</sup>	
B	18.540	D	97	1000/25	
		E	.5	810 V.	
Tim Crit.	11:07	AM	Duration	min.	

Inserted Rod A to 9.810 to produce (+) period.  
Levelled with Rod B.

CRITICAL POSITIONS					
C.A.	9	Expt.	3	Run	30
Table Pos.					
	Control Rod		Channel		
1	2.615	A	48x	1000/100	
2	2.552	B		0.011	
A	9.810	C	2.8x5x10	10 <sup>-10</sup>	
B	18.980	D	89x	1000/200	
		E	3.4	810V	
Tim Crit.	11:27	AM	Duration	20 min.	

Withdraw Rod A to 9.810 to reduce level  
 Levelled with Rod A. 125

CRITICAL POSITIONS			
C.A.	9	Expr.	3
		Run	31
Table Pos.	L	T	R
	Control Rod		Channel
1	2.615	A	32 1000/25
2	2.552	B	.001
A	9.980	C	3 10 <sup>-10</sup>
B	18.980	D	88 1000/25
		E	.5 810 V
Tim Crit.	12:04	<del>AM</del> PM	Duration 23 min.

Insert Rod A to 9.18 to produce (+) period  
 Levelled with Rod B.

CRITICAL POSITIONS			
C.A.	9	Expr.	3
		Run	32
Table Pos.	L	T	R
	Control Rod		Channel
1	2.615	A	46 1000/100
2	2.552	B	.01
A	9.180	C	2.9 5 X 10 <sup>-10</sup>
4	19.570	D	85 1000/200
		E	3.4 810 V
Tim Crit.	12:21	<del>AM</del> PM	Duration 17 min.

withdrew Rod A to 11.180 to reduce level.  
Levelled with Rod A.

CRITICAL POSITIONS			
C.A.	<u>9</u>	Expr.	<u>3</u> Run <u>33</u>
Table Pos.		L	T R
	Control Rod		Channel
1	<u>2.615</u>	A	<u>34</u> <u>1000/25</u>
2	<u>2.552</u>	B	<u>.0011</u>
A	<u>9.340</u>	C	<u>3.6</u> <u>10<sup>-10</sup></u>
B	<u>19.570</u>	D	<u>95</u> <u>1000/25</u>
		E	<u>.5</u> <u>810 V.</u>
Tim Crit.	<u>12:41</u>	<del>AM</del> PM	Duration <u>20</u> min.

Insert Rod A to 8.440 to produce (+) period  
Level with Rod B.

CRITICAL POSITIONS			
C.A.	<u>9</u>	Expr.	<u>3</u> Run <u>34</u>
Table Pos.		L	T R
	Control Rod		Channel
1	<u>2.615</u>	A	<u>49</u> <u>1000/100</u>
2	<u>2.552</u>	B	<u>.01</u>
A	<u>8.440</u>	C	<u>3.0</u> <u>5 X 10<sup>-10</sup></u>
B	<u>20.210</u>	D	<u>90</u> <u>1000/200</u>
		E	<u>3.6</u> <u>810 V.</u>
Tim Crit.	<u>1:01</u>	<del>AM</del> PM	Duration <u>20</u> min.



Withdraw Rod A to 10.940 to reduce level  
 Leveled with Rod A. 127

CRITICAL POSITIONS			
CA	9	Expr.	3
		Run	36
Table Pos.	L	T	R
Control Rod	Channel		
1	2.615	A	3.5    1000/25
2	2.552	B	.0012
A	8.645	C	3.9    10 <sup>-10</sup>
B	20.210	D	98    1000/25
		E	.6    810 V.
Tim Crit.	1:21	AM PM	Duration <u>20</u> min.

Insert Rod A to 7.745 to produce (+) period  
 Leveled with Rod B.

CRITICAL POSITIONS			
CA	9	Expr.	3
		Run	36
Table Pos.	L	T	R
Control Rod	Channel		
1	2.615	A	49    1000/100
2	2.552	B	.011
A	7.745	C	3.0    5 X 10 <sup>-10</sup>
B	20.755	D	90    1000/200
		E	3.6    810 V.
Tim Crit.	1:50	AM PM	Duration <u>29</u> min.

withdrew Rod A to 10.745 to reduce level.  
 Levelled with Rod A.

CRITICAL POSITIONS			
C.A.	<u>9</u>	Expr	<u>3</u> Run <u>37</u>
Table Pos.		L	T R
	Control Rod		Channel
1	<u>2.615</u>	A	<u>34</u> <u>1000/25</u>
2	<u>2.552</u>	B	<u>.0011</u>
A	<u>8.010</u>	C	<u>3.8</u> <u>10-10</u>
B	<u>20.755</u>	D	<u>95</u> <u>1000/25</u>
		E	<u>.6</u> <u>810 V.</u>
Tim Crit.	<u>2:09</u>	<del>AM</del> PM	Duration <u>19</u> min.

<sup>6.810</sup>  
 Inserted Rod A to ~~6.180~~ to produce (+) peria.  
 Levelled with Rod B.

CRITICAL POSITIONS			
C.A.	<u>9</u>	Expr	<u>3</u> Run <u>38</u>
Table Pos.		L	T R
	Control Rod		Channel
1	<u>2.615</u>	A	<u>50</u> <u>1000/100</u>
2	<u>2.552</u>	B	<u>.01</u>
A	<u>6.810</u>	C	<u>3.2</u> <u>5x10-10</u>
B	<u>21.410</u>	D	<u>95</u> <u>1000/250</u>
		E	<u>3.7</u> <u>810 V.</u>
Tim Crit.	<u>2:27</u>	<del>AM</del> PM	Duration <u>18</u> min.

Withdrawn Rod A to 9.810 to reduce level  
 Lets leveled with Rod A. 129

CRITICAL POSITIONS			
C.A.	9	Expr.	3
		Run	37
Table Pos.		L	T
Control Rod	Channel		
1	2.615	A	34 1000/25
2	2.552	B	.0011
A	7.200	C	3.7 10 <sup>-10</sup>
B	21.410	E	.6 810V
		D	97 1000/25
Tim Crit.	2:42	<del>AM</del> PM	Duration 15 min.

Inserted Rod A to 5.600 to produce (+) period.  
 Leveled with Rod B.

CRITICAL POSITIONS			
C.A.	9	Expr.	3
		Run	40
Table Pos.		L	T R
Control Rod	Channel		
1	2.615	A	50 1000/100
2	2.552	B	.01
A	5.600	C	3.1 5 X 10 <sup>-10</sup>
B	22.090	D	93 1000/200
		E	3.6 810V
Tim Crit.	3:04	<del>AM</del> PM	Duration 22 min.

130

57 tubes

Shut down and  
Added tube #57  
to 11-4. In order  
to allow the removal  
of Rod A.

CRITICAL POSITIONS			
G.A.	9	Expr.	3 Run 41
Table Pos.		T	R
	Control Rod		Channel
1	2.618	A	<del>3.2</del> 3.5 1000/25
2	2.552	B	.001
A	13.85	C	2.8 10 <sup>-10</sup>
B	22.090	D	88 1000/25
		E	1.0 900 V
Tim Crit.	3:37	<del>AM</del> PM	Duration _____ min.

Inserted Rod A to 13.35 to produce (+) period  
Levelled with Rod B.

CRITICAL POSITIONS			
C.A.	9	Expr	3 Run 42
Table Pos.		T	R
	Control Rod		Channel
1	2.618	A	93 1000/50
2	2.552	B	.01
A	13.350	C	5.5 2.25X10
B	22.835	D	85 1000/200
		E	3.5 810 V.
Tim Crit.	3:52	<del>AM</del> PM	Duration _____ min.

Withdraw Rod A to 15.350 to reduce level.  
 Levelled with rod A.

131  
 10/4/52

CRITICAL POSITIONS			
C.A.	9	Expr.	3
		Run	43
Table Pos. _____ L _____ T _____ R _____			
Control Rod		Channel	
1	2.618	A	31 1000/25
2	2.552	B	0.001
A	13.495	C	.9 2.5 x 10 <sup>-6</sup>
B	22.834	D	85 1000/25
		E	0.5 810V
Tim Crit.		4:10	AM PM Duration _____ min.

Inserted A at 13.00 + period - level with B -

CRITICAL POSITIONS			
C.A.	9	Expr.	3
		Run	44
Table Pos. _____ L _____ T _____ R _____			
Control Rod		Channel	
1	2.618	A	50 x 1000/100
2	2.552	B	0.01
A	13.000	C	5.9 x 2.5 x 10 <sup>-10</sup>
B	{ 23.500 23.500	D	92 x 1000/200
		E	3.8 @ 810V.
Tim Crit.		AM PM	Duration _____ min.

4:45P Shut down -

25  
 0  
 5  
 V

rod

150  
 5 x 10<sup>-10</sup>  
 200  
 V

132

10-6-52

C.A. 9      Expr. 3      Run 45  
 Sheet \_\_\_\_\_      Date 6 Oct 1952      Time 9:00 <sup>AM</sup>/<sub>PM</sub>  
 Purpose Cont calibration of Pool  
B

INSTRUMENT CHECK

Time 8:30 <sup>AM</sup>/<sub>PM</sub>      Source PB267

	Channel				
	A	B	C	D	E
Range	$\frac{10}{1000}$	015	$10^{-10}$	$\frac{10}{100}$	900
Source Dist.	15"		6"	4"	3"
% F.S. Trip	45	6	100	30	100
	ARB Count 1-2 O.K.				

CRITICAL POSITIONS

C.A. 9    Expr. 3    Run 45

Table Pos. \_\_\_\_\_ I \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
1 <u>2.615</u>	A <u>29</u> <u>1000/25</u>
2 <u>2.553</u>	B <u>0.0009</u>
# <u>13.005</u>	C <u>1.7</u> <u>10<sup>-10</sup></u>
B <u>23.500</u>	D <u>78</u> <u>1000/25</u>
	E <u>.9</u> <u>900V</u>

Tim Crit. 9:14    ~~PM~~ <sup>AM</sup> Duration 7 min.

*I inserted A to 12.400 to produce (+) period level with B.*

CRITICAL POSITIONS

9    Expr. 3    Run 46

\_\_\_\_\_ I \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
<u>same</u>	A <u>50</u> <u>1000/100</u>
<u>same</u>	B <u>.01</u>
A <u>12.400</u>	C <u>3.5</u> <u>5x10<sup>-10</sup></u>
B <u>24.710</u>	D <u>94</u> <u>1000/200</u>
	E <u>3.6</u> <u>810V</u>

Tim Crit. 9:21    ~~PM~~ <sup>AM</sup> Duration 25 min.

134

Withdraw A to 14.400 To reduce level.  
Level with A.

CRITICAL POSITIONS					
C.A.	9	Expr.	3	Run	47
Table Pos.		I	T	R	
	Control Rod		Channel		
	same	A	32	1000/25	
	same	B	.0011		
A	12.500	C	5.7	$10^{-10}$	
B	24.710	D	90	1000/25	
		E	.6	810V	
Tim Crit.	9:46	<del>PM</del> AM	Duration	19	min.

Inserted A to 11.900 To produce (+) period.  
Level with B.

CRITICAL POSITIONS					
C.A.	9	Expr.	3	Run	48
Table Pos.		I	T	R	
	Control Rod		Channel		
	2.614	A	51	1000/100	
	2.553	B	.01		
A	11.900	C	3.4	$5 \times 10^{-10}$	
B	25.935	D	95	1000/200	
		E	3.6	710V	
Tim Crit.	10:05	<del>PM</del> AM	Duration	19	min.

7



Withdraw A to 13,900 to reduce level.  
Level with A.

135

CRITICAL POSITIONS			
CA	9	Expr.	3
		Run	49
Table Pos.		I	T R
	Control Rod		Channel
1	same	A	31 1000/25
2	same	B	.001
A	<del>11.925</del>	C	.8 5X10 <sup>-10</sup>
B	25.935	D	85 1000/25
		E	.5 710V
Tim Crit.	10:24	AM	Duration 29 min

Inserted Rod A to 11,200 to produce (+) period.  
Level with B.

Temp at 11:28  
1.3821

CRITICAL POSITIONS			
CA	9	Expr.	3
		Run	50
Table Pos.		I	T R
	Control Rod		Channel
	same	A	32 1000/100
	same	B	.01
A	11,200	C	3.4 5X10 <sup>-10</sup>
B	28.580	D	96 1000/200
		E	3.6 810V
Tim Crit.	10:58	AM	Duration 20 min

136

Withdraw rod A to 13.200 to reduce level.  
Level with A.

CRITICAL POSITIONS			
C.A.	9	Expt.	3
Table Pos.		Run 51	
Control Rod		Chammel	
1	2.614	A	32 1000/25
2	2.553	B	.0012
A	11.330	C	0.8 $5 \times 10^{-10}$
B	28.580	D	92 1000/25
		E	.6 710 V
Tim Crit.	11:18	AM PM	Duration 23 min.

Insert Rod A to 10.750 to produce (+) period  
Level with Rod B.

with Rod B  
all way out  
power level  
period still  
increased.

CRITICAL POSITIONS			
C.A.	9	Expt.	3
Table Pos.		Run 52	
Control Rod		Chammel	
1	2.614	A	
2	2.553	B	
A		C	
B		D	
		E	
Tim Crit.	11:41	AM PM	Duration min.

Reset B to 28.580. withdraw A to 13.650 to reduce level. leveled with A 137

CRITICAL POSITIONS			
C.A.	9	Expr.	3 Run 53
Table Pos.		L	T R
	Control Rod		Channel
1	2.614	A	28 1000/25
2	2.553	B	.00095
	A 11.380	C	.8 5 X 10 <sup>-10</sup>
	B 28.580	D	76 1000/25
		E	.7 7.50V
Tim Crit.	11:58	AM PM	Duration min.

Insert Rod A to ~~7.8~~ <sup>10.900</sup> to produce a positive period. Level with rod B.

rod

With Rod B all way out power level still increases

CRITICAL POSITIONS			
C.A.	9	Expr.	3 Run 54
Table Pos.		L	T R
	Control Rod		Channel
1	2.614	A	
2	2.553	B	
3		C	
4		D	
		E	
Tim Crit.		AM PM	Duration min.

React Rod B back to 28.580 and  
Withdraw A to 13.650 to reduce level.  
Level with A.

CRITICAL POSITIONS		
C.A.	<u>9</u>	Exp. <u>3</u> Run <u>55</u>
Table Pos. _____		
Control Rod		
1	<u>2.614</u>	A <u>32</u> <u>1000/25</u>
2	<u>2.553</u>	F <u>0.001</u>
A	<u>11.330</u>	C <u>0.8</u> <u>5X10<sup>-10</sup></u>
B	<u>28.580</u>	D <u>91</u> <u>1000/25</u>
E <u>0.6 @ 710V</u>		
Tim Crit.	AM	PM Duration _____ min.

Inserted A to 11.030 to produce (+) period.

Levelled with B.

Reactor was still  
rising after a very  
long period.

Temp. 1:29 P.M.

1.3819

CRITICAL POSITIONS		
C.A.	<u>9</u>	Exp. <u>3</u> Run <u>56</u>
Table Pos. _____		
Control Rod		Channel
1	<u>2.614</u>	A <u>50</u> <u>1000/100</u>
2	<u>2.553</u>	B <u>.01</u>
A	<u>11.030</u>	C <u>8.5 X 2.5 X 10<sup>-10</sup></u>
B	<u>31.000</u>	D <u>93</u> <u>1000/200</u>
E <u>3.7</u> <u>810V</u>		
Tim Crit.	AM	PM Duration <u>45</u> min.

withdrew Rod B to 33.400 and observed (+) period. Levelled with Rod A. 139

Temp.  
2:15 P.M.  
1.3822

CRITICAL POSITIONS			
C.A.	9	Expr.	3
		Run	57
Table Pos.		L	T
		R	
Control Rod		Channel	
1	2.615	A	58 1000/200
2	2.553	B	.03
A	11.230	C	2.9 10 <sup>-9</sup>
B	33.400	D	87 1000/500
		E	4.5 750 V.
Tim Crit.		1:50	Duration 17 min.

~~Inserted rod A to~~ ~~to produce (+) period.~~  
~~Level with B.~~ Withdrew Rod A and inserted Rod B to 1.00 in. Levelled with

CRITICAL POSITIONS			
C.A.	9	Expr.	3
		Run	58
Table Pos.		L	T
		R	
Control Rod		Channel	
1	2.615	A	32 1000/25
2	2.553	B	.001
A	21.375	C	6.2 10 <sup>-10</sup>
B	1.000	D	91 1000/25
		E	.6 810 V
Tim Crit.		2:07	Duration min.

1/100  
10<sup>-10</sup>  
200  
V

140

I inserted rod A to 20.875 to produce (+) period.  
Levelled with B

CRITICAL POSITIONS					
CA	9	Expr.	3	Run	59
Table Pos.		L	T	R	
	Control Rod		Channel		
1	same	A	53	1000/100	
2	same	B	.01		
A	20.875	C	7.1	$2.5 \times 10^{-10}$	
B	7.590	D	98	1000/200	
		E	3.9	810V	
Tim Crit.	2:30	AM PM	Duration	23	min.

Withdrew rod A to 22.875 to reduce level.  
I inserted B to 2.00 in, level with A

CRITICAL POSITIONS					
CA	9	Expr.	3	Run	60
Table Pos.		L	T	R	
	Control Rod		Channel		
1	2.615	A	33	1000/25	
2	2.553	B	.001		
A	21.440	C	5.9	$10^{-10}$	
B	2.000	D	91	1000/25	
		E	.6	810V	
Tim Crit.	2:48	AM PM	Duration	16	min.

rod.

Inserted rod A to 20.940 to produce a (+) period. Levelled with B. 141

CRITICAL POSITIONS			
C.A.	9	Expr.	3 Run 61
Table Pos.		I	T R
	Control Rod		Channel
1	2.615	A	52 1000/100
2	2.553	B	.013
A	20.940	C	3.5 5x10 <sup>-10</sup>
B	7.318	D	94 1000/200
		E	3.8 810V
Tim Crit.	3:04	<del>AM</del> PM	Duration 21 min.

rod.

Withdrawn rod A to 22.940 to reduce level. Inserted B to 3.00 in. Level with A.

CRITICAL POSITIONS			
C.A.	9	Expr.	3 Run 62
Table Pos.		I	T R
	Control Rod		Channel
1	same	A	33 1000/25
2	same	B	.0012
A	21.490	C	5.9 10 <sup>-10</sup>
B	3.000	D	93 1000/25
		E	.6 810V
Tim Crit.	3:26	<del>AM</del> PM	Duration 17 min.

CRITICAL POSITIONS

C.A. 9    Expr. 3    Run 63

Table Pos. \_\_\_\_\_

Control Rod	Channel
1 <u>same</u>	A <u>51</u> <u>1000/100</u>
2 <u>same</u>	B <u>.012</u>
A <u>20.990</u>	C <u>3.4</u> <u>5x10<sup>-10</sup></u>
B <u>7.070</u>	D <u>94</u> <u>1000/200</u>
	E <u>3.8</u> <u>810V</u>

Tim Crit. 3:43    ~~PM~~    Duration 10 min.

Insert rod A to 20.990 To produce (+) period. Levelled with B.

withdrew rod A to 22.99.  
 Inserted B to 3.400 and levelled with A.

CRITICAL POSITIONS

A 9    Expr. 3    Run 64

Table Pos. \_\_\_\_\_

Control Rod	Channel
1 <u>same</u>	A <u>33</u> <u>1000/25</u>
2 <u>same</u>	B <u>.0011</u>
A <u>21.515</u>	C <u><del>9.8</del> 5.3</u> <u>10<sup>-10</sup></u>
B <u>3.400</u>	D <u>90</u> <u>1000/25</u>
	E <u>.6</u> <u>810V</u>

Tim Crit. 3:59    ~~AM~~ PM    Duration \_\_\_\_\_ min.



Inserted A to 21.015 level with B.  
21.015

143  
9/10/6/52

CRITICAL POSITIONS

CA 9    Expr. 3    Run 65

Table Pos.                    I    T    R

Control Rod                    Channel

1 power                    A 53 x 1000/100

2 lane                    B 0.01

A 21.015                    C 2.8 K.S x 10<sup>-10</sup>

B 6.950                    D 96 x 1000/200

E 3.9 @ 210V.

Tim Crit: 4:35 <sup>AM</sup> PM    Duration \_\_\_\_\_ min.

144

10-6-52

C.A.	9	Expr.	4	Run	1
Sheet		Date	95	Time	7:45 <sup>AM</sup> PM
Purpose	Range Truff. at several radii of CH-8 type fuel element				

For 9.4.1 (Zero Run) Fuel element  
 # 57 removed from position 11-4 and  
 element # 64 removed from 10-11 (55 tub)

3W0

CRITICAL POSITIONS

C.A.	9	Expr.	4	Run	1
Table Pos.		I	T	R	
	Control Rod		Channel		
1	2.615	A	86	$\frac{100}{200}$	
2	2.550	B	.004		
A	0.033	C	7	$\frac{1000}{1000}$	
B	16.510	D	70	$\frac{1000}{1000}$	
		E	3.0	900	✓
Tim Crit.	8:23	<sup>AM</sup> PM	Duration	15	min.

58.7  
29.7  
29.04

Remove Tube # 72 from 9-8  
 → Placed Tube # 46 in 9-8 (#46 has ZA-8 type fuel)  
 55 tubes

tubes

46 in 9-8			
CRITICAL POSITIONS			
CA	9	Expr.	4 Run 2
Table Pos.		L	T R
	Control Rod		Channel
1	2.615	A	89 $\frac{100}{200}$
2	2.550	B	.007
A	0.030	C	7.1 $2 \times 10^{10}$
B	12.393	D	70 $\frac{1000}{100}$
		E	3.1 900V
Tim Crit.	9:00	AM/PM	Duration 21 min.

58.7  
37.6  
21.14

Removed # 68 from 10-8 55 tubes  
 Replaced # 72 in 9-8  
 → Placed # 46 in 10-8

10-8

CRITICAL POSITIONS

C.A. 9 Expr. 7 Run 3

Table Pos. \_\_\_\_\_

Control Rod	Channel	
1 <u>2.615</u>	A <u>91</u>	<u>100</u> <u>200</u>
2 <u>2.550</u>	B <u>.004</u>	
A <u>0.030</u>	C <u>7.2</u>	<u>10-10</u>
B <sup>37.6</sup> <u>13.615</u>	D <u>7.2</u>	<u>1000</u> <u>100</u>
	E <u>3.1</u>	<u>900V</u>

Tim Crit. 9:43 <sup>AM</sup> PM Duration 19 min.

58.7  
44.2  
14.54

Replaced #68 in 10-8  
Placed #46 in 11-8  
Removed #12 from 11-8

55 tubes

Temp  
10:15 P  
1.382 m

11-8

CRITICAL POSITIONS

C.A. 9 Expr. 4 Run 4

Table Pos. \_\_\_\_\_

Control Rod	Channel	
1 <u>2.615</u>	A <u>85</u>	<u>1000</u> <u>200</u>
2 <u>2.550</u>	B <u>.0045</u>	
A <u>0.030</u>	C <u>7.0</u>	<u>10-10</u>
B <sup>44.2</sup> <u>14.635</u>	D <u>6.8</u>	<u>1000</u> <u>100</u>
	E <u>2.9</u>	<u>900V</u>

Tim Crit. 10:20 <sup>AM</sup> PM Duration 10 n.

58.7 Replaced #12 in 11-8  
 49.7  
 9.0 Removed #45 from 12-8  
 Placed #46 in 12-8

55 tubes

46 L 12-8

CRITICAL POSITIONS

CA. 9 Expr. 4 Run 5

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel	
<u>2.615</u>	A <u>88</u>	<u>100</u> <u>200</u>
<u>2.548</u>	B <u>0.5</u>	
A <u>0.030</u>	C <u>7.0</u>	<u>10-10</u> <u>1000</u>
<sup>49.75</sup> B <u>15.285</u>	D <u>70</u>	<u>100</u>
	E <u>2-9</u>	<u>900</u> ✓

Tim Crit. 10:49 <sup>AM</sup> PM Duration 11 min.

Removed 45 from 12-8 Placed #45 in 12-8  
 Replaced #64 in 10-11 & 57 in 11-4  
 Removed #53 and ~~54~~ from 6-9, #65 in 6-9 (empty)  
 Placed #39 into 11-3

57 full tubes + 1 empty

C.A. 9 Expr. 5 Run 1  
 Sheet \_\_\_\_\_ Date 1/17 1952 Time AM  
 Purpose Foil Traverses - some for some Al catches

INSTRUMENT CHECK

Time \_\_\_\_\_ AM \_\_\_\_\_ PM \_\_\_\_\_ Source \_\_\_\_\_

Range	Channel				
	A	B	C	D	E
	<u>10/1000</u>	<u>OK</u>	<u>10<sup>-10</sup></u>	<u>10/100</u>	<u>900R</u>
Source Dist.	<u>12"</u>			<u>5'</u>	<u>5"</u>
% F.S. Trip	<u>55</u>			<u>25</u>	<u>100</u>

#142 OK -

*Tube 58 placed in 9-4 tube <sup>(33)</sup> in 7-11. Tube 25 out of 4-7*

*Pat. (1:34 P.M.)  
 Temperature  
 3.3840*

CRITICAL POSITIONS

C.A. 9 Expr. 5 Run 1a

Tube Pos. \_\_\_\_\_ I \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
<u>1</u> <u>in</u>	A _____
<u>2</u> <u>in</u>	B <u>0.01</u>
<u>A</u> <u>in</u>	C _____
<u>B</u> <u>18"</u>	D _____
	E _____

Tim Crit. \_\_\_\_\_ AM \_\_\_\_\_ PM Duration \_\_\_\_\_ min.

*(58 tubes)  
 (6 attempts)*

Add JB to 9-4 } approx 81.74  
 33 to 7-11 }

B  
 18" -70.04  
 22.7 +103  
 +48.7  
 81.7

#25

CRITICAL POSITIONS	
C.A. <u>9</u>	Expr. <input checked="" type="checkbox"/> Run <u>1b</u>
Table Pos: _____ L _____ T _____ R _____	
Control Rod	Channel
1 <u>du</u>	A _____
2 <u>du</u>	B <u>0.001</u>
A <u>~8.9"</u>	C _____
B <u>cut</u>	D _____
	E _____
Tim Crit: _____	AM PM Duration _____ min.

48.74

Removed tube 25 from ~~4-7~~ (JB tubes + 1 empty)

2 tubes  
 out)

CRITICAL POSITIONS	
C.A. <u>9</u>	Expr. <input checked="" type="checkbox"/> Run <u>1c</u>
Table Pos: _____ L _____ T _____ R _____	
Control Rod	Channel
1 <u>du</u>	A _____
2 <u>du</u>	B <u>0.001</u>
A <u>du</u>	C _____
B <u>22.7</u>	D _____
	E _____
Tim Crit: _____	AM PM Duration _____ min.

150

12/7/5<sup>v</sup>

~~Subs~~

Remove 15 from 6-7  
added 80 to 6-7 (Substitution of  
an al fuel tube for a stainless tube  
to gain some reactivity).

CRITICAL POSITIONS	
9	Expr. 5 Run 1d
Table Pos	L T R
Control Rod	Channel
1 in	A
2 in	B
A 9.00 in	C
B out	D
	E
Tim Crit.	AM PM Duration min.

Remove #80 from 6-7 returned #15 to 6-7  
Returned #25 to 4-7

probably 5<sup>0</sup>  
(5 tubes)  
(1 empty)



C.A. 9 Expr. 5 Run 2  
 Sheet \_\_\_\_\_ Date Oct 8, 1952 Time 9:00 ~~AM~~ ~~PM~~  
 Purpose Fail Traverses

INSTRUMENT CHECK

Time 8:20 ~~AM~~ ~~PM~~ Source P0267

	Channel				
	A	B	C	D	E
Range	$10^{1000} \cdot 0K$		$10^{100}$	$10^{100}$	500V
Source Dist.	16"		5"	6"	2.5"
% F.S. Trip	35		100%	24	100%

*Counter 122 OK*

59  
27

①

CRITICAL POSITIONS

C.A. 9 Expr. 5 Run 2

Table Pos. \_\_\_\_\_ I \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

	Control Rod	Channel
1	<u>2.618</u>	A <u>20</u> $\frac{1000}{1000}$
2	<u>2.550</u>	B <u>.048</u>
B	<u>33.400</u>	C <u>4.8</u> $10^{-9}$
A	<u>9.053</u>	D <u>74</u> $1000$
		E <u>3.5</u> <u>690V</u>

Tim Crit: 9:12  $\frac{20}{60}$  ~~AM~~ ~~PM~~ Duration 20 min.

## Foil Location for 9.5.2

## Catchers

113	24.4.4 (1/2)	-1.25	Std
112	18.11.5 (3/4)	-1.25	
111	18.13.3 (3/4)	-1.25	

1.25" In # E-1 30.6.3 -0-0

## Indian Bar

C-30	18.8.7 (1/2)	-1 1/32
C-24	18.8.7 (1/2)	-1 1/16
C-36	18.9.8 (1/4)	1 23/32
C-35	18.9.8 (1)	2 7/32
C-34	18.11.8 (1)	-.94

## Indian Cd round

C-9	0.11.8 - (1)	- 25/32
C-2	6.11.8 - (1)	- 25/32
C-15	12.11.8 - (1)	- 25/32
C-6	18.11.8 - (1)	- 25/32
C-14	24.11.8 - (1)	- 25/32
C-19	30.11.8 - (1)	- 5/32
C-23	36.11.8 - (1)	- 25/32

## Foil Location for 9.5.3

## Catches

✓ # 115 24-4-4  $\left(\frac{1}{6}\right)$  - 1.25 STD.  
 ✓ Cl # ~~114~~ 114 18-11-5  $\left(\frac{3}{4}\right)$  - 1.25  
 ✓ # 116 18-13-3  $\left(\frac{3}{4}\right)$  - 1.25

1.25" Au #E1 30-6-3- $\textcircled{0}$ -0

## Indium Bare

#C33 0-11-8- $\textcircled{0}$  -  $\frac{25}{32}$   
 #C28 6-11-8- $\textcircled{0}$  -  $\frac{25}{32}$   
 #C26 12-11-8- $\textcircled{0}$  -  $\frac{25}{32}$   
 #C22 18-11-8- $\textcircled{0}$  -  $\frac{25}{32}$   
 #C21 24-11-8- $\textcircled{0}$  -  $\frac{25}{32}$   
 #C18 30-11-8- $\textcircled{0}$  -  $\frac{25}{32}$   
 #C10 36-11-8- $\textcircled{0}$  -  $\frac{25}{32}$

## Indium Cl. Cvd.

# C1 18-8-7 -  $\left(\frac{1}{2}\right)$  -  $1\frac{1}{32}$   
 # C5 18-8-7 -  $\left(\frac{1}{2}\right)$  -  $1\frac{1}{16}$   
 # C13 18-9-8 -  $\textcircled{4}$  -  $1\frac{23}{32}$   
 # C17 18-9-8  $\textcircled{1}$   $\frac{25}{32}$   
 # C3 18-14-8  $\textcircled{1}$  .94

(2)

CRITICAL POSITIONS

C.A. 9      Expr. 5      Run 3

Table Pos. \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod		Channel	
1	<u>2.658</u>	A	<u>51</u> $\frac{1000}{500}$
2	<u>2.571</u>	B	<u>0.051</u>
A	<u>6.358</u>	C	<u>2.8</u> $2.5 \times 10^{-9}$
B	<u>33.395 (out)</u>	E	<del>105</del> <u>4.9</u> $\times 690V$
		F	<u>93</u> $\frac{1000}{1000}$

Tim Crit. 11:36 ~~AM~~ Duration 20 min.

Catcher #118 18-12-4 - (3/4) 1.25  
 Cd. #117 18-14-2 - (3/4) 1.25  
 ↓ #119 24-4-4 - (1/6) 1.25

Indium Bars

#C 40 18-6-9 - (6) -  $1\frac{23}{32}$   
 #C 32 18-6-9 - (0) - 0  
 #C 44 18-14-8 - (4) -  $\frac{25}{32}$   
~~#C 42 18-8-7 - (0) - 0~~  
~~#C 31 18-8-2 - (1/2) -  $1\frac{9}{32}$~~   
~~#C 20 18-8-7 - (1/2) -  $2\frac{1}{16}$~~

# 204 Cd. Core  
 @ 30.6.3-0-0

Indium Cd. cvd.

~~#C 11 18-9-8 - (4) -  $\frac{25}{32}$~~   
~~#C 12 18-9-8 - (0) -  $1\frac{23}{32}$~~   
 ↓ #C 16 18-14-8 Exp  $\frac{1}{16}$  in Incored Shell

Fuel Tube #12 was inadvertently left out of position 11-8 - this omission affects foil exposed in 9-8 + 8-7 since it required the poison rod in 8-7 to be removed about half way - 155

(3)

CRITICAL POSITIONS			
CA	9	Expr	5
		Run	4
Table Pos.		L	T R
Control Rod		Channel	
1	2.619	A	50 $\frac{100}{50}$
	2.544	B	.052
A	0.030	C	5.9 $10^{-9}$
B	19.306	D	90 $\frac{1000}{1000}$
		E	7.1 720V
Tim. Crit.		2:07	AM
		PM	Duration 20 min.

Catches Cd. Rod #122 - 18-12-4 - (3/4) - 1.25  
 #120 - 18-14-2 (3/4) 1.25  
 Std #121 - 18-4-4 (3/4) 1.25

Indium Cd Rod  
 C <sup>39</sup> 18-6-9-0 -  $\frac{23}{32}$   
 C 8 18-6-9-0-0  
 C 27 18-14-8-4 -  $\frac{25}{32}$   
 C 11 18-9-8-4 -  $\frac{25}{32}$   
 C 12 18-9-8-0 -  $\frac{23}{32}$

MN #7 @ 30.6.3.0.0

Indium Bare  
 C 42 18-8-7-0-0  
 C 31 18-8-7-1/2 -  $1\frac{9}{32}$   
 C 20 18-8-7-1/2 -  $2\frac{1}{16}$   
 C 7 18-14-8 Extend to 1/16 in Inconel Shell

156

Qnt 9-52

INSTRUMENT CHECK

Time 9:00 AM  
PM

Source FB267

	Channel				
	A	B	C	D	E
Range	$\frac{10}{1000}$		$10^{-18}$	$\frac{10}{1000}$	900V
Source Dist.	15"	OK	5"	5'	2 1/2"
% F.S. Trip	35		100	24	100%
Counts/sec	152	OK			

CA 9 Expr. 5 Run 5

Sheet 2 Date 10-9 1952 Time 9:15 AM  
PM

Purpose Continue foil irradiation  
(Page 155)

CRITICAL POSITIONS (4)

CA 9 Expr. 5 Run 5


Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

	Control Rod	Channel
1	<u>2.9 2.615</u>	A <u>49</u> <u>1000/500</u>
2	<u>2.548</u>	B <u>.055</u>
A	<u>7.190</u>	C <u>2.2</u> <u>2.5 X 10<sup>-9</sup></u>
B	<u>33.403</u>	D <u>90</u> <u>1000/1000</u>
		E <u>5.3</u> <u>700V</u>

Tim Crit. 9:33<sup>15</sup> AM  
PM Duration 20 min.



discon tabs (11-8)



10000

INSTRUMENT CHECK						
Time <u>9:10</u>	AM	Source <u>BB26</u>				
	PM	Channel				
		A	B	C	D	E
Range		<u>10</u> <u>1000</u>		<u>10</u> <u>1000</u>	<u>10</u> <u>1000</u>	<u>900</u>
Source Dist.		<u>17"</u>	<u>OK</u>	<u>8"</u>	<u>5'</u>	<u>4"</u>
% F.S. Trip		<u>50</u>		<u>100<sup>+</sup></u>	<u>24</u>	<u>100<sup>+</sup></u>
		<u>Counts 14L</u>				

C.A. <u>9</u>	Expr. <u>5</u>	Run <u>7</u>	
Sheet _____	Date _____	195 _____	Time _____ AM PM
Purpose _____			
_____			
_____			



Catchers #123 - 24-4-4 (1) - 1.25 Std

#126 18-9-7 (2) - 1.25 Bar

Indium In\*22 - 18-10-8 (4) - 25/32

cdIn\*26 18-11-8 (4) - 1 23/32

cdIn\*5 18-11-8 (1) 1 23/32


Co\*2 @ 30, 6, 3, 0, 0

cdIn\*44 18-6-9 (6) 25/32

cdIn\*24 18-6-9 (3) 25/32

Inconel Tube

(11-8)



(16)

CRITICAL POSITIONS

C.A. 9    Expr. 5    Run 7

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
1 <u>2.618</u>	A <u>50</u> 1000/500
2 <u>2.549</u>	B <u>.051</u>
A <u>4.660</u>	C <u>2.3</u> 2.5 x 10 <sup>-9</sup>
B <u>33.398</u>	D <u>91</u> 100%/1000
	E <u>4.4</u> 690V

Tim Crit. 9:37:15 AM    Duration 20 min.

160

Catcher

Bar AI #128 18-9-7 - (5/6) 1.25

AI #127 24-4-4 - (1/6) 1.25 Std

cd Cd Mm #8 30-6-3-0-0  
Indium

C6 18-9-8 - (4) - 25/32

C11 18-9-8 - (1) - 1 23/32

cd C32 18-11-8 - (4) - 25/32


cd C31 18-11-8 - (1) - 25/32

~~cd C19~~ 18-8-7 - (0) - 0

cd C21 18-8-7 - (1/2) - 1 9/32

cd C25 18-8-7 - (1/2) - 2 1/16

Second Tuler (11-8) 29



CRITICAL POSITIONS

C 9 Expt 5 Run 8

Probe Pos. \_\_\_\_\_ T \_\_\_\_\_

	Control Rod	Channel
1	2.555	A 46 1000/500
2	2.547	B .054
A	5.020	C 2.3 2.5 x 10 <sup>-9</sup>
B	33.396	D 90 1000/1000
		E 4.3 680V

Tim Crit. 2:47 25/60 AM PM Duration \_\_\_\_\_ min.

Catch

Ed-A1 # 130 18-9-7-(12) 1.25

Ed-A1 # 129 27-4-4-(12) 1.25 Std

Ed-Im E-1 30-6-3-(12) 0


C27 Bare In 18-11-8-0-35/32

C35 Bare In 18-11-8-0-0

C42 Bare In 18-11-8-(4) 35/32

C40 Cd In 18-8-7-(12) 19/32

Second Tube (11-8)



CRITICAL POSITIONS		
CA	9	Exp. 5 Run 9
Table Pos.		L T R
Control Red		Channel
1 2.615	A	50 1000/500
2 2.546	B	.05
A 2.500	C	2.2 2.5217-9
B 3.500	D	90 1000/1000
	E	4.3 680V
Tim Crit.	8:02 <sup>33</sup> / <sub>100</sub>	PM Duration 20 min.


162

10-11-52

INSTRUMENT CHECK					
Time	9:45 AM		Source _____		
	PM		Channel		
Range	A	B	C	D	900V
	$\frac{12}{1000}$		$10^{-10}$	$\frac{10}{100}$	$\frac{10}{100}$
Source Dist.	15	OK	8	5'	3"
% E.S. Trip	35		100*	18	100*
	Counts 1+1 0a				

Norm Catcher #al134 24-4-4  $\frac{1}{6}$  - 1.25' Std  
 Bas Catcher #al131 24-11-5  $\frac{3}{4}$  - 1.25'  
 cd Catcher #al133 18-11-5  $\frac{3}{4}$  - 1.25'  
 cd Catcher #al132 36-11-5  $\frac{3}{4}$  - 1.25'

Incorel Tube (9-8-)



Fuel tube # 72 disconnected from Rod A drive and replaced in (9-8) by Incorel-Cast fuel element

(1)

CRITICAL POSITIONS

C.A. 9      Expr. 5      Run 10

Table Pos. \_\_\_\_\_

Control Rod	Channel
<u>2.609</u>	A <u>35</u> $\frac{1000}{500}$
<u>2.545</u>	B <u>0.049</u>
A <u>0.037</u>	C <u>1.6</u> $2.5 \times 10^{-9}$
B <u>22.588</u>	D <u>70</u> $\frac{1000}{1000}$
	E <u>3.5</u> <u>690V</u>

Tim Crit. 10:11:0 <sup>AM</sup>/<sub>PM</sub>      Duration 20 min.

- \*72 returned to 9-8 and connected to Rod A
- \*53 replacing empty tube in 6-9
- ~~\*47 into 4-8~~
- ~~\*45 into 5-10~~
- \*25 out of 4-7
- \*56 out of 5-9
- \*11 out of 5-8
- \*59 out of 4-6

56



Tube C8 in 10-7

(10)

CRITICAL POSITIONS

C A. 9    Expr. 5    Run 12

Table Pos. \_\_\_\_\_

Control Rod		Channel	
1	<u>2.605</u>	A	<u>50</u> <u>1000/500</u>
2	<u>2.545</u>	B	<u>.055</u>
A	<u>8.270</u>	C	<u>2.2</u> <u>2.5x10<sup>-9</sup></u>
B	<u>0.80</u>	D	<u>90</u> <u>100%/1000</u>
		E	<u>4.3</u> <u>680V</u>

Tim Crit. 1:03<sup>30</sup>/<sub>60</sub>    AM/PM    Duration 20 min.

11 Norm Al# 139 24-4-4 (1/6) 1.25- Std  
Indium

BC8 18-8-7-0-0

cd C12 18-8-7-0-1<sup>9</sup>/<sub>32</sub>

BC7 18-8-7-0-1<sup>11</sup>/<sub>16</sub>

cd C43 18-9-8-0-1<sup>23</sup>/<sub>32</sub>

BC20 18-9-8-0-1<sup>23</sup>/<sub>32</sub>

cd C15 18-10-8-0-2<sup>5</sup>/<sub>32</sub>

BC9 18-10-8-0-1<sup>23</sup>/<sub>32</sub>

CRITICAL POSITIONS		
C.A. <u>9</u>	Expr. <u>5</u>	Run <u>13</u>
Table Pos. _____		
Control Rod	Channel	
1 <u>2.608</u>	A <u>50</u>	$\frac{100}{2000}$
2 <u>2.545</u>	B <u>0.01</u>	
A <u>10.733</u>	C <u>4.9</u>	$2.5 \times 10^{-10}$
B <u>0.084</u>	D <u>40</u>	$\frac{1000}{500}$
	E <u>5.1</u>	<u>840V</u>
Tim Crit. <u>2:31:51</u> <del>PM</del> Duration <u>20</u> min.		

Norm 140 24-4-4- $\text{\textcircled{6}}$  1.25 *std*  
 Indium  
 (12) Cd #C36 18-8-7- $\text{\textcircled{0}}$ -0  
 B #C41 18-8-7-~~0~~ $\text{\textcircled{1}}$ - $\frac{9}{32}$   
 Cd C39 18-8-7- $\text{\textcircled{1}}$ - $\frac{11}{16}$   
 B C3 18-9-8- $\text{\textcircled{4}}$ - $\frac{123}{32}$   
 Cd C18 18-9-8- $\text{\textcircled{1}}$ - $\frac{123}{32}$   
 B C4 18-~~10~~-8- $\text{\textcircled{4}}$ - $\frac{25}{32}$   
 Cd C16 18-10-8- $\text{\textcircled{1}}$ - $\frac{123}{32}$



(12)

CRITICAL POSITIONS

CA 9 Expr 5 Run 14

Table Pos. \_\_\_\_\_ I \_\_\_\_\_ T \_\_\_\_\_ F \_\_\_\_\_

	Control Rod	Channel
1	<u>2.615</u>	A <u>54</u> $\frac{1000}{100}$
2	<u>2.545</u>	B <u>0.011</u>
A	<u>10.551</u>	C <u>4.9</u> $2.5 \times 10^{-10}$
B	<u>0.084</u>	D <u>40</u> $\frac{1000}{500}$
		E <u>5.0</u> <u>840V</u>

Tim Crit. 2:38 ~~PM~~ Duration 20 min.

INSTRUMENT CHECK					
Time	9:20 AM		Source PB267		
	Channel				
	A.	B.	C.	D.	E.
Range	$\frac{10}{1000}$	1	$10^{-6}$	$\frac{10}{1000}$	900V
Source Dist.	12	OK	5"	5'	3"
% F.S. Trip	40	1	100+	25	100+
	Counts 1+2 - OK				

Pat. Temp. 10:00 AM.

1.3793

~~Tube 11 placed into 5-8, Tube 59 into 4-6~~  
 Removed tube 39 from 11-3

These tubes were probably added at this time  
 8/4/53

C.A.	9	Expr.	6	Run	1
Sheet		Date	195	Time	AM PM
Purpose	Danger coll. of incand fuel tube (powder packed) (vs. stainless steel tube)				

CRITICAL POSITIONS

CA 9    Expr. 6    Run 1

Tests For \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
1 <u>2.605</u>	A <u>48</u> <u>100/200</u>
2 <u>2.545</u>	B <u>.0022</u>
A <u>0.028</u>	C <u>4.8</u> <u>5x10<sup>-11</sup></u>
B <sup>10502</sup> <u>23.120</u>	D <u>76</u> <u>1000/50</u>
	E <u>1.5</u> <u>900V</u>

Tim Crit. 10:33    ~~PM~~ <sup>AM</sup> Duration 10 min.

Tube 45 out of 12-8, insert no. 82 into 12-8.

#82 - 12-8

CRITICAL POSITIONS

CA 9    Expr. 6    Run 2

Tests For \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
1 <u>2.600</u>	A <u>90</u> <u>100/100</u>
2 <u>2.544</u>	B <u>.0021</u>
A <u>0.023</u>	C <u>4.6</u> <u>5x10<sup>-11</sup></u>
B <sup>44.94</sup> <u>21.410</u>	D <u>74</u> <u>1000/50</u>
	E <u>1.5</u> <u>900V</u>

Tim Crit. 11:15    ~~PM~~ <sup>AM</sup> Duration 11 min.

105.0  
94.9  
10.14

Pot. Temp 11:26 AM  
1.3784

screen  
at  
5:3



11-8.  
11-8.

Removed inconel <sup>#82</sup> from 10-8, placed it in 171  
9-8.

Returned Tube 68 to 10-8. Removed tube 72  
from 9-8.

105.0  
77.8  
-----  
27.24

#82 - 9-8

CRITICAL POSITIONS

C.A. 9 Expr. 6 Run 5

Table Pos. \_\_\_\_\_ I \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
1 <u>2.600</u>	A <u>94</u> <u>100/100</u>
2 <u>2.544</u>	B <u>.0022</u>
A <u>0.030</u>	C <u>4.5</u> <u>5X10<sup>-11</sup></u>
B <u>19.060</u>	D <u>75</u> <u>1000/50</u>
	E <u>1.5</u> <u>900V</u>

Tim Crit. 11:15 AM  
PM Duration 7 min.

Pat. Temp 2:16 P.M.  
1.3802

4 in 10-8  
68

~~Removed tube 82 from 9-8. Coupling on B  
slipping~~

46.7  
tube 25 placed  
into 4-7.

CRITICAL POSITIONS

C.A. 9 Expr. 6 Run 6

Table Pos. \_\_\_\_\_ I \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
1 <u>2.610</u>	A <u>92</u> <u>100/100</u>
2 <u>2.545</u>	B <u>.0021</u>
A <u>0.030</u>	C <u>4.6</u> <u>5X10<sup>-11</sup></u>
B <u>31.000</u>	D <u>75</u> <u>1000/50</u>
	E <u>1.5</u> <u>900V</u>

very slightly super  
~ 1/8

125.5  
323  
-----  
126.5  
31.923

Tim Crit. 2:13 AM  
PM Duration 6 min.

Remained Tube 82 from 9-8.

void 9-8

CRITICAL POSITIONS

C.A. 9 Expt. 6 Run 7

Table Pos. \_\_\_\_\_ I \_\_\_\_\_ F \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
<u>2.600</u>	A <u>90</u> <u>100/100</u>
<u>2.544</u>	B <u>.0021</u>
A <u>0.033</u>	C <u>4.5</u> <u>5x10<sup>-11</sup></u>
B <u>10.840</u>	D <u>73</u> <u>1000/50</u>
<u>22.74</u> <u>11.163</u>	E <u>1.5</u> <u>900V</u>

Tim Crit. 3:04 AM/PM Duration \_\_\_\_\_ min.

Inc. no. void  
 $\frac{126.5}{22.7} = 103.84$

SS. no. void  
 $\frac{105.0}{48.7} = 2.15$   
 $\frac{153.7}{22.7} = 6.77$   
 $\frac{131.0}{22.7} = 5.77$

Checked and replaced coupling on Rod 1  
 Reset Prod 1 zero to 2.615  
 Reset Prod B zero to 0.084

Exp. 6 Run 8  
 is a rerun of  
 Exp. 6 Run 7

void 9-8

CRITICAL POSITIONS

C.A. 9 Expt. 6 Run 8

Table Pos. \_\_\_\_\_ I \_\_\_\_\_ F \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
1 <u>2.615</u>	A <u>91</u> <u>100/100</u>
2 <u>2.545</u>	B <u>.0021</u>
A <u>.033</u>	C <u>4.8</u> <u>5x10<sup>-11</sup></u>
<u>22.74</u> <u>11.180</u>	D <u>74</u> <u>1000/50</u>
	E <u>1.5</u> <u>900V</u>

Tim Crit. 8:19 AM/PM Duration 15 min.



153.7  
83.4  

---

69.9

mid 11-8

CRITICAL POSITIONS

C.A. 9    Expr. 6    Run 10

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel	
1 <u>2.615</u>	A <u>90</u>	$\frac{100}{100}$
2 <u>2.545</u>	B <u>0.0021</u>	
A <u>0.025</u>	C <u>4.5</u>	$5 \times 10^{-11}$
<sup>83.8%</sup> B <u>19.778</u>	D <u>71</u>	$\frac{1000}{50}$
	E <u>1.5</u>	<u>900V</u>

Tim Crit. 9:34 <sup>AM</sup> PM    Duration 15 min.

Replaced #12 in 11-8  
Removed #45 from 12-8

153.7  
96.4  

---

57.3

mid in 12-8

CRITICAL POSITIONS

C.A. 9    Expr. 6    Run 11

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel	
1 <u>2.615</u>	A <u>91</u>	$\frac{100}{100}$
2 <u>2.545</u>	B <u>.0022</u>	
A <u>0.025</u>	C <u>4.6</u>	$5 \times 10^{-11}$
<sup>96.4%</sup> B <u>21.630</u>	D <u>72</u>	$\frac{1000}{50}$
	E <u>1.5</u>	<u>900V</u>

Tim Crit. 10:07 <sup>AM</sup> PM    Duration 18 min.



**INSTRUMENT CHECK**

Time 9:40 AM  
 Source PB267

Range	Channel				
	A	B	C	D	E
	$\frac{10}{1000}$		$10^{-6} \frac{10}{1000}$	$\frac{10}{1000}$	900V
Source Dist.	<u>14" OK</u>		<u>4"</u>	<u>5'</u>	<u>3"</u>
% F.S. Trip	<u>35</u>		<u>80</u>	<u>20</u>	<u>100</u>
Counts	<u>162 OK</u>				

Removed #68 from 10-8

Returned #45 to 12-8

96.4  
 92.1  
 2.3  
 59.2  
 2.3  
 56.9

C.A. 9 Expr. 7 Run 1

Sheet \_\_\_\_\_ Date \_\_\_\_\_ 195 Time \_\_\_\_\_ AM  
 PM

Purpose Zero run for danger coefficients to be made in 10-8.

*with 106*

**CRITICAL POSITIONS**

C.A. 9 Expr. 7 Run 1

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
1 <u>2.615</u>	A <u>86</u> <u>100/100</u>
2 <u>2.545</u>	B <u>.0021</u>
A <u>0.025</u>	C <u>4.4</u> <u>5X10<sup>-11</sup></u>
B <u>16.600</u>	D <u>70</u> <u>1000/50</u>
	E <u>1.4</u> <u>900V</u>

Tim Crit. 9:14 AM  
 PM Duration 9 min.

Pat. Temp.  
 1.3832  
 at 9:23 AM.

176  
(nickel)

Inserted 1 in. dia. (A) necked solid rod into 10-8.

1" A Ni Rod - 10-8

CRITICAL POSITIONS

C.A. 9 Expt. 7 Run 2

Table Pos. \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod \_\_\_\_\_ Channel \_\_\_\_\_

1 in \_\_\_\_\_ A \_\_\_\_\_

2 in \_\_\_\_\_ B .00015 source in \_\_\_\_\_

3 in \_\_\_\_\_ C \_\_\_\_\_

4 in \_\_\_\_\_ D \_\_\_\_\_

\_\_\_\_\_ E \_\_\_\_\_

Tim Crit. \_\_\_\_\_ AM \_\_\_\_\_ PM Duration \_\_\_\_\_ min.

Removed above "A" nickel rod from 10-8. inserted  
 empty tube # 34 into 10-8; NOT CRITICAL -  $\beta = 0.0009$  source in  
 added  $\checkmark$  tube 39 to 11-3. Empty tube # 34  
shell in 10-8

Pot. Temp at 11:09 AM.  
 1.8832



Replaced tube #34 (Empty) in 10-8  
for the purpose of checking Expt 7 Run 3

106.7  
37.4  

---

69.3

P.T. #34 (Empty) in 10-8

CRITICAL POSITIONS

C.A. 9 Expt. 7 Run 5

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ P \_\_\_\_\_

	Control Rod		Chem. el
1	<u>2.612</u>	A	<u>85</u> <u>100/100</u>
2	<u>2.545</u>	B	<u>.002</u>
<sup>37.44</sup> A	<u>0.025</u>	C	<u>4.3</u> <u>5x10<sup>-11</sup></u>
B	<u>13.594</u>	D	<u>69</u> <u>1000/50</u>
		E	<u>1.4</u> <u>900V</u>

Tim Crit. 12:51 ~~AM~~ PM Duration: 6 min ~~2:5~~ min.

Tube 39 removed from 11-3, 25 from 4-7.  
Tube 34 (Empty) out of 10-8, Inconel (Cast slug filled)  
placed in 10-8.

106.7  
73.8  
32.9  
H

107  
151  
329  
6220

**Inconel & Slugs**  
CRITICAL POSITIONS

C.A. 9 Expr. 7 Run 6

Table Pos. \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
1 <u>2.610</u>	A <u>90</u> <u>100/100</u>
2 <u>2.545</u>	B <u>.0022</u>
A <u>0.025</u>	C <u>4.4</u> <u>5X10<sup>-10</sup></u>
B <sup>73.8</sup> <u>18.460</u>	D <u>72</u> <u>1000/50</u>
	E <u>1.4</u> <u>900V</u>

Tim Crit. 1:21 ~~AM~~ PM Duration 5 min.

Inconel (Cast slug filled) <sup>tube</sup> removed from 10-8. Cast Slugs removed from inconel tube and placed in Stainless-steel tube 34, and 34 placed into 10-8.

Pat. temp  
1.3857  
at 1:42 P.M.

46.4  
46.7  
95.1  
7.7  
87.4

106.7  
99.2  
7.7

**Stainless steel & Slugs**  
CRITICAL POSITIONS

C.A. 9 Expr. 7 Run 7

Table Pos. \_\_\_\_\_ I \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
1 <u>2.608</u>	A <u>85</u> <u>100/100</u>
2 <u>2.545</u>	B <u>.0021</u>
A <u>0.025</u>	C <u>4.3</u> <u>5X10<sup>-11</sup></u>
B <sup>99.0</sup> <u>22.050</u>	D <u>68</u> <u>1000/50</u>
	E <u>1.3</u> <u>900V</u>

Tim Crit. 1:48 ~~AM~~ PM Duration \_\_\_\_\_ min.

Removed St. Steel tube 34 (slug filled) from 10-8, and inserted empty Inconel tube into 10-8. Returned tube 39 to 11-3, and tube 25 to 4-7.

R11 - 106.7  
 13.7  
 93.0

R12 107.2  
 13.7  
 93.5

Inconel # (Empty) in 10-8		CRITICAL POSITIONS	
C.A.	9	Expr.	7
		Run	8
Table Pos. _____			
Control Rod		Channel	
1	2.610	A	84 100/100
2	2.543	B	.0021
A	0.025	C	4.2 5X10 <sup>-11</sup>
B	9.320	D	67 1000/50
		E	1.5 900V
Tim Crit. 2:22		AM PM Duration 6 min.	

Removed empty inconel tube from 10-8, inserted 1.240 Fe rod. Not Critical B, 0.00019. ~~Removed~~  
 Removed 1.240 Fe rod, inserted a iron rod (1/2 in. dia.)

*1/2" Fe Rod in 10-8*  
CRITICAL POSITIONS

C.A. 9    Expr. 7    Run 9

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

	Control Rod		Channel
1	<u>2.610</u>	A	<u>80 85</u> <sup>100/100</sup>
2	<u>2.545</u>	B	<u>.0021</u>
3	<u>0.025</u>	C	<u>4.1</u> <sup>5X10<sup>-11</sup></sup>
4	<sup>5644</sup> <u>16.185</u>	D	<u>68</u> <sup>1000/50</sup>
		E	<u>1.5</u> <sup>900V</sup>

Tim Crit. 3:16 <sup>AM</sup> PM Duration 12 min.

*107.2  
5644  
50.*

*0 Fe*

*1/2 iron tube removed from 10-8, and 1 in. O.D. X 2S Aluminum tube inserted into 10-8.*

*d*

*1 in O.D. Aluminum tube in 10-8.*  
CRITICAL POSITIONS

C.A. 9    Expr. 7    Run 10

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

	Control Rod		Channel
1	<u>2.610</u>	A	<u>49</u> <sup>100/200</sup>
2	<u>2.545</u>	B	<u>.0027</u>
3	<u>0.025</u>	C	<u>4.6</u> <sup>5X10<sup>-11</sup></sup>
4	<sup>105.24</sup> <u>23.155</u>	D	<u>78</u> <sup>1000/50</sup>
		E	<u>1.6</u> <sup>900V</sup>

Tim Crit. 3:42 <sup>AM</sup> PM Duration 14 min.

*107.2  
105.24  
2.0*

182 2S Aluminum tube removed from 10-8  
 (p.d. 1 in) (.035 wall thickness) Michel? Tube is  
 into 10-8.

107  
 35  
 9  
 53

.035 wall Michel 1" Tube  
 CRITICAL POSITIONS

C.A. 9 Expr. 7 Run 11

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ P \_\_\_\_\_

Control Rod	Channel
1 <u>2.610</u>	A <u>88</u> <u>100/100</u>
2 <u>2.545</u>	B <u>.0022</u>
A <u>0.025</u>	C <u>4.3</u> <u>5x10<sup>-11</sup></u>
B <u>15.800</u>	D <u>68</u> <u>1000/50</u>
	E <u>1.5</u> <u>900V</u>

Tim Crit. 4:16 ~~AM~~ PM Duration 6 min.

Pat. temp.  
 1.3877  
 at 4:23 P.M.

Removed 1" Michel tubing from 10-8

Temp @  
 8:05 P  
 1.3877

New zero

Empty hole in 10-8  
 CRITICAL POSITIONS

C.A. 9 Expr. 7 Run 12

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ P \_\_\_\_\_

Control Rod	Channel
1 <u>2.610</u>	A <u>90</u> <u>100/100</u>
2 <u>2.544</u>	B <u>.0025</u>
A <u>0.025</u>	C <u>4.6</u> <u>5x10<sup>-11</sup></u>
B <u>23.522</u>	D <u>90</u> <u>1000/50</u>
	E <u>1.4</u> <u>900V</u>

Tim Crit. 8:10 ~~AM~~ PM Duration 16



inted

Placed 1" HI tube of SiO<sub>2</sub> (Density 1.76) in 10-8 (Tagged end up)

105.2  
-106.1  
-----  
-0.98

SiO<sub>2</sub> in 10-8

CRITICAL POSITIONS

C.A. 9 Expr. 7 Run 13

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control D	Channel
1 <u>2.610</u>	A <u>85</u> <sup>100/100</sup>
2 <u>2.545</u>	B <u>0.0022</u>
A <u>0.024</u>	C <u>4.2</u> <sup>5x10<sup>-4</sup></sup>
B <sup>106.1</sup> <u>23.350</u>	D <u>69</u> <sup>100/50</sup>
	E <u>1.4</u> <sup>900V</sup>

Tim Crit. 8:38 <sup>AM</sup> PM Duration 8 min.

Remove SiO<sub>2</sub> from 10-8

Placed 1" HI tube of NaF (Density 1.08) in 10-8 (Tagged end up)

105.2  
100.7  
-----  
4.50

NaF in 10-8

CRITICAL POSITIONS

C.A. 9 Expr. 7 Run 14

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control D	Channel
1 <u>2.610</u>	A <u>85</u> <sup>100/100</sup>
2 <u>2.544</u>	B <u>0.0022</u>
A <u>0.025</u>	C <u>4.2</u> <sup>5x10<sup>-4</sup></sup>
B <sup>100.7</sup> <u>22.368</u>	D <u>69</u> <sup>100/50</sup>
	E <u>1.4</u> <sup>900V</sup>

Tim Crit. 9:04 <sup>AM</sup> PM Duration 7 min.

Removed Na F from 10-8

Placed 1" Al tube of KF (Density 1.43) in 10-8  
(Tagged and exp)

R-16  
105.2  
- 77.6  
27.6

KF in 10-8

CRITICAL POSITIONS

C.A. 9 Expr. 7 Run 15

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
1 <u>2.610</u>	A <u>87</u> <u>100/100</u>
2 <u>2.545</u>	B <u>0.0022</u>
A <u>0.025</u>	C <u>4.2</u> <u>5 x 10<sup>-4</sup></u>
B <u>18.955</u>	D <u>69</u> <u>1000/50</u>
	E <u>1.4</u> <u>900V</u>

Tim Crit. 9:32 ~~AM~~ PM Duration 13 min.

Removed KF from 10-8

Placed Empty 1" Al tube in 10-8 (w #5 Rubber stopper)

Temp. R  
10:00 PM  
1.389 mV

Zero with tube

Empty 1" Al tube

CRITICAL POSITIONS

C.A. 9 Expr. 7 Run 16

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
1 <u>2.610</u>	A <u>90</u> <u>100/100</u>
2 <u>2.545</u>	B <u>.0025</u>
A <u>0.025</u>	C <u>4.2</u> <u>5 x 10<sup>-11</sup></u>
B <u>23.170</u>	D <u>70</u> <u>1000/50</u>
	E <u>1.5</u> <u>900V</u>

Tim Crit. 10:02 ~~AM~~ PM Duration 12 min.

10-15-52

Ellis  
Scott

INSTRUMENT CHECK					
Time	9:05	AM	Source	PB267	
		PM			
			Channel		
	A	B	C	D	E
Range	$\frac{10}{1000}$	1	$10^0$	$\frac{10}{1000}$	900V
Source Dist.	15"	OK	4"	5'	2 1/2"
% F.S. Trip	37	1	<del>30</del>	18	100%
	Count 142				

C.A.	9	Expr.	7	Run	17
Sheet		Date	10/15	1952	Time 9:10
					AM
					PM
Purpose	Continuation of danger coefficients. (Empty Aluminum tube still in 10-8)				

Empty Al tube

CRITICAL POSITIONS					
C.A.	9	Expr.	7	Run	17
Table Pos.		L	T	R	
	Control Rod		Channel		
1	2.610		A	90	100/100
2	2.545		B	.0021	
A	0.025		C	4.4	$5 \times 10^{-11}$
B	23.200	105.54	D	71	1000/50
			E	1.4	900V
Crit.	9:30	AM	Duration	13	min.
		PM			

Loaded 1 in dia. Aluminum Tube (filled with 12.73 grams Mn.) into 10-8.  
(Removed 1 in dia Empty aluminum tube from 10-8)

~~Added tube 56 to 5-9 - Not Critical -~~  
B, 0.0002

Added tube 56 to 5-9.  
— Not critical, B, .00031 —

Tube 47 placed in 7-4

105.5  
5.0  

---

100.5 R17

51.8  
56.5  

---

108.3  
100.5  


---

208.8

mm in 10-8			
CRITICAL POSITIONS			
C.A.	9	Expt.	7
		Run	18
Table Pos.		L	T R
	Control Rod		Channel
1	2.610	A	92 100/100
2	2.545	B	.0023
A	0.025	C	4.5 5x10 <sup>-4</sup>
B	6.970 5.03d	D	72 1000/50
		E	1.5 900V
Tim Crit.	10:39	AM	9 min.
		PM	<del>10:4</del> min.

Removed Mn filled al tube from 10-8.  
Placed chromium filled al tube  
in 10-8. Cr - 1801.6 gm net.

old m  
from  
steel



Net - 1801.6 gm

-8)

105.5  
107.2  
-1.7

108.3  
-1.7  
106.6

CRITICAL POSITIONS

CA 9    Expr. 7    Run 19

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
<u>2.610</u>	A <u>89</u> <u>100/100</u>
<u>2.545</u>	B <u>.0022</u>
A <u>0.025</u>	C <u>4.3</u> <u>5x10<sup>-11</sup></u>
B <u>23.550</u> <u>107.24</u>	D <u>70</u> <u>1000/50</u>
	E <u>1.5</u> <u>900V</u>

Tim Crit. 11:09 AM    Duration 6 min.

Removed Chromium filled tube and inserted Cobalt filled Al. tube in 10-8.    1969.0 grams net.

CRITICAL POSITIONS

CA 9    Expr. 7    Run 20

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
<u>NOT CRITICAL</u>	A _____
<u>Source ch</u>	B <u>0.0002</u>
	C _____
	D _____
	E _____

Tim Crit. \_\_\_\_\_ AM    Duration \_\_\_\_\_ min.

10/11/54

Removed Co filled all tube from 10-8  
 Inserted slid A-Ni rod - 1" diameter - 10-8

Temp 11:58 AM  
 1.386 mV

APZ 107.2  
 97.8  
 56+47 = 103.3  
 206.10

CRITICAL POSITIONS	
C.A. <u>9</u>	Expr. <u>7</u> Run <u>21</u>
Table Pos. _____ L _____ T _____	
Control Rod	Channel
1 <u>2.610</u>	A <u>92 x 100 / 100</u>
2 <u>2.545</u>	B <u>0.0023</u>
A <u>0.025</u>	C <u>44 x 5 x 10<sup>-11</sup></u>
B <u>8.290</u> <sup>9.48</sup>	D <u>72 x 1000 / 50</u>
	E <u>1.5 @ 900v</u>
Tim Crit. <u>11:50 AM</u>	PM Duration <u>10</u> min.

69.9  
 9.4  
 60.5

A-Ni Rod still in 10-8

Placed tube # 26 in 4-5

Temp @ 12:30 PM  
 1.3855 mV

CRITICAL POSITIONS	
C.A. <u>9</u>	Expr. <u>7</u> Run <u>22</u>
Table Pos. _____ L _____ T _____	
Control Rod	Channel
1 <u>2.610</u>	A <u>90. 100 / 100</u>
2 <u>2.536</u>	B <u>0.0022</u>
A <u>0.024</u>	C <u>4.3 5 x 10<sup>-11</sup></u>
B <u>17.940</u> <sup>69.9x</sup>	D <u>700 1000 / 50</u>
	E <u>1.5 @ 900v</u>
Tim Crit. <u>12:17</u> <sup>PM</sup>	Duration <u>14</u> min.

Part 1.240" dia. Fe rod in 10-8  
 Removed A-N: from 10-8

107.2  
 79.3  
 ---  
 27.9  
 109.3 <sup>56#27</sup>  
 60.5  
 ---  
 196.78

CRITICAL POSITIONS			
CA	9	Expr.	7 Run 23
Table Pos.		L	T R
	Control Rod		Channel
1	2.610	A	92 100/100
2	2.546	B	.0025
#	0.025	C	4.4 5x10 <sup>-11</sup>
B	19.170 <sup>79.34</sup>	D	70 1000/50
		E	1.5 900V
Tim Crit.	12:59	AM PM	Duration 1.0 min.

Temp at 1:17 P.M.  
 1.3852

12 <sup>rod</sup>  
 107.2 <sup>rod</sup>  
 109.3 <sup>56#27</sup>  
 60.5 <sup>26</sup>  
 39.3 <sup>28</sup>  
 ---  
 327.38

Removed the filler Rod (1.240" dia.) from 10-8  
 Placed label filled tube in 10-8. 1969.0 grams net.

- Not Critical - B, = .00037

Tube no 28 into 5-10

- Not Critical - B, = .001 (source in)

Source removed and negative period observed  
 indicated the reactor subcritical by ~ 12% <sup>+9%</sup> <sub>-7%</sub>  
 Since the total value of the Cobalt tube is great <sup>#3</sup>  
 this measurement should suffice.



Removed Co filled tube from 10-8  
 Place 1" A-Ni rod in 10-8

R22  $\frac{109.2}{69.9} = 39.5$

CRITICAL POSITIONS			
C.A.	9	Expr.	7 Run 24
Table Pos.		I	T R
	Control Rod		Channel
1	2.610	A	86 100/100
2	2.545	B	.0024
A	0.024	C	4.5 $5 \times 10^{-11}$
B	23.930 <sup>109.24</sup>	D	68 1000/50
		E	1.5 900V
Tim Crit.	3:04	<del>AM</del> PM	Duration 10 min.

Temp. at 3:12 P.M.  
 1.3883

$\frac{109.2}{9.4} = 99.84$

Removed tube 26 from 4-5  
 Removed tube 28 from 5-10

CRITICAL POSITIONS			
C.A.	9	Expr.	7 Run 25
Table Pos.		I	T R
	Control Rod		Channel
1	2.610	A	89 100/100
2	2.545	B	.0025
A	0.020	C	4.3 $5 \times 10^{-11}$
B	8.290 <sup>9.44</sup>	D	70 1000/50
		E	1.5 900V
Tim Crit.	3:31	<del>AM</del> PM	Duration 3 min.

Removed 1 in. (A) Nickel ~~rod~~ from 10-8.

I inserted Cobalt filled Al. tube in 10-8.

(5/8 in dia tube) 3/32 wall thickness. \*

Slugs .395 dia Loading 719.1 grams Cobalt.

$$\begin{array}{r} 107.2 \\ - 25.1 \\ \hline 82.1 \\ - 88.3 \\ \hline 108.3 \\ - 190.4 \\ \hline - 1.5 \\ \hline 188.9 \end{array}$$

Temp at 1.3890

Co @ island		CRITICAL POSITIONS	
CA	9	Expr.	7
		Run	26
Table Pos.		L	T
		R	
	Control Rod		Channel
1	2.610	A	93 $\frac{100}{100}$
2	2.545	B	.0025
A	0.025	C	4.4 $5 \times 10^{-11}$
B	11.580 $25.1 \%$	D	22 $\frac{1000}{50}$
		E	1.6 900V
Tim Crit.	4.57	AVT PM	Duration 10 min.

Removed 5/8 in Cobalt filled tube from 10-8, and inserted Chromium filled tube into 10-8. (See Run 19)

Removed fuel tube #47 from 7-4

$$\begin{array}{r} \text{Run 19} \quad 107.2 \\ - 50.7 \\ \hline \text{Run 27} \quad 56.5 \end{array}$$

CRITICAL POSITIONS

C.A. 9    Expt. 7    Run 27

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
1 <u>2.610</u>	A <u>88 x 100 / 100</u>
2 <u>2.545</u>	B <u>0.0022</u>
A <u>0.025</u>	C <u>43 x 5 x 10<sup>-3</sup></u>
B <u>15.460 50.7</u>	D <u>70 x 100 / 5</u>
	E <u>1.5 e 900</u>

Tim Crit. 4:27    ~~AM~~ PM    Duration 10 min.

Remove Zn filled A1 tube from 10-8  
 Placed 1/2" Iron Rod in 10-8  
 Purpose: To evaluate End tube = 56 in 5-9 (See Run 9)

Temp. @  
 8:06 PM  
 1.390 mV

CRITICAL POSITIONS

C.A. 9    Expt. 7    Run 28

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
1 <u>2.610</u>	A <u>90</u> <u>104/100</u>
2 <u>2.545</u>	B <u>.0022</u>
<del>A</del> <u>0.025</u>	C <u>4.5</u> <u>5 x 10<sup>-11</sup></u>
B <u>23.750 108.24</u>	D <u>90</u> <u>1000 / 50</u>
	E <u>1.5</u> <u>900V</u>

Tim Crit. 8:10    ~~AM~~ PM    Duration 11 min.

108.2  
 56.4  
 51.8

Removed Fuel tube # 39 from 11-3

Purpose: To evaluate F.T. # 39

108.2  
61.8  
46.4

$\frac{1}{2}$ " Fe rod in 10-8

CRITICAL POSITIONS

C.A. 9 Expr. 7 Run: 29

Table Pos. \_\_\_\_\_ I \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

	Control Rod	Channel	
1	<u>2.610</u>	A <u>90</u>	$\frac{100}{100}$
2	<u>2.545</u>	B <u>.0022</u>	
A	<u>0.025</u>	C <u>4.4</u>	$5 \times 10^{-11}$
B	<u>16.930</u> <sup>61.9%</sup>	D <u>70</u>	$\frac{100}{50}$
		E <u>1.5</u>	900V

Tim Crit. 8:45 <sup>PM</sup> Duration 8 min.

Run 9)

<sup>40" long</sup>  
 Cu in 1.001" O.D. Al tube with 25 #1  
 tube insert. Insert was 39" long with <sup>with</sup> 0.290545"  
 Total WT of Cu = 1193.1 gm

Replaced #39 (Fuel Tube) in 11-3

Placed Cu (1193.1 gm) in 1" Al tube in 10-8

Removed  $\frac{1}{2}$ " Fe rod from 10-8

~~CR in Al with island~~  
**CR in Al with island**  
**CRITICAL POSITIONS**

C.A. 9 Expr. 7 Run 30

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
1 <u>2.610</u>	A <u>93</u> <u>100/100</u>
2 <u>2.545</u>	B <u>0.0022</u>
A <u>0.025</u>	C <u>5.3</u> <u>5x10<sup>-4</sup></u>
B <u>18.960</u> <u>77.7</u>	D <u>74</u> <u>1000/50</u>
	E <u>1.6</u> <u>900V</u>

Tim Crit. 9:20 <sup>\*\*\*</sup>PM Duration 9 min.

46.4  
 57.8  
 98.2  
 -21.9  
 76.30

55.8  
 77.7  
 -21.9

Removed Cr tube (w island) from 10-8  
 Inserted 1/2" O.D. Fe Pipe into 10-8  
 Removed FT #39 from 11-3

79.8  
 61.8  
 17.0

50.8 Value of Fe led  
 17.0  
 33.84

1/2" Fe Pipe  
**CRITICAL POSITIONS**

C.A. 9 Expr. 7 Run 31

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
1 <u>2.610</u>	A <u>83</u> <u>100/100</u>
2 <u>2.545</u>	B <u>0.0021</u>
A <u>0.025</u>	C <u>4.9</u> <u>5x10<sup>-11</sup></u>
B <u>19.110</u> <u>78.80</u>	D <u>68</u> <u>1000/50</u>
	E <u>1.5</u> <u>900V</u>

Tim Crit. 9:46 <sup>\*\*\*</sup>PM Duration 10 min.



196

10/16/52

INSTRUMENT CHECK

Time 8:30 PM Source 267

	Channel				
	A	B	C	D	E
Range	<u>10/1000</u>	<u>OK</u>	<u>10<sup>-6</sup></u>	<u>10/1000</u>	<u>900V</u>
Source Dist.	<u>15" 24"</u>		<u>OK</u>	<u>4"</u>	<u>2 1/2"</u>
% F.S. Trip	<u>40%</u>			<u>20</u>	<u>100</u>

#1 + 2 OK

F Tube 56 out of 5-9

F Tube 39 out of 11-3

Mr filled tube removed from 10-8, All tubes (Empty but on island) placed in 10-8

C.A. 9    Expr. 7    Run 33

Sheet           Date        195        Time        AM  
       PM

Purpose Continuation of danger  
Coefficient

*Zero Al. tube with island*

*Al. tube with island*

CRITICAL POSITIONS

C.A. 9 Expt. 7 Run 33

Table Pos. \_\_\_\_\_ I \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod		Channel	
1	<u>2.609</u>	A	<u>33</u> <u>100/200</u>
2	<u>2.545</u>	B	<u>0.0019</u>
A	<u>0.022</u>	C	<u>3.5</u> <u>5x10<sup>-11</sup></u>
B	<u>16.155</u> <sup>50.84</sup> <sub>55.84</sub>	D	<u>50</u> <u>100/500</u>
		E	<u>1.1</u> <u>900V</u>

Tim. Crit. 10:19 <sup>AM</sup> ~~PM~~ Duration 12 min.

*Temp 10:38 AM  
1.3860*

*Removed empty al. tube from 10-8  
Place no. 68 S.S. tube in 10-8  
Remove tube 25 from 4-7.*

CRITICAL POSITIONS

C.A. 9 Expt. 7 Run 34

Table Pos. \_\_\_\_\_ I \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod		Channel	
1	<u>2.609</u>	A	<u>38</u> <u>100/200</u>
2	<u>2.544</u>	B	<u>.0021</u>
A	<u>0.020</u>	C	<u>4.0</u> <u>5x10<sup>-11</sup></u>
B	<u>23.335</u> <sup>106.1</sup>	D	<u>59</u> <u>100/500</u>
		E	<u>1.2</u> <u>900V</u>

Tim. Crit. 11:07 <sup>AM</sup> ~~PM~~ Duration 13 min.

*Temp at 11:17 AM  
1.3860*

*empty*



Removed #66 from 5-4

Removed #59 from 4-6


106.1  
6.8  
99.3

CRITICAL POSITIONS	
C.A. <u>9</u>	Expr. <u>7</u> Run <u>35</u>
Table Pos. _____	L _____ T _____ R _____
Control Rod	Channel
1 <u>2.609</u>	A <u>40</u> <u>100/200</u>
2 <u>2.545</u>	B <u>0.002</u>
A <u>0.019</u>	C <u>8.0</u> <u>2.5 X 10<sup>-11</sup></u>
B <u>7.535</u> <u>6.8</u>	D <u>60</u> <u>100/500</u>
	E <u>1.3</u> <u>900V</u>
Tim Crit. <u>11:44</u>	AM <u>13</u> min. PM _____

Removed FT #68(55) from 10-8  
Inserted Al. FT #80 into 10-8

68.2  
6.8  
61.4

CRITICAL POSITIONS	
C.A. <u>9</u>	Expr. <u>7</u> Run <u>36</u>
Table Pos. _____	L _____ T _____ R _____
Control Rod	Channel
1 <u>2.609</u>	A <u>40</u> <u>100/200</u>
2 <u>2.545</u>	B <u>.0015</u>
3 <u>0.020</u>	C <u>8.2</u> <u>2.5 X 10<sup>-11</sup></u>
4 <u>17.730</u> <u>68.2</u>	D <u>62</u> <u>100/500</u>
	E <u>1.4</u> <u>900V</u>
Tim Crit. <u>12:13</u>	AM _____ min. PM _____



PRINTED IN U.S.A.

.200 0.04

© 1941 BY THE BRUSH

On Run 36 the level was raised to 0.01 and Rod #2 was dropped. The vibration knocked Safety Rod #1 loose from its magnet. The estimated value of Rod #2 is #6.2 and of Rod 1 & 2 combined is #11.

Temp @  
3.45 P  
1.3885 mvr.

Removed Ad. FT #80 from 10-8, replaced FT #68 into 10-8

6" x 9" (2 3/8 x 2 7/8 SS Blocks) S. Stud was placed on top of the fuel tubes (See Chart for location)

12.7  
6.8 R 35  
5.9 P S. Stud

CRITICAL POSITIONS			
C.A.	9	Expr.	7 Run 37
Table Pos.		L	T R
	Control Rod		Channel
1	2.610	A	89 $\frac{100}{100}$
2	2.540	B	0.002
A	0.021	C	out
B	<del>9.123</del> 9.123 <sup>12.7</sup>	D	71 $\frac{100}{50}$
		E	1.6 900 V
Tim Crit.	3:58	PM	Duration 19 min.

Chamber B moved ~~to~~ close to the reactor (on sup ladder  
 ~4 ft from mid plane edge.)  
 Stainless Steel removed from top of reactor and  
 replaced with Na (6" x 9") (See Chart).

Temp @ 4:52 PM  
 1.3852

9.7  
 6.8 + 35  
 2.94 Na

CRITICAL POSITIONS			
C.A.	9	Expt.	7
		Run	38
Table Pos.		L	T
	Control Rod		Channel
1	2.610	A	86 $\frac{100}{100}$
	2.540	* B	0.0034
	A 0.020	C	out
	B 8.365 <sup>9.7</sup>	D	70 $\frac{1000}{50}$
		E	1.5 900V
Tim Crit.	450	PM	Duration 22 min.

Na	Can #	Can Wt.	Na wt (Net)
	00126	33.156 gm	121.568 gm
	00137	32.484	121.357
	00131	33.530	119.964
	00128	32.876	120.667
	00127	32.984	120.502
	00136	32.864	121.737

## INSTRUMENT CHECK

Time 9:00 <sup>AM</sup> ~~PM~~ Source PB 267

Channel

	A	B	C	D	E
Range	<u>10</u> <u>1000</u>			<u>10</u> <u>1000</u>	<u>900</u>
Source Dist.	<u>16"</u>	<u>OK</u>	<u>out</u>	<u>4 1/2'</u>	<u>2 1/2'</u>
% F.S. Trip	<u>30</u>			<u>22</u>	<u>100*</u>

Counters 1 + 2 OK

Removed F.T. # 68 from 10-9. <sup>Probably 10<sup>-8</sup> DR</sup>

Inserted Al tube @ in 10-4

Inserted F.T. 66 in 5-4, Inserted F.T. # 59 in 4-6, Inserted F.T. # 25 in 4-7.

Purpose: To check apparent high values of Run 33.

## CRITICAL POSITIONS

C.A. 9 Expt. 7 Run 39

Table Pos. I T R

Control Rod

Channel

1 2.615 A 90 100/100

2 2.545 B .005

A 0.025 C out

B 16.325 <sup>57.2</sup> D 72 1000/50

E 1.4 900 V

Tim Crit. 9:45 <sup>AM</sup> ~~PM~~ Duration 19 min.

Temp. 9:45  
1.3802


Probably 10-8

Removed Al tube @ from 10-4

61.4  
57.2  
4.2

CRITICAL POSITIONS			
C.A.	9	Expr.	7 Run 40
Table Pos.		L	T
	Control Rod		Channel
1	2.610	A	86 100/100
2	2.540	B	.0049
A	0.025	C	out
B	16.870 <sup>61.4</sup>	D	69 1000/50
		E	1.4 900 V.
Tim Crit.	10:13	AM PM	Duration 25 min.

CHART No. 4-25



182

$$\begin{array}{r} .600 \\ + .106 \\ \hline .706 \\ \hline .494 \\ \hline .056 \end{array}$$

$$\begin{array}{r} .494 \\ \hline .056 \\ \hline \end{array} \quad \underline{\underline{\$7.85}}$$


---

5 Rnd 2

$$\begin{array}{r} .600 \\ + .145 \\ \hline .745 \\ \hline .455 \\ \hline \end{array} \quad \begin{array}{r} .145 \\ \hline .50 \\ \hline .095 \end{array}$$

$$\underline{\underline{\$4.8}}$$

CHART No. 4-25





Probably 10-4

Removed Al tube @ from 10-4

61.4  
57.2  
4.2

CRITICAL POSITIONS			
C.A.	9	Expr.	7 Run 40
Table Pos.		L	T
	Control Rod		Channel
1	2.610	A	86 100/100
2	2.540	B	.0049
A	0.025	C	out
B	16.870 <sup>61.4</sup>	D	69 1000/50
		E	1.4 900 V.
Tim Crit.	10:13	AM	Duration 25 min.

Raised level for rod drop.  
Dropped Safety Rod #1

# 9.28 Value of Safety Rod #1

CRITICAL POSITIONS

CA 9      Expr. 7      Run 41

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

	Control Rod	Channel
1	<u>2.615</u>	A <u>55</u> <u>1000/200</u>
2	<u>2.538</u>	B <u>.05</u>
A	<u>0.024</u>	C <u>8.2</u> <u>10-10</u>
<sup>61.0</sup> B	<u>16.821</u>	D <u>82</u> <u>1000/500</u>
		E <u>4.0</u> <u>750V.</u>

Tim Crit. \_\_\_\_\_ AM \_\_\_\_\_ PM    Duration \_\_\_\_\_ min.

Removed all reflector Cadant tubes (including the inconel) except the following: 6-12, 10-12, 6-2, 7-2, 7-3, 8-1, 9-2, 9-3, 10-2, + 10-3.

Removed F.T. # 25 from 4-7.

91.4  
60.0  
-----  
30.4  
47.8  
-----  
78.2

Red #25

CRITICAL POSITIONS

C.A. 9 Expr. 7 Run 42

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

	Control Rod		Channel
1	<u>2.610</u>	A	<u>93 100/100</u>
2	<u>2.545</u>	B	<u>.005</u>
A	<u>0.025</u>	C	<u>out</u>
B	<u>20.850</u> <sup>91.4<sup>2</sup></sup>	D	<u>74 100/50</u>
		E	<u>1.5 900 V.</u>

Tim Crit. 12:45 <sup>AM</sup> ~~PM~~ Duration 14 min.

*Raised level for rod depth.*

CRITICAL POSITIONS

C.A. 9 Expr. 7 Run 43

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

	Control Rod		Channel
1	<u>2.610</u>	A	<u>92 1000/100</u>
2	<u>2.545</u>	B	<u>.05</u>
A	<u>0.025</u>	C	<u>out</u>
B <sup>91.2</sup>	<u>20.810</u>	D	<u>69 1000/500</u>
		E	<u>3.2 750 V.</u>

Tim Crit. 1:06 <sup>AM</sup> ~~PM~~ Duration \_\_\_\_\_ min.



CRITICAL POSITIONS

C.A. 9 Expr. 8 Run 1

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

	Control Rod		Channel
1	<u>2.608</u>	A	<u>97 100/100</u>
2	<u>2.545</u>	B	<u>.0052</u>
A	<u>0.025</u>	C	<u>out</u>
B	<u>9.470</u> <sup>14.24</sup>	D	<u>75 1000/50</u>
		E	<u>1.5 900 V</u>

Tim. Crit. 2:47 <sup>AM</sup> PM Duration 8 min.

~~97.7  
14.22  
85.5~~

Placed F.T. # 68 in 5-10 + F.T. # 27 in  
6-11.

CRITICAL POSITIONS

C.A. 9 Expr. 8 Run 2

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

	Control Rod		Channel
1	<u>2.608</u>	A	<u>88 100/100</u>
2	<u>2.545</u>	B	<u>.005</u>
A	<u>0.025</u>	C	<u>out</u>
B	<u>21.890</u> <sup>97.7</sup>	D	<u>70 1000/50</u>
		E	<u>1.5 900 V</u>

Tim. Crit. 3:11 <sup>AM</sup> PM Duration 13 min.

Inserted the two (2) larger incore thimble tubes into 10-8

INSTRUMENT CHECK					
Time	8:35 AM		Source PB 267		
	PM				
	Channel				
	A	B	C	D	E
Range	$\frac{1}{1000}$	0.1	10 <sup>00</sup>	$\frac{1}{100}$	900 V
Source Dist.	15"		0 ft	5'	3"
% F.S. Trip	35	6		18	100 <sup>+</sup>
	Counter 1 + 2		OK		

C.A.	9	Expr.	8	Run	3
Sheet		Date	195	Time	AM PM
Purpose	Calibration of A.R.E. Safety-rod.				

not critical  $B_1 = .0005$ , (Source in)

Tube	47	placed into	7-4	56.5
"	26	" into	4-5	60.5
				54.9
				<u>171.9</u>
	97.7			
	42.8			
	<u>54.9</u>			

208

10/18/52

CRITICAL POSITIONS			
9	Expr.	8	Run 3
Tube Pos.		T	R
Control Rod		Channel	
2.610	A	88	100/100
2.545	B	.006	
A 0.025	C	out	
B 14.380 42.84	D	70	1000/50
	E	1.4	900
Tim Crit.	9:21	AM	Duration 6 min.



Removed Fuel Tube 47 from 7-4 56.5  
 " " " 26 " 4-5 60.5  
 117.0  
 Added " " 28 to 5-3  
 " " 60 " 4-8  
 " " 18 " 4-4

$$\begin{array}{r} 75.5 \\ 42.8 \\ \hline 32.7 \end{array}$$

$$\begin{array}{r} 117.0 \\ 32.7 \\ \hline 149.7 \end{array}$$

aluminum tube (SiO<sub>2</sub> filled)

no. 5 rubber stopper in each end





#56	51.8	91.4
#39	46.4	<u>14.2</u>
#25	48.7	77.2

	<u>146.9</u>
Rds	<u>77.2</u>
	<u>224.1</u>

value of Be O Column in 10-8

#47	56.5	97.7
#26	60.5	<u>42.8</u>
	54.9	54.9

Rds	<u>54.9</u>
	<u>171.9</u>

value of 2 outer Inconel tubes

75.5
<u>44.6</u>
30.9

value of third Inconel tube

94.1 & value of #68 ~ 10-8

4.2 after ARE

209  
10/12/52

CRITICAL POSITIONS

CA: 9    Expr. 8    Run 4

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
<u>2.610</u>	A <u>87</u> $\frac{100}{100}$
<u>2.545</u>	B <u>0062</u>
A <u>0.025</u>	C <u>07</u>
B <u>18.690</u> 75.5	D <u>70</u> $\frac{1000}{50}$
	E <u>1.4</u> 900V

Tim Crit. 9:50    AM  
PM    Duration 10 min.

75.5  
44.6  
-----  
30.9

Installed central (third) incorel guide tube for ARE safety rod

CRITICAL POSITIONS

CA: 9    Expr. 8    Run 5

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
<u>2.610</u>	A <u>93 + 100 / 100</u>
<u>2.535</u>	B <u>0.006</u> 0.007
A <u>0.024</u>	C <u>-</u>
B <u>14.614</u> 44.6	D <u>73 x 1000 / 1000</u>
	E <u>1.5 @ 900V</u>

Tim Crit. 10:35    AM  
PM    Duration 5 min.

Installed ARE Safety on Rod drop rig - i.e. pulley & wire to 107 -

See D chart for details of ARE Safety Rod Sensitivity

Safety  
ARE Rod  
at 32.25  
above 0.  
0 = the  
end of rod is  
3 in above  
al plate.

1.383 mvr.

Temp at 3:14 PM.

CRITICAL POSITIONS			
C.A.	9	Expr.	B
		Run	6
Table Pos.		I	T
		R	
	Control Rod		Channel
1	2.610	A	50 x 1000 / 200
2	2.535	B	0.05
A	0.022	C	
B	14.810	D	75 x 1000 / 500.
		E	4.2 @ 750V
Tim. Crit.	2:01	AM/PM	Duration 28 min.

Unsatisfactory Trace on Brush Recorder.  
A.R.E. safety rod drop repeated.

CRITICAL POSITIONS

C.A. 9    Expt. 8    Run 7

Table Pos. \_\_\_\_\_

	Control Rod	Channel
1	<u>2.610</u>	A <u>46</u> <u>1000/200</u>
2	<u>2.535</u>	B <u>.05</u>
3	<u>0.022</u>	C <u>out</u>
4	<u>14.804</u>	D <u>70</u> <u>1000/500</u>
		E <u>3.9</u> <u>750V</u>

Tim Crit. 3:09 <sup>AM</sup>/<sub>PM</sub>    Duration 10 min.

A.R.E. Safety  
Rod at 32.25  
on scale w  
Run 107-

Dropped Rod See over.

map of road to top  
of mountain  
distance from base = 3000 m,  
with road the  
way in.

at 3214 on scale  
in 107 distance from  
top of road to top of  
mountain.

position of inner tube  
4 m above the  
alt. 3214.

212

CHART No. 4-25

ARE  
Safety Run  
Run 9-8-7

28-1-30  
11  
15.5

28-1-30  
11  
15.5

15.5

214

10/19/52

Removed "light" Rod A-2-5-1 from  
B - installed "Heavy" A-2-5-2 -

Set up "light" Rod A-2-5-1 for  
Rod Drop in 10-8

The reflecting properties of A-2-5-1 was  
assumed to be the same as A-2-5-2 and  
therefore was with draw  $32\frac{1}{4}$ " before  
rod drop

CHART No. 4-25

9-8-8

"Strong" or "Heavy"  
ABE Control w 10-8

300  
100  
200

← 1000 →

①  
1/3



CHART No. 4-25

.67


$$\frac{36-13}{13} = \frac{23}{13} = 1.77$$

$$\frac{36-14}{14} = \frac{22}{14} = 1.57$$

#1.6

① 213

CHART No. 4-25



© 1941 BY THE BRUSH DEVELOPMENT CO.; PRINTED IN U.S.A.

© 1941 BY THE BRUSH DEVELOPMENT CO. PRINTED IN U.S.A.

①  
3/3

CHART No. 4-25

$$\frac{36-20}{20} = \frac{16}{20} = 80\%$$

Run 9-2-9  
Drop 8 ARE 1/2

© 1941 BY THE BRUSH DEVELOPMENT CO. PRINTED IN U.S.A.

2  
1/4

CHART No. 4-25

Run 9-2-9  
Drop of NRE Light Curve Rod. w 10-8


100  
100

← / sec

© 1941 BY THE BRUSH DEVELOPMENT CO., PRINTED IN U.S.A.

2  
21A


CHART No. 4-25



© 1941 BY THE BRUSH DEVELOPMENT CO., PRINTED IN U.S.A.


②  
3/4

CHART No. 4-25



© 1941 BY THE BRUSH DEVELOPMENT CO., PRINTED IN U.S.A.

2  
4/14



10/19/52

### CRITICAL POSITIONS

CA 9 Expr. 8 Run 9

Table Pos. \_\_\_\_\_ L \_\_\_\_\_ T \_\_\_\_\_ R \_\_\_\_\_

Control Rod	Channel
<u>2.615</u>	A <u>46</u> $\frac{1000}{200}$
<u>2.535</u>	B <u>.083</u>
<u>0.021</u>	C <u>out (10<sup>-10</sup> Lw)</u>
<u>12.180</u>	D <u>70</u> $\frac{1000}{500}$
	E <u>3.5</u> $\frac{2500}{500}$

Tim Crit. 1:13 <sup>AM</sup>~~PM~~ Duration 15 min.

Overholser -

slip  $1\frac{1}{16}$ " dia -

what 0-23, density?

2" long -


$14.516/H^3$  vfy ?

17


0.1632  $\frac{ft}{cc}$




296



Top  
Left



Top Right



9-2 Run

B 19.105

B 3.185

507

2.016

1.095

Moved #1

B 16.055

A 2.50


A 3.00

A 2.500

A 0.04

A 2.500

CHART NO. 5401 COPYRIGHT 1933 BY THE BROWN INSTRUMENT CO., PHILADELPHIA, PA., PRINTED IN U.S.A.



58 tubes + empty

in	out	
53	<del>empty</del>	58
<del>82</del>	25 ✓	53 <del>56</del>
<del>9</del>	<del>55</del>	39
<del>34</del>	11	68
<del>11</del>	59	25
<del>11</del>	<del>39</del>	(55 tubes) (25) 91.2¢ - 78.2¢ <small>coolant</small>
<del>56</del>	45	40-8 empty
47	+2	
<del>26</del>	67	
<del>28</del>	<del>42</del>	
	68	
	45	
	<del>39</del>	
	<del>39</del>	
	<del>25</del>	
	<del>11</del>	
	39	
	<del>39</del>	
	56 ✓	
	39 ✓	
	<del>39</del> ✓	
	<del>68</del> ✓	
	59 ✓	
	<del>11</del>	
	68 ✓	
53	25 ✓	

55 tubes  
 + 56 Be Out 14.2¢  
 + 39  
 + 25

58 tubes  
 68  
 27  
~~11~~  
 26  
 28  
 60  
 18

63 tubes 44.6¢

RESTRICTED  
This document is  
classified in the Atomic Energy Act  
and is to be controlled as such.

SECRET  
SECURITY INFORMATION

Classification Change to *Declass*  
Authority of *E. J. Murphy* Date *5/27/60*