

BOOK11R

5055 on bottom edge

Notes:

CA-25 APPR BOOK II on front of book.

Blank pages:1-9, 160-300, inside back cover.

-Each page has 1 graph glued to it: 43, 45, 49, 57, 65, 77, 87, 93, 102, 104, 110, 113, 119, 121, 130.

Scanned by:

Sheila Finch

RSICC /Oak Ridge National Lab.

July 29, 1999

SECRET

SOME INSTRUCTIONS FOR USE OF THIS NOTEBOOK

This notebook is assigned to personnel performing research and development work and must be used for all original calculations, notes and abstracts from reports.

Assignee is responsible for the safeguarding of this notebook in accordance with security regulations.

This notebook must be returned to issuing office when completed or upon termination of assignee.

Every page or entry should bear a date and the signature of the person who made the entry.

Entries should be made in ink whenever it is reasonable to do so.

Alteration or amplification of entries made on previous dates should be made as separate entries under their own dates and cross referenced to the previous entries.

Charts, drawings and graphs drawn on special paper should be glued or otherwise securely fastened in place and should individually bear a date and signature. Do not obscure any information.

The notebook should be periodically reviewed by one or more independent persons in the department and should be signed and dated by them. Likewise, they should make a statement that they have "read and understood the foregoing material." Witnessing stamps for this purpose are available in your department's office.

It is advisable to preface each new item, such as a heat treatment, process or reaction, etc., with a very brief description of the purpose, objective or approach.

Description of the invention or discovery should be complete enough to be understood by anyone skilled in the art.

Reference to name or catalogue number should be made when standard items are being discussed, i.e., Westinghouse pump.

In cases where work is conducted in cooperation with others, it is often necessary to meet with them from time to time and discuss new developments. The occurrences of such conferences should always be entered in your notebook regardless of recording elsewhere, giving the date, who was present (if possible), and an outline of the subjects discussed. This often will establish error in occasional claims of other parties that you have appropriated information from them revealed during an interview, and thus provide you with patent protection.

SECRET

SECRET

10-9-21

OAK RIDGE NATIONAL LABORATORY

OPERATED BY

UNION CARBIDE NUCLEAR COMPANY

A DIVISION OF UNION CARBIDE AND CARBON CORPORATION

Inv 57

C-14

This document consists of 300 pages of 1 copies, Series A-1000

5-25-60 OAK RIDGE, TENNESSEE

NOTEBOOK NO. 5852

(58)

69 OCT

Assigned to: A. D. Callihan

Department: Applied Nuclear Physics

Location: Bldg - 9213, 4-12

Date: Oct 19, 1955

This notebook is assigned to personnel performing research and development work and must be used for all original calculations, notes and abstracts from reports.

Assignee is responsible for the safe-guarding of this notebook in accordance with security regulations.

Do not use scrap paper.

Be sure to record all personal conferences.

This notebook must be returned to Laboratory Records-Bldg. 4500 when completed or upon termination of assignee.

Subject	CLASSIFICATION CANCELLED	"This document consists of _____ pages.
	DATE <u>6-3-60</u>	Page _____ copies, Series _____
	<u>Edgar J. Murphy</u>	
	COORDINATING ORGANIZATION DIRECTOR	
	OAK RIDGE NATIONAL LABORATORY	
	AUTHORITY DELEGATED BY AEC 9-10-57	

RESTRICTED DATA

... contains restricted data as of 1954. Its release or disclosure of its contents by any unauthorized person is prohibited.

7-10
11-11
12-12
2-14
5-16
11-17
10-18

27

Expr. 9-39 Time 6:00 AM Date 11-22 1955
 Purpose Zero check on run 9-38.
 Personnel: _____

INSTRUMENT CHECK
 Date 11-22 1955 Time 5:00 AM Source No. _____
 Trip _____
 Instrument Value Scale Source Distance Start-Up Scale
 DC-1 _____
 DC-2 _____
 DC-3 50 10x20 3"
 Log N 125 125
 R-1 5 87/100 contact
 R-2 _____
 P-M. contact

Loading - exactly the same as 9-38 (I, p 218):


Slot	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Series	1	5	3	4	5	6	2	11	9	7	12	12	8	14	15	9	17	18
Material	f	f	s	f	s	f	f	f	s	f	f	s	f	f	f	f	f	p

Box	slot 14	slot 17	slot 14	slot 17
1	1-9	H-959	6-9	12-23
2	-21	537	rod	
3	-23	H-958	-21	1-11
4	-25	435	-23	6-40
5	-37	H-	-25	H-928
6	2-9	10-25	-37	516
7	-21	10-27 4-20	7-9	10-23
8	-23	10-27	-21	510
9	rod		-23	H-913
10	-25	11-9	-25	511
11	-37	#507	-37	1-15
12	3-9	11-21	8-9	3-1
13	-21	578	-21	1-16
14	-23	H-961	rod	
15	-25	4-27	-23	1-17
16	-37	10-21	-25	#505
17	4-9	4-28(200)	-37	1-19
18	-21	H-951	9-9	H-960
19	-23	6-32	-21	515
20	-25	1-9	-23	H-935
21	rod		-25	512
22	-37	12-21	-37	H-952
23	rod			

START-UP CHECK LIST
 Equipment Checked by RJ Personnel Check by DW
 Instrument and Safeties Checked and Reset by DM
 "Source In" Checked by DM Source No. _____
 Emergency Equipment in Control Room Checked by MB
 Red Light On by DM Time 5:00 AM
 Start-Up OK'd by DM Time 5:00 PM Date 11-22 1955

All APPR ~~rod~~ eccentric rods in full without fuel attached on the bottom.

APPR central rod full section attached on bottom.



log N has been re-calibrated.

Critical Conditions:

Temp.	73°F	DC-3	68(10x20)
Height	109.3	Log N	0.18
Blade	16.02		
Rod	29.02		
Eccentric Rod	0.01		
Central Rod.	24.15		

Expr. 9-40 Time 6:15 AM Date 11-22 1955
 Purpose Measurement of δk between central & eccentric rod all the way out
 Personnel: _____

START-UP CHECK LIST
 Equipment Checked by HB Personnel Check by HB
 Instrument and Safeties Checked and Reset by MB
 "Source In" Checked by DM Source No. _____
 Emergency Equipment in Control Room Checked by MB
 Red Light On by HB
 Start-Up OK'd by DM Time 6:15 AM Date 11-22 1955

Loading - exactly the same as 9-39 except slot 17, box 7 now contains ss 1-7 instead of 4-20.

Didn't go critical.
 Water up.
 Rod + Blade out.

Expr. 9-41 Time 6:45 AM Date 11-22 1955
 Purpose δk measurement - new zero point.
 Personnel: _____

START-UP CHECK LIST
 Equipment Checked by HB Personnel Check by HB
 Instrument and Safeties Checked and Reset by JL
 "Source In" Checked by JL Source No. _____
 Emergency Equipment in Control Room Checked by MB
 Red Light On by HB
 Start-Up OK'd by JL Time 6:50 AM Date 11-22 1955

Loading - same as 9-39 except for the following exchanges:
 Box now in slot 17

- 1 3-24
- ~~5~~ 5 3-5
- ~~3~~ 3 3-3
- ~~43~~ 43 3-43
- 45 3-45
- 41 3-41 (piece 4-20 replaced)

Rod ~~29.05~~ 29.05 DC-3 69(10x20)
 Blade 13.75 ~~178~~ 178
 Temp. 73°F

$(1.28 - .68) = 0.60$ $.60 \times 7.52 = 4.512$ value
 of 6 half plation perimeter
 in slot 17 or $\frac{4.512}{95.8} = 0.0471 \frac{\text{g}}{\text{g}}$

Expr. 9-42 Time 8:15 PM Date 11-22 1955
 Purpose New zero point prior to
extending S.K. D. fuel plates (by
comparison to 6 blade position)
 Personnel: J.L., DWM, M.B.

START-UP CHECK LIST
 Equipment Checked by DWM Personnel Check by DWM
 Instrument and Safeties Checked and Reset by J.L.
 "Source In" Checked by M.B. Source No. _____
 Emergency Equipment in Control Room Checked by DWM
 Red Light On by DWM
 Start-Up OK'd by M.B. Time 8:15 PM Date 11-22 1955

Loading: ~~Same~~

4 Half plates exchanged for 4 full plates in slot 17
 in boxes 14, 18, 28 & 32. (Added 2 equiv plates)
 to the loading of 9-41.

Removed H 961 from box 14 slot 17; inserted 3-14.

H 951 " box 18 " " 3-18
 H 928 " " 28 " " 3-28
 H 913 " " 32 " " 3-22

Control Rod 29.02 Log N 0.19
 Control Blade 10.73 DC-3 79x10x20 R-1: 9.6x100x1000
 Eccentric Rod In 00.01 Water Ht. 109.6
 Control Rod Out (M.B.) 24.15 Water Temp 73 °F

Expr. 9-43 Time 9:00 ^{AM} PM Date 11-22 1955
 Purpose Compare 3 fuel plates with
control blade.
 Personnel: M.B. DWM J.L. R.S. H.B.

START-UP CHECK LIST
 Equipment Checked by J.L. Personnel Check by DWM
 Instrument and Safeties Checked and Reset by J.L.
 "Source In" Checked by M.B. Source No. _____
 Emergency Equipment in Control Room Checked by DWM
 Red Light On by DWM
 Start-Up OK'd by M.B. Time 9:03 ^{AM} PM Date 11-22 1955

Loading: 9-42 Loading less 3 fuel plates from slot 17
 boxes 11, 26 and 39 -- (502, 1-11, 505 removed)
 SS 1-11, 26, and 39 inserted.

APPR Control Rod 29.14 Log N 0.18
 " Eccentric Rod 0.01 DC-3 68.5 x 10 x 20
 Control Blade 20.00 R-1 4.1 x 100 x 1000
 " Rod 29.02 Water Ht. 109.5
 Water Temp. 73

3 fuel plates worth (20.01 - 10.73) on control blade
 or $(2.365 - .165) \times 7.57 = 2.2 \times 7.57 = 16.64$
 $35.2 - 18.8 = 16.4$

START-UP CHECK LIST
 Equipment Checked by TL Personnel Check by HGB
 Instrument and Safeties Checked and Reset by TL
 "Source In" Checked by WRJ Source No. _____
 Emergency Equipment in Control Room Checked by SWM
 Red Light On by OK SWM AM
 Start Up OK'd by WRJ Time 10⁰² PM Date 11-22 1955

Expr. 9-44 Time 10⁰⁰ ^{AM} PM Date 11-22 1955
 Purpose Evaluate 2 plates
 Personnel: WRJ SWM J.R. MB HGB

Loading: Same as 9-42 less 10-21 & 10-23 from slot 17
 of boxes 16 and 30. resp. (Replaced 507 1-11 and 505
 in boxes 11, 26, & 39 slot 17 from run 9-43)

Critical cond.

APPR Central Rod	Log N
" Eccentric Rod	DC-3
Control Blade 28.00	R-1
" Rod	Water Ht
	" Temp

Sub Critical

Expr. 9-45 Time 10³⁰ ^{AM} PM Date 11-22 1955
 Purpose Evaluate fuel plate 10-23 from 30-17
 Personnel: _____

START-UP CHECK LIST
 Equipment Checked by JL Personnel Check by SWM
 Instrument and Safeties Checked and Reset by WRJ
 "Source In" Checked by WRJ Source No. _____
 Emergency Equipment in Control Room Checked by SWM
 Red Light On by OK SWM
 Start Up OK'd by WRJ Time 10³⁰ PM Date 11-22 1955

Loading: Same as 9-42 less plate 10-23 from
 Box 30 slot 17.

Critical Conditions

APPR Central Rod	Log N
" Eccentric Rod	DCB
Control Blade	R-1
" Rod	Water Ht
	Water Temp.

Sub Critical.

Expr. 9-46 Time 10⁵⁵ AM Date 11-22 1955
 Purpose Evaluate half fuel plate in Box 30 Slot 17
 Personnel: _____

START-UP CHECK LIST
 Equipment Checked by MB Personnel Check by MB
 Instrument and Safeties Checked and Reset by MB
 "Source In" Checked by WRS Source No. _____
 Emergency Equipment in Control Room Checked by DWM
 Red Light On by Ch DWM
 Start-Up OK'd by WRS Time 10⁵⁵ AM Date 11-22 1955

Loading: ~~Change~~ Insert half plate in Box 30 Slot 17
 from previous loading. (Removed 1-30 steel)
 (Loading is 1/2 plate less than 9-42)

Barely Subcritical λ Period ~ 1000 sec.

APPR Control	24.14	Log N	0.10 R
" Ec	00.01	R-1	2.68 x 100 x 1000
Control Blade	28.28	Water Ht.	109.7
" Rod	29.02	Temp	73

$2.37 \times 7.57 = 17.9 \phi$
 $36.8 - 18.8 = 18.0$

Expr. 9-47 Time 10²⁰ AM Date 11-22 1955
 Purpose Evaluate Sk 5 + 1/2 in slot 2 and -1/2 plate in slot 17 of box 16.
 Personnel: _____

START-UP CHECK LIST
 Equipment Checked by MB Personnel Check by WRS
 Instrument and Safeties Checked and Reset by MB
 "Source In" Checked by WRS Source No. _____
 Emergency Equipment in Control Room Checked by DWM
 Red Light On by Ch DWM
 Start-Up OK'd by DWM Time 10²⁰ AM Date 11-22 1955

Loading: Box 16 Interchange plate 5-16 slot 2
 with plate 10-21 slot 17, assume this adds 17.9 ϕ Sk
~~Box 30~~ when 1/2 plate added in slot 2.

Box 30 Interchange plate 5-21 with plate 10-23
 in slot 17.

Critical Cond:	log N	0.12
APPR Control	DC-3	46 x 20 x 10
Eccentric	R-1	2.68 x 100 x 1000
Control Blade	Water Ht.	110.1
" Rod	" Temp.	73

$36.6 - 18.8 = 17.8$
 $\frac{17.8}{17.9} + \frac{18.0}{17.9} = 35.8 \phi$ value 1/2 plate
 in slot 17

Total Reactivity difference between 3 ecc + 1 centric
 and 4 ~~centric~~ ^{eccentric rods} is ~~1.40~~ for the 8 fuel plates
 in boxes 7, 11, 16, 20, 26, 30, 35, & 39.
 $2 \times 16.4 = 32.8$
 $2 \times 18.0 = 36.0$
 $2 \times 35.8 = 71.6$
 140.4
 Total with 8 fuel plates
 26.72 g U or 249 g U-235 or 0.566 ϕ /gm

The previous ²³ fuel plates are in error

Slot 1	MAC 259	10	12-37
2	A 506	11	17-23
3	SS	12	11-25
4	341	13	
5	SS	14	11-37
6	A 264	15	
7	12-9	16	
8	12-25	17	
9	SS	18	

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
+	+			+	+			+			+			+		+	+

Expr. 7-13 Time 7:15 ^{AM} ~~PM~~ Date 11-23 1955
 Purpose Check on critical mass-effect
& long time bulging.
 Personnel: _____

INSTRUMENT CHECK

Date 11-23 1955 Time 7:15 ^{AM} ~~PM~~ Source No. _____
 Trip _____
 Instrument Value Scale Source Distance Start-Up Scale

DC-1				
DC-2				
DC-3	<u>=</u>	<u>50</u>	<u>20x10</u>	
Log N	<u>=</u>	<u>15m</u>	<u>15sec</u>	
R-1	<u>=</u>	<u>6</u>	<u>8x1000</u>	
R-2			<u>x100</u>	
P. M.	<u>✓</u>			<u>5"</u>

START-UP CHECK LIST

Equipment Checked by DW Personnel Check by DM
 Instrument and Safeties Checked and Reset by DW
 "Source In" Checked by _____ Source No. _____
 Emergency Equipment in Control Room Checked by MB
 Red Light On by DM AM
 Start-Up OK'd by DW Time 7:26 ^{AM} ~~PM~~ Date 11-23 1955

Loadings cold clean critical loading:

slot	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
series	1	2	3	4	5	6	7	5	9	9	11	12	8	4	15	9	1	10
material	f	s	f	s	s	f	s	f	s	f	s	s	f	s	s	f	s	f

plus:
 box 11 slot 8 contains #378 instead of Raff fuel.
 7 3-41
 30 4-20
 59 6-46

All series of plates have been weighed.
End boxes on

Summary of weighing -

Series	Weight in H ₂ O		Weight change between 10-20 & 11-23	Total Void Volume 11-23-55	Total Volume
	10-20-55 (7-8)	11-23-55			
1	8096	7675	421	785	810
2		7787.5		810 673	810
3		8001		459	810
4	8048	7781	267	679	810
5	7417	8009 6932	485	776	810 1168
6	8137	8009	125	451	810 829
7	8120	7874.5	245	585	810 986
8	8243	8131 8184	112	329	810 741
9	8312	8071	241	389	810 821
10	8247	8047	415	413	810 866
11		7832		628	810 7513
12		6626		1835	
41 extra plates in 9-39		7150		558	
	64620	62741			

critical conditions.

water	109.0 cm.	Lag N	0.19
rod	29.015 in	DC 3	82(10x20)
blade	17.72 in	Temp.	72.5°F

Total void volume = 4187 cm³

Mass: $7.5 \times 45 + 2 = 337.5 + 2 = 339.5$ plates

$339.5 \times 31.1 = 10.56$ kg - U-235

blade correction = $\frac{-0.01}{10.55}$

11-25-55

The following plates were opened to let gas escape.

1-1	3-5	5-2	6-6	7-10	8-1
2	14	4	15	11	6
5	25	5	23A	324	9
6	32	6	35	15	10
8	34	14	37	16	13
9A	42	17	38	19	14
10	45	18	39	31	28
19A		23	40A	33	34
21		25	41	42	41
26		26	42		
27		27	45		
30		28		9-1	10-39
31		30		3	40
34		31		4.5	41
35		34			42
36		36			43
37		38			
38		43			
39					
40					
41					
42					
43					
44					
45					

Final plate weighing in H₂O

zero	767	Dry weight	Total Volume
1	8863	8096	8660 8891 795
3	8862	8095	9637 8868 773
5	8235	7468	8868.5 8110 682
6	8982	8215	9647 8688 683
7	8946	8179	9630 8561 682
8	9025	8258	9641 8892 614
9	8991	8224	9661 8892 468
10	8990	8223	9682 8913 690
		64758	9517

U-235
voids decreased
2017

Expr. 7-14 Time 3:30 PM Date 11-25-55
 Purpose: Evaluation of voids
 Personnel: J.L., DWM, IED

INSTRUMENT CHECK

Date 11-25 1955 Time 3:30 PM Source No. _____
 Trip _____

Instrument	Value	Scale	Source Distance	Start-Up Scale
DC-1				
DC-2				
DC-3	<u>✓</u>	<u>55</u>	<u>10x20</u>	
Log N	<u>✓</u>	<u>15</u>	<u>15m</u>	
R-1	<u>✓</u>	<u>5</u>	<u>8x1000</u>	<u>~6"</u>
R-2	<u>✓</u>	<u>100</u>		
P. M.	<u>✓</u>			<u>3"</u>

START-UP CHECK LIST

Equipment Checked by J.L. Personnel Check by DWM
 Instrument and Safeties Checked and Reset by I.E.D.
 "Source In" Checked by DWM Source No. _____
 Emergency Equipment in Control Room Checked by DWM
 Red Light On by DWM(ch) AM
 Start-Up OK'd by DWPW Time 3:40 PM Date 11-25 1955

Loading: Same as 7-13
 Critical Cond:

Control Blade	0.05	Log N	0.20
Rod	29.	DC-3	
Water Ht	90.5	R-1	
Water Temp	72°F		

Expr. 7-15 Time 1:15 PM Date 11-25 1955
 Purpose: Evaluation of Voids
 Personnel: DWPW DWM JL MB IED

START-UP CHECK LIST

Equipment Checked by J.L. Personnel Check by M.B.
 Instrument and Safeties Checked and Reset by I.E.D.
 "Source In" Checked by DWPW Source No. _____
 Emergency Equipment in Control Room Checked by DWM
 Red Light On by DWM AM
 Start-Up OK'd by DWPW Time 4:15 PM Date _____ 195_____

Loading: Remove # 378 (NAC) from Box 11 Slot 8

3-41	7 "
4-20	35
6-40	39

(9 1/2 - 4 half plate)

	Dry	11-25	A	Void	11-23	A
	Weight	WT in H ₂ O	(Volume)	Volume		
1	9659.5	8096	1563.5	364	7675	1984.5
3	9636.5	8095	1541.5	365	8001	1635.5
5	8868.5	7468	1400.5	317	6932	1936.5
6	9646.7	8215	1431.7	245	8009	1637.7
7	9629.5	8179	1450.5	281	7884.5	1755.0
8	9640.5	8258	1382.5	202	8131	1509.5
9	9660.5	8224	1436.5	236	8071	1589.5
10	9681.5	8223	1458.5	237	8047	1634.5
	76423.2	64758	11662.2	2247		13680.2

Not quite critical: blade out, water up
 Water temp 72°F

Void volume = $2247 - \frac{2247}{337.5} \times 4 = 2220$

Mass: $7.5 \times 45 - 2 = 337.5 - 2 = 335.5$
 $= 10.43 \text{ kg}$

11-28-55:

"Flattened" (opened, applied pressure & closed)
 the following plates:

Series	Series
11-8	12
-24	#678-12-38
#531	A-271-12-1
	684-
	667
	675
	674
	668
	679
	677
	669
	672
	680
	673
	12-41

contained a lot of water.

- 2-1
- 2
- 12A
- 14
- 18
- 24
- 28
- 29
- 33
- 38
- 39
- 40
- 41
- 43
- 44
- 45
- 42

- 4-3
- 5
- 7
- 9
- 10
- 11
- 12
- 13
- 18
- 20
- 20A
- 23
- 25
- 27A
- 29
- 31
- 32
- 37
- 41
- 42
- 44

Expr. 9-48 Time 6:25 AM Date 11-29 1955
 Purpose 5-APPR rods half in.
 Personnel: _____

INSTRUMENT CHECK

Date _____ AM _____ Source No. _____

Instrument _____ Start-Up Scale _____

R-1 50 10 20 3 1/2"
 R-2 125 125
 R-3 5 8x1000 1"
 P. M. 2 1/2"

Loading: all boxes: (11 plates per box)

slot	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
series	1	2	3	4	5	6	7	8	9	10	11	12	13	2	15	9	11	10
+material	f	f	f	f	f	f	f	f	f	f	f	f	f	f	f	f	f	f

START-UP CHECK LIST

Equipment Checked by RJ Personnel Check by DM
 Instrument and Safeties Checked and Reset by MB
 "Source In" Checked by JL Source No. _____
 Emergency Equipment in Control Room Checked by MB
 Red Light On by DM AM _____
 Start-Up OK'd by JL Time 6:30 AM Date 11-29 1955

All five APPR rods mounted; the eccentric rods one at 12 inches above the core ("Half-way in")

With source in, water at 68 cm., ~~positive~~ central rod all the way in, reactor going on positive period. Much too super critical. Loading.

Expr. 9-49 Time 9:00 AM Date 11-29 1955
 Purpose 5-APPR rods half in.
 Personnel: _____

START-UP CHECK LIST

Equipment Checked by DM Personnel Check by MB
 Instrument and Safeties Checked and Reset by MB
 "Source In" Checked by DM Source No. _____
 Emergency Equipment in Control Room Checked by DM
 Red Light On by HP AM _____
 Start-Up OK'd by DM Time 9:00 AM Date 11-29 1955

Loading: all boxes: (10 plates per box)

slot	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
series	1	2	3	4	5	6	7	8	9	7	11	12	13	2	15	9	1	10
+material	f	f	f	f	f	f	f	f	f	f	f	f	f	f	f	f	f	f

With APPR central rod all the way out, very super critical.
 With APPR central rod all the way in, water all the way HP reactor sub-critical.

Source Billed Out; Eccentric Rod. 12.02 in.

Central Rod	11.025 in.	Water	62.7	-	critical (approx)
	10.84 in.		63.0	-	critical (approx)
	10.2 in.		63.3	-	critical (approx)
	9.80 in.		64.0	-	"
	9.13 in.		64.9	-	"
	8.70 in.		65.7	-	"
	8.13 in.		67.0	-	"
	7.72 in.		68.1	-	"
	7.12 in.		70.1	-	"
	6.41		73.0	-	"
	5.8		76.0	-	"

Central Rod	5.27	Water height	80.1
	4.83		83.6
	4.43		90.0
	4.28		∞ (109)

Expt. 9-50 Time 11:00 AM Date 11-27 1955
 Purpose 5-APPR rods half in.
 Personnel: _____

START-UP CHECK LIST
 Equipment Checked by DW Personnel Check by MB
 Instrument and Safeties Checked and Reset by DW
 "Source In" Checked by DW Source No. _____
 Emergency Equipment in Control Room Checked by MB
 Red Light On by MB
 Start-Up OK'd by DW Time 11:00 AM Date 11-27 1955

Loading: for all boxes except APPR rod boxes:
 Slot 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18
 Series 1 2 3 4 5 6 7 8 9 7 4 12 13 15 9 1 10
 Material F $\frac{5}{3}$ F $\frac{5}{3}$ $\frac{5}{3}$ F $\frac{5}{3}$ F $\frac{5}{3}$ F $\frac{5}{3}$ F $\frac{5}{3}$ F $\frac{5}{3}$ F $\frac{5}{3}$ F $\frac{5}{3}$ F

The APPR boxes are similar above except slot 4 contains Fuel

Source Out; Eccentric Rod at 12.02 (blade all the way in)
 Central Rod. 13.52 in. Water height. ~~69.8~~ 70.8 in. critical
 12.86 71.2
 11.82 73.8
 11.02 77.7
 10.46 84.8
 10.16 109.1 critical

Pulling plate out: 28.28 in.
 Central Rod 9.65 in; Water height 109.1 cm critical

START UP CHECK LIST

Equipment Checked by MB Check by DM

Instrument and S. DM

"Source In" Ch. DM No. DM

Emergency Equip. Room checked by MB

Red Light On by JL

Start-Up OK'd by DM Time 12:30 AM Date 11-30 1963

Expt. 9-3051 Time 12:30 AM Date 11-30 1963

Purpose 5-APPR rods in half way.

Personnel: _____

Loading - all boxes:

slat	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
series	1	2	3	4	5	6	7	8	9	7	11	12	13	2	15	9	11	10
material	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P

APPR ~~rod~~ eccentric rods ~~in~~ out 11 7/8"
 (Dryen rod at 11.86)

Central Rod	15.02 in.	Water height	73.5 cm
	14.26		74.5
	13.62		75.9
	13.30		76.2
From Eccentric rod inadvertently inserted to <u>11.78</u>			11.78
	12.70		79.6
	12.61		85.1
	14.78		88.0
	11.77		92.8

Blade pulled all the out

Central 11.055 Water 109.3 super critical
 Ecc 11.78

Central ~~11.03~~ Water 109.3 sub-critical
 Ecc 11.78

Temp. 73°F

Center Rod 11.03 in ~~critical~~ 109.3 ~~critical~~ super critical.

Ecc Rod 11.87 in

Blade 28.29 in

Center Rod inserted 11.00 in - sub critical.

9 x 45 = 405 gals total

401 x 11.1 = 4451.1 gals

B-26

Expt. ~~9-51~~ Time 5:55 ^{AM} ~~PM~~ Date 11-30 1955
 Purpose Power Distribution - 5 rods out
IN - zero valn.
 Personnel: _____

INSTRUMENT CHECK

Date 11-30 1955 Time 6:00 ^{AM} ~~PM~~ Source No. _____
 Trip _____
 Instrument Value Scale Source Distance Start-Up Scale

P-1					
P-2	✓	50	10x20		
Log N	✓	155m			
R-1	✓	6	1000x		
R-2			100		
P. M.	✓				3

START-UP CHECK LIST

Equipment Checked by HB Personnel Check by DW
 Instrument and Safeties Checked and Reset by MB
 "Source In" Checked by DM Source No. _____
 Emergency Equipment in Control Room Checked by MB
 Red Light On by HB ^{AM} ~~PM~~
 Start-Up OK'd by DW Time 6:00 ^{AM} ~~PM~~ Date 11-30 1955

loading - complete loading of 9; exactly the same as 9-51 (page 32)
 The purpose of this run is for zero check with 9-51; to get experience running this configuration in order to expose foils; to see exactly where this loading will go critical.

No foils are in.

Log N has been recalibrated.

Critical Conditions:

Temp.	73°F	Asst. Blade	2.25' in	2.72
Height	109.5 cm.	Rod	2.11	0.41
DC-3	49 (10x50)	APPR (Central)	11.88	11.88
Log N	0.2	(Eccentric)	11.87	11.82
R-1	3.1 (200x1000)			

also:
 Mass = 12.60
 blank motion = 1.05
 12.53

B-27

Expt. 8-27 Time 9:00 ^{AM} ~~PM~~ Date 11-30 1955
 Purpose POWER DIST - 5 APPR RODS HALF IN.
 Personnel: _____

START-UP CHECK LIST

Equipment Checked by MB Personnel Check by DW
 Instrument and Safeties Checked and Reset by DW+DM
 "Source In" Checked by DW Source No. _____
 Emergency Equipment in Control Room Checked by MB
 Red Light On by MB ^{AM} ~~PM~~
 Start-Up OK'd by DW Time 9:00 ^{AM} ~~PM~~ Date 11-30 1955

LOADING - complete loading of 9; same as 9-6 (page 32) except F-1 (MAC# 507) in slot 10, box 23 and F-2 (MAC# 571) in slot 10, box 16.

FOIL LOCATION - F-1: top to bottom. F-2: top to bottom

- B-182
- B-17
- B-173
- B-116
- B-61
- B-64
- B-175
- B-34
- B-74
- B-161
- B-7

- B-83
- B-122
- B-22
- B-70
- B-115
- B-180
- B-110
- B-88
- B-82
- B-140

1/2 power at 9:24:32 pm. (Log N reading of 1.1)
 Scrammed by photo-multiplier.
 Something appears to be drastically changed from last foil exposure: at the scram, log N was reading 1.3 - a much lower value than our usual foil exposure level (2.0) but R-1 was reading 6.9 on 1000x1000 scale - approx. a factor of 2 over our usual foil exposure level (3.9)
 The photo-multiplier voltage was at the usual 900 volts.
 The most plausible reason is that the five rods have made an entirely new reactor with very different leakage.

Expt. 8-28 Time 10:40 AM Date 11-30 1955
 Purpose POWER DIST - 5 APPR RODS
HALF IN.
 Personnel:

START-UP CHECK LIST
 Equipment Checked by JL Personnel Check by DW
 Instrument and Safeties Checked and Reset by DM
 "Source In" Checked by DW Source No. _____
 Emergency Equipment in Control Room Checked by DM
 Red Light On by MB
 Start-Up OK'd by DW Time 10:40 AM Date 11-30 1955

LOADING - Exactly the same as 8-27.
 FOIL LOCATION - Special plate F-2; top to bottom: slot 10, box 16.

- B-24
- B-33
- B-131
- B-52
- B-53
- B-20
- B-50
- B-117
- B-37
- B-146
- B-18

H-V on photo-multiplier turned down to 800 volts.
 1/2 power at 11:03:00 (Log N = 0.37)
 Run conditions.

Log N	1.0	Central APPR	11.875
DC-2	70 (10x5)	Eccentric APPR	11.02
R-1	5.3 (1000x1000)	Rod	0.15
Temp.	93°F	Blade	6.99
Height	109.3		

Twenty minute exposure.
 Register on proportional counter not operating properly.

Expt. 8-29 Time 5:25 AM Date 12-1 1955
 Purpose POWER DIST - 5 APPR RODS
HALF IN; VERTICAL DIST IN BOX 16 AND
IN FUEL SECTION CONNECTED TO CENTRAL ISD.
 Personnel:

INSTRUMENT CHECK
 Date 12-1 1955 Time 5:25 AM Source No. _____
 Trip _____
 Instrument Vials Seals Source Distances Starting Date

DC-1				
DC-2				
DC-3	-	55	20x10	3"
Log N	-	1.25	1.25	
R-1	-	5.2	8x1000	1/2"
R-2				
P. M.	-	900V.		3"

Note: The special catcher foil plates are developing holes in the uranium foil due to water in the plates. No regular fuel plate has been torn apart to see if this condition is also occurring in it.

START-UP CHECK LIST
 Equipment Checked by HP Personnel Check by DM
 Instrument and Safeties Checked and Reset by MB
 "Source In" Checked by JL Source No. _____
 Emergency Equipment in Control Room Checked by _____
 Red Light On by DM
 Start-Up OK'd by DW Time 6:20 AM Date 12-1 1955

8:15 pm - start-up. Delayed by register on proportional counter. Replaced the register with a "rebuilt" one.

Photomultiplier voltage turned down to 800V.

Fail location. top to bottom

Slot 10, Box 23
plate F-2;

- 1 3-147
- 2 -100
- 3 -65
- 4 -158
- 5 -31
- 6 -85
- 7 -176
- 8 -106
- 9 -130
- 10 -27
- 11 -29

Slot 10, Box 23
plate F-1

- 1 3-44 - very small amount of water on it.
- 2 -132
- 3 -45
- 4 -38
- 5 -136
- 6 -84
- 7 -137
- 8 -169
- 9 -66
- 10 -48
- 11 -40

1/2 power at 8:32:05 (1/2 final power = 0.37 on log N)

Run conditions:

Temp.	73.6°F	APPR	{ Central	11.88
DC-2	65 (10x5)		{ Eccentric	11.875
R-1	5 (1000x1000)	Control	{ Blade	0
Log N	1.0		{ Rod	0.105
		Height		109.7cm.

12-6-55

An analysis of a H₂O sample taken on 12-5-55 showed that there was less than 0.01 ppm U in the water. Wipe tests on bottom of tank and on pipe support showed 500 - 1000 c/min (5" x 5" area)
Aurkin

Full boron, or "B" plates - 1.889 gm Nat B/plate.
1/2 boron, or "C" plate - 0.944 gm Nat B/plate

On 12-5, a ^{flu}oroscopic analysis of the physical condition of the U-forks in 17 plates was made. Seven of these 17 showed small holes in the fork. Detailed results are on page 17 of D.W.M.'s notebook.

Expr. 13-1 Time 5:05 ^{AM} ~~PM~~ Date 12-6 1955
 Purpose Red Evaluation with Boron -
3 ecc. & 1 cent. rod in; normal
positions.
 Personnel: _____

INSTRUMENT CHECK

Date 12-6 1955 Time 5:00 ^{AM} ~~PM~~ Source No. _____
 Trip _____

Instrument	Value	Scale	Source Distance	Start-Up Scale
DC-1				
DC-2				
DC-3	<u>✓</u>	<u>45</u>	<u>10x20 contact</u>	
Log N	<u>✓</u>		<u>12.000</u>	
R-1	<u>-</u>	<u>5</u>	<u>1000*</u>	
R-2			<u>1000*</u>	
P. M.	<u>3</u>			<u>3'</u>

START-UP CHECK LIST

Equipment Checked by J.L. Personnel Check by D.W.
 Instrument and Safeties Checked and Reset by M.B.
 "Source In" Checked by D.W. Source No. _____
 Emergency Equipment in Control Room Checked by D.M.
 Red Light On by D.W. ^{AM} ~~PM~~
 Start-Up OK'd by D.W. Time 5:15 ^{AM} ~~PM~~ Date 12-6 1955

Loading:

Slot	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Series	<u>1</u>	<u>4</u>	<u>3</u>	<u>4</u>	<u>6*</u>	<u>8</u>	<u>8</u>	<u>11</u>	<u>7</u>	<u>11*</u>	<u>12</u>	<u>5</u>	<u>2</u>	<u>15</u>	<u>9</u>	<u>*</u>	<u>10</u>	
Material	<u>f</u>	<u>f</u>	<u>f</u>	<u>f</u>	<u>f</u>	<u>f</u>	<u>f</u>	<u>f</u>	<u>f</u>	<u>f</u>	<u>f</u>	<u>f</u>	<u>f</u>	<u>f</u>	<u>f</u>	<u>f</u>	<u>f</u>	<u>f</u>

APRR rods: in positions 9, 21, 23, 37; fid sections not on
 in position 25, rods ~~section~~ ^{fuel} section in core; Poison section not attached
 * boron plates (Series "C" ^{half} boron) in slot 11 & the
 following boxes: 1, 3, 5, 6, 8, 10, 12 38, 40, 41, 43, 45.

Box	slot # 17	slot # 6	slot # 17	slot # 6	
1	1-9	S.S.	24	11-21	H-960
2	2-9	1-9*	25	12-21	1-11*
3	3-9	10-37 S.S.	26	1-23	H-952
4	4-9	10-37	27	2-23	4-27*
5	6-9	S.S.	28	3-23	S.S.
6	7-9	#878	29	4-23	4-23*
7	8-9	11-37	30	6-23	S.S.
8	9-9	5-9	31	7-23	6-32*
9	— void —		32	8-23	S.S.
10	10-9	5-21	33	9-23	#A264
11	11-9	MHC-67 (12-37)	34	10-23	H-961
12	12-9	5-23	35	11-23	2-59
13	1-21	1-19*	36	12-23	H-958
14	2-21	S.S.	37	— void —	
15	3-21	1-17*	38	7-37	H-959
16	4-21	S.S.	39	2-37	2-21*
17	6-21	1-16*	40	3-37	8-41*
18	7-21	S.S.	41	4-37	S.S.
19	8-21	1-15*	42	6-37	4-20*
20	9-21	5-37	43	7-37	S.S.
21	— void —		44	8-37	6-40*
22	10-21	H-951	45	9-37	S.S.
23	— void —				

Critical conditions:

Water @ 4.5 cm

Apprx Control { Blank 0.05
 { Geometric 0.00

Control { Blank 0.02
 { Rod 29.015

Long N 1.5
 DC-3 60 (10 x 10)

2 + half B plate
 x 0.944 g/plate
 = 22.667 g total

12.5 plate/rod x 41 x 31.1

= 15.939

2 + plate x 31.1 (from slot) = 124.6

16.685

Mass of U²³⁵ = 17.075 Kg

16.685 x $\frac{45}{41}$ = 18.31
 Kg = U²³⁵

42

Expt. 13-2 Time 3:50 ^{PM} Date 12-6 1955
Purpose Rod Evaluation with boron:
3 ecc. & 1 control in.
Personnel: _____

START-UP CHECK LIST
Equipment Checked by D.L. Personnel Check by D.M.
Instrument and Safeties Checked and _____ D.M.
"Source In" Checked by D.M. _____ D.M.
Emergency Equipment in Control Room _____
Red Light On by D.W. _____
Start-Up OK'd by D.W. Time 3:55 ^{PM} Date 12-6 1955

Loading: Fuel exactly the same as 13-1.

Boron: slot 11 contains boron throughout the reactor

Not critical.

Expr. 13-3 Time 4:20 ^{AM}/_{PM} Date 12-6 1955
 Purpose Rod evaluation with boron
3 ecc + 1 control in.
 Personnel: _____

START-UP CHECK LIST
 Equipment Checked by JL Personnel Check by RJ
 Instrument and Safeties Checked and Reset by DW
 "Source In" Checked by DW Source No. _____
 Emergency Equipment in Control Room Checked by RJ
 Red Light On by MB
 Start-Up OK'd by DW Time 6:20 ^{AM}/_{PM} Date 12-6 1955

Loading: Fuel exactly the same as 13-1.

Boron: slot II contains boron except for boxes:

3, 15, 17, 20, 26, 29, 31, 43. Also note no

B in boxes 9, 21, 23 & 27 ∴ Actual amount of B in slots =

Critical Conditions:

$13 \times 0.944 = 31.15g$

Height	109.5	control	{ Blade	0.00
Log N.	0.2		{ Rod	15.11


APPR	{ Eccentric	0.00
	{ Control	0.05

Blade pulled to - 13.50 inches; positive period taken
 Scrammed on photo-multiplier (set at 900V)

Log N at ~ 1.0

Blade worth 00.00 → 13.50"
 = 7.1 cents

425 = 1075 kg



Expr. 13-4 Time 8:30 ~~PM~~ Date 12-6 1955
 Purpose ROD EVALUATION WITH BARON
 Personnel: DVPW, JL, WRS, DWM

STARTUP CHECK LIST
 Equipment Checked by DWM Date _____ Book by DWM
 Instrument and Safety checked and _____ DWM
 "Source In" Checked by DVPW _____
 Emergency Equipment in Control Room Location by DWM
 Red Light On by Ch DWM _____
 Start-Up OK'd by DVPW Time 8:40 ~~PM~~ Date 12-6 1955

Because of Rod shielding Made, blade worth has decreased
 Returned to Boxes 9, 21, 23, & 25 as the 4 APPR rods
 in by interchanging boxes ²⁵ ~~26~~ and eccentric APPR rod.
 Hence box 25_A is in box 37 position in a control rod
 fuel and SS plates

Loading:

Same as 13-3 with above box change

[Eccentric rod that is out has boron attached, other rods have
 no fuel]

P.M. voltage decreased to 800V.

Critical Conditions:

Cental APPR	5000	Water height	109.5 cm
Ecc APPR	1000 (23.99)	Temp	71°F
Control Blade	1.907	Log N	0.16
Control Rod	29.02 (out)	DC-3	74. x 10 x 10

Positive period


Cont. Blade @ $17.85 - 14.07 = 3.78''$

176.5 sec period $\rightarrow 6.2 \text{ } \phi$

Levelled off with Cont Rod

29.02 \rightarrow 12.46

6.56" $\rightarrow 6.2 \text{ } \phi$



Mass U²⁵ = 17.025 \pm See page 41

$\sim 25 \text{ g}$ in Cont. Blade

$\sim \text{mass} = 18.31 - .025 = 18.29$

Expt. <u>13-6</u>	Time <u>11:45</u> ^{AM}	Date <u>12-6</u>	195 <u>5</u>
Purpose <u>Red Evaluation with Boron.</u>			
<u>Spec in close position of central in;</u> <u>other eccentric completely out.</u>			
Personnel: _____			


START-UP CHECK LIST			
Equipment Checked by <u>DM</u>	Personnel Check by <u>DM</u>		
Instrument and Safeties Checked and Reset by <u>JL</u>			
"Source In" Checked by <u>DW</u>	Source No. _____		
Emergency Equipment in Control Room Checked by <u>DM</u>			
Red Light On by <u>MP</u>	AM		
Start-Up OK'd by <u>DW</u>	Time <u>11:45</u> ^{AM}	Date <u>12-6</u>	195 <u>5</u>

Loading: some fuel loading as 13-~~4~~ together with
the box positions of 13-5.

exapt: boxes 1, 3, 5, 14, 16, 18, 28, 30, 32, 41, 43, & 45
are the only ones containing ~~SS~~ in slot 11; the rest
contain boron series "C";

Subcritical

plate pulled to 14.07 & period measured.



Expr. 13-8	Time 1:10 ^(AM)	Date 12-7 1955
Purpose Rod evaluation with boron - 4 ecc. in full & in close position. Central rod out.		
Personnel: _____		

START-UP CHECK LIST		
Equipment Checked by RJ	Personnel Check by DW	
Instrument and Safeties Checked and Reset by DM		
"Source In" Checked by DW	Source No. _____	
Emergency Equipment in Control Room Checked by MB		
Red Light On by MB		
Start-Up OK'd by DW	Time 1:10 ^(AM)	Date 12-7 1955

loading - exactly the same as 13-7 except the control rods in ~~the~~ positions 31 & 23 have been physically interchanged.

- Now, APPR rods in positions 15, 17, 29, & 31 in full. Have no fuel on bottom.
- APPR rod in position #23 completely out; fuel section attached.

Not critical - water up; blade out.

Log N 0.015

Expr. 14-1 Time 6:50 ^{AM} Date 12-7 1955
 Purpose Critical mass with boron.
(No APPR rods)
 Personnel: _____

INSTRUMENT CHECK

Date _____ 195____ Time _____ AM
 Trip _____ PM Source No. _____
 Instrument Value Scale Source Distance Start-Up scale

DC-1 _____
 DC-2 _____
 DC-3 ✓ 50 1 3"
 Log N _____ 12 sec.
 R-1 - 5.5 3x1000
 R-2 _____ 2100
 P. M. ✓ 900V 3"

START-UP CHECK-LIST

Equipment Checked by RS Personnel Check by DM
 Instrument and Safeties Checked and Tested by JL
 "Source In" Checked by JL Source No. _____
 Emergency Equipment in Control Room Checked by MB
 Red Light On by MB 7:50 AM
 Start-Up OK'd by JL Time 8:50 ^{AM} Date 12-7 1955

Loading:

slot	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Series	1	2	3	4	5	6	7	8	9	7	8	12	13	2	15	9	1	10
Material	f	3	f	3	3	f	3	f	3	f	3	f	3	f	3	f	3	f

fuel loading - complete loading of 9. (12.6 kg U²³⁵)

Boron loading - loading of 1-1/2 plate in all boxes

except 3, 15, 17, 20, 26, 29, 31, + 43. (6.56 gm B¹⁰)

Note: fuel boxes are all in normal position except:

because of bad box, box 22 is replaced by box 9; in position 9, an APPR rod-bottom & "dummy" rod are in correct. All fuel numbers correspond to Prev position.

(not box)

Much too reactive: critical at ~ 77 1/2 cm. water height.

Expt. <u>14-2</u>	Time <u>8:20</u> ^{AM}	Date <u>12-7</u> 195 <u>5</u>
Purpose <u>Critical Mass with Boron.</u>		
Personnel: _____		

START-UP CHECK LIST		
Equipment Checked by <u>DM</u>	Personnel Check by <u>DM</u>	
Instrument and Safeties Checked and OK'd by <u>JL</u>		
"Source In" Checked by <u>JL</u>		
Emergency Equipment in Control Room OK'd by <u>DM</u>		
Red Light On by <u>MB</u>		
Start-Up OK'd by <u>JL</u>	Time <u>8:20</u> ^{AM}	Date <u>12-7</u> 195 <u>5</u>

loading exactly the same as 14-1 except slot 16 now contains service fire fuel instead of service 9.

Still too reactive - water light ~ 88.7 ; critical

JF

Expt. <u>14-3</u>	Time <u>8:50^{AM}</u>	Date <u>12-7</u>	195 <u>5</u>
Purpose <u>Critical mass with boron.</u>			
Personnel: _____			
START-UP CHECK LIST			
Equipment Checked by <u>MB</u>	Personnel Check by <u>DW</u>		
Instrument and Safeties Checked and Reset by <u>JL</u>			
"Source In" Checked by <u>JL</u>	Source No. _____		
Emergency Equipment in Control Room Checked by <u>DM</u>			
Red Light On by <u>MB</u>	AM		
Start-Up OK'd by <u>JL</u>	Time <u>8:52^{PM}</u>	Date <u>12-7</u>	195 <u>5</u>

Loading: exactly the same as 14-1 except slot 16.

In all boxes slot 16 now contains series five plates except in ~~positions~~ ^{positions} 7, 9, 11, 21, 23, 25, 35, 37, 43. in which slot 16 contains S.S.

- U mass = 11.75 kg U^{235}

- Boron = 6.56 gm B^{10} .

Temp. 72°F

log N ~ 2.1

Reactor sub-critical. Blade out, rod out, water up.

We were slightly sub-critical. It is felt that the reactor would have been critical had we left in the left plates in 21 & 25 ~~It is felt that~~

Expt. <u>14-4</u>	Time <u>9:30</u> ^{AM}	Date <u>12-7</u> 195 <u>5</u>
Purpose <u>CRITICAL MASS WITH BORON</u> <u>ROD EVALUATION</u>		
Personnel:		
START-UP CHECK LIST		
Equipment Checked by <u>J. L.</u>	Personnel Check by <u>J. L.</u>	
Instrument and Safeties Checked and Reset by <u>D. M.</u>		
"Source In" Checked by <u>D. M.</u>	Source No	
Emergency Equipment in Control Room Checked by <u>D. W.</u>		
Red Light On by <u>J. L.</u>		
Start-Up OK'd by <u>A. B.</u>	Time <u>9:30</u> ^{AM}	Date <u>12-7</u> 195 <u>5</u>

LOADING SAME AS 14-1 EXCEPT SLOT 16
SLOT 16 NOW CONTAINS SERIES 5 PLATE
EXCEPT BOXES 7, 9, 11, 23, 35, 37, 39
which contain s.s.

U MASS 11.78 Kg - U²⁵ ✓ MD
B " 6.56 gm B¹⁰ 34.93 g Natural B ✓

TEMP 72 11.78 ✓ MD
LOG N 0.11 1.02 ✓ MD

WATER 109.3 cm. 11.76 with blade out

D C-3 69 x 10 x 10

CONTROL BLADE 14.45

ROD 29.01

NO APPR RODS

Expr. 14-5 Time 10:30 ^{AM} Date 12-7 1955
 Purpose Critical Mass with Boron.
 Personnel: _____

START-UP CHECK LIST
 Equipment Checked by R.J. Personnel Check by J.L.
 Instrument and Safeties Checked and Reset by R.J.
 "Source In" Checked by R.J. Source No. _____
 Emergency Equipment in Control Room Checked by M.B.
 Red Light On by M.B. AM
 Start-up OK'd by R.J. Time 10:20 AM Date 12-7 1955

Loading

slot	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Series	1	2	3	4	5	6	7	8	9	7	11*	12	13	2	15	11*	1	10
material	f	5	f	5	3	f	3	f	3	f	3	f	3	f	3	3	3	f

* Boron series C

slot 11 contains ~~2~~ in boxes: 1, 3, 5, 6, 8, ... 40, 41, 43, 45.

slot 16 contains series 5 fuel in boxes: 8, 10, 21, 25, 36, 38.

Total U mass = 11.27 kg U^{235} 11.29 kg U^{235}

Total B mass = 4.26 gm B^{10} 22.46 g of B ↳

Not critical, water up, blade & rod out.
 with source out, reactor going on "source" period.

56

Expr.	14-6	Time	10:55 ^{AM} PM	Date	12-7	1955
Purpose	Critical Mass with Boron					
Personnel:						

START-UP CHECK LIST						
Equipment Checked by	MB	Checked by	MB			
Instrument and Safeties Checked and			RJ			
"Source In" Checked by	RJ					
Emergency Equipment in Control Room		Checked by	JL			
Red Light On by	MB					
Start-Up OK'd by	RJ	Time	10:55 ^{AM} PM	Date	12-7	1955

Loading - same as 14-5 except slot 16.

Slot 16 contains s.s. in all boxes except 8, 10, 14, 18,
28, 32, 36, 38

Still sub-critical.

21, 25, 28, ~~32~~, 36, 37, 38


U mass = 11.37 kg U^{235}
 Boron Mass = 4.26 gm B^{10}

11.38
 11.32
 11.38
 - 1.06
 11.32

Critical Conditions:

Temp.	71.5°F	Height	109.2 cm.	blade width	11.38
Log N.	.15	Blade	3.015 in	-	1.06
DC-3	57 (10x20)	Rod	29.01 in		11.32

Rod pulled to 9.00 in; positive period measured.



Expr. 14-7 Time 11:30 AM Date 12-7 1955
 Purpose Critical Mass with Boron
 Personnel: _____

START-UP CHECK LIST
 Equipment Checked by MJB Personnel Check by JL
 Instrument and Safeties Checked and Reset by JL
 "Source In" Checked by RJ Source No. _____
 Emergency Equipment in Control Room Checked by MJB
 Red Light On by MJB AM
 Start-Up OK'd by RJ Time 11:30 AM Date 12-7 1955

loading - same as 14-5 except slot 16
 slot 16 contains ss in all boxes except 8, 9, 10, 14, 18
 21, 25, 28, 32, 36, 37, 38

U mass = 11.37 kg ^{4²⁵}
 Boron Mass = 4.26 _g ¹⁰

✓ md

$$\begin{array}{r} 11.38 \\ - 1.05 \\ \hline 11.33 \end{array}$$

made with mg - side 1/8


Critical Conditions:

Temp. 71.5°F Height 109.2 cm.
 Log N. .15 Blade 3.015 in
 DC-S 57 (10x20) Rod 29.01 in

black with

$$\begin{array}{r} 11.38 \\ - 1.06 \\ \hline 11.32 \end{array}$$

Rod pulled to 9.00 in; positive period measured.



12-8-55

Preliminary solution analyses (uncorrected for iron)

1.1329 Spec Grav

0.09698 gm U/gm solution

0.1099 gm U/cc

0.102 gm U-235/cc

9213 Spec Grav Meas. 1.1197

0.1086 gm U/cc

0.1012 gm U-235/cc

Design Element

2240 ± 10 cc

or 0.104 gm U-235/cc

12-¹³55Y-12 analytic lab requisition # 354736 gram for
solution analysis:

0.096550 gm U/gm solution.

0.08998 gm U²³⁵/gm solution. ✓

Date: 10-1 6:30 12-8-5
 Purpose: Homogeneity effect - zero run.
 Personnel:

Date: 12-8 MS Time: AM
 Instrument: Counts: 47 10x20
 5 12cm
 3 18x1000
 3 x100
 3"

Equipment checked by: RJ Personnel checked by: JW, MB
 Instrument and Safety: MB
 Source in? MB
 Equipment checked: MB
 Read by: MB
 Start: MB 630 8 Dec 5

Loading: "Cold Clean Critical", $7\frac{1}{2}^+$ plates/Box

Slot	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Series	1	2	3	4	5	6	7	5*	9	7	11	12	11	14	15	8	1	10
Type	F	$\frac{S}{3}$	F	$\frac{S}{3}$	$\frac{S}{3}$	F	$\frac{S}{3}$	$\frac{F}{2}$	$\frac{S}{3}$	F	$\frac{S}{3}$	$\frac{S}{3}$	F	$\frac{S}{3}$	$\frac{S}{3}$	F	$\frac{S}{3}$	F

[†] Slot 8, Boxes 7, 11, 35, 39.

Box	7	Slot 8	Fuel Plate # 3-41
"	11	"	MAC 378
"	35	"	4-20
"	39	"	6-40

Loading/Box w/ $7\frac{1}{2}$ plates = 233 gms U²³⁵
 Mass: 10.562

Critical

log N - .105

Control Blade 7.39

DC-3 76 ~~x10~~

Control Rod 29.01

Water Ht 109.5

Temp. 72°F

~~Mass~~

It was decided to pull the equivalent of $2\frac{1}{2}$ plates in order to put the critical position of the blade farther out. This is in anticipation of an increase in reactivity of $\sim 15\%$, when the Homogeneous element is substituted for a Normal Fuel Box.

Note: Boxes are in the same location as listed on page 51.

Expr. <u>15-2</u>	Time <u>7-15</u> PM	Date <u>8-Dec</u> 195 <u>5</u>
Purpose <u>Homogeneity Effect - Zero Run</u>		
<u>Adjusting Blade position by removing mass</u>		
Personnel: <u>MB, JL, RJ</u>		

START-UP CHECK LIST	
Equipment Checked by <u>RJ</u>	Personnel Check by <u>JL</u>
Instrument and Safeties Checked and Reset by <u>JL</u>	
Source In Charge by <u>MB</u>	Source No. _____
Emergency Equipment in Control Room Checked by <u>RJ</u>	
Red Light On by <u>RJ</u>	
Start-Up OK'd by <u>MB</u>	Time <u>7:15</u> PM Date <u>8-Dec</u> 195 <u>5</u>

Loading: Same as 15-1, except the following $\frac{1}{2}$ plates were substituted for full plates in Boxes 7+39.

Slot	Box	Plate	Substituted For	Plate
8	7	5-7 ($\frac{1}{2}$ plate)	" "	3-41 (full plate)
8	39	5-39 "	" "	6-40

Mass. 10.531

Critical:

Log N - 103

Control Blade 12.49

DC-3 74 110/10

Control Rod 29.01

Water Ht - 109.7

Temp 72°F

The remaining 2 full plates in Slot 8 will be replaced in order to give more Control Blade area to control the homogeneous box.

Results.

2- $\frac{1}{2}$ plates in Box 7+39 are worth $-(12.46 - 7.39) = 5.07$ in.
 This is worth 8.3¢ from chart or 0.267¢/gm U²³⁵ (calibration curve)

Expr. <u>15-3</u>	Time <u>7:40</u>	Date <u>8 Dec 1955</u>
Purpose <u>Homogeneity Effect -</u>		<u>Zero Run</u>
Personnel: <u>MB JL - RJ DW</u>		

START-UP CHECK LIST			
Equipment Checked by <u>MB</u>	Checked by <u>JL</u>		
Instrument and Safety Checked by <u>JL</u>	Checked by <u>JL</u>		
Source In Checked by <u>MB</u>	Checked by <u>JL</u>		
Emergency Equipment Checked by <u>RS</u>	Checked by <u>RS</u>		
Red Light On by <u>RS</u>	Checked by <u>RS</u>		
Start-Up OK'd by <u>MB</u>	Time <u>7:40</u>	Date <u>8 Dec 1955</u>	

loading: Same as 15-1, with no extra full plates, uniform
 $7\frac{1}{2}$ Plates/Box.
 Mass - 10.5 Kg U^{235}

Critical:

Log N .112

DC-3 76110110

Water Ht 109.5

Control Blade 20.91

Control Rod 29.01

Temp: 72°F

From the control blade evaluation curve, this change
 in position (between 15-3 & 15-2) is worth ~~9.8¢~~ 10.7¢
 The fuel in this position is ∴ worth ~~0.33¢~~ $\text{¢/gm } U^{235}$
 when averaged with 15-2, the fuel worth comes out
 to be ~~0.33¢~~ $\text{¢/gm } U^{235}$ for this position.

Expt. 15-4 Time 9:45 AM Date 12-8 1955
 Purpose Homogeneity effect - homogenous
 box in position 37
 Personnel:

START-UP CHECK LIST
 Equipment Checked by MB Personnel Check by JL
 Instrument and Safeties Checked and Reset by DW
 "Source In" Checked by DW Source No
 Emergency Equipment in Control Room Checked by MB
 Red Light On by MB
 Start-Up OK'd by DW Time 8:45 AM Date 12-8 1955

Loading - "pure" 7 1/2 Loading - same as 15-1 without the extra full plates.

In position 37, the special fuel box has been inserted. This box is a water-tight container the same size as the fuel box. Eighteen s.s. plates in normal position are inside the box.

See notes pg 84

The box contains 2,529.5 gm. of solution or ~~2529.5~~ ± 2 gm. of U²³⁵. The ~~other~~ rest of the boxes contain 7 1/2 plates of fuel or 253 gm. U²³⁵.

Critical Conditions

① Water height 99.2 cm. Rod 29.01
 Log N 0.062 Blade 0.01

② Rod inserted; Water ~~height~~ taken up.
 Water height 109.4 cm. Rod 15.25
 Log N 0.205 Blade 0.015
 DC-3 82.5 (10x20)
 Temp. 72.5 °F

Rod withdrawn to 29.02 Positive period measured

For a factor of 10, the period to 40 divisions.

$$40 \times 21.72 = 869 \text{ sec}$$

$$= 1.44 \text{ } \mu$$

The blade from 20.91 to 0 is worth ^{24.8} ~~23.9~~ μ
(from rod calibration curve)

\therefore the total change in reactivity between runs 15-3
& 15.4 is $\approx 25.3 \mu$

Note. Volume of solution in container was determined by three methods:


- weight loss of container: 2,529.5 \pm 1 gm.
- weight gain of element: 2535. \pm 1 gm.
- volume of material put in element: 2350 cc.

Using the average of the density measurements
(pg 58) together with the volume measurement,
the mass inserted is ~~2275~~ gm.
227.5

Critical Conditions.

Height	109.3	Log N	0.195
Rod	29.02	DC-3	75.5 (10x20)
Blade	14.26	Temp	71.5°F

Blade pulled to 17.25 positive period measured
 Blade pulled to 20.88; positive period again measured.



Expr. 15-5 Time 9:50 ^{AM} ~~PM~~ Date 12-8 1965
 Purpose Homogeneity effect - homogenous
box in position #43.
 Personnel: _____


START-UP CHECK LIST
 Equipment Checked by MB Personnel Check by DW
 Instrument and Safeties Checked and Reset by DW
 "Source In" Checked by DW Source No. MB
 Emergency Equipment in Control Room Checked by MB
 Red Light On by MB
 Start-Up OK'd by DW Time 9:50 ^{AM} Date 12-8 1965

Loadings exactly the same as 15-4 except the Homogenous box is now in position #43.

Critical Conditions.

Height	109.3	Log N	0.195
Rock	29.02	DL-3	75.5 (10x20)
Blade	14.26	Temp	71.5°F

Blade pulled to 17.25 positive period measured.
 Blade pulled to 20.88; positive period again measured.



Expr. 15-6 Time 10:45 AM Date 12-8 1955
 Purpose Homogeneity effect - new zero point evaluation
 Personnel:

START-UP CHECK LIST
 Equipment Checked by JL Personnel Check by JL
 Instrument and Safeties Checked and Reset by JL
 "Source In" Checked by DW Source No. MB
 Emergency Equipment in Control Room Checked by MB
 Red Light On by MB AM
 Start-Up OK'd by DW Time 10:45 AM Date 12-8 1955

• Loading - same as 15-4 (including homogenous box in position 37) except half plates pulled from boxes 21 & 25.

Critical conditions.

Height	109.4	Log N	.19
Rod	29.02	De-3	72(10x20)
Blade	16.25	Temp.	71.50F

This has evaluated the ^{half plates} fuel in boxes 21 & 25.
 ∴ value of blade at 16.25 is 20.2¢. (from calibration curve.)
 ∴ The value of the fuel is therefore $20.2 + 1.44 = 21.6$ ¢.
 (0.695¢/gm U²³⁵)

✓ MB

Expr. 15-7 Time 11:15 AM Date 12-8 1955
 Purpose Homogeneity effect - homogenous element in position 23
 Personnel:

START-UP CHECK LIST
 Equipment Checked by RW Personnel Check by JL
 Instrument and Safeties Checked and Reset by JL
 "Source In" Checked by RW Source No. MB
 Emergency Equipment in Control Room Checked by MB
 Red Light On by MB AM
 Start-Up OK'd by DJ Time 11:15 AM Date 12-8 1955

Loading: same as 15-4 with the homogenous box in position 23. - complete loading of 7 1/2 plates with the half plates removed from boxes 7, 11, 21, 25, 35 & 39.

~~Half plates removed:~~

The value of the half plates removed is assumed to be $8.3¢ + 9.8¢ + 21.6¢ = 39.7$ ¢ from experiments 15-2, 15-3, & 15-6 respectively.

Expt. 15-7 Time 11:15 AM Date 12-8 1955
 Purpose Homogeneity effect - new zero point evaluation
 Personnel:

START-UP CHECK LIST
 Equipment Checked by RJ Personnel Check by JL
 Instrument and Safeties Checked and Reset by JL
 "Source In" Checked by RJ Source No.
 Emergency Equipment in Control Room Checked by MB
 Red Light On by MB
 Start-Up OK'd by RJ Time 11:15 AM Date 12-8 1955

Loading - complete loading of 7 1/2 with half removed from 7, 11, 35, 39. Homogeneous element in #37. (For series numbers, see page 59)

Condition			
Log N	0.14	Water	109.1
DC-3	51 (10x20)	Rod	29.01
Temp.	71.5°F	Blade	15.995

∴ The value of the half plates in 7, 11, 35, 39 is the value of the blade from 16 to 0 plus 1.44 (see experiment 15-4)
 This is (from the blade calibration curve)
 $19.99 + 1.44 = 21.43 \text{ } \phi$

Expt. 15-8 Time 11:50 AM Date 12-8 1955
 Purpose Homogeneity effect - homogeneous element in position 23.
 Personnel:

START-UP CHECK LIST
 Equipment Checked by JL Personnel Check by JL
 Instrument and Safeties Checked and Reset by JL
 "Source In" Checked by RJ Source No.
 Emergency Equipment in Control Room Checked by MB
 Red Light On by MB
 Start-Up OK'd by RJ Time 11:50 AM Date 12-8 1955

Loading - complete loading of 7 1/2 with half plates removed from 7, 11, 21, 25, 35, 39. Homogeneous element in #23. (For series numbers, see page 59.)

The total value of fuel removed from the reactor from the original zero point (15-3) to this loading is 21.43 ϕ (exp. 15-7) plus 21.6 ϕ (exp. 15-6) or a total of 43.0 ϕ .

Log N	0.11	Height	109.4
DC-3	79 (10x10)	Rod	29.01
Temp.	72°F	Blade	13.06

The blade value between 20.9 (exp 15-3) + 13.06 (this exp.) is 34.0 ϕ .
 ∴ The total reactivity change between the "zero" run (exp. 15-3) + having the homogeneous box in position 23 is 34.0 ϕ + 43.0 ϕ or 77.0 ϕ .

Expt. 16-1 Time 6:00 AM Date 12-14 1955
 Purpose Zero-run: ^{2 1/2} experiment
 Personnel: DMM

INSTRUMENT CHECK
 Date 12-14 1955 Time 6:00 AM Source No. Trip
 Instrument Value Scale Source Distance Start-Up Scale
 DC-1
 DC-2
 DC-3 ✓ 45 10x20
 Log N ✓ 6750
 R-1 ✓ 4.5 .8x1000
 R-2
 P.M. ✓ 3'

START-UP CHECK LIST
 Equipment Checked by RJ Personnel Check by MB
 Instrument and Safeties Checked and OK'd by JL
 "Source In" Checked by JL Source No.
 Emergency Equipment in Control Room Checked by RJ
 Red Light On by MB+JL AM
 Start-Up OK'd by Time 6:00 AM Date 12-14 1955

Loading - a straight 7 1/2 with these additional plates:
 Box 7 contains 6.40 in slot 8 instead of its half plate

- 11 " 3-41
- 35 MAC 378
- 39 4-20
- 43 1-17

Slot	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Series	1	2	3	4	5	6	7	5	9	7	11	12	11	14	15	8	1	10
Material	F	S	F	S	S	F	S	F	S	F	S	S	F	S	S	F	S	F

Notes: Yesterday evening when we went to take the homogeneous box out of the core & found that it has been leaking solution. The contamination in the tank was very well localized to the box #24, the center plug, & the rubber cover over the dump valve. (See ~~the~~ ^{the} page)

Conditions - super critical.
 blade ~~in~~ in; rod in; water up

It is desirable to get the zero run condition with the blade near zero.

We are pulling, therefore, full plate 4-20 out of slot 8 of box 39 and re-inserting plate 5-39.

12-13-55

To determine the amount of U solution lost from the liquid fuel element, its contents were removed and weighed.

3571 g. = wt of fuel solution bottle (final)
 1059 g. = tare wt. of bottle (some solution still in it)
 2512 g = amount removed from liquid element
 ∴ 43 g short of original wt in element (p. 64)

Wt. of solution removed (in five steps: 470 cc, 452, 461, 446 and 393 = total of 2242 cc
 ∴ 8 cc lost from volume added of 2250 cc (p. 64)
 (Cont. to item p. 72)

Expt. <u>16-2</u>	Time <u>6:45</u> ^{AM} _{PM}	Date <u>12-14</u> 19 <u>53</u>
Purpose <u>Zero Run</u>		
Personnel: _____		
START-UP CHECK LIST		
Equipment Checked by <u>RJ</u>	Personnel Check by <u>RJ</u>	
Instrument and Safeties Checked and Reset by <u>RJL</u>		
"Source In" Checked by <u>JL</u>	Source No. _____	
Emergency Equipment in Control Room Checked by <u>MB</u>		
Red Light On by <u>MB</u>	Time <u>6:45</u> ^{AM} _{PM}	
Start-Up OK'd by <u>JL</u>	Date <u>12-14</u> 19 <u>53</u>	

Loading - same as 16-1 except 4-20 removed & replaced by 5-39.

Critical Condition:

Hight	109.6 cm	DE-3	89. (10x10)
Rod	13.13	Log N	0.11
Blade	0.03	RT	4.75 (50x1000)

Man = 10.562 Kg
 - 0.50 for Blank
 10.592 Kg Crit. Man

12/14/53
10P

Water sampled following mixing in Runs 16-2, 3, & 4 -

Sample Req	354741
Gross wgt	76.759 gm.
Tare	45.373
Net	31.386

12/15 Result (by phone) 0.03 ppm U
 (~ 0.2 gm^U in 1500 gal).

Expr.	16-3	Time	8:45 ^{AM}	Date	12-14	1955
Purpose	C.C.C. loading: slot 10, box 25 removed.					
Personnel:						
START-UP CHECK LIST						
Equipment Checked by	JL	Personnel Check by	JL			
Instrument and Safeties Checked and Reset by	JL					
"Source In" Checked by	JL	Source No.				
Emergency Equipment in Control Room Checked by	MB					
Red Light On by	MB					
Start-Up OK'd by	JL	Time	8:45 ^{PM}	Date	12-14	1955

loading - same as 16-2 except fuel in slot 10, box 25 removed & replaced by s.s. : fuel 7-25 replaced by s.s. 10-25

Log N 0.09
Temp. 73°F

Barely sub-critical with source out
Blade out. Rod out 13.13.

74

Expt. 16-4	Time 9:25	Date 12-14	1955
Purpose CCC loading Slot 8 box 25 to plates removed			
Personnel:			

START-UP CHECK LIST			
Equipment Checked by MB	Checked by MB		
Instrument and Safety Checked by JL	Checked by JL		
"Source In" Checked by MB	Checked by MB		
Emergency Equipment in Control Room Checked by JL	Checked by JL		
Red Light On by JL	Checked by JL		
Start-Up OK'd by MB	Time 9:25 AM	Date 12-14	1955

Loading same as 16-2 except ^{now} SS in slot 8 &
5-25 removed from slot 8 box 25

Critical conditions

Height	109.4	DC-3	82 (10x10)
Rod	13.13	Log N	0.103
Blade	12.09	RC 7	2.25 (100x1000)
Temp	72.5°F		

12.09 " = 13.34 which is

width of 1/2 fuel plate in Slot #8
of box 25

Expt. <u>16-5</u>	Time: <u>11:05</u> ^{AM} _{PM}	Date <u>12-14</u> 195 <u>5</u>
Purpose <u>Zero with one full boron.</u>		
Personnel:		

START-UP CHECK-LIST		
Equipment Checked by <u>MB</u>	Personnel Check by <u>JL</u>	
Instrument and Safeties Checked and	<u>DUPW</u>	
"Source In" Checked by <u>DUPW</u>	Source No.	
Emergency Equipment in Control Room Checked by <u>MB</u>		
Red Light On by <u>JL</u>	AM	
Start-Up OK'd by <u>DUPW</u>	Time: <u>11:05</u> ^{AM} _{PM}	Date <u>12-14</u> 195 <u>5</u>

Loading - complete loading of 9 1/2 u. of one full boron plate per box.

slot	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Series	1	2	3	4	4	6	7	5	9	7	9	12	11	"B"	15	8	1	10
material	f	f	f	f	f	f	f	f	f	f	f	f	f	B	f	f	f	f

Mass U = 13.3 kg U²³⁵ 13.295 kg U-235
 Mass B = 85.0 gm Net. Boron

Sub-critical

LogN 0.15

Source out; blades rod out; water up.

Considered ~~crit~~ within 1st criticality.

Expt. 16-6	Time 11:30 ^{AM} (PM)	Date 12-14 1955
Purpose Critical mass with one full boron		
Personnel: _____		

START-UP CHECK LIST	
Equipment Checked by DC	Personnel Check by DC
Instrument and Safeties Checked and Ready by DC	
"Source In" Checked by D.V.P.W.	
Emergency Equipment in Control Room Checked by MB	
Red Light On by JL	
Start-Up OK'd by D.V.P.W.	Time 11:30 ^{AM} (PM) Date 12-14 1955

Loading - same as 16-5 except half plates in boxes 7+35 replaced by full plates.

5-7 replaced by 6-40*

5-35 " " 1-17*

U mass = 13.34 kg U²³⁵

Boron mass = 85.0 gm. Nat boron.

13.33 kg - U-235 ✓ MB

85.0 gm B

13.31 kg. - U-235 count
of rod


Critical Conditions

Height	109.6 cm.	DC-3	60 (10x20)
Blade	15.72 in.	R-1	3.4 (100x1000)
Rod	29.01 in.	Log N	0.15
		Temp.	73°F

Blade pulled to 28.20: positive period measured.

blade correction = 0.03

mass with blade correction = 13.30



$$9.5 \times 45 = 427.5$$

$$.5 \times 2$$

$$\frac{1}{427.5}$$

$$\times 33.4 = 14.229 \text{ kg}$$

$$\times 31.1 = 13.295 \text{ kg U-235}$$

Expt. 16-7	Time 12:05 ^{AM}	Date 12-15 1955
Purpose Critical mass with one full boron.		

START-UP CHECK LIST		
Equipment Checked by DC	Personnel Check by DC	
Instrument and Safeties Checked and Reset by DVPW		
"Source In" Checked by JL	Source No.	
Emergency Equipment in Control Room Checked by MB		
Red Light On by MB		
Start-Up OK'd by JL	Time 12:05 ^{AM}	Date 12-15 1955

Loading - same as 16-5 except half plates in boxes 7, 21 & 35 replaced by full plates.

5-7	replaced by 6-40*	13.295	
5-21	" " #378	+ .047	
5-35	" " 1-17*	+ 13.342	
		- 26	plate
		<hr/>	
		13.316	

Critical Heizer Conditions

Blank	11.635	Lag N	0.14
Rod	29.01	DC-3	55 (10x20)
Water	109.3	R-1	3.1 (100x1000)
		Temp.	73°F

Expt. 16-8 Time 12:25 ^(AM) PM Date 12-15 1965
 Purpose AK evaluation - one full boron
plate per box
 Personnel: _____

START-UP CHECK LIST

Equipment Checked by RJ Personnel Check by RJ
 Instrument and Safeties Checked and Reset by RJ
 "Source In" Checked by RJ Source No. _____
 Emergency Equipment in Control Room Checked by MB
 Red Light On by MB
 Start-Up OK'd by RJ Time 12:25 ^(AM) PM Date 12-15 1965

Loading - same as 16-7 except half plate in box 25
 replaced by s.s.

5-25 replaced by s.s. 8-25

Critical Conditions

Water	109.2	Log N	.15
Roll Blade	15.32	DC-3	56 (10x20)
Roll Roll	29.01	R-1	3.2 (100x1000)
		Temp.	73 °f

Using the c.c.c. blade calibration curve (which from
 exp. 16-6 looks to be valid), the value of the fuel
 in slot 8 turns out to be 6.2 cents.

Expr: 17-1 Time 6:20 ^{AM} Date 12-15 1955
 Purpose Effect of lumpy ~~and~~ boron.
Zero Ran
 Personnel: _____

START-UP CHECK LIST
 Equipment Checked by RJ Personnel Check by MB
 Instrument and Safeties Checked and Reset by MB
 "Source In" Checked by RJ Source No. _____
 Emergency Equipment in Control Room Checked by MB
 Red Light On by MB ^{AM}
 Start-Up OK'd by RJ Time 6:20 ^{AM} Date 12-15 1955

loading: complete loading of 9 1/2 plus ^{four} exchanges of ~~full~~ ^{half} plates by full plates.

slot	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Swic	1	2	2	4	4	6	7	5	9	7	9	12	11	"B"	15	8	1	10
material	f	s	f	s	f	f	s	f	s	f	f	s	f	B	s	f	s	f

except: slot 8 box ⁷ contains 6-40* instead of 5-7
 21 " " #378 " " 5-21
~~25~~ " " ~~35~~
 35 " " 1-17* " " 5-35

INSTRUMENT CHECK
 Date 12-15 1955 Time 6:20 ^{AM} Source No. _____
 Trip _____
 Instrument Value Scale Source Distance Start-Up Scale
 DC-1 _____
 DC-2 _____
 DC-3 _____
 Log N 12.5u.
 R-1 5 1000x
 R-2 _____ 100
 P. M. _____ 3u

Water up, blade out, rod out, source out.
 Log N 0.8
 Reactor sub-critical

Expr. 17-2	Time 7:00 ^{AM} _{PM}	Date 12-15 1955
Purpose <u>Effect of lumpy boron</u> <u>Zero Run</u>		
Personnel: _____		

START-UP CHECK LIST		
Equipment Checked by <u>MB</u>	Personnel Check by <u>MB</u>	
Instrument and Safeties Checked and Reset by <u>MB</u>		
"Source In" Checked by <u>RJ</u>	Source No. _____	
Emergency Equipment in Control Room Checked by <u>MB</u>		
Red Light On by <u>MB</u>	AM	
Start-Up OK'd by <u>RJ</u>	Time 7:00 ^{AM} _{PM}	Date 12-15 1955

Loading: Same as 17-1 plus:

full plate in slot 8 box #11 (1-16 in → 5-11 out)
25 (1-19 in → 5-25 out)
39 (3-4 in → 5-39 out)

We thus now have a complete loading of 9½ plus 6 half plates

Note: run 17-1 should have agreed with run 16-7. The "zero" seems to have taken a drastic shift.

Critical conditions:

Blank	13.33	Log N	0.91
Rod	29.01	De-3	67 (10x10)
Water	109.2	R-1	4.1 (50x1000)
		Temp.	73 °F

Expr. 17-3	Time 8:20	Date 14 Dec 1955
Purpose The Effect of Lumping Boron Boron (Fall Boron replaced by 2 1/2 plates)		
Personnel: MB DW RS		

Equipment Checked by MB	Check by RS
Instrument and Safety Log MB	
"Source In" Checked by MB	
Emergency Equipment DW	
Red Light On by DW	
Start-Up OK'd by MB	Time 8:20 Date 14 Dec 1955

Loading: Same As 17-2: ~~Except~~ Except The Boron Fall plate in slot 14, Box 23 was Replaced By Boron 1/2 plates in Slots 14 + 2., and steel removed from slot.

Subcritical: Source out, Rods Blade out,
log N .1

By Changing the Boron from a single fall plate to two 1/2 plat
the effect of Boron Poisoning is increased.

^{apparent} IRa magnitude of this effect is $> 29'' - 13.3''$ on the Control Blade
 $\approx 27 - 16 \approx 11''$

Expr.	17-4	Time	9:00 AM	Date	14 ¹⁵ Dec 1955
Purpose	The effect of Lumping Boron (Evaluation of fuel)				
Personnel:	MB, JL, RJ				

START-UP CHECK LIST	
Equipment Checked by	MB Personnel Check by RJ
Instrument and Safeties Checked and Reset by	JL
Source In ¹ Checked by	MB No.
Emergency Equipment in Control Room Checked by	RJ
Red Light On by	RJ AM
Start-Up OK'd by	MB Time 9:00 PM Date 14 Dec 1955

Loading: Same as 17-2, except that a full fuel plate ¹⁻¹⁵ ~~1-14~~ was put in place of $\frac{1}{2}$ plate 5-37, in slot 8 of Box 37.

Critical.

Water, 109.5

Control Blade 12.46

log N .1

Control Rod 29.01

DC-3 77 X10K10

Temp 72.5°F

The apparent effect of loading the extra full $\frac{1}{2}$ fuel plate was only of the order of $\frac{1}{2}\%$. At this point it was decided to recheck the zero loading of 17-2.

Expr. <u>17-6</u>	9 30 O	¹⁶ <u>14 Dec</u> 1965
Purpose: <u>The effect of Lumping of Boron</u> <u>[Recheck Zero Run (17-2)]</u>		
Personnel: <u>MB JL WRS</u>		

Equipment Checked by <u>MB</u>	Checked by <u>RS</u>
Instrumentation <u>MB</u>	
Source Int'l's <u>MB</u>	
Emergency Repairs <u>JL</u>	
Red Light On by <u>JL</u>	
Start-Up OK'd by <u>MB</u>	9 30 O Date <u>14 Dec</u> 1965

Loading: SAME as 17-2

Critical:

Water 109.5	Control Blade 16.49
Log N. .11	Control Rod 29.01
DC-3 76 X10X10	Temp 72.5

The "Zero" position found for this loading in run 17-2 was at 13.33" on the Control Blade.

Higher power level position near:

Critical

Water 109.5	Control Blade 15.01
Log N - .19	Control Rod 29.01
DC-3 79.5 X10X20	TEMP. 72.5

Expr. 11a-9 Time 10:40 ^{AM} Date 12-15 1955
 Purpose critical Mass with boron
1/2
 Personnel: _____

START-UP CHECK LIST

Equipment Checked by JSJ Personnel Check by MB
 Instrument and Safeties Checked and Reset by JSJ
 "Source In" Checked by RS
 Emergency Equipment in Control Room Checked by MB
 Red Light On by RSJ ^{AM}
 Start-Up OK'd by JSJ Time 10:50 ^{AM} Date 12-15 1955

Loading:

shot	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
series	1	2	3	"C"	4	6	7	5	9	7	9	12	U	"B"	15	8	2	10
material	f	f	f	B	f	f	f	f	f	f	f	f	f	B	f	f	f	f

Reactor very sub-critical, blade out, rod out, water ~~out~~ up.
 Log N 0.01.

Expt. <u>16-10</u>	Time <u>11:25</u> ^{AM} PM	Date <u>12-5</u> 19 <u>5</u>
Purpose <u>Critical Mass with Boron -</u> <u>1 + 1/2 plates</u>		
Personnel: _____		

START-UP CHECK LIST	
Equipment Checked by <u>JL</u>	Personnel Check by <u>JL</u>
Instrument and Safeties Checked and Reset by <u>RS</u>	
"Source In" Checked by <u>MB</u>	Source No. _____
Emergency Equipment in Control Room Checked by <u>MB</u>	
Red Light On by <u>MB</u>	
Start-Up OK'd by <u>RS</u>	Time <u>11:25</u> ^{AM} PM Date <u>12-5</u> 19 <u>5</u>

Loading - complete loading of ~~11~~ 11.

slot	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Series	1	2	3	"0"	4	6	7	12	9	7	9	12	11	"B"	15	8	2	10
material	P	S	F	B	F	F	S	F	S	F	F	S	F	B	S	F	F	F

Critical at water height of 90.5 cm.

$$\text{Log } N = 0.12$$

DC-3 84 (5x10)

Rod out; blade in; source out.

Too reactive: going to pull 12 - half plates.

Critical conditions:

Log N 0.16 Height 109.2

DC-3 58.5 (20x10) Blade 13.40

R-1 3.6 (100x1000) Rod 29.01

Temp. 75°F

blade correction = -0.3
critical mass with blade = 15.18

U mass = 15.21 kg U²⁵


15.203 kg U²⁵

B mass = 127.5 gm Net B

- 20 blade

15.183 kg U²⁵

Blade pulled to 16.65 + positive period measured.



Expt. 16-11 Time 11:50 AM Date 12-15 1965
 Purpose Critical mass with boron = 1 1/2 plates
 Personnel:

START-UP CHECK LIST
 Equipment Checked by RJ Personnel Check by JL
 Instrument and Safeties Checked and Reset by RJ
 "Source In" Checked by RJ Source No.
 Emergency Equipment in Control Room Checked by MB
 Red Light On by MB
 Start-Up OK'd by RJ Time 11:50 AM Date 12-15 1965


Loading - same as 16-10 except slot 8 contains PuF plates
 in the following boxes: 1, 3, 5, 14, 16, 18, 28, 30, 32, 41, 43, 45

Critical conditions:

LogN	0.16	Height	109.2
DC-3	58.5 (20x10)	Blade	13.40
R-1	3.6 (100x1000)	Rod	29.01
Temp.	75°F	blade correction =	- .03
		critical mass with blade =	15.18

U mass =	15.21 kg U ²³⁵	15.208 kg U ²³⁵ ✓ MD
B mass =	<u>127.5</u> gm Nat B	2° blade
	"	15.188 kg U ²³⁵ - 2°

Blade pulled to 16.65 + positive period measured.



INSTRUMENT CHECK				
Date	16 Dec 1955	Time	4.42 AM	Source No.
Instrument	Value	Area	Source Distance	Start-Up Scale
DC-1				
DC-2				
DC-3	✓ 85	110120		
Log N	✓ ~125cc		210	
R-1	✓ 5.6	11000000	Constant	
R-2			2 in	
P. M.	✓	✓		3 in

Expt.	16-12	Time	1700 AM	Date	16 Dec 1955
Purpose	Critical Mass w. Boron Zero Run				
Personnel:					

START UP CHECK LIST					
Equipment Checked by	JL	Checked by	JL		
Instrument and Set		Checked by	RJ		
Source In		Checked by			
Emergency Eq.		Checked by	RJ		
Red Light (if eq.)	RJ				
Start-Up OK'd by	RJ	Time	1700 AM	Date	16 Dec 1955

LOADING SAME AS 16-11 ZERO CHECK
CRITICAL CONDITIONS

WATER: HEIGHT 109.1 TEMP 73°

LOG N .155

DC B 54 (10 X 20)

R1 3.4 ($\frac{100}{50} \times 1000$)

BLADE: ~~17.99~~ 16.50 IN.

ROD: 29.01

Expt.	16-13	Time	1805 ^{AM}	Date	16 Dec 1955
Purpose	Critical Mass with Boron Fuel Evaluation for 4K/AM				
Personnel:	RJ JL				

START-UP CHECK LIST	
Equipment Checked by	JL Personnel Check by
Instrument and Safeties Checked and Reset by	JL
"Source In" Checked by	RJ Source No.
Emergency Equipment in Control Room Checked by	RJ
Red Light On by	JL AM
Start-Up OK'd by	JL Time 1807 PM Date 16 Dec 1955

Loading: Same as 16-12. except 55 plate 8-25 in slot 8 Box 25
in place of fuel 12-25

The following full plates were put in in place of $\frac{1}{2}$ plates,
in slot 8.

Full Plate	^{MAC} 378	Box 1	in Place of $\frac{1}{2}$ Plate	5-1
" "	1-17X	" 3	" " " "	5-3
" "	4-20 ¹	" 5	" " " "	5-5
" "	6-40 ²	" 41	" " " "	5-41
" "	1-16 ¹	" 43	" " " "	5-43
" "	1-19 ¹	" 45	" " " "	5-45

This extra fuel was added to balance the removal of
the fuel plate (12-25) and also to bring the critical blade
position ~~down~~ ^{up} ^{high} enough so that the excess reactivity
addition when a $\frac{1}{2}$ plate is put in slot 8 Box 25 can be measured
on the control blade.

The Arrangement was Subcritical

Expr. <u>16-14</u>	Time <u>10:59</u> ^{AM} _{PM}	Date <u>16 Dec</u> 195 <u>5</u>
Purpose <u>Critical Mass with Boron</u>		
<u>Fuel evaluation for AK/AM measurement</u>		
Personnel: <u>RT, JL</u>		

START-UP CHECK LIST		
Equipment Checked by <u>JL</u>	Personnel check by <u>JL</u>	
Instrument and Safeties checked by <u>JL</u>		<u>RT</u>
"Source In" Checked by <u>JL</u>		
Emergency Equipment in <u>OK</u> and items <u>OK</u>		<u>RS</u>
Red Light On by <u>RT</u>		
Start-Up OK'd by <u>JL</u>	Time <u>1900</u> ^{AM} _{PM}	Date <u>16 Dec</u> 195 <u>5</u>

Loading: Same as 16-13 except $\frac{1}{2}$ plate 5-13 is inserted
in Box 13 slot 9 ~~instead of~~ in place of SS 9-13

This arrangement was Subcritical

Expr.	16-15	Time	1925	AM	Date	16 Dec	1955
Purpose	Critical Mass with Boron Fuel Evaluation for A/R/qm measurement						
Personnel:	RJ, JL						

START-UP CHECK LIST	
Equipment Checked by	JL Personnel Check by RJ
Instrument and Safeties Checked and Reset by	JL
Source In" Checked by	JL Source No.
Emergency Equipment in Control Room Checked by	RJ
Red Light On by	RJ AM
Start-Up OK'd by	JL Time 1926 PM Date 16 Dec 1955

Loading: Same as 16-14 except $\frac{1}{2}$ plate 5-27, is inserted in Box 28 Slot 9 in place of SS 9-28.

Critical:

Log N .16	Control Blade 18.02
DC-3 56x10x20	Control Rod 29.01
Water Ht 109.8	Water Temp. 73°F

This critical position will be used to find the value of a $\frac{1}{2}$ fuel plate added to Slot 8, Box 25, in place of a stainless steel Plate.

Mass	15.301	kg of 25
	.006	g
	<hr/>	
	15.295	

Expt. <u>16-16</u>	Time <u>17:40</u> ^{AM} _{PM}	Date <u>16 Dec</u> 195 <u>5</u>
Purpose <u>Critical Mass With Boron</u> <u>(Fast evaluation) Axiom</u>		
Personnel: <u>RJ, JL</u>		

START-UP CHECK LIST	
Equipment Checked by <u>JL</u>	Personnel Check by <u>RJ</u>
Instrument and Safeties Checked and Start by <u>JL</u>	
"Source In" Checked by <u>JL</u>	Source No. <u></u>
Emergency Equipment in Control Room checked by <u>RJ</u>	
Red Light On by <u>RJ</u>	AM <u></u>
Start-Up OK'd by <u>JL</u>	Time <u>1740</u> PM Date <u>16 Dec</u> 195 <u>5</u>

Loading: Same as 16-15 except that SS in slot 8 of Box 25⁸⁻¹⁵ was replaced by $\frac{1}{2}$ Plate 5-25.


This ^(Run 16) experiment compared with 16-15 will give the value of a $\frac{1}{2}$ plate in slot 8 Box 25.

~~BE~~
Critical:

Log N. .15	Control Blade 14.40
Dc3 5411020	Control Rod 29.01
Water Hl. 109.6	Water Temp 73°F.

Control Blade pulled to 18.03 from 14.4 giving a
The blade was pulled to positive ~~rod~~
positive period of 208 sec.

This period calculates to be 5.44.



Expr. <u>16-17</u>	Time <u>2121</u> AM	Date <u>16 Dec</u> 195 <u>5</u>
Purpose <u>Critical Mass With Boron 2 plates/Box</u>		
Personnel: <u>DM, DW, RJ, JL</u>		

START-UP CHECK LIST	
Equipment Checked by <u>DM</u>	Personnel Check by <u>RJ</u>
Instrument and Safeties checked and OK'd by <u>JL</u>	
"Source In" Checked by <u>DM</u>	
Emergency Equipment in Control Room checked by <u>RJ</u>	
Red Light On by <u>RJ</u>	
Start-Up OK'd by <u>DM</u>	Time <u>2121</u> PM Date <u>16 Dec</u> 195 <u>5</u>

Loading

Slot	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Series	1	13	3	"B"	4	6	7	12	9	7	9	7 ⁵	11	"B"	15	8	2	10
Type	f	f	f	B	f	f	f ^{SS*}	f	SS	f	f	f ^{f/2}	f	B	3	f	f	f

Equivalent to a full 13 plate/Box loading.

* Slot 7

Contains SS in Boxes 1-3-5-6-8-10 - - - 36-38-40-41-43-45

Contains $\frac{1}{2}$ fuel (5) in Boxes 2-4-7-9-11 - - - 37-39-42-44,

(Note: Box 25 has fuel (5) in slot 8, fuel 12-25 in slot 7)

⊙ Slot 12

Contains fuel Series 14 in Boxes 1-3-5-6-8-10 - - - 36-38-40-41-43-45

Contains $\frac{1}{2}$ fuel Series 5 in Boxes 2-4-7-9-11 - - 37-39-42-44.

$$\text{Boron Mass} = 2 \times 45 \times \frac{1.889}{100} \text{ gms} = 1.70 \text{ gms}$$

$$\text{U}^{235} \text{ Mass} = 13 \times 1.41 \text{ g} = 18.2 \text{ Kgs}$$

Super Critical at 78.1 " of Water

Expt. <u>16-18</u>	Time <u>2215</u> ^{AM} PM	Date <u>16 Dec</u> 195 <u>5</u>
Purpose <u>Critical Mass With Burn 2 Plates</u>		
Personnel: <u>DM, DW, RJ, JL</u>		

START-UP CHECK LIST	
Equipment Checked by <u>DM</u>	Personnel Check by <u>RJ</u>
Instrument and Safeties Checked and Reset by <u>JL</u>	
Source In Checked by <u>DM</u>	Source No. _____
Emergency Equipment in Control Room Checked by <u>RJ</u>	
Red Light On by <u>RJ</u>	AM _____
Start-Up OK'd by <u>DM</u>	Time <u>2215</u> PM Date <u>16 Dec</u> 195 <u>5</u>

Loading: Same as 16-17 except all series "5" $\frac{1}{2}$ plates were removed from Slots 7+12 of Boxes 2-4-7-9-11... 37-39-42-44, and replaced with SS of the proper Series (7+12 Slot 8, Box 25 still contains a $\frac{1}{2}$ plate (Series 5) and a full fuel plate in slot 7.

Supercritical: with water at 02.9

Expr. <u>16-19</u>	Time <u>2240</u> ^{AM}	Date <u>16 Dec</u> 195 <u>5</u>
Purpose <u>Critical Mass with Boron</u>		
Personnel: <u>DM, DW, JLR, RJ</u>		

START UP CHECK LIST	
Equipment Checked by <u>DM</u>	Source In Check by <u>RJ</u>
Instrument and Safety checked by <u>DM</u>	
"Source In" Checked by <u>DM</u>	
Emergency Equipment in Control Room checked by <u>RJ</u>	
Red Light On by <u>RS</u>	
Start-Up OK'd by <u>DM</u>	Time <u>2240</u> ^{PM} Date <u>16 Dec</u> 195 <u>5</u>

Loading

Slot	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Series	1	13	3	"B"	4	6	7	12	9	7	9	12	11	"B"	15	8	2	16
Type	f	f	f	B	f	f	S ₃	f	S ₃	f	f	S ₃	f	B	S ₃	f	f	f

Slot 8 Box 25 Contains Series 5 plate, Slot 7 Box 25 Contains Fuel 12

Super critical 97.3

Expr. 16-20 Time 2305 ^{AM} _{PM} Date 16 Dec 1965
 Purpose Critical Mass with Boron - 2 plates per element.
 Personnel: DM, DW, JL, RS

START-UP CHECK LIST

Equipment Checked by DM Personnel Check by RS
 Instrument and Safeties Checked and Reset by DM
 Source Inlet checked by DM Source No. _____
 Emergency Equipment in Control Room Checked by RS
 Red Light On by RS AM
 Start-Up OK'd by DM Time 2305 PM Date 16 Dec 1965

Loading:

Same as 16-19 except the following $\frac{1}{2}$ plates were put in the place of full plates -

- Box 7, $\frac{1}{2}$ plate 5-2 put in in place of plate 13-7 in slot 2
- Box 11 " " 5-11 " " " " " " 13-11 " " 2
- Box 35 " " 5-35 " " " " " " 13-35 " " 2
- Box 39 " " 5-39 " " " " " "

also Box 25 SS plate 7-25 was put in in place of $\frac{1}{2}$ ^{Full} plate 5-25. (Slot 7)

~~kg~~ kg 25 = $(22 \times 1.4) - (4 \times 20^{.0155}) = 16.73 \text{ kg}$ ✓ MB
 blade correction = $-.08$ - blade .056
 Critical 16.65 ~~16.676~~

Log N .17	Control Blade 4.99
DC-3 69 x 10 x 20	Control Rod 29.01
Water ht. 109.7	Water Temp. 72.5

Expr. 16-21 Time 1:45 ⁽¹⁾ Date 12-19 1955
 Purpose Δk lam with boron - zero run
 Personnel: _____

INSTRUMENT CHECK

Date _____ 195__ Time _____ AM
 PM Source No. _____

Instrument	Trip	Value	Scale	Source Distance	Start-Up Scale
DC-1					
DC-2					
DC-3		<u>80</u>	<u>10 x 20</u>	<u>3"</u>	
Log N			<u>12.5</u>		
R-1		<u>6.5</u>	<u>1000</u>		
R-2			<u>100</u>		
P. M.			<u>800V</u>		

START-UP CHECK LIST

Equipment Checked by RS Personnel Check by JL
 Instrument and Safeties Checked and Reset by JL
 "Source In" Checked by RS Source No. _____
 Emergency Equipment in Control Room Checked by MB
 Red Light On by JL AM
 Start-Up OK'd by RS Time 4:55 ⁽¹⁾ PM Date 12-19 1955

Loading

slot	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Series	<u>1</u>	<u>13</u>	<u>3</u>	<u>8</u>	<u>4</u>	<u>6</u>	<u>7</u>	<u>12</u>	<u>9</u>	<u>7</u>	<u>9</u>	<u>12</u>	<u>11</u>	<u>8</u>	<u>15</u>	<u>8</u>	<u>2</u>	<u>10</u>
material	<u>f</u>	<u>f</u>	<u>f</u>	<u>B</u>	<u>f</u>	<u>f</u>	<u>3</u>	<u>f</u>	<u>3</u>	<u>f</u>	<u>f</u>	<u>3</u>	<u>f</u>	<u>B</u>	<u>3</u>	<u>f</u>	<u>f</u>	<u>f</u>

except for the following exchanges in slot 2:

- Box 7 contains 5-7 instead of 13-7
- 11 5-11 13-11
- 35 5-35 13-35
- 39 5-39 13-39

and. fuel 12-25 and ss. 7-25 have been interchanged.
 Reactor subcritical - rod in, blade in, water up, source out.

Expt. 16-22 Time 5:30^{AM} PM Date 12-19 1955
 Purpose 51/2m with beam - 2000 run
 Personnel: _____

START-UP CHECK LIST
 Equipment Checked by JL Personnel Check by JL
 Instrument and Safeties Checked and Reset by JL
 "Source In" Checked by RJ Source No. _____
 Emergency Equipment in Control Room Checked by MB
 Red Light On by MB
 Start-Up OK'd by RJ Time 5:50^{AM} PM Date 12-19 1955

Loading - same as 16-21 except 13-9 fuel has been replaced by 2-9 SS.

Still to reactive - source out, red out, blue in.

100

Expr. 16-23 Time 5:46 ^{AM} ~~PM~~ Date 12-19 1955
 Purpose Start/om with beam non-zero run
 Personnel: _____

START-UP CHECK-LIST
 Equipment Checked by JL Personnel Check by JL
 Instrument and Safeties Checked and Reset by JL
 "Source In" Checked by RJ Source No. _____
 Emergency Equipment in Control Room Checked by MB
 Red Light On by MB
 Start-Up OK'd by RJ Time 5:45 ^{AM} ~~PM~~ Date 12-19 1955

Loading - same as 16-21 except ^{fuel} 13-16 in slot 2, box 16
 has been replaced by S.S. 2-16.

Critical conditions:

DC-3	56 (10x20)	Height	108.2 108.2
log N	0.14	Blade	6.30
R-1	3.3 (100x1000)	Rad	29.01
Temp.	72.5°F.		

Mass 16.704

~~0.072~~ ~~Head~~ 07

Corrected Mass 16.659 Kg ^{u²³}
 16.63

Loop

Expt.	16-24	Time	1800	AM	Date	12-19	1955
Purpose	AK/AM with Boron Adding 1 (1/2) plate to Box 25						
Personnel:	MB JL RS						

START-UP CHECK LIST							
Equipment Checked by	RS	Personnel Check by	JL				
Instrument and Safeties Checked and Reset by	RS						
Source In Checked by	MB	Source No.					
Emergency Equipment in Control Room Checked by	RS						
Red Light On by	RS	AM					
Start-Up OK'd by	MB	Time	1800	PM	Date	12-19	1955

Loading: Same as 16-23 except 1/2 fuel plate 5-25 was put into slot (8) Box 25, in place of SS 7-25


Critical Conditions:

DC-3	74 x 10 x 20	Wt ht	109.2
Log M	.18	Control Blade	0.00
R-1	4.15 x 100 x 1000	Control Rod	29.01
Temp			

Control Blade pulled out to 6.30", the critical blade position of the 16-23 Zero Run.

16.716

$$\text{Inch} = \frac{-0.09}{16.63}$$



Expr. 17-6 Time 1835^{AM} PM Date 19 Dec 1955
 Purpose Effect of Lumping of Boron
 Personnel: MB JL RS

START-UP CHECK LIST
 Equipment Checked by MB Personnel Check by RS
 Instrument and Safeties Checked and Reset by MB
 Source Inst Checked by MB Source No. _____
 Emergency Equipment in Control Room Checked by RS
 Red Light On by RS AM
 Start-Up OK'd by MB Time 1835 PM Date 19 Dec 1955


Loading Same as 16-24, except that Boron $\frac{1}{2}$ plates were inserted in Slots 4, 7, 12, 14 of Box ~~25~~²³, and Boron full plates removed from Slots 4+14, 55 plates 7-23, and 12-23 were removed from slots 7+72 respectively.

Critical Condition

DC-3	B2 10x20	WT HT	109.6
Log N	-2	Control Blade	25 11.615
R-1	- 2.2 200x100	Control Rod	- 29.01
Temp.	235		

Control Blade pulled to 15.70 for a point on a new Blade Calibration Curve

W. with ~ 12 g



Expt. <u>16-25</u>	Time <u>8:30</u> ^{AM} PM	Date <u>12-19</u> 19 <u>55</u>
Purpose <u>Critical Mass with Baron.</u>		
Personnel: _____		
START-UP CHECK LIST		
Equipment Checked by <u>MB</u>	Personnel Check by <u>RJ</u>	
Instrument and Safeties Checked and Reset by <u>JL</u>		
"Source In" Checked by <u>RJ</u>	Source No. _____	
Emergency Equipment in Control Room Checked by <u>MB</u>		
Red Light On by <u>JL</u>		
Start-Up OK'd by <u>RJ</u>	Time <u>8:35</u> ^{AM} PM	Date <u>12-19</u> 19 <u>55</u>

Loading—

slot	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Series	1	13	3	"B"	4	5	12	7	9	12	4	"B"	5	8	2	10		
material	f	f	f	B	f	f	f	"C"	B	f	f	f	B	f	f	f	f	f

14 series +
2 pack
14
cornt. M.B.

Complete loading at 13 1/2 fuel, a 2 1/2 Baron.

Plates which are not in proper series position:

Box	Slot 15	Slot 12
36	A-264	
37	3-41x	
38	1-15A	
40	1-17x	
41	4-20x	
42	6-40x	
43	7-16x	
44	1-19A	
45	961-H	952-H.

Super critical at water Right ~ 89.6 cm.
Blade in, rod out, source out.

Expt. <u>16-26</u>	Time <u>2048</u> ^{AM} _{PM}	Date <u>19 Dec</u> 196 <u>5</u>
Purpose <u>Critical Mass with Boron</u>		
<u>2 1/2 plates</u>		
Personnel: <u>MB JL RJ</u>		

START-UP CHECK LIST		
Equipment Checked by <u>RJ</u>	Checked by <u>JL</u>	
Instrument and Safety <u>MB</u>		
"Source In" <u>MB</u>		
Emergency Equipment <u>RJ</u>		
Red Light On by <u>RJ</u>	<u>2049</u> AM	
Start-Up OK'd by <u>MB</u>	Time <u>18</u> PM	Date <u>19 Dec 1965</u>

Loading: Same as 16-25 except that 6 1/2 plates were removed

and Replaced by Steel in the following Boxes

In Box 8 fuel (1/2)	5-8	in slot 7	was replaced by SS 7-8
" " 10	5-10	" " 7	" " SS 7-10
" " 21	5-21	" " 7	" " SS 7-21
" " 25	5-25	" " 7	" " SS 7-25
" " 36	5-36	" " 7	" " SS 7-36
" " 38	6-38	" " 7	" " SS 7-38

~~loading 16-25 1965 - 6.1.21~~

Critical at water height 91.3

Expt. <u>16-26</u>	Time <u>2107</u> ^{AM} PM	Date <u>19-Dec</u> 196 <u>5</u>
Purpose <u>Critical Mass with Boron</u>		
<u>2 1/2 plates</u>		
Personnel: <u>MB, JL, RJ</u>		

START-UP CHECK LIST		
Equipment Checked by <u>RJ</u>	Personnel Check by <u>JL</u>	
Instrument and Safety checked and OK	<u>MB</u>	
Source In Check List by <u>MB</u>	Serial No. _____	
Emergency Equipment in Control Room checked by <u>RS</u>		
Red Light On by <u>RJ</u>	Time <u>2109</u> AM	
Start-Up OK'd by <u>MB</u>	Time <u>2109</u> PM	Date <u>19-Dec 1965</u>

loading: Same as 16-25 with the following changes

In Box 7	1/2 fuel plate 5-9,	in slot 7	was replaced by	SS 7-7
" " 9	" " " 5-9	" " " "	" " "	SS 7-9
" 11	5-11	" " " "	" " "	7-11
" 21	5-21	" " " "	" " "	7-21
" 23	5-23	" " " "	" " "	7-23
" 25	5-25	" " " "	" " "	7-25
" 35	5-35	" " " "	" " "	7-35
" 37	5-37	" " " "	" " "	7-37
" 39	5-39	" " " "	" " "	7-39

Expt. <u>16-27</u>	Time <u>9:30</u> ^{AM} PM	Date <u>Dec 9</u>	195 <u>5</u>
Purpose <u>vis. in MMS with Boron</u>			
Personnel: _____			
START-UP CHECK LIST			
Equipment Checked by <u>MB</u>	Personnel Check by <u>JL</u>		
Instrument and Safeties Checked and Reset by <u>JL</u>			
"Source In" Checked by <u>RJ</u>	Source No. _____		
Emergency Equipment in Control Room Checked by <u>MB</u>			
Red Light On by <u>MB</u>	_____		
Start-Up OK'd by <u>RJ</u>	Time <u>9:30</u> ^{AM} PM	Date <u>Dec 9</u>	195 <u>5</u>

Loading - same as 16-25 except for slot 7:
 slot 7 contains series five fuel in boxes 1, 3, 5, 6, 8,
 10, 12, ... 38, 40, 41, 43, 45; s.s. series 7 fuel
 in rest of boxes.

Critical Conditions

Log N	0.13	Height	109.2
DC-3	50(10x20)	Rod	28.02
R1	3.0(100x1000)	Blade	11.36
Temp	73°		

$$\text{Mass: } 13 \cdot \left(\frac{24}{25}\right) \left(\frac{1}{2}\right) \cdot 1.4 = 13.267 (1.399) = \overset{18.57}{\cancel{18.5049}}$$

$$\begin{aligned} \sqrt{MB} &= 18.566 \text{ Kg of U-235} \\ &= \overset{18.57}{\cancel{18.566}} \rightarrow \text{made with} \\ &= 18.540 \text{ Kg of U-235} \end{aligned}$$

$$\text{blade correction} = \frac{-0.05}{18.52}$$

$$\text{boron} = 47.2$$

Expr. 16-28	Time 9:50 ^{AM} PM	Date Dec 19 1953
Purpose <u>ok/AM</u> w. the Baron - 24 barograph plates.		
Personnel:		

START-UP CHECK LIST	
Equipment Checked by <u>JL</u>	Personnel Check by <u>JL</u>
Instrument and Safeties Checked and Reset by <u>JL</u>	
"Source Hk" Checked by <u>RJ</u>	Source No. _____
Emergency Equipment in Control Room Checked by <u>MB</u>	
Red Light On by <u>MB</u>	
Start Up OK'd by <u>RJ</u>	Time 9:50 ^{AM} PM Date Dec 19 1953

Loading - Same as 16-27 except ^{SS} ~~full plate~~ removed from slot 7 & replaced by ~~full plate~~ ^{half plate} in box 25 only.


Critical Conditions

Log N	0.11	Height	109.4
DC-3	44 (10x20)	Rod	29.02
R-1	2.6 (100x1000)	Blade	9.64 9.50

Temp. 73°f

Blade pulled to 11.36, the zero point of run 16-27, inducing a period of 312.6 sec. or 3.89.

Mass: $\frac{18.585}{-18.547} = 18.581$ mass
 $- .034$ blade weight
 18.547



Expr. <u>16-29</u>	Time <u>2220</u> AM	Date <u>19 Dec 1985</u>
Purpose <u>0.5% / AM</u> , <u>With Boron</u> , <u>2 1/2 plates</u>		
Personnel: <u>MB JL, RJ DW</u>		

START-UP CHECK LIST		
Equipment Checked by <u>JL</u>	Personnel Check by <u>JL</u>	
Instrument and Safeties Checked and Reset by <u>MB</u>		
"Source In" Checked by <u>MB</u>	Source No. _____	
Emergency Equipment in Control Room Checked by <u>RJ</u>		
Red Light On by <u>RJ</u>	AM	
Start-Up OK'd by <u>MB</u>	Time <u>2221</u> PM	Date <u>19 Dec 1985</u>

Loading: Same as 16-28 except that in Box 25
Full 5-25 in slot 7 and Full 12-25 in slot 8 were interchanged,
 so that $\frac{1}{2}$ plate 5-25 is in Slot 8, and Full Plate
 12-25 is in Slot 7.

Critical Conditions

Log N. 19

Control Blade 12.37

OC-3 83-110X20

Control Rod 29.02

R-1 2.27 X 200 X 100

Water Ht 109.6

Water Temp 73°F

Mass 18.585 Kg U²³⁵

Expt. <u>16-30</u>	Time <u>2240</u> ^{AM}	Date <u>19 Dec</u> 19 <u>65</u>
Purpose <u>AK/AM, With Boron, 2 1/2 Boron plates</u>		
Personnel: <u>MB, JL, RS, DW</u>		

START-UP CHECK LIST	
Equipment Checked by <u>JL</u>	Personnel Check by <u>JL</u>
Instrument and Safety checked and found by <u>MB</u>	
Source In ¹ Checked by <u>MB</u>	Source No. _____
Emergency Equipment in Control Room checked by <u>RS</u>	
Red Light On by <u>RS</u>	AM
Start-Up OK'd by <u>MB</u>	Time <u>2240</u> PM Date <u>19 Dec</u> 19 <u>65</u>


Loading: Same as 16-29, except SS 7-25 is put in
in place of 5-25 in Box 25 slot 8.

Mass - 18.59 kg, U235

Critical:

log N - 1.9	Control Blade 13.445
DC-3 80 X10X10	Control Rod 29.02
R-1 Jammed	Water Ht. 109.5
Water Temp 73°F	

Control Blade moved into 10.37, the critical
position of 16-29, to find the worth of the $\frac{1}{2}$ plate in
slot 8.



$$27.6 \text{ sec} = (12.7)(21.72) = 276 \text{ sec}$$

$$NL = 5.5 \text{ cm} = 5.5 \text{ cm}$$

$$10.3 \text{ cm}$$

$$13.49 \text{ cm}$$

Expt. 16-31 Time 6:30 ^{AM} ~~PM~~ Date 12-30 195
 Purpose Critical mass w/ 3 boron plates
 Personnel: _____

INSTRUMENT CHECK

Date _____ 195 Time _____ ^{AM} ~~PM~~ Source No. _____
 Trip _____
 Instrument Value Scale Source Distance Start-Up Scale
 DC-1 _____
 DC-2 _____
 DC-3 ✓ 80 10x20
 Log N ✓ 12mm
 R-1 ✓ 5 5x1000 1"
 X100
 R-2 _____
 P. M. ✓ 80V 3"

Loading -

slot	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
series	1	13	3	8	4	6	5	12	B	7	9	15	11	B	14	8	2	10
material	f	f	f	B	f	f	f	f	B	f	f	f	f	B	f	f	f	f

* ~~##~~ Slot 12 is loaded as follows.

	Box #	Fuel	Box	Fuel	Box	Fuel	Box	Fuel
X	1	^{MAC} 12-35 625	12	15-12	23	1-17	34	15-7
146	2	12 12-38	15		24	^{MAC} 378	35	15-8
L	3	3 H-951	14		25	1-15	36	F-1
	4	12 12-26	15		26	3-41	37	A-505
	5	^{MAC} 12-34 674	16		27	^{MAC} A-264	38	510
	6	^{MAC} 12-29 669	17		28	15-1	39	F-2
	7	^{MAC} 12-27 667	18		29	15-2	40	A-506
	8	12 12-37	19		30	15-3	41	516
	9	15-9	20		31	15-4	42	H-962
	10	15-10	21		32	15-5	43	515
	11	15-11	22		33	15-6	44	H-961
							45	512

START-UP CHECK LIST

Equipment Checked by RS Personnel Check by JL
 Instrument and Safeties Checked and OK'd by MB
 "Source In" Checked by MB Source No. _____
 Emergency Equipment in Control Room Checked by RS
 Red Light On by JL AM
 Start-Up OK'd by MB Time 1843 PM Date 20 Dec 1965

MASS: ~~14~~ $14\frac{1}{2} \times 1.399 = 20.6^3 \text{ Kg}^{235}$

Critical Conditions (Slightly Super)

Log N. -7

Water Ht 93.

DC-3

Blade 0.00

R-1

Rod 29.02

Water temp. 73°F.

Expt. <u>16-32</u>	Time <u>8:30</u> ^{AM} PM	Date <u>12-20</u> 195 <u>5</u>
Purpose <u>Critical mass with boron - 3 full plates.</u>		
Personnel: _____		

START-UP CHECK LIST	
Equipment Checked by <u>RS</u>	Personnel Check by <u>MB</u>
Instrument and Safeties Checked and <u>OK</u>	<u>JL</u>
"Source In" Checked by <u>RS</u>	<u>MB</u>
Emergency Equipment in Control Room Locked by <u>MB</u>	
Red Light On by <u>JL</u>	
Start-Up OK'd by <u>RS</u>	Time <u>8:30</u> ^{AM} PM Date <u>12-20</u> 195 <u>5</u>

Loading -

Same as 16-32 ³¹ except:

box 8, slot 12 now contains 3.5.
 - 10 " " " " "
 - 21 " " " " "
 - 25 " " " " "
 - 36 " " " " "
 - 38 " " " " "
 - 3 " " " " " 6.40
 - 42 " " " " " 1-15
 - 44 " " " " " 15-10

Total U mass = 20.1 Kg. U ²³⁵	20.105 Kg
Total B mass = 255 gm Nat. B.	1.804 g
	20.101 correct mass

Critical Conditions -

Log N	0.14	Slide	19.03
DC-3	47.5 (10x20)	Rod	29.02
R-1	3.03 (100x1000)	Water	109.2
Temp.	72.5°F		

Expr. 16-33 Time 9:00 ^{AM} _{PM} Date 12-20 1955
 Purpose AK/AM with barn -
Zero run.
 Personnel: _____

START-UP CHECK LIST
 Equipment Checked by JL Personnel Check by JL
 Instrument and Safeties Checked and Reset by JL
 "Source In" Checked by RJ Source No. _____
 Emergency Equipment in Control Room Checked by MB
 Red Light On by MB
 Start-Up OK'd by RJ Time 9:00 ^{AM} _{PM} Date 12-20 1955

Loading -

same as 16-32 except:

- in box 25, slot 7 now contains s.s. (instead of half plate)
- slot 12 now contains fuel #507 [F-1]

Critical Conditions -

DC-3	45.5 (10x20)	Blade	15.01
R-1	2.8 (100x1000)	Red	29.02
LogN	0.125	Water	109.2 cm.
temp.	72.5°F		

Expr. <u>1634</u>	Time <u>925</u> AM	Date <u>20 Dec 1955</u>
Purpose <u>AK/AM, With Boron - Slot 7</u>		
Personnel: <u>MB, RJ, JL</u>		

START-UP CHECK LIST		
Equipment Checked by <u>RJ</u>	Personnel Check by <u>JL</u>	
Instrument and Safeties Checked and Reset by <u>MB</u>		
"Sources In" Checked by <u>MB</u>	Source No. _____	
Emergency Equipment in Control Room Checked by <u>RJ</u>		
Red Light Off by <u>RJ</u>	AM	
Start-Up OK'd by <u>MB</u>	Time <u>9 30</u>	PM Date <u>20 Dec 1955</u>


Loading: Same as 16-33, except that $\frac{1}{2}$ fuel plate 5-25 is put into Slot 7, Box 25, in place of SS, (12-25)

Critical Conditions

Log N	.16	Control Blade	13.38
De-3	56.10x20	Control Rod	29.02
Water Temp	72.5	Water Ht.	109.5

Control Blade pulled out to 15.01" to critical position of 16-33, to measure the reactivity worth of adding a $\frac{1}{2}$ ^{fuel} plate to Slot 7, Box 25.

Warr	20.132	
	- .020	slab worth
	<u>20.112</u>	



$$(13.6)(21.72) = 295.5 \text{ SEC}$$

$$= 3.49$$

15.015 on blade
13.375

This part mounted in position

Expr. <u>16-35</u>	Time <u>10:25</u> ^{AM} _{PM}	Date <u>12-20</u> 19 <u>55</u>
Purpose <u>ΔR/am with 3 full boron - slot 8</u>		
Personnel: _____		

START-UP CHECK LIST.	
Equipment Checked by <u>DM</u>	Personnel Check by <u>MB</u>
Instrument and Safeties Checked and Reset by <u>JL</u>	
"Source In" Checked by <u>RJ</u>	Source No. _____
Emergency Equipment in Control Room Checked by <u>MB</u>	
Red Light On by <u>MB</u>	
Start-Up OK'd by <u>RS</u>	Time <u>10:25</u> ^{AM} _{PM} Date <u>12-20</u> 19 <u>55</u>

Loading - same as 16-33 except slot 7
 Box 25 now contains fuel 12-25 and
 slot 8, box 25 contains s.s. 12-25.


Critical Conditions

WogN	0.12	Blade	17.5 in.
DC-3	43.5 (10x20)	Rod	29.02 in
R-1	2.781	Water	109.2 in
Temp.	72.5°F		

Critical Conditions -

Log N	0.150 -	Water	109.2
DL-3	6.1 (10x20)	Blade	14.23
R-1	3.8 (100x1000)	Rod	29.01
Temp	72.5°f		

Pulling blade to 17.495 for positive period measurement.



Expt. 16-36 Time 10:45 AM Date 12-20 1955
 Purpose AB/dm with 3 full boron - slot 8
 Personnel: _____


START-UP CHECK LIST
 Equipment Checked by JL Personnel Check by JL
 Instrument and Safeties Checked and Reset by JL
 "Source In" Checked by RJ Source No. _____
 Emergency Stop Control Panel Checked by MB
 Red _____ MB
 Start _____ RJ 10:45 12:20 1955

Loading - same as 16-35 except slot 8^{box 25} which now contains ^{full} 5-25 instead of 55 5-25.

Critical Conditions -

logN	0.150-	Water	109.2
DL-3	6.1 (10x20)	Blade	14.23
R-1	3.8 (100x100)	Rod	29.01
Temp	72.5°F		

Pulling blade to 17.495 for positive period measurement.



Expr. 10-1 Time 5:55 AM Date 12-21 1953
 Purpose Critical mass with 80% boxes in rod positions
 Personnel:
START-UP CHECK LIST
 Equipment Checked by JL Personnel Check by JL
 Instrument and Safeties Checked and Reset by MB
 "Source In" Checked by RJ Source No.
 Emergency Equipment in Control Room Checked by MB
 Red Light On by JL
 Start-Up OK'd by RJ Time 5:55 AM Date 12-21 1953

INSTRUMENT CHECK
 Date 12-21 1953 Time 5:55 AM Source No.
 Trip
 Instrument Value Scale Source Distance Start-Up Scale
 DC-1
 DC-2
 DC-3 ✓ 80 10x20
 Log N 1.2500
 R-1 ✓ 5.5 9x1000x100
 R-2
 P.M. ✓ 1"

Loading - for all boxes except rod boxes.

slot	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
series	1	13	3	B	4	6	12	B	7	9	f	f	f	f	B	f	f	f
material	f	f	f	B	f	f	f	B	f	f	f	f	f	f	B	f	f	f

	slot 7	slot 12	slot 7	slot 12	slot 7	slot 12
1	10-9	1-9	18	9-31	15-18	35
2	10-15	4-2	19	-25	18-19	36
3	-21	6-32	20	-23	1-16	37
4	-23	6-40	21	-rod		38
5	-25	1-11	22	-21	4-20	39
6	-31	2-12	23	-rod		40
7	-37	4-259	24	-15	3-78	41
8	8-15	8-1	25	-rod		42
9	-rod		26	-9	3-41	43
10	-9	5-10	27	4-37	1-264	44
11	-37	15-11	28	-31	15-1	45
12	-37	15-12	29	-25	15-2	614
13	-25	15-13	30	-23	15-3	621
14	-23	15-14	31	-rod		615
15	-rod	15-15	32	-21	15-5	
16	-21	15-16	33	-15	15-6	
17	9-37	15-17	34	-9	15-7	

Loading for rod position boxes - 9, 15, 21, 23, 25, 31, & 37.

slot	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
series	f	5	3	3	5	6	5	12	B	7	5	f	11	3	14	5	2	5
material	f	f	f	B	f	f	f	f	B	f	f	f	f	B	f	f	f	f

Box	slot 2	5	11	16	18	12
9	5-1	5-2	5-3	5-4	5-5	15-9
15	-6	-7	-8	-10	-11	15-15
21	-12	-13	-14	-16	-17	512
23	-18	-19	-20	-22	-24	1-17
25	-26	-27	-28	-29	-30	515
31	-32	-33	-34	-35	-36	15-4
37	-38	-39	-40	-41	-43	A506

Very sub-critical.
 Water up
 Source out
 Log N 0.007
 Blade out
 Rod out.

Expt. 18-2	Time 6:50 ^{AM}	Date 12-21 1955
Purpose Critical Mass with 90% boxes in rod positions.		
Personnel:		
START-UP CHECK LIST		
Equipment Checked by JL	Personnel Check by RJ	
Instrument and Safeties Checked and Reset by MB		
"Source In" Checked by RJ	Source No.	
Emergency Equipment in Control Room Checked by MB		
Red Light On by MB	AM	
Start-Up OK'd by RJ	Time 6:50 ^{PM}	Date 12-21 1955

Loading - Fuel loading in all boxes is the same as 18-1
 - boron loading is the same as 18-1 except:
 in "core" boxes - the series "B" boron in slot 9 has been changed to series "C".
 in "rod" boxes - 9, 21, 25 & 37 contain boron series "C" in slots 9 & 14
 - 15, 23, & 31 contain s.s. plates in slot 9.

Critical - water height 78.7
 Log N 0.09

Expt. 18-3	Time 20:20 ^{AM}	Date 12-21 1955
Purpose CRITICAL MASS with 90% boxes in 7 Rod positions		
Personnel:		
START-UP CHECK LIST		
Equipment Checked by M.B.	Personnel Check by M.B.	
Instrument and Safeties Checked and Reset by M.B.		
"Source In" Checked by J.L.	Source No.	
Emergency Equipment in Control Room Checked by M.B.		
Red Light On by J.L.	AM	
Start-Up OK'd by M.B.	Time 20:20 ^{PM}	Date 12-21 1955

LOADING - SA FUEL IN ALL BOXES AS IN 18-1
 - BORON LOADING FOR ROD BOXES SAME AS IN 18-2
 - CORE BOXES SAME AS 18-2 EXCEPT BOXES ~~2, 4~~ 1, 2, 5, 6, 8, 10
 41, 43, 45 (LARGE CHECKER BOARD)
 NOW CONTAIN SERIES "B" BORON

CRITICAL - water height 84.7
 LOG N 0.16

Expr. 18-4 Time 2:00 ^{AM} Date 12-21 1955
 Purpose Critical mass with 80% boron in
seven rod positions
 Personnel:

START-UP CHECK LIST
 Equipment Checked by MB Personnel Check by MB
 Instrument and Safeties Checked and Reset by MB
 "Source In" Checked by MB Source No. MB
 Emergency Equipment in Control Room Checked by MB
 Red Light On by MB AM
 Start-Up OK'd by MB Time 2:00 ^{AM} Date 12-21 1955

LOADING - SAME AS 18-1 EXCEPT THAT
 ROD POSITION BOXES, 9, 15, 21, 23, 25
 31, 37 NOW CONTAIN SERIES 2"
 (±) BORON PLATES IN SLOT 9

CRITICAL CONDITIONS

WATER HEIGHT 109.6cm WATER TEMP 71.0° F
 LOG-N ~~0.27~~ 0.22 R-1 3.7 (200X1000)
 DC - 3 52 (10X50)

ROD POSITION 29.02
 BLADE " 16.21

Mass: $15 \times 38 \times 31.1 = 17.73 \text{ kg.}$
 $+ 12 \times 7 \times 31.1 = 2.61$
 Blade correction -.02
 20.32

Boron.
 $3 \times 38 \times 1.889 = 2.15$
 $2.5 \times 7 \times 1.889 = 3.3$
 24/8 gm.

Expr. 18-5 Time 2:30 ^{AM} Date 12-21 1955
 Purpose Critical Mass with 80% boron
in seven rod positions - with four extra
steel plates in each rod position
 Personnel:

START-UP CHECK LIST
 Equipment Checked by MB Personnel Check by JL
 Instrument and Safeties Checked and Reset by JL
 "Source In" Checked by RJ Source No. MB
 Emergency Equipment in Control Room Checked by MB
 Red Light On by MB AM
 Start-Up OK'd by RJ Time 2:30 ^{PM} Date 12-21 1955

Loading - same as 18-4 except 4 steel plates added to
 each rod-position box. Two of these plates were added
 in slots 4 + 14 adjacent to the boron. The other
 two were taped to the east + south sides of the
 boxes

~~Not~~ Not Critical -

Water up.
 Blade out
 Rod out.
 Source out
 LogN 0.015

Expt. 18-6	Time 2255	Date 12-21 1965
Purpose: Critical mass with 80% rod boxes Extra steel plates in rod boxes		
Personnel:		
START-UP CHECK LIST		
Equipment Checked by RJ	Personnel Check by JL	
Instrument and Safeties Checked and Reset by JL		
"Source In" Checked by RJ	Source No.	
Emergency Equipment in Control Room Checked by MB		
Red Light On by MB	AM	
Start-Up OK'd by RJ	Time 2255	Date 12-21 1965

Loading - Same as 18-5 except full boron plates removed from the following boxes & replaced with half-boron plates: 8, 10, 14, 18, 28, 32, 36, 38.

H₂O Height 109.0 H₂O Temp 72°F

Log N (0.13)

~~DC-3 43~~

RI 43 (100 x 100)

DC-3 67 (10 x 20)

BLADE 19.15 IN.

ROD 29.02 IN.

Mass = Mass of 18-4 = 20.34 kg

blade correction = -.01

20.33 kg

Boron = $3 \times 38 \times 1.889 - 4 \times 1.889 = 208 \text{ gm.}$

+ $2.5 \times 7 \times 1.889 = 33$

241

Expt. 18-6	Time 2325 ^{AM}	Date 21 Dec 1965
Purpose: Critical Mass with 80% rod boxes & 22% steel in these boxes		
Personnel: MB JL AS		

START-UP CHECK LIST		
Equipment Checked by AS	Personnel Check by JL	
Instrument and Safeties Checked and Reset by MB		
"Source In" Checked by MB	Source No.	
Emergency Equipment in Control Room Checked by AS		
Red Light On by AS	AM	
Start-Up OK'd by MB	Time 2325	Date 21 Dec 1965

Loading: Same, except end boxes added to top of all boxes:

Critical Conditions:

log N .22

Control Blade 16.99


DC-3 50 x 150 x 10

Control Rod 29.02

Water temp 72.5

Water Ht. 109.6

The effect of adding end boxes to the top of the assembly is that the core is slightly more reactive. Control blade is lowered from 19.15 (exp 18-6) to 16.99 (18-7) or 3.35%. This difference is negligible when considered in terms of Uranium Mass.



Expt. ~~19-1~~ 19-1 Time ~~4:44~~ ^{4:44} AM Date 22 Dec 1955
 Purpose Flux Power Traverse, with Full Boron Loading (3 fl/box) Zero Ran
 Personnel: JL, RS, DW

INSTRUMENT CHECK

Date 22 Dec 1955 Time ~~4:44~~ ^{16:33} AM Source No. _____
 Trip _____
 Instrument DC-3 Log N R-1 P. M. Scale 80 12 5 2 Distance 110x20 110 Start-Up Scale 3" 2" 2"

START-UP CHECK LIST

Equipment Checked by JL Personnel Check by JL
 Instrument and Safety Checked and Reset by RS
 Source in Control Room Checked by DW Source No. _____
 Emergency Stop in Control Room Checked by RS
 Red Light On by RS AM
 Start-Up OK'd by DW Time 5.00 PM Date 22 Dec 1955

Loading: Same as 16-32, with some changes in the odd loading of Slot 12

Slot	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Series	1	13	3	"B"	4	6	5	12	"B"	7	9	15*	11	"B"	14	8	2	10
Type	F	F	F	B	F	F	F _{1/2}	F	B	F	F	F	F	B	F	F	F	F

(over)

Slot 12.

Box	Box	Box	Box	Box	Box
1 - 1-9 ¹	12 - 15-12	23 1-17	34 15-7		
2 - 4-2	13 - 15-13	24 #328	35 15-8		
3 - 6-32	14 - 15-14	25 # 328 SS	36 # 328 SS		
4 - 6-40	15 - 15-15	26 3-41	37 # A 506		
5 - 1-11	16 - 15-16	27 # A-264	38 SS 516		
6 - 2-12	17 15-17	28 15-1	39 # A 506		
7 - #259	18 15-18	29 15-2	40 617		
8 - SS 617	19 1-19	30 15-3	41 619		
9 - 15-9	20 1-16	31 15-4	42 617 1-15		
10 - SS	21 # 328 SS	32 15-5	43 618		
11 - 15-11	22 4-20	33 15-6	44 15-10		
			45 616		

Mass U = 20.1 kg U²³⁵

Critical ; water ht 92.3 cm

Expt. 19-2	Time 5:20 AM	Date 22 Dec 1965
Purpose: Test + Power + Run w/ Boron		
Zero Run		
Personnel: DW, JK, RS		

START-UP CHECK LIST	
Equipment Checked by DL	Personnel Check by JK
Instrument and Safeties Checked and Reset by RS	
Source-In ² Checked by RS	Control No.
Emergency Equipment in Control Room Checked by RS	
Red Light On by RS	AM
Start-Up OK'd by RS	Time 5:22 AM Date 22 Dec 1965

Loading: Same as 19-1, except fuel plates #259, 15-11, ~~15-11~~, 15-8¹ A 505 removed from Slot 12 of Boxes 7, 11, 35 + 39 respectively, and replaced with SS.

Super critical with water at 109.0, rod and blade full in.

It was discovered after this run that in boxes 8, 10, 14, 18, 28, 32, 36 + 38 slot 9 contained Boron 1/2 plates instead of full Boron plates as specified in loading 19-1. This had the effect of making the reactor super critical.

Expt. 19-3 Time 5:52 AM Date 22 Dec 1965
 Purpose Zero Run
 Personnel: JL, RS

START-UP CHECK LIST
 Equipment Checked by RS Personnel Check by JL
 Instrument and Safeties Checked and Reset by JL
 "Source In" Checked by JL Source No.
 Emergency Equipment in Control Room Checked by RS
 Red Light On by RS AM
 Start-Up OK'd by JL Time 5:52 PM Date 22 Dec 1965

Loading: Same as 19-1, except boxes 8, 38 contain fuel #512 + #516 respectively, in slot 12

~~Critical~~ Mass = 20.16 Kg U²³⁵

Critical
 Log N .135 Control Blade 15.54
 DC-3 50 X 10 X 20 Control Rod ~~23.8~~ 29.02
 A-1 32. X 100 X 100 Water Ht 109.5
 Water Temp 73.5

Expt. 19-4 Time 6:20 AM Date 22 Dec 1965
 Purpose Power Distribution with Boron
 Personnel: RT, JL

START-UP CHECK LIST
 Equipment Checked by RS Personnel Check by RS
 Instrument and Safeties Checked and Reset by JL
 "Source In" Checked by JL Source No.
 Emergency Equipment in Control Room Checked by RS
 Red Light On by RS AM
 Start-Up OK'd by RS Time 6:20 AM Date 22 Dec 1965

Critical Conditions

Log N 1.0 Control Blade 15.73
 DC-3 — Control Rod 29.02
 R1 6.35 X 500 X 1000 Water Ht. 109.2
 Water Temp 73.5 (Loading Same as 19-3)
 End Boxes on Bottom, Not on top
 Foil Run:

to be leveled at 1. on Log N meter.
 Clocks started at 6:36:15", Log N read .37
 Reactor Scrammed at 6:56:15"

Catcher Foil Positions

To P. B-2 59
 12 62
 13 65
 15 67 Bottom
 21
 36
 42

Exp. 20-1 Time 9:00 ^{AM} Date 27 DEC 1955
 Purpose ZERO RUN FINE STRUCTURE IN
BOYES 16 & 23
 Personnel: _____

INSTRUMENT CHECK
 Date 27 (DEC) 1955 Time 8:50 ^{AM} Source No. _____
 Trip _____
 Instrument Value Scale Source Distance _____
 Trip To Scale _____
 DC-1 _____
 DC-2 _____
 DC-3 80 (10 x 20) 3
 Reg N 12 _____
 R-1 5
 R-2 _____
 P. M. 3

START-UP CHECK LIST
 Equipment Checked by J.L. Personnel Check by _____
 Instrument and Safeties Checked and Reset by J.L.
 "Source In" Checked by _____ Source No. _____
 Emergency Equipment in Control Room Checked by J.L.
 Red Light On by J.L. AM _____
 Start-Up OK'd by _____ Time _____ PM Date _____ 1955

LOADING: Same as loading in exp ~~19-3~~ 19-3
 except slot 11 and lot 16 & 23

SLOT	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
SERIES	1	13	3	"B"	4	6	5	"B"	7	9	15	16	"B"	14	8	
TYPE	f	f	f	B	f	f	1/2	f	B	f	f	f	f	B	f	f
SLOT															17	18
SERIES															2	10
TYPE															f	f

FOR SLOT 13 LOADING SEE NEXT PAGE

Slot #
Box

1	1-16A	12	14-16	23	11-23	34	11-34
2	2-16	13	15-16	24	11-24	35	11-35
3	3-16	14	1-23	25	8-23	36	11-36
4	4-16	15	2-23	26	11-26	37	11-37
5	6-16	16	11-16	27	9-23	38	11-38
6	7-16	17	3-23	28	10-23	39	11-39
7	8-16	18	4-23	29	12-23	40	11-40
8	9-16	19	5-23	30	13-23	41	11-41 ^{5/2}
9	10-16	20	11-20	31	14-23	42	11-42
10	12-16	21	7-23	32	11-32	43	11-43 417
11	13-16	22	11-22	33	1-17°	44	11-44
						45	11-45 ^{4/8}

Box 23

SLOT # 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18
 SERIES # 11
 EXCEPT AS NOTED 13 14 15 B 17 18 ⁵ 19 B 21 25 27 28 ^B ~~29~~ ¹¹ 30 ¹¹ 31

Box 16

SLOT # 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18
 SERIES # 11
 EXCEPT AS NOTED 33 1 2 B 3 4 ⁵ 16 5 B 6 7 8 16 B 9 10 11 12

~~NOT CRU~~

SUPER CRITICAL WATER HEIGHT 96
 TEMP 73°F

SLOT 12 LOADING FOR EXP 20-1

BOX

1	1-9 [*]	12	15-12	23	11-27	34	15-7
2	4-2	13	15-18	24	*328	35	15-8
3	6-32	14	15-14	25	SS	36	SS
4	6-40	15	15-15	26	3-41	37	A506 ✓
5	1-11	16	11-278 11-278	27	*A-264	38	516
6	2-12	17	15-17	28	15-1	39	*A505 ✓
7	*259	18	15-18	29	15-2	40	617
8	512	19	1-19	30	15-3	41	619
9	15-9	20	1-16	31	15-4	42	1-15
10	SS	21	SS	32	15-5	43	618
11	15-11	22	4-20	33	15-6	44	15-10
						45	616

Expt.	20-2	Time	10:26 ^{AM}	Date	27 DEC 1951
Purpose	ZERO RUN CONT'D FIRE STRUCTURE				
	11 BOX 15-23				
Personnel:					

START-UP CHECK LIST	
Equipment Checked by	J.L. Personnel Check by J.L.
Instrument and Safeties Checked and Reset by	J.L.
"Source In" Checked by	DFC Source No.
Emergency Equipment in Control Room Checked by	J.L.
Red Light On by	J.L. AM
Start-Up OK'd by	Time PM Date 1951

LOADING: SAME AS EXP 20-1 EXCEPT FUEL
 PLATES 516 & 512 REPLACED BY
 SS IN SLOT 12 BOXES 38 & 8
 RESPECTIVELY

CRITICAL CONDITIONS

WATER HT. 109 WATER TEMP 72.5
 LOG N .11 CONTROL ROD 29.02
 DC-3 66 (10Y20) CONTROL BLADE 8.8 ±.3
 R-1 ~~4.2~~ 4.2 (100X1000)

Expt. 20-3 Time 12:10 AM Date 27 DEC 1955
 Purpose FINE STRUCTURE FOIL RUN
 Personnel:

START-UP CHECK LIST
 Equipment Checked by J.L. Personnel Check by J.L.
 Instrument and Safeties Checked and Reset by J.L.
 "Source In" Checked by DFC Source No.
 Emergency Equipment in Control Room Checked by DFC
 Red Light On by DEC AM
 Start-Up OK'd by DFC Time 12:10 PM Date 27 DEC 1955

LOADING: SAME AS ^{EXP} 20-2 WITH GOLD
 FOILS AS NOTED BELOW

Foil 57 on plate B in slot 14 between slots 13 & 14 in Box 16

J-42	"	11-9	"	15	"	14 & 15	"	"
J-45	"	11-10	"	16	"	15 & 16	"	16
J-40	"	11-11	"	17	"	16 & 17	"	16
J-65	"	11-12	"	18	"	17 & 18	"	16

J-63 on outside of box 23 between box 23 & 16

cd COVERED foils J-32 on plate 11-18 in slot 6 between slots 6 & 7 box 23

J-46	"	"	5-23	"	7	"	6 & 7	"	23
J-50	"	"	11-19	"	8	"	7 & 8	"	23
J- ⁵² 62	"	"	B	"	9	"	8 & 9	"	23

Norm foil 11-41 on plate 11-30 in box 23 slot 17 between slots
 17 & 18

Time started at 12:34:25

" Scrammed at 12:54:25

CRITICAL CONDITIONS

WATER HT 109 WATER TEMP 72.5
 DC-3 OFF SCALE R-1 OFF SCALE
 LOG-N OFF SCALE EXT ROD 29.02
 DC-2 62 (20 X 10) EXT BLADE ~~11.75~~

Expr. 20-4 Time 9:05 ^{AM} PM Date 28 DEC 1955
 Purpose ZERO RUN FINE STRUCTURE
 IN BOXES 16 & 23
 Personnel: LESLIE JOHNSON

INSTRUMENT CHECK

Date 28 DEC 1955 Time 0900 ^{AM} Source No.

Instrument	Value	Scale	Source Distance	Start-Up Scale
DC-1				
DC-2				
DC-3	83	10V20	2 IN	
Log N	12 SEC			
R-1	4.5	100X1000	1 IN	
R-2				
P. M.	✓		2 IN	

START-UP CHECK LIST

Equipment Checked by R.J. Personnel Check by R.J.
 Instrument and Safeties Checked and Reset by J.L.
 "Source In" Checked by J.L. Source No.
 Emergency Equipment in Control Room Checked by J.L.
 Red Light On by R.J.
 Start-Up OK'd by J.L. Time 9:08 ^{AM} PM Date 28 DEC 1955

LOADING SAME AS 20-3
 CRITICAL COND

WATER HT. 109.2 WATER TEMP 71
 LOG N 0.07 EXT BLADE 18.05
 R-1 5.4 (50X1000) EXT ROD 29.02
 DC-3 82 (10V20)

Decided to put one fuel plate in Bot 38 slot 12
 for sub run

Expr. 20-5 Time 11:20 ^{AM} PM Date 28 DEC 1955
 Purpose FOIL RUN AND COVERED AU FOLDS
 FOR FINE STRUCTURE IN BOXES 16 & 23
 Personnel: LESLIE JOHNSON

START-UP CHECK LIST

Equipment Checked by J.L. Personnel Check by J.L.
 Instrument and Safeties Checked and Reset by J.L.
 "Source In" Checked by R.J. Source No.
 Emergency Equipment in Control Room Checked by J.L.
 Red Light On by R.J.
 Start-Up OK'd by R.J. Time 11:20 ^{AM} PM Date 28 DEC 1955

LOADING: SAME AS 20-4 EXCEPT FUEL PLATES
 4-27⁺; 512; 514 IN BOXES 38, 8, 36
 RESPECTIVELY IN PLACE OF SS IN SLOT 12

An attempt was made to go critical with foil in
 and only ^{fuel} plate 4-27⁺ in bot 38 and the reactor never
 got critical. Log N reading was 0.02, a factor of 100
 below foil run level. The two extra fuel plates were
 added to boxes ~~38~~ 38 and 8 in place of SS. ~~The~~
 New foils were not reloaded after the false start ~~and~~ the
 same ^{foils} were left in.

CRITICAL CONDITIONS

TIME CLOCK STARTED 11:29
 TIME RUN ENDED 11:49
 LOG N 2 WATER HT 109
 DC-2 69 (10X20) WATER TEMP 72
 CONTROL ROD 29.02 CONTROL BLADE 7.6

(OVER)

Foil # J-47 on plate # 5-23 Bot 23 plot 7 between plots 6 & 7
 " J-41 " " 11-19 " 23 " 8 " " 7 & 8
 " J-53 " " B 23 " 9 " " 8 & 9
 Norm " N-39 " " 11-30 " 23 " 17 " " 17 & 18
 Cd COVERED " J-49 " " B " 16 " 14 " " 13 & 14
 J-66 " " 11-9 " 16 " 15 " " 14 & 15
 J-60 " " 11-10 " 16 " 16 " " 15 & 16
 J-44 " " 11-11 " 16 " 17 " " 17 & 18
 J-35 " " 11-12 " 16 " 18 " " 17 & 18

Expt. 20-6 Time 16:18 AM Date 28 DEC 1955
 Purpose Fine structure in Boas 16.423
 gold foil run
 Personnel: JOHNSON CALHMAN LESLIE

START-UP CHECK LIST
 Equipment Checked by J.L. Personnel Check by J.L.
 Instrument and Safeties Checked and Reset by R.J.
 Source in " " Checked by R.J. Source No. _____
 Emergency Equipment in Control Room Checked by J.L.
 Red Light On by J.L.
 Start-Up OK'd by R.J. Time 16:20 AM Date 28 DEC 1955

LOADING. SAME AS FOR 20-5 WITH FOILS
 LOADED AS NOTED BELOW

Bar foil J-39 on plate B Bot 16 plot 14 between plots 14 & 15
 " " J-37 " " 11-9 " 16 " 15 " " 15 & 16
 " " J-34 " " 11-11 " 16 " 17 " " 17 & 18
 " " J-56 " " 11-12 " 16 " 18 " " 18 & BOX WALL
 Norm " N-44 " " 11-30 Box 26 " 17 " " 17 & 18
 " " N-48 " " 13-30 Box 30 " 2 " " 2 & 3
 Cd covered " J-55 " " 5-23 " 23 " 7 " " 7 & 8
 " " J-62 " " 11-19 " 23 " 8 " " 8 & 9

START CLOCK AT 16:41:00 @ .74 ON LOG N
 REACTOR SCRAPPED AT 17:01:00
 WATER HT. 109 WATER TEMP 70.8
 LOG N 2.0 EXT. ROD 29.02
 DC-2 68 (10Y20) EXT. BLADE 10.77

Expr. 20-7 Time 5:00 ^{AM} ~~PM~~ Date 1-3 1956
 Purpose Zero Check
 Personnel: _____

INSTRUMENT CHECK

Date _____ 195__ Time _____ ^{AM} ~~PM~~ Source No. _____
 Trip _____
 Instrument Value Scale Source Distance Start-Up Scale
 DC-1 _____
 DC-2 _____
 DC-3 - 90 0x20 2"
 Log N - 125m
 R-1 - 3 8x1000
 R-2 _____
 P. M. ✓ 800V 1"

START-UP CHECK LIST

Equipment Checked by JL Personnel Check by RJ & JL
 Instrument and Safeties Checked and Reset by MB
 "Source In" Checked by RJ Source No. _____
 Emergency Equipment in Control Room Checked by MB
 Red Light On by JL
 Start-Up OK'd by RJ Time 5:00 ^{AM} ~~PM~~ Date 1-3 1956

slot	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
series	1	13	3	"B"	f	6	5	12	"B"	7	9	15	"B"	14	8	2	10	
type	f	f	f	B	f	f	f/2	f	B	f	f	f	B	f	f	f		

for slot 13, see page 137; slot 12, page 138
 for boxes 23 & 16, see page 137.

(This loading is exactly the same as 20-1 page 136.)
 except: 4-27, 5-12, & 5-16 in boxes 38, 8, & 36 slot 12 instead of s.s.
 Reactor supercritical - water up, blade & rod in.

Expr. 20-8 Time 7:00 ^{AM} ~~PM~~ Date 1-3 1956
 Purpose Fine structure flux Bars
Au foils in 23 & 16
 Personnel: _____

START-UP CHECK LIST

Equipment Checked by JL Personnel Check by JL
 Instrument and Safeties Checked and Reset by JL
 "Source In" Checked by RJ Source No. _____
 Emergency Equipment in Control Room Checked by MB
 Red Light On by MB
 Start-Up OK'd by RJ Time 7:00 ^{AM} ~~PM~~ Date 1-3 1956

LOADING SAME AS IN 20-8 EXCEPT SS 12-36
 IN PLACE OF FUEL 516 IN SLOT 12 BOX 36
 GOLD FOILS LOADED AS NOTED BELOW.

	BARE Au FOIL	J-31	ON PLATE	11-14	BOX 23	SLOT 2	BETWEEN SLOTS	2 & 3
"	"	J-45	"	B	BOX 23	" 4	"	" 4 & 5
"	"	J-38	"	11-18	" 23	" 6	"	" 6 & 7
"	"	J-54	BETWEEN PLATES	5-23 & 11-19	BETWEEN SLOTS	7 & 8		
"	"	J-58	"	11-19	" B	"	"	" 8 & 9
NORM	"	"	"	N-34	ON PLATE	11-30	BOX 23	SLOT 17 BETWEEN SLOTS 17 & 19
NORM	"	"	"	N-35	"	"	13-30	BOX 30 SLOT 2 " " 2 & 3
Cd COVERED	"	"	"	J-51	"	"	11-12	" 16 " 18 " 18 & BOX
"	"	"	"	J-33	"	"	11-11	" 16 " 17 " 17 & 18
"	"	"	"	J-46	"	"	11-9	" 16 " 15 " 15 & 16
"	"	"	"	J-61	"	"	" B	" 16 " 14 " 14 & 15

CLOCK STARTED 7:12:19 PM
 Screen 7:32:19 PM
 WATER HT 109 WATER TEMP 69.0°F
 LOG N 2 DC-2 87.5 (5x10)
 BLADE 3.38 ROD 14.03

Expt. 20-9 Time 10:25 ^{AM} Date 3 Jan 1956
 Purpose Fine Structure w/ Bare Dysprosium
Foils in boxes 16 & 23
 Personnel: MB RJ, JL

START-UP CHECK LIST
 Equipment Checked by JL Person to Check by RJ
 Instrument and Safeties Checked and Reset by MB
 "Source In" Checked by MB
 Emergency Equipment in Control Room Checked by RJ
 Red Light On by RJ AM
 Start-Up OK'd by MB Time 10:25 Date 3 Jan 1956

Loading: Same as 20-8, except for a different foil arrangement:

Dysprosium Foil #1 on Fuel Plate 11-21 in Slot 10 Box 23
 " " #2 Boron plate " " 9 " "
 " " #3 " Fuel Plate 11-19 " " 8 " "
 " " #4 $\frac{1}{2}$ " " 5-23 " " 7 " "
 " " #6 " " " 11-18 " " 6 " "
 " " #7 " " " 11-17 " " 5 " "
 " " #8 Boron Plate " " 4 " "
 " " #9 " Fuel Plate 11-15 " " 3 " "
 " " #10 " " " 11-13 " " 1 " "
 " " #11 " " " 11-12 " " 18 " 16
 " " #12 " " " 11-11 " " 17 " 16
 " " #13 " " " 11-9 " " 15 " "
 " " #14 Boron plate " " 14 " "
 " " #15 Fuel plate 11-16 " " 13 " "

Dysprosium Foil #16 on Fuel Plate 11-7 in Slot 11 Box 16
 " " " #17 on Boron plate in Slot 9 Box 16
 " " " #18 on Side of Box 16 adjacent to Box 23
 Au Normalizing Foil #37 on Fuel Plate in Slot ~~11~~ Box
 " " " " 43 " " " " " "

Clock started at 10:37:13 PM

Critical Conditions:

Water Ht	109.5	Control Blade	6.60
De-2	89 x 5 x 10	Control Rod	29.02
Log N	2.0	Water Temp	69°
R+1	4.6 x 1000 x 1000		

Expr. 20-10 Time 4:30 AM Date 1-4 1956
 Purpose Zero Check
 Personnel:

INSTRUMENT CHECK
 Date 1-4 1956 Time 4:30 AM Source No.
 Trip
 Instrument Value Scale Source Distance Set-Up Scale
 DC-1
 DC-2
 DC-3 - BS 10x20
 Log N - 1.25
 R-1 - 4 8x1000
 R-2 - 8x100
 P. M. - 800V

START-UP CHECK LIST
 Equipment Checked by RJ Personnel Check by JL
 Instrument and Safeties Checked and Reset by MB
 "Source In" Checked by RJ Source No.
 Emergency Equipment in Control Room Checked by MB
 Red Light On by JL
 Start-Up OK'd by RJ Time 4:30 AM Date 1-4 1956

2
2
5
12
19
59

Loading - same as 20-1, page 136 ~~except~~ (from 20-9)
 s.s. 12-36 has replaced fuel with 512, slot 12, box 38
 s.s.

except: fuel 512 in place of s.s. in slot 12, box 38.

Critical conditions:

Blank	16.28	Log N	0.17
Red	29.02	DC-3	60x(20x10)
Water	109.4	R-1	4(100x1000)
		Temp.	69°F

Expr. 20-10 Time 5:40 AM Date 4 Jan 1956
 Purpose Fine Structure Au Normal foils
 Dy-Cd covered foils
 Personnel: W.R.J., J.L., M.B.

START-UP CHECK LIST
 Equipment Checked by MB Personnel Check by JL
 Instrument and Safeties Checked and Reset by MB
 "Source In" Checked by MB Source No.
 Emergency Equipment in Control Room Checked by RJ
 Red Light On by RJ
 Start Up OK'd by MB Time 5:40 AM Date 4 Jan 1956

Loading ~~SS plates 20-11, 12, 13, 14, 15, 16~~
 Same as 20-10, except fuel plate 4-27* is
 put in, in place of SS in slot 12, Box 38

Dy. Foil # 12, on plate 11-11 Box 16 Slot 17, Cd Covered
 " " " 7 " " 11-17 " 23 " 5, cd "
 Au " " N32 " " 13-30 " 30 " 2, No cd
 Au " " N42 " " 11-30 " 23 " 17, " "

Clock started at 5:51:28"

In order to approximate as closely as possible the run 20-9,
 the assembly was fueled at $\log N = 1.6$, since the clock was
 started at .74, (2.0%), the run will be completed ²⁰ seconds
 earlier than the clock would indicate for a 20 minute run,
 thus keeping the time interval between the start of the
 run $\ln N = \frac{1.6}{e}$, and the finish, 20 minutes. ²⁰ seconds
 being the period between $\frac{1.6}{e}$ and $\frac{2.0}{e}$

Critical Conditions

Log IN	1.6	Control Blade	12.44
DC-2	89 89 X10X5	Control Rod	29.02
R-1	5.3 5.3 X1000X1000	Water Temp	69
Water Ht	109.5		

Expr.	19-5	Time	6:50 AM	Date	4 Jan 1956
Purpose	Verticle power Distribution w Boron				
Personnel:	RJ, JL, DM				

START-UP CHECK LIST	
Equipment Checked by	DM Personnel Check by JL
Instrument and Safeties Checked and Reset by	JL
"Source In" Checked by	DM Source No. RS
Emergency Equipment in Control Room Checked by	RS
Red Light On by	RS AM
Start-Up OK'd by	Time PM Date 195

Loading: Same as 20-11:
 Catcher foil plate is in Box 23, Slot 11, in place of Full Fuel 11-25.

Catcher Foils:	Position (0 = verticle center of core)	
B-1	+10	
3	+8	
16	+6	
26	+4	
41	+2	
43	0	
81	-2	
119	-4	
142	-6	
163	-8	
164	-10	

Normalizing Foil
 A-40, at center
 outside skirt -.

Clock Started at 7:17:18"


Critical Conditions:

log N	2.0	Control Blade	17.35
DC-2	58 x 10 x 10	Control Rod	29.02
R-1	6.4 x 1000 x 1000	Water Ht.	109.4
Water Temp,	69°F		

Exp. 19-6 Time 11:15 AM Date 1-4 1956
 Purpose Diagonal horizontal power distribution with boron. End boxes on.
 Personnel: RJ, JL, MB

START-UP CHECK LIST
 Equipment Checked by JL Personnel Check by JL
 Instrument and Safeties Checked and Reset by JL
 "Source In" Checked by RJ Source No.
 Emergency Equipment in Control Room Checked by MB
 Red Light On by MB
 Start-Up OK'd by RJ Time 11:15 AM Date 1-4 1956

Loading - same as 20-10 except 515 has replaced 616 in slot 12, box 4g
 + 11-17 + 11-~~12~~²¹ now in boxes 36 + 10 slot 12 instead of 8,5.
 Also the following foil plates have replaced the fuel originally in these slots:



Standardizing foil #20 in holder #1.

Note: reactor was very sub-critical on first trial. We then added fuel plates 11-17 + 11-12. + are making a second trial. The reason for the low reactivity of the core is not certain - the core was checked for possible plate vacancy but none ^{was} found. log N got up to 0.1 on first trial but for a very short period of time.

1/2 power at:

12:01:27 am.

Run conditions —

Blade 9.14
Rod 29.02
Water 109.3 cm.

Log N 2.0
DC-2 61 (10x10)
R-1 6.6 (1000x1000)
Temp 69°F

Expt. 19-7	Time 5:50 AM	Date 1-5 1966
Purpose Zero check		
Personnel:		

INSTRUMENT CHECK			
Date	1-5 1966	Time	5:50 AM
Instrument	Yield	Rate	Source No.
DC-1			
DC-2			
DC-3	✓	80	10x20
Log N	✓		12.5cm
R-1	✓	4	8x1000 1"
R-2			2100
P. M.	—	4	800V comb.

Log N can now be check-calibrated every day by the following procedure - lay the P-source on top of the core so that the source is touching the thimble housing the Log N chamber. In this position, Log N should read 0.09.

START-UP CHECK LIST	
Equipment Checked by	JL Personnel Check by RJ
Instrument and Safeties Checked and Reset by	MIB+RJ
"Source In" Checked by	RJ Source No.
Emergency Equipment in Control Room Checked by	MIB
Red Light On by	MIB
Start-Up OK'd by	RJ Time 6:30 AM Date 1-5 1966

Loading - same as 20-10, page 150 except 515 has replaced 616 in slot 12, box 45. plus fuel plate 427 in slot 12, box 38.

Reactor just critical - water up, blade + rod up.
Log N = 0.1

Expt. 19-8 Time 8:20 AM Date 1-5 1956
 Purpose Radial power distribution with
bovend end boxes
 Personnel: _____

START-UP CHECK LIST
 Equipment Checked by JL Part of check by JL
 Instrument and Safety checked and OK'd by JL
 "Source In" Checked by RJ
 Emergency Equipment in Control Room checked by MB
 Red Light On by MB AM
 Start-Up OK'd by RJ Time 8:20 PM Date 1-5 1956

loading - mass-wise; run 19-7 plus two full plates

Box	Slot	Distance from center	Plate	Foil
23	10		618	B-212
	5		619	206
16	15		614	216
	10		613	214
	9	15	615	209
		10	621	218
		5	616	201
3	10		512	208
	5		617	217

Std. foil - A-117

slot	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
series	1	13	3	"B"	4	6	5	12	"B"	7	9	"B"	14	8	2	10		
material	f	f	f	B	f	f	f	B	f	f		f	B	f	f	f		

for slot 13, see page 137
 box 23, see page 137
 box 16, see page 137

slot 12.

1	1-9*	16	11-8	31	15-4
2	4-2	17	15-17	32	-5
3	6-32	18	15-18	33	-6
4	6-40	19	1-19	34	-7
5	1-11	20	1-16	35	-8
6	2-12	21	H-961	36	S.S.
7	#259	22	4-20	37	A-506
8	5-11	23	11-27	38	4-27*
9	15-9	24	#328	39	A-505
10	512	25	H-959	40	515
11	15-11	26	3-41	41	4-3
12	15-12	27	#A-264	42	1-15
13	-13	28	15-1	43	7-3
14	-14	29	15-2	44	15-10
15	-15	30	15-3	45	4-9

1/2 power at 8:22:40

20 min. exposure.

Run conditions:

Rod	8.87	DC-2	64 (10x10)
Blade	29.02	R-1	—
Water	109.4	Log N	2.0
		Temp.	69°F

SECRET

SECRET

Classification Change to Decl. BY
Authority of E. J. Murphy Date 6/3/60

SECRET

SECRET

45 x 31.1 = 1399.5