

BOOK34R

Notes:

"HFIR #1" on spine

Blank pages: inside cover page, inside cover page opposite page 1, 1, 6, 8, 20, 26, 28, 30, 32, 36, 38, 40, 42, 44, 50, 144, 145, 150-152, inside back covers

-2 pieces of paper clipped to page 114

Scanned by:

Sheila Finch

RSICC /Oak Ridge National Lab.

August 7, 1999

HFIR Log No. 1

7/10/63 (south) → 6/9/66 (west)

THE PAPER USED IN THIS BOOK WILL
GIVE COMPLETE WRITING SATISFACTION.
IT WAS SELECTED FROM MANY PAPERS
FOR ITS FINE WRITING LEDGER SURFACE



No. 168 BLANK BOOK

JOURNAL

SINGLE ENTRY LEDGER

DOUBLE ENTRY LEDGER

RECORD

WITHOUT

UNITS

IN 150 AND 300 PAGES

M A D E I N T H E U. S. A.

TO REORDER THIS BOOK, SPECIFY
NUMBER, RULING AND THICKNESS
AS INDICATED ON BACKBONE OF BOOK

First Bore concentration { 1.18 mg O/gal
1.1788 mg B/cc

Exp 131 W/T

Instrument Check on 7-13-63 Source 10mcX

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Responst	Calibration	JH		
IC-4	Responst	Calibration	JH		
CRM		Meter Trip			

Preliminary Check on 7-13-64

Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check JH C.C.
 Scrums and Bldg. Alarm Reset JH
 Source Inserted C.C.
 Safety Withdrawal 26.00
 Controls Set Inner 15.0 Outer 0.0
 Reflector Water 6" above Be
 Moderator Water 25.88

Condition	Inner	Outer	Safety
$k > 1$	19.70	19.80	26.00
$k = 1$		19.54	26.00
$k = L$	19.62	19.62	26.00
$k = 1$	19.63	19.63	20.27

3PN-97

{	Bkg	8	{	cpo	30	{	145 KV
	Delay	16		Burst	10^3		0.9 ma
	ch. wdt.	160		Beam	7 μ a		

1.18 mg/cc

Exp 131 A w/Target

Instrument Check on 7-14-64 Source covered

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK		
IC-3	Responds	Calibration	JH		
IC-4	Responds	Calibration	JH		
CM		Meter Trip			

Preliminary Check on 7-14-64

- Room 113 Pressure Differential 1.4"
- Red Light On and Personnel Check JH c.c.
- Scrams and Bldg, Alarm Reset JH
- Source Inserted JH
- Safety Withdrawn 26.00
- Controls Set Inner 19.62 Outer 10.00
- Reflector Water 6" above Be.
- Moderator Water

Condition	Inner	Outer	Safety
K > 1	19.62	19.85	26.0
K = 1	19.62	19.60	26.0
K = 1	19.61	19.61	26.0
K = 1	19.63	19.63	20.77

"Note"

Shut Down to Repair Safety Drive

Cont Exp # 131 (B)

12 ^{3/6} PM

Condition	Inner	Outer	Safety
K > 1	19.63	19.86	20.77
K = 1	19.61	19.61	20.77

Exp. 132

W/T

Instrument Check on 7-15-64 Source 10mcK

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 > 3x10⁻⁴ Meter Trip OK Fast Trip OK
 IC-2 > 3x10⁻⁴ Meter Trip OK
 IC-3 Responds Calibration JII
 IC-4 Responds Calibration JII
 CRM Meter Trip

Preliminary Check on 7-15-64

Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check JT CC
 Scrams and Bldg, Alarm Reset JII
 Source Inserted JII Acc.
 Safety Withdrawn 26.00
 Controls Set Inner 18.00 Outer 18.00
 Reflector Water 6" above Be.
 Moderator Water 25-82 in.

Exp.	Condition	Inner	Outer	3PN #	exp. 146
132	k < 1	19.00	19.00	98	
133	"	18.00	18.00	99	
4	"	17.00	17.00	100	
5	"	15.00	15.00	101	
6	"	13.63	13.63	102	
7	"	13.63	19.63	103	
8	"	19.63	13.63	104	
9	"	19.63	15.00	105	
140	k > 1	19.63	19.85		
	k = 1	19.63	19.61		Probe -14.1
		19.00	20.35		Control Cyl. Calib.
		18.57	21.00		
		18.07	22.00		

Condition	Eym 140 cont'd		W/T
	Inner	Outer	safety
R=1	17.71	23.00	26.00
	17.45	24.00	
	17.29 ⁶	25.00	
	17.225	26.00	
	17.20	26.09	
	20.00	19.25	
	21.00	18.48	
	22.00	17.95	
	23.00	17.56	
	24.00	17.29	
	24.70	17.16 ⁵	

	Condition	Inner Outer		δ/w	
		inner	outer	outer	inner
14	R<I	^{2096.51} 20.49	18.69 ²⁸⁵ 18.23		.441
15	R>I	20.49	18.98 ⁵	.789	
16	R<I	^{2030.39} 20.10	18.98 ⁵		.609
17	R>I	20.10	^{17.17.325} 19.31	.786	
18	R<I	^{19.82.56} 19.54	19.31		
19	R>I	19.54	^{17.62.615} 19.92 ⁵		
20	R<I	^{19.35} 19.19	19.92 ⁵		.706
21	R>I	19.19	^{20.345} 20.27	.596	
22	R<I	^{18.27} 18.92	20.27		.757
23	R>I	18.92	^{20.649} 20.66	.416	
24	R<I	^{18.27} 18.65	20.66		.836
25	R>I	18.65	^{20.7425} 21.08 ⁵	.515	
26	R<I	^{18.29} 18.36	21.08 ⁵		.907
27	R>I	18.36	^{21.545} 21.63	.491	
28	R<I	^{18.23} 18.13	21.63		.875
29	R>I	18.13	^{21.849} 22.12	.391	
30	R<I	^{18.23} 17.90	22.12		.910
31	R>I	17.90	^{22.65} 22.77	.399	
32	R<I	^{17.77.25} 17.65	22.77		.966
33	R>I	17.65	^{22.815} 23.58 ⁵	.273	
34	R<I	^{17.22} 17.43	23.58 ⁵		.957
35	R>I	17.43	^{24.178} 24.76	.1807	
36	R<I	^{17.23} 17.20	24.76		1.03
37	R=I	17.20	^{25.72.325} 26.09	.100	

Control Calibration

Instrument Check on 7-16-64 Source 10mcK
 Expt 141 WIT

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	OK
IC-1	> 3x10 ⁻⁴	Meter Trip	OK	Fast Trip
IC-2	> 3x10 ⁻⁴	Meter Trip	OK	
IC-3	Responds	Calibration	JH	
IC-4	Responds	Calibration	JH	
CRM		Meter Trip		

Preliminary Check on 7-16-64

Room 113 Pressure Differential	6.4"
Red Light On and Personnel Check	JH C.C.
Scrams and Bldg, Alarm Reset	JH
Source Inserted	JH
Safety Withdrawn	26.00
Controls Set	In: 24.70 Out: 0.0
Reflector Water	6" above Bc.
Moderator Water	25.74

	Condition	Inner	Outer	\$/in	Outer	Inner
1.	R > 1	24.70	17.40		.875	
2.	R < 1	24.70	17.05 ³⁵	17.20	.965	
3.	R > 1	24.70	17.40 ³⁵	17.60		
4.	R < 1	23.24 ^{23.17, 4.6}	17.40		.19.92	.28.77
5.	R > 4	23.24	17.62 ²²	17.51	.873	
6.	R < 1	22.48 ^{22.46, 7.55}	17.62 ^{17.75}		.317	
7.	R > 1	22.48 ⁵	17.88 ²⁰		.919	
8.	R < 1	21.86 ^{21.62, 5}	17.88 ^{17.82}		.389	
9.	R > 1	21.86 ⁵	18.15 ²⁹		.879	.447
10.	R < 1	21.34 ^{21.52, 5}	18.15 ^{26.5}	18.28	.447	
11.	R > 1	21.34 ⁵	18.41 ⁵		.866	.44
12.	R < 1	20.90 ^{21.44, 5}	18.41 ⁵	18.55	.492	
13.	R > 1	20.90	18.69 ^{27.5}		.772	

Foils:

Inner IE-3E location: 37a

Outer OE-96 location: 78b

Norm foil 5 of IE-3G in #4 slot of IE10F location: 17th slot from 37a

Target ID of IE-3G location 23/32" from ϕ

IC of IE-3G location on surface of Target assembly

Begin Exposure at 8:55 AM Expose 30min at 1×10^{-8} IC-3

7 $\times 10^{-8}$ IC4

1.8 70×10^{-8} IC1

4.7 3×10^{-8} IC2

Foil Exposure

Expt. 142

W/T

Instrument Check on 7-17-64 Source 10mc8

PM-1	Low Trip	ok	Alarm Trip	ok
FM-2			Alarm Trip	ok
IC-1	$> 3 \times 10^{-11}$	Meter Trip	ok	Fast Trip
IC-2	$> 3 \times 10^{-11}$	Meter Trip	ok	
IC-3	Responds	Calibration	JH	
IC-4	Responds	Calibration	JH	
CRM		Meter Trip		

Preliminary Check on 7-17-64

Room 113 Pressure Differential	1.4"
Red Light On and Personnel Check	JH (East on)
Screams and Bldg, Alarm Reset	JH
Source Inserted	JH
Safety Withdrawn	26.00
Controls Set	Inner 19.00 Outer 1.0
Reflector Water	6" above bc
Moderator Water	25.70

Condition	Inner	Outer	
k > 1	19.61	19.80	Rhette 14.78
k = 1	19.61	19.65	

foils

Inner IE 15E location 37a

Outer OE 4F " 78b

Norm foil # of IE 34 " slot 17 from 37a

Begin Exposure at 8⁵⁵/_{AM} Expose 30 min. 6.8 10×10^{-8} IC 15.3 3×10^{-8} IC 2End Exposure at 9²⁷/_{AM} .9 10^{-8} IC 35.5 10^{-8} IC 4

foil Expos.

Expt. 143

w/T

Instrument Check on 7-20-64 Source 10mcY

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK		
IC-3	Responds	Calibration	JW		
IC-4	Responds	Calibration	JW		
CRM		Meter Trip			

Preliminary Check on 7-20-64

Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check JW CC.
 Scrums and Disg. Alarm Reset JW
 Source Inserted JW
 Safety Withdrawn 26.00
 Controls Set Inner 14.0 Outer 26.09
 Reflector Water 6" above Be
 Moderator Water 25.24

Condition	Inner	Outer		
k>1	17.94	26.09	Rhottle (18.2 f)	.83 $\frac{1}{in}$
k=1	17.22	26.09		

Inter. mag. current.

Have dissolved 72.4 gms of dried $\text{Na}_2\text{B}_4\text{O}_7$ in 2 liters of H_2O .

Expt 144 - add 500 cc of above solution.

Expt 145 " 1000 cc " " "

Expt 147 " 500 cc " " "

Exp 144 w/T
 Instrument Check on 2-21-64 Source 10 mgd

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 $> 3 \times 10^{-4}$ Meter Trip OK Fast Trip OK
 IC-2 $> 3 \times 10^{-4}$ Meter Trip OK
 IC-3 Responds Calibration JH
 IC-4 Responds Calibration JH
 CRM Preliminary Check on
 Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check JH (cast)
 Scrams and Bldg, Alarm Reset JH
 Source Inserted JH
 Safety Withdrawn 26.00
 Controls Set Inner 20.00 : Outer
 Reflector Water 6" above Be
 Moderator Water 25.74

+500 cc

	Condition	Inner	Outer
Exp 144	R > 1	20.17	20.17
	R = 1	20.17	19.85

+1000 cc

Exp 145	R > 1	21.00	21.15
	R = 1	21.00	20.77

Repeat:

Exp 146	R > 1	21.00	21.15
	R = 1	20.00	20.77

R&R 500cc.

Exp 147	R > 1	21.00	22.31
	R = 1	21.00	21.82
	R = 1	21.38	21.38

Exp 148

Dissolved 72.4 gms of dried $\text{Na}_2\text{B}_4\text{O}_7$ in 2 liters of H_2O

Expr 148

add 1000 cc.

Expr 148	Condition	Inner	Outer
	K > 1	22.90	23.00
	K = 1	22.68	22.68

add 1000 cc

Expr 149	R = 1	24.70	26.09
----------	-------	-------	-------

Removed 1 liter of moderator & added 1 liter of H₂O

Expr 150	K > 1	24.70	25.80
	K = 1	24.27	24.27

added 300 cc of the removed 1 liter of moderator. (Expr 149)

Expr 151	K = 1	24.29	24.29
----------	-------	-------	-------

added 500 cc of the removed 1 liter of moderator (Expr 149)

	K > 1	24.70	25.75
	K = 1	24.30	24.30

Added 100 cc Boron Solⁿ~~Expr # 152 24.70 26.085~~~~K > 1 24.70 26.085 26.00~~~~K = 1 24.70 25.05 26.00~~9⁴⁰ AMDrain fuel H₂O10¹⁷~~K > 1 24.70 26.085 26.00~~~~K = 1 24.70 25.10~~

Expt. 152 W/T

Instrument Check on 7-22-64 Source 10mc8

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK		
IC-3	Responds	Calibration	JH		
IC-4	Responds	Calibration	JH		
BRM		Meter Trip			

Preliminary Check on 7-22-64

Room 113 Pressure Differential	1.4"
Red Light On and Personnel Check	JH CC.
Scrams and Bldg. Alarm Reset	JH
Source Inserted	JH
Safety Withdrawn	26.00
Controls Set	In: 24.70 O: 20
Reflector Water	6" above bc
Moderator Water	~26"

Condition	Inner	Outer
K=1	24.70	26.09
K=1	24.52	24.52

Expt 153 Add 100 cc Boron Solon

K>1	24.70	26.085	26.00
K=1	24.70	25.05	26.00

9⁴⁰ AM Drain fuel H₂O

10 ¹¹	K>1	24.70	26.085	26.00
------------------	-----	-------	--------	-------

Expt 154	K=1	24.70	25.10	26.00
----------	-----	-------	-------	-------

Add 100 cc H₂O

Expt 155	K>1	24.70	26.085	26.0
----------	-----	-------	--------	------

	K=1	24.70	24.94	26.0
--	-----	-------	-------	------

11¹⁰ Add 100 cc H₂O

Foil

Inner: IE 13 A in 37a

Outer: OE 13 F in 28b

Norm 4F of IE 36 - slot 17 from 37a

target 1 $\frac{3}{32}$ from $\frac{1}{2}$

1B edge

Reflector: 4B on Be

4C 2"

4D 4"

4E 6"

foils from Plate IE-36

Begin Exposure at $9\frac{1}{4}\%$ AM, Expose 30 min2.1 10×10^{-8} IC 14.9 3×10^{-8} IC 21.05 10^{-8} IC 36.5 10^{-8} IC 4

	Condition	Inner	Outer	
Exp. 155	k=1	24.67	24.67) 7.6 $\frac{1}{2}$ in
	k>1	24.67	26.09	
	k=1	23.87	26.09) 13.7 $\frac{1}{2}$ in
	k<1	23.37	26.09	

Foil Exposure 2 exp. 152 w/T
 Instrument Check on 7-23-64 Source _____

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Responds	Calibration	JH		
IC-4	Responds	Calibration	JH		
CRM		Meter Trip			

Preliminary Check on 7-23-64

Room 115 Pressure Differential 1.4"
 Red Light On and Personnel Check JH C.C. (East)
 Scrums and Bldg, Alarm Reset JH
 Source Inserted C.C.
 Safety Withdrawn 26.00
 Controls Set In: 24.67 out: 0.0
 Reflector Water 6" above Re.
 Moderator Water ~26.5"

Condition	Inner	Outer	
k>1	24.70	26.09	5.15 $\frac{1}{2}$ in \Rightarrow 124.9 μ \Rightarrow 8.274
k=1	24.70	24.93	7.1 $\frac{1}{2}$ in

Moderator water sampled
 has 6.48 $\frac{1}{2}$ B/L.

Foils:

~~IE-36~~

Outer plates only

OE 2I in 28b

6G in 155b

7F in 207b

15G in 259b

16F in 315b

16G in 1b

Norm. foil 2 of IE-36 in slot 17 from 37a.

Begin Exposure	9 ²¹ / _{AM}	Exposure	30min.	6.9	10×10^{-8}	IC1
				51	3×10^{-8}	IC2
				6.5	10^{-8}	IC3
				6.5	10^{-8}	IC4

Fails

Expt 157 w/T

Instrument Check on 7-24-64 Source Co met

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Responds	Calibration	JK		
IC-4	Responds	Calibration	JW		
CRM		Meter Trip			

Preliminary Check on 7-24-64

Room 113 Pressure Differential 14

Red Light On and Personnel Check JT CC.

Scrams and Bldg, Alarm Reset JT

Source Inserted JT

Safety Withdrawn 26.00

Controls Set Inner 24.70 Outer 20.00

Reflector Water 6" above bc

Moderator Water ~ 26.5"

Condition	Inner	Outer
k>1	24.70	26.09
k=1	24.70	25.35

Expt 158 Added 100cc H₂O

k>1	24.70	26.09	w/source
k=1	24.70	24.96	

Exp. 159

Instrument Check on 7-31-69 Source 10mc

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 > 3x10⁻⁴ Meter Trip OK Fast Trip OK
 IC-2 > 3x10⁻⁴ Meter Trip OK
 IC-3 Respects Calibration JH
 IC-4 Respects Calibration JH
 CRM Meter Trip

Preliminary Check on 7-31-69

Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check
 Scrams and ~~Blig~~ Alarm Reset JH
 Source Inserted Source Acc.
 Safety Withdrawn 20.77
 Controls Set Same 24.70
 Reflector Water ~ 6" above BE
 Moderator Water ~ 27"

Condition	Inner	Outer	Safety	
k>1	24.70	26.09	26.01	
R=1	24.70	25.34	26.01	
R=1	24.70	25.50f	20.76	
R=1	24.70	25.34	26.01	
k<1	19.61	19.61	26.01	3PN-107

add 125 cc H₂O mixed for 1/2 hr.

Expt. 163

Instrument Check on 8-3-64 Source 10mc

N-1	Low Trip	OK	Alarm Trip	OK	
N-2			Alarm Trip	OK	
C-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip	OK
C-2	$> 3 \times 10^{-11}$	Meter Trip	OK		
C-5	<u>Out</u>	Calibration			
C-4	<u>Response</u>	Calibration	<u>JH</u>		
NIM		Meter Trip			

Preliminary Check on 8-3-64

Room 113 Pressure Differential	<u>1.4"</u>
Red Light On and Personnel Check	<u>JH - C.C.</u>
Screams and Bldg. Alarm Reset	<u>JH</u>
Source Inserted	<u>C.C.</u>
Safety Withdrawn	<u>26.00</u>
Controls Set	<u>Inner 24.70 Outer 0.0</u>
Reflector Water	<u>2" above BL.</u>
Moderator Water	<u>~27"</u>

Condition	Inner	Outer	Safety
k=1	24.70	26.09	26.00
k=1	24.70	25.30	26.00
k=1	24.70	25.47	26.76

added 100 cc H₂O

k=1	24.70	25.12	26.00
-----	-------	-------	-------

added 100 cc H₂O

k=1	24.70	24.85	26.00
-----	-------	-------	-------

take sample of (B) moderator
Sample 5 A. 1.49 g/p B.

Exp. 164 W/T

Instrument Check on 8-4-64 Source 10 mcX

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 $> 3 \times 10^{-11}$ Meter Trip OK Fast Trip OK
 IC-2 $> 3 \times 10^{-11}$ Meter Trip OK
 IC-3 Calibration alarm ✓
 IC-4 Responds Calibration JTT
 CRM Meter Trip

Preliminary Check on 8-4-64

Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check JTT CC.
 Scrams and Bldg. Alarm Reset JTT
 Source Inserted JTT
 Safety Withdrawn 26.00
 Controls Set Inner 24.70; Outer 00
 Reflector Water 6" above Be.
 Moderator Water ~ 26.00

Condition	Inner	Outer	Rhetta
$R > 1$	24.70	26.09	6.48 f
$R = 1$	24.70	24.94	
$R < 1$	24.70	24.31	-7.73
$R = 1$	24.70	25.09	

Out of D²

Exp 165 W/T

Instrument Check on 8-5-64 Source 10mcV

PM-1 Low Trip OK Alarm Trip ✓
 PM-2 Alarm Trip ✓
 IC-1 > 3 × 10⁻⁴ Meter Trip ✓ Fast Trip ✓
 IC-2 > 3 × 10⁻⁴ Meter Trip OK
 IC-3 ✓ Calibration JII
 IC-4 ✓ Calibration JII
 CRM Meter Trip

Preliminary Check on 8-5-64

Room 113 Pressure Differential 1.4^{cc}
 Red Light On and Personnel Check CC-
 Scrams and Bldg. Alarm Reset JII
 Source Inserted JII
 Safety Withdrawn
 Controls Set
 Reflector Water
 Moderator Water

Condition Inner Outer Safety

R=1 24.70 25.425 26.00

R=1 24.70 25.59 20.76 3PN-111 see p146.

R<1 24.70 25.59 20.76

neg period 126 div/sec 2738 sec ⇒ R = -0.4724

R ≈ .99968

<i>div/sec</i>	T	P
11.5	249.9	4.59
13.35	290.1	-5.18
10.9	236.8	4.81
14.05	305.3	-4.88

Expt 166 W/T

Instrument Check on 8-6-64 Source 10 mcd

FM-1	Low Trip	✓	Alarm Trip	✓	
FM-2			Alarm Trip	✓	
IC-1	> 3x10 ⁻¹¹	Meter Trip	✓	Fast Trip	✓
IC-2	> 3x10 ⁻¹¹	Meter Trip	✓		
IC-3	Response	Calibration	JH		
IC-4	Response	Calibration	JH		
CRM		Meter Trip			

Preliminary Check on 8-6-64

Room 113 Pressure Differential 1.9"
 Red Light On and Personnel Check JH
 Sprays and ~~Blow~~ Alarm Reset JH
 Source Inserted JH - Acc.
 Safety Withdrawn 26.00
 Controls Set Inner 24.70 Outer 23.00
 Reflector Water 6" above Be.
 Moderator Water ~26"

Condition: Inner Outer

$R \approx 1$	24.70	26.09	slight positive period w/4
---------------	-------	-------	----------------------------

added 150 cc H₂O to Moderator - f Rhette

$k > 1$	24.70	26.09	+4.59
---------	-------	-------	-------

$k = 1$	24.70	25.27	-5.18
---------	-------	-------	-------

$k < 1$	24.70	24.72	+4.81
---------	-------	-------	-------

$k > 1$	24.70	26.09	+4.88
---------	-------	-------	-------

Expr 256 w/T Eu_2O_3 cylinders.

24³ PM.

Moderator water contains $\approx 1.48 \text{ g/l}$.

Condition Inner Outer Safety

26.00

k>1 25.00 23.65 26.00

R=1 24.09 23.65 26.00

Add 150 cc of Borated[?] Water. Expr. 257

R>1 25.00 24.12 26.00

R=1 24.12 24.12

Add 200 cc of Borated[?] Water Expr. 258

Expr 258

Instrument Check on 11-25-64 Source 10mc

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	OK
IC-1	> 10K16-12	Meter Trip	Fast Trip	
IC-2		Meter Trip		out
IC-3	Responds	Calibration	JIT	
IC-4	Responds	Calibration	JIT	
CRM		Meter Trip		

Preliminary Check on 11-25-64

- Room 113 Pressure Differential 1.4"
- Red Light On and Personnel Check JIT CC
- Scrams and Bldg, Alarm Reset JIT
- Source Inserted JIT
- Safety Withdrawn 26.00
- Controls Set James 0.0 Peter 0.0
- Reflector Water 6" above Be
- Moderator Water ~ 25"

Expr	Condition	Inner	Outer	Safety	
258	k>1	25.00	24.80	26.00	2317 dir/sec
	k=1	24.17	24.80	26.00	
Add 200 cc of Borated [?] Solution					
259	k>1	25.00	25.71	26.00	2983 dir/sec.
	k=1	25.00	24.61	26.00	
Add 200cc of Borated [?] Solution					
260	k>1	26.00	25.69	26.00	13354 3.083 dir/sec.
	k=1	26.00	24.63	26.00	12.64/in
	k=1	24.73	25.69	26.00	
	k=1	25.11	25.16	26.00	
	k=1	25.23	25.23	20.88	3PN-184
	k=1	at end of 3PN-184			

12/9/64 → 13895/1

Expt.	Condition	Inner	Outer	Safety	SPN#	1.39 $\frac{85}{L}$
261	K<1	25.16	24.00	26.00	185	
262	K<1	25.16	23.00	26.00	186	
263	K<1	25.16	22.00	26.00	187	
264	K<1	25.16	21.00	26.00	188	
265	K<1	25.16	20.00	26.00	189	
266	K<1	25.16	19.00	26.00	190	
267	K<1	25.16	18.00	26.00	191	
268	K<1	25.16	17.00	26.00	192	
269	K<1	24.00	25.16	26.00	193	
270	K<1	23.00	25.16	26.00	194	

Exp 271
Instrument Check on 11-27-64 Source 10 mc r

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	OK
IC-1	7×10^{-12}	Meter Trip	Fast Trip	
IC-2	—	Meter Trip		Out
IC-3	Responds	Calibration	S/R	
IC-4	Responds	Calibration	S/R	
PM		Meter Trip		

Preliminary Check on 11-27-64

Room 113 Pressure Differential	1.4"	
Red Light On and Personnel Check	S/R	CC.
Scrams and Bldg, Alarm Reset	S/R	
Source Inserted	S/R	
Safety Withdrawn	26.00	
Controls Set	Inner 25.16	Outer 0.0
Reflector Water	6" above Be	
Moderator Water	~ 25"	

Exp.	Condition	Inner	Outer	Safety	3 PN #
271	b=1	25.30	25.69	26.00	
	add 100 cc of H ₂ O				
272	b>1	26.89	25.71	26.00	
	b=1	25.275	25.71	26.00	
	add 400 cc of H ₂ O				
273	b>1	25.75	25.71	26.00	3.267 div/sec.
	b=1	25.08	25.09	26.00	
	add 10 cc of Borated ³ solution				
274	b>1	26.89	25.69	26.00	1.975 div/sec
	b=1	25.11	25.11	26.00	
275	b<1	22.00	25.11	26.00	195
276	b<1	21.00	25.11	26.00	196
					1.38 8 1/2

Exp 277
Instrument Check on 12-1-64 Source 10 mcr

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	OK
IC-1	7 3x10"	Meter Trip	Fast Trip	
IC-2		Meter Trip		Out
IC-3	Responds	Calibration	S/R.	
IC-4	Responds	Calibration	S/R.	
CRM		Meter Trip		

Preliminary Check on 12-1-64

113 Pressure Differential	1.6"
Light On and Personnel Check	S/R. C.C.
Alarms and Bldg. Alarm Reset	S/R. C.C.
Probe Inserted	
Probe Withdrawn	26.00
Controls Set	Lower 24.48 Outer 0.0
Collector Water	6" above Re
Generator Water	~ 25"

Exp	Condition	Inner	Outer	Safety	SPN #
277	b > 1	26.89	25.72	26.00	3433 di/dec
	b = 1	25.16	25.68	26.00	
278	add 200 cc of H ₂ O				
278	b > 1	26.58	25.72	26.00	2.867 di/dec
	b = 1	25.28	25.28	26.00	
	add 150 cc of H ₂ O				
279	b > 1	26.70	25.72	26.00	2.5 di/dec
	b = 1	25.14	25.14	26.00	

1.387 1/2

280 - 283 on page 148

12/14/64
10^{am} Removed 18 Liters of Moderator H₂O
added 20 " " distilled H₂O.

Sample 8A taken 3⁴⁵ PM

Results on 12/21/64 0.28 gB/l.

Expr 284 w/T

Instrument Check on 12-14-64 Source 10mc

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 $> 3 \times 10^{-11}$ Water Trip OK Fast Trip OK
 IC-2 $> 10 \times 10^{-12}$ Water Trip OK
 IC-3 Responds Calibration SR
 IC-4 Responds Calibration JIT
 CRM Water Trip

Preliminary Check on 12-14-64

Room 113 Pressure Differential 1.4 in.
 Red Light On and Personnel Check ✓ (past)
 Scrams and Bldg, Alarm-Reset ✓
 Source Inserted ✓
 Safety Withdrawn 26.00
 Controls Set Inner 0.0 Outer 0.0
 Reflector Water 6" above Be
 Moderator Water

Condition	Inner	Outer	Safety	
$k > 1$	20.05	20.14	26.00	no period.
$k > 1$	20.05	20.20	26.00	2.7 lit/sec.
$k = 1$	20.05	20.00	26.00	
$k = 1$	20.02	20.02	26.00	
$k = 1$	20.045	20.045	20.88	3PN-204
$k = 1$	at end of 3PN.			

Expr. 285-294 3PN see p. 147.

Drained, Flushed with Dilute H_2O_2 and Rinsed.

Experiment 297

Instrument Check on 1-19-65 Source 10mc

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK		
IC-3	Responds	Calibration	JH		
IC-4	Responds	Calibration	JH		
CRM		Meter Trip			

Preliminary Check on 1-19-65

Naem 113 Pressure Differential	1.4"
Red Light-On and Personnel Check	JH - C.C.
Scrams and Bldg, Alarm Reset	JH
Source Inserted	JH
Safety Withdrawn	25.00
Controls Set	Inner 0.0 Outer 0.0
Reflector Water	6" above Be
Moderator Water	~ 26

Condition	Inner	Outer	Safety	
$k > 1$	20.00	21.10	26.00	2.5" dia. beam.
$k = 1$	20.00	20.85 ⁵	26.00	Mod. Water
$k = 1$	20.00	20.81	26.00	23.17
$k < 1$	20.00	20.81	26.00	21.42

N.B. linear instr. shows increase then decrease.

ln N - very slightly negative.

$k = 1$	20.01	20.81	26.00	21.42
$k < 1$	20.01	20.81	26.00	18.92

N.B. all instr. show decrease

$k = 1$	20.64	20.81	26.00	18.92
$k < 1$	26.83	25.80	26.00	12.38
$k = 1$	26.83	25.80	26.00	14.85

tested

1-19-65

Expt. 298

added 200cc of conc. B-solution to moderator.
 mixed in moderator storage tank ~ 8 min.
 Condition Inner Outer Safety Mod. H₂O.

$R > 1$	20.00	21.20	26.00	26.81	2 div/sec
$R = 1$	20.00	20.91	26.00	26.81	
$R = 1$	20.45 ^s	20.45 ^s	26.00	26.81	
$R < 1$	20.45 ^s	20.45 ^s	26.00	20.8	

N.B. In H shows only decrease.

$R = 1$	21.26	21.26	26.00	20.0	
$R < 1$	21.26	21.26	26.00	19.5	
$R = 1$	21.43 ^s	21.43 ^s	26.00	19.5	
$R < 1$	21.43 ^s	21.43 ^s	26.00	17.0	
$R = 1$	23.39 ^s	23.39 ^s	26.00	17.0	
$R < 1$	25.00	25.00	26.00	16.00	

Continued decreasing showed no change in
 normal neutron decay for shutdown condition.

Expt. 299

Added ~ 1 liter conc. B-solution mixed ~ 5 min.

Cond.	Inner	Outer	Safety	Mod. H ₂ O	
$R > 1$	21.76	20.27	26.00	~ 27.0	1.834 div/sec
$R = 1$	21.39	20.27	26.00	~ 27.0	
$R = 1$	20.80 ^s	20.80 ^s	26.00	~ 27.0	
$R < 1$	20.80 ^s	20.80 ^s	26.00	23.5	
$R = 1$	20.85	20.85	26.00	23.5	
$R < 1$	20.85	20.85	26.00	22.0	
$R = 1$	21.72	21.72	26.00	19.5	
$R = 1$	25.00	25.00	26.00	17.0	

1-19-65 Put 0.885^g/_l moderator into system again.

25.41

N.B.

Comparison of results observed in Expt 297 with those of Expt 298 casts doubts on 297.

Since additional Boron was small in quantity & effect the experimental conditions may be considered *v* same. Seems to suggest moderator for Expt 297 may not have been well mixed.

May also suggest that effect would be more manifested in dilute Boron solutions rather than more concentrated.

Spent element D-24 centered in island of CE-3

Expt 518 Spent Plate D 3224 in slot 1 of D24.

D 5495 " " 22 " " .532 (N)

1.78 $\frac{\text{dir}}{\text{sec}}$ \rightarrow ~~79~~ 38.65 sec \rightarrow 19.40¢ \rightarrow 36.47¢/in (16.474)

Expt 519 ^{Added} Spent Plate D 3242 in slot 2 of D24

D 2870 " " 21 " D24 (N)

2.87 $\frac{\text{dir}}{\text{sec}}$ \rightarrow 62.31 sec \rightarrow 14.07¢ \rightarrow 63.95¢/in (13.52)

Expt 520 ^{Added} Spent plates D-3252 in slot 20 of D24

D 3228 in slot 3 of D24

3.52 $\frac{\text{dir}}{\text{sec}}$ \rightarrow 76.42 sec \rightarrow 12.13¢ \rightarrow 75.81¢/in (11.79)

Expt. 518

Instrument Check on 3-15-65 Source 10 met

PM-1	Low Trip	Alarm Trip	OK
PM-2		Alarm Trip	
IC-1	> 3x10 ⁻⁴	Water Trip	OK
IC-2	> 3x10 ⁻⁴	Water Trip	OK
IC-3	Responds	Calibration	JH
IC-4	Responds	Calibration	JH
CRM		Water Trip	

Preliminary Check on 3-15-65

Room 113 Pressure Differential	1.5"
Red Light On and Removal Check	JH CC
Scrams and Bldg. Alarm Reset	JH A trips but does not stay on
Source Inserted	JH
Safety Withdrawn	0
Controls Set	
Reflector Water	} combined
Moderator Water	

Expt.	Condition	Safety	H ₂ O	Island
518	k > 1	16.75	26.26	2 spect plates
	k = 1	16.218	26.26	" "
519	k > 1	13.63	26.26	4 " "
	k = 1	13.41	"	" " "
520	k > 1	11.87	26.32	6 " "
	k = 1	11.71	"	" " "
521	k > 1	14.61³	26.07	

Expt. 521 Spent plate D 3243 in slot 19 of D24

$$1.7 \frac{\text{div}}{\text{sec}} \rightarrow 36.91 \text{ sec} \rightarrow 19.98 \phi \rightarrow 85.38 \phi/\text{in} \quad (10.585)$$

Expt. 522 Spent plate D3230 in slot 5 of D24

$$3.76 \frac{\text{div}}{\text{sec}} \rightarrow 81.63 \text{ sec} \rightarrow 11.54 \phi \rightarrow 86.12 \phi/\text{in} \quad (9.497)$$

Expt. 523 Spent plate D3219 in slot 6 of D-24

$$2.88 \frac{\text{div}}{\text{sec}} \rightarrow 62.53 \text{ sec} \rightarrow 14.03 \phi \rightarrow 93.53 \phi/\text{in} \quad (8.645)$$

Expt. 524 Spent plate D3241 in slot 7 of D-24

$$1.61 \frac{\text{div}}{\text{sec}} \rightarrow 34.95 \text{ sec} \rightarrow 20.67 \phi \rightarrow 83.68 \phi/\text{in} \quad (7.937)$$

Expt. 526 3 B¹⁰ strips in I.A. ; 22 B¹⁰ strips in O.A.₁₅

$$1.78 \frac{\text{div}}{\text{sec}} \rightarrow 38.65 \text{ sec} \rightarrow 19.40 \phi \rightarrow 27.13 \phi/\text{in} \quad (18.863)$$

Expt. 527 5 B¹⁰ strips in I.A. ; 22 B¹⁰ strips in O.A. R << 1

Instrument Check on 3-16-65 Source 10met

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip
 IC-1 > 3x10⁻⁴ Water Trip OK Fast Trip OK
 IC-2 > 3x10⁻⁴ Water Trip OK
 IC-3 Responds Calibration JH
 IC-4 Responds Calibration JH
 CRM Water Trip

Preliminary Check on 3-16-65

Room 113 Pressure Differential 1.5 "
 Red Light On and Personnel Check (East) JH
 Scrums and Bldg, Alarm Reset JH all ok
 Source Inserted JH
 Safety Withdrawn 0
 Controls Set
 Reflector Water } 26.26
 Moderator Water }

Expt.	Condition	Safety	H ₂ O	Island
521	k > 1	10.70 ²	26.26	8 plates
	k = 1	10.46 ⁸	26.26	
522	k > 1	9.56 ⁴	26.26	10 plates
	k = 1	9.43	26.26	
523	k > 1 ⁷	8.72	26.26	12 plates
	k = 1	8.57	26.26	
524	k > 1	8.06	26.29	14 plates
	k = 1	2.81 ³ ₈₂	26.29	
525	k << 1	26.00	26.29	14 plates { 6 8" strips inner annulus 22 8" " outer "
526	k > 1	18.42	26.29	14 plates { 38" " inner " 22 8" " outer "
	k = 1	17.70 ⁵ ₂₃₈	26.29	
527	k << 1	26.00	26.29	14 plates { 5 8" strips inner annulus 22 8" strips outer "

0.585)

9.497)

7.645

7.937)

8.63)

Expt. 528 52.2 $\frac{\text{dir}}{\text{dec.}}$

- 529 3 B¹⁰ I.A + 23 B¹⁰ O.A ^{.603}
 2.83 $\frac{\text{dir}}{\text{dec.}}$ → 61.44 sec → 14.21 φ → 23.57 $\frac{\phi}{\text{in}}$ (18.53)
- 530 2 B¹⁰ I.A + 23 B¹⁰ O.A ^{.195}
 6.53 $\frac{\text{dir}}{\text{dec.}}$ → 141.77 sec → 7.46 φ → 38.26 $\frac{\phi}{\text{in}}$ (16.863)
- 531 1 B¹⁰ I.A + 23 B¹⁰ O.A ^{.207}
 4.36 $\frac{\text{dir}}{\text{dec.}}$ → 94.66 sec → 10.31 φ → 49.81 $\frac{\phi}{\text{in}}$ (15.337)
- 532 23 B¹⁰ O.A. ^{.255}
 2.6 $\frac{\text{dir}}{\text{dec.}}$ → 56.45 sec → 15.08 φ → 59.14 $\frac{\phi}{\text{in}}$ (14.753)
- 533 29 B¹⁰ O.A. ^{.94}
 0.94 $\frac{\text{dir}}{\text{dec.}}$ → 20.41 sec → 28.20 φ → 30.00 $\frac{\phi}{\text{in}}$ (17.88)
- 534 33 B¹⁰ O.A.
 48 $\frac{\text{dir}}{\text{dec.}}$ → 1042 sec → 1.21 φ
- 535 31 B¹⁰ O.A. ^{.989}
 2.04 $\frac{\text{dir}}{\text{dec.}}$ → 44.29 sec → 17.77 φ → 17.97 $\frac{\phi}{\text{in}}$ (19.32)

Expr	Condition	Safety	A ₂ O	Island	48" strips inner annulus. 23 B" " Outer "
528	R=1	26.00	26.30	14 plates	23 B" " Outer "
529	b > 1	18.88	"	"	3 B" I.A. + 23 B" O.A.
3)	b = 1	19.27 ^{2.01}	"	"	" "
530	b > 1	16.96	"	"	2 B" I.A. + 23 B" O.A.
63	b = 1	16.76 ^{0.65}	"	"	" "
531	b > 1	15.74	"	"	1 B" I.A. + 23 B" O.A.
7)	b = 1	15.53 ^{0.67}	"	"	" "
532	b > 1	14.88	"	"	23 B" O.A.
8)	b = 1	14.62 ^{0.95}	"	"	"
533	K > 1	18.35	"	"	29 B" O.A.
8)	b = 1	17.41	"	"	"
534	b ~ 1	26.03	"	"	33 B" O.A.
535	b > 1	19.87 ^{0.3}	"	"	31 B" O.A.
	b = 1	18.89 ^{0.3}	"	"	"

Instrument Check on 17 Mar 65 Source 10 mCV

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	7.3×10^{-11}	Meter Trip	OK	Fast Trip	OK
IC-2	7.3×10^{-11}	Meter Trip	OK		
IC-3	Responds	Calibration	J.T.T.		
IC-4	Responds	Calibration	J.T.T.		
CRM		Meter Trip			

Preliminary Check on 3-17-65

Room 113 Pressure Differential	1.5"
Red Light On and Personnel Check	S.R. & T.T.
Scrams and Bldg, Alarm Reset	J.T.T.
Source Inserted	S.R.
Safety Withdrawn	0
Controls Set	
Reflector Water	} Combined
Moderator Water	

536	33 B ¹⁰ Strips O.A.	3.03		
	81 dir/sec \Rightarrow 13.24 sec \Rightarrow .958 ϕ \rightarrow .32 ϕ /in			(23.98)
537	32 B ¹⁰ Strips O.A.	1.37		
	2.72 dir/sec \Rightarrow 59.05 sec \Rightarrow 14.612 ϕ \rightarrow 10.67 ϕ /in			(20.52)
538	28 B ¹⁰ Strips O.A.	.435		
	2.06 dir/sec \Rightarrow 44.72 sec \Rightarrow 17.655 ϕ \rightarrow 40.59 ϕ /in			(17.003)
539	24 B ¹⁰ Strips O.A.	.25		
	3.06 dir/sec \Rightarrow 66.43 sec \Rightarrow 13.437 ϕ \rightarrow 53.75 ϕ /in			(15.115)
540	20 B ¹⁰ Strips O.A.	.345		
	1.48 dir/sec \Rightarrow 32.13 sec \Rightarrow 21.761 ϕ \rightarrow 63.08 ϕ /in			(13.743)
541	16 B ¹⁰ Strips O.A.	.252		
	2.02 dir/sec \Rightarrow 43.85 sec \Rightarrow 17.884 ϕ \rightarrow 70.97 ϕ /in			(12.434)
542	12 B ¹⁰ Strips O.A.	.084		
	6.634 dir/sec \Rightarrow 144.02 sec \Rightarrow 7.370 ϕ \rightarrow 87.74 ϕ /in			(11.196)
543	8 B ¹⁰ Strips O.A.	.210		
	2.24 dir/sec \rightarrow 48.63 \rightarrow 16.70 ϕ \rightarrow 79.52			10.115
544	4 B ¹⁰ Strips O.A.	.121		
	3.96 dir/sec \rightarrow 85.97 \rightarrow 11.10 ϕ \rightarrow 91.74			9.00
545	Removed Spent plates: 3241 from slot 7 and 3246 from slot 10 4 B ¹⁰ strips in O.A.; 12 plates in D-24	.245		
	1.37 dir/sec \Rightarrow 29.74 sec \Rightarrow 22.796 ϕ \Rightarrow 93.04 ϕ /in			9.978
546	12 B ¹⁰ strips in O.A.	.262		
	1.53 dir/sec \Rightarrow 33.22 sec \Rightarrow 21.323 ϕ 81.39 ϕ /in			(12.199)
547	20 B ¹⁰ Strips in O.A.	.264		
	2.81 dir/sec \rightarrow 61.01 sec \rightarrow 14.28 ϕ \rightarrow 54.09 ϕ /in			(14.948)
548	28 B¹⁰ Strips in O.A. Removed spent plates 3219 and 3223	5.91		
	1.74 dir/sec \rightarrow 37.78 sec \rightarrow 19.68 ϕ 3.33 ϕ /in			22.06
549	Removed spent plate 3219 and 3223	5.534		
	2.75 dir/sec \rightarrow 59.70 sec \rightarrow 14.50 ϕ	2.62 ϕ /in		(22.31)
		9.58		
		13.542	2.504	5.41 ϕ /in
				21.50

Expt	Condition	Safety	H ₂ O	Island	Comments
536	R > 1	26.00	26.28	14 plates	33 B ¹⁰ strips in O.A.
	k = 1	22.97	26.28	"	" " " "
537	k > 1	21.33	26.28	"	32 B ¹⁰ strips " "
	R = 1	19.96	" "	"	" " " " "
538	k > 1	17.22	" "	"	28 B ¹⁰ strips " "
	k = 1	16.78 ⁵	"	"	"
539	k > 1	15.24	"	"	24 B ¹⁰ strips O.A.
	k = 1	14.99	"	"	" " " "
540	k > 1	13.91 ⁵	"	"	20 B ¹⁰ strips "
	k = 1	13.57	"	"	" " "
541	k > 1	12.56	"	"	16 B ¹⁰ " "
	R = 1	12.30 ⁸	"	"	" " " "
542	k > 1	11.23 ⁸	"	"	12 B ¹⁰ " "
	k = 1	11.15 ⁴	"	"	" " " "
543	k > 1	10.22	"	"	8 B ¹⁰ " "
	R = 1	10.01	"	"	" " " "
544	k > 1	9.00	"	"	4 B ¹⁰ " "
	k = 1	8.93 ³ ₄₀	"	"	" " " "
545	k > 1	9.94	26.27	12 plates	4 B ¹⁰ " "
	k = 1	9.69 ⁵	"	"	4 B ¹⁰ " "
546	k > 1	12.33	26.27	"	12 B ¹⁰ " "
	k = 1	12.06 ⁸ ₂₀	"	"	" " " "
547	k > 1	15.08	"	"	20 B ¹⁰ " "
	R = 1	14.81 ⁶ ₈₈	"	"	" " " "
548	k > 1	26.00	"	"	28 " " "
	k = 1	20.09 ₁₉₉	"	"	" " " "
549	k > 1	26.00	"	10 plates	24 " " "
	k = 1	20.46 ⁶ ₈₃₅	"	"	" " " "

550 20 B¹⁰ Strips O.A. .43
 2.34 $\frac{\text{dir}}{\text{sec}} \rightarrow 50.80 \text{ sec} \rightarrow 16.21 \text{ \#} \rightarrow 37.70 \text{ \%/in} \quad (16.885)$

551 12 B¹⁰ Strips O.A. .22
 2.52 $\frac{\text{dir}}{\text{sec}} \rightarrow 54.71 \text{ sec} \rightarrow 15.41 \text{ \#} \rightarrow 70.05 \text{ \%/in} \quad (13.31)$

552 4 B¹⁰ Strips O.A. .155
 3.25 $\frac{\text{dir}}{\text{sec}} \rightarrow 70.56 \text{ sec} \rightarrow 12.86 \text{ \#} \rightarrow 82.97 \text{ \%/in} \quad (10.673)$

Expt. 553 4 B¹⁰ Strips ; 10 Spent plates. 12.39 \#
 10.1 $\frac{\text{dir}}{\text{sec}} \rightarrow 219.28 \text{ sec} \Rightarrow 5.15 \text{ \#} \quad \left. \begin{array}{l} \Rightarrow 86.64 \text{ \%/in} \quad (10.732) \\ 2.08 \frac{\text{dir}}{\text{sec}} \Rightarrow 45.16 \text{ sec} \Rightarrow 17.54 \text{ \#} \end{array} \right\}$
 $5.15 \text{ \#} \Rightarrow 85.83 \text{ \%/in} \quad (10.63)$
 $17.54 \text{ \#} \Rightarrow 86.40 \text{ \%/in} \quad (10.702)$

Expt. 554 96 B¹⁰ Strips ; 10 Spent plates .10
 2.48 $\frac{\text{dir}}{\text{sec}} \rightarrow 53.84 \text{ sec} \rightarrow 15.58 \text{ \#} \quad \left. \begin{array}{l} = 8.91 \text{ \#} \rightarrow 79.10 \text{ \%/in} \quad (9.55) \\ 7.47 \frac{\text{dir}}{\text{sec}} \rightarrow 162.18 \text{ sec} \rightarrow 6.67 \text{ \#} \end{array} \right\}$

Removed Spent plates 3230 from slot 5 and 3259 from slot 18

Expt. 555 96 B¹⁰ Strips ; 8 Spent plates. .157
 2.96 $\frac{\text{dir}}{\text{sec}} \rightarrow 64.26 \text{ sec} \rightarrow 13.76 \text{ \#} \rightarrow 87.64 \text{ \%/in} \quad 10.584$

Expn.	Condition	Safety	H ₂ O	Island	Comments
550	k > 1	17.10	26.27	10 plates	20 B ¹⁰ strips O.A.
	k = 1	16.67 ₁₄₀	"	"	" " "
551	k > 1	13.42	"	"	12 " "
	k = 1	13.20 ₇₃	"	"	" " "
552	k > 1	10.75	"	"	4 " "
	k = 1	10.59 ₅₂	"	"	" " "

Instrument Check on 3-18-65 Source 1.0 mck

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1 1.73×10^{-4}	Meter Trip	OK	Fast Trip	OK
IC-2 2.3×10^{-4}	Meter Trip	J.T.T. OK		
IC-3 <u>Responds</u>	Calibration	J.T.T.		
IC-4 <u>Responds</u>	Calibration	J.T.T.		
CRM	Meter Trip			

Preliminary Check on 3-18-65

Room I13 Pressure Differential	1.5"
Red Light On and Personnel Check	S/R, J.T.T.
Scrams and Bldg. Alarm Reset	OK J.T.T.
Source Inserted	S/R.
Safety Withdrawn	0
Controls Set	
Reflector Water	} Combined
Moderator Water	

Expn.	Condition	Safety	H ₂ O	Island	Comments
553	k > 1	10.66	26.45	10 plates	4 B ¹⁰ strips O.A.
	k > 1	10.80 ³	"	"	" " "
	k = 1	10.60 ₁₄₀	"	"	" " "
554	k > 1	9.50	"	10 plates	No B ¹⁰ strips O.A.
	k > 1	9.60	"	" "	" " " "
555	k > 1	10.61 ²	"	8 plates	No B ¹⁰ strips O.A.
	k = 1	10.45 ₅₂	"	"	" " "

556 $2.28 \frac{\text{dir}}{\text{dec}} \rightarrow 49.50 \text{ sec} \rightarrow 16.50 \text{¢}$ } $10.33 \text{¢} \rightarrow 79.46 \frac{\text{¢}}{\text{in}}$ ^{.13} (11.825)
 $8.99 \frac{\text{dir}}{\text{dec}} \rightarrow 177.81 \text{ sec} \rightarrow 6.17 \text{¢}$ }

557

$2.35 \frac{\text{dir}}{\text{dec}} \rightarrow 51.02 \text{ sec} \rightarrow 16.16 \text{¢} \rightarrow 60.52 \frac{\text{¢}}{\text{in}}$ ^{.267} (14.049)

558

$3.00 \frac{\text{dir}}{\text{dec}} \rightarrow 65.13 \text{ sec} \rightarrow 13.63 \text{¢}$ } $4.48 \text{¢} \rightarrow 37.02 \frac{\text{¢}}{\text{in}}$ ^{.121} (17.20)
 $5.08 \frac{\text{dir}}{\text{dec}} \rightarrow 110.29 \text{ sec} \rightarrow 9.15 \text{¢}$ }

559

20 B¹⁰ Strips ; 8 Spent Plates ^{3.78}
 $18.7 \frac{\text{dir}}{\text{dec}} \rightarrow 405.99 \text{ sec} \rightarrow 2.957 \text{¢} \rightarrow 0.78 \frac{\text{¢}}{\text{in}}$ (23.48)

560

Removed Spent plates 3261 from Slot 4 and 3243 from slot 19.

6 spent plates + 16 B¹⁰ strips.

$5.48 \frac{\text{dir}}{\text{dec}} \rightarrow 118.98 \text{ sec} \rightarrow 8.61 \text{¢} \rightarrow 1.75 \frac{\text{¢}}{\text{in}}$ ^{4.91} (22.73)

561

11 B¹⁰ Strips ; 6 Spent plates

$2.33 \frac{\text{dir}}{\text{dec}} \rightarrow 50.59 \text{ sec} \rightarrow 16.26 \text{¢} \rightarrow 37.99 \frac{\text{¢}}{\text{in}}$ ^{.428} (16.246)

562

$1.9 \frac{\text{dir}}{\text{dec}} \rightarrow 41.25 \text{ sec} \rightarrow 18.61 \text{¢}$ } $7.59 \text{¢} \rightarrow 54.21 \frac{\text{¢}}{\text{in}}$ ^{.14} (14.67)

$4.00 \frac{\text{dir}}{\text{dec}} \rightarrow 86.84 \text{ sec} \rightarrow 10.02 \text{¢}$ } $56.39 \frac{\text{¢}}{\text{in}}$ ^{.33} (14.575)

$58.00 \frac{\text{¢}}{\text{in}}$ ^{.19} (14.5105)

563

3 B¹⁰ Strips ; 6 Spent plates

$2.17 \frac{\text{dir}}{\text{dec}} \rightarrow 47.44 \text{ sec} \rightarrow 17.06 \text{¢} \rightarrow 69.35 \frac{\text{¢}}{\text{in}}$ ^{.246} (12.827)

564

No B¹⁰ Strips ; 6 Spent plates

$4.44 \frac{\text{dir}}{\text{dec}} \rightarrow 96.40 \text{ sec} \rightarrow 10.17 \text{¢} \rightarrow 78.23 \frac{\text{¢}}{\text{in}}$ ^{.13} (11.765)

565

No B¹⁰ Strips ; 4 Spent plates

$1.81 \frac{\text{dir}}{\text{dec}} \rightarrow 39.30 \text{ sec} \rightarrow 19.20 \text{¢} \rightarrow 62.95 \frac{\text{¢}}{\text{in}}$ ^{.305} (13.537)

566

3 B¹⁰ Strips ; 4 Spent plates

$2.04 \frac{\text{dir}}{\text{dec}} \rightarrow 44.29 \text{ sec} \rightarrow 17.77 \text{¢} \rightarrow 50.20 \frac{\text{¢}}{\text{in}}$ ^{.354} (14.913)

567

7 B¹⁰ Strips ; 4 Spent plates

$3.82 \frac{\text{dir}}{\text{dec}} \rightarrow 82.94 \text{ sec} \rightarrow 11.41 \text{¢} \rightarrow 31.09 \frac{\text{¢}}{\text{in}}$ ^{.367} (17.392)

	Eqn.	Condition	Safety	H ₂ O	Island	Comments	
8.25	556	b > 1	11.81	26.45	8 plate	4	B ¹⁰ ship O.A.
		b > 1	11.94	"	"	"	"
19)	557	b > 1	14.18 ²	"	"	10	"
		b = 1	13.91 ⁵	"	"	"	"
20)	558	b > 1	17.13 ²	"	"	16	"
		b > 1	17.26 ^{4.0}	"	"	"	"
3)	559	b > 1	26.00	"	"	20	"
		b = 1	22.22 ^{1.26}	"	"	"	"
	560	b > 1	26.00	26.35	6 plates	15	"
3)		b = 1	21.09 ^{1.6}	"	"	"	"
	561	b > 1	16.96	"	"	11	"
16)		b = 1	16.53 ²	"	"	"	"
7)	562	b > 1	14.60	"	"	7	"
25)		b > 1	14.74	"	"	"	"
25)		b = 1	14.41	"	"	"	"
	563	b > 1	13.04 ¹	"	"	3	"
9)		b = 1	12.77 ⁵	"	"	"	"
	564	K > 1	11.83	"	"	0	"
5)		b = 1	11.70	"	"	"	"
	565	b > 1	13.69	"	4 plates	0	"
		b = 1	13.38 ⁵	"	"	"	"
	566	b > 1	15.09	"	"	3	"
		b = 1	14.73 ⁶	"	"	"	"
	567	b > 1	17.57 ⁵	"	"	7	"
		b = 1	17.20 ⁸	"	"	"	"

64

568 10 B¹⁰ Strips in OA. ; 4 Spent Plates 4.00
 18.38 $\frac{\text{dir}}{\text{sec}} \rightarrow 399.04 \text{ sec} \rightarrow 3.01 \text{¢} \rightarrow 0.75 \frac{\text{¢}}{\text{in}}$ (23.33)

570 Have removed spent plate 2870 from slot 21 and 3242 from slot 2.
 4 B¹⁰ Strips ; 2 Spent Plates 4.82
 7.25 $\frac{\text{dir}}{\text{sec}} \rightarrow 157.40 \text{ sec} \rightarrow 6.84 \text{¢} \rightarrow 1.42 \frac{\text{¢}}{\text{in}}$ (22.79)

571 2 B¹⁰ Strips ; 2 Spent Plates .669
 2.25 $\frac{\text{dir}}{\text{sec}} \rightarrow 48.85 \text{ sec} \rightarrow 16.65 \text{¢} \rightarrow 24.89 \frac{\text{¢}}{\text{in}}$ (18.075)

572 9 B¹⁰ Strips ; 2 Spent Plates .54
 1.69 $\frac{\text{dir}}{\text{sec}} \rightarrow 36.69 \text{ sec} \rightarrow 20.05 \text{¢} \rightarrow 37.13 \frac{\text{¢}}{\text{in}}$ (16.45)

573 Have moved spent plates D-3224 + D-5495 to slot 2 & 21.
 3.98 $\frac{\text{dir}}{\text{sec}} \rightarrow 86.41 \text{ sec} \rightarrow 11.06 \text{¢} \rightarrow 40.96 \frac{\text{¢}}{\text{in}}$ (16.075)

574 Have moved spent plates D-3224 & D-5495 to slots 3 & 20.
 2.26 $\frac{\text{dir}}{\text{sec}} \rightarrow 49.07 \text{ sec} \rightarrow 16.60 \text{¢} \rightarrow 39.65 \frac{\text{¢}}{\text{in}}$ (15.958)

33)

Instrument Check on 3-19-65 Source 10mc8

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip
 IC-1 $> 3 \times 10^{-11}$ Meter Trip OK Fast Trip OK
 IC-2 $> 3 \times 10^{-11}$ Meter Trip OK
 IC-3 Responds Calibration JH
 IC-4 Responds Calibration JH
 CRM Meter Trip

79)

075)

Preliminary Check on 3-19-65

Room 115 Pressure Differential 1.5"
 Red Light-On and Personnel Check S/R. + JH
 Scrums and Bldg. Alarm Reset all OK JH
 Source Inserted S/R.
 Safety Withdrawn 0
 Controls Set
 Reflector Water } Combined
 Moderator Water }

45)

075)

Expr.	Condition	Safety	H ₂ O	Island	Comments
568	$k > 1$	26.00	26.36	4 plates	10 B ¹⁰ strips in O.A.
569	$k < 1$	22.00	"	"	" " "
570	$k > 1$	26.00	"	2 plates	5 B ¹⁰ strips in O.A.
	$k = 1$	21.18	"	"	" " "
571	$k > 1$	18.409	"	"	2 " "
	$k = 1$	17.74	"	"	" " "
572	$k > 1$	16.72	"	"	Flu " "
	$k = 1$	16.18	"	"	" " "
573	$k > 1$	16.21	"	"	Flu B ¹⁰ strips
	$k = 1$	15.94	"	"	" " "
574	$k > 1$	16.16	"	"	" " "
	$k = 1$	15.75 ^{13.5}	"	"	" " "

25)

- 575 Moved plate D-3224 + D-5495 to slot 4 + 19.
 $1.98 \frac{\text{dir}}{\text{sec}} \rightarrow 42.99 \text{ sec} \rightarrow 18.12 \text{¢} \rightarrow 42.64 \text{¢/in}$ (15.818)
- 576 Moved plates D-3224 + D-5495 to slot 5 + 18.
 $1.92 \frac{\text{dir}}{\text{sec}} \rightarrow 41.68 \text{ sec} \rightarrow 18.49 \text{¢} \rightarrow 43.20 \text{¢/in}$ (15.726)
- 577 Moved plates D-3224 + D-5495 to slot 6 + 17.
 $2.5 \frac{\text{dir}}{\text{sec}} \rightarrow 54.28 \text{ sec} \rightarrow 15.49 \text{¢} \rightarrow 44.90 \text{¢/in}$ (15.633)
- 578 Moved plates D-3224 + D-5495 to slot 7 + 16
 $1.84 \frac{\text{dir}}{\text{sec}} \rightarrow 39.95 \text{ sec} \rightarrow 19.00 \text{¢} \rightarrow 43.18 \text{¢/in}$ (15.67)
- 579 Replaced all 14 spent plates in original slots.
 $2.04 \frac{\text{dir}}{\text{sec}} \rightarrow 44.29 \text{ sec} \rightarrow 17.77 \text{¢} \rightarrow 93.53 \text{¢/in}$ (7.915)
- 580 Removed spent element, took centering rod out, replaced and
 + replaced element in reactor. Side that was south is now north.
 $2.22 \frac{\text{dir}}{\text{sec}} \rightarrow 48.20 \text{ sec} \rightarrow 16.80 \text{¢} \rightarrow 92.82 \text{¢/in}$ (7.92)
- 581 Removed spent plates D-3241 + D-3246 from slots 7 + 16
 $2.53 \frac{\text{dir}}{\text{sec}} \rightarrow 54.93 \text{ sec} \rightarrow 15.37 \text{¢} \rightarrow 100.46 \text{¢/in}$ (8.634)
- 582 Placed spent plates D-3241 in slot 7, D-3246 in 16, D-3260 in 8, D-3253 in 11.
 $2.27 \frac{\text{dir}}{\text{sec}} \rightarrow 49.28 \text{ sec} \rightarrow 16.55 \text{¢} \rightarrow 94.57 \text{¢/in}$ (7.333)
- 583 3 B¹⁰ strips in O.A. ; 16 spent plates
 $2.59 \frac{\text{dir}}{\text{sec}} \rightarrow 56.23 \text{ sec} \rightarrow 15.12 \text{¢} \rightarrow 97.55 \text{¢/in}$ (8.153)
- 584 6 B¹⁰ strips in O.A. ; 16 spent plates
 $3.66 \frac{\text{dir}}{\text{sec}} \rightarrow 79.46 \text{ sec} \rightarrow 11.78 \text{¢} \rightarrow 102.43 \text{¢/in}$ (8.944)
- 585 36 B¹⁰ strips in O.A. ; 16 spent plates
 $-44 \frac{\text{dir}}{\text{sec}} \rightarrow 955.28 \text{ sec} \rightarrow -1.42 \text{¢}$

	Eggs	Condition	Safety	H ₂ O	Island	Comments
718)	575	b > 1	16.03	26.36	2 plates	Mr B ¹⁰ Strip
		b = 1	15.605 ₁₄₂	"	"	" "
726)	576	b > 1	15.94	"	"	" "
		b = 1	15.51 ²	"	"	" "
633)	577	b > 1	15.80 ⁵	"	"	" "
		b = 1	15.46	"	"	" "
77)	578	b > 1	15.89	"	"	" "
		b = 1	15.45 ₁₄₇	"	"	" "
5)	579	b > 1	8.01	"	14 plates	" "
		b = 1	7.82	"	"	" "
	580	b > 1	8.01	"	"	" "
2)		b = 1	7.82 ⁹	"	"	" "
	581	b > 1	8.71	"	12 plates	" "
34)		b = 1	8.55 ⁷ ₅₁	"	"	" "
53 & 15)	582	b > 1	7.42	"	16 plates	" "
33)		b = 1	7.24 ⁵ ₅₅	"	"	" "
	583	b > 1	8.24	"	"	3 B ¹⁰ Strip O.A.
63)		b = 1	8.08 ⁵ ₅₂	"	"	" " "
	584	b > 1	9.00 ¹ ?	"	"	6 B ¹⁰ " "
94)		b = 1	7.87 ⁶ ₃₈	"	"	" " "
	585	b ≤ 1	26.00	"	"	36 B ¹⁰ " "

Have removed CE-3 and placed CE-2 on pedestal in tank.

586 spent plates D-3224 and D-5495 in slots 7 + 16

587 added spent plate D-3242 in slot 2
and D-2870 in slot 21
4 B¹⁰ strips in O.A.

588 4 spent plates ; 3 B¹⁰ strips . 5.314
4.32 ^{hr}/sec → 93.79 sec → 10.39 φ → 1.96 φ/in (22.46)

589 6 spent plates ; 9¹⁰ B¹⁰ strips . 328
1.86 ^{hr}/sec → 40.38 sec → 18.87 φ → 57.53 φ/in (14.449)

CE-2

69

Instrument Check on 22 Mar 65 Source 10mcK

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip
 IC-1 $> 3 \times 10^{-11}$ Meter Trip OK Fast Trip OK
 IC-2 $> 3 \times 10^{-11}$ Meter Trip OK
 IC-3 Response Calibration S/R.
 IC-4 Response Calibration S/R.
 CRM Meter Trip

Preliminary Check on 3-22-65


Room 113 Pressure Differential 1.5"
 Red Light On and Personnel Check S/R. & C.C.
 Scrams and Bldg, Alarm Reset OK S/R.
 Source Inserted S/R.
 Safety Withdrawn 0.0
 Controls Set
 Reflector Water } Combined.
 Moderator Water }

Expt.	Condition	Safety	H ₂ O	Island	Comments
586	b < 1	26.00	26.07	2 Spent Plates	
587	b < 1	26.00	26.07	4 " "	4 B ¹⁰ strips O.A.
588	b > 1	26.00	26.08	4 " "	3 B ¹⁰ " "
	b = 1	20.68 ⁶	"	4 " "	" " "
589	b > 1	14.61 ³	26.08	6 " "	No B ¹⁰ strips
	b = 1	14.28 ⁵	"	4 " "	" " "

590 4 Spent Plates in Island .469
 $2.9 \frac{\text{dir}}{\text{dec}} \rightarrow 52.11 \text{ sec} \rightarrow 15.93 \phi \rightarrow 33.97 \frac{\phi}{\text{in}}$ (17.096)

591 4 Spent Plates ; 3 B¹⁰ Strips in O.A. 1.69
 $6.17 \frac{\text{dir}}{\text{dec}} \rightarrow 133.96 \text{ sec} \rightarrow 7.82 \phi \rightarrow 4.63 \frac{\phi}{\text{in}}$ (21.40)

592 Have moved Spent element off center ~ $\frac{5}{16}$ "
 Had to raise it $\frac{1}{4}$ " by placing a $\frac{1}{4}$ " Plexiglas spacer
 under it.

2 B¹⁰ Strips  ↑ off center
 $3.1 \frac{\text{dir}}{\text{dec}} \rightarrow 67.30 \text{ sec} \rightarrow 13.31 \phi \rightarrow 13.05 \frac{\phi}{\text{in}}$ (19.85)

593 Spent element same as 592. 4 B¹⁰ Strips .37
 $3.64 \frac{\text{dir}}{\text{dec}} \rightarrow 79.03 \rightarrow 11.83 \phi \rightarrow 31.97 \frac{\phi}{\text{in}}$ (17.32)

594 Replaced Spent element in center of Island but with
 $\frac{1}{4}$ " Plexiglas spacer on bottom. .471
 $2.43 \frac{\text{dir}}{\text{dec}} \rightarrow 52.76 \text{ sec} \rightarrow 15.80 \phi \rightarrow 33.55$ (17.784)

595 Same as 594 ; 2 B¹⁰ Strips in O.A. 1.43
 $1.64 \frac{\text{dir}}{\text{dec}} \rightarrow 35.61 \text{ sec} \rightarrow 20.43 \phi \rightarrow 14.29 \frac{\phi}{\text{in}}$ (19.63)

Instrument Check on 3-26-65 Source 10 m c Y

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip _____
 IC-1 $>3 \times 10^{-4}$ Meter Trip OK Fast Trip OK
 IC-2 $>3 \times 10^{-4}$ Meter Trip OK
 IC-3 Responds Calibration S.F.R.
 IC-4 Responds Calibration S.F.R.
 CRM Meter Trip _____

Preliminary Check on 3-26-65

Room 113 Pressure Differential 1.5"
 Red Light On and Personnel Check S.F.R. C.C.
 Scrums and Bldg. Alarm Reset S.F.R. OK
 Source Inserted S.F.R.
 Safety Withdrawn 0.0
 Controls Set 0
 Reflector Water } combined.
 Moderator Water }

Expt.	Condition	Safety	H ₂ O	Island	Comment.
590	b > 1	17.33	25.98	4 spent plates	
	b = 1	16.86 ¹	"	"	
591	b > 1	22.50	"	"	3 B ¹⁰ strips in O.A.
	b = 1	20.81 ⁸⁷	"	"	" " "
592	b > 1	20.36	26.00	"	2 B ¹⁰ strips in O.A.
	b = 1	19.34	"	"	" " "
593	b > 1	17.51	"	"	No B ¹⁰ strips
	b = 1	17.14 ¹	"	"	" "
594	b > 1	17.42	"	"	" "
	b = 1	16.949 ²	"	"	" "
595	b > 1	20.365 ⁵	"	"	2 B ¹⁰ strips in O.A.
	b = 1	18.935 ⁷⁰	"	"	" " "

7-27-65

1st production core (ORNL) - Reactivity measurement in
 West assembly area. Outer Element is described in Dwg. D42126 Rev. A
 and Inner Element D-42118 Rev. ~~B~~^F 1/14/65 ~~29~~

Mass of Inner H.F.I.R. fuel element = 7.611 ~~gm~~^{Kg} 0235
 Mass of Outer H.F.I.R. fuel element = 6.816 ~~gm~~^{Kg} 0235
 Total 9.427 Kg 0235

{ 1-6-65 SS net = 10.119 Kg inner +
 outer core, RKAJ.

7-27-65

73

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter ✓	1"	✓	10×10^{-12}
"	"	Fast ✓	"	✓	"
K-2	"	Meter ✓	2"	✓	"
"	"	Fast ✓	"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	14"	✓	500V
PM-2	1200V	Low ✓	14"	✓	900V
"	"	Alarm ✓	1"	✓	"
LOG N CALIBRATE		✓	OPERATE	✓	SOURCE No. B-80
DUMP WELL FORCE LIGHT		X			

C
A

Cover support, standard 13.375" dia. by 1/2" Lu
 Element (to top of side plate) 2.25" Lu

H.F.I.R. : Inner and outer fuel elements only:

START-UP CHECK LIST

Equipment checked by PKM Personnel check by F.D.C.
 Instruments and safeties checked and reset by PKM
 Source in checked by PKM Source No. M-93
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1-2 PM-2
 Red light on by PKM Time 1005
 Start-up OK'd by J.T.T., F.D.C., PKM Date 7-27-65

When H₂O at top of table, scale reads 0.0 cm.
 Fuel rate = 5.75 cm/min. } Fuel rate reset at 3.80 cm/min
 Dump rate = 7.40 cm/min. } 1230.

1100

Water ht = 124.95 cm.
 System sub critical. Drain! over!

74

7-27-65

1230 added spent fuel element in ^{center of} inner cone: spent element has 2 fuel plates. (mass of 2 fuel plate = 28.1 gm U²³⁵).

1344 Water ht = 117.90 cm. System very sub critical.
Drain: Log $\eta = .005$.

1402 added two more spent fuel plates to element. (mass of 2 fuel plate = 27.8 gm U²³⁵). Total mass of spent fuel now = 55.9 gm U²³⁵.

1438 Water ht = 107.00 cm. System sub critical.
Drain: Log $\eta = .012$.

1454 added two more spent fuel plates to element. (mass of 2 fuel plate = 28.3 gm U²³⁵). Total mass of spent fuel now = 84.2 gm U²³⁵. Total mass of 2 HFIR elements + spent elements = 9.5112 Kg U²³⁵.

1527 ⁽¹⁾ + Low Water ht = 96.00 cm. $\Delta h = .55$ cm
 $t = 144.5 \mu s = 7.4 \%$ = 13.32 %/cm.

1535 Water ht = 95.45 cm. System just critical.
Drain: "2.1 in. above top of fuel plate."

7-28-65

INSTRUMENT CHECK

75

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter ✓	1"	✓	1000^{-12}
"	"	Fast ✓	"	✓	"
K-2	"	Meter	1"	✓	"
"	"	Fast	"	✓	"
P-1					
P-2					
PM-1	700 V	Alarm ✓	Contact	✓	500V
PM-2	1200 V	Low ✓	14"	✓	200V
"	"	Alarm ✓	1"	✓	"
LOG N CALIBRATE <input checked="" type="checkbox"/>			OPERATE <input checked="" type="checkbox"/>		SOURCE No. <u>B-80</u>
DUMP WELL PROBE LIGHT <input checked="" type="checkbox"/>					

START-UP CHECK LIST

Equipment checked by AKM JTF Personnel check by AKM
 Instruments and safeties checked and reset by AKM
 Source in checked by AKM JTF Source No. M-43
 Emergency equipment in control room checked by AKM
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by JTF Time 0750
 Start-up OK'd by JTF AKM Date 7-28-65

added 4.031" x $\frac{5}{8}$ " x 29" Natural Poron Stainless
 steel strip. 0.92 weight per unit length. (Horn)

over:

76

7-28-64

Water ht = 107.00 cm. kept slightly sub critical.
 - Per: $\tau = 136.9 \text{ sec} = 14.1 \text{ f}$

0900 Remove two of the .031" x $\frac{5}{8}$ " x 29" Natural Boron strips
 and added 10 .031" x $\frac{5}{8}$ " x 29" stainless steel strips.

0920 Water ht = 104.70 cm: kept slightly sub critical
 - Per: $\tau = 367.23 \text{ sec} = 4.0 \text{ f}$

0925 adder H₂O to ~ 111.0 cm no change in - Per:

0928 Drain to ~ 75.0 cm.

0943 Removed three .031" x $\frac{5}{8}$ " x 29" stainless steel strips.

(1)
 + Per: Water ht = 106.20 cm. Critical to water ht
 $\tau = 962.64 \text{ sec} = 1.3 \text{ f}$
 $\Delta h = 2.50 \text{ cm}$
 Water Temp = 29.5°C (Measured with $^{\circ}\text{C}$ thermometer)

1001 Drain: ~ 0.0 cm.

110.1 Water ht = 103.65 cm: kept just critical.
 Drain.

12.15 Removed remaining (natural Boron & stainless steel strip).
 Now have inner & outer cores, + spent fuel element
 with 6 fuel plates. Moved the BF₃ chamber as
 close as possible to into core. (BF₃ chamber supplied
 by P.M. Fry I & C Div.)

(2)
 1259 + Per: Water ht = 105.45 cm $\Delta h = 4.9$
 $\tau = 239.03 \text{ sec} = 4.8 \text{ f}$

1311 Water ht = 100.55 cm: System just critical; Log $\eta = 61$
 Drain to ~ 69.5 cm. +

(3)
 1346 + Per; Water ht = 105.00 cm:
 $T = 251.84 \text{ m} \Rightarrow P = 4.564$

1427 Water ht = 100.80 cm. System very very slightly + R.
 Log $\eta = 3.5$ Start of power run for D.M. Foy's
 BF₃ chamber. BF₃ chamber with 374 g ²³⁵U

1431 Water ht = 100.70 cm. System very very slightly - R.
 Log $\eta = 3.5$ PM-2 = 17 at 760 volts

1502 Water ht = 100.70 cm: System just critical. Log = 3.5
 PM-2 = 17 at 760 volts.

1505 Drain:

1510 Drain H₂O to ~ 79 cm: Core reading ~ 6.0" away
 from fuel = 440 MR/HR. at ~ center of outer
 core at contact ~ 1 R/H.

Drain:

78

7-29-65

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3 x 10 ⁻¹²	Meter ✓	1"	✓	10 x 10 ⁻¹²
"	"	Fast ✓	"	✓	"
K-2	"	Meter ✓	2"	✓	"
"	"	Fast ✓	"	✓	"
R-1					
R-2					
PM-1	700V ✓	Alarm ✓	cont	✓	500V
PM-2	1200V ✓	Low ✓	19"	✓	900V
"	"	Alarm ✓	1"	✓	"
LOG N CALIBRATE _____			OPERATE _____	SOURCE No. B-80	
DUMP WELL PROBE LIGHT _____					

START-UP CHECK LIST

Equipment checked by AKM Personnel check by FIDC
 Instruments and safeties checked and reset by AKM
 Source in checked by AKM Source No. M-43
 Emergency equipment in control room checked by FIDC
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by AKM Time 0800
 Start-up OK'd by FIDC AKM Date 7-29-65

0750 Outer coil reading at center of core = 18 ^{M/R} / _{HR.}

SPERT element with 4 no. 1-2-3 still in. Critical at 100.72
 with D₂O element (no. 5-1-8) installed. 5-2-8 77
 Enriched Boron Stainless
 Steel (Type 304) Strips .031" x 5/8" x 29"
 which is equal to #2.10 (equal spaced in outer
 element.)
 - 8-2-13 29 1/2

0920 Water ht = 100.70 cm: system sub critical. Log N = .012

added same # M-227 with M-43. Log N = .075
 K-1 = 57.5% 10×10^{-11} . PM-2 = 1.5 - 900V. For 20 min
 run P.M. Fry.

1023 Remained bath same: For run for P.M. Fry.

1248 added 8^{to outer element.} .031" x 5/8" x 29" stainless steel strip.
 = to ~ 10.7 f. also same M-43 & M-227.
 For run for P.M. Fry. Total position added = ~ 2.20.
 Water ht = 100.70 cm: Temp = 24.5°C
 Log N = .075. K-1 = 54.5% 10×10^{-11} . PM-2 = 1.5 - 900V
 - 8-2-4 29 1/2

1420 added two more Enriched Boron Stainless Steel (Type
 304) strips .031 x 5/8" x 29". and 5 Natural Boron
 stainless steel (.031 x 5/8" x 29") strip to outer
 element. Water ht still 100.70 cm. Total
 position now = 3.41. Run for P.M. Fry.
 Log N = .05 K-1 = 32.5 - 10×10^{-11} PM-2 = 1.0 - 900V.
 - 8-2-4 29 1/2

over

80

7-29-65

1454 Drain H_2O to $\approx 75.0\%$. Removed all strips added, except 4 Enriched Boron Stainless Steel (which are equal divided in outer coil: ~~four~~ ~~pieces~~ now in core #405.
-91766

1520 Water ht = 100.70 cm. Same M-93, M-227 in same pos. with condition as above. Run for D. N. Fry:
Log $n = 0.115$ $K-1 = \frac{387}{3 \times 10^{-4}}$ PM-2 = 3-9000

1600 Drain:

NB: Since (core + 6 SPERT plates + BF₃ chamber) was critical flooded, the amount of poison installed represents the subcriticality of the flooded core.

7-30-65

INSTRUMENT CHECK

10
ins

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter -	1"	-	10×10^{-12}
"	"	Fast -	"	-	"
K-2	"	Meter -	2"	-	"
"	"	Fast -	"	-	"
R-1					
R-2					
PM-1	700V	Alarm -	Cont.	-	500V
PM-2	1200V	Low -	1 1/2"	-	900V
"	"	Alarm -	1"	-	"

LOG 'N CALIBRATE OPERATE SOURCE No. B-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by AKM Personnel check by FID.C

Instruments and safeties checked and reset by AKM

Source in checked by AKM Source No. M-43

Emergency equipment in control room checked by FID.C

Instruments in trip circuit: K-1-2 PM-1-2

Red light on by AKM Time 0855

Start-up OK'd by FID.C AKM Date 7-30-65

Removed spent fuel element + the 4 enriched boron stainless steel strip. Added the ^{aluminum} styrofoam void to inner fuel element. diameter of styrofoam = 4.1875" ^{+ 26.250" long.} Also removed D.M. Fry's instrument and set.

over:

82
636
7-30-65

1011 Water ht = 106.00 cm. System sub critical.
Drain.

1100 Remove inner cone: Put in optimum styrofoam
void in outer cone: Styrofoam is 10.500" O.D. x
25.4375" long.

1217 Water ht = 106.00^{cm}, System sub critical. $F_g N = .0055$
Drain:

1300 Reduced the O.D. of styrofoam to 10.125."

1334 Water ht = 106.30 cm, System sub critical. $F_g N = .0059$
Drain:

1425 Now have inner fuel element as close as
possible ($9/16"$) to outer fuel element. Fuel
plates ^{match} to within ~~1/8"~~ $1/8"$. Both elements
have styrofoam voids. Outer element void = 10.125"
Inner element void = 4.1875"

1500 Water ht = 107.60 cm. System sub critical. $F_g N = .0055$
Drain.

Production Core #2
(made by M&C) (M&C #1)
INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3 x 10 ⁻¹²	Meter ✓	1"	✓	3 x 10 ⁻¹²
"	"	Foot ✓	"	✓	"
K-2	"	Meter ✓	1"	✓	"
"	"	Foot ✓	"	✓	"
R-1					
R-2					
PM-1	700v	Alarm ✓	cont	✓	500v
PM-2	1200v	Low ✓	12"	✓	900v
"	"	Alarm ✓	1"	✓	900v
LOG N CALIBRATE ✓			OPERATE ✓	SOURCE No. B-80	
DUMP WELL PROBE LIGHT					

START-UP CHECK LIST

Equipment checked by AKH Personnel check by I.D.C.

Instruments and safeties checked and reset by AKH

Source in checked by AKH Source No. M-43

Emergency equipment in control room checked by I.D.C.

Instruments in trip circuit: K-1-2 PM-1-2

Red light on by AKH Time 1500

Start-up OK'd by I.D.C. AKH Date 1-6-65

Now have outer & inner H.F.I.R. Core assembly.

over

When water ht = 21.05 cm on glass scale, we have 6.5" top reflection.

Feed rate = 2.9 cm/min
 3/4" Drain rate = 8.3 cm/min
 3" Drain rate = 3.8 cm/min

When water ht = 9.20 cm on glass scale, water ht is at ^{top} of fuel elements. (Top of plates)

→ An eighth-in. screw was placed in the outer annulus to support the inner annulus at its correct height. This

was necessary because we are supporting only the ^{OUTER annulus at the bottom.}
 1545 Water ht = 21.05 cm

Hyton sub critical.

Log $k = .003$

This element is the second production core and the first made by Metals & Controls. It contains 9.40268 kg of ²³⁵U, of which 2.55628 kg is in the inner annulus and 6.80640 kg is in the outer annulus. The inner annulus contains also 2.805 g ¹⁰B. These numbers from telecon w. R. McCord who quoted inspection certification reports from M&C; they do not agree with the transfer weights because of an error made by M&C in the 101 form. 5/9/66

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Master ✓	1"	✓	3×10^{-12}
	"	Fast ✓	"	✓	"
K-2	"	Master ✓	1"	✓	"
	"	Fast ✓	"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	Cont	✓	500V
PM-2	1200V	Low ✓	12"	✓	900V
	"	Alarm ✓	2"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. B-80
 DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by AKM Personnel check by F.I.C.

Instruments and safeties checked and reset by AKM

Source in checked by AKM Source No. M-93

Emergency equipment in control room checked by F.I.C.

Instruments in trip circuit: K-1-2 PM-1-2

Red-light on by AKM Time 12:15

Start-up OK'd by F.I.C. AKM Date 1-7-66

added spent fuel element in center of cores.
 spent element has 4 fuel plates, #5 0-3224,
 5-5495, 0-3242, 0-2870. for more in row
 = 55.97 0235

over.

- 1255 Water ht = 6.30 cm $\Delta h = .20$ cm
 (1) + Per.
 $T = 390.05 \text{ sec} = 3.14 = 15.5 \text{ f/cm.}$
- 1304 Water ht = 6.10 cm
 System just critical
 Drain.
- 1330 added 2 (.031" x .625" x 29.0" enriched boron #5122
 stainless steel strips) in outer element. = 53,32¢
- 1415 Water ht = 9.20 cm $\Delta h = .80$ cm
 (2) + Per.
 $T = 191.22 \text{ sec} = 5.84 = 7.3 \text{ f/cm.}$
- 1425 Water ht = 8.40 cm
 System just critical
 Drain.
- 1436 added 2 (.031" x .625" x 29.0" Natural Boron strips) in #324
 outer element. = 27,50¢
- 1506 Water ht = 10.60 cm $\Delta h = .35$ cm }
 (3) + Per
 $T = 126.03 \text{ sec} = 4.24 = 23.4 \text{ f/cm.}$
 see page 49
- 1520 Water ht = 10.25 cm
 System just critical

1521 Drain H₂O below center of core.

1525 Removed the two (2) natural boron strips and added two (2) 0.031" x 0.625" x 29.0" enriched boron strip^{#8+10} = 53.32 f; now have 4 enriched strips.

$$d_h = 0.60 \text{ cm.}$$

1540 (4) Water ht = 12.30 cm

+ Per:

$$C = 182.53 \text{ sec} = 6.10 \text{ f} = 9.9 \text{ f/cm.}$$

1548 Water ht = 11.70 cm

system just critical

1608 Water ht = 13.10 cm

$$d_h = 1.4 \text{ cm}$$

(5) + Per:

$$C = 81.49 \text{ sec} = 11.6 \text{ f} = 9.3 \text{ f/cm}$$

1613 Water ht = 11.70 cm

system just critical
Drain:

24

~~1613~~

1-10-66

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1 (3)	10^{-12}	Meter ✓	1"	—	3×10^{-12}
"	"	Fast ✓	"	—	"
K-2	"	Meter ✓	1"	—	"
"	"	Fast ✓	"	—	"
R-1					
R-2					
PM-1	700V	Alarm ✓	cont	✓	500V
PM-2	1200V	Low ✓	12"	✓	900V
"	"	Alarm ✓	1"	✓	"
LOG N. CALIBRATE —			OPERATE —	SOURCE No. B-80	
DUMP WELL PROBE LIGHT —					

START-UP CHECK LIST

Equipment checked by AKM Personnel check by FID.C
 Instruments and safeties checked and reset by AKM
 Source in checked by AKM Source No. M-23
 Emergency equipment in control room checked by FID.C
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by AKM Time 0405
 Start-up OK'd by FID.C AKM Date 1-10-66

#344
 added two (2) natural boron strips! Now
 have four (4) enriched strips and two (2)
 natural strips! Total of six (6). Total
 worth = 134.14 f

1-10-60

0839 (1) $\Delta h = 3.05 \text{ cm}$
 Water ht = 21.05 cm
 + Per.
 $\tau = 597.58 \text{ cm} = 2.14 = .694/\text{cm}$

0900 Water ht = 18.00 cm
 hepten just critical
 Drain.

0950 Removed two (2) enriched boron strips.
 Now have ^{two} (2) natural and two (2)
 enriched boron strips. Purpose is to
 repeat + Per #3 and critical ht on
 page 46.

1015 $\Delta h = .50 \text{ cm}$
~~0915~~ (2) Water ht = 11.30 cm
 + Per.
 $\tau = 151.02 \text{ cm} = 7.1 \text{ f} = 14.2 \text{ f/cm}$

1023
~~0923~~ Water ht = 10.80 cm
 hepten just critical
 Draister 0.0 cm in order to repeat
 critical ht.

1032 (3) $\Delta h = .80 \text{ cm}$
 Water ht = 11.60 cm
 + Per
 $\tau = 89.09 \text{ cm} = 10.8 \text{ f} = 13.5 \text{ f/cm}$
 Water ht = 10.80 cm
 hepten just critical.
 Water Temp
 = 23.3°C

90

1-10-66

- 1255 Removed spent fuel elements and reworked and enriched boron strips: installed the 4.18 x 26.0" optimum styrofoam void in lower element. Top of void is .750" above top of fuel plates.
void = (~69%)
- 1324 Water ht = 7.10 cm: $\Delta h = .50$ cm Water Temp = 29.0°C
+ Per:
 $E = 156.45 \text{ me} = 6.94 = 13.84$ cm.
- 1330 Water ht = 6.60 cm
System just critical
Drain.
- 1430 Removed the 4.18" x 26.0" styrofoam: and replaced it with the 2.875" x 24.0" ^{13/16"} void styrofoam ~~void~~ void. (~31.5% void). Top of styrofoam is even with top of fuel plates.
- 1512 Water ht = 17.20 cm
System just critical.
Drain.

1-11-66

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter ✓	1"	—	3×10^{-12}
	"	Fast ✓	"	—	"
K-2	"	Meter ✓	1"	—	"
	"	Fast ✓	"	—	"
R-1					
R-2					
PM-1	700V	Alarm —	Cent	—	500V
PM-2	1200V	Low ✓	10"	—	900V
	"	Alarm ✓	2"	—	"
LOG N CALIBRATE		✓	OPERATE	—	SOURCE No. B-80
DUMP WELL PROBE LIGHT					

START-UP CHECK LIST

Equipment checked by AKH Personnel check by F.D.C.Instruments and safeties checked and reset by AKHSource in checked by AKH Source No. M-43Emergency equipment in control room checked by F.D.C.Instruments in trip circuit: K-1-2 PM-1-2Red light on by AKH Time 0819Start-up OK'd by F.D.C. AKH Date 1-11-66

Purpose to repeat experiment with the 2.875" x 29.0" styrofoam void, (see bottom of page 90). The void now is centered with a .50" x .50" plexiglass disk at top of void.

over:

92

1-11-66

0911 (1) Water ht = 21.10 cm $\Delta h = 3.30$ cm
+ Per.
 $\tau = 478.00 \text{ cm} = 2.54 = .76 \text{ f/cm}$

Water Temp.
Recorder:
#3 = 25.5°C
#4 = 11



0937 Water ht = 17.80 cm
system just critical
Drain.

Temp measured
with thermometer
= 24.0°C

importance of .60 cm in critical ht (page 91)

Installed the 3,250" x 24,437" styrofoam void.
= 41% void.

1033 (2) Water ht = 10.90 cm $\Delta h = .65$ cm
+ Per.
 $\tau = 112.26 \text{ cm} = 9.0 \text{ f} = 13.9 \text{ f/cm}$

1043 Water ht = 10.25 cm
system just critical
Drain.

Water Temp.
= 24.0°C

1050 added 2 enriched boron strips #1 & 2 = 53.32 f

(3) Water ht = 16.00 cm $\Delta h = 1.85$ cm
+ Per.
 $\tau = 165.80 \text{ cm} = 6.6 \text{ f} = 3.6 \text{ f/cm}$

Water Temp.
= 24.0°C

1118. Water ht = 14.15 cm
system just critical
Drain.

1-11-60

1225 Removed enriched boron strip #^s 1 & 2, and replaced them with enriched boron strip #^s 8 & 10. in same position in outer core:

1249 Water ht = 16.00 cm $D_4 = 1.8 \text{ cm}$
 4 + Per
 $E = 172.75 \text{ sec} = 6.3 \text{ f} = 3.5 \text{ f/cm}$

1300 Water ht = 14.20 cm Water temp.
 hepten just critical = 24.0°C
 Drain.

added natural boron strip #3. Now have 2 enriched and 1 natural boron strip. Total worth = 67.10 f

1330 5 Water ht = 21.00 cm. hepten very slightly - neg.
 - Per.
 $E = -1412.45 \text{ sec} = -1.09 \text{ f}$

1345 Increased H₂O to 22.00 cm. No change in reactivity.
 Drain.

94

1-22-66

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter ✓	cont	✓	3×10^{-12}
"	"	Fast ✓	"	✓	"
K-2	"	Meter ✓	$1/2$ "	✓	"
"	"	Fast ✓	"	✓	"
P-1					
P-2					
PM-1	700V	Alarm ✓	cont	✓	500V
PM-2	1200V	Low ✓	10"	✓	900V
		Alarm ✓	2"	✓	"
LOG IN CALIBRATE		✓	OPERATE	✓	SOURCE No. <u>B-80</u>
DUMP WELL PROBE LIGHT					

START-UP CHECK LIST

Equipment checked by RKL Personnel check by F.D.C.Instruments and safeties checked and reset by RKLSource in checked by RKL Source No. M-93Emergency equipment in control room checked by F.D.C.Instruments in trip circuits K-1-2 PM-1-2Red light on by RKL Time 0915Start-up OK'd by F.D.C. RKL Date 1-12-66

7-12-66

Now have the 9.18 x 24.5" styrofoam void, plus
 2 natural boron strips, and 4 enriched boron
 strips. (all strips in outer element)
 void = 400.00¢. strips = 134.00¢

0950 Water ht = 12.55 cm $D_h = .65$
 (1) + Per
 $\tau = 136.90 \text{ m} = 7.7 \text{ f} = 11.8 \text{ f/cm}$.

Water Temp.
 29.0°C

1000 Water ht = 11.90 cm
 system just critical
 Drain.

1005 added 2 more enriched strips. Now have
 6 enriched ^{strips} and 2 natural boron strips
 void = 400.00¢. strips = 187.52¢

1030 Water ht = 21.10 cm. system sub critical
 (2) - per:
 $\tau = -137.73 \text{ m} = -14.5 \text{ f}$

Water Temp.
 = 29.0°C

1043 Remained 1 enriched boron strip, and added 1 natural
 boron strip. Now have 5 enriched boron strips
 and 3 natural strips.
 void = 400.00¢. strips = 174.64¢

over.

1-
1104 (3) Water ht = 21.10 cm: system slightly subcritical
- Per:

$$\beta = -484.58 \text{ sec} = -2.9 \text{ f}$$

Water Temp
= 24.2°C

1225. Now have spent fuel element in. With 2 fuel plates. # D-3224, & D-5495. all poison strip removed. Top of spent fuel plates even with top of core fuel plates.
Spent plate (2) = 240.00¢ ~~per~~

1300 Water ht = 21.10 cm: system subcritical.

(4) - Per

$$\beta = -173.84 \text{ sec} = -9.9 \text{ f}$$

Water Temp

1330 Now have 6 fuel plates in spent element, # D-3224, D-5495, D-3242, D-2870, D-3228, and D-3252. also have 8 enriched boron strips and 2 natural boron strips.

$$\text{Spent plate} = 515.00 \text{¢} \quad \text{Strip} = 240.84 \text{¢}$$

1403 (5) Water ht = 12.00 cm $D_h = .70 \text{ cm}$

+ Per

$$\beta = 145.59 \text{ sec} = 7.3 \text{ f} = 10.4 \text{ f/am}$$

1414 Water ht = 11.30 cm
 System just critical;
 Drain.

Water Temp
 = 29.2

added 1 enriched boron strip and 1 natural
 boron strip. Now have 9 enriched, and 3
 natural boron strip.
 spent plate = 515.00 \$ Strip = 281.25 \$

1450 (6) Water ht = 21.10 cm. System sub critical
 - Per

$t = -275.97 \text{ sec} = -5.5 \text{ } \phi$
 sub critical = 239.22 \$

Water Temp
 = 29.0

1508 Now have 4 fuel plates in spent element. #D-3224
 D-5495, D-3242, and D-2870. Also have 4 enriched
 boron strip and 2 natural boron strip. Repeat of
 exp on pages 88 and top of 89.)
 Spent plate = 391.00 \$ Strip = 134.12 \$

1539 Water ht = 21.10 cm $\Delta h = 5.9 \text{ cm}$

(1) + Per.
 $t = 162.24 \text{ sec} = 6.7 \text{ } \phi = 1.1 \text{ } \phi/\text{cm}$

1550 Water ht = 15.20 cm
 System just critical.
 Drain.

Water Temp
 = 29.0

diff in critical ht (page 88 + 89)
 = 3.08 \$

15.00
 15.20
 25.00

98

1-13-66

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3 K10 ⁻¹²	Master ✓	1/2"	✓	3 K10 ⁻¹²
"	"	Fast ✓	"	-	"
K-2	"	Master ✓	"	✓	"
"	"	Fast ✓	"	-	"
R-1					
R-2					
PM-1	700V	Alarm ✓	cont	✓	500V
PM-2	1200V	Low ✓	10"	✓	900V
"	"	Alarm ✓	2"	✓	1"
LOG N. CALIBRATE		✓	OPERATE	✓	SOURCE No. <u>B-80</u>
DUMP WELL PROBE LIGHT					

START-UP CHECK LIST

Equipment checked by AKW Personnel check by I.P.C.Instruments and safeties checked and reset by AKWSource in checked by AKW Source No. M-43Emergency equipment in control room checked by I.P.C.Instruments in trip circuit: K-1-2 PM-1-2Red light on by AKW Time 0810Start-up OK'd by I.P.C. AKW Date 1-13-66

Purpose is to repeat info described on bottom of page 97.

1-13-66

0845 Water ht = 21.19 cm. $\Delta h = 5.90$ cm
 (+ Per) Water Temp. = 24.0°C
 $\tau = 167.32 \text{ sec} = 6.54 = 1.11 \text{ f/cm}$

0856 Water ht = ^{15.20} ~~15.20~~
 System just critical
 Drain.

0915 Removed the .125" pleiglass spacer^{or skin} from inner cone. Inner cone now .125" below outer cone. Other condition same as above. 4 fuel plates, 4 enriched strip, and 2 natural strips.

0932 Water ht = 21.30 cm. $- .125"$
 System very sub critical. > 6.54
 Drain.

0938 Installed .250" pleiglass spacer^{or skin} in inner cone. Other conditions the same as above.

0954 (2) Water ht = 17.40 cm $\Delta h = 2.30$ 7.54 sec/cm
 (+ Per) Water Temp. = 24.0°C
 $\tau = 244.68 \text{ sec} = 4.74 = 2.04 \text{ f/cm}$

1010 Water ht = 15.10 cm
 System just critical
 Drain.

over

100

1-13-66

1025 Installed .500" plepiglass spacer or skin in inner core. other condition the same. $+ .375''$

1046 (3) Water ht = 22.90 cm. $\Delta L = 6.60$ cm

+ Per
 $\tau = 178.19 \text{ cm} = 6.24 = .93 \text{ /cm}$

Water Temp
= 29.0°C

1157 Water ht = 15.80 cm
System just critical.
Drain.

1118 Installed 1.00" plepiglass spacer or skin in inner core. also removed 1 natural boron strip. other conditions the same. $+ .875''$

1134 (4) Water ht = 14.90 cm $\Delta L = 1.15$ cm

+ Per
 $\tau = 201.35 \text{ cm} = 5.54 = 4.78 \text{ /cm}$

Water Temp
= 29.0°C

1147 Water ht = 13.75 cm
System just critical
Drain.

1235 Installed 1.50" plepiglass spacer or skin in inner core. conditions same as above. (4 fuel plates, 9 enriched boron strips and 1 natural boron strip.)

$+ 1.375''$

1-13-66

1305 Water ht = 19.40 cm

Dh = 2.50 cm

(5) + Per

$$C = 145.59 \text{ cm} = 7.3 \text{ f}$$

Water Temp.

29.0°C

1315 Water ht = 15.90 cm

System just critical

Drain.

Installed 1.75" pleiglass spacer or skin in inner
 core. Conditions same as above.

+ 1.625"

1352 Water ht = 29.60 cm

Dh = 7.30 cm.

(6) + Per

$$C = 176.01 \text{ cm} = 6.2 \text{ f}$$

1403 Water ht = ^{17.30} 17.40 cm

System just critical

Drain.

Water Temp.

24.2°C

1430 "Removed" the 1.75" pleiglass spacer or skin in
 inner core. In new core now 1.25" below
 outer core. Have 4 fuel plates, 4 enriched
 boron strip and 1 natural strip. - 1.25"

1515 (7) Water ht = 21.10 cm

Dh = 5.20 cm.

(7) + Per

$$C = 134.73 \text{ cm} = 7.8 \text{ f}$$

over.

102

1-13-66

1530

~~1530~~ Water ht = 15.90 cm

Temp = 24.2°C

System just critical
Orari.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE UP
K-1	3x10 ⁻¹²	Meter -	1/2"	✓	3x10 ⁻¹²
"	"	Fst ✓	"	-	"
K-2	"	Meter ✓	"	✓	"
"	"	Fst ✓	"	✓	"
R-1					
R-2					
SM-1	700V	Alarm ✓	cont	-	500V
SM-2	1200V	Low ✓	10"	✓	900V
"	"	Alarm ✓	2"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. B-80

DUMP WELL PROBE LIGHT

1-14-66

~~START-UP CHECK LIST~~

Equipment checked by _____ Personnel check by _____
 Instruments and safeties checked and reset by _____
 Source in checked by _____ Source No. _____
 Emergency equipment in control room checked by _____
 Instruments in trip circuit _____
 Red light on by _____ Time _____
 Start-up OK'd by _____ Date _____

START-UP CHECK LIST

Equipment checked by AKH Personnel check by F.D.C.
 Instruments and safeties checked and reset by AKH
 Source in checked by AKH Source No. M-93
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by AKH Time 0805
 Start-up OK'd by F.D.C. AKH Date 1-14-66

Removed spent fuel element and the 4 fuel plates. Purpose is to see if any air is trapped between inner & outer core.

Water ht = 21.50 cm
 System sub-critical.

Raised the inner core and did not find any sufficient amounts of air trapped between cores.

104

1-14-66

Now have inner cone raised ^{with ploughed skins} 2.0" above outer
cone. Also raised the front fuel element
1.875" (limit.) System has: 4 fuel plates, 4
enriched boron strips, and 1 natural boron
strip.

1010 Water ht = 24.90 cm
System just critical
Orain.

Water Temp
= 24.2°C

1-14-66

H.F.I.R. CE-2
West End.

1320 Now have CE-2 installed in test tank,
same conditions as with production cone
2

When water ht = 8.85 cm on glass scale outer
cone plates are just covered, and when water ht
= 9.12 cm inner cone plates are just covered.

1345 Water ht = 22.00 cm: CE-2 Flooded.
System sub critical

1500 Now have 3.25" ^{26.75"} Styrofoam void in place
1 natural boron strip. The void ^{extends} 1.18"
above top of fuel plates.

1550 Water ht = 21.0 cm

+ Pen

$$C = 543.25 \text{ sec} = 2.3 \text{ f}$$

Water Temp.

$$= 29.5^\circ \text{C}$$

1603 Water ht = 16.60 cm
System just critical
Down.

1/17/66

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter ✓	1/2"	✓	3×10^{-12}
"	"	Foot ✓	"	✓	"
K-2	"	Meter ✓	1"	✓	"
"	"	Foot ✓	"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	Contact	✓	500V
PM-2	1200V	Low ✓	10"	✓	900V
"	"	Alarm ✓	2"	✓	"
LOG N CALIBRATE		✓	OPERATE	✓	SOURCE No. B-80
DUMP WELL PROBE LIGHT _____					

START-UP CHECK LIST

Equipment checked by AKH Personnel check by AKH
 Instruments and safeties checked and reset by E.B.V.
 Source in checked by AKH Source No. M-93
 Emergency equipment in control room checked by AKH
 Instruments in trip circuit: K-1-2 PM-1-2
 Red-light on by AKH Time 0830
 Start-up OK'd by E.B.V. AKH Date 1-17-66

0830 Now have spent fuel element in. with fuel plates # D-3229, D-5995, D-3292, & D-2870. The spent fuel plates are .125" below H.F.L.R. fuel plates. Also have 3 enriched boron strip in.

0907 (1) Water ht = 12.20 cm ^{D.H. = 0.75}
 + Per. $\tau = 166.45 \text{ sec} = 6.5 \phi = 6.7 \text{ H/cm.}$

0918 Water ht = 11.45 cm
 System just critical

0923 added 1 more enriched boron strip. Now have 4 spent plates, and 4 enriched strips.

0944 (2) Water ht = 21.05 cm; System sub critical
 - Per. $\tau = -225.99 \text{ sec} = -7.0 \phi$

1004 Removed 1 enriched boron strip, and replaced it with 1 natural boron strip. Now have 3 enriched + 1 natural strip; + 4 spent fuel plates.

1031 (3) Water ht = 21.05 cm ^{D.H. = 6.35}
 + Per. $\tau = 321.60 \text{ sec} = 3.7 \phi$

over.

1049 Water ht = 14.70 cm
 System just critical.
 Drain:

$$Plates = 3.91$$

$$Strips = 3(26.44) + 13.78 = 93.76 \text{ g}$$

$$Excess = 3.7 \text{ g}$$

$$Conv = 3.91 + 0.04 + 0.94 = 2.93 \pm 17\% \approx 9.164$$

3-14-66

3-14-66
M+C "No 2"

Outer Element # 2-0 S.S. Net = 7305.01 0235
68.06.08

Inner Element # 3-1 S.S. Net = 2787.18 0255
25.96.81
 + 2.805 g¹⁰ in inner element. T = 9,402.89 g⁰²³⁵

The inner cone ^{fuel plates} is 1.25" below the outer cone fuel plates.

Feed rate = 2.7 cm/min
 3/4" drain rate = 4.80 cm/30 sec
 30" " " = 38.1 cm/15 sec.

3-14-66

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Motor ✓	2"	✓	3×10^{-12}
	"	Fast ✓	"	✓	"
K-2	"	Motor ✓	"	✓	"
	"	Fast ✓	"	✓	"
R-1					
R-2					
PM-1	700v	Alarm ✓	Cont	✓	500v
PM-2	1200v	Low ✓	14"	✓	900v
	"	Alarm ✓	3"	✓	"
LOG N CALIBRATE		—	OPERATE	—	SOURCE No. B-80
DUMP WELL PROBE LIGHT					

START-UP CHECK LIST

Equipment checked by AKK Personnel check by E.I.D.C

Instruments and safeties checked and reset by AKK

Source in checked by AKK Source No. M-43

Emergency equipment in control room checked by E.I.D.C

Instruments in trip circuit: K-1-2 PM-1-2

Red light on by AKK Time 1023

Start-up OK'd by E.I.D.C AKK Date 3-14-66

1030 9.2 cm on glass scale water ht even with top of plate ^(center core)
 Now have Ducter + burner H.F.I.R. Core assembly.

1120 Water ht = 21.50 cm.
 System sub critical.

Water Temp.
 #1 = 23.0°
 2 = 23.5°
 av.

3-14-66

1355 Added spent fuel element in center of core.
 Element has 4 fuel plates: #S D-3224, D-5495,
 D-3242 and D-2870. Mass increase = 55.9 g⁰²³⁵
 Top of spent fuel plates, one even with top of outer
 element fuel plates.

1426 Water ht = ?

(1) + Per

Drain to re-run + Per:

1438 (2) Water ht = 4.50 cm $d_h = .10$ cm

+ Per

$$\tau = 415.04 \text{ sec} = 2.9 \text{ \textcircled{d}}$$

Water Temp.

1445 Water ht = 4.40 cm

#1 = 23.5 °C

System just critical
 Drain.

2 = 24.0 °C

1515 added 4 enriched boron strips #s 7, 8, 9, & 10, and
 2 natural boron strips #s 3 & 4. Worths = 134.29 \textcircled{d}
 all strips one piece ~ equal distance in
 outer core.

1537 (3) Water ht = 10.10 cm $d_h = .130$ cm.

+ Per

$$\tau = 212.95 \text{ sec} = 5.3 \text{ \textcircled{d}} = 17.7 \text{ \textcircled{d}/cm.}$$

Water Temp. °C

#1 = 23.7

2 = 24.0

3-14-66

111

1.548 Water ht = 9.80 cm

System just critical.

Drain

$$Corr = 58.5 \text{ K} \times 0.0001 + 134.20 \text{ K} (5 \text{ steps}) \times 0.0001 + 156.30 \text{ K} \pm 18.4$$

3-15-66

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Motor —	2"	✓	3×10^{-12}
"	"	Flt ✓	"	✓	"
K-2	"	Motor ✓	"	—	"
"	"	Flt ✓	"	—	"
R-1					
R-2					
PM-1	700V	Alarm ✓	Cont	✓	500V
PM-2	1200V	Low ✓	14"	✓	900V
"	"	Alarm ✓	3"	✓	"

LOG-N CALIBRATE OPERATE SOURCE No. B-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by AKV Personnel check by F.D.C

Instruments and safeties checked and reset by AKV

Source in checked by AKV Source No. M-43

Emergency equipment in control room checked by F.D.C

Instruments in trip circuit: K-1-2 PM-1-2

Red light on by AKV Time 0800

Start-up OK'd by F.D.C AKV Date 3-15-66

over.

112

3-15-66

Purpose is to repeat last experiment.

0841 Water ht = 10.30 cm.
(1) + P₂
L = 160.80 cm = 6.74

Water Temp: °C
#1 = 24.0
#2 = 24.2

0851 Water ht = 9.90 cm
System just critical
Drain.

0900 added two more enriched boron strips #5 & 5.
Now have 6 enriched boron strips #5 4, 5, 7, 8, 9 & 10.
and 2 natural boron strips #5 3 & 4. Total of 8
strips. Total weight = ~187.52 g

0933 Water ht = 18.35 cm
System just critical.
Drain.

0945 added .125" plastic spacers to raise inner core
even with outer core. Other conditions the same as
above.

1008 Water ht = 21.20 cm.
(2) + Per
C = 673.63 cm = 1.8 f

Water Temp, °C
#1 = 24.2
2 = 24.3

1030 Water ht = 18.25 cm
System just critical
Drain.

Water Temp
#1 = 24.2
2 = 24.5

391.00 f - 187.52 f - 1.8 f = 19.49
= 201.68 f sub critical (4 fuel plates in target region)

1105 Removed fuel plates #5 D-3242, & D-2870 from spent fuel element. Also removed 4 enriched boron strips, #5 4, 5, 8, & 10. #5 7 & 9

Now have 2 enriched boron strips, and 2 natural boron strips, and fuel plates #5 D-3224, & D-5495.

1125 Water ht = 21.40 cm
System sub critical
Drain.

Water Temp, °C
#1 = 24.5
2 = 24.7

1230 Removed 1 enriched boron strip, and 1 natural boron strip. Now have two fuel plates, and 1 enriched strip, and 1 natural strip. Strip #3 = 40.00 f

Water ht = 21.40 cm
System slightly - Neg.

Temp °C
1 = 24.3
2 = 24.5

(3) - Per
T = -543.3 cm = -2.6 f

aver.

24226-4044
1202.12 f = 28

Remained enriched boron strip #9, and added natural boron strip #4 in its place. Also added 6 stainless steel strip.

Now have 2 spent fuel plate, 2 natural boron strips #5 3 & 4, and 6 stainless steel strips. Total worth of strip = 35.60¢

1348 Water ht = 21.40 cm
 + Res
 $5 = 6052 \text{ sec} = 1.2 \text{ f}$

1405 Water ht = 18.90 cm

System just critical

Down is.

$$240.00 \text{ f} - 35.60 \text{ f} - 1.2 \text{ f}$$

$$= 203.20 \text{ f} \text{ sub critical (2 fuel v 1 - res in + neg v region)}$$

Water Temp. °C

#1 = 24.3

2 = 24.5

Average: $(200.20 \pm 8.5) + (202.16 \pm 8) + (201.6 \pm 15.4) = 202.55 \pm 12.6$

Reflection water sample taken after run.

Req # 68 + 496.

ask for.

1. Total solids

2. Spec.

001490
 - BO 5 END
 65

Pol
 SPL

REPORT TO RK Peeler
 BUILDING NO. 92173
 PHONE NO. 3-5237


SPECTROGRAPHIC REPORT

MATERIAL / PE Thermal DATE 3-21-66 BATCH NUMBER Refined Salt PLATE SHEET NO. 07368 REQUISITION NO. 684-196

TYPE SPECS		REPORTING BASIS							
<input type="checkbox"/> N.C.	<input checked="" type="checkbox"/> ppm as received	<input type="checkbox"/> ppm metal basis	<input type="checkbox"/> ppm as received	<input type="checkbox"/> ppm metal basis	<input type="checkbox"/> ppm as received	<input type="checkbox"/> ppm metal basis	<input type="checkbox"/> other	<input type="checkbox"/> other	<input type="checkbox"/> other
<input checked="" type="checkbox"/> PYRO	<input type="checkbox"/> ppm - U ₂ O ₇ basis	<input type="checkbox"/> other	<input type="checkbox"/> other	<input type="checkbox"/> other	<input type="checkbox"/> other	<input type="checkbox"/> other	<input type="checkbox"/> other	<input type="checkbox"/> other	<input type="checkbox"/> other
1	Ag	Al	3	B	0.05	Ba	< 20		
	Ba	Ca	< 1	Cd	< 0.1	Co	< 1		
	Cr	Cu	< 1	Fe	< 1	K	< 6		
2	Li	Mg	< 20	Mn	< 1	Nb	1		
	Ni	P	< 10	Pb	< 1	Sr	1		
	Sn	T	< 4	V	< 1				
3	As	Au	< 1	Bi	< 1	Cs	< 10	Hg	
	Ga	Ge	< 0.4	Hf	< 10	In	< 20	Re	
		Nb	< 4	Pd	< 1	Rb	< 20	Ta	
4	Sb	Sr	< 20	Tl		Tl	< 4	U	
	W	Zn	< 1	Zr	< 20				
5	C	Mo	4			O			
	C/G	Mo							

000000012	g U/g
	g Ay/g
	g D/g
	g H/g
	g No/g
	g P/g
	SPEC.
	ASSAY

29 ppm total solid

	REPT. BY
3-24-66	DATE
	DEPT.

7

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE RANGE	SET	START-UP RANGE
K-1	3 X 10 ⁻¹²	Alarm ✓	1"	✓	3 X 10 ⁻¹²
"	"	Alarm ✓	"	✓	"
K-2	"	Alarm ✓	"	✓	"
"	"	Alarm ✓	"	✓	"
R-1					
R-2					
PM-1	700 ✓	Alarm ✓	Cont	✓	500 ✓
PM-2	1200 ✓	Low ✓	10"	✓	900 ✓
"	"	Alarm ✓	2"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. 13-50

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by AKH Personnel check by F.D.C

Instruments and safeties checked and reset by AKH

Source in checked by AKH Source No. M-43

Emergency equipment in control room checked by F.D.C

Instruments in trip circuit: K-1-2 PM-1-2

Red light on by AKH 1410

Start-up OK'd by F.D.C AKH date 5-26-66

over!

116

Fuel rate = 2.90 cm/min "water ht on mirror scale"
 3/4" drain rate = 10.11 cm/min " " = 8.85 cm outer element
 3" dump rate = 38.0 cm/min " " = 9.10 cm inner element
 covered

5-26-66 Repeat of critical conditions with C.F. - 2
 Cone. (See pages 105, 106, 107, 108.)

Now have C.F. - 2 cone in reflector tank: inner
 and outer cone only.

1456 Water ht = 20.9 cm
 System sub critical

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE	SET	START-UP RANGE
K-1	3×10^{-12}	Motor ✓	1"	✓	3×10^{-12}
"	"	Fast ✓	"	✓	"
K-2	"	METER ✓	"	✓	"
"	"	Fast ✓	"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	cont	✓	500V
PM-2	1200V	Low ✓	18"	✓	900V
"	"	Alarm ✓	3"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. B-80 A

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by AKH Personnel check by E.D.C.Instruments and safeties checked and reset by AKHSource in checked by AKH Source No. M-43Emergency equipment in control room checked by E.D.C.Instruments in trip circuit: X-1-2 PM-1-2Red light on by AKH Time 0805Start-up OK'd by E.D.C. AKH Date 5-27-66

Now have spent fuel element installed:

4 fuel plates. #^s D-3229, D-5495, D-3242, D-2870. also have three (3) enriched boron strip #^s 10, 8, 4. and one natural strip # 2.

0855 Water ht = 21.00 cm $0.4 = 5.70$ cm Water Temp °C
 # 1 = 23.5
 # 2 = 23.7
 + Per.
 $C = 495.44 \text{ cm} = 2.44 = .4 \text{ 1/cm}$

0917 Water ht = 15.30 cm
 System just critical
 Drain.

$C_{214} = 290.74$

Productions Cones: # 3-0 # 2-1

1025 Now have production cones # 3-0 (outer element) and # 2-1 (inner element) assemble. Inner element fuel plate .125" below top of outer element fuel plate.

over:

When water ht = 9.25 cm on mirror scale: Water even with top of fuel plates in outer element.

10.55 Water ht = 21.10 cm $\rho_{\text{eff}} = 1.0009$ Temp °C
 System sub critical with source in. #1 = 23.7
 #2 = 24.0

1230 added spent fuel element with 2 fuel plates #5 0-5495 and 0-3224. Also added 2 natural boron strips #5 3 & 4, plus 6 stainless steel strips.

2 fuel plates = 240.0¢
 poison strips = 35.6¢

1345 Water ht = 21.10 cm $\rho_{\text{eff}} = 1.0011$ Water Temp °C
 System sub critical #1 = 24.2
 Drain. #2 = 24.2

1350 Removed the 2 natural boron strips #5 3 & 4. Now have 2 fuel plate plus 6 stainless steel strips.

2 fuel plates = 240.0¢
 poison strips = 8.04¢

1427 Water ht = 21.00 cm $\rho_{\text{eff}} = 1.0012$ Temp °C
 System sub critical #1 = 24.2
 Drain. #2 = 24.3

1450 added 2 more fuel plates:

Now have 4 fuel plates in best element.

Plus 4 enriched boron strips #s 7, 8, 9, & 10.

4 fuel plates = 391.00¢

4 boron strips = 106.50¢

1515 Water ht = 21.00 cm. $\Delta h = 7.2$ cm

+ Pres

$\bar{v} = 52.15 \text{ cm} = 15.9 \text{ } \mu = 2.2 \text{ } \mu/\text{cm}$,

Temp °

#1 = 29.5

#2 = 29.5

1524 Water ht = 13.80 cm.

lytens just critical

Drain

DUMP WELL PROBE LIGHT

LOG N-CALIBRATE

OPERATE

SOURCE No.

Alarm

PM-2

Alarm

PM-1

PM-2

PM-1

Alarm

K-2

Master

Alarm

K-1

Master

INSTRUMENT

RANGE

TRIP

SOURCE

SET

STARTUP

INSTRUMENT CHECK

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter ✓	5"	✓	3×10^{-12}
	"	Fast ✓	"	✓	"
K-2	"	Meter ✓	"	✓	"
	"	Fast ✓	"	✓	"
R-1					
R-2					
PM-1	200V	Alarm ✓	Cont	✓	500V
PM-2	1200V	Low ✓	18"	✓	900V
	"	Alarm ✓	3"	✓	"
LOG-N-CALIBRATE		✓	OPERATE	✓	SOURCE No. B-80
DUMP WELL PROBE LIGHT _____					

START-UP CHECK LIST

Equipment checked by JAL Personnel check by DC

Instruments and safeties checked and reset by DC

Source in checked by JAL Source No. M-43

Emergency equipment in control room checked by DC

Instruments in trip circuit: K-1-2 PM-1-2

Red light on by JDC Time 0820

Start-up OK'd by JDC DC Date 5/31/66

Log M blew a fuse. Bad rectifier tube. Replaced.

Repeat of last run of 5/27/66

0924 H₂O at 8.40 cm, T period #7 sh = .90 cm Temp #1: 24.2°C

0935 H₂O at 7.50 cm. Level. #2: 24.3°C

Dustin

$$E = 135.81 = 7.74$$

7/31/66

1037 H₂O at 8.40 cm. + period #2
 $\epsilon = 144.50 \text{ m} = 7.3 \text{ \#}$

#1: 24.5°C

#2: 24.5°C

1049 H₂O at 7.60 cm. Level.

Drain

Added #1 + 2 enriched boron, 2 natural boron.

Now have 6 enriched boron and 1 natural boron.

+ 4 SPERT plates. Fuel = 390g, strips = 173.7g

$$\epsilon = 164.06 \text{ m} = 6.6 \text{ \#}$$

1047 H₂O at 12.70 cm, + period #3

#1: 24.5°C

#2: 24.5°C

1153 H₂O at 11.8 cm, Level.

Drain Core = $-390 + 173.7 + 29.5 = -186.8 \text{ \#}$

Add #3 enriched boron strip. Now have 7 enriched strips and 1 natural strip. Strips = 200.5g, fuel = 390g
 but 189.5g

1055 H₂O at 21.7 cm. Slightly subcritical

Put source back in to increase power level.

1413 Removed source for neg. period #4

#1: 24.5

Drain - $\text{Pow} = -671.46 \text{ neg} = -2.1 \text{ \#}$ #2: 24.7

Core + fuel + poison = K_{eff}

$$\text{Core} + 391 - 200.5 = -2.1$$

$$\text{Core} = 200.5 - 2.1 - 391 = -192.6 \text{ \#}$$

Removed 2 plates from SPERT element. Now have 2 fuel plates, enriched strip #7, natural strip #3, and 4 stainless strips. Total 45.80g in poison, 240g in fuel

1522 H₂O at 21.5 cm. Subcritical.

Drain

5/31/66

Removed enriched strip #3, Now have 1 enriched
and 4 stainless stages.

1553

Head at 21.5 cm, identical
Drain.

#1: 25.0

#2: 25.0

Removed all strips. Now have only 2 fuel plates.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Motor ✓	1"	✓	3×10^{-12}
	"	Fast ✓	"	✓	"
K-2	"	Motor ✓	"	✓	"
	"	Fast ✓	"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	cont	✓	500V
PM-2	1200V	Low ✓	18"	✓	900V
	"	Alarm ✓	3"	✓	"
LOG N CALIBRATE		✓	OPERATE	✓	SOURCE No. 0.80
DUMP WELL PROBE LIGHT _____					

vertical
5.28
24.5
-4.7
fuel

6-1-66

START-UP CHECK LIST

Equipment checked by AKM Personnel check by F.D.C.
 Instruments and safeties checked and reset by AKM
 Source in checked by AKM Source No. M-93
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by AKM Time 0820
 Start-up OK'd by F.D.C. AKM Date 6-1-66

0820 all poison strips removed; Have 2 fuel plate in spent element, #s D-3224 and D-5495.
 plates = 240.0 f

0911 Water ht = 11.60 cm. $\Delta h = 1.2$ cm Temp °C
 + Per: #1 = 24.5
 $\tau = 58.67 \text{ sec} = 14.7 \text{ f}$ #2 = 24.7

0921 Water ht = $\frac{10.35}{+10.40}$ cm = avg = 10.375
 System just critical
 Poison

0945 added .125" plastic spacers to raise inner core even with outer core; other conditions same as above;

1050 Water ht = 10.80 cm $\Delta h = .475$ Water Temp $^{\circ}$
 $^2 + \text{Per.}$ $\frac{16.0}{C} = 139.07 = 7.64 = 15.96 \text{ f/cm}$ #1 = 24.7
 2 = 25.0

1101 Water ht = $\frac{-10.30 \text{ avg} = 10.325}{+10.35}$
 System just critical.

1105 Drain to ~ 0.0 cm on narrow scale;
 to repeat + Per.

1112 Water ht = 11.30 cm $\Delta h = .195$ cm Water Temp $^{\circ}$
 $^3 + \text{Per.}$ #1 = 24.7
 $\frac{16.0}{C} = 67.36 \text{ sec} = 13.34 = 13.96 \text{ f/cm}$ #2 = 25.0

1120 Water ht = $\frac{-10.30 \text{ avg} = 10.325}{10.35}$
 System just critical
 Drain

1340 Now have 2 spent fuel plates; 4 stainless
 steel strips and 1 natural boron strip #2.
 plates = 240.0 f (Core raised, 12.5").
 poison strip = 19.14 f

1410 Water ht = 12.25 cm $\Delta h = .55$ cm Temp $^{\circ}$
 $^4 + \text{Per}$ #1 = 24.7
 $\frac{16.0}{C} = 264.02 \text{ sec} = 4.44 = 8.04 \text{ f/cm}$ 2 = 25.0

aver.

1428 Water ht = 11.70 cm. Fuel = 240, steps = 19.1
 System just critical $Corr = -240 \times 19.1 + 30.9 = -190.0 \neq$
 Drain.

1500- Removed kept element. Flooded core to
 check for air; could not find any air bubbles
 on core fuel plate. Raised inner core up, and
 found some small air bubbles. Drain water.
 Removed .125" spacers and flooded core again.
 When inner core was raised, had a large
 release of air bubbles.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter <input checked="" type="checkbox"/>	1"	<input checked="" type="checkbox"/>	3×10^{-12}
"	"	Fast <input checked="" type="checkbox"/>	"	<input checked="" type="checkbox"/>	"
K-2	"	Meter <input checked="" type="checkbox"/>	"	<input checked="" type="checkbox"/>	"
"	"	Fast <input checked="" type="checkbox"/>	"	<input checked="" type="checkbox"/>	"
R-1					
R-2					
PM-1	700V	Alarm <input checked="" type="checkbox"/>	Cent	<input checked="" type="checkbox"/>	500V
PM-2	1200V	Low <input checked="" type="checkbox"/>	12"	<input checked="" type="checkbox"/>	900V
"	"	Alarm <input checked="" type="checkbox"/>	2"	<input checked="" type="checkbox"/>	"

LOG N CALIBRATE OPERATE SOURCE No. B-80
 DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by AKL Personnel check by F.D.C.

Instruments and safeties checked and reset by AKL

Source in checked by AKL Source No. M-93

Emergency equipment in control room checked by F.D.C.

Instruments in trip circuit: K-1-2 P.M-1-2

Red light on by AKL Time 0808

Start-up OK'd by F.D.C. AKL Date 6-2-66

0800 Have inner cone raised .125" with plastic spacers.
Also have 2 spent fuel plates #5 D-3229 and
D-5495. With 4 stainless steel strips plus
internal boron strip #2. (see bottom of page 125)

0840 Water ht = 13.00 cm $\Delta h = .30$ cm Water temp °C
(1) + Per. #1 = 29.5
 $\bar{v} = 706.23$ cm = 1.6 ϕ = 5.3 ϕ /cm #2 = 29.7

0925 Water ht = 12.70 cm
System just critical
Drain - 1/2 way down ~~stop~~ with 3" dump valve.

0945 Water ht = 12.90 cm $\Delta h = 1.10$ cm Water temp °C
(2) + Per. #1 = 29.5
 $\bar{v} = 123.86$ cm = 8.3 ϕ = 7.5 ϕ /cm #2 = 29.7

0955 Water ht = 11.80 cm
System just critical
Drain.

In order to vent air trapped between
outer and inner core.

10.30 Now have inner core raised .375". ^{Top of} Inner core
fuel plate now .250" above top of outer core
fuel plate. Top of inner core fuel plate also
.250" above top of spent fuel plate.
Same fuel and poison loading as described
on page 127.
Fuel = 240.0 g,
poison = 19.14 g.

11.18 Water ht = 13.10 cm $\Delta h = 1.02$ Water Temp °C
(3) + Per #1 = 24.5
 $C = 132.55 \text{ mm} = 7.9 \text{ f} = 7.7 \text{ f/cm}$ #2 = 24.7

11.30 Water ht = 12.05 cm $+12.10 \text{ cm} = 12.075$
System just critical
Drain.

12.30 Repeat of above.

12.55 Water ht = 13.10 cm $\Delta h = 1.05$ Water Temp °C
4 + Per #1 = 24.7
 $C = 135.81 \text{ mm} = 7.9 \text{ f} = 7.5 \text{ f/cm}$ #2 = 25.0

13.05 Water ht = 12.00 $+12.10$
System just critical
Drain.

1330 added natural boron strips #3. Now have spent fuel element with 2 fuel plates #SD-3224 and D-5495. Two (2) natural boron strips #^s 2 and 3. and 4 stainless steel strips.

$$\text{Fuel} = 240.0 \text{ g}$$

$$\text{poison strips} = 32.92 \text{ g}$$

1400 Water ht = 18.70 cm $\Delta h = 4.70 \text{ cm}$ Water Temp $^{\circ}\text{C}$

(5) + Per

$$C = 99.96 \text{ sec} = 9.9 \text{ f} = 2.14 \text{ f/cm}$$

$$\#1 = 24.7$$

$$+ 14.10 \text{ cm} = 14.00 \text{ cm}$$

$$\#2 = 25.0$$

1410 Water ht = 13.90 cm

System just critical

Drain to $\sim 0.0 \text{ cm}$ on manometer scale: repeat + Per.

1420 Water ht = 21.20 cm $\Delta h = 7.20 \text{ cm}$ Water Temp $^{\circ}\text{C}$

(6) + Per

$$C = 83.66 \text{ sec} = 11.3 \text{ f} = 1.56 \text{ f/cm}$$

$$\#1 = 25.0$$

$$\#2 = 25.1$$

1427 Water ht = 14.00 cm

System just critical.

Drain.

$$\therefore \text{Core} + \text{fuel} + \text{strips} = K_{\text{eff}}$$

$$\text{Core} = K_{\text{eff}} - \text{fuel} - \text{strips}$$

$$= 11.3 - 240 + 32.9 = -195.8 \text{ g}$$

Now have 4 fuel plates in spent element, # D-3228,
D-5495, D-3242 and D-2870. Also have 4
enriched boron strips, #s 7, 8, 9, & 10. weekly spaced
in outer fuel element.

pieces = 391.604
mass = 100.674

1.515 Water ht = 8.70 cm. $D_h = .90$ cm. Water Temp °C
(7) + Per #1 = 25.0
 $T = 97.19 = 10.7 = 12.6$ f/cm $T = 25.2$

1.530 Water ht = -7.80 = $+7.80$
System just critical.
Drain to ~ 0.0 cm on narrow scale; repeat
+ Per.

1.338 Water ht = 8.60 cm $D_h = .80$ cm. Water Temp °C
(8) + Per #1 = 25.0
 $T = 97.19 = 10.7 = 12.6$ f/cm $T = 25.2$

1.545 Water ht = 7.80 cm ✓
System just critical
Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3 x 10 ⁻¹²	Master	1"	-	3 x 10 ⁻¹²
	"	Fast	"	-	"
K-2	"	Master	"	-	"
	"	Fast	"	-	"
R-1					
R-2					
PM-1	700 V ✓ 500 V	Alarm	Cont	-	500 V
PM-2	1200 V	Low	18"	-	900 V
	"	Alarm	3"	-	"
LOG N CALIBRATE		✓	OPERATE	✓	SOURCE No. B-80
DUMP WELL PROBE LIGHT _____					

START-UP CHECK LIST

Equipment checked by AKH Personnel check by F.D.C.

Instruments and safeties checked and reset by AKH.

Source in checked by AKH Source No. M-43

Emergency equipment in control room checked by F.D.C.

Instruments in trip circuit: 1A-1-2 PM-1-2

Red light on by AKH Time 0815

Start-up OK'd by F.D.C. AKH Date 6-3-66

Same conditions as described on top of page 130.

4 fuel plate in spent element #5 D-3224, D-5495,
D-3242 and D-2370. 4 enriched boron strips #5
7, 8, 9, & 10.

over 5

132

6-3-66

fuel = 391.00¢
is - Per = 103.64¢

0935 Water ht = 8.60 cm, $D_{25} = .80$ cm Water Temp °C
① + Per #1 = 24.7
 $E = 157.5 \text{ m} = 0.85 = 0.59 \text{ m}$ #2 = 24.7

0947 Water ht = 7.80 cm
system just critical
Drain.

1000 Now have 4 fuel plates in spent element, plus
7 Enriched boron strips #s 1, 2, 3, 7, 8, 9 & 10, plus
natural boron strip # 2. Total of 4 fuel plates
plus 8 strips.
Fuel = 391.00¢
is - Per = 200.00¢
Fuel - strips - -K = -K
 $391.00 - 200.00 + 1.6 = 192.6 \text{¢} \pm 15.2 \text{¢}$

1038 Water ht = 21.10 cm Water Temp °C
② - Per #1 = 24.5
 $E = -\$40.95 \text{ water} = -1.6 \text{¢}$ #2 = 25.0

1048 added water; ht = 23.90 cm, no change
is - Per.
Drain.

1100 Remained natural boron strips # 2. Added 5 stainless steel strips.

Now have:

4 fuel plates.

7 enriched strips (1, 2, 3, 7, 8, 9 & 10.)

5 stainless steel strips.

fuel = 391.00¢

poison = 193.32¢

$$391.0 - 193.32 - 3.9 = 193.78 \pm 15.2¢$$

1130 Water ht = 21.10 cm $\Delta h = 4.80$ cm. Water Temp $^{\circ}$ C

(3) + Rev

$$T_1 = 25.0$$

$$T = 297.70 \text{ rev} = 3.9¢ = .81¢/\text{cm}$$

$$T_2 = 25.0$$

1146 Water ht = 16.30 cm

keeters just critical
Downis.

1240 Now have:

2 fuel plates (D-3224 & D-5492.)

2 natural boron strips # 2 & 3

4 stainless steel strips.

See page 129.

Fuel = 240.00¢

poison = 32.92¢

$$11.4 - 240.0 + 32.9 = 195.6¢ \pm 7.8¢$$

1315 Water ht = 21.10 cm $\Delta h = 7.1$ cm Water Temp $^{\circ}$ C

(4) + Rev

$$T_1 = 25.0$$

$$T = 83.23 \text{ rev} = 11.4¢ = .62¢/\text{cm. avr.}$$

$$T_2 = 25.2$$

1322 Water ht = 14.00 cm.
System just critical
Drain.

Outer core # 3-0 Inner core # 4-1

Now have inner core 4-1 in place of 2-1.
Outer core # 3-0. No plastic spacers or
poison strips.

1420 Water ht = 22.00 cm.
System sub critical.

1423 ~~Water~~ Raised inner core and found a large release of
air bubbles. Could also ~~hear~~ see air ~~escaping~~
as if under pressure from at the ~~escaping~~
joint. ^{before refueling inner core.} System still sub critical.
Drain.

1445 Now have: inner core raised .375"
2 fuel plate (# D-3224 + D-5494)
2 natural boron strips (# 2 + 3)
4 stainless steel strips.
Fuel = 220.00 g
poison = 32.92 g

1520 (5) Water ht = 16.80 cm $\Delta h = 3.10$ cm
+ Res Water Temp °C
1 = 25.2
2 = 25.5
 $\epsilon = 114.08 \text{ sec} = 8.94 = 2.9 \text{ g/cm}$

15.30 Water ht = 13.70 cm.

System just critical
Drain.

Core = 13.3 + 0.5 - 24.3 = -19.3. P.P. ± 9.5g

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter ✓	4"	✓	3×10^{-12}
	"	Fast ✓	"	✓	"
K-2	"	Meter ✓	5"	✓	"
	"	Fast ✓	"	✓	"
R-1					
R-2					
PM-1	900V ✓	Alarm ✓	cont.	✓	500V
PM-2	1200V ✓	Low ✓	12"	✓	900V
		Alarm ✓	2	✓	"
LOG N CALIBRATE ✓			OPERATE ✓	SOURCE No. B-80	
DUMP WELL PROBE LIGHT _____					

START-UP CHECK LIST

Equipment checked by D.C. Personnel check by D.C.

Instruments and safeties checked and reset by D.C.

Source in checked by D.C. Source No. M-43

Emergency equipment in control room checked by D.C.

Instruments in trip circuit: K1-2 PM1-2

Red light on by D.C. Time 0810

Start-up OK'd by D.C. D.C. Date 6/6/66

Repeat of last experiment 6/3/66 (OVER)

136

4/6/66

0906 H₂O at 16.70 cm. + period #1 #1: 24.2°C.
 T = 176.4 sec = 6.2 F #2: 24.2°C

0920 H₂O at 14.30 cm. Critical and level.
 Drain part way back to bottom of manometer. ↑

0942 H₂O at 17.1 cm. + period #2 #1: 24.2°C
 T = 157.5 sec = 6.4 F #2: 24.2°C

0954 H₂O at 14.30 cm. Level.
 Drain
 Core = 240 + 32.9 + 10 = 197.1 F ± 8.5 F

Removed 3-D and 4-F, replaced with 4-D and 4-F.
 Led ^{SPERT} element on various strips. Flux monitor spaced 0.375 in.

1225 H₂O at 21.2 cm. Subcritical.

Installed SPERT element with 2 fuel plates,
 #2 + 3 Natural D strips and 4 SS strips.
 Fuel = 240 F, Poisson = 32.9 F

1305 Apparently critical at low neutron #1: 24.5°C
 level. Put source back in to raise #2: 24.5°C
 power. H₂O at 21.20 cm.

1320 Removed source.

1325 H₂O at 17.1 cm. Level
 Core = -240 + 32.9 + 3.2 = -203.9 F ± 8.5 F

4/6/66

Removed 4 SS strips. Now have 2 SPERT plates
and 2 natural boron strips.

Fuel = 240, Poisson = 27.56 μ

1404

H₂O at 21.2 cm. + Period #3

#1: 24.5 °C

T = 129.2 mm = 9.2 μ

#2: 25.0 °C

1410

H₂O at 14.6 cm. Level.

Drain Core = -240 + 27.6 + 9.2 = -203.2 μ

Added 2 plates in SPERT element, have included
B¹⁰ strips 2, 3, 7, 8, 9, 10 (total 6) and natural strip #3.

Fuel = 391, Poisson = 173.74

1515

H₂O at 15.0 cm. + Period #4

#1: 25.0 °C

T = 126.4 mm = 8.2 μ

#2: 25.0 °C

1525

H₂O at 12.95 cm. Level

Drain

Core = -391 + 173.7 + 19.0 = -198.3 μ ± 18.7 μ

4/7/66

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE	SET	START-UP RANGE
K-1	3 x 10 ⁻¹²	Meter ✓ Fast ✓	4"	✓	3 x 10 ⁻¹²
K-2	3 x 10 ⁻¹²	Meter ✓ Fast ✓	4"	✓	3 x 10 ⁻¹²
P-1	—	—	—	—	—
P-2	—	—	—	—	—
PM-1	700V	Alarm ✓	Contact	✓	500V
PM-2	1200V	Low ✓ Alarm ✓	14" 3"	✓	900V
LOG N CALIBRATE		✓	OPERATE	✓	SOURCE No. B-80
DUMP WELL PROBE LIGHT —					

START-UP CHECK LIST

Equipment checked by EJ, IDC Personnel check by IDC
 Instruments and safeties checked and reset by EJ
 Source in checked by IDC Source No. M-40
 Emergency equipment in control room checked by IDC
 Instruments in trip circuit: K-1, K-2, PM-1, PM-2
 Red light on by DC Time 1210
 Start-up OK'd by DC, IDC Date 4/7/66

Installed 5-I in 4-D with 0.375 in. spacer
 1240 H₂O at 22.9 cm. Subcritical.

6/7/66

Added SPERT element with 2 fuel plates and #2 + #3 natural boron strips and 4 SS strips.

Fuel = 240g, Poison = 32.92g

K-2 noisy. Replaced HV batteries. Temporary improvement but still noisy. Out of Trip.

1330

H₂D at 21.25 cm. Source back in to raise power.

#1: 24.5°C

#2: 24.7°C

1341

Source amt. by period #1

$T = 1719 \text{ sec} = 0.76 \%$

$\text{Core} = 240 - 32.9 + 0.76 = 207.9 \text{ g} \pm 8.5 \text{ g}$

Removed 4 SS strips. Now have 2 fuel plates and 2 natural boron strips. Poison = 27.56g

1414

H₂D at 21.20 cm. + Period #2

$T = 215.7 \text{ sec} = 5.2 \%$

$\text{Core} = 240 - 27.56 - 5.2 = 207.2 \text{ g} \pm 9.4 \text{ g}$

#1: 24.7°C

#2: 25.0°C

1422

H₂D at 15.95 cm. Critical.

Drain

Installed 5-I and 5-O with 0.375-in spacers.

1450

H₂D at 21.20. Identical

Drain

Added 2 fuel plates and #2 + #3 natural boron strips. Poison = 27.56g

4/8/66

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter ✓	3"	✓	3×10^{-12}
"	"	Fast ✓	"	✓	"
K-2	3×10^{-12}	Meter ✓	3"	✓	3×10^{-12}
"	"	Fast ✓	"	✓	"
R-1	—				
R-2	—				
PM-1	700V	Alarm ✓		✓	500V
PM-2	1200V	Low ✓	12"	✓	900V
		Alarm ✓	1"	✓	
LOG N CALIBRATE		✓	OPERATE	✓	SOURCE No. B-80
DUMP WELL PROBE LIGHT		✓			

START-UP CHECK LIST

Equipment checked by EJIK Personnel checked by IDC
 Instruments and safeties checked and reset by EQ
 Source in checked by EQ Source No. M-43
 Emergency equipment in control room checked by IDC
 Instruments in trip circuit: K-1, K-2, PM-1, PM-2
 Red light on by QBE Time 0815
 Start-up OK'd by EQ, IDC Date 6/8/66
 Condition as of end of p. 135.

0900 H₂O at 21.25 cm. + Period #1
 T = 15.4 + 27.56 + 6.7 = 205.74 ± 84
 #1, 24.5
 #2, 24.5

0910 H₂O at 15.25 cm. Critical.
 Drain.
 C_{ov} = -240 + 27.56 + 6.7 = -205.74 ± 84

9/8/66

Added 2 fuel plates and enriched strips #2, 3, 7, 8, 9, 11, and #3 natural strip. Now have 4 fuel plates, 6 enriched strips and 1 natural strip.
 Changed amplifier on K-2. Working. Out of trip

1305

H₂O at 15.65 am. + period #2
 T = 144.9 sec 7.3%

#1: 24.7°C
 #2: 25.0°C

1316

H₂O at 13.46 am. Critical.

Core = -391 + 173.74 + 15.4 = 201.94 ± 18.7%

Drain part way back.

1347

H₂O at 16.5 am + period #3
 T = 104.5 sec 9.5%

#1: 24.7°C
 #2: 25.0°C

1355

H₂O at 13.35 am. Critical

Drain

Installed U-I in 5-D with 0.375-in. spaces
 Point in above; i.e., 6 enriched strips, one natural strip, and 4 SPERT plates.

1505

H₂O at 14.5 am. + period #4
 T = 145.3 sec 7.3%

#1: 24.7°C
 #2: 25.0°C

1515

H₂O at 12.9 am. Critical.

Drain.

Core = 391 - 173.4 - 16.8 = 200.84 ± 18.7%

Now have 2 plates in SPERT element and Natural
 lower strips #2 + 3.

142

4/8/66

1603 H₂O at 21.2 cm. + Period #5
T = 87.5 mV 10.94

#1: 25.0°C

#2: 25.0°C

1610 H₂O at 14.20 cm. Critical.

Drain

Core = 270 + 27.56 + 10.9 = 308.46 ± 8.44

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter <input checked="" type="checkbox"/>	4"	<input checked="" type="checkbox"/>	3×10^{-12}
"	"	Fast <input checked="" type="checkbox"/>	"	<input checked="" type="checkbox"/>	"
K-2	3×10^{-12}	Meter <input checked="" type="checkbox"/>	4"	<input checked="" type="checkbox"/>	3×10^{-12}
"	"	Fast <input checked="" type="checkbox"/>	"	<input checked="" type="checkbox"/>	"
R-1	—				
R-2	—				
PM-1	900V	Alarm <input checked="" type="checkbox"/>	6"	<input checked="" type="checkbox"/>	500V
PM-2	1200V	Low <input checked="" type="checkbox"/>	12"	<input checked="" type="checkbox"/>	900V
		Alarm <input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
LOG N CALIBRATE <input checked="" type="checkbox"/>		OPERATE <input checked="" type="checkbox"/>		SOURCE No. <u>B-80</u>	
DUMP WELL PROBE LIGHT <input checked="" type="checkbox"/>					

START-UP CHECK LIST

- Equipment checked by D.O.E Personnel check by D.O.E.
- Instruments and safeties checked and reset by D.O.E
- Source in checked by DC Source No. M-43
- Emergency equipment in control room checked by D.O.E
- Instruments in trip circuit: K1-2 PM1-2
- Red light on by DC Time 0810
- Start-up OK'd by D.O.E D.O.E Date 6/9/66

Repeat of last experiment on 6/8.

0849

Wolw at 18.75 cm. + Period #1

#1: 24.5°C

T = 118.8 sec = 8.6 sec

#2: 24.7°C

0858

Wolw at 14.35 cm. Critical.

Drain. $Cor = 240 - 27.52 - 9.7 = 202.78 \pm 8.49$

Expt	Page	3-PV #	Inner	Outer	Safety	Island	R	Chan. #s.	Bkg	Delay	Disc	Mem.	Barst width #s	Beam I #s.	CP:
131	5	97	19.61	19.61	20.77	T	R=1	160	8	16	4	1/2	1000	7.0	3
132	7	98	19.00	19.00	26.00	T	R<1	80	4	8	4	1/2	400	4.0	7
133	7	99	18.00	18.00	26.00	T	R<1	80	4	8	4	1/2	600	10.0	7
134	7	100	17.00	17.00	26.00	T	R<1	80	4	8	4	1/2	600	10.0	7
135	7	101	15.00	15.00	26.00	T	R<1	40	4	16	4	1/2	800	20.0	11
136	7	102	13.63	13.63	26.00	T	R<1	40	4	16	4	1/2	800	20.0	11
137	7	103	13.63	19.63	26.00	T	R<1	40	4	16	4	1/2	800	20.0	11
138	7	104	19.63	13.63	26.00	T	R<1	40	4	16	4	1/2	800	20.0	11
139	7	105	19.63	15.00	26.00	T	R<1	40	4	16	4	1/2	800	22.0	1
140		106	16.63	16.63	26.00	T	R<1	40	8	16	4	1/2	600	7.0	1
159	27	107	19.61	19.61	26.01	T	R<1	160	8	8	4	1/2	1000	6.0	3
160	27	108	19.61	19.61	26.01	T	R<1	80	4	16	4	1/2	1000	14.0	6
161	27	109	23.00	23.00	26.01	T	R<1	160	4	16	4	1/2	1000	6.0	5
162	27	110	24.00	24.00	26.01	T	R<1	160	4	16	4	1/2	1000	7.0	3
165	33	111	24.70	25.59	20.76	T	R=1	160	4	4	4	1/2	800	4.0	3
167	35	112	23.00	23.00	26.00	T	R<1	160	4	8	4	1/2	800	3.0	3
168	35	113	19.61	19.61	26.00	T	R<1	80	4	8	4	1/2	600	6.0	6
260	39	184	25.23	25.23	20.88	T	R=1	160	8	8	4	1/2	1280 10	9.0	3
261	41	185	25.16	24.00	26.00	T	R<1	160	8	8	4	1/2	800	8.0	3
262	41	186	25.16	23.00	26.00	T	R<1	160	4	8	4	1/2	800	8.0	3
263	41	187	25.16	22.00	26.00	T	R<1	160	4	8	4	1/2	800	8.0	3
264	41	188	25.16	21.00	26.00	T	R<1	160	2	8	4	1/2	800	8.0	3
265	41	189	25.16	20.00	26.00	T	R<1	160	2	8	4	1/2	800	8.0	3
266	41	190	25.16	19.00	26.00	T	R<1	80	2	8	4	1/2	630	12	3
267	41	191	25.16	18.00	26.00	T	R<1	80	2	8	4	1/2	630	10	3
268	41	192	25.16	17.00	26.00	T	R<1	80	2	8	4	1/2	630	12	3
269	41	193	24.00	25.16	26.00	T	R<1	160	2	8	4	1/2	800	8.0	3
270	41	194	23.00	25.16	26.00	T	R<1	160	2	8	4	1/2	800	8.0	3
275	43	195	22.00	25.11	26.00	T	R<1	160	2	8	4	1/2	800	8.0	3

am I λ	cps	KV	I _{ma}	Cycles	λ _{est}	λ _{cal}	R. Reg		
2.0	30	145	0.9	53208		158 ± 1	~3	Ag-Cu-Al cylinders.	
4.0	70	145	0.95	224188	-281	256 ± 10	~3		
10.0	70	145	1.1	108861	578	490 ± 10	20		
10.0	70	145	1.05	118938	757	740 ± 50	53		
10.0	115	145	1.05	240814	1626	696 ± 6	89		
20.0	115	145	1.01	335381	1444	1225 ± 50	128		3300 ± 200
20.0	115	145	1.00	239032	1006	850 ± 25	54		3000 ± 200
20.0	115	145	1.00	201901	942	850 ± 10	54		3000 ± 120
22.0	115	145	1.02	176374	777	735 ± 15	32		3000 ± 210
7.0	110	147	.93	968408	886	860 ± 40	32		+ 1.1889%
6.0	35	146	1.01	57396	519	500 ± 5	40	- 1.4289%	
14.0	67	147	1.05	104268	519	500 ± 3	24		
6.0	35	148	1.05	39288	207	200 ± 10	5		
7.0	35	145	1.01	18532	159	154 ± 3	~2		
4.0	35	145	.9	28510	132	115 ± 2	~4		
3.0	30	145	1.0	43006	183	185 ± 3	4		
6.0	60	145	.99	8000	516	508 ± 10			
9.0	30	150	1.06	14,110	121.5	110 ± 1		Eu ₂ O ₃ cylinders 1/4 - slots unaligned + 1.3889%	
8.0	35	150	1.20	100000	147	133 ± 2			
8.0	35	150	1.20	15504	170	163 ± 2			
9.0	35	150	1.20	20000	214	202 ± 2			
8.0	35	150	1.21	24209	258	252 ± 2			
8.0	35	150	1.21	30000	320	319 ± 2			
12	75	150	1.26	40838	409	401 ± 3			
10	75	150	1.06	90000	493	470 ± 5			
12	75	150	1.13	70000	596	577 ± 10			
8.0	35	150	1.13	15988	154	134 ± 2			
8.0	35	150	1.14	20000	176	162 ± 2			
8.0	35	150	1.13	30000	211	202 ± 2			

Expt	Page	3 ^{PU} #	Inner	Outer	Safety	Island	R	Chan #5	BK ₉	Delay	Disc	Mem	Burst width #5	Beam I #
276	43	196	21.00	25.11	26.0	T	b<1	160	2	8	4	1/2	800	10.0
270	45	197	22.00	25.14	26.0	T	b<1	160	2	8	4	1/2	800	6.0
281	45	198	21.00	25.14	26.0	T	b<1	160	2	8	4	1/2	800	6.0
282	45	199	20.00	25.14	26.0	T	b<1	160	2	8	4	1/2	800	6.0
283	45	200	19.00	25.14	26.0	T	b<1	160	2	8	4	1/2	630	8.0
284	47	201	20.045	20.045	20.88	T	b=1	160	4	8	4	1/2	1000	4.0
285	47	202	20.02	17.00	26.00	T	b<1	80	4	8	4	1/2	630	8.0
286	47	203	20.02	18.00	26.00	T	b<1	160	4	4	4	1/2	630	2.0
287	47	204	20.02	18.50	26.00	T	b<1	160	4	4	4	1/2	630	2.0
288	47	205	20.02	19.00	26.00	T	b<1	160	4	4	4	1/2	630	2.0
289	47	206	20.02	19.50	26.00	T	b<1	160	4	4	4	1/2	630	2.0
290	47	207	19.50	20.02	26.00	T	b<1	160	4	4	4	1/2	630	2.0
291	47	208	19.00	20.02	26.00	T	b<1	160	4	4	4	1/2	630	2.0
292	47	209	18.50	20.02	26.00	T	b<1	160	4	4	4	1/2	630	2.0
293	47	210	18.00	20.02	26.00	T	b<1	80	4	8	4	1/2	630	4.0
294	47	211	17.00	20.02	26.00	T	b<1	80	4	8	4	1/2	630	6.0

am I	CPS	KV	I MA	Cycles	λ_{est}	λ_{cal}	R	
0.0	35	150	1.19	28,551	257	257 ± 2		1.38 g ^B /l
1.0	35	150	1.07	15,016		199 ± 1		
5.0	35	150	1.07	20,000		253 ± 1		
1.0	35	150	1.09	20,000		317 ± 1		
0.0	75	150	1.29					High Voltage Filter broke down
0.0	35	150	.93	10500	-141	123.5 ± 1	1	0.98 g ^B /l
0.0	75	150	1.04	30000	-518	498 ± 5	4.03	
2.0	35	150	.93	30000	-360	359 ± 3	2.91	
2.0	35	150	.93	30000	-288	293 ± 5	2.37	
2.0	35	150	.93	19894	-242	237 ± 2	1.92	
1.0	35	150	.93	20000	-189	180 ± 2	1.46	
2.0	35	150	.93	20000	-191	186 ± 2	1.51	
1.0	35	150	.93	20000	-246	240 ± 2	1.94	
1.0	35	150	.93	30000	-296	302 ± 1	2.45	
0.0	75	150	.93	60000	-391	378 ± 2	3.06	
0.0	75	150	.97	50000	-523	512 ± 3	4.15	