

## **BOOK35R**

*Notes:*

"HFIR#2" on spine

Blank pages: inside cover sheet opposite page 1, 1, 2, 58, 151, inside back cover sheets

-page 37 has sheet clipped to it

-small sheet between pages 66 & 67

*Scanned by:*

*Sheila Finch*

*RSICC /Oak Ridge National Lab.*

*August 7, 1999*

HFIR Log #2

6/9/46 →



# Account Book

No. S 149

NO UNITS

Journal . . . . .

Ledger, Single Entry . .

Ledger, Double Entry .

Record Ruled (27 Lines)

Made in 150, and 300 Pages

MADE IN U. S. A.

TO REORDER, SPECIFY NUMBER,  
RULING AND THICKNESS INDICATED  
ON BACKBONE OF THIS BOOK.

4/9/66

See HFIR Log #1 for previous work and for check out of this date.

Installed G-O and G-I with 0.375 in. spacers.  
No SPERT element or poison.

1026

Water at 21.2 cm. Subcritical

Added SPERT element with 2 fuel plates and #2 and #3 natural boron strips.

Fuel = 240, Strips = 27.56

1101

Water at 15.40 cm. + Period #2

#1: 24.7°C

#2: 25.0°C

T = 115.8 mW 8.8%

1112

Water at 13.20 cm. Critical

Core = -240 + 27.56 + 15 = -197.6 ± 8.4%

Added 6 SS strips. Now have 2 fuel plates, 2 natural strips and 6 SS strips.

Fuel = 240, Poison = 35.6%

1338

Water at 21.2 cm. + Period #3

#1: 25.0°C

#2: 25.0°C

T = 158.1 mW 6.8%

1350

Water at 15.40 cm. Critical

During

Core = -240 + 35.6 + 6.2 = -198.2% ± 8.5%

4

6/9/66

Now have 4 fuel plates in the SPERT element  
and 6 enriched strips (#2, 3, 7, 8, 9, 10) and 1 natural  
strip (#1). Fuel = 391, poison = 173.74

1607

W = W at 14.05 am. + Period #4

#1: 25.32  
#2: 25.32

T = 86.8 m 11.0%

1610

W = W at 12:45 am. Critical

Drain

$C_{crit} = 391 + 173.74 + 22.7 = 587.44 \pm 18.74$

Added natural strip #3. Now have 4 fuel  
plates, 6 enriched strips and 2 natural strips.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	$3 \times 10^{-12}$	Meter ✓	4"	✓	$3 \times 10^{-12}$
"	"	Fast ✓	"	✓	"
K-2	$3 \times 10^{-12}$	Meter ✓	5"	✓	$3 \times 10^{-12}$
"	"	Fast ✓	"		"
R-1	-				
R-2	-				
PSA-1	700V	Alarm ✓	cont'	✓	500V
PSA-2	1200V	Low ✓	15"	✓	900V
		Alarm ✓	cont.	✓	
LOG IN CALIBRATE ✓		OPERATE ✓		SOURCE No. B-80	
DUMP WELL PROBE LIGHT ✓					

START-UP CHECK LIST

Equipment checked by J. D. C. Personnel check by J. D. C.

Instruments and safeties checked and reset by D. C.

Source in checked by D. C. Source No. M-43

Emergency equipment in control room checked by D. C.

Instruments in trip circuit: K1-2 PM1-2

Red light on by D. C. Time 0805

Start-up CK'd by J. D. C. D. C. Date 4/10/66

New have 4 fuel plates. 2 natural strips # 2 + 3. and 6 enriched strips # 7, 8, 9, 10

6

6/10/66

0840

Water at 21.25 cm. + Period #1

#1: 24.5°C

T = 135.8 sec 7.7%

#2: 24.7°C

0858

Water at 14.7 cm. Critical

Drain

Core = 391 - 187.52 - 8.5 = -193.98% ± 19.4

Installed 7-I in 6-D <sup>with 0.375 in. spacers</sup> No SPERT element or pinion strips

1110

Water at 21.2 cm. Subcritical

Added SPERT element with v plates and lateral strips #2 and #3.

1152

Water at 16.4 cm. + Period #2

#1: 25.0

T = 104.2 sec 9.6%

#2: 25.0

1200 P

Water at 13.4 cm. Critical

Core = 240 + 27.56 + 14.2 = -198.4% ± 8.4%

Added <sup>6</sup> SS strips. Now have v fuel plates, v lateral strips and <sup>6</sup> SS strips.

1:53

Water = 21.4 cm

Temp. #1 - 25.0°C

Period #3.

#2 - 25.0

T = 135.2 6.25%

Critical - Water Height 15.7 cm

Core = -240 + 35.60 + 5.8% = -198.6% ± 8.54

6/10/66

VSTP

INSTALLED CORE 75 + 70 3/8" spaces

MISSING mmw WITH RESPECT TO CENTER.

2 SPERT PLATES - <sup>D</sup> 3224 & D 5495

6 SS Strips

2 Natural B - SS Strips No. 2 & 3.

3:44 P

Water 71.4cm

Temp #1 75.1 °C

PERIOD # 4

#2 75.5

T = 26.6mm 4.4x

40SP CRITICAL. 16.35 cm. H<sub>2</sub>O Height.

$C_{me} = -240 + 35.6 + 4.4 = -200.0 \pm 8.5x$



0

### INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3 x 10 <sup>-12</sup>	Meter ✓	3"	✓	3 x 10 <sup>-12</sup>
"	"	Fast ✓	"	✓	"
K-2	"	Meter ✓	"	✓	"
"	"	Fast ✓	"	✓	"
R-1					
R-2					
PM-1	700 v	Alarm ✓	cont	✓	500 v
PM-2	1200 v	Low ✓	1.4"	✓	900 v
"	1'	Alarm ✓	3"	✓	1'
LOG N CALIBRATE ✓		OPERATE ✓		SOURCE No. B-80	
DUMP WELL PROBE LIGHT _____					

### START-UP CHECK LIST

Equipment checked by AKM Personnel check by I.D.C  
 Instruments and safeties checked and reset by AKM  
 Source in checked by AKM Source No. M-43  
 Emergency equipment in control room checked by I.D.C  
 Instruments in trip circuit: K-1-2 - PM-1-2  
 Red light on by AKM Time 0815  
 Start-up OK'd by I.D.C AKM Date 6-13-66

0825 Repeat of experiment described on page 7.  
6-10-66. Cones # 7-0 & 7-E

0907 Water ht = 21.25 cm Water Temp. °C  
(1) + Per #1 = 24.3  
 $E = 457.19 \text{ sec} = 2.3 \text{ f}$  #2 = 25.0  
Cone =  $-240.2 + 35.6 + 2.3 = 202.1 \pm 8.5\%$

0937 Water ht = 17.20 cm  
System just critical  
Drain.

Cones #<sup>s</sup> 7-0 & 7-E.

Have 4 fuel plates, 2 natural strips, #2,3.  
and 6 enriched strips, 2,3,7,8,9,10.

1125 Water ht = 21.30 cm Water Temp. °C  
(2) + Per #1 = 24.5  
 $E = 347.68 \text{ sec} = 3.4 \text{ f}$  #2 = 29.5

1135 added water to 24.15 cm.  
No change in + Per.

1145 Water ht = 16.80 cm Cone =  $-391.0 + 187.52 + 3.4$   
System just critical: Drain. = 200.10

1300

Outer core # 7-0

Inner core # 8-1

2 spent fuel plates.

2 natural boron strips # 2 + 3

6 stainless steel strips.

1336

(3) Water ht = 21.20 cm

+ Per

 $\Sigma = 81.49 \text{ cm} = 11.6 \text{ f}$ 

Water Temp °C

#1 = 24.7

#2 = 25.0

1347

Water ht = 14.00 cm

System just critical

Drain

 $\text{core} = -240.0 + 35.6 + 11.6 = 192.8 \text{ f} \pm 8.5 \text{ f}$ 

1450

Now have:

Outer core # 8-0

Inner core # 8-1

2 spent fuel plates

2 natural boron strips # 2 + 3

6 stainless steel strips.

1540

Water ht = 18.10 cm

+ Per

 $\Sigma = 76.06 \text{ cm} = 12.2 \text{ f}$ 

Water Temp °C

#1 = 24.7

#2 = 25.0

1550 Water ht = 13.50 cm  
System just critical  
Drain:

Repeat of + Pr:  
1555 Water ht = 21.30 cm  
⑤ + Pr  
 $U = 60.89 \text{ rev} = 14.3 \text{ \AA}$

Water Temp  $^{\circ}\text{C}$   
#1 = 24.7  
2 = 25.0

1600 Water ht = 13.50 cm.  
System just critical  
Drain:

$$L_{cr} = -240.0 + 35.6 + 14.3 = 190.10 \text{ \AA} \pm 8.5 \text{ \AA}$$

$^{\circ}\text{C}$   
F.7  
5.0

$^{\circ}\text{C}$   
7  
0

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	START-UP RANGE
K-1	$3 \times 10^{-12}$	Meter ✓	$3 \times 10^{-12}$
"	"	Fast ✓	"
K-2	"	Meter ✓	"
"	"	Fast ✓	"
R-1			
R-2			
EM	700 V	Alarm ✓	500 V
EM	1200 V	Low ✓	900 V
"	"	Alarm ✓	"

LOG N CALIBRATE \_\_\_\_\_

OPERATE \_\_\_\_\_

SOURCE No.

B-80

BUMP WELL PROBE LIGHT \_\_\_\_\_

START-UP CHECK LIST

Equipment checked by PKAL Personnel check by FIDC

Instruments and safeties checked and passed by AKAV

Source in checked by AKAL No. M-93

Emergency equipment in control room checked by FIDC

Instruments in trip circuit: K-1-2 PM9-1-2

Red light on by PKAL Time 0820

Start-up OK'd by FIDC PKAL Date 6-14-66

0820

outer core # 8-0

inner core # 8-1

4 spent fuel plates.

2 natural boron strips # 2 + 3.

6 enriched boron strips # 2, 3, 7, 8, 9, 10.

0855

Water ht = 19.10 cm.

Water Temp °C

(1) + Per

#1 = 29.3

 $E = 68.01 \text{ m} = 13.2 \text{ f}$ 

2 = 29.5

0905

Water ht = 13.20 cm.

system just critical

Drain too ~ 8.5 cm: Report + Per.

0912

Water ht = 19.30 cm.

Water Temp °C

(2) + Per.

#1 = 29.3

 $E = 71.00 \text{ m} = 12.8 \text{ f}$ 

2 = 29.5

0922

Water ht = 13.35

system just critical

Drain:

Core = -391.0 + 187.52 + 14.0 = 189.48 f = 15.4 f

err.

1030

Outer core # 8.0

Inner core # 8.1

4 spent fuel plates. = 391.00 f

2 natural boron strips. = 27.56 f

6 enriched boron strips = 159.96 f

4 stainless steel strips. = 8.36 f

Total poison

= 192.88 f

1100

Water ht = 21.20 cm

Water Temp °C

(3) + Per

#1 = 24.5

E = 112.34 m = 9.0 f

2 = 24.5

1113

Water ht = 14.50 cm

System just critical  
Drain.Core =  $-391.0 + 192.88 + 9.0 = 189.12 f \pm 19.4 f$ 

1245

Outer core # 8.0

Inner core # 9-1

2 spent fuel plates = 240.00 f

2 natural boron strips = 27.56 f

6 stainless steel strips. = 8.04 f

Total poison

= 35.60 f

1313

Water ht = 18.00 cm

Water Temp °C

4 + Per

#1 = 24.7

E = 81.91 m = 11.1 f

2 = 25.0

1325 Water ht = 13.55 cm

System just critical

Drain:

$$\text{Cost} = -240.00 + 35.60 + 12.0 = -192.40 \text{ f } \pm 9\text{f}$$

1335 added 4 more stainless steel strips:

Now have.

Outer core #8-0

Inner core #9-1

2 spent fuel plates = 240.00 €

2 natural boron strips = 27.50 f

10 stainless steel strips = 13.40 f

Total previous

= 40.96 f

1408 Water ht = 21.20 cm

(5) Per

$$B = 135.81 \text{ cm} = 7.7 \text{ f}$$

Water Temp °C

#1 = 25.0

#2 = 25.0

1420 Water ht = 15.10 cm.

System just critical

Drain:

$$\text{Cost} = -240.00 + 40.96 \text{ f} + 7.7 = -191.42 \text{ f } \pm 9\text{f}$$



1505

New hole.

Outer core # 9-0

Inner core # 9-1

2 spent fuel plates = 240.00 \$

2 natural boron strips. 27.50 \$

6 stainless steel strips. 7.00 \$

= total price

= 35.60 \$

1543

Water ht = 21.20 cm

Water Temp °C

(6) + Pen.

#1 = 25.0

t = 67.36 sec = 13.3 \$

#2 = 25.2

1552

Water ht = 13.65 cm.

System just critical

Drain

cm = -240.00 + 35.60 + 13.3 = 191.10 \$ ± 5 \$

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3 X 10 <sup>-12</sup>	Meter ✓	4"	✓	3 X 10 <sup>-12</sup>
	"	Fast -	"	✓	"
K-2	"	Meter -	"	-	"
	"	Fast ✓	"	-	"
R-1					
R-2					
PM-1	700 v	Alarm -	cut	-	500 v
PM-2	1200 v	Low ✓	12"	✓	900 v
	"	Alarm ✓	2"	-	"
LOG N. CALIBRATE		✓	OPERATE	-	SOURCE No. B-80
DUMP WELL PROBE LIGHT					

60 f  
 60  
 = 25.0  
 = 25.2

START-UP CHECK LIST

Equipment checked by AKAL Personnel check by AKAL  
 Instruments and safeties checked and reset by AKAL  
 Source in checked by AKAL Source No. M-43  
 Emergency equipment in control room checked by F.D.C.  
 Instruments in trip circuit: K-1-2 PM 1-2  
 Red light on by A.K. R.P. Time 0802  
 Start-up OK'd by F.D.C. AKAL Date 6-15-66

0805 Repeat of experiment described on page 16.

acc.

0836 Water ht = 21.30 cm  
 (1) + Pen  
 $E = 72.36 \text{ cm} = 12.6 \text{ f}$

Water Temp °C  
 #1 = 24.5  
 2 = 24.7

0848 Water ht = 13.75 cm  
 system just critical  
 Drain.

$$\text{core} = -240.00 + 35.00 + 12.6 \text{ f} = 191.80 \text{ f} \pm 9 \text{ f}$$

0910

Now here:

Outer core # 9-0

Inner core # 9-1

4 sput fuel plates # 2+3 = 391.00 g

2 natural boron strips # 2,3,7,8,9,10 = 27.56 g

6 enriched boron strips = 159.96 g

Drain = 187.52

0943 Water ht = 21.25 cm  
 (2) + Pen

Water Temp °C  
 #1 = 24.5  
 2 = 24.7

0952 Water ht = 13.80  
 system just critical  
 Drain.

$$\text{core} = -391 + 187.52 + 13.20 = 190.30 \text{ f} \pm 15.4 \text{ f}$$

INSTRUMENT CHECK

24.5  
24.7

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	$3 \times 10^{-12}$	Meter ✓	3"	✓	$3 \times 10^{-12}$
	"	Fast ✓	"	-	"
K-2	"	Meter ✓	"	-	"
	"	Fast ✓	"	-	"
R-1					
R-2					
PM-1	700 V	Alarm ✓	cont	-	500 V
PM-2	1200 V	Low ✓	19"	-	900 V
	"	Alarm ✓	3"	-	"

LOG N CALIBRATE  OPERATE  SOURCE No. B-80  
 DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by AKM Personnel check by FID.C  
 Instruments and safeties checked and reset by AKM  
 Source in checked by AKM Source No. M-43  
 Emergency equipment in control room checked by FID.C  
 Instruments in trip circuit: K-1-2 PM-1-2  
 Red light on by AKM Time 0815  
 Start-up OK'd by FID.C AKM Date 6-16-66

24.5  
24.7

0830

Now have:

Outer core #9-0

Inner core #9-1

4 spent fuel plates = 391.00¢

1 natural boron strip = 13.75¢

5 enriched boron strips = 133.30¢

also have D. M. Fry Ion Chamber mounted against outer core.

Purpose to obtain month of Ion Chamber weather mounted next to core.

0900

Water ht = 21.20 cm:

Water Temp °C

(4) + Pen

#1 = 24.2

5 = 127.47 re = 8.1¢

#2 = 24.9

Core = -391.00¢ + 155.18¢ = 232.82¢ chamber = 42.12¢  
- 199.70¢ = 33.12¢ using + Pen values.Log  $\eta = .10$ 

0914

Water ht = 14.70 cm

Core with chamber

System just critical

= -235.00¢

Chamber = 45.0¢

43.3¢

0915

- Pen; to reduce power level:

0930

Water ht = 14.70

Log  $\eta = .032$ 

System just critical.

K-2 = 50% 10 x 10<sup>-10</sup>K-1 = 47% 10 x 10<sup>-11</sup>

Start of power run for D. M. Fry.

0957 Drain:

0959 120 MR at center of outer core:

1015 Removed spent fuel plates and all poison strips: Now have sources # M-43 and M-227 opposite Fry's Ion Chamber. Purpose is for subcritical measurement for Fry. Subcritical by  $151.1 + 43.3\% = 234.4\%$

1040 Water ht = 21.20 cm: sources in:

Log $\eta = .012$	Water Temp $^{\circ}C$
$K-1 = \sim 40\% \quad 3 \times 10^{-11}$	#1 = 24.3
$K-2 = \sim 43\% \quad 3 \times 10^{-11}$	2 = 24.5

1115 Removed sources:

Background run for Fry.

Log  $\eta = .0017$   
 $K-1 = \sim 15\% \quad 3 \times 10^{-12}$   
 $K-2 = \sim 30\% \quad 3 \times 10^{-12}$

1205 Drain

over:

$^{\circ}C$   
4.2  
7.4

5.04  
13.34

11  
11

22

1245

New hole:

Outer core #7-0

Inner core #7-1

Have samplers # M-43 & M-227 opposite Fry  
Jan Chamber: Purpose is sub critical  
measurement for Fry. Subcritical by  $200.7 + 43.3$   
 $= 244.0 \text{ cm}$

1313

Water ht = 21.20 cm; samplers in:

Log  $n = .0095$

K-1 =  $\sim 34\% 3 \times 10^{-11}$

K-2 =  $\sim 35\% 3 \times 10^{-12}$

Water Temp  $^{\circ}\text{C}$

#1 = 24.5

2 = 24.7

1400

Drain.

1428

New hole:

outer core #8-0

Inner core #8-1

Have samplers # M-43 & M-227 opposite Fry Jan  
Chamber: Purpose is sub critical measurement  
for Fry. Subcritical by  $189.6 + 43.3 = 232.9$

1452

Water ht = 21.30. samplers in: Water Temp  $^{\circ}\text{C}$

Log  $n = .0095$

K-1 =  $\sim 34\% 3 \times 10^{-11}$

K-2 =  $\sim 35\% 3 \times 10^{-12}$

#1 = 24.7

2 = 25.0

1540 Moved Fry's for Chamber up 3.0". Other conditions same as described on bottom page 22

1612 Drossin

ing

+43.3

o  
c

24.5

24.7

low  
meat

°c

7

.0



24

7/13/66

INSTRUMENT CHECK

INSTRUMENT	RANGE	TEST	STARTUP RANGE
K-1	3x10 <sup>-12</sup>	✓	4" ✓ 3x10 <sup>-12</sup>
K-2	3x10 <sup>-12</sup>	✓	4" ✓ 3x10 <sup>-12</sup>
PM-1	700V	✓	Constant ✓ 500V
PM-2	1200V	✓	8" ✓ 900V
LOW CALIBRATION	✓	OPERATE ✓	SOURCE No. B-80
DIAGNOSTIC LIGHT	✓		

START-UP CHECK SHEET

Equipment checked by EQ IDC Channel check by IDC

Instruments and safeties checked and reset by EQ

Source in checked by IDC Source No. M-43

Emergency equipment in control room checked IDC

Instruments in trip circuit: K-1, K-2, PM-1, PM-2

Red light on by EQ Time 0915

Start-up OK'd by EQ IDC Date 7/13/66

7/13/66

HFIR cores 9 and 6 spaced 3" in bell.

Set feed rate: 2.4 cm/min.

Because of vibration induced noise, Tech

K-1 + K-2 out of trip. Am pumping air.

10:45

Water at 44.6 cm (load scale). Critical.

Drain.

Moved #6 element away. Put new hose clamps on suction side of pump. Tightened bolts on flange of drain valve. Throttle with system valve. Pumped water over elements. Substantially less noise in being pumped.

Water at 47.1 cm (load scale) when over fuel plates in outer annulus. (2 in)

Feed rate: 3.4 cm/min.

Drain rate: 2.8 cm/min.

Respace elements to 3" separation.

15:13

Water at 45.1 cm (load scale) + period #1

 $T = 112.5 \text{ sec} = 9.08$ 

15:20

Water at 44.7 cm. Very slight + period

Water at 44.7 cm. Very slight - period

$W_0 = 2.68 \text{ cm}$  above top of fuel. C + 3.25 cm in TM 1488 for CE-2 and CE-3 at this separation.

Top of fuel  
42.02 cm

26

7/13/66

Elements low spread 3.6 in.

1555

Water at 51.3 cm. + pinned

$T = 85.4$  now  $\sim 11.2$   $\phi$

1600

Water at 49.9 cm. Critical.

Drain

7/14/66

## EQUIPMENT LIST

INSTRUMENT	RANGE	TRIP	SOURCE D. RANGE	SET	START-UP RANGE
K-1	3x15 <sup>-14</sup>	✓	4"	✓	3x15 <sup>-14</sup>
K-2	3x15 <sup>-14</sup>	✓	4"	✓	3x15 <sup>-14</sup>
R-1	—	✓		✓	
R-2	—	✓		✓	
PM-1	200V	Alarm ✓	Contact	✓	500V
PM-2	1200V	Low ✓	8"	✓	
		Alarm ✓	2"	✓	900V
LOG N CALIBRATE ✓		CHECKED ✓	SOURCE No. B-80		
DUMP WELL PROBE LIGHT —					

## START-UP CHECK LIST

Equipment checked by IOC, DC Personnel check by IOCInstruments and safeties checked and reset by IOCSource in checked by DC Source No. M-43Emergency equipment in control room checked by IOCInstruments in trip circuits: PM-1, PM-2, K-1Red light on by DC Time 0730Start-up OK'd by DC, IDC, LG Date 7/14/66

Elements 9 and 6 separated 3.95 in.

28

7/14/66

Check feed rate: 3.4 cm/min  
water at 58.7 cm. Subcritical


0930

Pull source for reg. period.<sup>#1</sup>

Drain

• T = 199.1 rev - 8.2%

1330



Now have 4 elements spaced in square pattern as shown above.

1354

W<sub>2</sub>W<sub>2</sub> at 43.7 cm. + period 4v

T = 93.9 rev 10.4%

1400

W<sub>2</sub>W<sub>2</sub> at 43.30 cm. Critical.

Drain

now spaced 4.535 in.

1445

W<sub>2</sub>W<sub>2</sub> at 48.4 cm. + period #3

T = 48.1 rev 16.8%

7/14/66

1455

Water at 47.6 cm. Critical.

Drain

Elements low speed 5.045 in.

1545

Water at 58.7 cm. + panel #4.

T = 400.6 sec 3.0¢

1558

Water at 54.9 cm. Critical.

Drain

30

7/15/76

### INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3 x 10 <sup>-12</sup>	Meter ✓ Fast ✓	2"	✓	3 x 10 <sup>-12</sup>
K-2	3 x 10 <sup>-12</sup>	Meter ✓ Fast ✓	2"	✓	3 x 10 <sup>-12</sup>
R-1					
R-2					
PM-1	700 ✓	Alarm ✓	Content	✓	5000 ✓
PM-2	1200 ✓	Low ✓ Alarm ✓	10" 2"	✓	9000 ✓

LOG N CALIBRATE \_\_\_\_\_ OPERATE \_\_\_\_\_ SOURCE No. B-60

DUMP WELL PROBE LIGHT \_\_\_\_\_

### START-UP CHECK LIST

Equipment checked by EJ, IDC Personnel check by IDC

Instruments and safeties checked and reset by EJ

Source in checked by EJ Source No. M-43


Emergency equipment in control room checked by IDC

Instruments in trip circuit: K-1, PM-1, PM-2

Red light on by EJ Time 1430

Start-up OK'd by EJ, IDC Date 7/15/76

Now have 5 elements in triangular array  
side to side separation = 5.0"




1455 W at W at 45.5 cm. + Point #1

$$T = 98.3 \text{ sec} = 10.0 \%$$

1503 W at W at 44.9 cm. Critical

Drain

15130 Now have 6 elements in triangular array  
side to side separation = 5.0"



1548 W at W at 44.5 cm. + Point #2

$$T = 74.4 \text{ sec} = 12.4 \%$$

1555 W at W at 44.1 cm. Critical.

Drain



32

7/19/66

## INSTRUMENT CHECK


INSTRUMENT	RANGE	TRIP	SET	START-UP RANGE
K-1	3x10 <sup>14</sup>	Meter ✓ - ✓	4" ✓	3x10 <sup>14</sup>
K-2	3x10 <sup>14</sup>	Meter ✓ - ✓	4" ✓	3x10 <sup>14</sup>
R-1				
R-2				
PM-1	7000	Alarm ✓	Constant ✓	5000
PM-2	12000	Alarm ✓	10" ✓	9000
		Alarm ✓	2" ✓	
LOG IN CALIBRATION ✓		✓	SOURCE NO. B-80	

## START-UP CHECK LIST

Equipment checked by EJ, IDC Personnel check by IDCInstruments and safeties checked and reset by EJSource in checked by IDC Source No. M-43Emergency equipment in control room checked by IDCInstruments in trip circuit: K-1, PM-1, PM-2Red light on by EJ Time 0910Start-up OK'd by EJ, IDC Date 7/19/66

7/15/66

Now use 7 HFIR elements in Well. Triangular pattern, 5.0 in. separation.



0945 Water at 43.1 cm. + Point #1

0955 Water at 42.7 cm. Critical  
Drain

Spacing now 5.60 in. 7 elements in Triangular pattern.

~~08~~ 1445 Water at 46.2 cm. + Point #2

1455 Water at 45.6 cm. Critical.  
Drain

34

7/21/66

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3 x 15" <sup>12</sup>	Meter ✓ Fast ✓	3"		3 x 15" <sup>12</sup>
K-2	3 x 15" <sup>12</sup>	Meter ✓ Fast ✓	3"		3 x 15" <sup>12</sup>
R-1					
R-2					
PM-1	7000	Alarm ✓	Contact		5000
PM-2	12000	Low ✓ Alarm ✓	15" 2"		9000

LOG IN CALIBRATE  OPERATE  SOURCE No. 2-FO

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by EJ IDC Personnel check by IDC

Instruments and safeties checked and reset by EJ

Source in checked by EJ Source No. 71-73

Emergency equipment in control room checked by IDC

Instruments in trip circuit: K-1, K-2

Red light on by \_\_\_\_\_ Time 0840

start-up OK'd by \_\_\_\_\_ Date \_\_\_\_\_

7/21/66

7 elements in triangular pattern spaced 6.7 in.

1202

W of W at 58.20 cm. sub-critical.  
Source in to increase level.

1010

Remove source for leg. Point #1. Too steep to measure.

Drain

Spacing now 6.55 in.

1405

W of W at 58.3 cm. sub-critical  
Source in to increase level.

1415

Remove source for leg. Point #2.  
 $T \approx 53 \text{ sec}$ ;  $P7-28F$

Drain

7/22/66

7 elements spaced 4.55 in. The center one (#9) now is adjusted so that it will be critical submerged; it contains 2 fuel plates, 1 enriched strip, 1 natural strip, and 6 SS strips.

$240 - 49.5 = 191.5$ . Element measured  $23 - 191.1$

$\therefore$  should have 0.4% excess associated with center element.

1048 Wt wt at 48.0 gm. + Poisson #1

$T = 47.6$  sec;  $\rho = 16.9\%$  ( $26\%$  / cm)

1055 Wt wt at 47.35. Critical

Drain

Added 2 enriched strips to #9 (center).

Now have  $49.5 + 53.4$  in poison =  $101.9$

$240 - 101.9 - 191.1 = 53.0$  The center element is subcritical.

1125 Wt wt at 50.9 gm. + Poisson #2

$T = 68.6$  sec;  $\rho = 13.1\%$  ( $8.7\%$  / cm)

1133 Wt wt at 49.4 gm. Critical

Drain

Replace poison to have 4 enriched strips and 1 natural strip. Poison =  $120.6$

$240 - 120.6 - 191.1 = 71.7$  subcritical (center element)

1333 Wt wt at 52.6 gm. + Poisson #3

$T = 100.35$  sec;  $\rho = 9.9\%$

Top of f... 42.02 cm  
1" ... 57.26 cm  
3" ... 49.64 cm

7/22/66

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START RANGE
K-1	3x15"	Meter ✓ Fst ✓	3"	✓	3x15"
K-2	3x15"	Meter ✓ Fst ✓	3"	✓	3x15"
R-1	—	—	—	—	—
R-2	—	—	—	—	—
PM-1	700V	Alarm ✓	Contact	✓	500V
PM-2	1200V	Low ✓ Alarm ✓	10" 2"	✓	900V

LOG N CALIBRATE  OPERATE  SOURCE No. B-10  
 DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by EJ IDC Personnel check by IDC  
 Instruments and safeties checked and reset by EJ  
 Source in checked by EJ Source No. M-70  
 Emergency equipment in control room checked by IDC  
 Instruments in trip circuit: K-1, K-2, PM-1, PM-2  
 Red light on by EJ Time 1020  
 Start-up OK'd by EJ, IDC Date 7/22/66

7/22/66

1340

Water at 50.65 cm. Critical

Drain.

Add 1 natural strip. Now have 4 enriched  
and 2 natural strips. Poisson = 325.5 (including el.)  
240 - 325.5 = -85.5 & that the center element  
is subcritical.

1412

Water at 58.0 cm. + period #4

T = 112.8 sec; p = 9.3%

1420

Water at 52.25 cm. Critical.

Drain

240 - 325.5 = -85.5 & that center element  
should have been subcritical to make array  
critical submerged. ∴ Added 96.6% to center  
element to make array critical.



## INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	$3 \times 10^{-12}$	Meter <input checked="" type="checkbox"/>	7"	<input checked="" type="checkbox"/>	$3 \times 10^{-14}$
		Fast <input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
K-2	$3 \times 10^{-12}$	Meter <input checked="" type="checkbox"/>	4"	<input checked="" type="checkbox"/>	$3 \times 10^{-12}$
		Fast <input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
R-1	—				
R-2	—				
PM-1	700V	Alarm <input checked="" type="checkbox"/>	Cont	<input checked="" type="checkbox"/>	500V
PM-2	1200V	Low <input checked="" type="checkbox"/>	10"	<input checked="" type="checkbox"/>	900V
		Alarm <input checked="" type="checkbox"/>	3	<input checked="" type="checkbox"/>	
LOG IN CALIBRATE <input checked="" type="checkbox"/>		OPERATE <input checked="" type="checkbox"/>		SOURCE No. B-86	
DUMP WELL PROBE LIGHT <input checked="" type="checkbox"/>					

## START-UP CHECK LIST

Equipment checked by IDC Personnel check by F. DC

Instruments and safeties checked and reset by I. DC

Source in checked by IDC Source No. M 43

Emergency equipment in control room checked by I. DC

Instruments in trip circuit: K1 K2 PM1 PM2

Red light on by DC Time 0815

Start-up OK'd by DC, IDC Date 7/25/66

7/25766

7 elements, Triangular pattern, spaced 6.40 in.

0850

Water at 58.0 cm. Source in to increase level.

0855

Remove source for reg. period #1

$T = 124.4$  sec;  $\rho = -16.6\%$

Drain

Removed spacers for plates. Replaced spacers. Now use 7 elements, triangular pattern, 6.4 in. separation.

1343

Water at 58.0 cm. Source in to increase neutron level.

1354

Remove source for reg. period #2

$T = 124.0$  sec;  $\rho = -16.6\%$

Drain

At same spacing, installed SPERT element with 2 fuel plates and 4 natural boron strips in center element (09).

Fuel = +240, element = -191.1, strips = -55.2%

1444

Water at 47.8 cm. + period #3

$T = 70.7$  sec;  $\rho = -12.8\%$

1448

Water at 47.1 cm. Critical

Drain.

7/25/66

Now leave 2 fuel plates, 3 enriched and  
3 natural strips.

~40 fuel, -191.1 element, -121.4 strips.

1522 W<sub>2</sub> at 52.8 cm. + period #4

T = 57.0 sec; p = 15.0%

Doesn't fit curve.

1530 W<sub>2</sub> at 49.6 cm. Critical

Duzin

~40 - 191.1 - 121.4 - 15 = -87.5%, amount center element  
must be subcritical to make any critical: ∴ added  
191.1 - 87.5 = 103.6% to center element to make  
away critical. See p. 43 for further comments.

7/24/66

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	$3 \times 10^{-12}$	Meter ✓ Fast ✓	5"	✓	$3 \times 10^{-12}$
K-2	$3 \times 10^{-12}$	Meter ✓ Fast ✓	5"	✓	$3 \times 10^{-12}$
R-1	—				
R-2	—				
PM-1	700V	Alarm ✓	cont.	✓	500V
PM-2	1200V	Low ✓ Alarm ✓	10" 3"	✓	900V

LOG N CALIBRATE ✓ OPERATE ✓ SOURCE No. B-86

DUMP WELL PROBE LIGHT ✓

START-UP CHECK LIST

Equipment checked by FDC Personnel check by DC  
 Instruments and safeties checked and reset by FDC  
 Source in checked by DC Source No. M-43  
 Emergency equipment in control room checked by FDC  
 Instruments in trip circuit: K1-K2-PM1-PM2  
 Red light on by DC Time 0810  
 Start-up OK'd by DC & DC Date 0815

7/26/46

Now have 1 more enriched strip, making a total of 4 enriched and 3 natural strips. Spacing 6.4 in.  
 Position = 148.2 F

0850

Water at 51.8 cm. Critical

 $T = 90.9$  mm;  $p = 10.6$  g

0855

Water at 58.0 cm. + Period #1

0900

Water at 52.2 cm. Critical.

Drain

∴ Center element was +240-191.1-148.2-10.6 g  
 subcritical = 99.9 g; added 91.2 g to center  
 element.

Removed the inner 2 rods from all elements  
 except the center one. The center element  
 contains 2 fuel plates, 3 enriched and 3 natural  
 strips. Position = 121.58; center element  
 subcritical by 22.6 g

1053

Water at 58 cm. Essentially no multiplication  
 Drain.

Now have 2 fuel plates and 2 enriched strips  
 in the center element. Position = 53.42; element  
 subcritical by 4.59

1105

Water at 58 cm. Slight + period #2.

1105

Water at 57.2 cm. Critical  $K_{eff} = 4.5$  f  
 Drain

11  
1966  
7/26

Seven HFIR outer annuli -  $\Delta$  pattern  
in contact

---

105P CRITICAL H<sub>2</sub>O @ 25.9 cm

---

Seven HFIR outer annuli  $\Delta$  pattern  
4.4 in. 5-to-5.

200P VERY SUBCRITICAL

Spacing now .025 in.

1545 Water at 58. cm. Very subcritical.

Drain.

Spacing now 1.060 in.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	$3 \times 10^{-12}$	Meter <input type="checkbox"/>	5"	<input type="checkbox"/>	$3 \times 10^{-12}$
		Fast <input type="checkbox"/>		<input type="checkbox"/>	
K-2	$3 \times 10^{-12}$	Meter <input checked="" type="checkbox"/>	5"	<input checked="" type="checkbox"/>	$3 \times 10^{-12}$
		Fast <input checked="" type="checkbox"/>			
R-1	—				
R-2	—				
PM-1	700V	Alarm <input checked="" type="checkbox"/>	Cont	<input type="checkbox"/>	500V
PM-2	1200V	Low <input checked="" type="checkbox"/>	10"	<input type="checkbox"/>	900V
		Alarm <input checked="" type="checkbox"/>	2"	<input checked="" type="checkbox"/>	

LOG IN CALIBRATE  OPERATE  SOURCE No. B-80  
 DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by J. A. E. Personnel check by R. E.  
 Instruments and safeties checked and reset by J. A. E.  
 Source in checked by R. E. Source No. M-43  
 Emergency equipment in control room checked by J. A. E.  
 Instruments in trip circuit: K1-K2-PM1-PM2  
 Red light on by J. A. E. Time 0810  
 Start-up OK'd by J. A. E. R. E. Date 7/27/65

0838 Spacing now 1.06 in. 7 antenna assembly  
 Water at 36.1 cm. + Period #1  
 0847 Water at 36.1 cm. Critical. Drain.

7/27/66

Spacing now 1.535 in.  $\pm$  0.010 in.

0948 . Water at 58.2 cm. Little multiplication.  
 Drain

Spacing now 1.420 in.

1042 Water at 49.4 cm. + present  $\frac{1}{2}$

1052 Water at 48.6 cm. Critical.  
 Drain



7/28/66

## INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE RANGE	SET	START-UP RANGE
K-1	3 x 15" <sup>14</sup>	Meter ✓ F-st ✓	5"		3 x 15" <sup>14</sup>
K-2	3 x 15" <sup>12</sup>	Meter ✓ F-st ✓	4"		3 x 15" <sup>12</sup>
R-1					
R-2					
PM-1	200 V	Alarm ✓	Constant		500 ✓
PM-2	1200 ✓	Low ✓ Alarm ✓	10" 2"		900 ✓

LOG N CALIBRATE ✓

OPERATE ✓

SOURCE No.


B-80

DUMP WELL PROBE LIGHT

## START-UP CHECK LIST

Equipment checked by EJ, IDC Personnel check by IDCInstruments and safeties checked and reset by EJSources in checked by EJ Source No. M-43Emergency equipment in control room checked by IDCInstruments in trip circuit: K-1, K-2, PM-1, PM-2Red light on by EJ Time 1100Start-up CR'd by EJ, IDC Date 7/28/66

7/28/66



1128

W = 27.58 cm. Sub-critical.  
Drain

Annuli spaced as close as possible. Some in contact at top, some gaps. Slightly irregular spacing.

1315

W = 40.7 cm, + P. limit #1

T = 80.1 cm; p = 11.7 g


1320

W = 40.5 cm. Critical.

k = 7.754

W = 1.5 cm below top of fuel.

7/28/60



All inner annuli; raised  $\frac{1}{2}$ " off floor by plastic  
 spacers because of center flange in floor of  
 tank. ~~Inner~~ Annuli in contact at tops; fuel spacing  
 1.2 in.

1555

Water at 60 cm. Subcritical; little multiplication.  
 Drizin

7/29/66


INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE	SET	START-UP RANGE
K-1	$3 \times 10^{-12}$	Meter ✓ Fast ✓	5"	✓	$3 \times 10^{-12}$
K-2	$3 \times 10^{-12}$	Meter ✓ Fast ✓	5"	-	$3 \times 10^{-12}$
R-1	—				
R-2	—				
PM-1	700V	Alarm ✓	Contact	✓	500V
PM-2	1200V	Low ✓ Alarm ✓	10" 2"	-	900V
LOG IN CALIBRATE		✓	OPERATE	✓	SOURCE No. B-80
DUM - WHITE FLAG LIGHT		—			

START-UP CHECK LIST

Equipment checked by EP, IDC Personnel check by IDC  
 Instruments and safeties checked and reset by EP  
 Source in checked by EP Source No. M-43  
 Emergency equipment in control room checked by IDC  
 Instruments in trip circuit: K-1, K-2, PM-1, PM-2  
 Red light on by EP Date - 1830  
 Start-up OK'd by EP, IDC Date - 7/29/66

2/25/64



13.9

Three outer annuli in contact as shown above.

1103


Water at 51.8 cm. + Period #1

$T = 63.7$  sec;  $P = 13.88$

1111

Water at 49.6 cm. Critical.

Drain This way was about 2.5% supercritical



Four outer annuli in contact, square pattern.


1335

Water at 58 cm. Very subcritical.

Drain via screen bottom. It works!

7/29/66

3 elements spaced  
5.050 in.



1550 Water at 58.0 cm. + record #2

$T = 112.0$  sec;  $P = 9.18$

1600 Water at 52.05 cm. Critical

Drain.

8/1/66

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3x15" ✓	Meter ✓	5" ✓	✓	3x15" ✓
		Fast ✓		✓	
K-2	3x15" ✓	Meter ✓	5" ✓	✓	3x15" ✓
		Fast ✓		✓	
R-1	—				
R-2	—				
PM-1	7000 ✓	Alarm ✓	Contact ✓		5000 ✓
PM-2	12000 ✓	Low ✓	12" ✓	✓	9000 ✓
		Alarm ✓	2" ✓	✓	

LOG N CALIBRATE  OPERATE  SOURCE No. B-80

DUMP WELL FLOOD LIGHT

START-UP CHECK LIST

Equipment checked by DC, IDC Personnel check by IDC

Instruments and safeties checked and reset by IDC

Source in checked by DC Source No. M-43

Emergency equipment in control room checked by IDC

Instruments in trip circuit: K-1, K-2, PM-1, PM-2

Red light on by IDC Time 0830

Start-up OK'd by EQ, DC, IDC Date 8/1/66

8/1/66

Element <sup>(#9)</sup> with 2 SPERT plates and 2 natural strips.

1020

Water at 52.7 cm. + period #1

$T = 59.6$  sec  $p = 14.5\%$

1027

Water at 50.1 cm. Critical

$240 - 27.6$  (poison)  $- 22.6$  (water level)  $= 189.8\%$

Drain

Element <sup>(#10)</sup> with 2 SPERT plates and 2 natural strips.

1325

Water at <sup>11.5</sup> 50.2 cm. + period #2

$240 - 27.6 - 30.4 = 182.0\%$  <sup>28.4</sup>  $T = 12.16$  sec  $p = 8.5\%$

1335

Water at <sup>11.5</sup> 49.4 cm. Critical

Drain.

Add 1 natural strip. Now have 2 fuel plates and 3 natural strips. Poison = 41.4%

1406

Water at <sup>18.5</sup> 56.4 cm. + period #3

$T = 69.2$  sec  $p = 13.0\%$

1414

Water at <sup>13.15</sup> 51.05 cm. Critical

$240 - 41.4 - 15.6 = 183.0\%$  <sup>29.1</sup>

Drain

Now have 4 SPERT plates, 6 enriched and 3 natural strips. Total poison = 201.6

$391 - 201.6 = 189.4$



9/1/66

1517

Water at 58.8 cm. + Period #4

T = 112.6 gm 9.2%

1526

Water at 52.5 cm. Critical

Dry

391 - 201.6 - 9 = 180.4 ± 20.1

SPERT element with 2 fuel plates, 3 natural straws

1607

Water at 56.0 cm. + Period #5

T = 62.1 gm 14.1%

1614

Water at 51.1 cm. Critical.

Dry

243 - 41.4 - 15.6 = 186.0 ± 9.1

8/2/66

## INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE	SET	START-UP RANGE
K-1	3x10 <sup>-12</sup>	Meter ✓ Dist ✓	4"		3x10 <sup>-12</sup>
K-2	3x10 <sup>-12</sup>	Meter ✓ Dist ✓	4"		3x10 <sup>-12</sup>
R-1	—				
R-2	—				
PM-1	2000	Alarm ✓	Constant		5000
PM-2	12000	Low ✓ Alarm ✓	10" 2"		9000
LOG IN CALIBRATE ✓		OPERATE ✓	SOURCE No. B-80		
DIPAS WHEEL FLYING LIGHT —					

## START-UP CHECK LIST

Equipment checked by EJ, IDC Personnel check by IDCInstruments and safeties checked and reset by EJSource in checked by IDC Source No. M-43Emergency equipment in control room checked by IDCInstruments in trip circuit: K-1, K-2, PM-1, PM-2Red light on by EJ Time 0945Start-up OK'd by EJ, IDC Date 8/2/66

8/2/66

Element #11 in Well; SPERT element with 2 fuel plates and 3 natural strips.

1030

Wet W at 58.1 cm. + Period #1

1035

Wet W at 51.8 cm. Critical

Drain

$$270 - 41.4 - 11.4 = 187.24 \pm 9.1$$

Now have 4 fuel plates, 6 enriched and 3 natural strips.

$$391 - 201.5 - 189.0 =$$

1128

Wet W at 58.1 cm. + Period #2

1139

Wet W at 54.1 cm. Critical

Drain

$$391 - 201.6 - 4.7 = 184.74 \pm 20.1$$

Stopped data

summary 5/14/66

See summary sheet in  
Reed's file marked  
operating history

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	$3 \times 10^{-12}$	Motor -	2"	-	$3 \times 10^{-12}$
"	"	Fret ✓	"	✓	"
K-2	"	Motor -	"	-	"
"	"	Fret ✓	"	-	"
R-1					
R-2					
PM-1	700V	Alarm ✓	cont	-	500V
PM-2	1200V	Low ✓	12"	✓	900V
"	"	Alarm ✓	3"	-	"

LOG N CALIBRATE  OPERATE  SOURCE No. B-80  
 DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by <sup>E.D.C.</sup> AKH Personnel check by AKH  
 Instruments and safeties checked and reset by AKH  
 Source in checked by AKH Source No. M-43  
 Emergency equipment in control room checked by E.D.C.  
 Instruments in trip circuit: K-1-2 PM-1-2  
 Red light on by AKH Time 1345  
 Start-up OK'd by E.D.C. AKH Date 1-12-66

*ans*

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	$3 \times 10^{-12}$	Meter ✓	cont	✓	$3 \times 10^{-12}$
	"	Fast ✓	"	✓	"
K-2	"	Meter ✓	2"	✓	"
	"	Fast ✓	"	✓	"
R-1					
R-2					
PM-1	700 V	Alarm ✓	cont	✓	500 V
PM-2	1200 V	Low ✓	10"	✓	900 V
	"	Alarm ✓	2"	✓	"

LOG N CALIBRATE  OPERATE  SOURCE No. B-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by AKP Personnel check by FIDC  
 Instruments and safeties checked and reset by AKP  
 Source in checked by AKP Source No. M-43  
 Emergency equipment in control room checked by FIDC  
 Instruments in trip circuit: K-1-2 PM-1-2  
 Red light on by AKP Time 0910  
 Start-up OK'd by FIDC AKP Date 1-13-67

over

Cones 20-0 + 20-1

Now have spent element with 4 fuel plates, and 6 enriched strips, and 3 <sup>(2,3,4)</sup> natural strips.  $P_{\text{min}} = 201.6 \pm 195.5$

1103 Water ht = 21.0 cm Water Temp °C  
 + Per.  $\pm 1 = 24.2$   
 $C = 158.6 \text{ m} = 6.8 \text{ f}$   $\pm 2 = 24.2$

11.11 Water ht = 15.20 cm

System just critical

Drain  $391.0 - 160.2 - 41.7 - 6.8 = 182.3 \text{ f}$   
 $195.5 \quad 188.7$   
 $391 - 201.6 - 6.8 = 182.6 \text{ f} \pm 20.1$

Cones 20-0 + 20-1.

1310

Now have spent element with 2 fuel plates (# 0 - 3224 + 0 - 5495), and <sup>4</sup> natural strips.  $P_{\text{min}} = 55.2 \pm 9.8$   
 $2.3, 4, 4.5$   
 $\pm 2.3 \text{ f}$

1341 Water ht = 21.10 cm Water Temp °C  
 (3) + Per.  $\pm 1 = 24.3$   
 $C = 912.7 \text{ m} = 1.4 \text{ f}$   $\pm 2 = 24.3$

1351 Water ht = 19.20 cm

System just critical

Drain  $240.0 - 55.20 - 1.4 = 183.4 \text{ f}$   
 $2.6 \quad 186.5$   
 $240 - 55.2 - 0.9 = 183.9 \text{ f} = 9.8$

60

Fuel rate = 2.9 cm/min.

 $\frac{3}{4}$ " drain rate = 9.8 cm/min.

3" deep rate = 73.9 cm/30 sec.

also water ht on mirror scale  
reads:

8.9 cm outer element core

9.1 cm inner element core.

Repeat of critical conditions with CE-2 core.  
See page 116 & 117 in H.E. i.R. Log book #1.  
Have core only; for first run.

1430

Water ht = 22.4 cm

System sub critical

1455

Now have the spent fuel element installed, with  
4 fuel plates. # D-3224, D-5495, D-3242, ~~old~~  
D-2870. also have 3 enriched boron strips # 5  
4, 8, & 10. and 1 natural strip # 2.

Power = 93.9  $\mu$ 

1525

Water ht = 21.10 cm

System just critical

Drain.

391 - 93.9 = 297.1  $\mu$

62

20 den water ht on mirror scale  
 made 10.4 cm water is even with top of plate. When  
 it made 9.8 cm water is even with top of outer fuel plate <sup>of inner core</sup>

Have cones #<sup>5</sup> 20-0 and 20-1 assemble in  
 small reflection tank. Inner core spaced  
 3.75" with plastic spacers.

0947 Water ht = 21.0 cm Water Temp °C  
 System sub critical.  $\alpha_1 = 24.0^\circ$   
 $\alpha_2 = 24.0^\circ$

Now have spent fuel elements installed with  
 4 fuel plates. #D-3224, D-5495, D-3242, and  
 D-2870. Also have 6 enriched strips # 2, 3,  
 7, 8, 9, 10, and 2 natural strips # 2 & 3. Spent  
 fuel plates are 1.250" below top of inner core  
 fuel plates.  $P_{inner} = 187.84$   
 $182.24$

1048 Water ht = 18.80 cm Water Temp °C  
 + Per.  $\alpha_1 = 24.2$   
 $\alpha_2 = 39.1 \text{ cm} = 19.34$   $\alpha_2 = 24.2$

1051 Water ht = 12.6 cm  $391 - 182.2 - 18 = 195.8$   
 System just critical Core  $391 - 187.8 - 19 = 184.24$   
 Drain to ~ 0.0 cm on mirror scale. and  $\pm 19.4$   
 added 1 natural ~~sp~~ strip # 4.

— New (7.5) colls of strips



new Core  
has  
2 plates

Core 20-0 + 20-1

Now have spent element with 9 fuel plates,  
and 6 enriched strips, and 3 <sup>(2,3,4)</sup> natural  
strips.  $\text{Power} = 201.6 \text{ } \mu\text{W}$   
195.5

°C  
4.0°  
4.0°

1103 Water ht = 21.0 cm

Water Temp °C

+ Per.  
 $C = 158.6 \text{ } \mu\text{W} = 6.8 \text{ } \mu\text{W}$

#1 = 24.2

#2 = 24.2

1111 Water ht = 15.20 cm

System just critical

Drain  $\frac{391.0}{195.5} - 160.2 - 41.7 - 6.8 = 182.3 \text{ } \mu\text{W}$

$391 - 201.6 - 6.8 = 182.6 \text{ } \mu\text{W} \pm 0.1$

it's  
and  
1.3.  
ent  
e

Core 20-0 + 20-1.

1310

Now have spent element with 2 fuel  
plates (# 0 - 3224 + 0 - 5495), and <sup>4</sup>  
natural strips.  $\frac{2.3, 4, 2.5}{2.3, 4}$   $\text{Power} = 55.2 \pm 9.8$

°C  
24.2  
24.2  
9.8  
4.2  
9.8  
end

1341 Water ht = 21.10 cm

Water Temp °C

(3) + Per.  
 $C = 912.7 \text{ } \mu\text{W} = 1.4 \text{ } \mu\text{W}$

#1 = 24.3

#2 = 24.3

1351 Water ht = 19.20 cm

System just critical

Drain  $\frac{240.0}{195.5} - 55.20 - 1.4 = 183.4 \text{ } \mu\text{W}$

$240 - 55.2 - 0.9 = 183.9 \text{ } \mu\text{W} = 9.8$

64

1/16/67

## INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	TRIP	SET	START-UP RANGE
K-1	3 X 10 <sup>-12</sup>	Alarm	✓	2"	3 X 10 <sup>-12</sup>
		Test	✓		"
K-2	3 X 10 <sup>-12</sup>	Meter	✓	2 1/2"	"
		Test	✓		"
R-1	—				
R-2	—				
PM-1	700V	Alarm	✓	Contact	500V
PM-2	1200V	Low	✓	10"	900V
		Alarm	✓	2"	"

LOG N CALIBRATE OPERATE 

SOURCE No.

B-80

DUMP WELL PROBE LIGHT 

## START-UP CHECK LIST

Equipment checked by ef & RKL Personnel check by RKLInstruments and safeties checked and reset by efSource in checked by RKL Source No. M-93Emergency equipment in control room checked by RKLInstruments in trip circuit: K-1-2 PM-1-2Red light on by RKL Time 0920Start-up OK'd by ef RKL Date 1-16-67

Have cores 21-0 & ~~21-0~~<sup>21-1</sup> available in small reflector tanks. Inner core spaced, 3.75" with ~~reflector~~ spacer.

1003

Water ht = 21.0 cm  
System sub critical  
Drain

Now have spent element with 2 fuel plates. (# D-3224 & D-5495) and 4 natural boron strips. (# 2, 3, 4 & 5) Power = <sup>52.6</sup>55.2 ± 9.8

1045

Water ht = 21.10 cm  $\Delta h = 5.90$   
+ Per  
 $\tau = 143.4 \text{ sec} = 7.4 \text{ f}$

1049

Water ht = 15.20 cm  
System just critical  
Drain  
 $240 - 52.6 - 180.6 - 240.0 - 55.2 - 7.4 = 177.4 \text{ f}$   
 $240 - 55.2 - 6.8 = 178.0 \pm 9.8$

Now have spent element with 4 fuel plates. (# D-3224 & D-5495, D-3242, & D-2870) Plus 6 enriched strips (#s 2, 3, 7, 9, 10) and 3 natural strips (# 2, 3, 4) and 4 stainless steel strips Power = 206.8 200.7 sec. ± 20.1

1340 Water ht = 21.15 cm

2. + per

$$T = 152.1 \text{ sec} = 7.0 \text{ f}$$

Water Temp °C

1352. Water ht = 15.25 cm.

# 124.0

System just critical

2 = 24.2

Crain.

$$391.0 - 160.2 - 41.4 - 5.20 - 7.0$$

200.7

180.5

$$= 173.0 \text{ f}$$

$$391 - 206.9 - 6.8 = 177.7 \pm 20.1$$

1353

Scramed system: Check system's scram system with scram bottom.

Core #s 22-0 & 22-1

Have core 22-0 & 22-1 ensemble in small reflector tank. Inner core spaced .375" with plastic spacers.

1500 Water ht = 21.20 cm

System sub critical

Crain.

Now have spent fuel element with 4 plates, 6 enriched strips, 3 natural strips, and 4 stainless steel strips. (See bottom of page 65 for numbers.)

$$\text{Power} = 200.7$$

$$= 206.7$$

REQUISITION

684502

'67 JAN 9 PM 2:27

REPORT TO

*R. K. Rudy*

BUILDING NO.

9213

PHONE NO.

3-5237

00000004										
										g U/g
										g Ay/g
										g D/g
										g H/g
										g Mo/g
										g F/g
										SPEC.
										ASSAY

Water sample of  
 reflective water from  
 H.F.I.R. elements.  
 1-12-67

<i>Chen</i>	REF. BY
<i>1-11-67</i>	DATE
	DEPT.
<i>7</i>	

1603 Water ht = 21.20 cm  
 System very slightly - Neg.  
 Drain -  $\approx 150$  = cur

Water Temp °C  
 #1 = 29.9  
 2 = 29.9

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	$3 \times 10^{-12}$	Meter	1"	-	$3 \times 10^{-12}$
"	"	Fast	"	-	"
K-2	"	Meter	2"	-	"
"	"	Fast	"	-	"
R-1					
R-2					
PM-1	700V	Alarm	cent	-	500V
PM-2	1200V	Low	10"	-	900V
"	"	Alarm	1"	-	"

LOG N CALIBRATE  OPERATE  SOURCE No. B-82

DUMP WELL PROBE LIGHT

6.0  
1.0  
2.2

rel

tw,

re

START-UP CHECK LIST

Equipment checked by AKH Personnel check by F.D.C  
 Instruments and safeties checked and reset by AKH  
 Source in checked by AKH Source No. 14-43  
 Emergency equipment in control room checked by F.D.C  
 Instruments in trip circuit: X-1-2 PM-1-2  
 Red light on by AKH Time 1030  
 Start-up OK'd by F.D.C AKH Date 1-17-67

cores 22-0 + 22-1

~~7th~~  
 Remove the 4 stainless steel strips, now  
 have 4 fuel plates. 6 enriched strips and  
 3 natural strips. <sup>195.5</sup>  $\rho_{in} = 201.6$

1103 Water ht = 21.40 cm Water Temp °C  
 (1) - Per  $\rho_1 = 24.0$   
 $\rho = -1303.80 \text{ cm} = -1.0 \text{ f}$   $\rho_2 = 24.2$

1112 Drain. <sup>195.5</sup>  $351 - 201.6 + 1.0 = 190.4 \pm 20.1$  <sup>195.5</sup>

Removed 1 natural strip ( $\rho = 1$ ), and added  
 6 stainless steel strips:  
<sup>190.0</sup>  $\rho_{in} = 155.8$



1305 Water ht = 21.40 cm.  
 (2) + Per.

Water Temp °C

#1 = 24.0

$t = 149.9 \mu = 7.1 \text{ } \mu$

#2 = 24.2

1316 Water ht = 15.00 cm.

Leakage just initial  
 Drains.

391.0 - 160.2 - 27.6 - 7.8

- 7.1 = 188.9  $\mu$

190.0 193.2  
 $351 - 195.8 - 7.8 = 187.4 \pm 19.5$

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	$3 \times 10^{-12}$	Meter ✓	1"	✓	$3 \times 10^{-12}$
	"	Fast ✓	"	✓	"
K-2	"	Meter ✓	"	✓	"
	"	Fast ✓	"	✓	"
R-1					
R-2					
PM-1	<del>700V</del> 500V	Alarm ✓	Cont	✓	500V
PM-2	<del>1200V</del> 900V	Low ✓	12"	✓	900V
	"	Alarm ✓	2"	✓	"

LOG N CALIBRATE

OPERATE

SOURCE No.

13-801

DUMP WELL PROBE LIGHT

w  
ml  
0  
c  
24.0  
24.2

2

## START-UP CHECK LIST

Equipment checked by R.K.H. <sup>I.O.C.</sup> Personnel check by F.D.C.  
 Instruments and safeties checked and reset by R.K.H.  
 Source in checked by R.K.H. Source No. M-43  
 Emergency equipment in control room checked by F.D.C.  
 Instruments in trip circuit: Z-1-2 PM-1-2  
 Red light on by R.K.H. Time 0830  
 Start-up OK'd by R.K.H. I.O.C. Date 1-18-67

Conv 22-0 & 22-1

Now have spent fuel element with  
 2 fuel plate ( $\square$  D-3224 & D-5495) and <sup>4</sup>  
 natural strips ( $\square$  <sup>2.3405</sup> ~~2.3405~~). Power = 52.6

0930 Water ht = 21.4 cm  
 System sub critical  
 Drain.

0935 Remained #5 natural strip, and added  
 6 stainless steel strips.

Water ht = 22.0 cm  
 + Res  
 $\tau = 434.60 \text{ sec} = 2.7 \text{ f}$   
 Power = 49.4 f  
 Water Temp °C  
 $t_1 = 24.2$   
 $t_2 = 24.2$

1002

Water ht = 17.90 cm  
System just critical

Drain:  $240.0 - 40.4 - 7.8 - 2.7 = 189.1$   
 $240 - 45.2 - 2.4 = 192.4$

Cores # 19-0 & 19-1

1430

Now have cores 19-0 & 19-1 assembled in small reflector tank. Brown core spaced .375" with plastic spacers.

Water ht = 21.50 cm  
System sub critical  
Drain:

Now have spent fuel element with 2 fuel plates (#s 15-3224 & 10-5495) and 4 radial strips (# 2, 3, 4 & 5). Poisson = 55.2

1554

Water ht = 21.30 cm  
System sub critical  
Drain:

Water temp °C  
#1 = 29.2  
2 = 29.5

## INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	$3 \times 10^{-12}$	Meter ✓	1"	✓	$3 \times 10^{-12}$
	"	✓	"	✓	"
K-2	"	Meter ✓	"	✓	"
	"	✓	"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	Cont	500V	
PM-2	1200V	low ✓	12"	900V	
	"	Alarm ✓	3"	"	
LOG N CALIBRATE		✓	OPERATE	✓	SOURCE No. B-80
DUMP WELL PROCBE LIGHT _____					

## START-UP CHECK LIST

Equipment checked by AKV Personnel check by F.P.C.

Instruments and safeties checked and reset by AKV

Source in checked by AKV Source No. M-93

Emergency equipment in control room checked by F.P.C.

Instruments in trip circuit: K-1-2 PM-1-2

Red light on by AKV Time 0825

Start-up OK'd by F.P.C. AKV Date 1-19-67

Cover 19-0 + 19-1

Remained #5 natural strips (see page 71) and added 3 stainless steel strips. P<sub>air</sub> = 45.3

0855 Water ht = 21.40 cm Water Temp °C  
 + P<sub>air</sub> #1 = 24.0  
 T = 532.4 rev p = 2.34 2 = 24.2

0915 Water ht = 17.80 cm  
 System just critical  
 Drain

$$240 - 45.3 - 2.3 = 192.4 \text{ NE}$$

1045 Now have spent element with 4 fuel plates  
 (#s D-3224, D-5495, D-3242, & D-2870.) 6  
 enriched strips (# 2, 3, 7, 8, 9 + 10.) and 2 natural  
 strips (# 2 & 3) ~~and 4 stainless steel strips.~~  
 P<sub>air</sub> = 187.8

1115 Water ht = 21.50 cm Water Temp °C  
 System slightly - Neg. 1 = 24.0  
 Drain 24.2

Core 203 NE

see

Core 19-0819-1

Removed natural strip #3 and added 3 stainless steel strips.

6 enriched, 1 natural, 3 SS

Water Temp °C

Water ht = 21.20 cm

#1 = 24.2

<sup>2</sup>+ Per.

24.5

$\epsilon = 543.25 \mu\text{m} = 2.3 \%$

1350 Water ht = 17.6'

System just critical ~~177.9~~

Power =  $391.0 - 160.20 - 13.80 - 3.90 - 2.3$   
 $= 210.80 \%$

$391 - 177.9 - 2.3 = 210.8 \%$  NG

In order to check above, removed natural strip #2 and added 3 stainless steel strip. Now have as shown on page 73, 4 fuel plates, 6 enriched strips, and 6 stainless steel strips.

Power = 168.0

Water ht = 21.50 cm

Water Temp °C

<sup>3</sup>+ Per

#1 = 24.3

$\epsilon = 78.2 \mu\text{m} = 11.9 \%$

2 = 24.5

1452 Water ht = 19.20 cm

System just critical

Power =  $391.0 - 160.2 - 7.8 - 11.9 = 211.1$  NG

Cores 18-0 + 18-1

1530

Now have cores 18-0 + 18-1 ~~assemble~~ in  
small refueler tank. Inner core spaced  
.375" with plastic spacers.

1559

Water ht = 21.2 cm  
System sub critical  
Drain.

## INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	$3 \times 10^{-12}$	Meter <input checked="" type="checkbox"/>	1"	<input checked="" type="checkbox"/>	$3 \times 10^{-12}$
"	"	Fast <input checked="" type="checkbox"/>	"	<input checked="" type="checkbox"/>	"
K-2	"	Meter <input checked="" type="checkbox"/>	"	<input checked="" type="checkbox"/>	"
"	"	Fast <input checked="" type="checkbox"/>	"	<input checked="" type="checkbox"/>	"
R-1					
R-2					
PM-1	700V	Alarm <input checked="" type="checkbox"/>	Cent	<input checked="" type="checkbox"/>	500V
PM-2	1200V	Low <input checked="" type="checkbox"/>	12"	<input checked="" type="checkbox"/>	900V
"	"	Alarm <input checked="" type="checkbox"/>	3"	<input checked="" type="checkbox"/>	"

LOG N CALIBRATE  OPERATE  SOURCE No. B-80  
DUMP WELL PROBE LIGHT

## START-UP CHECK LIST

Equipment checked by RKH <sup>F.P.C.</sup> Personnel check by F.P.C.  
 Instruments and safeties checked and reset by RKH  
 Source in checked by RKH Source No. 19-43  
 Emergency equipment in control room checked by F.P.C.  
 Instruments in trip circuit: K-1-2 PM-1-2  
 Red light on by RKH Time 0840  
 Start-up OK'd by F.P.C. RKH Date 1-20-67

Core 19-0 & 19-1

Purpose is to check critical as shown on top of page 73. Have spent fuel element with 2 fuel plates (# D-3224 & D-5495) and 3 natural strips (# 2, 3, 4.) and 3 stainless steel strips.  $P_{air} = 45.3$

Water ht = 21.30 cm

Water Temp °C

(1) + Res

$T_1 = 24.2$

$T = 21.3 \text{ cm} = 5.2 \text{ f}$

$T_2 = 24.3$

0937 Water ht = 15.80 cm

System just critical  
 Drain.

$240.0 - 43.6 - 191.3 \checkmark$   
 $240.0 - 45.3 - 5.2 = 189.5 \text{ f. N.G.}$

Page 73 = 190.4 f  
 1-19-67



Now have spent element with 4 fuel plates  
 (# D-3224, D-5495 D-3242 & D-2870), and  
 6 enriched strips (# 2, 3, 7, 8, 9, & 10) and 6  
 stainless steel strips. 168.0¢

Water ht = 21.30 cm.  
 (24 per  
 5 - 28.25 cm = 23.5¢

Water temp °C  
 # 1 = 29.3  
 2 = 29.3

1100 Water ht = 12.50 cm  
 system just critical

Drain: 391.0 - 160.2 - 7.8 - 23.5 NE  
 = 199.5¢ ✓

1-20-67  
 1300

added more water to hold tank.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3x10 <sup>-12</sup>	Meter ✓	1"	✓	3x10 <sup>-12</sup>
	"	Fast ✓	"	✓	"
K-2	"	Meter ✓	"	✓	"
	"	Fast ✓	"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	cont	✓	500V
PM-2	1200V	Low ✓	12"	✓	900V
	"	Alarm ✓	3"	✓	"

LOG N CALIBRATE  OPERATE  SOURCE No. B-80

DUMP WELL PROBE LIGHT

1/2 of

29.2  
 24.3

G.

## START-UP CHECK LIST

Equipment checked by I.C. AKM Personnel check by FID.CInstruments and safeties checked and reset by AKMSource in checked by AKM Source No. M-23Emergency equipment in control room checked by FID.CInstruments in trip circuits K-1-2 PCM-1-2Red light on by AKM Time 0810Start-up OK'd by FID.C AKM Date 1-23-67

Purpose is to check critical conditions shown  
on page 77. (4 full plates, 6 enriched strips  
and 6 stainless steel strips) 148.0 f

Water ht = 21.40 cm

Water Temp °C

+ Res.

#1 = 24.5<sup>3</sup>

C = 30.4 m = 22.5 f

#2 = 25.0<sup>5</sup>

0850 Water ht = 12.50 cm

Lepton just critical

391.0 - 160.2 - 7.8 - 22.5

= 200.5 f ✓ NE

Removed 3 stainless steel strips, and added  
natural strip # 2. (see page 74.) 177.9

Water ht - 21.30 cm

Water Temp °C

+ Res

#1 = 25.0<sup>7</sup>

C = 16.06 m = 12.2 f

#2 = 25.0<sup>3</sup>

0956 Water ht = 13.80 cm

System just critical

Drain

391.0 - 160.2 - 13.8 - 3.9 - 12.2

Core = 200.9 g ✓ NE

New core spent element with 7 fuel plates (2 D-3224 + D-5495) with 3 natural strips and 3 stainless steel strips. 45.3

Water ht = 21.50 cm

Water Temp °C

+1.5

#1 = 25.2

$\sigma = 386.8 \text{ cm} = 3.1 \text{ f}$

#2 = 25.5

1106 Water ht = 17.30 cm.

System just critical

Drain

240.0 - 41.4 - 3.9 - 3.1

Core = 191.6 g ✓ NE

2.2  
Temp

0  
24.3  
5  
25.0

5

2.2

0  
Temp  
25.0  
3  
25.0

## INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE	SET	START-UP RANGE
K-1	$3 \times 10^{-12}$	Meter <input checked="" type="checkbox"/>	1"	<input checked="" type="checkbox"/>	$3 \times 10^{-12}$
	"	Fast <input checked="" type="checkbox"/>	"	<input checked="" type="checkbox"/>	"
K-2	"	Meter <input checked="" type="checkbox"/>	"	<input checked="" type="checkbox"/>	"
	"	Fast <input checked="" type="checkbox"/>	"	<input checked="" type="checkbox"/>	"
R-1					
R-2					
PM-1	700V	Alarm <input checked="" type="checkbox"/>	cont	<input checked="" type="checkbox"/>	500V
PM-2	1200V	Low <input checked="" type="checkbox"/>	12"	<input checked="" type="checkbox"/>	900V
	"	Alarm <input checked="" type="checkbox"/>	3"	<input checked="" type="checkbox"/>	"

LOG N CALIBRATE OPERATE 

SOURCE No.

B-80

DUMP WELL PROBE LIGHT 

## START-UP CHECK LIST

Equipment checked by F.D.C. R.K.V. Personnel check by F.D.C.Instruments and safeties checked and reset by R.K.V.Source in checked by R.K.V. Source No. M-93Emergency equipment in control room checked by F.D.C.Instruments in trip circuit: K-1-2 PM-1-2Red light on by R.K.V. Time 0915Start-up OK'd by F.D.C. R.K.V. Date 1-24-67

Cores 19-0 &amp; 19-1

Have spent element with 2 fuel plates  
(#5 D-3224 & 0-5495), and 1 enriched  
strip and 1 natural strip. 40.5

0858 Water ht = 22.10 cm Water Temp °C  
+ Pen #1 = 25.5 ?  
2 = 25.7 ?

0905 Water ht = 13.45 cm  
System just critical  
Drain 240.0 - 40.5 - 15.5  
Core = 184.0 NE

C.F. - 2 Core!

Water ht = 21.60 cm Water Temp °C  
2 + Pen #1 = 25.7 ?  
5 = 173.8 sec = 6.3 f 2 = 26.0 ?

1132 Water ht = 13.80 cm  
System just critical  
Drain 391.0 - 93.6 - 6.3  
Core = 291.4 f

aver.

1-24-67

Cores 18-0 & 18-1.

See page 75 for 1st or sub critical exp't,  
for above # elements.

Now have spent element with 4 fuel  
plates. (#5 D-3224, D-5495, D-3242 and D-2870)  
and 6 enriched strips, (# 2,3,7,8,9 & 10) and  
~~6 stainless steel strips, and 3 natural strips~~  
# 2,3, & 4.  $P_{\text{power}} = 195.5$   
 $\pm 201.3 \pm 231$

1445 Water ht = 21.50 cm  
3 + Per  
 $\bar{I} = 182.5 \text{ sec} = 6.0 \text{ f}$

Water Temp °C  
#1 = 26.0  
#2 = 26.2

1455 Water ht = 15.60 cm  
System just critical  
Droiss.  $391.0 - 160.2 - 41.4 - 6.0$

note when  
measured with  
thermometer temp  
= 24.0°

$195.5$   
 $189.5$   
Core =  $183.40 \text{ f} \pm 20.1$   
 $183.7$

Now have spent element with 2 fuel plates  
(#5 D-3224, D-5495) with 4 natural strips  
(# 2,3,4,5)  $P_{\text{power}} = 52.6$   
 $55.1 \pm 9.8$

Water ht = 21.60 cm  
+ Per.  
 $\bar{I} = 669.3 \text{ sec} = 1.8 \text{ f}$

Water Temp °C  
#1 = 26.2  
#2 = 26.5

1600 Water ht = 18.55 cm  
 System just critical  
 Drum

240.0 - <sup>52.6</sup>55.2 - 1.8  
<sup>183.0</sup>Core = 183.0 ± 9.0

-2870  
 Temp

26.0  
 66.2  
 Temp

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	$3 \times 10^{-12}$	Meter ✓	1"	-	$3 \times 10^{-12}$
	"	Fast ✓	"	-	"
K-2	"	Meter ✓	"	-	"
		Fast ✓	"	-	"
R-1					
R-2					
PM-1	700V	Alarm ✓	Cont	-	500V
PM-2	1200V	Low ✓	12"	-	900V
	"	Alarm ✓	3"	-	16"

LOG N CALIBRATE  OPERATE  SOURCE No. 12-80

DUMP WELL PROBE LIGHT

6.2  
 6.5

## START-UP CHECK LIST

Equipment checked by ARK <sup>F.P.C.</sup> Personnel check by F.P.C.Instruments and safeties checked and reset by ARK.Source in checked by ARK Source No. M-93Emergency equipment in control room checked by ARK F.P.C.Instruments in trip circuit: Z-1-2 PA-1-2Red light on by ARK Time 1045Start-up OK'd by F.P.C. ARK Date 1-25-67

Core 18-0 + 18-1

Now have spent element with 2 fuel plates,  
 (1<sup>st</sup> D-3224 + D-5495), with 3 natural strips,  
 and 6 stainless-steel strips. P<sub>in</sub> = 47.7  
 49.4

Water ht = 21.60 cm

Water Temp °C

① + Per

21 = 26.0

C = 191.2 sec = 5.8 f

2 = 26.0

1130 Water ht = 15.80 cm

Temp = 24.0

System just critical  
 Drain -

240.0 - 41.4 - 7.8 - 5.8

Core = 185.0 f 186.8

184.8 = 9.2



F 25-67

Cores 17-0 & 17-1

Have cores 17-0 & 17-1 assembled in small reflector tanks. Inner core spaced .375" with plastic spacers.

14.15 Water ht = 21.60 cm Water Temp °C  
 krypton sub critical. #1 = 26.0 ?  
 #2 = 26.0 ?  
 therm reads 24.0 °C ?

now have spent fuel element with 2 fuel plates (DS D-3224 & D-5495), with 3 natural strips and 6 stainless steel strips.  $P_{max} = 47.4$   
 49.4

15.00 Water ht = 21.60 cm Water Temp °C  
 7. per  
 $\tau = 41.3 \text{ sec} = 18.6 \text{ f}$   
 Water ht = 13.0 cm  
 krypton just critical  
 Drain  $47.4$   
 $240.0 - 41.4 - 7.8 - 18.6$   
 $174.2$   
 $172.2 \text{ f}$   
 $172.0 \pm 9.2$

temp,  
 temp,  
 °C  
 °C  
 °C

over -

Removed 4 stainless steel strips. and added #5 natural strip. <sup>52.6</sup>  $\gamma_{rain} = 57.8 \%$

Water ht = 21.60 cm  
 + Per.

Water Temp °C

$\tau = 99.9 \text{ min} = 9.9 \%$

#1 = 26.2

#2 = 26.5

Therm - 24.00

rec'd off 2.0°

check by E.A.P.

1530

Water ht = 14.40 cm

System just critical

Drain:

<sup>52.6</sup> 240.0 - 55.2 - 2.6 - 9.9

core = 172.3  $\pm$  9.5

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	$3 \times 10^{-12}$	Meter ✓	1"	✓	$3 \times 10^{-12}$
	"	Fast —	"	✓	"
K-2	"	Meter ✓	"	✓	"
	"	Fast —	"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	Cont	✓	500V
PM-2	1200V	Low ✓	12"	✓	900V
	"	Alarm ✓	3"	✓	"

LOG N CALIBRATE  OPERATE  SOURCE No. B-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by AKM <sup>F.I.C.</sup> Personnel check by F.I.C.

Instruments and safeties checked and reset by AKM.

Source in checked by AKM Source No. M-43

Emergency equipment in control room checked by F.I.C.

Instruments in trip circuit: K-1-2 PM-1-2

Red light on by AKM Time 0810

Start-up OK'd by F.I.C. AKM Date 1-26-67

over

7.8  
6 °C  
= 26.2  
26.5  
2.00  
2.00  
11.

1-20-67

Cores 17-0 + 17-10

New low spent fuel element with 9  
fuel plates (# 0-3224, 0-5495, 0-3242 &  
0-2570.) and 8 enriched strips (#<sup>S</sup> 2,3,4,5,7,8,  
9,10).  $P_{\text{max}} = 205.8$   
 $\approx 13.3 \pm 1.5$

Water ht = 21.6 cm  
(1) + Per  
 $T = 119.52 \text{ cm} = 8.6 \text{ f}$

Water Temp °C  
#1 = 24.2  
2 = 24.2

0912 Water ht = 14.7 cm  
System just critical  
Drain.  $391.0 - 213.6 - 8.6$   
 $\text{Core} = 168.8 \text{ f } 17.6 \text{ f}$   
 $169.1 \pm 1.5$

Removed enriched strip #2. and added  
natural strip #2. also added 8 stainless-  
steel strips.  $P_{\text{max}} = 203.5$   
 $\approx 11.1$

Water ht = 21.5 cm.  
2 + Per  
 $T = 117.3 \text{ cm} = 8.6$

Water Temp °C  
#1 = 24.0  
2 = 24.2

1020 Water ht = 14.70  
System just critical.  $391.0 - 211.1 - 8.8$   
Drain to  $\approx 10.0$  cm. Repeating +  
Per.  $\text{Core} = 171.1 \text{ f } 17.8 \text{ f}$

Water ht = 21.5 cm.

+ Per

C = 119.5 sec = 8.6 f

1036

Water ht = 14.70 cm

System just critical  
Cross

391.0 - 211.1 - 8.6

core = 179.5 f ± 15.3

Cores 16-0 & 16-1

Have cores 16-0 & 16-1 assembled in small reflector tank. Inner core spaced .375" with plastic spacers.

1320

Water ht = 21.50

System sub critical

Water Temp °C

21 = 24.2

2 = 24.5

Now have spent fuel elements with 4 fuel plates (#0-3224, D-5495, D-3242 & D-2870). And 6 enriched strips (#2, 3, 7, 8, 9, 10.) and 3 natural strips (# 2, 3 & 4.) Power = 15.55

201.3 ± 20.1

avg

Conds 16-0 & 16-1

Water ht = 21.50 cm

Water Temp °C

+ Per

#1 = 29.5

C = 219.5 mm = 5.1 f

2 = 25.5

1415. Water ht = 15.70 cm

System just critical

Drain

155.5  
391.0 - 201.6 - 5.1  
184.3 f  
184.0 ± 19.1

Removed 2 natural strips #3 & 4, and added enriched strip #4. P = 200.4 ± 19.5

Water ht = 21.5 cm

Water Temp °C

+ Per

#1 = 29.5

C = 165.1 mm = 6.6 f

2 = 29.5

1522 Water ht = 15.45 cm

System just critical

Drain

195.3  
391.0 - 200.7 - 6.6  
183.7 189.1  
184.0 ± 19.5

### INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	$3 \times 10^{-12}$	Meter <input type="checkbox"/>	1"	<input checked="" type="checkbox"/>	$3 \times 10^{-12}$
	"	Fast <input checked="" type="checkbox"/>	"	<input type="checkbox"/>	"
K-2	"	Meter <input checked="" type="checkbox"/>	"	<input checked="" type="checkbox"/>	"
		Fast <input checked="" type="checkbox"/>	"	<input checked="" type="checkbox"/>	"
R-1					
R-2					
PM-1	700 V	Alarm <input checked="" type="checkbox"/>	cont	<input checked="" type="checkbox"/>	500 V
PM-2	1200 V	Low <input checked="" type="checkbox"/>	12"	<input checked="" type="checkbox"/>	900 V
		Alarm <input checked="" type="checkbox"/>	3"	<input checked="" type="checkbox"/>	"

LOG IN CALIBRATE  OPERATE  SOURCE No. 13-8

DUMP WELL PROBE LIGHT

### START-UP CHECK LIST

Equipment checked by AKM F.D.C. Personnel check by J.D.C.

Instruments and safeties checked and reset by AKM

Source in checked by AKM Source No. 14-43

Emergency equipment in control room checked by F.D.C.

Instruments in trip circuit: K-1-2 PM-1-2

Red light on by AKM Time 0810

Start-up OK'd by F.D.C. AKM Date 1-27-67

*over*

1-27-67

Conv 16-0 + 16-1

Now have spent element with 2 fuel plates  
(#S D-3224 + D-5495), with 4 natural  
plates (# 2, 3, 4, + 5.)

0950

Water ht = 21.50 cm  
System just critical  
Drain

Water Temp °C  
#1 = 24.2  
2 = 24.2

$$\begin{array}{r} 240.0 - 52.2 \\ 187.8 \\ \text{Conv} = 184.8 \text{ f} \\ \pm 9.8 \end{array}$$

Removed natural strip #2, and added  
6 stainless-steel strips.

Water ht = 21.60 cm.  
+ per  
C = 278.1 rev = 4.2 f

Water Temp °C  
#1 = 24.5  
2 = 24.5

0940

Water ht = 16.70 cm  
System just critical.  
Drain to = 0.0 cm.

$$\begin{array}{r} 240.0 - 57.1 - 9.2 \\ \text{Conv} = 186.6 \text{ f} \quad 188.7 \\ 186.4 \pm 9.2 \end{array}$$



Rotated spent fuel element 90°. Not changing vertical height. No other changes made.

Water ht = 21.50 cm.

Water Temp °C

+ Per  
 $\tau = 271.6 \text{ sec} = 4.3 \text{ f}$

#1 = 24.5

2 = 24.5

1030

Water ht = 16.70 cm.

System just critical core = 186.5

Cores 19-0 + 19-1

Have spent element with 2 fuel plates. (#D-3228 + D-5495). with ~~one~~ 1 enriched strip (#2) and 1 natural strip (#2). see pag 81

Water ht = 21.5 cm

Water Temp °C

+ Per  
 $\tau = 52.2 \text{ sec} = 15.9 \text{ f}$

#1 = 24.5

2 = 24.5

1400

Water ht = 13.30 cm

System just critical  
 Drains.

240.0 - 40.5 - 15.9

Core = 183.6 & NE

aver.

1-27-67

Rotated spent fuel element 90°. Not changing vertical height. No other changes made.

Water ht = 21.60 cm.

4 + per

$$t = 45.6 \text{ sec} = 17.2 \text{ f}$$

1450 Water ht = 13.25 cm.

System just critical

Drain:

$$240 - 40.5 - 17.2 \text{ f}$$

$$\text{core} = 182.3 \text{ f } \text{MC}$$

Rotated spent fuel element back to its original pos. (page 93). Removed enriched strip #2. And added natural strips #3 & 4, and 3 stainless-steel strips. Total of 3 natural strips and 3 stainless-steel strips.

5 Water ht = 21.60 cm.

+ per

$$t = 115.2 \text{ sec} = 8.8 \text{ f}$$

Water Temp °C

$$\#1 = 24.7$$

$$\#2 = 25.0$$

1540 Water ht = 14.80 cm.

System just critical

Drain:

$$240.0 - 41.4 - 8.9 - 8.8$$

$$\text{core} = 186.9 \text{ MC}$$

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	$3 \times 10^{-12}$	Meter ✓	1"	✓	$3 \times 10^{-12}$
"	"	Fast ✓	"	✓	"
K-2	"	Meter ✓	1"	✓	"
"	"	Fast ✓	"	✓	"
R-1					
R-2					
RM-1	700V	Alarm ✓	0.2"	✓	500V
RM-2	1200V	Low ✓	12"	✓	900V
"	"	Alarm ✓	3"	✓	"
LOG N CALIBRATE ✓		OPERATE ✓		SOURCE No. 12-80	
PUMP WELL PROBE LIGHT _____					

START-UP CHECK LIST

Equipment checked by F.D.C. RMP Personnel check by F.D.C.

Instruments and safeties checked and reset by RMP

Source in checked by RMP Source No. M-43

Emergency equipment in control room checked by F.D.C.

Instruments in trip circuit: K-1-2 PM-1-2

Red light on by AKAP Time 1025

Start-up OK'd by F.D.C. RMP Date 1-30-67

*[Handwritten signature]*

0.7  
0.7  
0.8

Cores 19-0 + 19-1

Repeat of expt described on bottom of  
page 94. (1-27-67)

Water ht = 21.70 cm

+ Per

 $t = 152.1 \text{ sec} = 7.0 \text{ f}$ 

Water Temp °C

#1 = 22.7

2 = 23.0

Therm = 22.5

1105

Water ht = 15.40 cm

System just critical

Drain:

240.0 - 41.4 - 3.9 - 7.0

Core = 188.7 f

Repeat of above:

Water ht = 21.70 cm

+ Per.

 $t = 149.9 \text{ sec} = 7.1 \text{ f}$ 

Water Temp °C

#1 = 23.0

2 = 23.2

1318

Water ht = 15.40 cm

System just critical

Drain:

Now ~~top~~ have spent element with 4 fuel plates (#D-3224 & D-5495, D-3242, D-2870.) and 6 enriched strips (#2,3,7,8,9,10.) plus 6 stainless steel strips. (Spent fuel in some box + rest put in with 2 fuel plates).

Water ht = 14.7 cm

3 + Per

$\tau = 34.8 \text{ sec} = 20.7 \text{ f}$

Water Temp °C

#1 = 23.0

1350

Water ht = 11.6

2 = 23.0

System just critical

Drain.

$391.0 - 168.0 = 223.0$

core = 193.5 f  $\lambda =$

Rotated spent fuel 90°. Not changing vertical ht. No other changes made.

Water ht = ~~14.6~~ 14.6 cm

Water Temp °C

4 + Per

$\tau = 32.6 \text{ sec} = 21.6 \text{ f}$

#1 = 23.0

2 = 23.0

1415

Water ht = 11.6 cm

System just critical

Drain.

$391.0 - 168.0 = 223.0$

core = 193.6 f  $\lambda =$

over.

Rotated spent fuel element back to its original pos; Remained the 6 stainless-steel strips, and added 2 natural strips (# 2, + 3).

Water ht = 21.6 cm.

Water temp °C

5 + Per

#1 = 23.0

$\tau = 58.7 \text{ sec} = 14.7 \text{ f}$

2 = 23.2

1450 Water ht = 13.5 cm  
System just critical  
Drain.

391.0 - 160.2 - 27.6 - 14.7

core = 188.5 f 140

Added 4 stainless-steel strip to above. ~~Now have 4 fuel plates, 4 stainless-steel strip, 6 enriched strips, and 2 natural strips.~~  
Now have ~~4~~ 4 fuel plates, ~~4~~ 4 stainless-steel strip, 6 enriched strips, and 2 natural strips.

Water ht = 21.6 cm

Water temp °C

6 + Per

#1 = 23.2

$\tau = 117.3 \text{ sec} = 8.7 \text{ f}$

2 = 23.2

1550 Water ht = 14.70 cm.  
System just critical  
Drain.

391.0 - 160.2 - 27.6 - 5.2 - 8.7

core = 189.3 140

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	$3 \times 10^{-12}$	Meter ✓	1"	✓	$3 \times 10^{-12}$
	"	Fast ✓	"	✓	"
K-2	"	Meter ✓	"	✓	"
	"	Fast ✓	"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	cont	✓	500V
PM-2	1200V	Low ✓	12"	✓	900V
	"	Alarm ✓	3"	✓	"

LOG N CALIBRATE  OPERATE  SOURCE No. B-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by AKH F.P.C Personnel check by FID.C

Instruments and safeties checked and reset by AKH

Source in checked by AKH Source No. M-43

Emergency equipment in control room checked by FID.C

Instruments in trip circuit: K-1-2 PM-1-2

Red light on by AKH Time 0810

Start-up OK'd by FID.C AKH Date 1-31-67

*over*

20  
2  
3.2  
3.2  
8.7

Cone 19-0 &amp; 19-1

Repeat of expt described on bottom of page  
98.Water ht = 21.6 cm  
+ Per.  
 $\tau = 121.7 \text{ sec} = 8.5 \text{ f}$ Water Temp  $^{\circ}\text{C}$   
#1 = 23.2  
2 = 23.50858. Water ht = 14.8 cm  
System just critical  
Drain.

391-160.2-27.0-5.2-8.5

Cone = 189.5. N =

Same as above except <sup>(19-1)</sup> lower element notated  
45 $^{\circ}$  (B-7)Water ht = 21.6 cm  
2 + Per.  
 $\tau = 117.3 \text{ sec} = 8.7 \text{ f}$ Water Temp  $^{\circ}\text{C}$   
#1 = 23.2  
2 = 23.51039. Water ht = 14.75  
System just critical  
Drain to  $\sim 0.0$  cm on reader.

391.0-160.2-27.0-5.2-8.7

Cone = 189.3 f



19-1  
Case 19-0 + ~~19-1~~

101

Rotated inner element another  $45^\circ$  (#-6).

Water ht = 21.6 cm

Water Temp  $^\circ\text{C}$

<sup>3</sup>+ Per

#1 = 23.2

$\tau = 113.0 \text{ sec} = 8.9 \text{ s}$

2 = 23.5

1110 Water ht = 14.75 cm

System just critical  
Drain.

$391.0 - 100.2 - 27.6 - 5.2 - 8.9$   
corr = 189.14 NG

Rotated inner element another  $45^\circ$  (#-5)

Water ht = 21.6 cm

Water Temp  $^\circ\text{C}$

<sup>4</sup>+ Per

#1 = 23.5

$\tau = 103.2 \text{ sec} = 9.6 \text{ s}$

2 = 23.5

1300 Water ht = 14.5 cm

System just critical  
Drain to  $\approx 0.0$  cm on scale

Rotated inner element another  $45^\circ$  (#-4)

Water ht = 21.6 cm

Water Temp  $^\circ\text{C}$

<sup>5</sup>+ Per

#1 = 23.5

$\tau = 111.9 \text{ sec} = 9.0 \text{ s}$

2 = 24.0

1330 Water ht = 14.7 cm

System just critical  
Drain -

corr.

Rotated inner element back to its original pos. Moved each piston strip four (4) slots in the clockwise pos in outer element.

#4 Water ht = 21.6 cm

Water Temp °C

(6) 4 per

#1 = 23.5

$t = 49.9 \text{ sec} = 16.9 \text{ f}$

2 = 29.0

~~1420~~ Water ht = 13.20 cm

391.0 - 193.0 - 16.4

1420 System just critical

cone = 181.6 f

Drain to 0.0 cm on scale.

Moved piston strips four (4) slots in the clockwise pos in outer element. Total of 4 slots from original pos.

Water ht = 21.6 cm

Water Temp °C

(7) 4 per

#1 = 23.7

$t = 58.7 \text{ sec} = 14.7 \text{ f}$

2 = 29.0

1520 Water ht = 13.3 cm

cone = 183.3 f

System just critical

Drain to 0.0 cm on scale

Moved portion steps back to their original pos.

Water ht = 21.6 cm  
+ Per

Water Temp °C  
#1 = 23.7  
2 = 24.0

1550 Water ht = 13.7 cm  
System just critical  
Drain:

391.0 - 193.0 - 13.0

cm = 185.0 f NG

104 ml/67

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	$3 \times 10^{-12}$	Meter <input checked="" type="checkbox"/>	5"	-	$3 \times 10^{-12}$
	"	Fast <input checked="" type="checkbox"/>	"	-	"
K-2	$3 \times 10^{-12}$	Meter <input checked="" type="checkbox"/>	4"	-	"
		Fast <input checked="" type="checkbox"/>	"	-	
R-1	<input checked="" type="checkbox"/>				
R-2	<input checked="" type="checkbox"/>				
PM-1	700V	Alarm <input checked="" type="checkbox"/>	cont	-	300V
PM-2	1200V	Low <input checked="" type="checkbox"/>	8"	-	900V
		Alarm <input checked="" type="checkbox"/>	3	-	"
LOG N CALIBRATE <input checked="" type="checkbox"/>		OPERATE <input checked="" type="checkbox"/>		SOURCE No. B-80	
DUMP WELL PROBE LIGHT <input type="checkbox"/>					

START-UP CHECK LIST

Equipment checked by J. W. C. Personnel check by J. W. C.  
 Instruments and safeties checked and reset by J. W. C.  
 Source in checked by W. C. Source No. M-43  
 Emergency equipment in control room checked by J. W. C.  
 Instruments in trip circuit: K1-K2-PM1-PM2  
 Red light on by W. C. Time 0820:  
 Start-up OK'd by W. C. J. W. C. Date 2-1-67

2/1/67

8.55H + per Water - 21.65 cm - Super critical -  
 $\tau = 65.2 \text{ sec} = 13.6 \text{ f}$  Period 91 2/1/67  
 Temp #1 24.0 °C #2 24.0 °C

9.00 Water 13.8 cm Slightly super critical.  
 9.02 " 13.7 cm Slightly sub critical  
 9.03 " 13.7 "

Repeat of above after removing each poison strip, and placing it back in the slot from which it was removed, (or original pos.)

Water ht = 21.60 cm,  
 2 + per  
 $\tau = 67.4 \text{ sec} = 13.3 \text{ f}$

Water Temp °C  
 #1 = 29.0  
 #2 = 29.2

10.30 Water ht = 13.70 cm  
 System just critical  
 Drain to ~ 0.0 cm on scale

Moved each poison strip four (4) slots in the clockwise pos in outer element. (see top of page 102.)

Water ht = 21.70 cm  
 3 + per  $\tau = 71.7 \text{ sec} = 12.7 \text{ f}$

over

2/1/67  
1100

Water ht = 13.70 cm  
System just critical  
Drain.

Water Temp °C  
#1 = 24.2  
2 = 24.2

Moved each strip four (4) more slots in  
the clockwise pos. (See bottom page 102) total  
of 8 slots.

Water ht = 21.70 cm  
4 + per  
C = 49.9 m = 16.4 f

Water Temp °C  
#1 = 24.2  
2 = 25.0

1315 Water ht = ~~21.70~~ 13.1 cm.  
System just critical  
Drain to ~ 0.0 cm

391.0 - 193.0 = 198.0

cone = 181.6 f NG

Moved each strip four (4) more slots in  
the clockwise pos. (Total of 12 slots).

Water ht = 21.60 cm  
5 + per

Water Temp °C  
#1 = 24.2  
2 = 25.0

1350 Water ht = 13.7 cm  
System just critical  
Drain.

391.0 - 193.0 = 198.0

cone = 185.3 f NG

Moved each strip four (4) more slots in the clockwise pos. (Total of 16 slots)

Water ht = 21.6 cm      Water Temp °C  
 6 + per #1 = 29.5  
 $\tau = 54.3 \text{ sec} = 15.5 \text{ f}$       2 = 29.5

1445 Water ht = 13.20  
 System just critical       $391.0 - 193.0 - 15.5 \text{ f}$   
 Drains to 20.0 cm      cone = 182.5 f NG

Moved each strip four (4) more slots in the clockwise pos. (Total of ~~20~~<sup>20</sup> slots)

Water ht = 21.6 cm      Water Temp °C  
 7 + per #1 = 29.5  
 $\tau = 49.9 = 16.4 \text{ f}$        $391.0 - 193.0 - 16.4$       2 = 29.5

1526 Water ht = 13.15 cm      cone = 181.6 NG  
 System just critical  
 Drains to 20.0 cm

Moved each strip four (4) more slots in the clockwise pos. (Total of 24 slots)

Water ht = 21.6 cm  
 8 + per  $\tau = 67.4 \text{ sec} = 13.3 \text{ f}$       aver.

108

2-1-67

1604

Water ht = 13.60 cm  
System just critical  
Drain.

Water Temp °C  
#1 = 29.5

cm = 184.7 / NG 2 = 29.5

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE	SET	START-UP RANGE
K-1	3 x 10 <sup>-12</sup>	Meter ✓	1"	✓	3 x 10 <sup>-12</sup>
	"	Fast ✓	"	✓	"
K-2	"	Meter ✓	"	✓	"
	"	Fast ✓	"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	cont	✓	500V
PM-2	1200V	Low ✓	12"	✓	900V
	"	Alarm ✓	3"	✓	"

LOG N CALIBRATE  OPERATE  SOURCE No. B-80

DUMP WELL PROBE LIGHT \_\_\_\_\_



✓  
 Comes 19-0 & 19-0

## START-UP CHECK LIST

Equipment checked by AKH Personnel check by F.D.C.

Instruments and safeties checked and reset by AKH

Source in checked by AKH Source No. M-43

Emergency equipment in control room checked by F.D.C.

Instruments in trip circuit: K-1-2 PM-1-2

Red light on by AKH Time 0815

Start-up OK'd by F.D.C. AKH Date 2-2-67

moved each strip four (4) more slots in  
 the clockwise pos. (Total of 28 slots)

Water ht = 21.6 cm

Water Temp °C

<sup>1</sup>+P<sub>2</sub>

#1 = 29.2

C = 69.5 sec = 130 f

2 = 29.2

0900

Water ht = 13.70 cm

cm = 195.0 f NG

System just critical

Quartz 0.0 cm

moved each strip back to its original pos.

Water ht = 21.6 cm

Water Temp °C

<sup>2</sup>+P<sub>2</sub>

#1 = 29.2

C = 82.6 sec = 11.4 f

2 = 29.2

0950

Water ht = 14.1 cm

cm = 186.6 f NG

System just critical

Removed cover from tanks, and made a visual inspection of the cores, and could not find any slats pleged. Replaced cover in tanks. Now have 4 fuel plates and 7 enriched strips. Trip (# 2,3,4,7,8,9+10.)

Water ht = 21.6 cm.

Water Temp °C

+ Per

#1 = 29.3

$t = 36.9 \text{ sec} = 20.0\phi$

2 = 29.5

1104 Water ht = 12.6 cm.  
System just critical  
Drain.

4 fuel plates in center (p. 98)  
Repeat of above after centering the enriched strips at top & bottom of core. (19-0).

Water ht = 21.6 cm.

Water Temp °C

+ Per

#1 = 29.5

$t = 28.3 = 23.5\phi$

2 = 29.5

1430

Water ht = 12.3

System just critical

Drain.

OK

186.1 ✓ 143.5 Obs  
 $391 - 179.9 - 21.3 = 189.8 \text{ sec}$

0-3224x 0-5495  
 Repeat of experiment (1-27-67 Page 99): Have  
 2 fuel plates and 2 enriched strips (#2 & 2).  
 Strips are centered at top and bottom on  
 core (19-0).

Water ht = 21.6 cm  
 + Per  
 $\sigma = 34.8 \mu = 20.7 \mu$

Water Temp °C  
 #1 = 24.5  
 #2 = 24.5

1.553 Water ht = 12.7 cm.  
 System just critical  
 Power

core = 178.80% NG

240 - 51.4 - 20.7 = 167.5 kW  
 240 - 53.4 - 20.7 = 165.9

## INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	$3 \times 10^{-12}$	Meter ✓	1"	✓	$3 \times 10^{-12}$
	"	Fast ✓	"	✓	"
K-2	"	Meter ✓	"	✓	"
	"	Fast ✓	"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	cont	✓	500V
PM-2	1200V	Low ✓	12	✓	900V
	"	Alarm ✓	3"	✓	"

LOG N CALIBRATE  OPERATE  SOURCE No. B-80

DUMP WELL PROBE LIGHT

## START-UP CHECK LIST

Equipment checked by ARKC Personnel check by FIVE

Instruments and safeties checked and reset by ARKC

Source in checked by ARKC Source No. M-93

Emergency equipment in control room checked by ARKC

Instruments in trip circuit: K-1-2 PM-1-2

Red light on by ARKC Time 0830

Start-up OK'd by FIVE ARKC Date 2/3/67

19

Now have spent element with 4 fuel plates  
 (# D-3224, D-5495, D-3242, & D-2870). Plus  
 6 enriched strips (# 2, 3, 7, 8, 9, 10) and 2 natural  
 strips (# 5 & 6) plus 4 stainless steel strips.  
 Each strip is centered in outer element (19.0)  
 top and bottom.  $192.9 \pm 19.5$

Water ht = 21.7 cm  
 + Pes  
 $C = 41.3 \text{ sec} = 18.6 \text{ g}$

Water Temp. °C  
 #1 = 29.3  
 #2 = 29.3

0914 Water ht = 12.9 cm  
 System just critical  
 Drain:

$391.0 - 193.0 - 18.6$   
 Core = 178.4  $195.0$   
 $179.5 \pm 19.5$

Removed all poison strips, then using the  
 regular procedure replaced strip back  
 in the same slots. (centering from top  
 only).

Water ht = 21.6 cm  
 + Pes  
 $C = 84.7 \text{ sec} = 11.2 \text{ g}$

Water Temp. °C  
 #1 = 29.3  
 #2 = 29.5

1008 Water ht = 14.1 cm.  
 System just critical.  
 Drain:

over:

Repeat of experiment described on <sup>top</sup> bottom of page 113. After centering strip at top and bottom of core (19-0).

Water ht = 21.6 cm  
<sup>3</sup>+ Per

Water temp °C  
 #1 = 29.5  
 2 = 29.5

1307 Water ht = 13.0 cm  
 System just critical  
 Drain.

Moved the strips from strips to the outer edge of slots in outer element. Same number of fuel plates and pinion strips as above.

1534 Water ht = 21.6 cm  
 System sub critical  
 Drain.

Water temp °C  
 #1 = 29.5  
 2 = 29.5

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	$3 \times 10^{-12}$	Meter ✓	1"	✓	$3 \times 10^{-12}$
	"	Fast ✓	"	✓	"
K-2	"	Meter ✓	"	✓	"
	"	Fast ✓	"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	Cont	✓	500V
PM-2	1200V	Low -	12"	✓	900V
	"	Alarm ✓	3	✓	"

LOG IN CALIBRATE  OPERATE  SOURCE No. B-80  
 DUMP WELL PROCBE LIGHT

START-UP CHECK LIST

Equipment checked by AKM FIDC Personnel check by FIDC  
 Instruments and safeties checked and reset by AKM EBN  
 Source in checked by AKM Source No. M-43  
 Emergency equipment in control room checked by FIDC  
 Instruments in trip circuit: K-1-2 PM-1-2  
 Red light on by AKM Time 0920  
 Start-up OK'd by FIDC AKM Date 3-6-67

*over*

Repeat of experiment described on top of page 113.

Water ht = 21.6 cm.

Water Temp °C

+ Per

#1 = 23.5°

$C = 56.5 \text{ sec} = 15.0 \text{ f}$

#2 = 23.5°

Water ht = 13.35 cm

System just critical

Drain to = 0.0 cm

Remained natural strip #3 to side of cond.

Water ht = 21.6 cm

Water Temp °C

+ Per.

#1 = 23.5°

$C = 45.6 \text{ sec} = 10.2 \text{ f}$

#2 = 23.5°

1030 Water ht = ~~14.3~~ 14.40 cm.

System just critical

Drain.

Remained natural strip #3. = 12.2 f

3 Water ht = 13.35 cm.

Water Temp °C

+ Per

#1 = 23.5°

$C = 76.1 \text{ sec} = 12.2 \text{ f}$

#2 = 23.5°

1132 Water ht = 11.8 cm

System just critical



Removed 4 stainless-steel strips. = 1.6 feet

Water ht = 13.35 cm.

4 + Per

$\tau = 91.3 \text{ sec} = 18.6 \text{ f}$

Water Temp  $^{\circ}\text{C}$

#1 = 23.5

2 = 23.7

1150 Water ht = 11.35

System just critical.  
Down.

Cone 17-0 & 17-1

Have 2 spent fuel plates (# D-3224 & D-5495)  
and 5 natural ~~the~~ strips. The strip one  
against the ~~rest~~ top and bottom outside  
ring. (See page 86)

1555 Water ht = 21.6 cm

System just critical. - Per  $\tau = 914.8 \text{ sec}$

Down

= -1.5 f

The above strip load is in error. Due  
to the fact that "I can not read."

7/12/67 2-7-67

## INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE D. RANGE	SET	START- RANGE
K-1	$3 \times 10^{-12}$	Meter ✓	1"	✓	$3 \times 10^{-12}$
"	"	Fast ✓	"	✓	"
K-2	"	Meter ✓	"	-	"
"	"	Fast ✓	"	-	"
R-1					
R-2					
FM-1	700 V	Alarm ✓	cont	✓	500 V
PM-2	1200 V	Low -	12"	✓	900 V
"	"	Alarm ✓	3"	✓	"

LOG N CALIBRATE  OPERATE  SOURCE No. B-80  
 DUMP WELL PROBE LIGHT

## START-UP CHECK LIST

Equipment checked by AKM F.P.C. Personnel check by F.P.C.

Instruments and safeties checked and reset by AKM

Source in checked by AKM Source No. M-43

Emergency equipment in control room checked by F.P.C.

Instruments in trip circuit: K-1-2 PM-1-2

Red light on by AKM Time 0900

Start-up OK'd by F.P.C. AKM Date 2-7-67

Have 2 spent fuel plates (20-3224 & 0-5495) and 9 natural <sup>235</sup>U strips, and 2 stainless steel strips. The strips are against the top and bottom of outside ring. (see page 85 & 86)

total poison: 57.84

Water ht = 21.6 cm

+ Per  
C = 128.2 sec = 8.1 f

Water Temp °C

#1 = 23.5

0945 Water ht = 15.0 cm

2 = 23.5

system just critical  
Drains.

Difference = 1.8 f

Core = 174.1 f

Some are above spent poison strips are moved to the second (2nd) inside ring.

Water ht = 21.6 cm

+ Per

C = 86.9 sec = 11.0 f

Water ht = 14.30 cm

diff = 2.9.

system just critical.

Drains to 20.0 cm

Core = 171.2

over!

Strips removed one at a time, and placed  
in center of top ring in the normal manner.

	Water ht = 21.6 cm	Water Temp °C
	+ Per	#1 = 23.5
	$\tau = 95.6 \text{ sec} = 10.2 \text{ f}$	#2 = 23.5
1132	Water ht = 14.5 cm	240.0 - 57.8 - 10.2
	System just critical	Cone = 172.0 f
	Drain to	1-25-67 (P-86) cone = 172.3 f
		$\pm 9.9$

Removed natural strip # 4.

	Water ht = 14.5 cm	Water Temp °C
	+ Per	#1 = 23.5
	$\tau = 67.1 \text{ sec} = 13.3 \text{ f}$	#2 = 23.7
1345	Water ht = 12.30 cm	
	System just critical.	
	Drain to $\approx 0.0 \text{ cm}$	

Removed natural strip # 2

	Water ht = 12.30 cm
	+ Per
	$\tau = 67.1 \text{ sec} = 13.3 \text{ f}$

1400 Water ht = 11.10 cm  
 System just critical  
 Drain to ~ 0.0 cm

Installed enriched strip # 2;

Water ht = 21.6

6 + Per

$\zeta = 78.2 \text{ sec} = 11.9 \text{ f}$

Water Exp<sup>c</sup>

#1 = 23.5

#2 = 23.7

1515 Water ht = 14.10 cm  
 System just critical  
 Drain to ~ 0.0 cm.

Removed natural strip # 5.

Water ht = 14.10 cm

7 + Per

$\zeta = 69.5 \text{ sec} = 13.0 \text{ f}$

1528 Water ht = 12.10 cm  
 System just critical  
 Drain to ~ 0.0 cm

oen

Removed natural strip #3.

Water ht = 12.10 cm.  
 8 + P<sub>2</sub>  
 E = 82.6 cm = 11.3 f

Water Temp °C

#1 = 23.5

2 = 23.7

1543

Water ht = 11.20 cm  
 System just critical  
 Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE RANGE	SET	START-UP RANGE
K-1	3 x 10 <sup>-12</sup>	Meter ✓	1.5	✓	3 x 10 <sup>-12</sup>
"	"	F set ✓	"	-	"
K-2	"	Meter ✓	"	-	"
"	"	F set ✓	"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	Cont	✓	500V
PM-2	1200V	Low -	12"	✓	900V
"	"	Alarm -	3"	✓	"

LOG  CALIBRATE  OPERATE  SOURCE No. B-80  
 DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by AMV FIDC Personnel check by FIDC  
 Instruments and safeties checked and reset by AMV  
 Source in checked by AMV Source No. M-43  
 Emergency equipment in control room checked by FIDC  
 Instruments in trip circuit: K-1-2 PM-1-2  
 Red light on by AMV Time 0810  
 Start-up OK'd by FIDC AMV Date 7-8-67

over:

3.5  
3.7

Cores 17-0 &amp; 17-1

Have spent element with 2 fuel plates, and  
 1 enriched strip (#2). 2 natural strips (#3) and  
 2 stainless steel strips. Purpose is to  
 include worths of natural strip #3.

Water ht = 21.6 cm  
 + Per  
 $t = 85.9 \text{ sec} = 11.0 \text{ cf}$

Water Temp °C  
 #1 = 23.0  
 2 = 23.0

0905 Water ht = 14.3 cm  
 System just critical  
 Drain to ~ 0.0 cm.

Remained natural strip #3.

Water ht = 14.3 cm  
 2 + Per  
 $t = 69.5 \text{ sec} = 13.0$

Water ht = 12.25  
 System just critical  
 Drain.

Worths of natural boron

Strips #2, 3, 4, 5. avg = 13.15¢

#2 = 13.3    #4 = 13.3  
 #3 = 13.0    #5 = 13.0



INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	$3 \times 10^{-12}$	Meter ✓	1"	✓	$3 \times 10^{-12}$
	"	Fast ✓	"	✓	"
K-2	"	Meter ✓	"	✓	"
	"	Fast ✓	"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	cont	✓	500V
PM-2	1200V	Low ✓	12"	✓	900V
		Alarm ✓	3"	✓	"
LOG N CALIBRATE ✓		OPERATE ✓		SOURCE No. B-80	
DUMP WELL PROBE LIGHT _____					

START-UP CHECK LIST

Equipment checked by AMF Personnel check by F.D.C.  
 Instruments and safeties checked and reset by AMF  
 Source in checked by AMF Source No. M-43  
 Emergency equipment in control room checked by F.D.C.  
 Instruments in trip circuit: K-1-2 PM-1-2  
 Red light on by AMF Time 0520  
 Start-up OK'd by F.D.C. AMF Date 2-9-67

over

154

Cores 17-0 &amp; 17-1

Have spent element with 2 fuel plates, 1 enriched strip (#2) and 1 natural strip (#5). Have removed the 2 stainless steel strips. (see page 124.)

Water ht = 14.3 cm

Water Temp °C

+ Pen

#1 = 22.0

 $\bar{c} = 56.5 \text{ sec} = 15.0 \phi$ 

#2 = 22.0

0900

Water ht = 12.1 cm Key = 24.8  $\phi$   
System just critical.

Now have 2 fuel plates, and 4 natural strips (#2, 3, 4, 5).

Water ht = 21.6 cm

Water Temp °C

+ Pen

#1 = 22.0

 $\bar{c} = 89.1 \text{ sec} = 10.8 \phi$ 

#2 = 22.0

1010

Water ht = 14.4 cm

System just critical.

Drain to 0.0 cm

Natural strips 3, 3, 4 = 35.6  $\phi$ 4 Key = 14.3  $\therefore 35.6 - 14.3 = 21.3 \phi = \#2$  critical

Removed natural strips #3 & 4 and added #1 enriched strip.

Water ht = 21.6 cm  
<sup>3</sup> + Per  
 $C = 80.2 \text{ cm} = 11.7 \text{ f}$

10 40 Water ht = 14.30 cm

System just critical

Drain to 20.0 cm. #1 = 27.2 f ✓

10.8 - 26.3 + #1 = 11.7 #1 = 27.2 ✓

Removed enriched strip #1. and added enriched strip #2.

Water ht = 21.6  
<sup>4</sup> + Per  
 $C = 97.8 \text{ cm} = 10.1 \text{ f}$

Water Temp °C

#1, 22.0

#2, 22.2

110.6 Water ht = 14.80 cm

System just critical

Drain:

#2 = 25.6 f ✓

Removed enriched strip #2, and added  
enriched strip #3.

Water ht = 21.6 cm  
<sup>5</sup>+Per  
 $\bar{c} = 78.2 \text{ mm} = 11.94$

Water Temp °C

#1 = 21.8

2 = 22.0

1310 Water ht = 14.10 cm.  
 System just critical  
 Drain to 0-0 cm

#3 = 27.4 ✓

Removed enriched strip #3, and added  
enriched strip #4.

Water ht = 21.6  
<sup>6</sup>+Per  
 $\bar{c} = 91.3 \text{ mm} = 10.64$

#4 = 26.14 ✓

1328 Water ht = 14.4 cm  
 System just critical  
 Drain.

Removed enriched strip #4, and added  
enriched strip #5.

Water ht = 21.6 cm

7 + Per

$\bar{c} = 123.9 \text{ mm} = 8.3 \text{ f}$

Temp °C

#1 = 21.5

#2 = 21.7

1403

Water ht = 15.5 cm

System just critical

Drain to 20.0 cm.

#5 = 23.8 f ✓

Removed enriched strip #5 and added enriched strip #6.

Water ht = 21.6 cm

8 + Per

$\bar{c} = 123.9 \text{ mm} = 8.3 \text{ f}$

#6 = 23.8 f ✓

1425

Water ht = 15.5 cm

System just critical

Drain to 20.0

Water Temp °C

#1 = 21.5

#2 = 21.7

Removed enriched strip #6 and added enriched strip #7.

Water ht = 21.6 cm

9 + Per

$\bar{c} = 123.9 \text{ mm} = 8.3 \text{ f}$

Water Temp °C

#7 = 23.8 f ✓

#1 = 21.5

#2 = 21.7

1500

Water ht = 14.8 cm

System just critical

Drain to 20.0 cm

over.

Removed enriched strip #7 and added enriched strip #8.

Water ht = 21.6 cm.

<sup>10</sup> + Per  
 $\bar{c} = 89.1 \text{ cm} = 10.8 \text{ f}$

Water Temp °C

#1 = 21.5

#2 = 21.7

#8 = 26.3 f ✓

1517 Water ht = 14.4 cm  
 System just critical  
 Drain to ~ 0.0 cm

Removed enriched strip #8, and added enriched strip #9.

Water ht = 21.6 cm

<sup>11</sup> + Per  
 $\bar{c} = 89.1 = 10.8 \text{ f}$

#9 = 26.3 f ✓

1530 Water ht = 14.3 cm  
 System just critical  
 Drain to ~ 0.0 cm.

Removed enriched strip #9, and added enriched strip #10.

Water ht = 21.6

<sup>12</sup> + Per  
C = 86.9 sec = 11.0 f

# 10 = 26.5 f ✓

1548 Water ht = 14.4 cm  
System just critical  
Drain to -0.0 cm

10 enriched avg = 25.7 f

Removed enriched strip # 10. and added natural strips # 3 & 4. Purpose is to check run shown on page 126, with 2 fuel plates and 4 natural strips.

Water ht = 21.6 cm

Water Temp °C

<sup>13</sup> + Per.  
C = 104.3 = 9.6 f 14.5 cm.

# 1 = 22.7  
2 = 22.0

1610 Water ht = 14.5  
System just critical  
Drain.

4 in = 0.1 cm = 0.3 f at this height

## INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	$3 \times 10^{-12}$	Meter ✓	1"	✓	$3 \times 10^{-12}$
"	"	Fast ✓	"	✓	"
K-2	"	Meter ✓	"	✓	"
"	"	Fast ✓	"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	Low	✓	500V
PM-2	1200V	Low ✓	12"	✓	900V
"	"	Alarm ✓	3"	✓	"

LOG N CALIBRATE  OPERATE  SOURCE No. B-80  
 DUMP WELL PROBE LIGHT

## START-UP CHECK LIST

Equipment checked by AKH <sup>T.D.C.</sup> Personnel check by T.D.C.  
 Instruments and safeties checked and reset by AKH  
 Source in checked by AKH Source No. 19-93  
 Emergency equipment in normal position checked by T.D.C.  
 Instruments in trip circuit: K-1-2 PM-1-2  
 Red light on by AKH Time 0920  
 Start-up OK'd by T.D.C. AKH Date 2-10-67



2-10-67

CE-2

Repeat of efft with CE-2 as described  
on page 60.

Water ht = 21.6 cm

Temp °C

+ Per

#1 = 21.5

E = 193.4 = 5.7f

#2 = 21.5

1010 Water ht = 14.0 cm

System just critical

Drain:

391.0 - 99.6

corr = -291.4 f

Moved the 4 parison strips toward the  
outer edge of element as possible.

Water ht = 21.6 cm

- Per

E = -217.3 sec = -7.3f

1115 Drain:

see

134

2-10-67

Cores 14-0 & 14-1

Have cores 14-0 & 14-1 assemble in small  
reflector tank. Lower core spaced 375"  
with plastic spacers.  
(See page 152 for new value on previous  
trips.)

1505 Water ht = 21.6 cm  
System sub critical.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE RANGE	SET	START-UP RANGE
K-1	3X10 <sup>-12</sup>	Meter ✓	1"	✓	3X10 <sup>-12</sup>
	"	Fast ✓	"	✓	"
K-2	"	Meter ✓	"	✓	"
	"	Fast ✓	"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	cont	✓	500V
PM-2	1200V	Low ✓	12"	✓	900V
	"	Alarm ✓	3"	✓	"

LOG N CALIBRATE  OPERATE  SOURCE No. B-80

DUMP WELL PROBE LIGHT

Conc 14-0 + 14-1

START-UP CHECK LIST

Equipment checked by PKC FPC Personnel check by FPC

Instruments and safeties checked and reset by PKC

Source in checked by PKC Source No. M-43

Emergency equipment in control room checked by FPC

Instruments in trip circuit: R-1-2 PM-1-2

Red light on by PKC Time 0515

Start-up OK'd by FPC PKC Date 2-13-67

Have 4 fuel plates. 6 enriched strips (#s 2,3,7,8,9, & 10.) and 3 natural strips (# 2,3 & 4).

Power = 193.5 201.3 ± 20.1

Water ht = 21.6 cm  
+ Res

Water Temp °C  
#1 = 21.5  
#2 = 21.5

0.858  $\bar{v} = 91.3 \text{ cm} = 10.6 \text{ f}$   
Water ht = 14.20

System just critical  
Drain

<sup>193.5</sup>  
391.0 - 193.8 - 10.6  
Core = 186.6 f 174.9  
179.1 ± 20.1

Now have 2 fuel plates, and 4 natural strips (#s 2,3,4, & 5). Power = 22.6  
55.1 ± 5.8

over:

2-13-67

Cores 14-0 + 14-1

Water ht = 21.6 cm.

+ Per.

$$C = 319.4 \text{ cm} = 3.7 \text{ f}$$

10 15 Water ht = 17.0 cm  
 System just critical  
 Drain.

$$240.05 - 52.86 - 3.7 \text{ f}$$

$$\text{Core} = 183.5 \text{ f.}$$

$$240 - 55.1 - 3.7 = 181.2 \pm 9.8$$

Cores 15-0 + 15-1

Have Cores 15-0 + 15-1 assemble in small  
 reflector tank, inner core spaced 1.375"  
 with plastic spacers.

11 10 Water ht = 21.6 cm  
 System sub critical

Water Temp °C

#1 = 21.5

2 = 21.7

Have 2 fuel plates, and 4 natural strips  
 (# 2, 3, 4, + 5.)

13 15 Water ht = 21.6 cm  
 System sub critical  
 Drain to 20.0 cm.

Water Temp °C

#1 = 22.0

2 = 22.7

Core 15-0 & 15-1

2-13-67

Removed natural strip #3.  $P_{min} = 41.3 \pm 9.1$

Water ht = 21.6 cm

+ Per.

$\bar{c} = 319.4 \text{ cm} = 3.7 \text{ f}$

1345 Water ht = 17.1 cm

System just critical  
Drain.

$240.0 \text{ f} - 39.6 \text{ f} - 3.7 \text{ f}$   
 $\text{core} = 196.7 \text{ f}$

$240 - 41.3 - 3.7 = 195.0 \pm 9.1$

Now have 4 fuel plates, 6 enriched strips (#s 2, 3, 7, 8, 9, & 10) and 2 natural strips (#s 2 & 4).  $P_{min} = 187.5$   
 $187.5 \pm 15.4$

Water ht = 21.6 cm

+ Per.

$\bar{c} = 93.4 \text{ cm} = 10.4 \text{ f}$

Water Temp °C

#1 = 22.2

#2 = 22.5

1445 Water ht = 14.35 cm.

System just critical  
Drain.

$391.0 - 154.2 - 26.4 - 10.4$   
 $\text{core} = 199.6$

$391 - 187.5 - 10.4 = 193.1 \pm 15.4$

over.

138

2-13-67

Cores 13-0 &amp; 13-1

Now have core 13-0 & 13-1 assemble in  
small refilutor tank. Inner core spaced  
.375" with plastic spacers.

1553 Water ht = 21.6 cm  
System with critical  
Drain.

## INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE	SET	START-UP RANGE
K-1	$3 \times 10^{-12}$	Meter -	1"	✓	$3 \times 10^{-12}$
	"	Fast -	"	✓	"
K-2	"	Meter ✓	"	✓	"
	"	Fast ✓	"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	cont	✓	500V
PM-2	1200V	Low ✓	12"	✓	900V
	"	Alarm -	3"	✓	"

LOG N CALIBRATE  OPERATE  SOURCE No. B-80DUMP WELL PROBE LIGHT  7

Core 13-0 & 13-1

START-UP CHECK LIST

Equipment checked by AKV <sup>F.D.C.</sup> Personnel check by F.D.C.

Instruments and safeties checked and reset by AKV

Source in checked by AKV Source No. M-43

Emergency equipment in control room checked by F.D.C.

Instruments in trip circuit: K-1-2 PM-1-2

Red light on by AKV Time 0815

Start-up OK'd by F.D.C. AKV Date 2-14-67

New have 4 fuel plates. 6 enriched strips  
(#s 2, 3, 7, 8, 9, 10.) and ~~3~~ 3 natural strips  
(# 2, 3, 4).

Water ht = 17.2 cm

Water Temp °C

+ Per

#1 = 22.5

$t = 52.2 \text{ sec} = 15.9 \text{ f}$

2 = 22.7

0856 Water ht = ~~17.2~~ <sup>13.8 cm</sup>

System just critical  
Drain to 20.0 cm.

Added natural strip #5. Total poison

Water ht = 21.6 cm

= 20.2 f

+ Per

- 5.5

$t = 204.3 \text{ sec} = 5.5 \text{ f}$

= 15.7 ± 0.8

aver.

Cores 13-0 &amp; 13-1

0928 Water ht = 16.0 cm  
 System just critical  
 Drain.

$$391.0 - \overset{209.5}{207.0} - 5.5$$

$$\text{Core} = \overset{177.0}{178.5} \text{ g}$$

$$391 - 215.1 - 5.5 = 170.4 \pm 20.8$$

Now have 2 fuel plates and 2 enriched  
 strips (#2 & #9).

$$\text{mass} = \overset{53.3}{51.4} \text{ g}$$

Water ht = 21.6 cm.

Water Temp °C

$$\#1 = 22.7$$

$$\#2 = 22.7$$

$$3 + \text{Per}$$

$$T = 69.5 \text{ sec} = 13.0 \text{ g}$$

1041. Water ht = 13.65 cm  
 System just critical  
 Drain.

$$240.0 - \overset{51.9}{51.4} - 13.0$$

$$240 - 53.3 - 13.0 = 173.7 \pm 8 \quad \text{Core} = 175.6 \quad 175.1$$

Cores 12-0 &amp; 12-1

Now have core 12-0 & 12-1 assembled in  
 small reflector tank. Inner core spaced  
 .375" with plastic spacers.

Water ht = 21.6 cm  
 System sub critical  
 Drain.



Core 12-0 & 12-1

~~Core 12-0~~  
Now have 2 fuel plates and 2 enriched  
strips (# 2 & 9) Power = 53.3 ± 8

Water ht = 21.6 cm

Water Temp °C

+ Per

#1 = 23.0

$\bar{c} = 95.6 \text{ cm} = 10.2 \text{ f}$

2 = 23.0

1345 Water ht = 14.5 cm

System just critical

Drain

$240.0 - 51.4 - 10.2$

Core = 178.4 ± 177.7

176.5 ± 8

Now have 4 fuel plates, 6 enriched strips  
(# 5, 2, 3, 7, 8, 9, 10.) and 4 natural strips (# 5, 2,  
3, 4, 5). Power = 215.1 ± 20.8

Water ht = 21.6 cm

Water Temp °C

+ Per

#1 = 23.2

$\bar{c} = 521.5 \text{ cm} = 2.3$

2 = 23.5

1451 Water ht = 17.40 cm

System just critical

Drain

$391.0 - 154.2 - 52.8 - 2.3$

Core = 181.7 ± 180.2

$391 - 215.1 - 2.3 = 173.6 \pm 20.8$

142

Cores 23-0 &amp; 23-1

Now have cores 23-0 & 23-1 assembled in  
small replicator tanks. Inner core spaced  
.375" with plastic spacers.

1600

Water ht = 21.6 cm  
System sub critical  
Drain.

## INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE RANGE	SET	START-UP RANGE
K-1	$3 \times 10^{-12}$	Alarm	1"	✓	$3 \times 10^{-12}$
"	"	Flt	"	✓	"
K-2	"	Alarm	"	✓	"
"	"	Flt	"	✓	"
R-1					
R-2					
PM-1	700 V	Alarm	cont	✓	500 V
PM-2	1200 V	Low	12"	✓	900 V
"	"	Alarm	3"	✓	"

LOG N CALIBRATE

✓

OPERATE

✓

SOURCE No.

B-80

DUMP WELL PROBE LIGHT

Cores 23-0 & 23-1

## START-UP CHECK LIST

Equipment checked by AKH Personnel check by Z.D.C.Instruments and safeties checked and reset by AKHSource in checked by AKH Source No. 19-83Emergency equipment in control room checked by Z.D.C.Instruments in trip circuit: K-1-2 P.M.-1-2Red light on by AKH Time 0945Start-up OK'd by Z.D.C. AKH Date 2-15-67

Now have 4 fuel plates, 6 enriched strips  
(#s 2, 3, 7, 8, 9, 10.) and 4 natural strips (#s 2,  
3, 4, 5).  $\approx 15.1 \pm 20\%$

1022 Water ht = 21.6 cm.

System sub critical  
Drain to 20.0 cm.

Water Temp °C

#1 = 23.7

#2 = 24.0

Ins. instrument scanned: K-2: (Cable movement)

Removed natural strip # 4. 195.2  
 $\approx 1.3 \pm 20.1$ 

Water ht = 21.6 cm

+ Per.

 $\sigma = 119.5 \text{ cm} = 8.6 \%$ 

over.

Cores 23-0 &amp; 23-1

1118

Water ht = 15.05 cm  
 System just critical  
 Drain.

Water temp °C

#1 = 23.7

#2 = 24.0

$$391.0 - 154.2 - 39.6 - 8.6$$

$$\text{Core} = 188.6 \text{ f}$$

X -

$$391 - 201.0 - 9.6 = 180.4 = 25.1$$

Now have 2 fuel plates, 3 natural  
 strips (#s 2, 3, 5).  $39.3 \text{ f}$   
 $41.3 = 9.1$

Water ht = 21.6 cm

+ Per.

$$5 = 54.3 \text{ cm} = 15.5 \text{ f}$$

1313

Water ht = 13.50 cm

System just critical

Drain.

$$240.0 - 39.6 - 15.5$$

$$240 - 41.3 - 15.5 =$$

$$\text{Core} = 184.9 \text{ f}$$

$$183.2 = 9.1$$

Core 24-0 &amp; 24-1

Now have cores 24-0 & 24-1 - assemble in small  
 reflector tank, inner core spaced .375"  
 with plastic spacers.

1445

Water ht = 21.6 cm

System sub critical.

Drain.

Cores 24-0 & 24-1

Now have 2 fuel plates. 9 natural strips  
(#s 2, 3, 4, 5)

Water ht = ~~21.6 cm~~  
21.6 cm

+ Per

$t = 34.8 \text{ sec} = 20.7 \text{ f}$

Water Temp °C

#1 = 29.5

29.5

22.0°

Therm.

1520

Water ht = 12.8 cm

System just critical.

$240 - 55.1 - 20.7 = 164.2 \pm 7.8$

52.6  
 $240 - 52.8 - 20.7$

Core = 166.5 f 16.7

Removed natural strip # 4. and added  
Enriched strip # 9. Power = 68.0 ± 9.6

1535

Water ht = 21.6 cm

+ Per

$t = 136.9 \text{ sec} = 7.7 \text{ f}$

1549

Water ht = 15.2 cm

System just critical

Power

$240 - 68 - 7.7 = 164.3 \pm 9.6$

65.6  
 $240 - 39.6 - 25.7 - 7.7$

Core = 167.0 f 16.7

## INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DETAILS	SET	START-UP RANGE
K-1	$3 \times 10^{-12}$	Meter ✓	1"	-	$3 \times 10^{-12}$
"	"	Fast ✓	"	-	"
K-2		Meter	/		
		Fast			
R-1					
R-2					
PM-1	700V	Alarm ✓	cont	-	500V
PM-2	1200V	Low ✓	12"	-	900V
"	"	Alarm ✓	3"	-	"
LOG N CALIBRATE		✓	OPERATE	✓	SOURCE No. B-80
DUMP WELL PROBE LIGHT					

## START-UP CHECK LIST

Equipment checked by F.D.C. PKM Personnel check by F.D.C.  
 Instruments and safeties checked and reset by PKM  
 Source in checked by PKM Source No. M-93  
 Emergency equipment in control room checked by F.D.C.  
 Instruments in trip circuit: K-1 X PM-1-2  
 Red light on by PKM Time 0815  
 Start-up OK'd by F.D.C. PKM Date 2-16-67

Cores 24-0 &amp; 24-1

Now have 4 fuel plates. 7 enriched strips  
(#s 2, 3, 4, 7, 8, 9, 10...) and 3 natural strips (#2,  
3, 5).

0900 Water ht = 21.6 cm.

System just critical.

Drain.

391.0 - 179.9 - 39.6

Core = 171.5 ± 169.7

391 - 228 = 163.0 ± 20.6

Cores 15-0 &amp; 15-1

Purpose is to check run made on 2-13-67  
see page 137. Have 4 fuel plates, 6 enriched  
strips (#s 2, 3, 7, 8, 9, 10...) and 2 natural strips  
(#s 2 & 4). ~~182.5~~  
187.5 ± 19.4

Water ht = 21.6 cm

+ Per.

t = 56.5 cm = 15.14

Water Temp. °C

1015 Water ht = 13.35 cm

Water Temp.

System just critical

182.5 = 22.2°C

Drain.

391.0 - 154.2 - 26.4 - 15.1

Core = 195.3 ± 152.4

391 - 187.5 - 15.1 = 188.4 ± 19.4

Stop

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	-	Meter			
		Fast			
K-2	$3 \times 10^{-12}$	Meter ✓	3"	✓	$3 \times 10^{-12}$
	"	Fast ✓	"	✓	"
R-1					
R-2					
PM-1	700 v	Alarm ✓	cont	✓	5000
PM-2	1200 v	Low ✓	10"	✓	9000
	"	Alarm ✓	3"	✓	"

LOG N CALIBRATE  OPERATE  SOURCE No. B-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by AKK, F.D.C Personnel check by F.D.C

Instruments and safeties checked and reset by AKK

Source in checked by AKK Source No. M-43

Emergency equipment in control room checked by F.D.C

Instruments in trip circuit: K-2 PM-1-2

Red light on by AKK Time 0810

Start-up OK'd by F.D.C AKK Date 6-6-67




Feed rate = 4.6 cm/min.  
 Drain rate = 27.6 cm/min.  
 Dump rate = 39.4 cm/min.

Each element is assembled with the inner element spaced with .375" plastic spacers. (For air release). Cd in inner cores is mounted on 4.5" polyplex tubing. (4.5" O.D.) The Cd is .060" thick and starts 3" above the bottom of the element and extends upward 20.0". The Cd on the outer elements is spaced .250" from core with plastic spacers and starts 2.56" from bottom of the element and extends upward 24.0". (See photos). Cd thickness on outer element = .030".

when  $H_2O = 56.3$  water is at top of fuel plates.

Have an  $2 \times 2$  array. Elements are in contact.




Water hts = 74.0 cm  
 System sub-critical  
 Drain Multiplication < 1.0

Water Temp. °C  
 23.5 °C

over.

Now have an  $3 \times 3$  array as shown below.  
elements in contact.



Water ht = 74.5 cm  
System sub critical  
Gross Multiplication  $< 1.0$

Water Temp  $^{\circ}\text{C}$   
= 23.5  $^{\circ}\text{C}$

See H.F.I.R. log book # 3.

150

152

Worth of Strips

No.	Natural Brown	No.	Enriched
2	13.34	1	27.2
3	13.0	2	25.6
4	13.3	3	27.4
5	13.0	4	26.1
	<u>13.15</u>	5	23.8
Avg		6	23.8
		7	23.8
		8	26.3
		9	26.3
		10	<u>26.5</u>
		Avg.	25.7