

## BOOK36R

*Notes:*

"HFIR-1" written on tape on front

"SOL HFIR-1" & "HIFR-1 1959, 60, 61" on spine

Blank pages: inside front cover, 37-39, 45,50, 53, 56, 57, 95, 127, 194, 199, 258, 285-300, inside back cover opposite 300

<u>page</u>	<u>sheets taped to it</u>
51	1
53	1
69	3
71	2
75	2
77	1
81	4
87	3
95	2
97	2
99	1
101	1
107	1
133	2
147	2
153	2
155	2
157	1
161	1
163	1
168	1
171	3
175	3
177	1
197	2
198	1
203	1 small
207	3
213	3
221	3
223	2
227	3
233	2

<u>page</u>	<u>sheets taped to it</u>
239	2
246	1 small
256	1
258	1
260	2
264	2
267	1
279	2 small graph sheets

*Scanned by:*  
*Sheila Finch*  
*RSICC /Oak Ridge National Lab.*  
*August 7, 1999*



HIER  
1967-68

1967-68

1967-68

1967-68

1967-68

1967-68

1967-68

1967-68

Density pure  $D_2O$  @  $20^{\circ}C$   
1.1054

@  $30^{\circ}C$  1.103

12  
Bot  
Can  
Net  
gm  
gm  
Av. g  
sp.  
Vol  
wt

D<sub>2</sub>O zero: 56.15

Fuel zero ~ 0.0

12-2-59 Inventory in lab storage:

Bottle no.	821	822	823
Sample no.	167202	167203	167204
Net wt.	17.334 gm	17.113	17.470
			Total 51.92 kg
gm U/gm	<del>.253</del>	<del>.2507</del>	<del>.2558</del>
	.253	.251	.256
gm U <sup>235</sup> /gm (av. 93.15)			
sp. gr.	1.630	1.628	<del>1.635</del>
Vol.	10.63 l	10.57	10.69 <del>10.63</del>
			Total <del>28.83 l</del> 31.89
Wt U	4385 gm	4295	4475
			Total U 13,155
			Total U <sup>235</sup> 12,26

12-2-59

H F I R

Personnel: Cross, Rabner  
Fox

Expt # 1

Preliminary expt. with soln. as received. Bare on top and bottom

Deionized water in region I } ~ 30"  
Tap water in region IV }

Inst checked & safety cocked.

Ran out of soln at ~ 8.4"

with D<sub>2</sub>O at ~ 13"

Very little multiplication

Drained Full

EXPT I B

Personnel: Cross, Rabner, Fox 12

Added bottom water refl. 5 4

expt above.

12-3-59  
AM.

D<sub>2</sub>O zero 56.1 Fuel zero 0.0

Inst. checked

Fuel ft 8.69 . all out Not out.

D<sub>2</sub>O at ~ 73.5"

Appreciable multiplication but far from critical

12-3-59 PM

Added to fuel soln 13.34 kg

of D<sub>2</sub>O used mixed for 1/2 hr.

alves  
Fox  
12-3-59  
2:20 PM

# Expt. #2

Personnel; cross  
Rohrer, Burchsted  
Fox

Preliminary expt. with side and  
bottom reflectors After dilution with  
13.34 kg D<sub>2</sub>O

Instr checked & safety cocked.

D<sub>2</sub>O - 71.01

Fuel 11.92 "

Not critical - Apprxiabile M<sup>-1</sup>

Fox  
12-3-59  
4:15

# Expt 2 B

Added 13.35 kg D<sub>2</sub>O to fuel can  
and mixed.

D<sub>2</sub>O 71.22 "

Fuel 15.02 Crit

Total D<sub>2</sub>O added:  $\frac{13.34}{13.35} = 26.69 \approx 24.2 \text{ p}$

- Vol of conc.  $\frac{31.9 \text{ h}}{56.1}$

$$\frac{\text{gm V}^{235}}{\text{h}} = 218.5$$

4

## Expt 2C

Cross, Raber, Burchsted  
Fox12-4-59  
9 AM.

Repeat of 2B after mixing

Inits. checked safety cocked

$$D_{20} \quad 71.40 - 56.10 = 15.30''$$

Fuel 15.30''

Crt

L ~~all substrate below of zero shift~~

## Expt. 3

12-4-59  
10 AM.Removed bottom reflector same  
as expt. 2C otherwiseapparent zero shift. to 99.57 found  
by rise per fuel fog. Due to draining  
water in bot. refl.out of fuel at  $16.82 + .43 = 17.25''$ 

$$D_{20} \text{ at } 73.04 - 56.1 = 16.94$$

Significant  $M^{-1}$  but sub. crit

## 3B

Repeat with  $D_{20}$  higher

Fuel zero 99.53.

$$D_{20} - 74.08$$

Fuel out at  $16.80 + .47 = 17.27$ About same  $M^{-1}$  as above.

Sample #1 taken: John wt. 1259m.

Reg. 593065

unrelated  
Fox 12-4-59 PM Added 12.23 kg D<sub>2</sub>O to system  
& mixed

Total D<sub>2</sub>O added to date:  $\begin{array}{r} 13.34 \\ 13.35 \\ 12.23 \\ \hline 38.92 \text{ kg} \end{array}$   
 at  $\sim 25^\circ$  sp. gr. = 1.104  
 $\therefore$  Vol = 35.25 l

Vol. of conc. = 31.89  
 Total vol = 67.14 l

$\frac{\text{gm } U^{235}}{\text{g}}$  = 182.5

Total wt. of soln. in lab:  $\begin{array}{r} 38.92 \text{ kg. D}_2\text{O} \\ 17.33 \\ 17.11 \\ 17.47 \\ \hline 90.83 \end{array}$

543065 -  $\frac{\text{gm } U}{\text{gm}} = 0.16727$   
 sp. gr. = 1.4055



6

12-4-59  
3:40 PM

Expt. 4

Cross, Burchsted Fox

System here on bottom and top  
 After ~~3~~ addition of D<sub>2</sub>O  
 In 182.5 gm U<sup>235</sup>/l  
 D<sub>2</sub>O 75.63 - 56.1  
 Fuel 19.49" crit

12-7-59  
9 AM

Expt 4 A

Cross,

Fox

Repeat of above after further mixing  
 Fuel zero - 0.20  
 Crit. Fuel reading 19.76 - 20 = 19.56  
 D<sub>2</sub>O at 75.84 - 56.10 = 19.74  
 Readjusting:  
 Crit Fuel 19.82 - 20 = 19.62  
 D<sub>2</sub>O at 75.75 - 56.10 = 19.65

Vertical traverse limits:

1.6" from bottom

8 3.75" " Top

Sample #2 (593066)

$$\frac{\text{gm U}}{\text{gm}} = 0.14466$$

$$\text{sp. gr.} = 1.356$$
183 gm U<sup>235</sup> ←

12/7/59 Exp. 5. Water added to bottom region.  
 to top reflector. Water in  
 region  $II \& I > 19.5''$ . Same  
 fuel solution as last experiment.  
 Fuel level selsyn reads 0.30" at  
 solution zero as determined by change  
 in response of selsyn to small fuel additions.

10<sup>30</sup>  
 For Cross, Gilley

Fuel selsyn	D <sub>2</sub> O selsyn	
16.86"	72.70"	crit
- .30	- 56.10	[corrected for zeros]
16.56	16.60	

12/7/59 Expt 5A  
 2<sup>30</sup> PM Repeat of above after allowing bottom  
 refl. to warm toward room temp  
 Fuel zero .30

Crit with	Fuel	72.70
	16.84	56.10
	30	<hr/>
	16.54	16.40

12-8-59 Sample #2 & 2A taken; #2 vol wt 91 gm,  
 593 blele

12-8-59 D<sub>2</sub>O concentration in fuel can be 92% ± 2%  
 per H.C. Claiborne

DW Magnuson

8

12-8-58 Drained out of alar:  $\frac{17.44}{2.17} = 15.27$  kg soln into 5" bottle

Added to slab:  $\frac{14.31}{2.31} = 2.50$  kg D<sub>2</sub>O

mixed for 1 hr.

Put in top water repl. ~ 7 1/2 in in region # 5 # After putting in pipe extension using teflon tape on threads.

Region # can was leak checked after extension was inserted and found to be tight.

Fraction of soln drained out of alar:  $\frac{90.83}{13.27} = 75.56$  kg soln

$$\frac{75.56}{90.83} \times 12.24 = 10.19 \text{ kg } U^{235}$$

$$\frac{15.27}{90.83} \times 67.14 = 11.28$$

Vol. of soln left at 182.57 ml;  $\frac{67.14}{11.28} = 55.86$

Vol of D<sub>2</sub>O added  $\frac{12.0}{1.104} = 10.87$

Total vol  $\rightarrow 66.73$

New gm  $U^{235}$  / l =  $\frac{10.19}{66.73} = 153$

Expt. 6

Cross, Gilley, Burchsted  
Fox

System completely surrounded with water.  
 Calm at  $\sim 153$  gm/l

Inst. checked safety up.

Fuel zero at zero on all syn.

Inserted control rod

Crit at 14.43 with  $D_2O$  region full

Small control rod ( $\sim 1''$ ) give almost no change in  $K$  when fully inserted in reflector IV.

Without removing any soln. from slab, 18.61 kg.  $D_2O$  was added and mixed.

Vol. of  $D_2O$  added 16.84 l.

$$\begin{array}{r} \text{Total vol.} = \\ 46.73 \\ \underline{16.84} \\ 83.59 \end{array}$$

Total mass: 75.56

18.61

~~94.17~~

12.00

106.17

$$\frac{10.19}{83.59} = 122 \text{ gm } U^{235} / \text{l}$$

Vol of Fuel Annulus = 2.73 l/in

12/9/59 Expt 7

Cross, Gilly, Fox

System completely reflected

Fuel conc. at ~ 122 gm/l.

Fuel zero 99.8

Dro region # full

Crit. with fuel at 15.65" on selsyn

For pos. period 15.69"

Actual fuel ht = 15.85" at crit.

period corresponding to 0.4 increase in fuel ht. = 122 sec.

11 <sup>30</sup>

Solu removed from system:

12/9/59

g 17.30  
T 2.31  
N 14.99

g 18.00  
T 2.92  
N 15.08  
14.99  
30.07

Total mass left  
in slab: 94.17  
30.07  
64.10 kg  
12.00  
76.10

91.86 kg = D<sub>2</sub>O added to system:

73.8

1,245 g/g

g 18.55  
T 2.79  
N 15.76

Total U<sup>235</sup> left in slab:

724  
76.10 64.10 x 10.19 = ~~6.935~~ kg  
106.9 94.17

Vol D<sub>2</sub>O added

15.74 ≈ 14.3  
1.164

Total vol left in slab:

76.1 64.1 x 83.6 = ~~56.8~~  
106.9 94.17 59.5

59.5  
14.3  
73.8

56.8  
14.3

7.1 Vol. after dil.

$\frac{91.86}{2} = \frac{7.24}{7.1} = \frac{98.4}{73.8} \text{ gm/l}$

Vol. Drained: 83.4  
59.5  
24.1

Uran, Satly 11  
FOX

12-9-59  
2:30 PM

Expt # 8

Test for crit. ht. after further dilution to ~100 gm/l

Fuel zero 49.87

Crit at 17.07" + .13 = 17.2

Fully refl.

8A

Repeat of above to test degree of mixing  
Fuel zero at 0.12"

Crit ht = 17.4 / - .12 = 17.29"

4:00 PM

added D<sub>2</sub>O:

1<sup>st</sup> g 18.04

2<sup>nd</sup> g 12.48

Net added 5.56

Vol added = 5.02 l

Fuel removed 7.96

net. → 5.17 kg

Soln. Man left

91.86  
76.10  
5.17  
70.93  
86.69

Total vol. after dilution:

5.02  
69.65  
74.67

~~5.56~~  
~~65.8~~  
~~71.36~~

~~5.02~~  
~~64.63~~  
~~73.65~~

$U^{235}$  man left:  $\frac{5893}{64.10} \times 6.93 =$

Vol. left = 65.8

$U^{235}$  man left:  $\frac{86.69}{70.93} \times 7.26 =$   
6.855

$9m U^{235} = \frac{64.10}{71.36} \times 2.88 =$   
6.855 91.8  
~~6.74~~  
73.82  
74.67

Vol left:  
 $\frac{86.69}{91.86} \times 73.8 = 68.8$   
 $\frac{70.93}{76.10} = 69.65$

12

12/10/59 Expt # ~~9~~ 9

cross Gully Fox

Test for crit. ht. fully refl. at ~ 90 gm/l

9<sup>11</sup> AM Fuel selsyn = 0.03" at soln zero.

9<sup>45</sup> A.M. Fuel selsyn = 18.33" (full) slightly sub.  
 " " = 18.48" slightly super  
 " " = 18.39 just crit. [  
 " " = 18.73 pos. period

10<sup>30</sup> AM Exp 9A

Solndrained and mixed ~30 min. No changes made in concentration.

Fuel selsyn = 0.15" at zero  
 recheck = 0.19

System full at ~ 18.00" according to change in selsyn increments per "td".

11<sup>40</sup> AM

Fuel selsyn = 18.41" just crit.

.19  
 18.22 = actual fuel thickness

Sample #3, 3A; 3B Ref. 593067

#3

$$\text{gm U/gm} = .080245 - \text{gm } \frac{1}{\text{gm}} = .07475$$

$$\text{gm NO}_2/\text{gm} = .04358$$

$$92.0 \text{ gm U}^{235}/\rho$$

$$\text{sp gr.} = 1.2314$$

$$\text{gm U}^{235} = 92$$


12-11-59  
3:40 PM

Expt. 10

Cross, Gilley, Fox

After adding ~ 1 l at conc. 182 gm/l  
cross mixing for 1 hr.

9 mtr checked safety set.

D<sub>2</sub>O Annular full

Fuel zero at 0.10

crit with selsyn - 17.87

Lowered safety &

raised full - full at ~ 18.0"

safety begins to have <sup>an</sup> effect after lower-  
ing ~ 3".

12/14/59  
8:45 AM

Exp. 10 A Repeat of Exp. 10

concentration - 92 g/liter (calculated)

Fuel selsyn = 0.00 at fuel zero

Fuel wt. = 17.87" just crit.

Reactor full at 18.00"

~~D<sub>2</sub>O selsyn = 85.31~~

~~Fuel " = 18.36~~

~~Full " = 18.00~~



14

12/14/59

Exp. 11 changed concentration by adding 2.46 D<sub>2</sub>O10<sup>55</sup>  
A.M.

Fuel selsyn = 0.03" at fuel zero

? 11<sup>20</sup>

18.07" = Fuel selsyn at crit.

? 78.37" = D<sub>2</sub>O selsyn at crit? 80.12" = " " ~~with~~ very slightly super

Question marks are because JJ (East End) was  
on high power level and changing

Fuel selsyn = 17.94" crit

D<sub>2</sub>O " = 74.11" "

12

D<sub>2</sub>O raised to 80.3" Slightly super

Recheck of selsyn (fuel) reading when just full.

Fuel selsyn = 17.91" when full

12/14/59

Exp. 11A

1<sup>25</sup>  
P.M.

Fuel selsyn = 0.03" at sol'n. zero

Fuel selsyn = 17.86 crit

D<sub>2</sub>O " = 81.07

Exp. 11A (cont.)

Fuel selsyn = 17.82" crit

D<sub>2</sub>O selsyn = 80.86" ~~crit~~Fuel selsyn = 17.85" { ~~full~~ }D<sub>2</sub>O " = 74.90" crit

Fuel selsyn at full = 18.00

Added ~0.9 l D<sub>2</sub>O and mixed for 1 hr.12-15-59 Inserted Chromel-Alumel Thermocouples  
in 4 regions:

#						
14D	in Region II	approx. 2"	down from top			
15E	" "	III	" 4"	" "	" "	" "
16F	" "	IV				
17G	outside in air					
18H	in center					

#14 & 15 were inserted down thru vent  
tubes.

12/15/59 Exp. 12 1<sup>00</sup> PM

Fuel selsyn = 0.10" at solution zero

D<sub>2</sub>O " = 85.31 } sub. crit

Fuel selsyn = 18.36 } " "

Full " = 18.00 } " "

Added solution to raise power:

D<sub>2</sub>O selsyn = 85.31 } pos. period

Fuel " = 18.91 } "

Reverted ~ 60 X/2 last level ~~at~~ at crit,1<sup>55</sup> PMFuel selsyn = 18.34, D<sub>2</sub>O = 85.31

Neg. period:

~~Fuel selsyn = 18.34~~D<sub>2</sub>O " = 85.31

Fuel selsyn = 18.01 (Full)

Temp readings 2<sup>30</sup> PM

#	EMF	°C
18	.95	23.75
17	.90	22.5
16	.90	22.45
15	.90	22.5
14	.93	23.2

Thermocouples 15, 16 & 18 were checked by putting them in water at same temp. Readings were #15 - .90; #16 - .89; #18 - .95 m.v.

Switched #16 & 18 at junction in reactor room. Readings were #16 - .94; #18 - .90

12-16-59 Exp # 13 JRF LWG ee  
 8<sup>25</sup> AM D<sub>2</sub>O Selsyn = "56.0" At Zero  
 " " = 73.0" Appears to be full  
 " " = 79.533"  
 Fuel selsyn = 0.14 at zero  
 " " = 17.88" crit  
 Fuel " = 17.98 when full

ReRun of Exp # 13  
 D<sub>2</sub>O Selsyn = 79.533  
 Fuel " = 0.14 At soln Zero  
 " " = 17.94 full  
 fuel " = 17.84 critical

Drained fuel Back to 14.5 and lowered  
 safety Blade to make Reactor sub-crit  
 so that thermal Couple wires could be  
 changed

11<sup>30</sup> AM Temp of soln & D<sub>2</sub>O after above exp.  
 Therm location Millivolts  
 #

14	Fuel	.9522	.9506
15	D <sub>2</sub> O	.8889	.8872

} two readings each  
 ~10 min apart

Temp of #14 = 23.8 °C

" " #15 = 22.2 °C

18

12/16/59

12 <sup>45</sup> PM

Solution mixed through lunch so pump would warm solution some.

12 <sup>50</sup> PM

Fuel sel syn = 0.14 at zero.

" " = 17.83 " crit

D<sub>2</sub>O " = 81.25 " "

Fuel " = 17.93 at full

Temp of soln + D<sub>2</sub>O during above exp.

#	Location	millivolts	°C
14	Fuel	1.0218	25.6
15	D <sub>2</sub> O	0.8914	22.2

pos. period obtained corresponding to just full (17.93).

NOTE: logarithmic amps. had not been calibrated for above period. To be repeated later

## Exp. 13 A Calibration of Control Blade

	Crit control selsyn reading	Period control selsyn reading	Crit wt	T	$P \times 10^4$
Log N amplifiers were calibrated after 1st period	999.95	4.07	18.56	253	2.91
	4.07	7.06	18.33	506	1.54
	7.06	11.02	18.21	228	3.17
	11.02	28.27	17.91	<del>247</del> 237	2.96
	9.49	13.24	18.08	346	2.18

Pos. period corresponding to full reactor:

$$D_2O \text{ selsyn} = 81.3$$

3 P.W.

→ Fuel selsyn = 17.9% (full) for period  
control blade out

$$\text{Crit. wt} = 17.83 \text{ [i.e. selsyn reading]}$$

$$\rightarrow \text{Period} = 231 \text{ sec.} : P = 3.13 \times 10^{-4}$$

12/14/59 Samples # 4 & 4A taken; Reg # = 593068

by phone 0.08047 gm U/gm

app. 1.2352

$$\sim 92.6 \frac{\text{gm U}^{235}}{\text{g}}$$

12/17/59  $\sim 10^{30}$  Sample # 1 of  $D_2O$  from system taken.

12/17/59 Check Out of Thermocouples { These are not the same thermocouples used earlier }

Six (6) Al-Cr thermocouples were made, by heli-arc welding, by inst. dept. All 6 thermocouples were placed in the same neighbourhood in a water bath and the following results obtained:

couple #	MV		couple #	MV		
11	.673	} 11 <sup>30</sup> <sub>AM</sub>	11	.684	} The variation is ~0.25 °C	
12	.677		12	.688		
13	.672		13	.683		
14	.674		14	.683		} 12 <sup>30</sup> <sub>PM</sub>
15	.684		15	.688		
16	.684		16	.692		

12/17/59 Exp. 13-B

Note: It was found that  $\approx 6-8''$  of non-stainless steel rod ~~was in the~~  $\frac{1}{4}$ -in dia was left in the fuel region [protruding down through the counter guide hole]. In addition to the perturbations introduced in the previous otherwise "clean" criticals, there was indication of some corrosion of the rod. A sample was taken for analysis. The purpose of this experiment is to repeat the clean critical with the rod removed [but with possibly small amounts of iron in solution].

$$D_2O \text{ selsyn} = 80.00''$$

$$\text{Fuel selsyn} = 0.14 \text{ at soln. zero}$$

$$\text{Fuel " } = 17.94 \text{ at full}$$

$\frac{10}{2PM}$

$$\text{Fuel " } = 17.85 \text{ at crit.}$$

$$\text{Fuel " } = 17.99 \text{ for pos. period}$$

$$\text{Period} = 196 \text{ sec} : P = 3.62 \times 10^{-4}$$

Soln drained back

$\frac{00}{2PM}$

Temp. by Thermocouples:

couple #	Location	$^{\circ}C$
11	II (fuel)	20.3
12	IV ( $H_2O$ )	17.5
14	I (center)	21.0
16	III ( $D_2O$ )	19.9

#'s 13 & 15 are not in use.



Exp. 13-B (cont.)

Repeat of pos. period

Fuel selsyn = 18.02 (full)

D<sub>2</sub>O " = 85.09T<sub>1</sub> = ~~20~~ 213 , T<sub>2</sub> = 217

4<sup>00</sup> PM

Temp by Thermocouple		
couple #	mV	°C
11	.701	17.5
12	.764	19.1
14	.895	22.4
16	.782	19.6

12/18/59 Exp. 14. Repeat of clean critical to  
 fuel get another check on temperature  
 distribution. Relatively cold water was put  
 in region II (from top) just prior to Exp. 13-A.

Thermocouple #13 was ~~not~~ taped to side of  
 soln storage tank. Temp. by #13 =  $20.1^{\circ}\text{C}$  before  
 feeding solution up (8<sup>30</sup> AM)

9<sup>40</sup> Fuel selsyn = 0.14" at soln zero

Fuel selsyn = 17.83 at crit.

D<sub>2</sub>O " = 83.63 at crit

Fuel selsyn = 18.00 four pos period

[ Fuel region apparently full ~ 17.95 - 18.00 ]

T<sub>1</sub> = 133 sec., T<sub>2</sub> = 136 sec.

These results are not consistent with Exp. 13-B

Temp. Readings by Thermocouple:

Couple #	Millivolts			°C		
	<u>9<sup>20</sup></u>	<u>9<sup>40</sup></u>	<del>9<sup>50</sup></del>	<u>9<sup>20</sup></u>	<u>9<sup>40</sup></u>	<del>9<sup>50</sup></del>
11	.677	.656				
12	.858	.855			21.4	
13	.817	.824			20.6	
14	.864	.862			21.6	
15	.922	.924			23.1	
16	.806	.807			20.2	

24

12/18/59 Exp. 14-A Repeat of last exp. (14) after installing different thermocouple in fuel region [temperatures indicated in fuel were below room temp.] This couple better insulated from solution

Fuel selsyn = ~.14 at soln zero

Fuel selsyn = 17.82  $\mu$ cnt

Fuel " = 18.01 for pos period [full]

$T_1 = 126$  sec,  $T_2 = 127$  sec.

Temp. readings |  $D_2O$  selsyn = 83.0

Couple #	Millivolts	$^{\circ}C$
IV ( $H_2O$ ) 12	.840	21.5
Slab 13	.845	20.1
I (center) 14	.890	22.2
II (Fuel) 15	.856	21.4
III ( $D_2O$ ) 16	.817	20.4

The above reading on slab was taken when solution was in reactor. An earlier reading with soln. in slab = .824 mv.

12/18/59 Exp. 14-B Repeat of 14-A above after mixing fuel and  $D_2O$  for several minutes in order to raise their temperature

Fuel selsyn = 0.14 at fuel zero

$D_2O$  " = 83.0 .2

Fuel selsyn = 17.78 at cut

<sup>1.45</sup> Fuel " = 17.99 for pos period (full)

$T_1 = 65 \text{ sec}$  ;  $T_2 = 65 \text{ sec}$

<sup>1.45</sup>

Temp readings

	Comp #	MV		$^{\circ}C$
		$\frac{100}{\mu m}$	$\frac{45}{\mu m}$	
$H_2O$ (iv)	12 13	.877	.880	22.0
slab	13 14	.970	.908	22.7
center.	14 15	.892	.957	24.0
Fuel	15 H <sub>6</sub>	.872	.958	21.8
$D_2O$	14	.912	.910	22.7


12-21-59 zeroing of vertical traverse list

When selsyn reads zero of counter tip  
 in region IV is up 0.12" from bottom &  
 in region II " " 0.14" " " This  
 is with full reflector water in. The  
 zero is decreased .3-.4" when filling  
 reflector compartments with water.  
 Top limit switch set at 11.81"

Notes on counters

Region III


#3 - 4-235



Two positions counter, pends to rotation of 180°

#4 - 4-235


Region II



(Note added 1/21/60)

See recheck of radius of rotation for Reg III & Reg II p 83

Description of (bare) 4-235 fission chambers:



The al. containing shell is 4" long. The one inch active chamber is located as shown (drawing is not to scale).

Dalley, Rohrer 27.  
70x

12-22-59  
3<sup>30</sup> PM

Expt. 15A Fission ctr in regions I, II  
& III; proportional ctr. in regio III, solution  
same as expt 14. This is a preliminary  
expt. to check on operation of ctr. and crit.  
with perturbation due to ctr.

Fuel zero at  $\sim 0.0$   
crit at 17.89 (full)  $\sigma$   
Vert ctr. lift at 11.82

4<sup>15</sup>  
PM

Counters lowered to  $\sim 6$ " (tip from bottom) and  
slow ( $\sim 14$ ) neg. period resulted.

Counters lowered to 0.00 and positive  
period resulted (few cents) [counter heads  
were near inside edges of respective regions]

Counters rotated  $90^\circ$  so counter heads  
are near center of regions; also counters raised  
to  $\sim 7.5$ " Crit. Pt.  $\approx 17.95$

all  
ch  
ted

12/23/59 Exp. 14

Region I counter "zeroed" against wall. When chamber just touches wall selsyn reads 4 units = .02"

Fuel selsyn = 0.10 at solution zero

P<sub>20</sub> " = 81.8

Fuel selsyn = 18.00 when full

Fuel selsyn = 17.98 at crit.

Center  
counter  
position

Rotating Counter position Counts obtained at crit. with vertical selsyn = 7.49

Rotating Counter position	I 16, 0.8, 15	II 16, .8, 15	III 16, .8, 10	IV 16, .8, 13	
181 489	98 700	5000	58+6	55+17	1 min
" "	98 820	4820	57+16	52+55	"
" "	99 090	4930	56+46	55+29	"
" "	102 630	5320	59+18	62+13	"
" "	102 470	5150	60+49	60+19	"
181 489	108050	4630	53+35 <sup>x64</sup>	52+54 <sup>x64</sup>	1 min
" "	109500	4730	51+45 <sup>x64</sup>	54+51 <sup>x64</sup>	"
" "	107370	4650	54+56 <sup>x64</sup>	49+50 <sup>x64</sup>	"
" "	107140	4480	54+5 <sup>x64</sup>	50+19 <sup>x64</sup>	"
194 489	107670	4580	54+5 <sup>x64</sup>	69+56 <sup>x64</sup>	11
" "	106850	—	54+35 <sup>x64</sup>	71+30 <sup>x64</sup>	
" "	106710	4430	52+32 <sup>x64</sup>	68+30 <sup>x64</sup>	

Amplifier Settings:

Counters		Detector		Amplifier Setting			HV
Region	Channel	<del>Fission Ctr #</del>	Fission Ctr #	Gain	R.T.	PDL	<del>135 v (batt)</del>
I	1		fission ctr #5-4-235	16	0.8 us	15	135 v (batt)
II	2		" 4-235	16	0.8 "	15	135 v "
III	3		" 3-235	16	0.8 "	10	135 v "
IV	4	BF <sub>3</sub>	767	16	0.8 "	13	1400 v

IC-3 = ~ .1 ; IC-4 = ~ .02

<del>Set #</del>		I	II	III	IV	
221	489	105920	—	51+3 <sup>x64</sup>	173+7 <sup>x64</sup>	
"	"	102750	4260	49+6 <sup>x64</sup>	154+22 <sup>x64</sup>	
"	"	102900	4390	49+27 <sup>x64</sup>	143+5 <sup>x64</sup>	
"	"	103010	4460	51+46 <sup>x64</sup>	149+24 <sup>x64</sup>	
271	489	98480	4800	43+4 <sup>x64</sup>	325+21 <sup>x256</sup>	
"	"	99160	4770	44+32 <sup>x64</sup>	362+61 <sup>x256</sup>	
"	"	100780	4780	45+34 <sup>x64</sup>	410+56 <sup>x256</sup>	
"	"	103080	—	46+2 <sup>x64</sup>	44+131 <sup>x256</sup>	#1 PDL=15
"	"	104900	5060	46+7 <sup>x64</sup>	45+64 <sup>x256</sup>	"
"	"	106160	5330	47+11 <sup>x64</sup>	45+177 <sup>x256</sup>	"
"	"	103490	—	44+52 <sup>x64</sup>	165+5 <sup>x64</sup>	"
"	"	100550	4930	43+58 <sup>x64</sup>	155+14 <sup>x64</sup>	"
"	"	98610	4860	43+27 <sup>x64</sup>	142+34 <sup>x64</sup>	"
"	"	98320	4790	43+0 <sup>x64</sup>	138+62 <sup>x64</sup>	"
360	489	84290	9180	27+58 <sup>x64</sup>	305+10 <sup>x64</sup>	"
"	"	78860	8590	25+23 <sup>x64</sup>	269+32 <sup>x64</sup>	"
"	"	73000	8110	23+8 <sup>x64</sup>	216+30 <sup>x64</sup>	"



Exp. 16 (cont.)

## Temperature

Region	Sample #	mV		°C	
		2 <sup>30</sup>	3 <sup>00</sup>	2 <sup>30</sup>	3 <sup>00</sup> pm
H IV	12	.834	.841	20.7	20
B slab	13	.785			
H I	14	.921	.945	23.0	23.5
H II	15	.766	.772	19.0	19.4
H III	16	.890	.900	22.2	22.5

12-24-59

Exp. 16-A ~~At~~ Preliminary Traverse with four  
counters and check-out of instruments.

$$D_2O \text{ selsyn} = 81.4$$

$$\text{Fuel selsyn} = 0.13 \text{ at solution zero}$$

32

## Expt 16 B

12/28/59 Preliminary traverse and check out of counting equipment.

9<sup>00</sup> AM. Fuel selsyn = 0.10 at soln zero

D<sub>2</sub>O " = 82.5

Fuel selsyn = ~18.00 at full.

Fuel " = 17.94 (essentially full) for traverse with exact critical being maintained with control blade.

Vertical list selsyn	Rotating counter's selsyn	Reg. I counter selsyn	I	II	TOT	TD	
7.5	361	488	346568	190+89 <sup>255</sup>	314+33 <sup>x64</sup>	371220	10 <sup>43</sup> min
"	<del>340</del>	"	348794	191+169	310+28	368040	"
"	340	"	365396	155+221	340+35	348850	"
"	"	"	397996	163+180	397+12	397960	10 <sup>50</sup> "
"	320	"	410963	137+210	430+45	340870	"
"	"	"	430339	142+57	456+43	369040	"
"	302	"	459064	132+150	519+40	324630	"
"	"	"	471685	140+149	530+9	336350	11 <sup>02</sup> min
"	281	"	468369	120+87	533+16 <sup>x64</sup>	221400	"
"	"	"	462351	116+106	145+65 <sup>x256</sup>	215810	"
"	261	"	471730	106+253	192+202 <sup>x256</sup>	143260	"
"	"	"	484430	109+181	199+124	149200	"
"	239	"	509198	110+97	180+6	100600	11 <sup>17</sup> min
"	"	"	509767	109+99	179+205	99320	"
"	220	"	512618	104+146	197+109	60650	"
"	"	"	512178	105+62	195+198	61120	"
"	200	"	518445	107+30	194+89	36240	"
"	"	"	526050	107+219	198+253	37650	"
"	180	"	540252	109+129	209+11	23170	"
"	"	"	542620	115+159	211+34	22800	"

Vertical Left	Rotating ctr. Pos.	Reg. f. se/sg n	I	II	III	IV	
7.5"	160	488	547941	120 <sup>+</sup> 239	199 <sup>+</sup> 22	14000	
"	"	"	533027	121 <sup>+</sup> 204	201 <sup>+</sup> 31	—	
"	140	"	554583	127 <sup>+</sup> 63	192 <sup>+</sup> 211	—	
"	"	"	541057	126 <sup>+</sup> 53	189 <sup>+</sup> 113	7800	
"	120	"	528120	127 <sup>+</sup> 231	173 <sup>+</sup> 172	4680	
"	"	"	534910	132 <sup>86</sup>	174 <sup>181</sup>	4730	
"	100	"	537420	143 <sup>128</sup>	168 <sup>251</sup>	3420	11 <sup>53</sup> AM
"	"	"	536334	140 <sup>171</sup>	170 <sup>68</sup>	3430	
"	80	"	535802	147 <sup>159</sup>	164 <sup>252</sup>	2760	
"	"	"	536682	150 <sup>243</sup>	167 <sup>90</sup>	2880	
1min	60	"	536180	164 <sup>1</sup>	160 <sup>184</sup>	2370	
"	"	"	534625	164 <sup>59</sup>	163 <sup>21</sup>	2570	
"	40	"	535586	174 <sup>174</sup>	156 <sup>25</sup>	1800	
"	"	"	535714	175 <sup>195</sup>	157 <sup>231</sup>	1790	
"	20	"	538108	184 <sup>146</sup>	154 <sup>19</sup>	1410	
"	"	"	537022	184 <sup>74</sup>	153 <sup>90</sup>	1470	
"	0	"	534977	191 <sup>220</sup>	151 <sup>00</sup>	1130	
"	"	"	533364	195 <sup>237</sup>	150 <sup>740</sup>	1180	
"	59	"	537047	167 <sup>112</sup>	155 <sup>148</sup>	1770	
"	"	"	539194	174 <sup>194</sup>	150 <sup>72</sup>	—	
"	120	"	543622	138 <sup>35</sup>	224 <sup>11</sup>	—	
"	"	"	546929	136 <sup>148</sup>	228 <sup>182</sup>	5110	
"	180	"	523125	109 <sup>+</sup> 241	233 <sup>+</sup> 127	18510	
"	"	"	518364	113 <sup>+</sup> 188	235 <sup>+</sup> 33	17480	
"	240	"	507216	107 <sup>+</sup> 162	194 <sup>+</sup> 227	94940	
"	"	"	508225	108 <sup>+</sup> 216	187 <sup>+</sup> 37	93990	
"	280	"	488968	121 <sup>+</sup> 209	147 <sup>+</sup> 216	237520	50 12M
"	"	"	478274	121 <sup>+</sup> 114	146 <sup>+</sup> 153	229600	

Vent. list	Rot. Ctr. position	Reg. I Ctr. position	I	II	III	IV	Vent. list
7.5	300	488	442631	126+18	122+248	282890	7.
"	"	"	427361	125+ <del>103</del> <sup>87</sup>	121+21	262430	"
"	320	"	413990	146+205	104+9	339220	"
"	"	"	412475	142+73	103+215	335350	"
"	360	"	365339	197+59	78+69	376680	"
"	"	"	355058	188+165	76+194	357500	"
Counts for			Center	Traverse			
7.5	360	440	417167	290+ <del>4</del> <sup>256</sup>	90+ <del>225</del> <sup>256</sup>	450730	
"	"	"	424936	290+94	91+116	460670	24
"	"	390	424714	301+18	93+163	474770	
"	"	"	431033	305+214	93+56	474350	33
"	"	340	425645	241+153	92+217	469600	
"	"	"	422746	230+69	92+163	457770	
"	"	290	402052	225+220	88+149	421840	
"	"	"	400265	217+43	88+5	411220	
"	"	240	380325	266+153	83+154	380430	
"	"	"	378871	278+217	84+208	371600	1
"	"	190	354966	258+149	80+183	344300	1
"	"	"	354566	250+106	81+197	342600	0
"	"	140	317928	245+7	76+174	316790	8
"	"	"	314805	232+230	76+114	304690	
"	"	90	279015	238+216	74+160	293890	
"	"	"	273076	243+194	73+155	281370	
"	"	40	219613	172+248	69+144	258280	
"	"	"	213304	217+191	67+4	240910	

Vert list.	Rot Ctr- position	Reg I Ctr position	I	II	III	TD
7.5	360	-10	162525	212+220	69+93	250650
"	"	"	167366	240+86	70+178	264230
"	"	-30	151196	242+254	78+88	315980
"	"	"	158496	218+51	82+111	345780

~ 4<sup>00</sup>  
PM

~~I~~ The region I counter was found to not have the stroke anticipated. Some alterations were made and new selsyn zero determined. Chamber is against wall when selsyn = ~~499.3~~ 2 units. Stroke now is  $\sim 3\frac{3}{8}$ ".

The counter in region II touches the wall of region I hard enough to almost hang when rotated by hand. It is worse near the upper end of the stroke, but is present also when at the mid-plane. It does not touch the wall of region III. Either the bearings of region II counter are not in the center of the annulus or the counter is bent slightly.

Rotating Counter position indicator reversed to read zero at ctrs. pointing toward center rather than opposite center direction



12-29-59 Expt 17 Horizontal traverse  
at approx. midplane (Left relyn read  
7.50")

Fuel zero ~ .10"

D<sub>2</sub>O at 82.17"

F<sub>1</sub> at ~ 17.9" Region I ctr. at 562

Rot. ctr Pos.	Region I	Region II <sub>x256</sub>	Region III <sub>x256</sub>	Region IV	Reg II ctr.	Reg III ctr.
0*	136270	109+40	29+111	93100		
0	135910	107+51	28+245	90640		
20	139195	92+44	31+66	79240		
"	144538	94+184	30+162	83310		
"	149047	98+238	31+192	90750		
Restart after work on ctr					x100	x100
0	441673	359+98	38+5	902590	920.0	99.2.
"	450370	365+69	39+93	909950	935.0	100.8.
20	490921	336+15	45+83	905440	860.0	116.0.
"	530986	367+59	49+44	1004270	940.0	126.0
41	265909	143+184	26+1	268020	367.7	546
"	270598	146+25	26+112	<del>2</del>	374.0	577
"	286838	166+68	27+211	305780	399.0	712
60	292617	134+106	29+223	251370	344.2	746
"	291765	132+234	30+137	246910	340.7	782
80	297057	115+43	35+91	185030	295.0	905
"	301960	118+142	37+95	191960	303.8	957
100	311531	109+9	39+231	145410	279.0	1022
"	321127	109+151	41+182	149550	280.7	1067
120	337334	107+119	45+9	117590	275.3	1162
"	345678	109+171	45+78	123200	280.5	1157

Zero at ctr nearest center of reactor



~~1~~  
I

Rect. Pos.	Reg I	Reg II	Reg III	Reg IV	Reg II ctr.	Reg III	
140	354807	108+122	67+93	90890	2779	1725	
11	362543	110+54	72+129	94400	2822	1854	
160	381440	113+78	50+39	73860	2900	1285	
11	390633	115+175	51+107	76080	2940	1318	.3875
180	406248	124+8	54+42	63740	3175	1388	.342
11	<del>377974</del>	114+33	49+19	57090	2920	1255	.332
200	341268	105+179	44+262	41490	2704	1152	.338
11	333228	105+41	44+242	41060	2693	1152	.344
11	325824	101+167	41+89	38830	2600	1057	.3245
220	322131	106+94	75+17	35570	2725	-	-
11	320080	105+252	59+9	35440	2715	1510	.472
11	319349	104+29	61+149	34920	2665	1574*	.493
240	320400	113+252	<del>70+46</del>	35280	2920	-	<del>.493</del>
11	320789	113+40	61+141	35080	2896	1574	.491
11	320558	113+122	64+243	35060	2916	1662	<del>.5185</del>
Stopped and checked on Reg II ctr. (same settings on ctr.)							
240	294559	106+1	24+27	28340	2715	617	.2093
11	295521	107+95	23+201	28580	2726	611	.2067
11	298209	109+60	24+194	29180	2795	634	.2125
260	311694	121+44	25+84	32220	3102	648	.2080
11	318578	122+230	25+145	32650	3148	656	.2060
280	327805	136+45	25+192	35780	3487	661	.2016
11	339873	143+163	26+203	37720	3678	686	.2018
300	327403	148+144	24+49	38770	3800	620	.1893
11	306801	140+188	22+213	36630	3600	586	.1911
320	317472	154+41	23+100	39980	3950	599	.1886
11	329868	160+181	24+63	41700	4113	620	.1880
340	316437	162+186	22+169	42100	4163	580	.1832
11	305137	157+90	22+53	40690	4030	569	.1865
360	295624	153+97	20+143	39550	3928	527	.1783
11	287798	149+149	20+15	38560	3830	514	.1785

Reg I	Reg II	Reg III	Reg IV	$\frac{I}{x_{100}}$	$\frac{II}{558}$	
300	292328	134+166	21+201	34970	345	558
11	304300	139+247	22+48	36360	358.4	568
240	317041	115+84	25+204	30950	295	661
11	315452	116+8	25+69	30840	297	648
200	312155	98+148	26+257	29010	252.5	691
200	308763	98+136	26+147	28930	252	681
160	299904	88+68	26+87	33620	226	674
11	302351	90+87	26+171	34440	231.3	683
100	293059	95+223	24+29	75170	245.5	617
11	281988	93+156	23+15	70090	239	590
50	257342	125+62	17+87	144910	321	444
11	252774	121+254	17+24	136570	312.2	438
0	242912	191+86	13+112	229380	490	344.5
11	240805	192+25	13+215	226570	492	354.5

ctr. Pos Traverse in region I (Rat Pos. = 0)

563	Use last two ctr. above						
510	237181	188+74	13+198	216450	482	353	9989
11	242889	191+129	13+230	222690	490	356	1006
460	258442	206+227	14+188	247960	529	378	9917
11	255331	202+87	14+141	240680	518	372.5	1000
410	244025	194+192	13+210	222090	499	353.5	9925
11	242950	193+26	13+145	218710	494.5	348	9971
360	240459	192+204	13+159	214600	493.5	348	9992
11	238640	191+180	13+220	210030	491	354.5	9864
310	228944	184+91	12+224	201360	472	330.5	9843
27	223767	179+153	13+12	191910	460	334	9876
200	218986	180+130	12+186	193120	462	325.5	9622
11	219593	179+197	12+182	195020	460	325	9691
210	206760	177+33	12+182	188720	453.5	325	9257
11	201885	173+87	12+116	180390	444	319	9230

ctr Pos.	Reg I	Reg II	Reg III	Reg IV	I	II		
160	188358	173+143	12+111	172600	444.5	319	9650	
11	193789	176+153	12+240	179090	452	331.5	8705	
110	174202	177+30	12+125	181150	453.5	322.5	7797	
11	174175	172+218	12+139	174410	442.5	321	7992	
11	168746	171+132	11+202	169390	439	302	7799	
600	139755	171+202	12+6	168850	440	307	6449	
11	141411	170+148	12+48	166780	437	312	6567	
30	117949	168+197	11+250	165570	432	307	5540	
11	119258	169+211	12+2	167980	435	307	5566	
0	97439	179+225	13+26	185600	460.5	335.5	4295	
11	100336	189+231	13+28	200890	486	340	4189	
110	184086	184+157	13+99	190140	472.5	343	7909	
11	183418	182+246	12+133	187570	468.5	320	7945	
210	227579	193+57	13+180	205500	495	351	9334	
11	264589	206+66	14+125	229520	528	371	1017	
310	272978	220+96	15+125	261980	562	397	9856	
11	287666	232+189	16+127	285430	596	422	9799	
9999	410	294259	237+184	16+59	288930	608	415	9825
6006	11	295834	237+252	16+230	289750	610	433	9843
7911	510	300133	243+238	17+15	301310	624	437	9762
6000	11	296370	237+13	16+132	289530	607	422.5	9912
9925	563	286469	231+145	16+50	274060	593	415	9807
9971	11	282473	227+214	16+58	266540	583	415	9837
9892								
9864								
9843								
9876								
9622								
9691								
9257								
9230								

Pos	I/E	II/E	III/E	Pos	I/E	II/E	III/E
0	.208	.0220	.2043	240	.0922		.09619
0	.208	.0224	.2020	"	.0922		.09670
20	.175	.0236	.1844	"	.0938		.09785
"	.177	.0237	.1891	260	.0996		.1034
41	.138	.0213	.1007	"	.0988		.1025
"	.138	.0213	-	280	.1065		.1092
"	.139	.0248	.1066	"	.108		.1110
60	.117	.0262	.8591	300	.116		.1184
"	.117	.0268	.8461	"	.1174		.1194
80	.0994	.0205	.6227	320	.1245		.1259
"	.101	.0317	.6358	"	.1248		.1264
100	.0895	.0328	.4667	340	.1316		.1331
"	.0875	.0332	.4657	"	.1320		.1334
120	.0816	.0341	.3486	360	.1328		.1337
"	.0812	.0336	.3563	"	.1331		.1339
140	.0784	.0486	.2562	300	.1182	.01909	.1196
"	.0777	.0511	.2604	"	.1178	.01867	.1195
160	.0761	.0337	.1937	240	.09306	.02085	.09763
"	.0757	.0337	.1948	"	.09410	.02054	.0977
180	.0782		.1569	200	.08088	.02213	.0929
"	.0773		.1510	"	.08160	.02205	.0937
200	.0793		.1216	160	.07536	.02247	.1121
"	.0809		.1232	"	.07648	.02259	.1138
"	.0798		.1192	100	.08375	.02105	.2564
220	.0846		.1104	"	.08475	.02092	.2485
"	.0848		.1107	50	.1248	.01726	.5631
"	.0836		.1093	"	.1235	.01733	.5403
240	.0912		.1101	0	.2017	.01418	.944
"	.0903		.1094	"	.2043	.01472	.9406
"	.0910		.1094				-

46

12-31-59

Expt 18

Billy, Robert  
Fox

Horizontal Traverse

vert. lift ht 7.50"

D<sub>2</sub>O annular fall  
Fuel " "

Req I Horiz. Pos.	Req I	Req II	Req II	Req III	Req III	D/K	
25 8	1414720	.1212	35220	03013	<del>70</del> 2765	?	2369
"	146918	.1211	36910	03043	<del>4668</del>	?	267
"	152019	.1215	38120	03047	3720	?	2974
57 40	186444	.1297	30220	02103	3980	?	2769
"	192446	.1305	31340	02125	4135	?	2803
87 70	222217	.1361	24870	01523	5410	?	3313
"	225251	.1361	25030	01511	5340	?	3225
"	222445	.1360	24700	01510	5400	?	3300
117/00	249967	.1439	21870	01259	6110	?	3518
"	243756	.1410	21580	01248	6080	?	3516
147/30	246586	.1443	26370	01191	6080	?	3557
"	248692	.1452	20570	01197	6110	?	3567
207 90	269921	.1490	21280	01175	6450	?	3561
"	272153	.1501	21350	01177	6480	?	3574
247 250	271978	.1513	21250	01182	6440	?	3584
"	275621	.1509	21460	01175	6540	?	3582
310	290210	.1528	23330	01229	6360	?	3349
347	300052	.1526	24500	01246	6710	?	3413
360	304970	.1535	25860	01301	7050	?	3548
"	297135	.1535	25030	01293	6870	?	3550
42 410	292050	.1538	26360	01388	6490	?	3417
"	284996	.1524	25830	01381	6470	?	3460
47 460	285031	.1548	27170	01475	6150	?	3341
"	285786	.1554	27380	01488	6040	?	3283
57 500	280146	.1516	29880	01617	6800	?	3139
	184968	.1503	29810	01616	6940	?	3220

III - 15 - 21.3°C at 3:50 PM  
 II - 11 - 21.2 "  
 IV - 14 - 21.4 "  
 I - 12 - 21.1 "

Rot. Pos	Reg IV	Normalizer	Reg V
<del>Reg IV</del>	<del>Reg IV</del>		
0	1689490 <del>1668521</del>	1.447	1166821
"	1695720	1.41 1397	1213086
"	1727550	1.381	1251095
40	1659130	1.152	1437147
"	1802650	1.154	1475216
80	1417890	8683	1632536
"	1423930	8599	1656286
"	1411600	8631	1636339
120	1616590	5854	1737125
"	1603720	5807	1729478
140	785900	4599	1709328
"	782280	4546	1712772
160	659260	3641	1811027
"	664730	3666	1813004
180	484880	2698	1797180
"	489610	2681	1826227
200	381290	2007	1898847
"	393470	2002	1966063
220	294950	1484	1986975
"	286400	1480	1935301
240	209060	1101	1898538
"	205090	1096	1870408
260	151640	8234	1841055
"	150950	8206	1839414
280	113670	6152	1847306
"	113800	6168	1844642

Reg I Pos	Reg I		Reg II		Reg III	III/II
500	278479	1514	29540	.01606	5840	3176
540 <sup>557</sup>	277294	1537	33850	.01876	5330	2955
"	264590	1501	32990	.01871	5170	2932
600 <sup>617</sup>	243564	1494	32860	.02016	4955	3040
"	246245	1518	32760	.02018	4868	2994
655 <sup>612</sup>	225641	1426	31690	.02003	4675	2955
"	219258	1424	31080	.02019	4635	3012
540 <sup>557</sup>	254894	1505	30180	.01782	5350	3158
"	268453	1502	32130	.01796	5760	3221
460 <sup>477</sup>	275709	1520	26620	.01471	5980	3303
"	278458	1519	26900	.01468	5910	3224
360 <sup>377</sup>	284416	1522	23980	.01284	6235	3338
"	290916	1530	24660	.01297	6065	3192
250 <sup>267</sup>	292463	1517	22660	.01175	6420	3330
"	293982	1519	23220	.01200	6340	3276
130 <sup>147</sup>	278277	1446	23490	.01221	6165	3204
"	278791	1449	23260	.01208	6285	3267
70 <sup>87</sup>	243592	1369	36810	.02068	5875	3301
"	254195	1416	37280	.02077	5780	3220
926	199760	1222	50020	.03061	85210	3188
"	201119	1223	50690	.03083	5110	3108

$\bar{z}$	Rot Pos. I	Reg III	D/E	Reg II
6	280	113350	6166	1839392
55	320	165780	3646	1804304
32	"	64170	3639	1763266
10	360	36690	2251	1630368
94	"	36660	2259	1622907
55	"	35480	2242	1581886
12	"	34620	2250	1539094
58	280	69790	4119	1693741
27	"	74140	4147	1787905
303	240	148340	8192	1809760
24	"	149920	8177	1833194
338	200	258240	13822	1867796
92	"	261570	1377 4505	1900472
30	160	322460	2710	1928401
276	"	529250	2735	1934978
204	120*	1004830	5223	1924072
167	"	1001300	5202	1923954
301	40	1942670	1091	1780271
220	"	1941960	1082	1794526
188	0	2063640	1262	1633552
108	0	2047720	1246	1643528

Reg I zero found to be ~~17~~ -17 for above expt.

Note added 1/4/60: The D<sub>2</sub>O traverse counter was found to be loose in its sleeve and "off" ~ 90°.

\* Drive stopped at one pt. due to some obstruction



1-4-60

Expt 19  
Horizontal Traverse

Vert. left at 7.50" Reg I reads 2 at wall

Level zero at 0 D.D. at 81.4

Root Pos.	Reg I Position	Reg. I	Reg II	Reg IV	Normal.	Reg III
0	2	227066	62450	<del>270500</del> 5860	2016727	5860
"	"	233698	64830	2732100	2071358	6080
"	"	238963	65240	2735800	2109652	6085
48	40	278692	62610	2460730	2242936	6970
"	"	277284	65640	2705190	2340589	7300
80	90	352327	47840	2374720	2517852	9620
"	"	374922	44150	2239230	2348895	8840
"	"	301498	39390	2073070	2131470	7840
100	130	283098	31130	1662430	2005151	8010
"	"	290564	31770	1686620	2037858	8120
120	170	311418	28510	1422240	2122322	8450
"	"	318368	29470	—	2172935	9290
"	"	257095	30550	1480880	2224346	9640
140	210	231271	30200	1286910	2371569	10500
"	"	253789	32580	1356030	2543950	11350
161	250	425456	34230	1174970	2766559	12830
"	"	446619	35920	1211660	2879348	13200
180	290	442406	34710	945430	2837302	13400
"	"	436386	34540	923010	2800921	13100
200	330	447223	34640	709880	2844631	13100
"	"	458869	35810	729550	2916926	13480
220	370	468590	38100	—	2973206	13370
"	"	467235	37980	555310	2968783	13660
"	"	468224	37980	548940	2976281	13400
240	410	470562	40290	407200	2993950	13170
"	"	476203	41030	412140	3018895	13570
260	450	481824	43720	304800	3046600	13000
"	"	481658	44410	307980	3057831	12840

291  
292  
293

Reg I	I/II	II/IV	III/IV	IV/IV
0 0	.113 1126	.310 3097	.291 2905	132 1341
" "	1128	3130	2936	1319
" "	1132	3092	2883	1297
40 40	.126 1242	.280 2791	311 3107	1186
" "	1269	2803	3118	.117 1155
80 90	.140 1292	.188 1899	375 3820	4432
" "	1596	1879	3763	.95 4531
" "	1415	1848	3679	4727
100 130	.142 1412	.156 1553	399 3993	.83 8285
" "	1425	1558	3982	8278
120 170	.147 1467	.136 1343	425 4217	6701
" "	1465	1356	4275	6659
" 210	1156	1373	4335	.6659 5421
140 210	990 4751	.128 1273	444 4420	5421 5330
" "	9970	1281	4461	5330 4244
161 250	.155 1537	.124 1237	461 4636	4246 4227
" "	1551	1244	4584	4227 3332
180 290	.158 1567	.123 1223	470 4723	3332 3245
180 290	1558	1233	4676	3295 2495
200 330	.157 1572	123 1218	461 4604	2495 2501
" "	1573	1228	4620	2501 1870
220 370	.158 1576	.128 1281	453 4497	1844
" "	1574	1279	4601	1870 1360
" "	1575	1276	4502	.1844 1366
240 410	.158 1572	.135 1345	444 4388	1360
" "	1577	1359	4494	1366
260 450	.158 1581	.145 1434	424 4266	1007
" "	1578	1455	4207	1009

Rot. pos.	Reg. I pos	I/V	II/V	III/R	IV/R
280	490	.158 1582	.157 1577	414 414	.07601
"	"	.158 1583	1552	4133	7546
300	530	.160 1612	.170 1698	4015 401	
"	"	.160 1594	1697	4017	5577
"	"	1596	1705	3980	5613
360	600	1554	.211 2106		2715
"	"	.157 1563	2112	3712 373	2698
"	"	.157 1565	2103	3754	2743
"	"	1568	2105	3751	2702
300	679	.1515 1508	.179 1793	3996 400	5000
"	"	1519	1775	4003	5040
260	600	.157 1574	.154 1536	4223 421	8142
"	"	1573	1537	4194	8072
200	530	.159 1588	.125 1258	4602 463	2109
"	"	1584	1245	4660	2121
160	450	.159 1595	.127 1261	4645 470	3698
"	"	1591	1275	4769	3711
110	370	.158 1582	.144 1440	4441 444	6446
80	290	.158 1573	.182 1810	4002 403	8226
"	"	1576	1827	4057	8266
40	210	.154 1535	.280 2790	3257 328	9910
"	"	1535	2805	3306	9907
2	130	.144 1437	.328 3270	3006 299	1014
0	"	1442	3290	2970	9931
140	40	.127 1270	.134 1340	4610 458	5771
"	"	1267	1338	4568	5111
"	2	.117 1166	1337	4559	5152
"	"	1167	1325	4576	

Expt 19 Cont

Reg Pos.	Reg I Pos.	Reg I	Normal	Reg II	Reg III	Reg IV
280	490	485431	306,8121	48,360	12700	233150
"	"	486403	3073183	47700	12700	231920
300	530	491865	3051050	51860	12250	-
"	"	481850	3024584	67340	12150	168770
"	"	478898	3000114	51880	11940	168430
360	600	464204	2987436	62910	<del>1150</del>	81100
"	"	486015	3104396	65650	11540	83850
"	"	502530	3280250	67490	12050	88040
"	"	570128	3252211	68480	12200	87880
380	679	492021	3260240	58420	12030	163020
"	"	508398	3347078	59390	12040	168680
260	600	526293	3343030	51350	14120	272150
"	"	522583	3319609	51010	13920	268020
200	530	519259	3268336	41130	15040	689410
"	"	518735	3273933	42020	15260	694270
160	450	529050	3315249	41800	15400	1223990
"	"	531794	3343606	42640	15950	1241010
"	370	518337	3276306	47200	14550	2112370
80	290	502773	3195804	57820	12790	2628740
"	"	509929	3178678	58090	12900	2628190
40	210	461290	3005358	83850	9790	2978430
"	"	461623	3007066	84340	9940	2979160
2	130	442727	3080660	800620	9260	3123610
"	"	460293	3191537	105040	9480	3170020
100	40	417023	3284355	44020	15140	1697780
"	"	407458	3215827	43030	14690	1644250
"	2	367504	3152202	42170	14370	1623870
"	"	371036	3179390	42130	<del>14550</del>	-

↳ after expt. it was found that Reg. I counter at zero was actually 0.49 inch from wall, due to tube not being vertical

54

Exp. 20  
1/6/60Horizontal 4-235 traverse  
Vertical position system = 7.5

Rot pos.	Reg I pos	Reg I	Nor	Reg II	Reg III	Reg IV	AT	
0	0	284406	1563892	137000	9250	8016420 <del>925</del>	6 min	
"	"	248867	1375865	120610	8020	7270930	"	
40	40	376935	1308625	103320	8270	7271010	"	
"	"	401070	1340174	105510	8310	6602810	"	
80	80	335428	948061	48910	7300	3731040	9 "	
"	"	547535	1019516	51920	7720	3,806360	"	
100	120	374846	1096190	47850	8910	3502010	"	
"	"	396704	1161572	50880	9420	3952650	"	
120	160	437742	1179485	44860	10120	2958390	"	
"	"	418852	1123727	43200	9940	3040590	"	
-		stopped (lowered safety) to check on Reg IV						

	I/N	II/N	III/N	IV/N
	.1818	876	592	512
	.1807	877	583	528
	288	790	632	556
	298	788	620	493
x	347	505	755	385
	.537	.509	757	373
	.342	.437	.813	3195
	342	438	811	340
	371	380	.858	251
	372	384	.884	270

Preliminary Vertical Traverse  
Region IV ctr. outCounters rotated to  $\sim 90^\circ$ , Region I ctr. at  
 $\sim$  center

Vertical pos	I	Nov	II	III	<del>III</del> III/N	I N
.32	430971	1518783	41150	1137	754	.284
"	481390	1693835	45900	1290	762	.284
.75	494971	1644561	44630	1354	822	.301
"	<del>477568</del> <del>47568</del>	1584539	42720	1300	821	.301
1.25	481584	1498039	41010	1256	839	.3215
"	443324	1439940	38660	1136	790	.3216
1.75	502418	1478296	42010	1492	101	.340
"	530689	1557557	44170	1260	808	.341
"	523496	<del>1532197</del> 1532197	43250	1210	790	.3415
2.25	525182	1480211	42710	1205	814	.355
"	506118	1424957	41260	1145	804	.355
2.75	497864	1348725	40250	1120	831	.3695
"	488498	1326969	39480	1067	805	.368
3.25	593624	1545702	47500	1315	850	.384
"	606154	1579819	49140	1349	853	.3835
3.75	616224	1560356	49540	1350	865	.395
"	604429	1533938	48490	1332	868	.394
4.25	602394	1487311	48310	1294	870	.405
"	582437	1441009	46780	1257	873	.404
4.75	587771	1423901	46980	1265	889	.413
"	589769	1431810	47630	1280	894	.412
5.25	598952	1428012	48120	1262	884	.419
"	594123	1417055	47650	1309	924	
"	588509	1405189	46980	1269	903	

H/N

.271 542

.271

2715 542

.270

5 274 550

6 .2755

.284 568

284

5 .282

5 .289 578

5 2895

75 2985 596

8 .297

4 .3075 618

35 311

5 .318 636

4 .316

5 .325 650

4 .325

3 330 664

12 .3325

19 .337 674

336



Vert. pos	I	N	II	III	IIIN	IIIN	IIIN	
575	603586	1426706	48300	1303	912	428	3385	7
"	625731	1473016	50150	1350	917	425	340.680	
625	630792	1475141	50520	1361	923	4270	344.688	3
"	612583	1433388	49120	1313	916	428	343	
675	603612	1405183	48060	<del>1264</del> 197	899	4295	342.686	
"	601038	1396758	47710	1309	936	4305	3415	
"	594917	1381180	47490	1335	967	431	344	
725	592297	1373707	47190	1309	953	431	344.688	
"	596477	1386002	47520	1330	959	430	343	
775	603412	1402405	47750	1324	944	4305	3405.686	
"	606129	1413136	48640	1393	985	4290	344	
825	610888	1427286	49100	1376	964	428	344.684	
"	623287	1453285	49240	1376	947	429	339	
875	631430	1488230	50170	1380	928	424	337.674	
"	640960	1512212	51210	1412	933	424	339	
925	650068	1553136	51940	1427	919	419	3305.668	
"	657021	1570220	52490	1455	927	4185	334	
975	676060	1628962	53030	1467	901	415	324.652	
"	692872	1665300	54340	1489	924	416	3265	
1025	642029	1568308	49800	1385	884	4095	3175.640	
"	589423	1446319	46640	1295	896	4085	323	
1075	575595	1457535	45140	1268	870	395	310.620	
"	583987	1464555	45410	1286	879	399	310	
1125	586054	1514680	45670	1314	867	387	3015.600	
"	600194	1536586	46520	1350	877	3905	303	
1175	570105	1535819	44440	1274	829	371	289.582	
"	549614	1522907	44550	1275	837	3735	292	

	I	N	II		III/N	I/N	II/N
	775	615918	1433364	48990	1334	931	430 <del>342</del> 342 (684)
680	"	611106	1423999	48500	1331	935	429 341
688	325	581327	1520248	47310	1280	842	383 311 (624)
	"	605272	1580835	49540	1364	863	383 313
5-686	.32	456813	1619218	43620	1166	721	282 269
	"	454012	1601340	43110	1117	698	2835 2695
							(538)
4 688							
3							
5 686							
f							
4 684							
39							
37 674							
39							
365							
34							
24 652							
265							
175 640							
23							
170 620							
310							
015 600							
03							
89 582							
92							

62

1/11/60 Vol. of fuel in tank and pipes

26.5 in height in storage tank

114.75" of  $\frac{3}{4}$ " pipe containing soln.)

1/11/60 Normalization of U-235 counter to be used as cal relative calibrations of other counters.

	Position of U-235 chamber	U-235 count rate	BF <sub>3</sub> Normalizer count rate	<sup>35</sup> S/BF <sub>3</sub>
10 AM	In center of Reg. I	101110	<del>57676</del> 121106	.8349
		101680	121985	.8335
1 min counts		102580	123633	.8299
		104700	125357	.8352
		101760	123284	.8254
		97780	119391	.819
				ave = .830

In center of

Annulus of Reg. II

2 min counts	more sec less than 2 min	27030	400600	.06747
		28100	414828	.06774
		29170	427435	.0682
	1.5 sec < 2 min	30310	445084	.0681
	1.2 sec < 2 min	29410	432453	.0680
	"	29720	438339	.0678
	"	30370	451428	.0673
				ave = .0678

10  
70 d

64 1/11/60

12:50 PM

Pos. of 4-235

4-235

BF<sub>3</sub>

Count Rate

Count Rate

In Center of

Annulus of

Reg. III

131410

518730

.253

134870

535780

.252

~2 sec < 2 min  
on 255 counts

123960

494350

.251

118960

477935

.249

118280

475100

.249

118710

475105

.250

119130

476954

.250

av .251

In center of Temp. Readings: I - 22.0°C; II - 21.5°; III - 20.8°; III - 22.0°

Annulus of

Reg IV-

10140

464415

.02183

~2 sec < 2 min

~~999~~ 9980

462918

.0211

on 235 counts

9960

462594

.0215

10080

464158

.0217

10020

468780

.0214

473567

10050

477553

.0210

10180

483601

.0212

10480

491539

.0212

10610

498342

.0213

av .02136

Sample 5 & 5A taken 1-12-60 after  
EXM 22

Pos. of U-235 In Center of Reg I [Repeat]	U-235 Count Rate	B.F. Count Rate	
	121420	148800	816
	129490	159178	813
	125210	152259	822
	122570	149136	822
	121500	148662	817
	119940	148460	808
	120460	149161	808
	122300	150733	811
			ave = 816 [of 6]

In center	20090	299911	6692
of Annulus & Reg II [Repeat]	20750	311275	667
	20920	315771	663
	21500	323749	664
	22250	334110	666
	22480	333107	675
	21970	331080	664
	21810	328014	ave = 667

## Expt 23 A

J. T. Ly  
cross  
Fox

Preliminary checkout of Fission  
Counter. Rotator selsyn = 9998 at zero  
Reg I selsyn reads .002 at zero  
Apparent reading at center 525

Part I. Reg I & Normalizer on print-out for  
pos. period; see graphs

Part II Reg II & Reg III  
Print out on for pos. periods

Part III Reg II & IV on print out for  
pos. period  
see graphs

1-13-60

## Expt 23 B

Repeat of pos. periods to determine  
where counter begin to loose in efficiency  
All five counter operated at the  
same time.

Data is plotted on graphs.

1/13/60 ~~EXPT 24~~

Vertical lift position = 7.04"

67

EXPT 24

Rot. Ctr. position	Reg. # pos.	I	N	II	III	IV
0	499	339626	190932	77200	31740	62190
"	"	358557	201557	81690	30010	65240
"	"	354464	200039	81060	29880	64390
40	550	369467	207496	52000	38100	57300
"	"	381180	215442	54040	39110	59200
80	600	389391	219992	41210	44850	43840
"	"	394114	221746	41410	45350	44480
120	650	404978	229371	36100	49220	28330
"	"	406915	230855	36410	49510	28540
140	600	390842	221719	33540	<del>47440</del> 47440	21220
"	"	363620	204801	31370	43970	20000
160	550	375102	212256	32190	45300	15910
"	"	372725	209763	32300	44710	15300
180	500	353192	200008	30480	41930	10890
"	"	340355	192321	29640	40490	10530
200	450	366534	206917	32810	41840	8220
"	"	376367	213201	33890	43740	8610
220	400	377580	214940	36230	41990	6260
"	"	367629	209760	35180	41320	<del>60200</del>
240	350	354824	204409	36300	38960	4530
"	"	353085	203796	36930	38580	4440
"	"	353829	204256	36290	38190	<del>4370</del>
260	300	348562	203986	39840	37350	3380
"	"	353859	207870	41650	39720	3420
"	"	360328	210566	41020	38330	<del>3540</del>
280	250	360355	217013	46040	38840	2870
"	"	473983	288995	62000	51880	3670
"	"	473656	287658	61260	51210	



68

Ret. Ctl	Reg I position	I	N	II	III	IV
280	250	475088	288718	61140	51650	3830
320	200	438745	279604	69160	48950	02190
"	"	429183	272576	68020	46360	2070
"	"	426470	271678	67680	46230	2160
360	150	390192	271020	70290	45000	1480
"	"	387953	270558	69460	45670	1510
"	"	385662	269195	69290	44810	1520
280	100	330350	262538	59680	45220	2730
"	"	322069	255131	58420	43890	2640
240	50	254237	252624	48530	46320	4430
"	"	254945	254089	48740	46370	4370
200	0	192154	270823	44420	53640	8930
"	"	199341	280250	46320	55830	9240
160	100	339836	267685	40940	55840	17530
"	"	331562	261376	39750	54910	17130
120	200	427431	273513	42170	58460	30220
"	"	433074	277386	42570	58770	30960
40	300	450948	267677	66920	47550	71960
"	"	447690	266255	67130	48320	72520
0	400	439400	256230	99590	39310	80810
"	"	429980	249291	97780	37300	79710
160	520	459216	263212	39910	55910	20680
"	"	452185	259325	39200	54760	20190
170	530	445574	255156	39080	53200	17180
"	"	442845	254739	39360	53070	17060
180	540	444907	254003	38850	52040	14840
"	"	446302	254714	39280	52570	14740
160	520	439466	252314	38060	52990	17670
"	"	438941	251261	38100	52410	17680

Actual vertical position  
in region at selsyn  
reading of 7.04

Position

$C_N^D$

Reg I	Reg II	Reg III	Reg IV
8.38"	8.75"	8.53	8.65

For center of ctr.

at selsyn vert. pos. zero!

1.34	1.71	1.49	1.61
1.62	1.78	1.62	1.81

new →  
Exp. 56 onward

Distance to Center:

<del>7.01-R</del>	<del>7.24 R</del>	<del>7.46 R</del>	<del>7.34-R</del>
7.33-R	7.17-R	7.33-R	7.14-R

320 .003271

360 .002335

280 .004359

240 .007294

200 .01386

160 .02702

120 .04576

40 .1115

0 .1308

160 .03225

170 .02768

180 .02397

160 .02892

0 .1334

40 .1134

80 .08234

120 .05083

140 .03987

160 .03048

180 .02253

200 .01652

220 .01207

240 .008979

260 .006838

280 .005355

Expt # 24

Rot Pos.	Reg I Pos.	I/ N	II/ N	III/ N	IV/ N	I/ 1776	II CN	III CN
320	200	1.570	2.474	<del>1757</del>	.00784	.8951	.1338	.2500
"	"	1.576 <sup>1576</sup>	2.495 <sup>2496</sup>	1700 <sup>1701</sup>	.00760 <sup>779</sup>			
"	"	1.570	2.490	1702	.00793			
260	150	1.440	2.594	1.660 <sup>1671</sup>	.00546	.8079	.1390	.2450
"	"	1.434 <sup>1435</sup>	2.567 <sup>2578</sup>	1.688	.00538 <sup>556</sup>			
"	"	<del>1.482</del>	2.573	1.664	.00564			
280	100	1.257 <sup>1260</sup>	2.273 <sup>2280</sup>	1.723 <sup>1723</sup>	.0104 <sup>1038</sup>	.7094	.1228	.2530
"	"	1.262	2.290	1.722	.01235			
240	50	1.006	1.922 <sup>1920</sup>	1.834 <sup>1830</sup>	.01753 <sup>1731</sup>	.5658	.1034	.2688
"	"	1.004 <sup>1005</sup>	1.918	1.825	.01720			
200	0	0.710 <sup>711</sup>	1.640 <sup>1647</sup>	1.982 <sup>1987</sup>	.0330 <sup>330</sup>	.14003	.0887	.2920
"	15	.712	1.653	1.992	.0330			
160	100	1.270	1.532 <sup>1526</sup>	2.087 <sup>2084</sup>	.0655 <sup>656</sup>	.7145	.0822	.3060
"	"	1.268 <sup>1269</sup>	1.520	2.100	.0656			
120	200	1.563 <sup>1562</sup>	1.541 <sup>1538</sup>	2.137 <sup>2139</sup>	.1105 <sup>1111</sup>	.8795	.0828	.3125
"	"	1.561	1.535	2.120 <sup>2129</sup>	.1116			
80	300	1.685 <sup>1684</sup>	2.503 <sup>2510</sup>	1.777 <sup>1781</sup>	.2690 <sup>2707</sup>	.9482	.1350	.2645
"	"	1.682	2.520	1.815	.2723			
0	400	1.715 <sup>1720</sup>	3.890 <sup>3907</sup>	1.534 <sup>1516</sup>	.3152 <sup>3176</sup>	.968	.2104	.2225
"	"	1.725	<del>3.895</del>	1.497	.3200			
160	520	1.745	1.516	2.123 <sup>2117</sup>	.0784 <sup>783</sup>	.9825	.0815	.3110
"	"	1.745	1.511 <sup>1514</sup>	2.110	.0789			
70	530	1.749 <sup>1748</sup>	1.532 <sup>1539</sup>	2.085 <sup>2098</sup>	.0674 <sup>672</sup>	.9842	.0828	.3080
"	"	1.730	1.545	2.110	.0670			
40	540	1.752	1.530 <sup>1536</sup>	2.050 <sup>2059</sup>	.0584 <sup>582</sup>	.9864	.0827	.3020
"	"	1.752	1.542	2.063	.0579			
160	520	1.742 <sup>1744</sup>	1.508 <sup>1512</sup>	2.100 <sup>2093</sup>	.0700 <sup>702</sup>	.9819	.0814	.3075
"	"	1.742	1.514	2.088	.0704			

Pat No.	Reg I No.	I/N	Expt II/N	#24 III/N	IV/ N	I/ 1776	C <sup>II</sup> N	C <sup>III</sup> N
0	499	1778	404	<del>1664</del> ?	3255	1	.2180	
"	"	1778 <sup>1776</sup>	4055	1489 <sup>1492</sup>	3240 <sup>3238</sup>			.2190
"	"	1773	<del>4055</del>	1495 <sup>1492</sup>	3220	.9994	.1350	.2680
40	550	1780 <sup>1775</sup>	2505	1836 <sup>1826</sup>	2760 <sup>2754</sup>			
"	"	1769	2588	1816 <sup>1826</sup>	2747			
80	600	1770 <sup>1774</sup>	1875	<del>2080</del>	1993 <sup>1999</sup>	.9988	.1006	.300
"	"	1777	1868	2045 <sup>2042</sup>	2005			
120	650	1766	1575 <sup>1576</sup>	2144 <sup>2146</sup>	1235 <sup>1234</sup>	.9938	.0848	.315
"	"	1764 <sup>1765</sup>	1577	2145	1232			
140	600	1763 <sup>1768</sup>	1513 <sup>1523</sup>	2040 <sup>2143</sup>	0958 <sup>948</sup>	.9954	.082	.3144
"	"	1774	1532	2045	0977			
160	550	1767 <sup>1772</sup>	1514 <sup>1548</sup>	2135 <sup>2132</sup>	0750 <sup>740</sup>	.9977	.0822	.314
"	"	1776	1540	2140	0730			
180	500	1765 <sup>1766</sup>	1524 <sup>1533</sup>	2095 <sup>2000</sup>	0543 <sup>547</sup>	.9943	.0825	.3085
"	"	1768	1542	2105	0548			
200	450	1772 <sup>1768</sup>	1585 <sup>1587</sup>	2020 <sup>2036</sup>	0397 <sup>401</sup>	.9955	.0854	.299
"	"	1765	1588	2052	0404			
220	400	1756 <sup>1755</sup>	1687 <sup>1694</sup>	1952 <sup>1960</sup>	029/293	.9881	.0908	.288
"	"	1753	1678	1968	0295			
240	350	1735	1775	1905	0221	.9757	.0961	.2775
"	"	1732 <sup>1733</sup>	1812 <sup>1785</sup>	1890 <sup>1880</sup>	0218 <sup>218</sup>			
"	"	1732	1778	1870	0214			
260	300	1725	1953	1830	0165	.9639	.1055	.268
"	"	1702 <sup>1712</sup>	2004 <sup>1960</sup>	1910 <sup>1909</sup>	0165 <sup>166</sup>			
"	"	1710	1948	1822	0168			
280	250	1660	2122	1790	0132	.9279	.1145	.263
"	"	<del>1647</del>	2145 <sup>2130</sup>	1795	0127 <sup>130</sup>			
"	"	1646 <sup>1648</sup>	2131	1780 <sup>1789</sup>	—			
"	"	1646	2117	1780	0132			

Temp #11 - 21.2°; 12 - 22.5°C; 14 - 22.7°; 15 - 21.2°

Relative flux at positions where U-235 normalizing counter was placed

$$\frac{\text{II}}{\text{I}} = \frac{.0672}{.823} = .08165$$

$$\frac{\text{III}}{\text{I}} = \frac{.251}{.823} = .3049$$

$$\frac{\text{IV}}{\text{I}} = \frac{.02134}{.823} = .02595$$

To normalize regions F, II, III, + IV to each other

$X^{\text{II}} C_N^{\text{II}} = .08165$ , where  $C_N^{\text{II}}$  is count rate in region II normalized to BF<sub>3</sub>. "X" is found by substituting  $C_N^{\text{II}}$  at the position of the U-235 normalizer

then

$$X^{\text{II}} = \frac{.08165}{C_N^{\text{II}}} = .5385, \quad C_N^{\text{II}} = .1517$$

$$X^{\text{III}} = \frac{.3049}{C_N^{\text{III}}} = 1.468, \quad C_N^{\text{III}} = .2096$$

$$X^{\text{IV}} = \frac{.02595}{C_N^{\text{IV}}} = .4199, \quad C_N^{\text{IV}} = .0618$$

Final values slightly different

Region I is normalized to 1 at center  
Div. normalized count rate by 1.776

701-14-LED

Expt 26A

~~Sub~~

Rotary position = 160°

Reg. I position = 521

n2 <sup>30</sup> pm

## Vertical Traverse

Lift Pos

Lift Pos	Reg I	Nov.	Reg II	Reg III	Reg IV	Lift Pos
42"	245011	202491	25040	33870	10680	8.00
"	254687	211782	26040	35210	11000	"
1.00	286934	219590	27130	38110	11290	9.00
"	294149	226178	27910	38500	11660	"
150	311893	224827	28540	39920	11850	10.00
"	305651	221875	27950	38840	11600	"
200	321247	221298	28870	40220	11800	10.50
"	319492	220248	28310	39920	11600	"
250	332506	219672	29150	41090	11740	11.00
"	332707	220616	29310	40870	11850	"
300	349479	224122	30380	42790	12540	11.80
"	359617	229943	31100	43520	12620	"
350	376004	233382	32690	45970	12920	10.75
"	377624	235065	32930	45950	13000	"
400	387531	234161	33420	46410	13160	9.75
"	385597	235188	33650	46090	—	"
"	<del>12819</del>	234137	33310	46820	13450	8.75
450	<del>13708</del>	234045	34220	49090	13530	"
"	397149	235291	34390	47320	13540	7.75
"	400807	237226	34660	47940	13710	"
500	408094	239675	35640	49380	13870	6.75
"	412039	241025	36410	49720	13830	"
550	417268	240062	36230	49740	14010	5.75
"	418460	242185	36610	49880	13930	"
650	424515	240075	36910	50650	13660	4.75
"	423639	239591	36310	50140	13980	4
700	421368	238814	36550	50540	14000	
"	420648	237450	36180	50260	13800	

Expt 25A

Lift Pos	I/N	II/N	III/N	IV/N
8.00	1.738 <sup>1.739</sup>	1.508	2.090	0.5786
"	1.719	1.474 <sup>1.491</sup>	<del>2.092</del> <sup>2.016</sup> <sub>2.055</sub>	5529 <sup>0.566</sup>
9.00	1.732 <sup>1.730</sup>	1.470 <sup>1.478</sup>	<del>2.064</del> <sup>2.016</sup> <sub>2.058</sub>	5542
"	1.727	1.486	<del>2.064</del> <sup>2.053</sup>	5502 <sup>0.552</sup>
10.00	1.671 <sup>1.670</sup>	1.432 <sup>1.429</sup>	2.035	5358
"	1.608	1.425	1990 <sup>2.012</sup>	5228 <sup>0.530</sup>
10.50	1.632 <sup>1.634</sup>	1.377 <sup>1.380</sup>	1989	5270
"	1.633	1.383	1939 <sup>1.944</sup>	5264 <sup>0.527</sup>
11.00	1.593 <sup>1.599</sup>	1.349 <sup>1.348</sup>	1924	5010 <sup>0.502</sup>
"	1.602	1.340	1912 <sup>1.918</sup>	5023
11.80	1.518 <sup>1.522</sup>	1.293 <sup>1.288</sup>	1847 <sup>1.850</sup>	4669 <sup>0.467</sup>
"	1.525	1.282	1856	4670
12.75	1.622 <sup>1.617</sup>	1.352 <sup>1.362</sup>	1943 <sup>1.951</sup>	4991 <sup>0.503</sup>
"	1.612	1.372	1935	5064
13.75	1.684 <sup>1.680</sup>	1.449 <sup>1.440</sup>	2005 <sup>2.013</sup>	5369 <sup>0.545</sup>
"	1.676	1.432	2021	5527 <sup>0.545</sup>
14.75	1.727 <sup>1.729</sup>	1.489 <sup>1.486</sup>	2047 <sup>2.050</sup>	5594 <sup>0.558</sup>
"	1.730	1.482	2065	5560
15.75	1.754 <sup>1.754</sup>	1.512 <sup>1.512</sup>	2099 <sup>2.084</sup>	5777
"	1.754	1.512	2072 <sup>2.084</sup>	5735 <sup>0.576</sup>
16.75	1.743 <sup>1.747</sup>	1.520 <sup>1.516</sup>	2082 <sup>2.081</sup>	5880
"	1.751	1.512	2079	5883 <sup>0.588</sup>
17.75	1.723	1.495 <sup>1.493</sup>	2054 <sup>2.059</sup>	5841 <sup>0.585</sup>
"	1.721 <sup>1.722</sup>	1.490	2064	5878
18.75	1.668 <sup>1.671</sup>	1.448 <sup>1.453</sup>	1996 <sup>1.987</sup>	5799 <sup>0.579</sup>
"	1.674	1.457	1977	5783
19.75	1.598 <sup>1.600</sup>	1.397 <sup>1.402</sup>	1860 <sup>1.859</sup>	5650 <sup>0.559</sup>
"	1.601	1.406	1819	5521
20.75	1.495 <sup>1.493</sup>	1.338 <sup>1.333</sup>	1793 <sup>1.818</sup>	5427 <sup>0.542</sup>
"	1.490	1.328	1849	5404
17.5	1.369 <sup>1.369</sup>	1.253 <sup>1.251</sup>	1622 <sup>1.639</sup>	5034
"	1.368	1.249	1657	5046 <sup>0.504</sup>
17.5	1.213 <sup>1.214</sup>	1.199 <sup>1.195</sup>	1572 <sup>1.545</sup>	4575 <sup>0.457</sup>
"	1.214	1.190	1515	4551

Lift Pos	EXPI			
	I/N	II/N	III/N	IV/N
42	1210	1237	1678	0528
41	1202 <sup>1206</sup>	1230 <sup>1235</sup>	1662 <sup>1667</sup>	0520 <sup>0524</sup>
1.00	1307 <sup>1304</sup>	1235 <sup>1234</sup>	1736 <sup>1718</sup>	515 <sup>0514</sup>
41	1300	1234	1702	514
1.50	1388 <sup>1388</sup>	1270 <sup>1265</sup>	1774 <sup>1765</sup>	527 <sup>0526</sup>
41	1387	1241	1752	523
2.00	1452 <sup>1451</sup>	1305 <sup>1295</sup>	1818 <sup>1815</sup>	533 <sup>0530</sup>
41	1450	1286	1812	527
2.50	1515 <sup>1512</sup>	1328 <sup>1327</sup>	1870 <sup>1861</sup>	535 <sup>0534</sup>
41	1508	1328	1853	537
3.00	1560 <sup>1562</sup>	1355 <sup>1353</sup>	1910 <sup>1908</sup>	540 <sup>0539</sup>
41	1563	1352	1892	549
3.50	1612 <sup>1609</sup>	1400 <sup>1400</sup>	1970 <sup>1962</sup>	554 <sup>0554</sup>
41	1605	1401	1955	554
4.00	1655 <sup>1655</sup>	1427 <sup>1429</sup>	1983 <sup>1980</sup>	563
41	1640	1430	1960	569
4.50	—	1422	2000	575
4.50	—	1462 <sup>1462</sup>	2013	578
41	1688 <sup>1689</sup>	1462	2010 <sup>2014</sup>	576 <sup>0577</sup>
41	1690	1460	2020	578
5.00	1703 <sup>1706</sup>	1487 <sup>1498</sup>	2061 <sup>2062</sup>	579 <sup>0577</sup>
41	1709	1510	2063	574
5.50	1739 <sup>1734</sup>	1509 <sup>1510</sup>	2072 <sup>2066</sup>	584 <sup>0580</sup>
41	1729	1512	2060	576
6.00	1768 <sup>1768</sup>	1538 <sup>1527</sup>	2105 <sup>2100</sup>	589 <sup>0587</sup>
41	1768	1514	2094	584
7.00	1765 <sup>1768</sup>	1531 <sup>1527</sup>	2114 <sup>2115</sup>	586
41	1770	1524	2115	586 <sup>0587</sup>



Reg I	Nov	II	III	IV
424615	241440	36400	50500	13970
440548	256298	37700	51680	14170
448961	259055	38090	53500	14360
462135	267549	39760	54920	14720
454579	272056	38970	55360	14580
456251	273526	39000	54430	14300
455703	279394	38440	<del>55570</del> 44720	14720
470716	287799	39800	55810	15150
474714	297454	40130	57250	14900
468520	292602	39390	55970	14700
442904	291691	37720	53900	13620
451336	295975	37950	54920	13840
469688	289639	39160	56270	14460
460974	285917	39210	55350	14480
468738	278049	40320	55760	14930
465317	277895	39790	56170	15360
480680	278331	41440	56980	15570
476684	275465	40850	56880	15320
480356	273859	41420	57490	15830
481865	274792	41550	56950	15760
479091	274806	41770	57220	16160
480681	274532	41510	57070	16150
477704	277171	41460	56940	16190
483929	281081	41910	58010	16440
484284	290173	42020	57940	16830
498135	297422	43350	58820	17200

72

Exp. 25-A

Lift Pos.	Reg I	Nov	II	III	IV
3.75	498146	311574	43530	57960	17610
"	503083	314246	44190	59160	17350
2.75	475712	318071	42560	57050	17270
"	478639	321038	42630	59340	17350
1.75	438841	320585	40180	51990	16140
"	430613	314656	39320	52130	15880
0.75	375994	309873	37180	48720	14180
"	370641	305052	36320	46230	13910

5:05 PM

Thermocouple readings

#	Reading
11	880
12	905
14	939
15	894

$$X^{III} = \frac{3049}{.21} = 1466$$

$$X^{IV} = \frac{.02595}{.058} = .4474$$

$$X^{II} = .5368 \quad 5451$$

$$C^I = 1.76 \# \text{ [for normalizing] reg. I.}$$

zero of lift system:

Reg. II - 1.26"

Reg. III - +.04

Reg. IV + .14

1-15-60

# Expt 25 B Omit

Check on Vertical lift reproducibility & Normalizer

Lift Pos	Dir. of appo.	Stability Reg I	1 MIN. counts				R <sub>V</sub> /N	R <sub>H</sub> /N
			NOR	Reg II	Reg III	Reg IV		
103	↓	104121	77023	9790	13450	3540	1353	1272
"	"	289778	219661	27280	37540	10160	1320	1242
"	"	322180	244087	30160	41920	11450	1320	1235
"	"	344013	265008	32790	45340	12340	1305	1237
"	"	346492	281563	34476	47620	13110	1302	1225
"	"	379291	292810	36130	49460	13720	1295	1233
"	"	<sup>1143</sup> 393299	306855	37480	51480	14370	1282	1222
"	"	396265	308577	37690	51740	14480	1284	1222
"	"	391904	305255	36890	51340	14020	1284	1208
"	"	<sup>1142</sup> 390693	304889	37280	51850	<del>14020</del>	1282	
"	"	391203	304929	37100	51050	14060	1283	
"	"	388703	304089	37150	51780	14060	1277	
"	"	391091	305031	37190	51030	14260	1282	
"	"	392898	308616	37150	51430	14390	1273	
"	"	396221	310651	37900	52120	14320	1278	
"	"	396778	311141	37410	51430	14270	1275	
"	"	388583	313689	38140	52790	14540	1271	
"	"	400392	314696	38210	52620	14690	1272	
"	↑	<del>381347</del> <del>400392</del>	<del>298661</del> <del>314696</del>	36490	49980	13680	1277	
"	"	362532	284465	34700	47630	13060	1274	
"	"	<del>346979</del> <del>364687</del>	272184	<del>33148</del> <del>34711</del>	45410	12420	1274	
"	"	381546	298653	36050	49680	13720	1278	
"	"	395488	311166	37130	51470	14230	1271	
9.00	↑	<sup>RA</sup> 538980	311731	46090	60810	16060	1728	
"	"	550332	318060	47250	63890	16470	1728	

74 DIR POS LIFT		Reg I	NORM	Reg II	Reg III	Reg IV	$\frac{I}{N}$
9.00	↑	558122	323166	47860	65960	16750	1.726
"	"	568750	327983	49060	66920	17080	1.734
9.00	↓ <sup>598</sup>	574836	331432	49120	67990	17080	1.736
"	"	570071	330651	49060	67340	17000	1.725
"	"	570961	330911	48950	67340	17020	1.725
"	"	570284	330456	48990	67190	17110	1.726
"	"	573261	330486	48700	67400	17140	1.734
9.00	↑	578337	333766	49340	68460	17110	1.734
		582641	334986	49700	68480	17150	1.738

End of Expt 25B

Ref. Pos	Reg I Pos	Reg I/N	EXPT 2 Co Reg II/N	Reg III/N	IV/N	C I	C II
0.0	449	1334	314	1103	2117		
"	"	1334	314	1166	2102	9971	2084
40	600	1338	204	1383	1802		
"	"	1338	2063	1389	1801	1000	362
80	550	1339	1445	1588	1301	1.003	0964
"	"	1347	1459	1590	1301		
120	500	1342	1248	1654	8331	1.005	
"	"	1348	1252	1659	8367		0830
140	450	1342	1230	1649	6626		
"	"	1342	1226	1647	6677	1.003	0815
160	400	1340	1235	1616	5249		
"	"	1335	1233	1614	5218	1.000	0820
180	350	1315	1248	1580	4142		
"	"	1321	1255	1580	4133	992	0830
"	"	1322	1247	1577	4133		
2.00	300	1305	1308	1552	3157	973	0865
"	"	1297	1297	1534	3163		
2.20	250	1265	1380	1506	2375	944	0909
"	"	1262	1360	1495	2413		
2.40	200	1195	1470	1425	1739	897	0982
"	"	1205	1487	1447	1828		
2.60	150	1106	1667	1458	1325	829	1069
"	"	1110	1605	1460	1347		
"	"	1110	1612	1450	1339		
2.80	100	975	1763	1398	1036	797	1171
"	"	972	1755	1400	1030		
"	"	971	1775	1398	1003		

$X^I = \frac{0.08165}{123} = .0006638$   
 $X^{III} = \frac{3049}{1000} = 3.049$

$X^{IV} = \frac{0.2595}{422} = .0006149$

- III - 1.668 =
- II - 1.23 =
- IV - 1.422 =

relative flux at normalizing position for II

Rot Pos	Reg I Pos	Reg I / N	Expt 2 <sup>Co</sup> Reg II / N	Reg III / N	Reg IV / N	C I	C II
300	50	796	1915	1375	7754		
D.60	11	794 <sup>793</sup>	1902 <sup>1914</sup>	1374 <sup>1371</sup>	8085 <sup>8085</sup>	594	1271
11	11	796	1924	1365	8404		
340	0	543	2148	1356	5287	406	
11	11	542 <sup>543</sup>	2132 <sup>2147</sup>	1332 <sup>1340</sup>	5288 <sup>521</sup>		1425
80 11	11	543	2160	1332	5113		
360	25	679	2150	1337	4501		
11	11	675 <sup>677</sup>	2113 <sup>2140</sup>	1322 <sup>1336</sup>	4598 <sup>453</sup>	504	1421
120 11	11	677	2156	1347	4604		
320	125	1037	2112	1348	5729		
149 14	11	1037 <sup>1039</sup>	2140	1340	5732	778	
11	11	1043	2156 <sup>2127</sup>	1334 <sup>1341</sup>	5575 <sup>570</sup>		1412
11	11	1039	2160	1343	5799		
270	225	1224	1805	1402	1002		
11	11	1224 <sup>1225</sup>	1830 <sup>1810</sup>	1440 <sup>1418</sup>	10120 <sup>1006</sup>	917	1201
213	11	1227	1795	1410	1002		
230	325	1304	1512 <sup>1506</sup>	1506 <sup>1511</sup>	1680	975	0997
11	11	1303 <sup>1304</sup>	1500	1517	1697 <sup>1687</sup>		
190	425	1324	1305 <sup>1310</sup>	1612	2795 <sup>281</sup>	994	0870
11	11	1331 <sup>1328</sup>	1314	1607 <sup>1610</sup>	2839		
180	500	1335 <sup>1338</sup>	1310 <sup>1291</sup>	1698 <sup>1684</sup>	3565 <sup>3551</sup>	<del>1000</del>	0857
11	11	1341	1272	1670	3472		
170	525	1340	1242 <sup>1249</sup>	1685 <sup>1692</sup>	4044 <sup>3998</sup>	1000	0829
11	11	1335 <sup>1338</sup>	1255	1700	8439 <sup>3924</sup>		
160	550	1336 <sup>1339</sup>	1230 <sup>1236</sup>	1700 <sup>1709</sup>	4524 <sup>4447</sup>	1000	0820
11	11	1342	1243	1718	4425		
290	625	1342 <sup>1342</sup>	1297 <sup>1299</sup>	1755 <sup>1764</sup>	9984 <sup>9998</sup>	1003	0862
11	11	1341	1300	1773	9983		
50	648	1335 <sup>1336</sup>	1807 <sup>1809</sup>	1579 <sup>1581</sup>	1651 <sup>1651</sup>	9985	1200
11	11	1337	1810	1582	1652		
0 1	525	1333	3045	1220	2056 <sup>2058</sup>		
11	11	1332 <sup>1332</sup>	3035 <sup>3045</sup>	1225 <sup>1220</sup>	2058 <sup>2058</sup>	9955	
11	11	1327	3038	1215	2048 <sup>205</sup>		2021
11	11	1334	3040	1221	2048 <sup>2076</sup>		
					2067		

1/15/60

Exp. 26

Vertical lift position 1.50"

75

Horizontal Traverse

Rot. Pos.	Reg. I	Nov.	II	III	IV
Reg I 0.00 649	347724	260759	81890	28740	55200
" "	334410	250805	78810	29250	52720
40 600	349428	261077	53230	36100	47050
" "	346413	257812	53210	35810	46910
80 550	348177	260333	37660	41350	33870
" "	354160	262683	38320	41750	34020
120 500	366417	273150	34080	45190	22760
" "	376864	279402	35000	46340	23380
140 450	379849	282819	34780	46620	18740
" "	384735	286828	35160	47240	19150
160 400	375608	280350	34650	45310	14720
" "	369812	276949	34160	44660	14450
180 350	361099	274500	34240	43360	—
" "	357217	270380	33930	42710	11200
" "	351588	265908	33140	41920	10990
200 300	347349	266010	34800	41280	8400
" "	351898	271288	35170	41610	8580
220 250	343786	271611	37460	40900	6450
" "	343021	271926	37000	40640	6560
240 200	313997	262804	38620	37440	4570
" "	306868	254630	37860	36860	4650
260 150	277360	250534	40410	36540	3320
" "	277455	250059	40100	36520	3370
" "	277570	250139	40360	36360	3350
280 100	241360	247151	43570	34570	2560
" "	235786	242820	42630	34050	2500
" "	231418	238409	41850	33340	2390

Handwritten notes on the left margin, including vertical alignment markers and numbers such as 0112, 0210, 0310, 0410, 0510, 0610, 0710, 0810, 0910, 1010, 1110, 1210, 1310, 1410, 1510, 1610, 1710, 1810, 1910, 2010, 2110, 2210, 2310, 2410, 2510, 2610, 2710, 2810, 2910, 3010, 3110, 3210, 3310, 3410, 3510, 3610, 3710, 3810, 3910, 4010, 4110, 4210, 4310, 4410, 4510, 4610, 4710, 4810, 4910, 5010, 5110, 5210, 5310, 5410, 5510, 5610, 5710, 5810, 5910, 6010, 6110, 6210, 6310, 6410, 6510, 6610, 6710, 6810, 6910, 7010, 7110, 7210, 7310, 7410, 7510.

Ret. Pos	Reg I Pos	Reg I	NOV II	II <del>II</del>	III <del>III</del>	IV
300	50	185758	233426	44700	32100	1810
"	"	183517	231314	44010	31800	1870
"	"	185985	235577	45290	32150	1980
340	0.0	134633	247792	53240	33610	1310
"	"	139560	257337	54910	34270	1340
"	"	148593	273842	59150	<del>740</del> 36480	1400
360	25	189844	279852	60170	37390	1260
"	"	188222	278960	58930	36870	1260
"	"	188253	277989	59980	37460	1280
320	125	284183	274034	59850	36950	1570
"	"	284152	273922	58650	36920	1570
"	"	286565	274399	58200	36610	1530
"	"	286795	275860	57980	37060	1600
270	225	360189	294328	53140	41230	2950
"	"	361732	295534	54790	42530	2990
"	"	389372	317261	56960	44770	3180
230	325	409796	314174	47500	47300	5280
"	"	404031	310025	46510	47060	5280
190	425	414958	313355	40920	50500	8760
"	"	424724	319126	41950	51310	9060
180	500	420890	315006	41280	53490	11230
"	"	437982	326617	41540	54580	11340
170	525	441515	329565	40900	55580	13330
"	"	441226	330261	41420	56180	12960
160	550	442536	331139	40940	56290	14980
"	"	442301	329689	40950	56610	14590



Rot Pos	C <sup>III</sup> <sub>N</sub>	C <sup>IV</sup> <sub>N</sub>	Rot. Pos	C <sup>III</sup> <sub>N</sub>	C <sup>IV</sup> <sub>N</sub>
300	.2504	.00501	0	.2075	.1297
310			40	.253	.1107 <del>.0743</del>
320	.245	.0032	80	.290	.080
330			120	.303	.051
340	.244	.0028	140	.301	.041
350			160	.295	.0322
360	.245	.0035	180	.289	.0254
370			200	.282	.0194
380	.259	.0062	220	.274	.01473
390	.274	.01037	240	.263 <del>.224</del>	.0110
400	.294	.01728	260	.266	.0082
410	.308	.02138	280		
420	.309	.0245	300	.256	.0063
430	.312	.0275	320		
440	.322	.0414	340		
450	.289	.0115	360		
460	.223	.126			
470					
480					
490					
500					
510					
520					
530					
540					
550					
560					
570					
580					
590					
600					

		I	N	II	III	IV
100	625	427191	318098	41240	55870	31760
<del>120</del>	"	415335	309894	40280	54920	30940
50	648	377624	282424	51040	44600	46640
21	"	369487	276492	50090	43730	45700
0.0 ↑	525	337604	253165	77100	30910	52070
"	"	327926	246243	74690	30150	50660
0.0 ↓	525	309533	232286	70500	28200	47580
"	"	304676	228593	69840	28550	47460
"	"	303205	227177	69040	27750	46960

<sup>35</sup>  
3 pm

Temp by thermocouples

Couple #	Reading (mV)
11	864
12	912
	99
14	906
15	852

Handwritten notes on the left margin, including vertical lines and some illegible characters.

78

1-19-60

Expt 27

Omit

Horizontal Travel: Vert. pos. 11.82"

FE

Rot. Pos.	Reg I Pos	Reg I	Normal.	Reg II	Reg III	Reg IV
163	525	311150	202020	—	—	—
0	648	311210	205048	44610	30,210	45320
"	"	319345	210607	48300	32110	46090
40	600	330944	218412	46890	34020	45580
"	"	321047	211737	45530	31450	44270
80	550	305863	201324	36900	32770	32980
"	"	301468	198655	36600	32910	32640
"	"	302593	197517	36990	33580	32900
"	"	303301	198554	36800	32810	32380
<i>Counter in Reg. II re-adjusted</i>						
80	550	312413	205109	37650	<del>32650</del> 33400	33400
"	"	311472	206152	37980	27090	—
"	"	313077	208078	38650	27170	33880
"	"	314198	207882	38320	27250	33660
40	600	318198	211702	45100	24320	43220
"	"	326220	216546	45620	24820	44480
0.0	648	311932	207701	46680	23320	46280
"	"	299734	200850	44940	22080	44850
120	500	309813	204566	31090	30370	—
"	"	308034	203615	31010	30710	22600
"	"	307509	202702	30630	30380	22320
140	450	307156	201954	29360	31640	18600
"	"	305035	201719	29170	31350	18570
160	400	305329	202300	27000	32480	14270
"	"	306251	203488	27660	32660	13970
180	350	303048	202153	26390	32740	10630
"	"	301520	200435	26180	32700	10520
200	300	296384	201018	25890	33020	7710
"	"	301611	204190	26070	32780	7820

Rot Pos

Reg I Pos

Reg I

NOV.

Reg II

Reg III

79  
Reg IV

200	300	303414	205946	25580	33430	7950
220	250	294365	204771	26160	32970	5780
"	"	291758	203714	26170	32530	5770
240	200	276778	201737	27030	31930	4260
"	"	287478	210526	27940	32730	4260
260	150	274798	216624	30910	33160	3080
"	"	272847	216014	30390	32500	3010
280	100	236211	212237	33500	31290	2260
"	"	233393	209870	33260	31280	2310
300	50	197811	217835	40930	30580	1740
"	"	199887	220825	41350	31110	1840
"	"	195474	215615	39300	30530	1690
360	0	142520	222574	71380	28090	800
"	"	145580	230060	73820	29520	870
"	"	144584	229266	73360	29310	770
320	50	204365	224170	90570	29550	1160
"	"	188678	207581	92830	29160	1120
"	"	196583	215760	54800	28600	1100
270	100	244491	218924	37380	31743	1930
"	"	247570	221889	38070	31570	2030
"	"	246788	221199	37940	31100	1990
230	150	273115	216319	29300	33700	3890
"	"	277333	219141	29110	33500	3890
"	"	278191	219696	29250	33630	3860
190	200	304009	223028	28080	35710	7940
"	"	297316	218547	27230	35060	7920
"	"	280191	204686	25600	33000	7280
150	300	14878	7393			

Rel. Pos.	Reg I Pos.	I	N	II	III	IV
150	300	268460	183734	24350	29100	11950
"	"	269713	183436	24530	29470	12510
100	400	290303	193593	30580	27330	24440
"	"	295560	196947	31010	30390	25110
50	500	303440	202682	<del>395</del> <sup>40810</sup>	23770	39540
"	"	307528	204749	40760	23960	40050
0.0	600	308607	205769	45810	22320	45890
"	"	308239	205867	45850	22460	45810
150	647	312620	208428	28490	33230	16270
"	"	306774	205433	27850	32300	16160
160	500	311263	206687	27420	32590	14660
"	"	315438	209719	27510	33420	14690
170	525	322167	211966	27700	33420	12980
"	"	326770	217361	28750	34850	13510
180	550	318855	211354	27370	34310	11180
"	"	301786	200552	26090	32470	10700

~~$X^{\text{II}} = \frac{08165}{1.359} = .6008$~~

~~$X^{\text{III}} = \frac{3019}{1607} = .1897$~~

~~$X^{\text{IV}} = \frac{102595}{.0540} = .04398$~~

Rot Pos	Reg I Pos	Reg I N	Reg II N	1897 Reg III N	04398 IV/N	I C <sub>N</sub>	II C <sub>N</sub>
200	300	1473	1256	1623	3861	9722	.07546
220	250	1438	1278	1610	2822	9492	.07696
"	"	1432	1284	1597	2832		
240	200	1372	1340	1583	2112	9036	.08015
"	"	1366	1327	1555	2024		
260	150	1268	1427	1530	1421	8349	.08513
"	"	1263	1407	1503	1394		
280	100	1113	1578	1474	1065	7346	.09499
"	"	1112	1583	1496	1101		
300	50	9081	1879	1404	7988	598	.1120
"	"	9049	1871	1409	8330		
"	"	9069	1832	1416	7838		
300	0.0	640	3207	1262	3593		
"	"	632	3210	1283	3783	4191	.1926
"	"	6308	3199	1278	3358		
320	50	9716	4040	1318	5174		.255(?)
"	"	9089	4447	1404	5394	6013	
"	"	9135	2546	1329	5111		
320	100	1117	1708	1451	8817		
"	"	1116	1715	1422	9148	7366	.1027
"	"	1116	1715	1406	8996		
330	150	1263	1354	1567	1798		
"	"	1266	1328	1528	1775	8349	.08021
"	"	1266	1331	1531	1756		
340	200	1363	1259	1602	356		
"	"	1363	1246	1604	3625	8997	.07510
"	"	1368	1251	1613	3556		
350	300	1462	1326	1584	6505		.0799
"	"	1476	1337	1414	6821	9676	
360	400	1499	1579	1414	1262		.09475
"	"	1501	1575	1543	1275	9901	

Rot. Pos	Reg I Pos	Reg I N	Reg II N	Reg III/N	Reg IV N	I C <sub>N</sub>	II C <sub>N</sub>	III C <sub>N</sub>
0	648	1518	2273	1473	221	1.001	.1373 04335	
11	"	1516 <sup>1517</sup>	2294 <sup>2285</sup>	1525	220	1.001		
40	600	1515 <sup>1516</sup>	2146 <sup>2148</sup>	1557	2087		.1291 04075	
11	"	1514	2150	1485	2091 2090			
80	550	1518 <sup>1525</sup>	1833 <sup>1850</sup>	1628	1638	1.007	.1111 03509	
11	"	1518	1842	1657	1642 164			
11	"	1532	1873	1701	1665			
11	"	1527	1853	1653	1630			
		Reg III adj.						
80	550	1524	1836	1300	1628			
11	"	1512 <sup>1514</sup>	1842 <sup>1842</sup>	1314 1308	1623	.9993	.1107 03494	02481
11	"	1505	1855	1306	1623			
11	"	1512	1843	1311	1619			
40	600	1503	2130	1148	2042		.1274 04022	2186
11	"	1507 <sup>1505</sup>	2107 <sup>2120</sup>	1147 1147	2055 205	9934		
0	648	1502 <sup>1497</sup>	2245 <sup>2241</sup>	1122	2228	9881	.1346 04251	2108
11	"	1492	2238	1100	2232			
120	500	1514	1519	1485 1498		1.000	.0913 02883	2842
11	"	1513 <sup>1515</sup>	1523 1520	1509	1110 1105			
11	"	1517	1512	1499	1101			
140	450	1520 <sup>1517</sup>	1434 1450	1566 1560	9212 921	1.001	.08711 0275	2959
11	"	1513	1467	1554	9206			
160	400	1508 <sup>1506</sup>	1335 1345	1605	7053 695	9941	.0808 0255	3045
11	"	1508	1358	1605 1605	6864			
180	350	1500 <sup>1503</sup>	1307 1307	1621 1626	5257 525	9920	.0785 02479	3085
11	"	1507	1306	1632	5249			
200	300	1474 <sup>1475</sup>	1288 1282	1643 1623	3835 383	9736	.0770 02432	3079
11	"	1477	1277	1605	3829			
			1284					

Rot  
Pos  
200

22

11

1515

Rot 3 Pos	Reg I Pos	Reg I N	Reg II N	Reg III N	Reg IV N	C <sup>I</sup> N	C <sup>II</sup> N	C <sup>III</sup> N
50	600	1497	2013	1174	1950 2229	4881	.01202 0379	2223
320	"	1500 1502	200 1991	1171	1172 1957	4901 9914		
08	600	1499 1498	2227 2227	1085	1088 2229	9887	.134 04225	2064
11	"	1497	2226	1092	2224			
150	647	1500	1360	1594	1582 7807	9881	.0816 02576	3001
11	"	1493 1497	1356	1572	7867			
160	500	1506	1326	1577	1585 7092	9934	.0793 02504	3007
230	"	1504	1312	1593	6995			
170	525	1521	1306	1577	1590 6126	9980	.0790 02495	3016
11	"	1503	1324	1603	6214			
180	550	1508	1294	1624	5288	9947	.0780 02464	3075
11	"	1505	1299	1619	5334			

11  
100

11



Rot Pos.	# EN	C IV N	Rot Pos.	C IV N
200				
220	3042	.01244	0	0967
"			40	0918
240	2980	00914	80	0721
"			80	0713
260	2880	0062	40	0901
"			0	0980
280	2810	00477	120	0485
"			140	0405
300	2675	00356	160	03055
"			180	0231
"			200	0168
360	2470	00158		
"			30	0858
"			0	0978
320	2510	00229	150	0344
"			160	0310
"			170	0271
270	2705	00394	180	02335
"				
230	293	00778		
"				
"				
190	3045	01575		
"				
"				
150	300	02925		
"				
1100	279	0558		
"				

1/19/60 Samples taken for fission product analysis  
Exp. 27

Sample before run # 6-1

" after " # 6-2

Total vol. of palm in system:

1. Height in storage tank:  $25.63'' \pm 200\mu$ .
2.  $1140''$  of  $\frac{3}{4}''$  pipe

Above measure applies after sample 7-1.

82

1/20/60

Exp. 27-B [Repeat of 27 after repair of rotating mechanism]

Vertical position = 11.82


gmt

Preliminary exploration

Rot. pos.	Req. Pos.	I	N	II	III	IV
0	0	137313	223787	50170	20760	50650
11	11	137643	225042	49630	20530	51200
40	60	202960	226697	53030	21660	46230
"	"	212027	235262	53450	22770	48070
60	100	252785	234129	51140	24670	43160
"	"	243314	226147	49380	23530	41040
170	200	323029	238623	32970	32420	10360
"	"	331814	245653	33650	33060	10450
180	300	391820	264031	35040	35610	9210
"	"	376664	254041	34130	34360	9000
190	400	392417	253527	34170	34680	7930
360	500	398281	260729	80440	27630	830
"	"	404978	265968	82500	28480	870
300	550	422949	276317	54900	31420	1350
"	"	428530	280354	53790	31350	1490
0	550	414244	271659	60460	24930	62100
"	"	424626	277689	61940	25460	63610
40	11	442210	290565	65940	28040	60320
"	"	443813	289915	66360	27970	60520
300	"	444913	288867	53360	32430	1700
"	"	448926	292109	51820	33000	1750
360	"	43885	286673	89850	30300	910
"	"	430800	281250	88690	29630	960

Recheck of radius of rotation of counters  
in Reg. II + III.

Reg. II




This drawing gives the outside dimensions of counter in the two positions shown (180° apart) when counter is near upper end of stroke vertically.

The corresponding dimensions when the counter is near lower end of stroke are  $4 \frac{27}{32}$ " and  $4 \frac{29}{32}$ ".

Diameter of the chamber is 0.33"

∴ Average radius of rotation = 2.26"

Reg III



The outside diameter corresponding to the active portion is  $7 \frac{14}{32}$ " at upper end of stroke and  $7 \frac{19}{32}$ " at lower end.

The diameter of the chamber is  $\frac{23}{64}$ "

average radius of rotation of active chamber = 3.55"

1/21/60

1 <sup>30</sup><sub>P.M.</sub>

Counters were removed from regions II & III and checked for straightness, "sameness" of radius of rotation near top and bottom (see previous page) etc.

It was found that the chamber in region II had become misaligned relative to the angle of rotation i.e. it was several degrees off when the other two were at zero.

Furthermore the cable used to simultaneously rotate the three chambers was found to be slack and it did not rotate them a full  $180^\circ$ .

Both difficulties have been corrected

1-21-60

85

EXP # 28

JRF LWG CC

Purpose: Horizontal Traverse

Vertical pos. 11.82" DN Selsyn

8<sup>45</sup>

Inst checked OK

Source in Inst Response OK

9<sup>20</sup>

D<sub>2</sub>O Ht 80.125-56.1 Fuel Ht 18.016

Critical

9<sup>31</sup>

Shut Down to Check Counters

Pot. Pos	Reg I Pos	I	N	II	III	IV
0.0	505	327055	202713	69750	22290	46040
"	"	322715	201660	69900	22240	45690
40	636	321488	202349	64840	22830	44580
103 = 0.5%	"	329067	210024	67440	23140	45920
80	500	355435	226168	46890	29350	38610
"	"	365892	233162	47570	29810	39880
120	550	393047	250597	37600	37060	28310
"	"	381471	243458	34240	36020	27760
140	450	371164	237770	32500	36800	20660
"	"	377155	240756	33420	37160	20420
160	400	386338	249428	33010	39750	15430
"	"	406496	263404	34380	41200	16100
180	350	417631	271693	34590	42070	11740
"	"	418969	271163	35200	42010	11770
200	300	418355	275444	35460	41740	8210
"	"	420197	276212	35870	42250	8150
220	250	411784	276912	37870	42520	<del>8290</del> 5790
"	"	407045	273234	37060	41900	5770
240	200	379738	264878	38940	39190	3950
"	"	370262	259168	37620	37970	3870

Rot 105	Reg P	I	N	II	III	TR
260	150	336282	250750	40850	35550	2610
"	"	333482	249380	39220	35000	2690
"	"	331379	248034	39030	34730	2620
280	100	300179	245186	42480	32950	1890
"	"	296456	242364	42600	32800	1930
"	"	293554	239770	41290	32380	1840
320	50	264223	245343	50940	31060	1140
"	"	278109	258199	53990	32680	1190
"	"	292034	269905	56410	34150	1260
360	0.0	273360	293794	67550	35820	910
"	"	275328	296644	68550	35420	950
"	"	279153	299800	69220	36560	970
320	50	314592	302078	65810	38010	1260
"	"	306527	296740	63810	36980	1240
"	"	306844	294765	63290	37340	1270
280	150	409238	305234	55180	40670	2230
"	"	413596	309069	55620	40770	2290
"	"	418004	313361	56290	41710	2340
240	250	479352	322176	48480	46530	4340
"	"	478246	322424	48250	46030	4460
200	350	504945	324623	42720	49670	9410
"	"	502516	323391	42400	50000	9370
180	450	505092	326779	41660	51760	13470
"	"	513507	333047	42250	53070	13760
170	525	497039	322626	40880	51390	16140
"	"	491356	319070	40560	51120	15870
160	550	484659	315520	40310	50820	18250
"	"	477596	309904	39740	49430	17910

Rot Pos.	IV CN [5194]	Rot Pos.	IV CN
0	.1178		
40	.1140	200	.01505
80	.08871	180	.02144
120	.05895	170	.12592
140	4462	160	.03002
160	3194	120	.05651
180	.02249	80	.08710
200	.01543	40	.1111
220	.01091	0.0	.1145
240	.007739	-2.0	.1066
260	5506	-1.0	.111.0
280	4051	0.0	.1146
300	2400		
320	.001641		
340	2197		
360	3840		
380	.007090		
400			
420			
440			
460			
480			
500			
520			
540			
560			
580			
600			
620			
640			
660			
680			
700			
720			
740			
760			
780			
800			
820			
840			
860			
880			
900			
920			
940			
960			
980			
1000			



Foot Pos	Reg I Pos	I/N	II/N	III/N	IV/N	C <sub>N</sub> <sup>I</sup> [155]	C <sub>N</sub> <sup>II</sup> [16281]	C <sub>N</sub> <sup>III</sup> [19]
0	505	1613	344	1100	2271	1036	2167	2122
"	"	1600	3465	1103	2266			
40	636	1556	3205	1128	2204	1007	2014	2147
"	"	1566	3210	1163	2186	2194		
80	500	1578	2072	1298	1706	1013	1293	2481
"	"	1568	2048	1278	1710	1708		
120	550	1568	1500	1479	1130	1010	9384	2850
"	"	1566	1488	1480	1140	1135		
140	450	1560	1366	1548	8690	1008	8649	2976
"	"	1567	1388	1543	848	859		
160	400	1548	1322	1593	6186	996	8253	3041
"	"	1542	1305	1563	6112	415		
180	350	1538	1273	1548	4321	9948	8071	2981
"	"	1543	1298	1548	4340	433		
200	300	1518	1284	1515	2981	9806	8115	2929
"	"	1521	1298	1528	2950	297		
220	250	1485	1367	1535	2091	960	1361	2954
"	"	1490	1356	1533	2112	210		
240	200	1434	1472	1480	1491	4232	9183	2837
"	"	1428	1452	1465	1493	149		
260	150	1342	1629	1418	1041	106		
"	"	1337	1572	1493	1079	8632	9874	2710
"	"	1330	1573	1400	1056			
280	100	1224	1732	1343	7710			2598
"	"	1223	1758	1353	7962	789	1093	
"	"	1223	1724	1350	7673			
320	50	1077	2078	1266	4645	496		
"	"	1077	2092	1267	4688	462	131	2438
"	"	1082	2090	1265	4668			
360	0	930	2300	1217	3097	600	145	2140
"	"	928	2310	1195	3202	316		
"	"	935	2313	1222	3242			

Ret Pos	Reg I Pos.	Reg I N	Reg II N	Reg III N	Reg IV N	C <sup>I</sup> <sub>N</sub>	C <sup>II</sup> <sub>N</sub> [628]	C <sup>III</sup> <sub>N</sub>
320	50	1042	2180	1258	4170	<del>6728</del>	1354	2421
"	add 10	1033	2150	1240 <sup>1257</sup>	4179 <sup>4230</sup>	<del>6664</del> <sup>6700</sup>		
"	"	1041	2138 <sup>2156</sup>	1247	4308	6716		
280	150	1341	1807	1333	7306	<del>8652</del> <sup>25</sup>	1132	2560
"	"	1338	1800 <sup>1802</sup>	1320 <sup>1329</sup>	7408 <sup>7393</sup>	<del>863</del> <sup>8620</sup>		
"	"	1334	1797	1332	7466	8606		
240	250	1488	1505 <sup>1501</sup>	1445	1347	460 <sup>459</sup>	9428	2766
"	"	1483	1497	1423 <sup>1436</sup>	1383 <sup>1365</sup>	9568		
200	350	1557	1317 <sup>1313</sup>	1530	2898	<del>1005</del> <sup>1003</sup>	8247	2962
"	"	1553	1310	1545 <sup>1538</sup>	2897 <sup>2897</sup>			
180	450	1545	1315 <sup>1295</sup>	1583	4122	9954	8134	3057
"	"	1542 <sup>1545</sup>	1268	1593 <sup>1587</sup>	4132 <sup>4227</sup>			
170	525	1541	1267 <sup>1270</sup>	1593	5003	9935	7977	3076
"	"	1539	1272	1602 <sup>1597</sup>	4973 <sup>499</sup>			
160	550	1536	1277 <sup>1280</sup>	1595	578 <sup>578</sup>	9929	8040	3072
"	"	1541	1282	1595 <sup>1595</sup>	<del>5779</del> <sup>373</sup>			
120	600	1533	1464 <sup>1468</sup>	1542	1088	987	9221	2989
"	"	1528	1472	1563 <sup>1552</sup>	1088 <sup>1088</sup>			
80	636	1523	1980 <sup>1967</sup>	1367	1670	9812	1235	2542
"	"	1518	1952	1372	1685 <sup>1677</sup>			
40	550	1531	3001 <sup>3007</sup>	1121	2135	4877	1886	2157
"	"	1530	3005	1118 <sup>1126</sup>	2156			
00	500	1529	3270	1074	2201	9864	2073	2080
"	"	1524	3280 <sup>330</sup>	1080 <sup>1080</sup>	2222 <sup>2205</sup>			
"	"	1535	3340	1102	2241			
"	"	1526	3270	1074	2238			
20	"	1523	3305	1148	2050 <sup>2053</sup>		2123	2211
"	"	1518	3395 <sup>338</sup>	1148	2056			
10	"	1523	3380 <sup>3375</sup>	1115	2159		2120	2144
"	"	1520	3360	1112	2115 <sup>2137</sup>			
"	"	1527	3320	1086 <sup>1100</sup>	2210		2083	2119
"	"		3315 <sup>3317</sup>	<del>1086</del>	2204 <sup>2207</sup>			

Set Pos.	Reg. I	I	W	II	III	IV
120	600	458910	299515	43840	46490	32580
"	"	467319	305748	45020	47780	33250
80	636	451664	296582	58690	40520	49560
"	"	449324	295974	57810	40610	49880
40	550	442692	289239	86800	32410	61770
"	"	432080	282452	84810	31610	60930
0.0	500	447819	292999	95850	31470	64480
"	"	474602	311493	<del>102070</del> 2070	33640	69230
"	"	495942	323036	107950	35620	72400
"	"	487192	319321	104340	34030	71470
-20	500	483621	317792	106940	36510	65160
"	"	482863	317743	107720	36500	65340
-10	500	481756	316467	107240	35280	68350
"	"	484850	318958	107110	35460	67460
0.0	500	487046	318826	105840	34630	70470
"	"	488451	321317	106500	34810	70830
40	500	523617	343100	101370	44260	63450
"	"	549104	358658	105170	45980	65060
-30	"	503324	330633	106190	40660	63900
"	"	486546	319384	102510	39250	61690
"	"	489194	320706	103570	39180	61910
<p><sup>12</sup> 4 PM Zero checked on Reg I counter. Counter is just touching wall when relay reads 989 i.e. 11 units below zero.</p>						

100  
 90  
 80  
 70  
 60  
 50  
 40  
 30  
 20  
 10  
 0

88

1-25-1960

Exp # 29

SRF LWC CC

Sample # 7-1 taken net 111.0g

Purpose: foil Exposure Bare <sup># 28</sup> on 33 cd covered <sup># 28</sup> on 33  
 Inst checked OK  $\downarrow$  1 1/2" above  $\downarrow$  1 1/2" above

Source in Inst Response OK

11 <sup>58</sup> AM Reached <sup>Desired</sup> Power level and started timing  
 foil Exposure.

12 <sup>48</sup> IC-3 =  $3.4 \times 10^{-8}$  IC-4 =  $3.7 \times 10^{-9}$

12 <sup>58</sup> Dump Soln

Temp #11 - 19.6° full

~~12 - 22.2~~

14 19.4 Rep IV

15 19.4 D.O

Sample # 7-2 taken After Exposure

Vol of Soln:

1. 25.63 in 2.75" S.S. flat  $\approx$  70.0 l

2. 114" of 3/4" pipe 0.83

Total vol. = 70.83 l

1-27-60

89

Exp # 30

JRF LWC CC

9<sup>00</sup> AM Sample # 8-1 taken net 90.02 g

Purpose foil Exposure Barc # 41 Pos 1.5" Below  
Center Cd Covered # 51 1.5" Above  
Center

9<sup>15</sup>

Inst Checked OK

10<sup>24</sup>

source in Inst Response OK

10<sup>25</sup>

start feeding Soln into system

10<sup>43</sup>

soln Ht control Rod

17.801

2.70

Slightly Super Crit

10<sup>48</sup>

17.820

20.86

Pos Per

~~10<sup>53</sup>~~

~~17.811~~

~~1.87~~

~~Slightly Pos~~

10<sup>52</sup>

Reached Desired Power level AND started  
timing Foil Exposure

17.811

1.33

IC-3 =  $2.4 \times 10^{-8}$  IC-4 =  $2.4 \times 10^{-9}$

11<sup>37</sup>

17.815

0.83

IC-3 =  $2.3 \times 10^{-8}$  IC-4 =  $2.4 \times 10^{-9}$

11<sup>52</sup>

Dump Soln

11<sup>53</sup>

start Emergency Exhaust fan RM # 113

11<sup>57</sup> AM

~10 v against tank (storage)

11<sup>58</sup>

start Mixing Soln in slab tank

12<sup>42</sup>

stop Mixing

12<sup>53</sup>

sample # 8-2 taken net 70.06 g

Had difficulty with Antenna rotator motor failure. Got one week before a better motor was installed.

Note: zero of rotating counter is at  
solen reading of -1

star  
ce 2/3/60 Counters reconnected (with CD covers)  
4 <sup>10</sup>/<sub>PM</sub> System made critical to see if counters count

Crit with Reg F counter at 554 (center)  
and Reg Rot. pos. of 129. Solu selyn = 21.04  
So Control blade out, lift position = 6.99 "

~~Notes~~

Rot. Pos	Reg F	Reg I	IV	II	III	TV		
		I.C-4 = .02						Log <sub>10</sub>
129	554	1069	59531	2650	390	20	1 min count	
"	"	1217	61386	2740	440	40	"	
"	"	1162	63232	2890	370	30	"	
"	"	1162	65303	2910	430	30	"	
"	"	2465	138230	5900	890	—	2 min "	
"	"	2665	149195	6360	990	60	"	

O.D of CD. covered counters is ~ 4/10 "

Horizontal Traverse - 235 fusion ctr  
 2 min counts cd - covered. New rotator motor was installed. Vertical lift. pos. 7.04"

Rot Pos	Reg I Pos	Reg I	N	Reg II	Reg III	Reg IV
		IC-4 = .2, .3				
99	500	27901	1643537	66720	12040	1300
"	"	30243	1772454	71330	13140	1370
"	"	33119	1953679	80150	15230	1510
120	539	32425	1881895	77590	12550	980
"	"	32858	1918705	78920	12570	960
140	460	34865	2023287	83750	11640	610
10 <sup>16</sup> AM " "	"	35207	2034356	84380	11860	650
160	400	36507	2030140	83770	9960	380
10 <sup>25</sup> AM " "	"	36852	2044627	84840	<del>98010</del> <sup>10010</sup>	400
180	340	24266	1277699	51370	6380	150
"	"	23609	1251738	50570	5110	120
200	280	23147	1111484	44260	3850	60
10 <sup>42</sup> AM " "	"	26747	1178664	46830	4920	70
"	"	25171	1211888	48600	4120	90
220	240	23179	1043864	40460	2820	40
10 <sup>59</sup> AM " "	"	23295	995988	38470	3160	40
"	"	20984	943983	36280	2540	40
240	200	23571	977347	36370	2580	30
10 <sup>05</sup> AM " "	"	23391	961402	35960	2230	20
"	"	22456	945095	35240	2220	30
260	160	31446	1201635	43720	2790	30
"	"	31974	1238642	44790	2460	30
"	"	32663	1245386	45500	2490	20
280	120	30527	1102227	38990	2300	20



	Rot Pass	Reg I Pass	Reg I	N	Reg II	Reg III	Reg IV
	280	120	30054	1085844	38390	2870	20
11 <sup>30</sup> AM	"	"	31218	1104491	38900	1800	20
300	80	31142	1033466	36100	1660	—	
"	"	31692	1055137	36300	1530	10	
"	"	32012	1072397	36680	1670	10	
320	60	33869	1101508	37730	1590	30	
11 <sup>50</sup> AM	"	"	32659	1053893	36290	1480	10
"	"	31099	1013015	34370	1390	10	
340	80	30478	1014888	34560	1420	10	
"	"	28825	973251	32630	1430	10	
"	"	28163	935460	31030	1280	⊖	
280	50	28483	894128	31230	1530	⊖	
"	"	27515	869132	29890	1590	10	
"	"	26538	845355	29370	1400	20	
100	500	21088	1247392	49320	9050	960	
"	"	21674	1302005	51480	9370	940	
140	460	25415	1504064	62660	8750	440	
1 <sup>00</sup> PM	"	"	23923	1414866	58800	8250	450
"	"	23715	1391978	57750	8070	430	
180	340	27034	1428039	58000	5900	170	
"	"	27891	1473803	59040	6130	160	
"	"	29099	1516985	61420	6350	210	
220	240	33106	1470564	56800	4460	60	
"	"	33714	1491935	58030	4370	80	
"	"	33787	1509451	58020	4320	80	
260	160	30178	1157510	41770	3120	40	
"	"	29837	1091833	38280	2100	20	
1 <sup>40</sup> PM	"	"	26732	1036318	37570	2080	30

Rot. Pos	Reg I pos	Reg I	IV	II	III	IV
300	80	29317	968191	33040	3060	10
"	"	30167	1005735	34570	1560	10
"	"	30828	1032889	35430	1630	20
340	90	30249	1032950	34860	1690	10
"	"	30568	1035844	35480	1430	20
"	"	30497	1039953	34970	1480	10
280	60	32552	1034486	34520	1810	30
"	"	32119	1021772	35880	1770	20
"	"	31856	1008453	35440	1800	20
170	500	16531	971739	<del>39790</del> 39790	4160	110
<sup>50</sup> <sub>22</sub> 17	"	16834	985505	40070	4300	100
"	"	17619	1022241	41450	4470	150

Reg I counter reads zero when cd. covered counter is against wall of Reg I

Expt 31

		Reg I N	Reg II N	Reg III N	Reg IV N
199	500	01697	0406	00733	0007920
259	"	01706170	04025	00742	0007730 <sup>78</sup>
"	"	01695	0410	780	0007730
1120	539	01724	04125	667 <sup>661</sup>	0005210 <sup>810</sup>
139	"	01712172	4115 <sup>4120</sup>	655	0005010
140	460	01723	414 <sup>415</sup>	577 <sup>581</sup>	0003020 <sup>311</sup>
"	"	01732	410	584	0003200
160	400	01796	4125	490 <sup>490</sup>	0001872 <sup>192</sup>
"	"	01802	415	489	0001954
180	340	01898	402	00499 <sup>453</sup>	0001170 <sup>1001065</sup>
"	"	01880	404	408	0000960
200	280	02085	398	347 <sup>382</sup>	0000540
"	"	02270	397 <sup>399</sup>	4175	0000394
"	"	02080	401	400	0000743
220	240	02220	387	270 <sup>285</sup>	0000383
"	"	02340	386 <sup>386</sup>	317	0000402
"	"	02220	384	269	0000424
240	200	02415	374	265	0000308
"	"	02430	374 <sup>374</sup>	232 <sup>244</sup>	0000208
"	"	02375	373	235	0000318
260	160	02615	364	232	0000250
"	"	02580	362 <sup>367</sup>	001988 <sup>2103</sup>	0000242
"	"	02620	3575	200	0000160
280	120	02780	354 <sup>353</sup>	209 <sup>212</sup>	0000183
"	"	02768	354	264	0000184
"	"	02828	3523	163	0000181
300	80	03012	349 <sup>345</sup>	1605	
"	"	0301	344	145 <sup>1537</sup>	0000948
"	"	02993	342	1557	0000934
320	60	0307	3425	1443 <sup>1424</sup>	00002700
"	"	0310	344 <sup>3433</sup>	1405	0000948
340	80	0300	340 <sup>338</sup>	1396 <sup>1434</sup>	0000987
"	"	0296	333	1470	0000103

Reg III correction for  
instrument adjustment = 1.221

Reg III Correction =

EXPT 31

pt Pos	Reg I Pos.	R I N	R II N	R III N	R IV N
340	80	0301	.0332	.001370	0
280	50	0319	03495	001712	0
"	"	0317 <sup>317</sup>	0344 <sup>3470</sup>	001830	00001267
"	"	0314	03475	001655	00001420
1002	500	01690 <sup>1679</sup>	03955 <sup>3955.00</sup>	7240	0007700
"	"	01667	03960	007210	0007230
40	460	01690 <sup>1679</sup>	04165	5820	002925
"	"	01692 <sup>1679</sup>	04155 <sup>155</sup>	5830	0003180
"	"	01705	04150	5800	0003090
80	340	01894 <sup>1901</sup>	04060	4130	0001190
"	"	01892 <sup>1901</sup>	04005 <sup>4055</sup>	4160	0001085
"	"	01917	04050	4188	0001384
220	240	02250	03860	3030	0000408
"	"	02240 <sup>2249</sup>	03890 <sup>3895</sup>	2930	0000536
"	"	02236 <sup>2249</sup>	03845	2860	0000530
460	160	02610	03610	2695	0000346
"	"	02400 <sup>2517</sup>	03570 <sup>3570</sup>	1940	0000187
"	"	02580 <sup>2580</sup>	03630	2010	0000290
300	80	03030	03415	3130	00001831
"	"	0300 <sup>300</sup>	03440 <sup>3428</sup>	1432	0000994
"	"	02970	03430	1580	0000194
340	90	02930	03372	1640	0000967
"	"	02950 <sup>2958</sup>	03420	1380	0000193
"	"	02933	03363	1423	000096.2
280	50	03145	03530	1750	0000290
"	"	03140 <sup>3147</sup>	03512 <sup>3519</sup>	1733	0001196
"	"	03157	03515	1785	0001198
170	500	01700	04100 <sup>4135</sup>	4280	00001133
"	"	01708 <sup>1710</sup>	04070	4365	00001015
"	"	01723			

96-5-60

Expt. 32 A

Gully  
run  
for

gmit

### Vertical Travers

Rot. Position 160; Reg I pos. 505

All ctr. cd - covered

IC-4 ~ .2

Vert. Pos.	Reg I	Nor. <sup>2 min</sup> ↑	Reg II	Reg III	Reg IV
11:30 .42	14835	1,272,500	34690	5790	230
" "	15467	1,334,890	35300	4040	280
" "	32343	2,781,749	75,760	8750	600
" "	336,681	3,077,440	85500	9770	720
1.00	35727	2867985	86000	8540	470
" "	34866	2800950	83470	8130	450
2.00	32751	2389460	78540	8000	450
12:20 " "	32164	2356795	78170	7970	380
3.00	29108	1993590	71890	8270	310
12:30 " "	30389	2079213	74270	7540	360
4.00	28224	1829998	68080	7130	330
12:40 " "	28370	1837115	69110	7080	330
12:45 PM 5.00	29910	1857958	71930	7470	320
12:55 PM " "	29536	1851711	73040	7300	340
6.00	33010	1997297	79710	8110	340
1:10 PM " "	32992	1996185	80090	8110	300
7.04	35548	2123956	86370	9260	390
1:22 PM " "	36473	2173114	88850	10900	360
8.00	35053	2096930	84300	8560	340
" "	35995	2162762	87470	8920	340
9.00	38436	2321702	91950	9470	330
1:40 " "	36772	2224170	88540	9100	340
10.00	40845	2507280	97160	10600	430
" "	43068	2676900	103,640	10500	390
11.00	42257	2653400	98720	9880	370
" "	41687	2649200	96800	10340	370

Expt #32A Ccl - covered V

Vert. L.	Reg I N	Reg II N	Reg III N	Reg IV N	
9	Pos.				
42	1166	2725	<del>465</del>	181	
"	1158	2645 <sup>27</sup>	303	210	210
"	1163 <sup>11</sup>	2725	3145 <sup>310</sup>	216	
"	1192	2778	3175	234	
7	1.00	1246 <sup>1246</sup>	3000 <sup>299</sup>	2980 <sup>291</sup>	164 <sup>163</sup>
"	1245	2980	2904	161	
6	2.00	1370 <sup>1367</sup>	3280 <sup>320</sup>	3360 <sup>337</sup>	188 <sup>175</sup>
"	1364	3315	3380	161	
4	3.00	1460 <sup>1461</sup>	3610 <sup>359</sup>	4150 <sup>390</sup>	156 <sup>165</sup>
"	1461	3575	3630	1733	
	4.00	1544 <sup>1544</sup>	3723 <sup>371</sup>	390 <sup>386</sup>	1804 <sup>180</sup>
"	1544	376	3855	1795	
	5.00	1610 <sup>1605</sup>	3879 <sup>391</sup>	404 <sup>400</sup>	1724
"	1595	3945	394	1844 <sup>178</sup>	
	6.00	1653 <sup>1653</sup>	399 <sup>405</sup>	406 <sup>406</sup>	1703 <sup>160</sup>
10 pm	"	1652	411	406	1504
	7.04	1672 <sup>1675</sup>	4065 <sup>407</sup>	436 <sup>418</sup>	184 <sup>175</sup>
"	1678	4090	402	166	
	8.00	1670 <sup>1678</sup>	4020 <sup>403</sup>	4085 <sup>410</sup>	162 <sup>160</sup>
10 pm	"	1665	4050	4125	157

Gilley  
 rohn

Expt 32 - Cd-covered Vertic

Vert Poz	Reg I N	Reg II N	Reg III N	Reg IV N
8.50	1650 <sup>1650</sup>	398 <sup>397</sup>	434 <sup>445</sup>	165 <sup>153</sup>
	1651	396	451 <sup>0</sup>	149
7.50	1608	404 <sup>403</sup>	470 <sup>463</sup>	158 <sup>157</sup>
	1648 <sup>1458</sup>	401	456	155
6.50	1675	406	457	203 <sup>285</sup>
	1655 <sup>1665</sup>	411 <sup>409</sup>	445 <sup>451</sup>	169
4.50	1584	385 <sup>387</sup>	415 <sup>427</sup>	177 <sup>190</sup>
	1570 <sup>1577</sup>	388	438	201
2.50	1438 <sup>1435</sup>	349 <sup>347</sup>	382 <sup>377</sup>	220 <sup>195</sup>
	1438	346 <sup>5</sup>	372	179
1.50	1305 <sup>1303</sup>	317 <sup>317</sup>	346 <sup>343</sup>	226 <sup>211</sup>
	1300	316	340	198





*gmt*

Expt 32B

an attempt to determine cause of vertical traverse of Expt 32A not being symmetrical about center vertically. Rot and Reg I counter same as above: 1601 & 515. Added extra Cd blade in region four.

Crit with fuel at 20.90"

Lift. Pos	Reg I	Nor.	Reg II	Reg III	Reg IV
11.86	40185	2580300	93420	10390	340
"	44509	2895030	102,210	10260	340
"	47729	3119400	112,290	11670	530
"	48625	3195100	112,570	11330	390

Crit with fuel at 21.85"

10.50	40323	250 1267	95860	9990	350
"	40405	248 8700	95610	9800	380
"	40346	249 4700	96840	9970	330
"	40737	250 4200	97090	10440	360
"	40849	252 7400	96310	9790	360

Removed extra poison in Reg III

Crit at 19.04"

11.86	42232	2885,430	97000	9880	360
"	36847	2527 700	84680	8580	310
"	37106	2531720	85570	8630	320
"	36426	25130,30	84000	8490	330
"	36084	2481966	84040	8390	260

Changed control rod from out to in position

Crit at 19.84"

11.86	35704	232 1750	81590	8280	400
	34644	231 8750	85890	12460	390
	33882	229 7640	79970	7980	280
	36572	2380200	84440	8640	350

\* Had to lower fuel bit to ~ 20.80 because of drift.

ical  
ind  
en  
a

Lift Pos	Reg I N	Reg II N	Reg III N	Reg IV N	crit ht
11.86	1557	1541 362			20.90
"	1537	353			"
"	1530	1521 360			20.80
"	1523	352			"
10.50	1610	3835			21.85
"	1625	3845			"
"	1617	3885			"
"	1625	3875			"
"	1616	3810			
11.86	1463	336			19.04
"	1458	335			"
"	1465	1458 338			
"	1450	3343			
"	1453	3390			
11.86	1537	3515			19.84
"	1495	3705			
"	1474	1504 3480			
"	1537	3550			
"	1491	3530			
"	1489	3480			

ref.

Lift Reg I NOR Reg II Reg III Reg IV  
 pos

11.86 34398 2307100 81420 8390 310  
 11 33425 2,244,200 78080 7800 260

Temp readings:

Reg	ctr No.	1 <sup>42</sup> PM	12 <sup>00</sup>	1 <sup>45</sup>	2 <sup>15</sup>	3 <sup>30</sup>	3 <sup>45</sup>	4 <sup>05</sup>
II	11	910/22.7	—	.897	.866	.848	.814	.804
I	12	905/22.6	.927	.944	.948	.942	.918	.924
IV	14	910/22.7	.927	.900	.910	.910	.921	.921
III	15	910/	.914	.918	.913	.910	.905	.903

100

2/9/60

1<sup>45</sup>  
P.M.

System made crit at Selu ht = 18.99 with  
counters III & IV lowered to bottom and  
rotated toward out side.

2/9/60

2<sup>20</sup>  
3 P.M.

System made crit at Selu ht = 17.80 with  
counters III and IV completely removed and  
with control blade all way in. Region I  
and II were heated with cal rod and  
Fuel and D<sub>2</sub>O were warmed with pumps.  
(prior to critical)

	#	uv
3 <sup>59</sup> ~3 P.M.	II 11	1120
	III 15 <del>14</del>	1173

3<sup>59</sup>  
4 P.M.

gmit

Lift	Lift	Reg I N	Reg II N
7.50	1755	.417	
"	1712	.416	416
8.50	1702	.410	410
"	1693	.410	410
9.50	1625	.400	398
"	1450	.396	
10.50	1602	.382	383
"	1600	.384	
"	1607	.384	
7.00	1702	.414	
"	1693	.415	415
7.50	1703	.413	413
"	1695	.4125	
10.00	1640	.388	
"	1648	.372	380
11.00	—	.409	
"	1623	.366	366
"	1620	.366	
11.88	1745	.349	
"	1586	.350	346
"	1657	.3435	
"	1471	.341	

5/10  
4

2/9/60

Exp. 32-C

101

The purpose of this experiment is to correct the asymmetry of the flux in exp. 32 due to reactor being "more" than full. Crit. ht. = 18.03; Control blade = 3.10

2 min. counts

Pos	Reg I	N	Reg II	Control Blade
50	13570	772600	32240	3.10
"	12903	754590	31410	"
5	12830	754385	30890	2.50
	12130	716631	29390	"
9.5	11892	731543	29280	1.42
3 <sup>47</sup> PM	1155mV 28.9°C		11237 28.4°C	
9.5	12030	728409	28870	1.42
10.50	13552	845899	32290	99.72 (-28)
"	14288	892816	34290	"
"	14725	915825	35180	"
00	16685	980339	40560	6.17
"	17743	1047786	43550	"
4 <sup>05</sup> PM	11251 {28.12}		11105 27.82	Reg III = 10605 26.5°C
7.50	17436	1023364	4224	5.4
"	16386	967188	39890	"
0.00	14485	883152	34260	1.69
"	14124	896364	33340	"
11.00	<del>16449</del>	<del>846952</del>	<del>34620</del>	-28
"	16838	1037270	37990	"
"	18237	1124951	41140	"
In order to get a point with counters at 11.88, D <sub>2</sub> O was drained				
back to relay reading of 74.58 (from ~80)				
11.88	<del>22961</del>	<del>1315484</del>	<del>45960</del>	-28
"	23257	1464513	51140	[D <sub>2</sub> O drained to 74.47]
"	17358	1060492	36410	

102 2/9/60

Lift. Pos.

Reg I

Nor

Reg II

11.88

15588

1060036

36150

Temp

1098

1090

2/10/60

Reg

Sample #

MU

°C

II

11

1.069

26.7

I

12

1.071

II

14

1.041

III

15

1.042

2-10-60 Exp # 32-D

103

Rotating position of II = 161  
 position of I = 515

Cross, Fox, Gilley

Lift. Pos.	Reg I	N	Reg II	
<sup>10:55</sup> 10 AM 11.92	17557	1211001	41130	
"	18037	1218477	42020	Note added 2/11/60 ; Reg I data not good ; see note, p 104
<sup>11:15</sup> 11.01	15996	982989	35870	
<sup>10:15</sup> 11	15217	873170	31740	
"	13093	837288	30130	
"	12916	841404	30400	
"	13347	864091	31230	
<sup>10:33</sup> 10 AM 10.00	12656	799113	29840	
"	13268	761912	59730	
"	13011	814793	89920	
"	14061	889346	32580	
"	14536	921417	34530	
<sup>10:55</sup> 10 9.00	18218	873600	34660	
<sup>11:15</sup> 11 AM	Shut down to check on spread in data. Discovered source drive motor had been left on and was probably throwing in counts.			
	Start again. Crit fuel ht = 18.01 (relay reading)			
<sup>11:33</sup> 11 AM 9.00	18830	1060986	40480	
"	19827	1057501	40860	
"	17380	1035150	40250	
Note:	Discriminator on amplifier I was changed from 12 to 18.			



lift pos	Z	N	II	I/N	II/N
9.00	11531	914315	35260	1261	387
"	11408	898735	34260	1286	382
"	11214	890797	34520	1258	387
"	11034	869302	33570	1269	386
"	10808	860628	33270	1256	386
"	12716	818753	34760		395
<sup>3 1/2</sup> 12 PM	"	10721	831591	32040	3
8.00	14097	1079939	42860	1.695	
"	18045	1135994	45290	1.590	
"	15644	1182846	46420	1.324	
"	15718	1232982	49250	1.275	
<sup>103</sup> 1 PM	9.00	18187	1445970	56150	1.258
"	<del>21512</del> 21912	1475434	57720	1.46	
"					

<sup>30</sup>  
2 PM

Reg I was giving poor statistics, therefore shut down to investigate. Counter #1 was found to have poor ground and was repaired and reassembled

Exp. 32-E  
Vertical Traverse Cd-covered

2/11/60 Reg. I counter put back in reactor and checked for transients due to operation of print-out counters. No transients were found this time.

Note: discriminator on amp. #1 was reset at 12. (see p 103)

Crit Rt relay = 18.01; D<sub>2</sub>O relay = 82.0

Rotating gas relay = 161, center relay = 515

8 <sup>45</sup> AM Temp: # 11 - 1061 mV; # 12 - 1086 mV; # 14 - 1137 mV; # 15 - 1081 mV  
or Reg I } Reg II } Reg III }

	I	N	II			
<del>11.78</del>						
9 <sup>03</sup> 11.78	18382	1215254	42990			
"	19382	1289984	43820			
"	19647	1318831	44730			
11.00	18655	1203655	43320			
9 <sup>12</sup> "	17379	1135204	40260			
10.00	14475	901408	33290			
"	14764	930443	34150			
9.00	15437	953463	36430			
9 <sup>30</sup> "	15921	976335	37340			
8.00	16570	989761	38760			
"	16625	1005993	39500			
7.04	16693	1003416	39470			
"	16898	1012162	39780			
9 <sup>45</sup> 6.00	17655	1052193	42670			
"	17914	1080244	42600			
9 <sup>50</sup> # 11 - 1100 <sup>27.5°C</sup> mV; # 12 - 1110 mV; # 14 - 11365 mV; # 15 - 1097 mV						
5.00	19012	1169045	45310			
"	20208	1220394	47010			
4.00	21821	140167	51670			
"	22750	144444	53510			

106 2/11/60

Exp. 32-E (cont.)

Lift. pos.	I	N	II	I/N	II/N
10 <sup>AM</sup> 3.00	23154	1531949	53900		
"	23848	1564096	55260		
2.00	23380	1660041	54120		
20 "	23043	1647287	53940		
10 Soln. relay had wind to -18.10 and was adjusted to 18.00					
1.00	27398	2144442	62990		
	D <sub>2</sub> O lowered to relay reading = 80.9 { system slightly super at this position with blade in				
1.00	29710	2328659	68630		
10 <sup>30</sup> AM	D <sub>2</sub> O lowered to relay reading = 79.15 ; ~ crit				
1.00	31864	2470299	73130		
1.50	32059	2385802	75010		
"	32129	2385996	78570		
3.50	22638	1493024	54070		
"	22286	1461995	52770		
5.50	20692	1248881	48330		
"	20001	1210993	47190		
10 <sup>52</sup> AM	#11-1101mV; #12-1113mV; #14-1139; #15-1.0965				
7.50	19400	1171275	45900		
"	19171	1152157	44330		
9.50	18923	1178046	43640		
11 <sup>14</sup> AM	19063	1184916	43470		
11.50	19449	1313318	43650		
"	19057	1295471	43520		
"	19042	1287670	43710		

Expt 32 E

Lift Pos	Reg I N	Reg II N		Lift Pos.	Reg I N	Reg II N	
11.78	.0512	.0354	345	5.50	.0655	.387	389
"	.0502 <sup>0150</sup>	.0340	345	"	.0653	390	
11	.0489	.0339		7.50	.0657 <sup>1000</sup>	.392	388
11.00	.0550 <sup>01540</sup>	.0360		"	.0464	.385	
"	.0532 <sup>01540</sup>	.0354	357	9.50	.0405 <sup>1007</sup>	.379	373
10.00	.0605 <sup>01594</sup>	.03695		"	.0410	367	
"	.0580 <sup>01594</sup>	.0367	348	11.50	.0482	.3325	
9.00	.0620 <sup>01624</sup>	.0382	382	"	.0472 <sup>1474</sup>	336	336
"	.0631 <sup>01624</sup>	.03825	382	"	.0478	3395	
8.00	.0675 <sup>01664</sup>	.03915	392				
"	.0653 <sup>01664</sup>	.03930	392				
7.04	.0663 <sup>01664</sup>	.03935					
"	.0670 <sup>01664</sup>	.0393	393				
6.00	.0679 <sup>01664</sup>	.04053	400				
"	.0657 <sup>01664</sup>	.0394					
5.00	.0626 <sup>01664</sup>	.03875					
"	.0654 <sup>01664</sup>	.0385	384				
4.00	.0557 <sup>01564</sup>	.0369	370				
"	.0575 <sup>01564</sup>	.03705					
3.00	.0511 <sup>01518</sup>	.0352	3525				
"	.0525 <sup>01518</sup>	.0353					
2.00	.0407 <sup>01403</sup>	.0324	327				
"	.0398 <sup>01403</sup>	.03275					
1.00	.0277 <sup>01240</sup>	.0294					
"	.0277 <sup>01240</sup>	.0295	295				
"	.0290 <sup>01240</sup>	.0294					
1.50	.0344 <sup>01215</sup>	.0315	322				
"	.0347 <sup>01215</sup>	.03295					
3.50	.0515 <sup>01520</sup>	.0362	362				
"	.0524 <sup>01520</sup>	.0361	362				
5.50							

1/11/60

Exp. 33

107

Crit fuel Solen = 17.83, D<sub>2</sub>O = 73.64

Blade in.

Normalizer counter (used in Exp. 22) connected to #2 pre-amp. Chamber placed in center of "island".

#2	N	2 min counts	I/N
863940	1061664	2 min counts	8 <sup>138</sup> / <del>138</del>
912610	1137212	"	8025
—	1155143		
938470	1164799		8057
933970	1169837		7984
935940	1169228		8005
907500	112670		8057
894800	1112507		8043
			av. 804

1/2/60 Normalizer counter in center of Reg IV  
#2 pre amp used. pre amp insulated from equipment

9 <sup>30</sup> AM

Crit solen reading (soln) = 17.84

D<sub>2</sub>O = 75.66

Control blade all way in. Reg IV cd-covered counter in system near bottom.

data not good

9 <sup>37</sup> AM

Reg IV counts	Norm.	I/N	5 min counts
34490	3478224	9916	
26810	3063154	8752	
32410	2775291	1168	
23520	2719234	865	
27650	2760794	1001	
25690	2886592	8899	
28350	3041916	9319	

108 2/12/60

10<sup>22</sup> AM

IV	N	D/N
28580	3156709	

It was discovered that the clock timer was throwing in counts into #2 amplifier. Amp. output has been changed to printout timer.

no good  
see page 109

	<del>32991</del>		
32991	3371986	978	
30691	3430467	895	
40719	3463528	1176	
30834	3527844	875	
38406	3611019	1065	
32184	3616679	890	

2/12/60

11<sup>00</sup> AM

Amplifier settings:

#	Gain	R.T.	Disc.	HV
I	16	.2 $\mu$ s	12	
II	16	.2 $\mu$ s	10	
III	16	.2 $\mu$ s	13	
IV	4	.2 $\mu$ s	30	1500+ Volts

12<sup>15</sup> PM

NOTE: The amplifier discriminator setting on II was found to not be "correct" for the normalizer chamber being used and was changed to 20

2/12/60

109

$\frac{25}{12 \text{ PM}}$	IV	N	D/N	no good see note below
	29939	3911648	7653	
	29992	3834905	782	
	27722	3820327	726	
	29481	3816820	772	
	29023	3838836	756	
	28250	3850884	734	
	28500	3876899	735	
	28554	3942643	724	
	29959	3996573	750	
	29415	4046517	727	

 $\frac{145}{\text{PM}}$ 

Shut down. Discovered normalizer counter had shifted so that center of counter was only  $1\frac{1}{8}$ " from outside wall instead of in center of region. Counter recentered and ~~panel~~ attached more rigidly.

Re normalization of region IV

$\frac{00}{2 \text{ PM}}$	IV	N	D/N
	64199	3480721	1844
	64305	3464575	1856
	63933	3489103	1832
	64378	3517863	1830
	65308	3541639	1840
	65911	3574443	1840

ave = 1840

110

2/12/60

Reg I normalization

4-235 chamber placed  
in center of region I2<sup>55</sup>  
AM

Reg I	N	I/N	
896679	1247,905	.719	2 min counts
887055	1233710	.719	
899625	1251049	.719	
933938	1297067	.720	
88949	1236894	.719	
		ave .719	

3<sup>20</sup>  
PMNormalization of Reg III 4-235 chamber placed in  
center of Reg III through vent hole.3<sup>50</sup>  
PM

Reg III	N	III/N
276777	1251743	2208
299576	1357646	2205
270622	1226440	2206
280557	1274400	2201
266083	1199477	2218
		ave = 2208

Normalization of Reg II with 4-235 chamber placed  
in center of vent hole.4<sup>10</sup>

Reg II	N	II/N
75608	1243548	.604
79563	1315316	.605
78423	1300646	.603
74512	1240069	.601
75950	1258537	.603

4<sup>20</sup>  
PM

ave .603



$$II/I = \frac{.0603}{.719} = .08386$$

$$III/I = \frac{.2206}{.719} = .3071$$

$$IV/I = \frac{.0184}{.719} = .02559$$

Av. of this and previous determinations on  
pages 43, 44 & 45

112

2/15/60 Samples taken to look for colloidal suspensions in following way:  
one sample<sup>#9-1</sup> taken without stirring;  
~ 1 liter flushed out then  
one sample<sup>#9-2</sup> taken (still without stirring);  
then pump turned on to mix soln.

Soln ht in storage tank measured  
(from inside bottom of tank)

9<sup>30</sup> AM

Soln ht = 24.95 { after samples above were taken  
Vol. in system at this point = 68.59 liters.

Sample #9-3 taken after mixing and after measurement of ht. above. Pipes flushed before sampling.

NOTE: Amount of solution taken from storage due to the ~~two~~ two flushings above was 1195 gm

Note: Selsyn for Wift being used for drive position indicator for reflector radial traverse. Selsyn = 11.76 when disconnected from Wift mechanism

2/15/60

Exp. 34

Radial traverse in upper most tube of bottom reflector.

Counter position relay reads 0.05 when center of active chamber is 0.875" inside reactor (measured from outside of outside wall). see page 114

taken	Reflector Chamber position	Pist C/L	Reflector counts	Normalizer counts	C/N	Counts Normalized to Exp. 24
<u>15</u> 2 PM	22.0	.7	122877	453518	.2709	$\times 1.391$
	"		124269	462398	.2687	.375
	"		125765	467760	.2688	
<u>20</u> 2 PM	24.00	2.7	99810	465801	.2143	.297
	"		97930	461123	.2124	
<u>24</u> 2 PM	26.0	4.7	57998	465587	.1246	.174
	"		58219	464100	.1254	
	29.0	7.7	56045	461471	.1214	.169
	"		55947	461057	.1214	
<u>30</u> 2 PM	32.0	10.7	71123	459761	.1547	.215
	"		71919	465406	.1545	
	35.0	13.7	65233	519167	.1256	.175
	"		67557	535961	.1260	
	39.0	17.7	20592	524329	.03927	.0545
	"		20519	525291	.03906	
<u>40</u> 2 PM	42.0	20.7	7243	1050192	.006891	.00980
	"		7542	1047474	.00720	
	37.0	15.7	97173	1065358	.09121	.127
	"		100273	1103313	.09088	

2/15/60

	Reflector chamber pos.	Dist. $\frac{1}{L}$	Reflector counts	Normalized counts	C/N	
	33.0	11.7	83761	559433	.1497	.208
	"		82812	554299	.1494 <sup>1496</sup>	
2 <sup>55</sup> / <sub>PM</sub>	27.0	5.7	61128	533810	.1145	.159
	"		59565	519101	.1147	
2 <sup>58</sup> / <sub>PM</sub>	23.0	1.7	129212	520009	.2484	.345
	"		129893	524793	.2475 <sup>2480</sup>	
	20.0-1.3		125394	527431	.2377	.331
	"		126255	528610	.2389	
	18.0-3.3		73907	533305	.1386	.193
	"		74202	534564	.1387	
	16.0-5.3		61281	542821	.1129	.159
	"		63034	547655	.1151	
10 <sup>10</sup> / <sub>3PM</sub>	14.0-7.3		73247	557972	.1313	.183
	"		74575	564110	.1322 <sup>1318</sup>	
	11.0-10.3		89642	574020	.1561	.218
	"		91356	581273	.1571 <sup>1569</sup>	
	8.00-13.3		70101	582245	.1204	.167
	"		69693	581177	.1199 <sup>1202</sup>	
3 <sup>20</sup> / <sub>PM</sub>	5.00-16.3		62975	1180729	.0533	.0741
	"		63897	1200716	.0532 <sup>533</sup>	
	1.0-20.3		5020	1229414	.00408	.00565
	"		5049	1250407	.00404 <sup>406</sup>	
	6.0-15.3		103148	1272600	.0811	.113
	"		104282	1288248	.0810 <sup>811</sup>	
	10.0-11.3		95112	641557	.1482	.206
	"		94323	637001	.148 <sup>148</sup>	

3  
37

	Ref. Chamber pos.	Ref. Counts	Normalized counts	C/N	
<sup>38</sup> 3 <sup>PM</sup>	12.0	97160	620903		
	12.0-9.3	97160	620903	.1564	.218
	"	95710	612064	.1563	1564
	17.24.3	74025	612508	.1210	.169
	"	77675	638826	.1220	1215
	21.0-.3	170774	651459	.262	.364
<sup>46</sup> 3 <sup>PM</sup>	"	171078	652700	.2621	
	31.0+9.7	100150	656711	.1525	.212
	"	100954	663263	.1521	

To obtain normalized (relative to exp. 24) count-rate  
in region V see notes in HFIR Folder

$$X^I = \frac{C^I}{C_N} ; \text{ where } C^I \text{ is normalized (to BF}_3\text{) count rate}$$

of "regular" chamber and  $C_N$  is normalizing  
(fusion) chamber count rate at same point.

Then the count rate normalized to Exp. 24 is

$$C_y = \frac{X^I}{1.776} C_{\text{actual}}$$

where  $C_{\text{actual}}$  is experimental  
count rate normalized to BF<sub>3</sub>

$$C_N = 1.391 C_{\text{actual}}$$

2/16/60

8<sup>30</sup> AM

A recheck of selsyn reading corresponding to counter position gave following results (for exp. 34)

Selsyn  $\leftrightarrow$  Tip of counter is "at"  
42.31 end of tube.

The guide tube extends 0.50" beyond the out of the outside wall of reactor

Midpoint of counter at 43.0

Selsyn at  $\frac{42.31}{.09}$

Add .7" to readings Expt 34

With counter in middle position

9<sup>00</sup> AM

Counter changed to middle position in bottom reflector. Selsyn = 41.85" when counter tip is at end of guide tube. (for exp. 35)

Horizontal Traverse in middle position of bottom reflector

2/16/60

Count rate  
Normalized to  
Exp. 24  
(x 1.391)

Counter seleyni	Dist from zero *	Dist. from C/L	Ref counts	Norm. counts	C/R	
					<del>.1365</del>	
22	23.15	1.15	87388	640266	.1365	.183
"	"		87043	650855	.1337	
"	"		85772	650885	.1317	
"	"		83369	634426	.1314	1313
"	"		85459	653429	.1308	
24	25.15	3.15	92152	662044	.139	139 .193
"	"		91543	660654	.1385	
26	27.15	5.15	93909	673250	.139	139 .193
"	"		95718	694804	.138	
28	29.15	7.15	82117	683591	.120	120 .167
"	"		81158	677412	.120	
30	31.15	9.15	61030	665198	.0917	914 .127
"	"		60499	661734	.0914	
33	34.15	12.15	32852	692836	.0474	480 .0668
"	"		35064	721811	.0486	
36	37.15	15.15	31348	1471091	.0213	214 .0298
"	"		31693	1478290	.0214	
39	40.15	18.15	9724	1479021	.00657	662 .00921
"	"		9765	<del>1465484</del> 1469484	.00667	
35	36.15	14.15	40393	1433562	.0282	.0392
"	"		39688	1410805	.0281	282

\* "Zero" is the outside of the outside wall and "distance" refers to center of active chamber

Counter Position	Dist from zero	Ref. Counts	Normalizer counts	C/N	
31	32.15	52600	696725	.0754	.1047
"	" 10.15	52526	698082	.0752 <sup>753</sup>	
27	28.15-6.15	92291	699330	.13197	.1836
"	"	91734	698241	.131 <sup>132</sup>	
23	24.15-2.15	93275	709910	.131	.1822
"	"	94968	724865	.131 <sup>131</sup>	
20	21.15-.85	96779	739782	.131 <sup>131</sup>	.1822
"	"	96166	736197	.131	
18	19.15-2.85	100888	735965	.137	
"	"	102334	738582	.139 <sup>138</sup>	.1920
"	"	102469	742967	.138	
17	18.15-3.85	105937	759175	.139	
"	"	107628	770311	.140 <sup>139</sup>	.193
"	"	108612	782723	.139	
16	17.15	106410	779157	.137	.191
"	" -4.85	104241	765869	.136 <sup>137</sup>	
14	15.15-6.85	87674	765993	.114 <sup>114</sup>	.159
"	"	89289	779265	.1145	
11	12.15-9.85	55102	813842	.06770	.0949
"	"	56435	830032	.06799 <sup>682</sup>	
"	"	57927	848346	.06828	
8	9.15	52965	1637171	.03235	.0453
"	" -12.85	52367	1601004	.0327 <sup>326</sup>	
4	5.15-16.85	13667	1622447	.00843 <sup>843</sup>	.00117
"	"	14070	1670703	.00842	



Counter position	Dist from zero	Ref counts	Norm counts	C/N	
10	11.15 - 10.85	92977	1724759	.0539	.0748
"	"	93313	1735399	.0538 <sup>538</sup>	
13	14.15 - 7.85	87223	875628	.0996 <sup>1001</sup>	.139
"	"	88009	875032	.1004	
15	16.15 - 5.85	112093	875439	.1280 <sup>1281</sup>	.178
"	"	112540	877250	.1282	
19	20.15 - 1.85	120748	881814	.1368 <sup>1371</sup>	.191
"	"	121583	884501	.1374	
21	22.15	116101	891101	.1303 <sup>1304</sup>	.181
"	" .15	116694	894438	.1305	
25	24.15	126488	800740 <sup>2</sup>	<del>.1579</del> (?)	[apparently print-out failed to print out 9 on normalizer.]
"	" 4.15	127790	908476	.1407 <sup>1405</sup>	.195
"	"	128869	917884	.1403	
19	20.15	124575	910615	.1368 <sup>1369</sup>	.190
"	" - 1.85	122688	895942	.1369	
20	21.15 - .85	116968	878848	.1331 <sup>1332</sup>	.185
"	"	119155	893992	.1333	
23	24.15	123532 + 123932	918618	.1344	
"	" 2.15	124301	824699	<del>.12</del> 1342	.187
"	"	126299	942924	.1339	

120


2/16/60

3<sup>30</sup>  
PM

Lower reflector traverse chamber (4-235)  
moved to lowest of the 3 positions.

Discovered bit + selyn had burned out.

A4 Soil # 19 was placed in center  
region along with Reg I chamber in the  
following manner:




Description of soil # 19:

1.11 cm dia.; 5 mil thick

Wt.: 0.2411 gm  
0.2412

Rezero of center chamber



122

2/17/60 zero of traverse chamber in lowest position in bottom reflector.

11<sup>09</sup> AM

Selsyn = 44.99 when tip of chamber coincides with end of guide tube.

Exp. 36. Radial traverse in lowest guide tube in bottom reflector.

Counter position 12<sup>30</sup> PM circ and begin pos. period to obtain power level.


Counter position	Dist. from zero	Reflector counts	Norm. counts	C/N(BF <sub>3</sub> )	Normalized to Exp. 24 X 1.591
22.0 <sup>4</sup>	-2.00	14862	581022	<del>2558</del> 2558	.0358
"		14904	583421	2553 <sup>0.02570</sup>	
"		14797	569073	2600	
24.0	0.0	14570	561221	2596	.0359
"		14217	<del>559677</del> 59677	2540	
"		15308	586324	2611 <sup>0.02581</sup>	
"		15443	598420	2580	
26	2.0	31866	1183559	2692	.0375
"		31008	1155876	2682 <sup>0.02697</sup>	
28	4.0	30705	1137960	2698	.0378
"		31273	1145913	2729 <sup>0.02714</sup>	
30	6.0	28510	1155457	2467	.0343
"		28636	1163514	2461 <sup>2464</sup>	
34.0	10.0	15473	1179165	1312	.0182
"		15422	1185104	1301 <sup>1306</sup>	
36	12.0	9361	1196339	7826	
		9139	1204656	7587	

Counter position	Pist. from zero	Reflector counts	Num. counts	C/N(B <sub>0</sub> )	Normalized to
					.0107
36	12.0	9413	1213345	<sup>7724</sup> <u>7760</u>	
39	15.0	3928	1232353	3188	.00446
"		3998	1244579	<sup>003207</sup> <u>3212</u>	
"		4116	1278052	<u>3221</u>	
35	11.0	12487	1241487	1005	.01398
"		12335	1227303	<u>1005</u>	
27	3.0	34377	1251745	2746	.0382
"		34407	1251252	<u>2750</u>	
32	8.0	25346	1253936	2021	.0280
"		25362	1260313	<u>2012</u>	
23	-1.0	32018	1272676	<sup>2530</sup> <u>02515</u>	.0352
"		32606	1280466	<u>2546</u>	
20	-4.0	32064	1306843	2454 <sup>2439</sup>	.0339
"		32133	1326377	<u>02423</u>	
18	-6.0	28284	1336182	2117 <sup>2128</sup>	.0296
"		28691	1341007	<u>2139</u>	
16	-8.0	22981	1348102	1704 <sup>1492</sup>	.0235
"		22759	1355600	<u>1679</u>	
14	-10.0	13975	1362825	1025 <sup>1035</sup>	.0144
"		14257	1364478	<u>1045</u>	
10	-14.0	4626	1329420	348	.00481
"		4449	1305992	3407 <sup>3459</sup>	
"		4521	129566	<u>3490</u>	
8.28	-15.72	2810	1286075	2185	.00314
"		2939	1280990	2294 <sup>2256</sup>	
"		2925	1277230	<u>2290</u>	

Counter position	Dist from zero	Reflector counts	Normalized counts	C/(WB <sub>0</sub> )	Normalized to Exp. 27
12	-12.0	8247	1334445	.00618	.00758
"		8316	1350618	.00616 <sup>617</sup>	
15	-9.0	17718	1339616	.01323	.0184
"		17692	1340578	.01319 <sup>1321</sup>	
19	-5.0	31237	1342586	.02327	.0324
"		31824	1345338	.02365 <sup>2344</sup>	
21	-3.0	35005	1372210	.02551	.0354
"		35625	1399793	.02545 <sup>2548</sup>	
<sup>28</sup> <sub>3</sub> 25	1.0	36000	1363811	.02639	
"		36476	1359822	.02682 <sup>2655</sup>	.0369
"		35664	<del>1351783</del> 1391783	.02638	

Total counts on counter #1 in center region with foil for total time of exposure = 190509910.  
 Total exposure time was 170.25 min.  
 [for locations and descriptions of counter & foil see page 120]  
 Power level  $\approx$  0.2 on IC-4

Measurements on ~~the~~ bottom reflector traverse  
guide tubes after exp. 36;  
measurements were taken as per diagram



results:

	Top	Middle	Lower	
East side	$5 \frac{5}{16}$ 5.32	$3 \frac{1}{64}$ 3.02	$1 \frac{9}{64}$ 2.96	ave. 2.85
West "	$5 \frac{5}{16}$	$2 \frac{13}{16}$ 2.81	2.75	

Using average values, the center of chambers were

$$\frac{1}{2}h = \frac{8.85}{0.25} = 15.10$$

Upper  
5.32  
.16  
5.48 up from  
bottom plate

hence is 9.55" below center  
9.62

Middle

$$2.91$$

$$\frac{.16}{3.07}$$

3.07 up from  
bottom plate

hence 11.93" below center  
12.03

Lower

$$2.85$$

$$\frac{.18}{4.45}$$

4.45 up from  
bottom plate

hence 14.55" below center  
14.65

2/19/60 Temp. control for experimental room raised  
 4<sup>pm</sup> to 84 to raise ~~some~~ room temp for  
 temp coefficient measurement. P<sub>2</sub>O left in  
 reactor along with water in Reg's I + II over  
 (long) weekend. One 375 watt infrared lamp  
 placed near center of fuel in storage slab  
 approx 12" away

8<sup>30</sup>  
 2/23/60 Temp. measurements

Couple #	Reg	mV	Temp
11	II	1.097	27.8
12	I	1.123	28.1
13	Slab	1.35	33.4
14	IV	1.213	30.3
15	III	1.098	

9<sup>15</sup>

Couple #	Reg	mV	Temp	10 <sup>20</sup> AM
11	II	1.125	fuel not up	1.188
12	I	1.125	28.1	1.147
13	Slab	1.204	30.0	—
14	IV	1.174	29.3	1.145
15	III	1.098	27.5	1.119



128

2/23/60

Exp. 37

Temp coefficient

10 <sup>50</sup> $D_2O$  relay = 75.53, Fuel relay = 18.04

Control blade relay = 0.0 (all way down)

There are two bare  $BF_3$  counters in system,

Reg II + III. Both are sitting on bottom

[above conditions were for period but log N not calibrated <sup>hence</sup> not used]11 <sup>30</sup>  
AM

Temp. couple &amp; m.v. Temp

11 1128

12 1138

13

14 1147  
+6

15 1105

11 <sup>30</sup>  
AM $D_2O$  relay = 75.53, Fuel relay 17.854

control blade relay 0.0 99682 (all way in)

~~BF~~ System CritThere are  $BF_3$  counters in Reg II + III near bottom

[no period here — adjusting log N instruments]

m.v.

12 <sup>30</sup>

11 1134

12 1144

13

14 1180

15 1115

2/23/60

1<sup>20</sup>  
PMSystem made crit. ~~Some conditions~~ $D_2O = 75.53$ , Fuel = 17.88, Blade = 99682

Pos. period

 $D_2O = 75.53$ , Fuel = 18.018, Blade = 99682

IC-3

IC-4

 $T = 96.65$ ;  $P = 6.47 \times 10^{-4}$  $T = 97.4$ ;  $P = 6.43 \times 10^{-4}$ 1<sup>23</sup>  
PM

Temp

comp. #

m.v.

°C

11

1.110

12

1.125

13

14

1.150

15

1.100

1<sup>35</sup>  
PM

Repeat of pos. period: Fuel selwyn = 18.013

IC-3

IC-4

 $T = 98.2$ ;  $P = 6.38 \times 10^{-4}$  $T = 100.3$ ;  $P = 6.28 \times 10^{-4}$ Temp 1<sup>35</sup>  
PM

#

m.v.

11

1.094

12

1.150

14

1.122

15

1.107

2<sup>00</sup>  
PM

IC-3 &amp; IC-4 checked - slightly off

2/23/60

Exp. 37 (cont.)

10-3 & 10-4 recalibrated

Repeat of pos period

$D_2O = *75.8$ , Fuel = 18.020, Blade = 9968.2

$\frac{10-3}{T=102.1, P=6.20 \times 10^{-4}}$

$\frac{10-4}{T=103.0, P=6.16 \times 10^{-4}}$

3<sup>15</sup> Temp

#	mv	oc
11	1.124	
12	1.144	
14	1.171	
15	1.113	

~~repeat~~  
~~short~~

Repeat: Fuel ht 18.02  
 $D_2O *75.91$

$\frac{10-3}{T=101.3, P=6.24}$

$\frac{10-4}{T=101.3, P=6.24}$

3:50 PM

Temp

11	~ .1114
12	~ .1140
14	~ .1174
15	~ .1110

10-3 & 10-4 checked; span essentially correct, slightly off  $10^{-8}$  mark

4<sup>13</sup> PM

Repeat of pos. period after recalibration of 10-3 & 10-4

$D_2O = 75.92$ , Fuel = 18.014, Blade 9968.2

$\frac{10-3}{T=101.3, P=6.24}$   
 $T=103.4, P=6.15$

$\frac{10-4}{T=105.2, P=6.09}$   
\*

20

4 PM Temp

11	1.119
12	1.150
13	
14	1.172
15	1.114

\*  $D_2O$  made  $\approx 1 - 1.5$  high

2/23/60

4 <sup>25</sup> PM Temp. control set at 76 for room 113

2/24/60 Preceding Exp. 37 the  $D_2O$  ~~sensor~~ <sup>selsyn</sup> became inoperative. After repair the zero was found to be different such that it read approx 74.5 instead of 73.5 when full.

After Exp 37 (but next day) selsyn became inoperative again and was repaired. Selsyn was set this time so that selsyn reads 73.5 when full [but vent empty].

2/24/60 @ 9<sup>00</sup> Fuel solenoid too high and some solution got in top reflector water above ~~sol~~ fuel and above  $D_2O$ .

12<sup>45</sup>

check of thermocouples by putting them together in a beaker of water {see Calibration opposite 132

#	mV	(Repeat)	°C	Temp. by Thermometer
11	1.0475	1.0480		is 26.0°C 1.04 mV = 26.0°C by Handbook Curve
12	1.0450	1.0435		
14	1.040	1.0384		
15	1.0325	1.0315		

2/24/60

Exp. 38

~~2/24/60~~ Second Temp. Coefficient measurement10<sup>15</sup> AM IC-3 + IC-4 calibrated

9<sup>15</sup> Fuel at 18.0 D<sub>2</sub>O at 74.9  
 System cut with blade at 99790.  
 (Blade at 99682 when down against limit)

9<sup>15</sup> Temp      11      12      14      15<sup>-</sup>  
                  .930<sup>2</sup>      942<sup>2</sup>      .960<sup>9</sup>      .933<sup>2</sup>  
                  .931<sup>2</sup>      939<sup>2</sup>      .962<sup>2</sup>      .931<sup>2</sup>

9<sup>20</sup>

check on Blade calibration

Cut Pos.	Period Position	$\Delta h$	T	P	$\frac{P}{\Delta h}$
99790	2.60	4.70	190.1; 186.8	3.72; 3.77	$.798 \times 10^{-4} \text{ in}^{-1}$
99790	1.04	3.14	<sup>1379</sup> 1344; 1390	.589; .584	$.187 \times 10^{-4} \text{ in}^{-1}$

4 rezero of blade gave a selsyn reading of  
 24.68 when blade is 28.8" above fuel bottom.

The above results do not fall on previous curve  
 (Exp. 13) and do not appear consistent. Reason uncertain.  
 Using the above blade zero the points (P/ $\Delta h$ ) are to be plotted  
 on previous curve at 4.37 and 3.59" respectively.

# 10N

2/24/60

# Calibration of Thermocouples

Curve

Thermocouple readings in mv with couples together  
in beaker of water

	<u>II</u> 11	<u>I</u> 12	<u>IV</u> 14	<u>III</u> 15	<u>ave.</u> m.v.	Thermoc m.v.
<u>20</u> 1 PM	1.037	1.033	1.050	1.0255	1.034	
<u>1 43</u>	1.0155	1.0135	1.020	1.0078	1.015	25.4 25.8
<u>2 05</u>	1.0045	1.0015	1.0250	1.0240	1.014	25.4 25.5
<u>2 15</u>	1.0015	.9995	1.0238	.9948	1.005	26.1 25.4
<u>2 30</u>	.9950	.9940	1.0210	.9900	1.000	25.0 25.2
<u>3 20</u>	.9870	.9838	1.020	.9760	.992	24.8 25.0

Calibration of Thermocouples

1.037	1.016	1.005
1.033	1.014	1.002
1.050	1.020	1.025
1.026	1.008	1.024
<u>4</u> 4.146 <u>1.036</u>	<u>4</u> 4.058 <u>1.015</u>	<u>4</u> 4.056 <u>1.014</u>

1.0020	.9950	.9870
.9995	.9940	.9838
1.0238	1.0210	1.0200
.9948	.9900	.9760
<u>4</u> 4.0201 <u>1.005</u>	<u>4</u> 4.0000 <u>1.000</u>	<u>4</u> 3.9668 <u>0.9917</u>

Results of calibration:

- # II  $\pm .1^{\circ}\text{C}$  of average
- # I  $+0, -.2^{\circ}\text{C}$  of average
- # III  $\pm .2^{\circ}\text{C}$ , "
- # IV  $+ .2, -0$  of average

Thermocouples were placed close together in beaker of water. Right most column of temp. readings are by thermometer. Left column of temperatures readings are taken from thermocouple curve.

2/25/60

1 <sup>00</sup> PM

A determination of the <sup>position of the</sup> tips of the counters above the fuel bottom corresponding to a selsyn reading (2ift) of 1.00" gave

Reg I	Reg II	Reg III	Reg IV
0.41"	1.00"	0.92"	0.94"

Pos. period with blade to check calibration:

	crit	Period
Fuel	Blade	Blade
<del>18.04</del>	<del>14.22</del>	
18.65	0004	6.54

$T = 180.7$ ;  $P = 3.88 \times 10^{-4}$

$T = 178.5$ ;  $P = 3.93 \times 10^{-4}$

Check of Reproducibility of Control Blade near lower end by recording crit. blade position, then moving blade and returning blade to crit position to see if system is still crit.

	Crit blade	moved to	Comment
	<del>3.32</del>		
3 <sup>45</sup> PM	2.77	limit then back	Crit.
	"	"	"

4 <sup>15</sup> PM Pos. period to check control blade

Fuel	Crit blade	Per. blade
18.67	99737	5.12

Note

4 <sup>25</sup> PM

System screamed by photo multiplier although instrument was on scale. [low level trip]



Zeit seligen = 7.00

Rot. pos	Reg I	N	II	III	IV
0.0 0.0	307542	78681	1197820	1039480	91930
" "	326064	<del>81845</del> <del>818165</del>	1236670	1069870	+ <sup>1</sup> 38010
" "	383009	83688	1267320	1079430	140520
" "	372144	86334	1288120	1096410	110870
" "	347189	82061	1196930	943590	74770
0.0 0.0	1498791	64189	924620	1108950	<del>1893740</del>
	1467354	63276	910260	1092490	—
	1252573	61273	885760	1057230	1515740
	1207881	60905	876270	1035990	1057520

The above counts were a preliminary  
check out of BF<sub>3</sub> chambers

Note: From the end of tube of BF<sub>3</sub> chamber  
to center of active chamber is 1 7/8".

2/26/60 Concerning Inconsistances in Control blade Calibration Checks

3/25/60 The real error in blade calibration is probably due to photo measurement building up differently due to different procedures

A check of control blade movement against selsyn reading shows the selsyn to be "tracking" properly when going up, certainly near bottom of stroke, but not tracking properly going down. Therefore, this probably accounts for the blade calibration checks not checking. Since

Since the motion of the blade was up in exp. 38, the indicated rise of 1.08" is very probably correct. This is further substantiated by the fact that the negative period as indicated by the instruments prior to movement of blade to obtain critical was very small.

Measurements show the lower edge of blade to be 0.5" above bottom of reflector region (10) when against lower limit switch (hence selsyn reading of 99682 corresponds to 0.5" above bottom in exp. 38.)

Exp. 40

12 <sup>40</sup>

Selsyn repaired and set so that Selsyn = 0.01" at lower limit switch.

Fuel	crit. Blade	Peried Blade	T		P	
			103	104		
17.996	0.01	7.50	118.7	118.7	$5.5 \times 10^{-4}$	$5.5 \times 10^{-4}$
17.978	0.01	4.00	292	290	2.54	2.56

2/26/60

1 <sup>25</sup>

Temp. for <sup>crit.</sup> conditions: Fuel = 18.01, D<sub>2</sub>O = 76.27, Blade 0.01 [all wa down]  
 and Bare BF<sub>3</sub> counters in #4 (attached); Rot. pos = 164, Lift = 7.42

11	12	14	15
.928 mv	.946 mv	.965 mv	.929 mv
23.2	23.4	24.1	23.2
av. 23.5			

2 <sup>56</sup>  
PM

Further checks on Blade calibration

	Crit fuel wt.	Crit Blade Position	Period Blade Position	
	17.89	4.50	<del>7.50</del> 6.52	
	17.91	4.50	9.50	← reactivity changed during period was slightly above at 4.50 afterwards
4 <sup>00</sup> PM	17.91	4.50	11.0	

2/29/60

System crit with following conditions:

9<sup>30</sup>

$D_2O = 74.8$  [41" invent],  $Fuel = 17.89$ ", blade = .02  
 and blade relay reads .01 when against lower limit switch.  
 Two BF<sub>3</sub> counters in system, Rog II + III against  
 bottom [disconnected] correspond to rotation pos. of 16.4

Temp readings

II	I	IV	III
11	12	14	15

9<sup>30</sup> IC-3 Calibrated

IC-4 inoperative

9<sup>30</sup>

.882 .891 .886 .881

.882 .891 .879 .877

9<sup>45</sup>

Check of period & reactivity corresponding  
 to raising blade 1.08" from down position (as in  
 exp. 38). Conditions same as immediately above  
 except blade moved from .02 to 1.09

$$T_{103} = 700 \text{ sec}, \quad \rho = 1.13 \times 10^{-4}$$

Blade returned to .02. approx crit, very  
 slight drift up.

10<sup>00</sup>

Temp

.880 .891 .883 .878

10<sup>15</sup>

Adjust to crit, with blade at .02, ~~using~~ by  
 lowering D<sub>2</sub>O slightly. [to 73.4]

Raised blade to 1.09 for period again

$$T_{103} = 800 \text{ sec}, \quad \rho = 1.0 \times 10^{-4}$$

10<sup>20</sup>

lowered blade to .02, just crit. after ~5 min.

10 <sup>35</sup>

To check reproducibility of blade over longer strokes blade raised to ~6" and lowered back to .02 just crit after ~5 min

10 <sup>35</sup>

Temp	11	12	14	15
	.880	.894	.887	.878

Since crit conditions seem inconsistent with results in exp. 38, a determination of the worth of the control blade for 1.09" was made. Now an evaluation of the reactivity corresponding to raising solution from 17.89 to 18.01 is to be made

$D_2O = 74.5$  (+1" up in vent), Fuel = 18.03 blade = .02  
counters in II + III still at 164 <sup>at</sup> ~~near~~ bottom

Ic-3 Calibrated

11 <sup>20</sup>

Temp	11	12	14	15
	849	895	890	879

Results of blade calibration (above 1.09"), for two periods

$T_{105}^{105} = 700$  sec;  $P = 1.13 \times 10^{-4}$ ;  $T_{102}^{242} = 800$ ,  $P = 1.0 \times 10^{-4}$

Reactivity corresponding to raising fuel from 17.89 to 18.01 above =;  $T = 214$  sec,  $P = 3.35 \times 10^{-4}$

11 <sup>15</sup>

To determine effect of moving counters in II + III from rot, pos 164 to 0.0 (with chambers against bottom).

$D_2O = 74.5$ , blade = 0.02, Fuel = 17.92  
crit.

1 <sup>30</sup> PM

	II	I	IV	III
Temp	11	12	14	15
	.880	.898	.886	.874
	.883	.895	.883	.875

1<sup>45</sup>

Recheck of period corresponding to raising blade  
to 1.09 (from crit conditions above)

$$T_{res} = 754 \quad P = 1.05 \times 10^{-4}$$

2<sup>17</sup>

After draining  $\sim 1.5$ " fuel reconnected  
counter as in Expt 40 for recheck on  
crit conditions:

	II	III	
11	12	14	15
868	897	882	870
870	895	882	870
21.7	22.4	22.0	21.7

av 21.8

crit. with following conditions

$$D_2O = 74.38, \text{ Fuel} = 17.90, \text{ blade} = .02$$

The above results are not consistent with  
the crit conditions on page 134 (assuming positive  
temp. coefficient), i.e. system is now too reactive.

To see what effect trapping air under top of  
fuel cover might have, fuel drained  $\sim 2$ " then  
brought back to 17.90, with other conditions  
remaining the same. Actually sel syn fluctuates  
between 17.896 and 17.899 - just crit.

3<sup>00</sup>

Fuel ht. raised, sel syn fluctuates between  
17.916 and 17.925; purpose: to obtain worth of  
small fuel measurement error at this ht.  $T = 1247$ ;  $P = .648 \times 10^{-4}$

3<sup>30</sup>

Drained out all of fuel and brought back up  
Fuel crit ht 17.91,  $D_2O = 74.48$  Blade 0.02

I - 895	II - 891	III - 874	IV - 881
			22.0

4<sup>00</sup> PM Drained fuel & D<sub>2</sub>O. Wedged control blade outward ~ 1/2 in. from wall of D<sub>2</sub>O annulus. Blade was ~ 1/2 in. from wall; now ~ 1.0 from wall.

Another check to look for reason we are not getting consistent results from exp. to exp. consisted of getting crit with following conditions.

4<sup>00</sup> PM D<sub>2</sub>O = 74.5, Fuel 18.035, blade = .02 then lowering D<sub>2</sub>O ~ 2" and then filling back to 74.6. The result was to get a positive period (see below) indicated possibly air trapping under top of D<sub>2</sub>O region.

3/1/60  $D_2O$  selwyn = 73.33 at 9<sup>30</sup>. Reason why selwyn reads less than 74.6, which was left overnight, not known

9<sup>40</sup> System made crit with counters back in reg. II + I to check out counters  
 $D_2O = 73.847$ , Fuel = 18.216 to 18.224,  $blod = .56$

10<sup>00</sup> Counter in reg. II not operating properly  
 Shut down to check  
 →  $D_2O$  raised till selwyn reads 80.095". Also piece of yellow tape placed on monometer tube at level of  $D_2O$

Two samples taken of ~~diluted~~ ~~con~~ reflector water from reg. II + III  
 10-1 & 10-2

3/1/60 Sample 10-1, Reg II  
 3<sup>20</sup> Reg. = 593071  
 PM (bottle = 9)

Sample 10-2 Reg II  
 Log. 593072  
 (bottles 10, 11, 12, 13, 14, 15)



3/2/60

Exp. 42

Cross, Gilley

1<sup>00</sup> PM

Purpose: to see if the change in reactivity due to lowering and raising  $D_2O$  as found previously ~~and~~ can be reproduced and to make checks of an reproducibility of worth of control blade.

There are no counters in reactor.  $D_2O$  has been left up essentially full over night at  $D_2O$  selcyn reading of 73.58 region not quite full, upon adding small "jog" selcyn went to 76.08"

Circ conditions:

{ Top plate is off. blade has been removed and replaced

 $D_2O = 76.098$ , Fuel = 17.89, Blade = .02
1<sup>31</sup> PM

For pos. period, blade raised to 1.09

 $T_{103} = 1050$ ,  $P =$  ;  $T_{104} = 1116$ ,  $P =$ 
1<sup>48</sup> PM

Lowered blade back to .02, just circ after ~7 min

1<sup>46</sup> PM

Temp.	11	12	14	15
	.823 <sub>mo</sub>	.833	.859	.828

2<sup>00</sup>

Raised blade to 4.00". No changes made in fuel or  $D_2O$  although  $D_2O$  now reads 76.15, possibly warming up.

 $T_{103} = 245$ ,  $T_{104} = 241$ 
2<sup>07</sup>

Blade lowered to .02, slightly sub. from  
Control blade displacement <sup>from .02</sup> necessary to attain circ<sup>n</sup> = 0.34

Temp 2<sup>15</sup>

Temp	11	12	14	15
	829	829	859	827

2 <sup>28</sup> blade lowered to .02 and system made crit again with fuel. D<sub>2</sub>O now reads 76.26, Fuel selcyn reads 17,898 at crit.

2 <sup>38</sup> D<sub>2</sub>O drained back to ~70, then refilled to 76.26 - just crit

3 <sup>00</sup> Drained D<sub>2</sub>O again, to ~~75~~ 71.7, then refilled to 76.26 - just crit

3 <sup>15</sup> pm Repeat of pos. period with blade at 4.00 (raised from .02) D<sub>2</sub>O = 76.28, Fuel = 17,90  
T<sub>103</sub> = 430

3 <sup>50</sup> pm System made crit with D<sub>2</sub>O = 73.48, Fuel = ~~17.94~~ <sup>17.93</sup>, blade = .02  
T<sub>103</sub> = 287

pos. period by raising blade to 4.00

4 <sup>00</sup> pm blade lowered to .02, slightly sub. Blade raised to .60 to make it crit.  
note: fuel selcyn = 17,928

4 <sup>10</sup> Shut down

4 <sup>15</sup> Solution and D<sub>2</sub>O drained back to 6.00 and 60.33 respectively to be left over night to check on any valve leaks. Markers were put on sight glasses.

144

Exp 43-A BF<sub>3</sub> chambers

Vertical Traverses; rotating pos = 161

Reg. I counter at 504 (in center)

D<sub>2</sub>O = 79.70, Fuel = 18.01

Vent pos	I	IV	II	III
11.78	1541157	23801	512540	804610
<del>11.78</del>				
"	1554310	24030	518610	815530
11.0	1600776	23339	547760	817660
"	1557624	22568	503340	792570
10.0	1489245	21093	495770	773180
<del>9.75</del> 11	1433985	20316	480390	—
"	1407613	20216	477290	742450

3-3<sup>0</sup> / lift relay became inoperative (does not reproduce.)  
Shut down

3-4-60

Took sample from D<sub>2</sub>O systemReg no. 593073 for Fluorimetric and D<sub>2</sub>O assay

3/7/60 rotating position\* = 161, Reg. delay m = 509  
Fuel = 17.93

See notes on p. 147 for chamber positions corresponding to lift position

log W = .05 on IC-4

Lift pos	I	N	II	III
10.50 / 11.78	4513526	148720	2394180	3261800
10.50 / "	4429978	139398	2262880	3142810
Power level lowered to IC-4 = .008				
10.40 / 11.78	1314865	24948	491190	777970
10.40 / "	1324106	25015	492250	782080
11.00	1345466	23814	481980	773720
10.35 / "	1274923	22320	458970	735520
10.35 / 10.00	1374558	23583	494530	793740
10.35 / "	1338902	22480	495570	768130
11.05 / 9.00	1425273	23217	506350	820820
11.05 / "	1391252	22799	499760	804820
8.00	1441973	22967	509620	832480
"	1463975	23787	521220	847670
7.00	1504282	23273	523530	855070
"	1533330	23378	522370	854170
6.00	1522319	23765	533220	873610
"	1628926	25611	570140	929960
5.00	1608040	26025	569990	933880
"	1585496	25924	572120	934520
11.20 / 4.00	1594894	27189	573510	947430
"	1653614	28465	589920	977270
3.00	1563599	27910	567380	944770
"	1565247	27961	568860	944790

\* See note p. 147

3/7/60

Left pos.	I	N	II	III
2.00	1492676	28280	552840	923840
"	1533845	29294	570460	954450
1.00	1388568	29253	546710	905330
"	1390196	29141	542260	900900
1.50	1418639	28216	535010	894340
"	1369436	26956	516060	861710
2.50	1429322	25507	512500	858620
"	1390076	24749	496130	831280
3.50	1442052	23970	509650	848810
"	1465079	24618	527390	877610
4.50	1526609	24875	542190	896330
"	1538057	24770	539500	891340
5.50	1566646	24235	543180	897040
"	1586686	25045	553500	911530
6.50	1663639	25413	576850	943910
"	1660054	25977	581020	952880
7.50	1676638	26011	584910	956480
"	1689502	26997	599640	978640
8.50	1685623	27100	598570	970490
"	1702582	27269	605190	980850
9.50	1698176	27713	605480	977580
"	1727375	28419	614160	994950
10.50	1688980	28840	603560	977760
"	1690806	29031	601320	975720
11.50	1644678	29275	588130	942900
"	1692842	29717	593030	950720

Exp 43 - B

lit	I/N	II/N	III/N
4.50	61.37 <sup>61.73</sup>	2179 <sup>21.79</sup>	36.03 <sup>36.01</sup>
"	62.09	21.78	35.98
5.50	64.64 <sup>63.99</sup>	22.41 <sup>22.26</sup>	37.01 <sup>36.70</sup>
"	63.34	22.10	36.39
6.50	65.46 <sup>64.68</sup>	22.70 <sup>22.54</sup>	37.14 <sup>36.91</sup>
"	63.90	22.37	36.68
7.50	64.45 <sup>63.52</sup>	22.49 <sup>22.35</sup>	36.77 <sup>36.52</sup>
"	62.59	22.21	36.26
8.50	62.19 <sup>62.51</sup>	22.08 <sup>22.14</sup>	35.81 <sup>35.89</sup>
"	62.43	22.19	35.96
9.50	61.27 <sup>61.02</sup>	21.84 <sup>21.69</sup>	35.27 <sup>35.14</sup>
"	60.77	21.61	35.01
10.50	58.56 <sup>58.40</sup>	20.93 <sup>20.18</sup>	33.90 <sup>33.76</sup>
"	58.24	20.71	33.61
11.50	56.17 <sup>54.57</sup>	20.08 <sup>20.02</sup>	32.20 <sup>32.10</sup>
"	56.96	19.95	32.00

Lift      I/N      II/N      III/N      3/7/60      Exp. 43-B


11.78	52.70	19.69	31.18
"	52.93 <sup>52.82</sup>	19.68 <sup>19.69</sup>	31.26 <sup>31.22</sup>
11.00	56.50	20.24	32.49
"	57.11 <sup>56.80</sup>	20.55 <sup>20.40</sup>	32.95 <sup>32.72</sup>
10.00	58.28	20.97	33.65
"	59.55 <sup>58.40</sup>	21.16 <sup>21.07</sup>	34.16 <sup>33.90</sup>
9.00	61.39	21.81	35.35
"	61.02 <sup>61.20</sup>	21.92 <sup>21.87</sup>	35.30 <sup>35.33</sup>
8.00	62.78	22.18	36.25
"	61.54 <sup>62.16</sup>	21.91 <sup>22.05</sup>	35.63 <sup>35.94</sup>
7.00	64.63	22.49	36.74
"	65.58 <sup>65.11</sup>	22.34 <sup>22.41</sup>	36.53 <sup>36.62</sup>
6.00	64.05	22.44	36.75
"	63.60 <sup>63.83</sup>	22.26 <sup>22.35</sup>	36.31 <sup>36.53</sup>
5.00	61.78	21.90	35.88
"	61.15 <sup>61.47</sup>	22.06 <sup>21.98</sup>	36.05 <sup>35.97</sup>
4.00	58.66	21.09	34.84
"	58.09 <sup>58.38</sup>	20.72 <sup>20.91</sup>	34.33 <sup>34.58</sup>
3.00	56.01	20.32	33.85
"	55.97 <sup>55.99</sup>	20.27 <sup>20.30</sup>	33.78 <sup>33.82</sup>
2.00	52.78	19.54	32.66
"	52.35 <sup>52.57</sup>	19.47 <sup>19.50</sup>	32.58 <sup>32.62</sup>
1.00	47.47	18.69	30.95
"	47.70 <sup>47.59</sup>	18.60 <sup>18.65</sup>	30.92 <sup>30.94</sup>
1.50	50.27	18.96	31.69
"	50.80 <sup>50.54</sup>	19.14 <sup>19.05</sup>	31.96 <sup>31.84</sup>
2.50	56.03	20.09	33.66
"	56.16 <sup>56.10</sup>	20.05 <sup>20.07</sup>	33.58 <sup>33.62</sup>
3.50	60.15	21.26	35.41
"	59.51 <sup>59.83</sup>	21.42 <sup>21.34</sup>	35.64 <sup>35.49</sup>

Note: after exp. 43-B it was discovered that the orientation of Reg II counter was off due to repair work on chamber before experiment. The orientation was such that the chamber was  $103^\circ$  from zero when scale read zero.


Reg I normalized by div. paper no. counts by value in center:  $\approx 65$  instead of value used in expt 44 B.



3/7/60 A recheck of height of counter relative to selsyn reading was made (BF<sub>3</sub>)




This is drawing corresponding to Selsyn = 1.00" for #I. It follows that height of center of active chamber is 2.70" above bottom at this selsyn reading




Drawing at left corresponds to Reg II at selsyn reading of 1.00 {measurement of .17 is due to plastic coating on bottom}

It follows that center of active chamber of Reg II is 2.93" above bottom when selsyn reads 1.00




Drawing at left corresponds to Reg III at selsyn reading of 1.00. Distance of center of active chamber above bottom is 3.13



Reg. IV counter at selsyn reading of 1.00. Distance of center of active chamber above bottom is 2.96"

Recheck of diameter of rotation of chambers  
 II & III



# II  
 counter

$\left\{ \begin{array}{l} \leftarrow 4 \frac{25}{32} \rightarrow \leftarrow 3'' \text{ down from sleeve} \\ \leftarrow 4 \frac{6}{8} \rightarrow \leftarrow 15 \frac{3}{4}'' \text{ down from sleeve} \end{array} \right.$

# 3  
 counter

$\left\{ \begin{array}{l} \leftarrow 7.5 \rightarrow \leftarrow 2 \frac{1}{4}'' \text{ down} \\ \leftarrow 7 \frac{1}{16} \rightarrow \leftarrow 9 \frac{3}{4}'' \\ \leftarrow 7 \frac{3}{8} \rightarrow \leftarrow 15 \frac{1}{4}'' \end{array} \right.$

150

Exp. 44-A

Bare BF<sub>3</sub> radial traverse at Center

3/8/60

Reg I selenium gaged <sup>with chamber just against wall</sup> ~~at~~ - center is at selenium reading of 512

Lift ht. = 7.02 i.e. selenium reading (see notes p 148)

Cut with D<sub>2</sub>O = 73.49, Fuel = 18.01\*

Reg. Rot	I	N	II	III	IV	Reg. I
		10-4 ~ .009				320
0.0 <sup>1/2</sup> 360	1031444	30916	802160	974450	12830	361
" " 120 300	1053988	31642	813370	993330	12880	"
40 300	<del>216001</del> 1203085	29861	707930	951270	16710	400
" " 80 260	1179737	28592	689770	926470	16370	2 PM
" <sup>100</sup> PM " 150 200	1399310	28899	585920	970420	—	450
" " 120 220	1468398	29871	613250	2009650 <sup>?</sup>	27290	"
" " 150 200	1529824	31171	630730	1052130	28950	"
" " 180 180	1671199	30728	519630	1100600	53150	500
" " 200 160	1587720	28478	490070	1038480	50260	12
" " 240 140	1703984	28662	467170	1071470	69880	"
" <sup>10</sup> PM " 280 120	1722728	28817	472400	1082930	71210	540
" " 320 100	1796296	29042	458170	1126050	104320	"
" " 360 80	1798391	29585	465270	1132760	104690	480
" " 400 60	1846313	29120	455540	1143450	149290	"
" " 440 40	1832660	29122	455320	1135810	148450	430
" " 480 20	1854137	28936	458540	1124590	201560	"
" " 520 0	1845613	28472	455980	1119560	201150	38
	power lowered to ~ .005					2
240 140	1154690	16675	270520	681220	116150	300
280 120	1173988	16304	279970	662470	151580	"
" " 320 100	1148391	15980	275100	650980	148560	240
						200
* new monometers installed (no float) and gaged.						
Full reading ~ 17.95						

Ref	Rot	I	N	II	III	IV
320	102	1148168	15726	285786	610440	188010
"	"	1156669	15264	281620	607500	187230
361	80	1102958	14629	312880	544800	229480
"	"	1063025	13859	299980	525360	219900
400	41	928727	12279	381170	388650	245220
"	<sup>20</sup> 2 PM	461529	12576	392150	400990	273530
450	0.0	933890	12226	487940	331900	309200
"	"	873509	11702	467320	313610	292280
"	"	1205276	16453	735270	501910	472000
500	60	1109853	15053	544580	721880	404090
"	<sup>20</sup> 2 PM	1460974	19993	508760	673960	375160
510	"	1412477	19196	491010	650750	360800
540	140	1710520	23022	354520	915750	152070
"	"	1792430	24136	376080	965970	161410
480	200	1379836	18409	295790	698860	45200
"	"	1319879	17227	279330	663870	42590
430	260	1269507	16943	339240	580750	15710
"	"	1287031	17391	344860	590740	15920
380	300	1230052	16397	396760	534390	9060
"	<sup>48</sup> 2 PM	1222857	16274	394610	531980	9090
300	322	1221788	16846	424430	529570	7620
"	"	1276284	17426	441160	553840	7920
240	360	1157957	16366	421950	517350	6570
"	"	1129491	15898	414160	506610	<del>4043</del> 6320
200	340	1054229	15168	396630	483910	6310
"	"	1022786	14593	379550	464380	5920

Reg I	Rot	I	W	II	III	IV
Reg 140	240	955960	14770	283350	536270	17340
" 3 <sup>13</sup> <sub>pm</sub>	"	989596	15474	281860	542070	17340
0.0 80	180	846665	14804	231740	591930	48080
" "	"	831449	14892	224830	583050	48320
40 40	140	689522	14497	222070	580840	93630
" "	"	693995	14306	224110	587410	95630
80 0.0	100	526744	14712	260580	565040	169420
" "	"	496770	14314	258460	545530	164120
"						
120						
"						
150						
" 1 <sup>10</sup> <sub>pm</sub>						
180						

" The plot of the above data shows a good deal of scatter in Reg. I. A check of reproducibility of position of counter one showed some variation, especially in the direction perpendicular to the direction of travel. A new guide was assembled consisting of two 3"x1"x1/16" pieces of plexiglas with two 1/4" plexiglas placed between them (plus shims) placed on top of center cylinder. This serves as a guide both in the direction of travel and vertically.

" after installing guide, Reg I counter centered and zeroed. Selayr = 513 at center and 9999 when chamber just touches wall.

Control blade guide installed.

Exp. 44-A

Reg I	Rate	Reg I	Reg II	Reg III	Reg IV
500	$\frac{202}{60}$	$\frac{N}{737}$	$\frac{N}{737}$	$\frac{N}{737}$	$\frac{N}{737}$
"	"	731 <sup>734</sup>	254 <sup>255</sup>	3371	18.76
"	"	736	256	3390 <sup>33.80</sup>	18.79 <sup>18.88</sup>
540	140 <sup>✓</sup>	743 <sup>743</sup>	154 <sup>155</sup>	3977	6.605
"	"	742	156	4002 <sup>39.90</sup>	6.687 <sup>6.646</sup>
480	200 <sup>✓</sup>	750 <sup>758</sup>	1605 <sup>161</sup>	3872	2.455
"	"	746	162	3853 <sup>38.63</sup>	2.472 <sup>2.444</sup>
430	260	780	200	3427	9.273
"	"	740 <sup>745</sup>	198 <sup>199</sup>	3396 <sup>34.12</sup>	9.154 <sup>9.214</sup>
380	300 <sup>✓</sup>	750 <sup>751</sup>	242 <sup>242</sup>	3259	5.525
"	"	752	242	3270 <sup>32.65</sup>	5.586 <sup>5.555</sup>
300	322 <sup>✓</sup>	726 <sup>729</sup>	252 <sup>253</sup>	3143	4.523
"	"	732	253	3178 <sup>31.61</sup>	4.544 <sup>4.532</sup>
240	360 <sup>✓</sup>	708 <sup>707</sup>	258 <sup>259</sup>	3161 <sup>31.70</sup>	4.014 <sup>3.995</sup>
"	"	706	259	3186	3.975
200	340 <sup>✓</sup>	695 <sup>697</sup>	261 <sup>261</sup>	3190 <sup>31.86</sup>	4.160 <sup>4.109</sup>
"	"	700	2601	3182	4.058
40	240 <sup>✓</sup>	648 <sup>644</sup>	192	3630 <sup>35.48</sup>	1.174 <sup>1.148</sup>
"	"	640	182 <sup>187</sup>	3503 <sup>35.48</sup>	1.121 <sup>1.148</sup>
80	180 <sup>✓</sup>	572 <sup>565</sup>	1565 <sup>154</sup>	3998	3.247 <sup>3.246</sup>
"	"	558	151	3915 <sup>39.57</sup>	3.245
120	140	476 <sup>480</sup>	153 <sup>155</sup>	4006 <sup>40.56</sup>	6.458 <sup>6.575</sup>
"	"	4849	1566	4105	6.683
200	100	3580 <sup>352</sup>	1771 <sup>179</sup>	3840 <sup>38.25</sup>	11.52
"	"	3470	1805	3810	11.46 <sup>11.49</sup>

Exp. 44-A

Radial traverse, Base <sup>BF<sub>3</sub></sup> ~~to~~ chambers

Reg I  
Pos.

	Reg I Pos.	I /N	II /N	III /N	IV /N	
0	360	3335	2595	3153	415	
"	"	333 <sup>333</sup>	2570 <sup>258</sup>	3140 <sup>3145</sup>	407	411
40	300	403 <sup>408</sup>	2372	319	560	560
"	"	413	241 <sup>239</sup>	324	572	
80	240	485 <sup>489</sup>	203	376		
"	"	492	205 <sup>203</sup>	-	33.7	914 920
"	"	491	202	337	928	
20	220	544 <sup>550</sup>	169 <sup>171</sup>	361	1730	1740
"	"	558	172	365 <sup>363</sup>	1765	
60	200	595 <sup>597</sup>	163 <sup>164</sup>	374	244	2455
"	"	598	164	375 <sup>375</sup>	247	
80	180	618 <sup>613</sup>	1575	3877	386	3592 356
"	"	608	1572 <sup>157</sup>	3828	3538	
0	160	634 <sup>631</sup>	1565	3926	391	5127 5110
"	"	629	1563	3900	5098	
0	140	<del>641</del>	1584 <sup>160</sup>	3886	6960	7000
"	"	648 <sup>670</sup>	1602	3932 <sup>395</sup>	7064	
"	"	693	1622	4085	6965	
280	120	720 <sup>719</sup>	1717	4063	407	9297 9295
"	"	718	1722	4073	9296	
320	100	731 <sup>743</sup>	1815	3882	1195	1210
"	"	757	1845 <sup>183</sup>	3981 <sup>393</sup>	1226	
361	80	754 <sup>760</sup>	214	3724	1568	
"	"	767	216 <sup>215</sup>	3791 <sup>375</sup>	1587	15.75
400	40	756 <sup>760</sup>	310	3165	2160	
"	"	765	312 <sup>311</sup>	3188 <sup>317</sup>	2175	2165
450	0	764	399	2715	2529	
"	"	746 <sup>755</sup>	399 <sup>399</sup>	2679 <sup>270</sup>	2497	251
"	"	732	4469	3051	2869	

3/10/60

Radial traverse with bare BF<sub>3</sub> chambers  
hoist position 7.02 (center vertically of active chambers)D<sub>2</sub>O = 73.63, Fuel = 17.98

10.4 = .005

Reg I	Ret	I	N	II	III	IV
5.13	0.0	1266349	15663	672190	430390	386530
5.13	0.0	1230227	15112	645620	415740	390790
"	"	1240749	15606	651550	421820	395410
"	"	1260721	16041	661020	430300	402710
"	"	1288312	16048	671120	437370	410101
"	"	1319390	16789	690290	452210	423560
"	"	1369829	17477	718010	468870	437550
"	"	1358306	17404	711580	464190	436330
"	"	1310474	16755	683770	447100	417760
"	"	1277108	16172	662350	432650	403470
"	"	1246036	15509	647200	422270	394250
Note: above counts in reg. I are to be used as normalization counts for BF <sub>3</sub> chambers.						
540	40	1241105	15581	499770	490300	337100
"	"	1222338	15087	488790	481560	331120
480	80	1357691	16972	379600	631690	262050
"	"	1464598	18629	410210	686440	285950
440	120	1648172	21306	372540	839830	192140
"	"	1694846	22337	384000	868230	199400
400	160	1009273	12586	204370	501190	56090
"	"	971669	12032	197540	483160	54160
360	200	1025300	12861	215350	487110	28140
"	"	1090318	13846	229840	518600	30260



Reg I	Rot	I	W	II	III	IV
300	240	1090132	13851	262430	487340	15490
"	11 <sup>OS</sup>	1071347	13901	259420	480300	15240
260	280	1049083	13553	303040	444790	8530
"	"	1076556	13993	310920	464060	8720
"	"	1084335	13956	312630	460550	8930
210	320	1013019	13419	341490	422740	5750
"	"	976402	12756	326680	405980	5430
160	360	934792	12752	336520	404450	4820
"	"	1026716	14197	375080	451920	5530
100	280	1016810	16178	359610	527940	10020
"	"	1009942	16036	354230	520020	10020
40	240	810178	15760	292400	549460	17070
"	"	812344	15782	291830	548600	—
"	"	813480	15842	292200	550760	17300
P.O.	200	664159	15947	264660	607980	35300
"	"	680447	16561	268190	614790	36290
60	140	888329	15749	259390	631170	100380
"	"	890257	16022	258370	632390	102110
120	100	1044548	15884	297520	602440	186510
"	"	1040144	16101	296470	601380	186620
180	50	1059609	14742	411640	468480	288820
"	"	1057251	14824	409140	465250	285630
240	0.0	1039490	13771	529850	353260	325350
"	"	1041118	13606	529400	353040	325340
320	100	1207882	15345	286330	581290	178290
"	"	1148164	14593	273450	556650	170490
380	160	1164604	14285	230440	577250	65810
"	"	1145808	14273	224240	560550	63400

Exp. 44-13 Radial traverse after installing guide

Reg I	I/N	II/N	III/N	IV/N	Rot. Pos.
513					0.0
	8084	4291	2747	2467	"
	8130	4272	2751	2585	"
	7950	4174	2703	2533	"
	7861	4120	2682	2510	"
	8026	4181	2725	2555	"
	786	4111	2693	2522	"
	784	4108	2682	2503	"
	780	4089	2667	2507	"
	782	4080	2668	2493	"
	7895	4095	2675	2495	"
	8015	4173	2722	2542	"
	796	3205	3145	2163	41
	810	3243	3193	2194	"
	800	2235	372	1544	81
	784	2202	3685	1535	"
	774	1748	398	9018	120
	757	1720	393	8969	"
	802	1623	3982	4456	160
	796	1640	4015	4501	"
	797	1675	3787	2188	200
	788	1660	3745	2185	"
300	787	1895	3518	1118	240
"	770	1865	346	1096	"
260	774	2235	328	6293	280
"	768	222	324	6231	"
50	777	224	330	6398	320
210	788	2545	315	4284	320
"	766	254	3182	4256	"
160	733	2638	3171	3779	360
"	723	2642	3183	3895	"

Reg I	Ref. Pos	Reg I N	Reg II N	Reg III N	Reg IV N
100	280	628	222	326	6193
"	"	631 <sup>630</sup>	221 <sup>222</sup>	325 <sup>326</sup>	6248 <sup>6221</sup>
40	248	516	1863	356	1087
"	"	515 <sup>519</sup>	1848 <sup>1852</sup>	3475 <sup>348</sup>	— <sup>1090</sup>
"	"	527 <sup>519</sup>	1845 <sup>1848</sup>	347 <sup>348</sup>	1092
0.6	200	4165	1658	381	2213
"	"	4114 <sup>414</sup>	1621 <sup>164</sup>	371 <sup>376</sup>	2191 <sup>2202</sup>
60	140	561 <sup>559</sup>	1647	401 <sup>398</sup>	6373 <sup>6373</sup>
"	"	556 <sup>559</sup>	1613 <sup>1630</sup>	395 <sup>398</sup>	6373 <sup>6373</sup>
120	100	658 <sup>652</sup>	1873 <sup>1869</sup>	379 <sup>377</sup>	1174
"	"	646 <sup>652</sup>	1865 <sup>1869</sup>	3735	1159 <sup>1167</sup>
180	50	719	279 <sup>276</sup>	318 <sup>315</sup>	1959
"	"	713 <sup>716</sup>	276 <sup>276</sup>	312 <sup>315</sup>	1926 <sup>1943</sup>
240	0	755 <sup>760</sup>	3845	2565 <sup>2580</sup>	2362
"	"	765 <sup>760</sup>	389 <sup>387</sup>	2595 <sup>2580</sup>	2390 <sup>2374</sup>
320	100	787	1865 <sup>1870</sup>	379 <sup>380</sup>	1161
"	"	787 <sup>787</sup>	1875	381 <sup>380</sup>	1168 <sup>1165</sup>
380	160	815 <sup>809</sup>	1614 <sup>1642</sup>	406 <sup>394</sup>	4606
"	"	802	1570	3925	4441 <sup>4524</sup>
420	180	807 <sup>813</sup>	1575 <sup>1592</sup>	3848 <sup>3878</sup>	3164
"	"	819	1608	3915 <sup>3878</sup>	3240 <sup>3202</sup>
513	220	815	1763 <sup>m</sup>	3695 <sup>m</sup>	1621 <sup>g</sup>
"	"	794	1700 <sup>m</sup>	3565 <sup>m</sup>	1558 <sup>g</sup>
		8079	1738	3640 <sup>m</sup>	1587 <sup>g</sup>

Reg Rot	I	N	II	III	IV
420 180	1156002	14335	225760	550140	45370
" "	1166763	14243	229210	558280	46140
513 220	1222641	14993	264760	554250	24310
" "	1270036	15999	272130	570750	24630
" "	1305001	16152	280830	587970	25640
Temp <sup>23</sup> / <sub>12 pm</sub>	#11, 1037	#12, 1080	#14, 1110	#15, 1020	
<sup>24</sup> / <sub>12 pm</sub>	Shut down				

3-11-60

Expt 44 C

Reg I counter in counter of Reg IV  
 104-.035 Fuel-1802, D<sub>2</sub>O - 7337

Normalized i.e. Reg I chamber, in Reg IV

#1 chamber in Reg. IV	Normalizer (power level)	$\frac{IV}{N}$	#1 in IV	Norm	$\frac{IV}{N}$
267291	108888	2455	272955	116503	2342
275251	112293	2451	279296	119328	2340
279360	115112	2427	277004	119216	2323
281643	117508	2396	281718	121512	2319
285660	119268	2395	279846	121289	2307
283466	118787	2386			
281832	118202	2384			
280299	117141	2392			
277373	117241	2365			
272580	115543	2359			
268773	114011	2357			
269236	114956	2342			

Note:  
 10<sup>00</sup>/<sub>am</sub> 3/11/60  
 It was found that background counts on counters were

#I	II	III	IV
4500 <sub>pm</sub>	1400	160	7

#15 voltage

156 3/11/60

Amplifier Settings: BF<sub>3</sub> chambers { settings have not been changed from previous BF<sub>3</sub> traverses.

	Gain	Rise time	PDL	
I	16	0.8	9	[change in Reg I PDL made on 3/17/60, p. 168]
II	16	0.8	8	
III	16	0.8	30	
IV	16	0.8	8	

High voltage for I+III = 1650

" " " II+IV = 1650 also but meter reads 1500

9<sup>48</sup>

The above counts (p. 155) show drift. Shut down. Reg I, II, III had spurious background count as shown on 155

i.e. Reg I chamber

Normalizer in Reg. IV

55  
10 AM

	I	N (power)	II	III	IV
	491298	230531	2849410	4136890	385980
	490079	231662	2840470	4151840	386320
	491094	232965	2838830	4157960	387070
	438919	209820	2817670	4148160	384970
	491182	235104	2828550	4156520	387220
	471028	224080	2715990	4109660	368220
	457195	221267	2669660	4086650	361430
	449173	217361	2618070	4061110	353690
	443904	215158	2591610	4045180	348990
	459751	220423	2648300	4089410	359150
	473312	229497	2709380	4135460	371870
11 <sup>25</sup>	469093	226462	2678860	4108180	368190
	464039	224191	2655730	4096990	364460
	461639	223602	2639840	4097340	362520
	462243	223568	2639520	4097340	362610
	463632	224836	2639270	4102180	363100

Dec changed  
revisions - BF<sub>3</sub>  
rscs.

Reg I PDL -  
3/17/60, p. 168

3/11/60

Exp. 44-C

Data for second  
series of counts

cells 1500

Sket  
shown

I/N      I/II

	I/N	I/II	
	<del>2131</del>	1272	I/N shows slight trend down in early counts, then seems to level.
	<del>2115</del>	1268	
5980	2108	1268	I/II gave no trend.
320	2091	1140	
7070	2089	1268	Normalizer may have drifted.
34970	2102	1279	
87220	2066	1270	
68220	2042	1271	
361430	2085	1280	
353690	2062	1272	
348990	2071	1274	
359150	2069	1273	
371870	2064	1273	
368190	2067	1274	
364460	2062	1276	
362520	2056	1275	
362610			
363100			

105 Reg I chamber, as normalizer, centered in vent hole of Reg III.

Reg I Counter	Normalizer (mag power)	IV	Reg I ctr N	I/IV
1,328,803	53062	85000	25.04	<del>15.63</del>
132475B	53272	84510	24.80	15.47
1321572	53217	85420	24.83	15.47
1319834	53383	84850	24.72	15.55
1325449	52999	85700	25.01	15.57
1325037	53020	84320	24.99	15.71
1326337	53187	84360	24.94	15.72
1323074	52466	84200	25.72	15.71
1321994	53299	83520	24.80	15.83
1307350	52367	83360	24.46	15.68
1304982	52939	83560	24.65	15.62

Reg I Counter placed back in center of Reg I

1276968	15008	23120	81.81	55.23
1295300	15880	23940	81.57	54.10
1325743	16520	25770	80.25	52.67
1324242	16410	25760	80.70	52.63
1360929	16894	25810	80.55	52.70
1379046	16992	26270	81.16	52.49
1386347	16973	26600	81.67	52.12
1385593	17240	26810	80.30	51.68
1396918	17217	26870	81.13	51.98
1403641	17267	27010	81.29	51.97
1418370	17590	27720	80.63	

158

Reg F

Nor

IV

Reg F/N

I/IV

3/11/60

140 1875

17312

27010

80.97

5190

3<sup>00</sup>  
P.M.

Reg I counter placed in center of Reg II vent (also centered vertically.)

Reg I	Norm. (power)	IV	F/N	I/IV
280755	34076		7782	
278236	35536		7829	
276560	35028		7895	
272722	35063		7777	
275460	35438		7773	
273065	34807		7845	
272684	35021		7786	
270277	34636		7803	
276073	35184		7846	
276213	35483		7784	
277879	35574		7811	
277650	36277		7653	
278828	35997		7745	
278304	36118		7705	
279151	36061		7741	

AV. 77.85



3/15/60

159

2.00  
3/15/60

Cd covered BF<sub>3</sub> counters installed in I, II, III & IV  
~~Reg I counter relay is geared when cd~~  
~~covered counter just touches wall~~ Reg I relay  
 reads 499 when chamber at center and 998  
 when chamber just touches wall

Exp. 45

Cd-Covered BF<sub>3</sub> counters Vertical traverseReg I relay = 499; Rot. pos relay = 160; Fuel rel. = 18.80; O<sub>2</sub> = 79.90

Height Pos	I	N	II	III	See note p. 160
11.78 <sup>3.00</sup> / <sub>3/15/60</sub>	193010	270986 <sup>2</sup>	597710	157320	
"	188899	206794	594130	157660	
"	189585	204840	577130	153470	
"	182818	204452	581750	152070	
11.02	207297	215115	640300	170040	
<sup>15</sup> / <sub>3</sub> "	210238	219839	646990	172680	
10.00	208188	208858	646930	176500	
"	210692	207500	646260	176060	
9.00	179724	182722	586470	160210	
"	176155	181039	581460	159640	
8.00	178688	177011	571340	161920	
"	178818	178958	573270	164750	
7.00	176112	178032	574040	165780	
"	178073	181095	576160	167930	
6.00	118669	63710	213390	59230	
"	115332	61239	204720	56970	
5.00	77068	40506	133980	37170	
"	66844	34855	114330	31420	

3/15/60

LIHT	I	N	II	TCL
4.00 <sup>5/8</sup> 3 PM	67391	34265	116160	30090
"	63621	33976	108000	29840
3.00	70634	39626	121080	33030
"	70311	39929	121250	32920
2.00	74319	40922	116940	31670
"	77124	42047	115350	32130
1.00	83042	45562	112800	31360
"	84838	45333	112510	31580
2.50	70464	40236	115250	32110
"	67744	38078	111770	30170
4.50	53034	28650	98160	25280
"				

It was discovered that Reg I counter had been lowered against the guide, above the center cyl. and counter was bent considerably, hence Reg I counts not good

Counter was straightened and put back in center of region

after straightening the counter was .09" higher at a given relay reading

Exp. 45 Vertical traverse

Height position	I/N	Σ/N	Σ <sup>2</sup> /N
11.78	7122	2206	
"	9134	2873	7624
"	9256 <sup>9110</sup>	2818	7492
"	8942	2845	7438
11.02	4636 <sup>9600</sup>	2976	7902
"	9563	2943 <sup>2960</sup>	7854 <sup>7878</sup>
10.00	9967 <sup>1006</sup>	3097 <sup>3104</sup>	8450
"	10154	3115	8486 <sup>8468</sup>
9.00	9835	3211	8768 <sup>8789</sup>
"	9734 <sup>9784</sup>	3212 <sup>3212</sup>	8810
8.00	10094 <sup>10046</sup>	3227	9146 <sup>9178</sup>
"	9994	3205 <sup>3216</sup>	9209
7.00	9893	3225	9308
"	9834 <sup>9864</sup>	3181 <sup>3202</sup>	9271
6.00	1862	3349	9296
"	1882	3342	9302
5.00	1902	3307	9175
"	1894	3279	9010
4.00	1966	3214	8781
"	1872	3178	8782
3.00	1782	3055	8334
"	1760	3034	8244
2.00	1816	2856	7739
1.00	1834	2743	7641
"	1822	2475	6883
2.50	1751	2864	7980
"	1779	2935	7923
4.50			

3/16/60

Exp. 4 G  
 Vertical + transverse; Cd-covered BF<sub>3</sub> chambers  
 Rot. pos. 160

161

lift	I	N	II	III
.80	103289	126054	326050	86410
"	100390	123659	318240	85050
2.00	82131	86827	254660	67910
" 9 <sup>30</sup>	74060	78105	229300	61120
3.00	102290	103520	327020	88640
"	105706	107258	337810	91280
4.00	97049	95830	321810	86060
"	91755	91979	308150	82760
5.00	80416	81054	279040	74520
"	76895	77615	267780	71480
6.00	82423	70652	255490	66340
"	77103	70798	250520	65210
7.00	78310	68949	245150	63620
"	87140	68312	242720	62430
8.00	93736	71550	254050	65220
"	92797	74404	261050	67260
9.00	99652	83946	290110	73170
"	93506	83963	287840	73020
"	44769	84276	285810	73700
"	101949	85457	291730	75250
10.00	117115	112779	362350	93950
" 10 <sup>30</sup>	126293	122771	388880	102360
"	132991	128138	407620	106050
11.00	137973	147674	440810	113470
"	140207	148677	442740	114060
"	139017	151471	450450	115790

Wt.	I	N	E	W
11.78 <sup>3/10</sup>	150817	176073	492930	127170
"	153466	175534	491300	126010
"	148160	169052	472680	120970
10.50	118704	123670	382620	98350
"	112773	119615	368240	94670
"	106355	119530	368110	93930
8.50	89584	95551	318500	83960
"	85368	91608	305340	79380
"	88273	91753	301950	79640
7.50	85714	87302	291440	77850
"	86254	86496	289790	77210
"	84681	85431	286580	76630
6.50	85149	88733	298560	80180
"	86613	90743	303601	81600
"	89108	93111	312750	84450
5.50	96841	102611	339710	92380
"	101317	105225	344530	94840
"	102989	106327	348790	96180
"	102808	104843	341550	94080
3.50	129071	142350	432000	121060
"	137202	152974	461160	129270
"	126507	139502	427690	118670
1.50	152516	182020	477490	135130
"	148312	182957	474640	134280
" <sup>3/10</sup>	149082	182204	472020	134170
11.25	Shutdown			

Exp. 46

list	I/N	II/N	III/N	list	I/N	II/N	III/N
1.77		193	3				
.8	8191	2586	6852	8.50	9375	3333	8787
.8	8122 <sup>8137</sup>	2574 <sup>2580</sup>	6881 <sup>6866</sup>	"	9318 <sup>9457</sup>	3333 <sup>3319</sup>	8665 <sup>8671</sup>
2.00	9459	2932 <sup>2954</sup>	7821 <sup>7823</sup>	"	9620	3291	8680
"	9482 <sup>9471</sup>	2935 <sup>2954</sup>	7825 <sup>7823</sup>	7.50	9818	3338	8917
3.00	9881	3159 <sup>3154</sup>	8564 <sup>8537</sup>	"	9972 <sup>9900</sup>	3350 <sup>3354</sup>	8926 <sup>8937</sup>
"	9855 <sup>9868</sup>	3149 <sup>3154</sup>	8510 <sup>8537</sup>	"	9912 <sup>9900</sup>	3354	8969
4.00	10127	3358 <sup>3354</sup>	8986 <sup>8989</sup>	6.50	9596	3364	9036
"	9976 <sup>1003</sup>	3350 <sup>3354</sup>	8997 <sup>8989</sup>	"	9544 <sup>957</sup>	3345 <sup>3352</sup>	8992 <sup>9000</sup>
5.00	9921	3442 <sup>3444</sup>	9191 <sup>9200</sup>	"	9570	3358	9069
"	9907 <sup>9914</sup>	3450 <sup>3444</sup>	9209 <sup>9200</sup>	5.50	9437	3311	9004
6.00	1166 <sup>1128</sup>	3616 <sup>3577</sup>	9389 <sup>9301</sup>	"	9629 <sup>9639</sup>	3274 <sup>3278</sup>	9013 <sup>9010</sup>
"	10893	3539 <sup>3577</sup>	9213 <sup>9301</sup>	"	9685 <sup>9639</sup>	3280 <sup>3278</sup>	9045 <sup>9010</sup>
7.00	11557 <sup>1206</sup>	3550 <sup>3552</sup>	9227 <sup>9182</sup>	"	9806	3259	8977
"	12756	3553 <sup>3552</sup>	9138 <sup>9182</sup>	3.50	9069	3034	8507
8.00	1370	3551 <sup>3530</sup>	9115 <sup>9077</sup>	"	8969 <sup>9035</sup>	3014 <sup>3010</sup>	8452 <sup>8488</sup>
"	1247 <sup>1279</sup>	3568 <sup>3530</sup>	9039 <sup>9077</sup>	"	9068 <sup>9035</sup>	3065	8506 <sup>8488</sup>
9.00	1187	3455	8715	1.50	8379	2623	7423
"	11136 <sup>115</sup>	3428 <sup>3422</sup>	8696 <sup>8740</sup>	"	8106 <sup>822</sup>	2594 <sup>2622</sup>	7341 <sup>7378</sup>
"	11245	3391 <sup>3422</sup>	8745 <sup>8740</sup>	"	8183 <sup>822</sup>	2590 <sup>2622</sup>	7365 <sup>7378</sup>
"	1092	3414	8805				
10.00	1038	3213	8330				
"	1028	3167 <sup>3186</sup>	8340 <sup>8315</sup>				
"	1037 <sup>1034</sup>	3180 <sup>3186</sup>	8276 <sup>8315</sup>				
11.00	9343	2985	7684				
"	9430 <sup>9315</sup>	2977 <sup>2978</sup>	7674 <sup>7666</sup>				
"	9174 <sup>9315</sup>	2973 <sup>2978</sup>	7642 <sup>7666</sup>				
11.78	8564	2799	7221				
"	8743 <sup>8689</sup>	2799 <sup>2797</sup>	7180 <sup>7184</sup>				
"	8761 <sup>8689</sup>	2795 <sup>2797</sup>	7153 <sup>7184</sup>				
10.50	9598	3093	7952				
"	9427 <sup>9307</sup>	3078 <sup>3083</sup>	7910 <sup>7906</sup>				
"	8898	3080	7858 <sup>7906</sup>				

omit

3/16/60

Repeat of Reg I  
(Vertical, Cd-covered)

163

2<sup>00</sup><sub>PM</sub> Reg I shows considerable scatter especially in center portion of travel. Counter was coated (after this was discovered) with grease to increase insulation from water.

Counts below are for purpose of determining if this will lessen scatter

Time	I	N	I/N	
11.78	111620	130721	853	} 8472
	115749	135346	855	
	119994	142685	841	
	126407	149604	845	
	124264	147649	842	
7.00	104323	105576	1.007	} 1.005
	103661	102759	1.009	
	<del>102853</del>	<del>101680</del>	<del>1.011</del>	
	<del>100500</del>	<del>100984</del>	<del>.9952</del>	
	100625	100396	1.002	

Counts seem constant, continue traverse

Time	I	N	I/N	
2 <sup>37</sup> <sub>PM</sub> 8.00	103275	104175	.9913	} 9829
"	104574	107309	.9744	
"	104582	106332	.9830	
9.00	109949	113622	.9674	} 9847
"	114882	115798	.9920	
"	120947	121593	.9947	

3/16/60

	Lift	I	N	I/M	
	10.00	124844	134171	.9290	
	"	125432	135177	.9278	9280
2 <sup>50</sup> / <sub>PM</sub>	"	127265	137220	.9274	
	11.00	145192	165364	.8780	
	"	139652	157296	.8878	8894
	"	137502	152231	.9032	
	10.50	127505	140625	.9068	
	"	125135	139229	.8987	9112
	"	126939	136748	.9282	
3 <sup>03</sup> / <sub>PM</sub>	8.50	114093	103445	<del>1.105</del>	1.081 ?
	"	100965	99332	<del>1.016</del>	
	"	109072	97044	1.123	
	7.50	101094	91979	1.099	
	"	94643	91511	<del>1.034</del>	1.063 ?
	"	95393	90285	1.056	
	6.00	102520	89589	1.144	
		183770	91247	2.013	?
		98403	92564	1.063	
		94040	94346	.9967	
		96034	96813	.9919	
		96275	98967	.9727	981
		100171	101874	.9833	
		99727	101953	.9781	
		102648	104814	.9793	
	5.00	110519	115344	.9582	
3 <sup>30</sup> / <sub>PM</sub>	"	112980	116398	.9706	9636
	"	110924	115311	.9620	



3/14/60

list	I	N	I/N
4.00	122155	130958	.9328
"	123629	130847	.9448 .9408
"	118577	125459	.9448
3.00	120608	136538	.8833
"	122598	138579	.8845 .8849
"	122305	137878	.8869
2.00	121114	145566	.8319
"	117110	141233	.8292 .8299
"	115578	139471	.8287
1.00	144464	187171	.7718
"	155822	201720	.7724 .7634
"	152409	204312	.7460
3 <sup>55</sup> / <sub>P.M.</sub>	1.50	150036	192967 .7775
"	158429	200262	.7911 .7893
"	161726	202287	.7994
3.50	126605	139476	.9075
"	125072	139881	.8941 .8997
"	126219	140586	.8977
5.50	101828	105581	.9644
"	98868	102107	.9482 .9646
"	95347	99180	.9613
6.50	92558	94884	.9754
"	92893	94197	.9861 .9808
4 <sup>18</sup> / <sub>P.M.</sub>	"	91899	93686 .9809
7.50	94427	96819	.9752
"	97341	98217	.9910 .9799
"	97699	100359	.9734

166 2/16/60

Since repeat points (going up) seem lower  
this repeat was made by raising left and lowering to 7.00

	LIST	I	N	E/N
	7.00	97697	98719	.9894
	"	96827	98676	.9812 9842
<sup>35</sup> 4 PM approached going up →	"	95787	97553	.9818
	9.00	117493	123337	.9526
	"	121873	127788	.9536 9473
	"	124128	132647	.9357

<sup>35</sup>  
4 PM Shut down

Temp at ~ 3:30 pm i

# 12	# 14	# 15
1000	1129	1091

9<sup>00</sup> Guide for Reg I counter was reinstalled and counter rezeroed. Selsyn = 999.41 when counter touches wall and selsyn = 44.5 at center.

Not good - See page 168

lift selsyn = 7.00

Reg I	Rot	Reg I	N	Reg II	Reg III	Reg II
509	5a	179206	166608	574740	289080	Log N = .04
509	52	313211	308880	987390	520000	Log N = .1
"	"	300088	298602	941320	498310	
"	"	294841	291716	912880	482810	counter in Reg I
445	90	294768	294894	938920	430300	giving some
"	"	315494	293539	929540	426450	difficulty as
"	"	319496	291076	923070	422610	before
"	"	315969	287787	905360	414920	
"	"	284766	287302	-	-	
"	"	280292	284172	-	-	
"	"	279132	280624	-	-	
"	"	272720	313291	-	-	
"	"	304049	361532	-	-	
"	"	464504	352753	-	-	
"	"	355753	344031	-	-	
"	"	345477	330502	-	-	
"	"	314682	328427	-	-	
"	"	319585	331409	-	-	
"	"	316199	326071	-	-	
"	"	310123		-	-	

Because of bad counts we shut down.  
Rohrer found counts being thrown into Reg I counter. Discriminator setting to be adjusted (see below).

<sup>00</sup>  
3 PM

Counter replaced in Reg I and rezeroed. Scaleyn = 999.50 when counter touches wall. Since stroke is same as before, center corresponds to scaleyn reading of 4.54.

~~Exp. 47 continued~~

~~Reg I Rot~~

~~510 40~~

Discriminator setting on Reg I amplifier changed to 12 (from 9 as per page 156).

5964

5987

20

Counts to check Reg I after

3/17/60

Discriminators changed to 12

Reg I  
/N

608

604

602

598

597

599

143741

240048

597

143715

240655

591

141111

238421

597

144227

241414

602

146231

242779

594

592

144864

244789

3/18/60

Exp. 47

Radial traverse; Cd-covered BF<sub>3</sub> chambers

Lift = 7.00

Fuel = 22.2; D<sub>2</sub>O = 81

Reg	Rot	I	N	II	III	IV
510	41	86282	144382	493310	250610	11510
"	<sup>80</sup> 80	79547	132990	452990	230540	10570
"	"	78893	131659	434660	227980	10090
"	"	77609	129177	417560	220280	10300
"	"	75487	125707	408490	216510	9900
480	80	138967	239759	791430	364470	10410
"	"	133561	231662	765440	352850	9910
440	120	173999	300826	977020	375740	5400
"	"	191477	328549	1048790	408070	5950
280	140	317291	480532	1455550	516140	5260
"	"	232451	357190	1105500	382730	3680
"	"	225541	348120	1074140	371940	3720
240	160	259182	381155	1160980	358100	2660
"	"	264596	391707	1192070	367000	2790
200	180	298775	412543	1225230	—	1870
"	"	305478	<del>422136</del> 30	1242840	332590	1820
"	"	302686	416266	1227160	328860	1850
160 <sup>200</sup>	200	328465	423646	1215760	284940	1300
"	"	332422	426589	1223630	286600	1280
120	240	376973	450748	1226720	219740	770
"	"	369991	444993	1214050	216820	740
"	"	368074	443389	1209300	215500	770
80 <sup>280</sup>	280	358850	414196	1112280	153410	460
"	"	366419	424301	1130840	156030	450

170

Log I	Rat	I	N	II	III	IV	
<del>40</del>	<del>320</del>						
40	320	387337	425778	1114150	132020	360	
"	"	387727	428019	1125280	133390	350	
999.50	320	379666	387580	1014870	118400	320	
"	"	373035	381170	994050	116820	300	
000	300	347948	367532	966800	120240	330	
"	"	366799	387530	1004660	125950	340	
320	260	318334	527376	1388470	223560	670	
"	"	326055	540959	1416080	229080	720	
360	220	300466	513387	1395830	294290	1120	
"	"	298143	508420	1386750	291480	1040	
400	190	245700	434752	1224860	314910	1590	
"	"	234408	415106	1185300	303370	1480	
460	150	170866	311438	926580	306290	2520	
"	"	167071	305338	911010	301700	2560	
490	120	123841	226217	682970	266710	3760	
"	"	127971	232349	703740	275180	3880	
260 <sup>3/4</sup> <sub>10</sub>	90	104271	168106	507610	232370	5730	
"	"	97369	157789	475750	215900	5080	
320	50	93533	144755	440220	227580	9550	
"	"	97028	148841	454980	535330	10070	
180 <sup>1/2</sup> <sub>10</sub>	100	157159	221390	678300	289800	5840	
"	"	156089	220987	676850	289200	5770	
100	140	220369	263925	076410	276660	2780	
"	"	225664	271732	787650	283130	2880	
50 <sup>1/2</sup> <sub>10</sub>	180	248776	276924	778130	209710	1210	
"	"	241748	268268	762240	204320	1110	
-10	210	235135	244755	683320	<del>146000</del> <del>300320</del>	600	
"	"	241590	252398	697400	151120	600	
1125		Shut down					

	Reg I	Rot	I/N	II/N	III/N	IV/N	
	510	41	598	3416	1735	7970	
	"	"	598	3406 <sup>3.21</sup>	1734 <sup>1</sup>	7902	
570	"	"	599	3302 <sup>3.21</sup>	1731 <sup>1.72</sup>	7740 <sup>1.78</sup>	
"	"	"	601 <sup>5.994</sup>	3232	1705 <sup>1.72</sup>	7973 <sup>1.78</sup>	
"	"	"	601	3249	1722	7875	
480	80	80	579 <sup>5.777</sup>	3301 <sup>3.30</sup>	1520 <sup>2.2</sup>	4342	
540	"	"	5765	3303 <sup>3.30</sup>	1523 <sup>1.3</sup>	4277 <sup>4.309</sup>	
440	120	120	5783 <sup>5.805</sup>	3248	1249	1795	
500	"	"	5828	3192 <sup>3.2</sup>	1242 <sup>1.246</sup>	1811 <sup>1.803</sup>	
280	140	140	6600 <sup>5</sup>	3029	1074 <sup>5</sup>	1094	
340	"	"	6507 <sup>6.525</sup>	3094 <sup>3.05</sup>	1071 <sup>10.71</sup>	1030 <sup>10.64</sup>	
"	"	"	6470 <sup>6.525</sup>	3085	1068	1068	
240	160	160	6799 <sup>7.16</sup>	3045	9395 <sup>9.378</sup>	6978	
300	"	"	6754 <sup>6.716</sup>	3043 <sup>3.04</sup>	9360 <sup>9.378</sup>	712 <sup>7.12</sup>	
200	180	180	7242 <sup>7.249</sup>	2969	-	4533	
200	"	"	7236 <sup>7.249</sup>	2944 <sup>2.95</sup>	7878 <sup>7.889</sup>	431 <sup>4.329</sup>	
"	"	"	7271	2947	7900	4444	
160	200	200	7750	2860 <sup>2.865</sup>	6725 <sup>6.722</sup>	3068	
220	"	"	7792 <sup>7.771</sup>	2869	6718 <sup>6.722</sup>	3000 <sup>3.034</sup>	
120	240	240	8363 <sup>8.364</sup>	2721	4874 <sup>4.876</sup>	1708	
180	"	"	8314 <sup>8.312</sup>	2728 <sup>2.72</sup>	4872 <sup>4.876</sup>	166 <sup>1.66</sup>	
"	"	"	8301 <sup>8.301</sup>	2726	4860 <sup>4.86</sup>	1737	
140	80	280	8643 <sup>8.643</sup>	2685	3703 <sup>3.703</sup>	1111	
"	"	"	8635 <sup>8.635</sup>	2665 <sup>2.67</sup>	3676 <sup>3.676</sup>	1061 <sup>1.061</sup>	
180	40	320	9097 <sup>9.097</sup>	2616 <sup>2.616</sup>	3100 <sup>3.108</sup>	8454	
100	"	"	9058 <sup>9.058</sup>	2629 <sup>2.62</sup>	3116 <sup>3.116</sup>	817 <sup>8.17</sup>	
10	999.50	320	9795 <sup>9.795</sup>	2618	3054 <sup>3.059</sup>	824	
0	"	"	9785 <sup>9.785</sup>	2607 <sup>2.61</sup>	3064 <sup>3.064</sup>	787 <sup>7.87</sup>	
60	0.00	300	9464 <sup>9.464</sup>	2631 <sup>2.631</sup>	3270 <sup>3.270</sup>	898	
"	"	"	9465 <sup>9.466</sup>	2593 <sup>2.61</sup>	3249 <sup>3.260</sup>	877 <sup>8.77</sup>	
380	320	260	6036 <sup>6.036</sup>	2632	4238 <sup>4.238</sup>	1270	
			6027 <sup>6.027</sup>	2617 <sup>2.62</sup>	4235 <sup>4.235</sup>	1331 <sup>1.331</sup>	

Print specimen of dip



Exp. 47

10  
9  
8  
7  
6  
5  
4  
3  
2  
1

Reg I	Rot	I/N	II/N	III/N	IV/N
<del>360</del>	<del>220</del>	<del>300466</del>	<del>513387</del>	<del>1595836</del>	<del>294290</del>
360	220	5853 <sup>8358</sup>	2718 <sup>2723</sup>	5732 <sup>5733</sup>	2181 <sup>002113</sup>
420	"	5863 <sup>5858</sup>	2727	5733 <sup>5733</sup>	2045 <sup>002113</sup>
400	190	5651 <sup>5649</sup>	2817 <sup>2835</sup>	7243 <sup>7275</sup>	3657 <sup>36611</sup>
460	"	5646 <sup>5649</sup>	2854 <sup>2835</sup>	7308 <sup>7275</sup>	3563 <sup>36611</sup>
460	150	5486	2975 <sup>2979</sup>	9834 <sup>9859</sup>	8092
520	"	5472 <sup>5479</sup>	2983 <sup>2979</sup>	9881 <sup>9859</sup>	8384 <sup>008238</sup>
490	120	5474 <sup>5491</sup>	3019 <sup>3024</sup>	1179 <sup>1182</sup>	1692 <sup>01666</sup>
550	"	5507 <sup>5491</sup>	3029 <sup>3024</sup>	1184 <sup>1182</sup>	1669 <sup>01666</sup>
260	90	6202 <sup>6186</sup>	3019 <sup>3017</sup>	1382	3408 <sup>03313</sup>
320	"	6170 <sup>6186</sup>	3015 <sup>3017</sup>	1368 <sup>1375</sup>	3219
220	50	6461 <sup>6490</sup>	3041 <sup>3049</sup>	30419	6597 <sup>06682</sup>
280	"	6518	3057	3596	6767 <sup>06682</sup>
180	100	7106 <sup>7082</sup>	3063 <sup>3063</sup>	1308 <sup>1308</sup>	2637 <sup>02624</sup>
240	"	7063 <sup>7082</sup>	3062 <sup>3063</sup>	1308 <sup>1308</sup>	2611 <sup>02624</sup>
100	140	8350 <sup>8327</sup>	2942 <sup>2920</sup>	1048 <sup>1045</sup>	1053 <sup>01056</sup>
100	"	8304 <sup>8327</sup>	2898 <sup>2920</sup>	1041 <sup>1045</sup>	1059 <sup>01056</sup>
50	180	8984 <sup>8997</sup>	2810 <sup>2826</sup>	7573 <sup>7594</sup>	4369 <sup>004253</sup>
110	"	9009	2841 <sup>2826</sup>	7615 <sup>7594</sup>	4137
50	-10	9609	2791	5464 <sup>5495</sup>	2451 <sup>02414</sup>
"	"	9572 <sup>9589</sup>	2763 <sup>2777</sup>	5487 <sup>5495</sup>	2377

Exp. 47-B

3/18/60 Check on Normalizer

	I/N	II/N	III/N	<del>IV/N</del>
20			9055	
2.0m	5638	3193	<del>3193</del>	
	5612	3181	9025	
	5605	3186	9016	
	5532	3156	8940	
	5531	3163	8937	
	5569	3132	8965	
	5573 <sup>40</sup>	3089 <sup>x</sup>	8927	
	5632 <sup>7</sup>	3035 <sup>10</sup>	9015	
	5599	3042	9019	
	5604	3023	8986	
2	5585	3020	9009	
	5556	3081	8997	
	5538	3058	8926	

3/18/60

Exp. 47-A

171

The data in exp. 47 shows some inconsistencies when plotted, namely in that repeat points tend to fall below 1st points. To check on whether or not normalizer (power) has drifted since 3/16/60 counts in Regs II, III + IV are to be taken at rotation position of  $70^{\circ}$  and lift position of 7.00, to be compared to ratios in Exp. 46

	I	N	II	III	IV
$\frac{10}{PM}$	82189	145758	465430	131990	
	88191	157136	499890	141830	
	90334	161154	513450	145300	
	90301	163231	515060	145980	
	90058	162802	514970	145530	
	90706	162852	510140	146000	
	91498	164168	507220	146570	
	92095	163478	496290	147390	
	91947	164205	499560	148060	
	92787	165581	500550	148800	
	92861	166241	502050	149770	
	92494	166452	512960	149770	
$\frac{42}{2 PM}$	93413	168669	515920	150560	

From above counts, Reg II is different from corresponding counts in Exp. 46 (~9%) but Reg III counts essentially agree. Reg I does not agree because of change of PDL.

172

3/17/60 3<sup>30</sup> PM

A check of the operation of Reg. I counter mechanically after above exp. showed counter to drag on guide and thereby be displaced. This could account for the scatter in the data in Reg I. Guide has been removed.

3/21/60

Exp. 47-B

Repeat of cd covered BF<sub>3</sub> Radial traverse  
Reg J counter in center of 445

		I	N	II	III	IV
Reg J	Rot					
509	40	82864	152784	535580	274680	12660
"	"	76839	143460	503480	252720	11740
"	"	74090	141044	491490	247610	11440
460	80	119889	229774	772040	358340	9730
"	"	123067	234403	780420	366710	9950
420	120	167440	326579	1062640	411170	5800
"	"	160163	315199	102004	393410	5550
380	140	186071	361759	1148500	395050	3820
"	"	181500	353175	1117190	384930	3810
320	160	206587	387310	1197430	366650	2700
"	"	200580	378984	1162530	355960	2560
280	170	217246	389443	1180420	336840	2150
"	"	222715	404312	1216400	349340	2190
240	180	239883	410150	1224060	331200	1850
"	"	241981	411444	1224350	332150	1940
200	200	251137	407140	1181010	TTT0	1070
"	"	245191	398409	1161630	268160	1220
"	"	249746	405461	1173810	271340	1150
160	220	267490	407808	1144860	230790	900
"	"	276432	418862	1174770	238480	920
120	240	337753	485191	1326210	237270	810
"	"	345864	491995	1326470	241040	800

172

174

3/17/60

Reg	Lot	I	N	II	III	IV
80	260	361874	484996	1276250	202700	650
"	"	360206	485904	1290700	202990	620
40	280	358018	456514	1176000	—	—
"	"	358224	459814	1203060	168420	490
"	"	358984	457840	1179060	168350	—
0.0	300	313968	385050	983460	125380	370
"	"	307825	381348	1000750	124410	350
-50	320	312512	373024	971110	113840	—
"	"	309333	368785	961370	112360	300
20	260	147437	216885	609670	87410	250
"	"	148287	192284	547180	77040	240
80	220	145917	204959	608230	111890	440
"	"	142713	200409	592690	109460	400
160	180	139740	223412	684190	169920	900
"	"	140539	223218	687190	181470	910
240	160	114399	207508	656690	190470	1360
"	"	116073	210757	664010	191600	1410
320	140	101847	204753	660610	217030	2180
"	"	101773	204856	655600	214380	2070
380	120	79214	165747	537830	197620	2680
"	"	74459	156405	504020	186170	2450
440	80	128777	276679	827400	404200	11490
"	"	136257	289928	859050	424180	11890
500	40	100169	209898	620100	344710	16300
"	"	100904	210991	624500	346110	16780

Exp. 47-B

	Reg I	Rot	I/N	II/N	III/N	IV/N	
	509	40	5423	3505	1797	8286	
	570	"	5356 <sup>534x</sup>	3509 <sup>3499</sup>	1761 <sup>171</sup>	8183 <sup>8193</sup>	
	"	"	5253	3484 <sup>3499</sup>	1755 <sup>171</sup>	8111	
70	520	460	80	5217 <sup>5234</sup>	3359 <sup>3344</sup>	1557 <sup>1560</sup>	4234 <sup>4239</sup>
0	"	"	"	5250 <sup>5234</sup>	3329 <sup>3344</sup>	1564 <sup>1560</sup>	4245 <sup>4239</sup>
	480	420	120	5127 <sup>5104</sup>	3254 <sup>3245</sup>	1258 <sup>1253</sup>	1776 <sup>1768</sup>
	"	"	"	5081 <sup>5104</sup>	3236 <sup>3245</sup>	1248 <sup>1253</sup>	1760 <sup>1768</sup>
20	1440	380	140	5145 <sup>5158</sup>	3175 <sup>3169</sup>	1092 <sup>1091</sup>	1056 <sup>1068</sup>
70	"	"	"	5130 <sup>5158</sup>	3163 <sup>3169</sup>	1090 <sup>1091</sup>	1079 <sup>1068</sup>
0	380	320	160	5333 <sup>5333</sup>	3090 <sup>3079</sup>	9465 <sup>9428</sup>	6971 <sup>6962</sup>
0	"	"	"	5293 <sup>5333</sup>	3067 <sup>3079</sup>	9392 <sup>9428</sup>	675 <sup>6962</sup>
0	340	280	170	5578 <sup>5543</sup>	3031 <sup>3020</sup>	8648 <sup>8644</sup>	5520 <sup>5468</sup>
0	"	"	"	5508 <sup>5543</sup>	3008 <sup>3020</sup>	8639 <sup>8644</sup>	5416 <sup>5468</sup>
0	300	240	180	5845 <sup>5863</sup>	2984 <sup>2977</sup>	8075 <sup>8074</sup>	4510 <sup>4510</sup>
0	"	"	"	5881 <sup>5863</sup>	2970 <sup>2977</sup>	8072 <sup>8074</sup>	4710 <sup>4610</sup>
60	260	200	200	6169 <sup>6160</sup>	2900	—	287
10	"	"	"	6154 <sup>6160</sup>	2915 <sup>2903</sup>	6730	306 <sup>292</sup>
80	"	"	"	6159	2894 <sup>2903</sup>	6692 <sup>6711</sup>	284
070	220	160	220	6559 <sup>6564</sup>	2807 <sup>2806</sup>	5659 <sup>5676</sup>	221 <sup>2203</sup>
	"	"	"	6574	2804 <sup>2806</sup>	5693 <sup>5676</sup>	2196 <sup>2203</sup>
680	180	120	240	6961 <sup>6975</sup>	2732	4890	1669
450	"	"	"	7029 <sup>6975</sup>	2696 <sup>2714</sup>	4898 <sup>4894</sup>	1626 <sup>1647</sup>
1490	140	80	260	7461 <sup>7437</sup>	2631	4179	1276
1890	"	"	"	7413 <sup>7437</sup>	2656 <sup>2643</sup>	4177 <sup>4178</sup>	1275 <sup>1276</sup>
6300	100	40	280	7790	2575	—	—
	"	"	"	7790	2616 <sup>2648</sup>	3662 <sup>3699</sup>	1065
6780	"	"	"	7841 <sup>7807</sup>	2575 <sup>2589</sup>	3677 <sup>3699</sup>	—
	60	0.0	300	8153	2554	3255 <sup>3299</sup>	—9.67
	"	"	"	8071 <sup>8112</sup>	2624 <sup>2589</sup>	3262 <sup>3299</sup>	—9.17 <sup>80939</sup>
	10	50	320	8378	2604 <sup>2606</sup>	3050	—
	"	"	"	8387 <sup>8382</sup>	2607 <sup>2606</sup>	3046 <sup>3048</sup>	—00813

omit because of high

# 47 B

	Reg f	Rot	I/N	II/N	III/N	IV/N
80	20	260	7719	2811 <sup>2828</sup>	4030	115
"	"	"	7711 <sup>7715</sup>	2845	4006 <sup>4018</sup>	125 <sup>10120</sup>
140	80	220	7118	2907	5459	214
"	"	"	7120 <sup>7119</sup>	2957 <sup>2962</sup>	5461 <sup>5460</sup>	199 <sup>207</sup>
220	160	180	6255 <sup>6275</sup>	3062	7605	8403
"	"	"	6296 <sup>6275</sup>	3078 <sup>3070</sup>	8131 <sup>7868</sup>	408 <sup>406</sup>
300	240	160	5513	3145	9180	4655
"	"	"	5506 <sup>5510</sup>	3149 <sup>3157</sup>	9089 <sup>9134</sup>	669 <sup>666</sup>
380	320	140	4974	3226	1059	3106
"	"	"	4968 <sup>4971</sup>	3200 <sup>3213</sup>	1047 <sup>105</sup>	101 <sup>1010</sup>
440	380	120	4780	3245	1192	161
"	"	"	4760 <sup>4770</sup>	3222 <sup>3234</sup>	1190 <sup>1191</sup>	156 <sup>0159</sup>
500	440	80	4654	2990	1460	415
"	"	"	4699 <sup>4676</sup>	2963 <sup>2977</sup>	1463 <sup>1462</sup>	410 <sup>0413</sup>
560	500	40	4770	2954	1642	1641
"	"	"	4782 <sup>4776</sup>	2959 <sup>2957</sup>	1640 <sup>1641</sup>	0795 <sup>086</sup>



47-C

dist = 7.00 ; Rat. = 160  
Reg I = 445

I/N	II/N	III/N
5015	344	937
502	342	934
492	343	929
494	340	930
491	337	924
492	336	923
490	331	915
490	331	913
4906	331	910
484	329	908
484	328	903
486	330	914
489	327	911
486	322	911
484	317	911
492	317	913
489	318	910
478	323	905
480	324	898
478	326	906
480	319	904
483	318	898
480	318	905
478	298	904
479	318	904

445

4

4

445

4

3/21/60

47-C

The previous data (47-B) is still not good. To see if counts-rate has drift at start up or over period ~30-45 min and check count rate of kgz at center (which has been checked physically) with previous data

	Rot I	N	II	III	Rot Pos
3:50 PM	16072771	145135	500020	135980	Subsys = 160
"	74839	149003	510840	139240	kgz centered ± 45
3:53	74980	152184	522660	141470	
"	76389	154594	527040	143790	
4:54	75035	152743	515880	141230	
"	74498	151187	507420	139570	
"	73738	150208	497440	137460	
"	72648	148187	490810	135330	
4:03	71981	146694	485640	133570	
4:07 PM	71175	147164	485140	133710	
"	71527	147687	484870	133530	
"	70968	145837	481640	133430	
4:11	71423	146061	478250	133050	
"	71080	146232	470500	133200	
"	70946	146686	466140	133720	
4:15	72210	146838	465160	134020	
"	72078	147279	469280	134080	
4:19	71242	148895	482250	134780	
"	71713	149304	486930	134190	
"	72054	150477	491590	136540	
"	72072	150109	478950	135730	
"	73335	151689	482440	136340	
4:21 PM	71010	147718	470480	133870	
"	71909	150287	4480090	135970	
4:32	73204	152757	485970	138100	

kgz moved out to 280 cm back to 445 to check reproducibility

3/22/

Purpose: A further attempt to determine possible drifts in counters, especially Reg I. Reg I counter is in center of region (elevation = 445, lift = 700). Rot. position = 160

	I	N	II	III	
<sup>33</sup> 10 AM	167127	333932	1145640	322200	850
	165527	336091	1146690	324130	
	161130	331997	1117660	318400	
	156071	325814	1082990	308360	
<sup>41</sup> 10	158642	332390	1096000	311660	
	158567	335850	1098330	313540	
	159737	340133	1101610	316580	
<sup>46</sup> 10 AM	161084	342338	1100710	316840	
	159381	339846	1092100	313810	
<sup>49</sup> 10	157730	338036	1079880	310530	
	155302	334142	1067890	307100	
	152918	329096	1062220	305390	
<sup>59</sup> 10	150884	326398	1041560	298220	
	148436	321768	1026330	293140	
	146902	317487	1010300	290790	
	142551	310669	992530	282080	
<sup>01</sup> 11	139794	304927	976980	277250	
	136906	<del>301084</del> <del>103086</del>	964600	272380	
	137974	301330	966480	275660	
	139820	304981	969440	276130	
	141816	309384	975490	279900	
<sup>11</sup> 11	143109	313535	991260	284230	

41-D

I/N

II/N

III/N

IV

10<sup>33</sup>

500

343

964

493

341

964

485

336

959

479

332

946

10<sup>41</sup>

477

329

937

472

326

933

469

324

930

10<sup>46</sup>

470

321

925

469

321

923

10<sup>49</sup>

466

319

918

464

319

919

464

322

927

10<sup>59</sup>

462

319

913

461

318

910

462

318

915

458

319

908

10<sup>61</sup>

458

321

909

454

320

904

457

321

915

458

318

905

458

315

904

11<sup>11</sup>

456

316

906

459

316

912

455

313

907

11<sup>15</sup>

455

312

910

455

310

904

458

312

913

459

312

918

456

312

917

455

313

914

455

312

910



3/22/60

1<sup>30</sup>

Purpose: ~~After~~ To determine ratio of count rates of Reg I counter bare after discriminator change to count rate before hence Cd-cover removed from counter

Note: When Cd-cover was removed several drops of H<sub>2</sub>O were found to have ~~and~~ gotten under cover

Reg I counter centered in Reg I

	I	N	I/N
<u>1<sup>45</sup></u> PM	2007613	43333	4632
	1324898	28710	4614
	1310746	28780	4554
	1306711	28730	4548
<u>1<sup>52</sup></u>	1285768	27905	4607
	1268341	27991	4530
	1242703	27580	4506
	1261288	28161	4479
	1257269	28192	4460
	1256262	28242	4448
<u>2<sup>01</sup></u> PM	1243002	28025	4434
	1237014	27508	4496
	1227880	27319	4496
<u>2<sup>06</sup></u> PM	1219801	27339	4461
	1214565	26885	4517
	1208221	26855	4490
	1205955	26903	4482
	1204274	27012	4457
	1203418	27023	4453

$$\frac{80.17}{4472} = 1.79$$

2008 = 4472

3/22/60

3<sup>00</sup>  
PM

Purpose: To determine effect of water under cd-cover of Reg. I counter. Counter was dried and cd-put back on, then counter was put back in center of Reg. I.

3<sup>08</sup>  
PM

I	N	I/N
79011	173578	4551
74014	161995	4569
71029	158694	4475
71033	155751	4560
69138	154048	4488
70973	157699	4500
71926	161839	4444
71729	164096	4371
72088	165491	4356
70877	161869	4378
70067	160368	4368
70964	162010	4380
71825	165175	4347
71611	163548	4378
71370	164021	4351
71661	165288	4336
72154	166986	4321
72332	167589	4316
72915	167663	4348
74528	173844	4304
75060	173503	4326
75511	175153	4311
75354	176703	4264

3<sup>15</sup>  
PM3<sup>30</sup>  
PM

180

3/22/60

3 <sup>54</sup>/<sub>pm</sub>

4 <sup>00</sup>/<sub>pm</sub>

I	N	I/N
78180	181423	4309
79238	183098	4327
78278	180407	4339
76370	176993	4314
74118	170886	4337
71965	165495	4348
71911	167684	4288

1  
2  
3  
4  
=

]



3/23/60 Note: Upon removal of counter #3 (Reg II) a small amount of water was found in bottom of cd cover (~ 2-3 drops). Exact effect of this on experiments not known.

On removal of cd counter in reg II was dry. However, Reg III counter had about 2 drops of  $H_2O$  inside the cd.

182  
3-23-60

Expt 50

Preliminary Bare ended Expt. -  
Removed Top and bottom reflector.  
Also removed all counter  
Added about 3 l of sample residue  
to inventory at a 92 gm  $U^{235}$ /l. &  
mixed.

Critical with fuel at 23.54 &  
 $D_{20}$  at 80.6.

It was found that fuel pump stopped  
adding at 23.54. After dumping the  
 $D_{20}$  it was found that we were out  
of solution.

3-24-60  
9 AM

Added 4.5 l. fuel at a sp. gr. of 1.2305  
to system and mixed.

Rechecked Fuel and  $D_{20}$  zeros:

$D_{20}$  - 56.10  
Fuel - 0.0

3-24-60

Expt. 51

Critical Expt. with Both ends  
bare.

at Crit:

	Reg I	Reg II	Reg III	Reg IV
Height	24.5"	24.04"	24.02"	24.5"

Dumped Fuel

Expt. 51A Repeat after  
adjusting Reg I & III heights:

Out at

	Reg I	Reg II	Reg III	Reg IV
Height:	24.00"	24.10	24.10"	24.10"

Temps	11.34 28.3°	1.114 27.9	1.140 28.5	11.53 28.9
-------	----------------	---------------	---------------	---------------

Expt 51 B

3-24-60

Repeat for radiating gold wire  
out at

Reg I	Reg II	Reg III	Reg IV
24.10	24.03	24.10	24.10
27.8°	27.4	27.9	28.5

IC - ~~at~~ at 10 Time 10 min  
Finished at 3.39 PM

184

3/24/60

Fuel Sample taken before last exp. (51-B)

# 11-A, to go to cooper

# 11-B, Reg. # 593074

# 11-C, hold back for possible check

3/29/60 Sample 11-C sent for  $D/H$  analysis, see p. 188

3/25/60

## Exp 52

Exposure of manganese and Au wire contained in small stainless steel tubes. Wires were ~3 ft. long and placed parallel to and  $\frac{1}{2}$ " from the center-line of the assembly.

Wires were irradiated for 30 min at power level of 10 (from chart) on 1-C4. Water ht. in reg. I was 24.1 and ~~24.2~~ 24.2 in III.

## Exp. 53

Zero of fuel ~~sealyn~~ checked - gerson sealyn is at zero.  $D_2O = 56.1$  on sealyn at  $D_2O$  zero. Reg. I ht = 24.1"

Fuel ht at crit = 24.09. Reg II water is  $\sim \frac{1}{2}$ " too high - to be lowered.

## 53-B

~~Removed~~ lowered  $H_2O$  in II to 24.1. Reg I + II are 24.1.

Fuel = 24.08 at crit

150

Reg I = 24.2 °C ; Reg II = 23.1 ; Reg III = 23.2  
Slab = 23.2 with soln in it.

3/25/60 To make qualitative check on temp. coefficient for HFIR without top and bottom reflector. Reg II thermocouple moved to Reg I to give temp check.

3 <sup>40</sup>  
 $D_2O$  soln = 80.21, blade out  
 Fuel soln = 24.04 just crit

Temp

# 12	# 14	# 15	# 13
977 (986)	no reading	928	934 } <sup>no soln</sup> in slab
24.5°			

3 <sup>45</sup> PM

~ 6" fuel drained then ~~enter~~ Reg I water removed and hotter water added.  $D_2O$  and blade same

Temp

time	# 12	# 15	13
3 <sup>50</sup>	1,350 33.7°C	935	
4 <sup>08</sup>	1,21	97	935 } <sup>no solution</sup> in slab
4 <sup>15</sup>	1,16	98	
4 <sup>20</sup>	1,15	98	
4 <sup>25</sup>	114	98	98

4 <sup>25</sup> PM Shut down

Note: System essentially level at ~ 4 <sup>05</sup> at Fuel  $\approx$  23.9+. Reactivity decreased with time as evidenced by repeated small additions of fuel to stay crit. At 4 <sup>25</sup> system was approx crit but had small drift down. Fuel hit at 4 <sup>25</sup> was 24.06. Thermocouple in II did not work. Over all temp coefficient (direction) therefore doubtful from above data, but Reg I alone seems to have positive coefficient

3/28/60 Entire inventory of  $D_2O$  fed into <sup>Bar-</sup> reactor. -  
 selwyn reading = 83.8  $\approx$  27.7" net

Approx. inventory of  $D_2O$ :

$$A = \pi (10^2 - 8^2) = 603 \text{ in}^2$$

$$\text{Vol} = 603 \times 27.7 = 16,700 \text{ in}^3$$

$$\text{"} = 16,700 \times 0.01639 = 273.8 \text{ l in reactor}$$

Including D. Vol. Total inventory  $\approx$  280 l

$\approx$  92 kg of  $D_2O$  removed from manifold

$\approx$  83.6 l

4<sup>00</sup> PM Removed from manifold { @ 92.6 g/l }

G 20.51                      20.37                      20.44

T 2.79                        2.75                        2.69

i.e. 43.3 liters removed ; 31.2 @ 92.6 remains

280.0

$$= \frac{83.6}{9.64} \rightarrow \text{liters } D_2O \text{ left}$$

177.8 l. required for 18" in reactor

time

3/29/60 To check on reason why ~~D<sub>2</sub>O~~ D/H ratio  
for the fuel was lower in the last sample,  
after small fuel addition at same concentration  
for reflector savings experiment, a new sample  
was taken from a 15 liter bottle which  
had been removed from manifold.

Sample # 12-A     D<sub>2</sub> 190.0  
   20.2

also to be sent Sample # 11-C, ser. p. 184

Two samples were taken from D<sub>2</sub>O manifold, and  
~~Sample~~ <sup>0.5</sup> gm of Na<sub>2</sub>B<sub>4</sub>O<sub>7</sub> was dissolved in  
sample # 4-D and Sample 3-D was sent as is.

Sample # 4-D

G 158.7, including borats

T 20.2

Borats 0.5



## EXP. 54 A

[beginning Boron poisoning of Reg III - no Boron this experiment]

3/30/60 concentration  $\sim 115 \mu\text{m}/\text{L}$ ; Bottom and top reflectors put back in $\text{D}_2\text{O}$  selyn = 80

Crit. selyn = 16.145

super	16.15
act @	16.14

#2 Bottle

4.50

2.48

2.02

2.02

4.00

4.00

 $\times 40 = 19.99 \text{ gm salt}$ added to  $\text{D}_2\text{O}$  system

stirring by recirculation

16.98

16.15

---

18.3

## EXPT 54 B

 $\text{D}_2\text{O}$  selyn 80.09

out. fuel selyn 16.98

## EXPT 54 C

#2 Bottle Drained to 1.34 kg.

.44

out. left  $\rightarrow$  .90

4.04

.90

---

3.14

3.14	$\times 40 = 31.1 \text{ gm salt}$
404	in $\text{D}_2\text{O}$

 $\text{D}_2\text{O} = 79.85$ 

out fuel wt = 17.47

Added remainder of contents of Bottle #2 to  $\text{D}_2\text{O}$  system.

54 D

After mixing with ~ 40 gm salt  
in D<sub>2</sub>O system.

D<sub>2</sub>O - 79.91

Cout fuel ht. - 19.13"

Added to fuel in slab ~ 4 l at 1229<sup>m</sup>  
V/l & mixed for ~ 1/2 h.

54 E

D<sub>2</sub>O - 81.23

Cout fuel ht 19.41 "

Since the effect of fuel addition was  
negative, the warming up of the fuel  
while mixing probably more than off-  
set the small increase in fuel conc.

54 F

3-30-60

Repeat as check on temp &  
mixing

D<sub>2</sub>O - 80.7

Cout fuel ht. 19.27

Added to reactor ~ 230 gm soln at  
~ 340 gm/l, or ~ 50 gm U and mixed

54 G

D<sub>2</sub>O - 80.7

Cout fuel ht. 19.01

3-30-60

191

2 Batches of dried  $\text{Na}_2\text{B}_4\text{O}_7$  in 1 gal. polyethylene bottles:

#1 gr. 4.28 kg  
T .40  
net 3.88 kg  
contains 40 gm  
dry  $\text{Na}_2\text{B}_4\text{O}_7$

#2 gr. 4.56  
T .44  
net 4.06 kg  
contains 40 gm  $\text{Na}_2\text{B}_4\text{O}_7$

Added ~ 300 cm<sup>3</sup> at 340 gm/l & mixed

54 H

D<sub>20</sub> 80.49

crit fuel ht. 18.94

Added ~ 1 l at ~ 340 gm/l & mixed


Thermocouple: #12 - Reg I; #15 - Reg II; #14 - Reg III

54 +

D<sub>20</sub> 80.83


crit fuel ht. 17.41

3/31/60 235 Chambers put back in reactor




Reg II

$$\begin{array}{r}
 4.781 \\
 - .36 \\
 \hline
 4.421 \\
 - 2.210 \\
 \hline
 \end{array}$$



Reg III



Reg IV

4-1-60

Expt 55

Installed fission counter - Reg I - IV

D<sub>2</sub>O - 8147

crit fuel 17.88

Counter left at 7.00 "

Reg Ex Pos.	Rat. Pos	Reg I	N	Reg II	Reg III	Reg IV
513	160	550,037	420,730	52,760	80160	24150
"	"	552,649	419,988	52,050	78840	23760
"	"	561,486	425,946	52,760	78620	23750
"	"	564,890	430,093	53,300	80110	24330
"	"	572,082	434,415	53,850	84060	24530
"	"	579,227	441,354	54,630	82960	24560
"	"	587,044	448,656	55,530	82140	24960
"	"	608,402	467,064	57,980	85270	26270

4-1-60

Fuel Sample #13A to Cooper 13B to Hanna

Net wt 110.35 gm

94.1 at. % D

Sample of D<sub>2</sub>O for Barium content sent to  
Lang at X610 Bldg 3550:

#6-D-1  $\frac{134.0}{20.3}$   
net 113.7 gm.

Adjusted Counter in Reg III

\* Reg I zero zero = 0.04

4/1/60

Exp. 56

195

Lift 7.44"

Rot.	Reg. Z	I	N	II	III	IV
Pos. 0.0	6	140787	273531	98220	35440	61020
" 2 <sup>00</sup> pm	"	149548	288194	103290	37150	63380
"	"	151875	297401	105640	38120	65540
"	"	154443	304600	108560	38830	67020
40	66	241208	310087	89510	46780	67660
"	"	236981	306107	87350	46890	66430
"	"	235271	305142	87350	46780	66160
80 <sup>15</sup>	106	269168	299813	54530	54710	49390
"	"	325332	366727	66830	66750	61230
100	146	393459	399509	71430	73490	66120
" 2 <sup>25</sup>	"	407660	411346	74340	75920	68710
120	206	382534	353652	49140	68990	37800
"	"	371933	343693	47340	67330	36580
140 <sup>33</sup>	246	387790	346747	44260	67760	27740
"	"	390068	347108	44440	68800	27680
160	306	402013	344745	42510	67630	19290
"	"	386174	331315	40680	64290	18420
180 <sup>47</sup>	346	403352	340052	41670	64480	13760
"	"	407461	343554	41220	64560	13840
200	406	417688	344909	42880	63160	9110
"	"	401420	333801	41640	61310	8740
220	456	396285	328241	42550	57320	5770
" 2 <sup>54</sup>	"	394378	326427	42240	56780	5810
240	486	395309	327206	45000	55330	4160
"	"	396429	329432	45030	55600	4270
260	526	397482	329648	49290	53760	3030
"	"	398141	328482	49710	53710	3060
300 <sup>1</sup>	538	389276	320181	57850	49980	1680
"	"	386265	317301	56960	49000	1620

1 196 <sup>4/1/60</sup>

Rot	Rq I	I	N	II	III	IV	
360	506	399935	327880	66380	50500	990	
"	<sup>13</sup> 3	"	400868	329622	66940	50740	990
320	466	396536	325578	<del>1662410</del>	49940	1330	
"	"	391673	321853	62040	49180	1330	
280	<sup>23</sup> <del>34</del> 426	387726	321298	52160	51480	2200	
"	"	400043	328928	53680	52050	2230	
250	386	405089	333737	47060	55490	3750	
"	"	405750	334858	48010	55890	—	
"	"	403806	333401	<del>474102</del> <del>45420</del>	12060 <sup>2</sup>	3400	
220	326	393151	327677	42430	56760	5790	
"	<sup>40</sup> 3	"	388402	324256	41690	56190	5800
200	286	357720	305254	37490	55320	8160	
"	"	354985	301466	36710	54680	7830	
180	246	335289	294715	35190	54610	10860	
"	<sup>10</sup> 3	"	333000	294454	35140	54570	10930
160	206	308379	283644	34560	53540	15260	
"	"	306362	282935	34620	53420	14830	
140	156	269070	268878	33870	51420	20350	
"	<sup>20</sup> 4	"	262781	262113	33170	50170	20170
120	106	211892	238864	32950	45460	25590	
"	"	202915	230065	31650	43590	24460	
100	66	161253	213071	32270	39740	27320	
"	"	169417	225933	34420	41600	29480	
50	36	131946	208582	53870	32100	42710	
"	"	128368	202558	51720	30830	41250	
8.0	<sup>20</sup> <del>4</del> pw 6	100681	203252	70530	25340	43490	
"	"	108457	218946	76180	26990	47390	
"	"	111407	226030	78010	27860	48340	

Exp. 56  $\frac{I}{N}$   $\frac{II}{N}$   $\frac{III}{N}$

Lat	Req	$\frac{I}{N}$	$\frac{II}{N}$	$\frac{III}{N}$	$\frac{IV}{N}$
41/60		x0.8264	x0.5453	x1.273	x0.4870
0,0	6 <sup>2</sup>	.5147	.3591	.1295	.2231
		.5187 <sup>1</sup>	.3583 <sup>2</sup>	.1289 <sup>4</sup>	.2199 <sup>2</sup>
		.5106 <sup>1/2</sup>	.3552 <sup>3</sup>	.1281 <sup>2</sup>	.2203 <sup>2</sup>
		.5070	.3564	.1274	.2200
40	66	.7770	.2886	.1508	.2181
"	"	.7739 <sup>7740</sup>	.2853 <sup>86</sup>	.1532 <sup>2</sup>	.2170
"	"	.7710	.2862	.1533	.2168
80	106	.8975	.1818	.1804	.1647
"	"	.8871 <sup>8963</sup>	.1822 <sup>120</sup>	.1820 <sup>12</sup>	.1669 <sup>1658</sup>
100	146	.9848	.1787	.1839	.1655
"	"	.9911 <sup>9879</sup>	.1807 <sup>1797</sup>	.1845 <sup>1842</sup>	.1670 <sup>1663</sup>
120	206	.1081	.1389	.1951	.1068
"	"	.1082 <sup>1092</sup>	.1377 <sup>1383</sup>	.1958 <sup>1955</sup>	.1064 <sup>1066</sup>
140	246	.1118	.1276	.1960	.08000
"	"	.1123 <sup>1121</sup>	.1280 <sup>1278</sup>	.1982 <sup>1971</sup>	.07974 <sup>07987</sup>
160	306	.1166	.1233	.1961	.05596
"	"	.1165 <sup>1164</sup>	.1227 <sup>1230</sup>	.1940 <sup>1951</sup>	.05559 <sup>05577</sup>
180	346	.1185	.1225	.1895	.04045
"	"	.1186 <sup>1186</sup>	.1199 <sup>1212</sup>	.1879 <sup>1887</sup>	.04028 <sup>04037</sup>
200	406	.1211	.1243	.1831	.02641
"	"	.1202 <sup>1207</sup>	.1247 <sup>1245</sup>	.1836 <sup>1824</sup>	.02618 <sup>02630</sup>
220	456	.1207	.1296	.1746	.01758
"	"	.1208 <sup>1208</sup>	.1294 <sup>1295</sup>	.1739 <sup>1743</sup>	.01780 <sup>01769</sup>
220	486	.1208	.1375	.1691	.01271
"	"	.1203 <sup>1200</sup>	.1367 <sup>1371</sup>	.1687 <sup>1689</sup>	.01296 <sup>01284</sup>
260	526	.1206	.1495	.1631	.009192
"	"	.1211 <sup>1209</sup>	.1573 <sup>1504</sup>	.1635 <sup>16</sup>	.009315 <sup>009253</sup>
300	538	.1215	.1806	.1560	.005246
"	"	.1217 <sup>1216</sup>	.1795 <sup>1801</sup>	.1544 <sup>153</sup>	.005105 <sup>005175</sup>



Exp. 56

Rot	Reg F	I/N	O/N	W/N	W/N
360	506	1.219	.2024	.1540	.00302
"	"	1216.1219	.2030	1539.1540	.00300
320	466	1.217	.1916	1533	.00408
"	"	1216.1217	.1927	1528.1531	.004133
380	426	1.206	.1623	1602	.006847
"	"	1216.1211	.1632	1582.1592	.00678
250	386	1.213	.1410	1662	.01123
"	"	1.212	.1434	1669	—
"	"	1.211	.1422	—	.01079
220	326	1.199	.1294	1732	.01766
"	"	1.198	.1285	1733	.01789
200	286	1.172	.1228	1812	.02673
"	"	1.177	.1217	1813	.02597
180	246	1.137	.1194	1853	.0368
"	"	1.131	.1193	1853	.0371
160	206	1.087	.1218	1887	.0538
"	"	1.083	.1223	1888	.0524
140	156	1.001	.1260	1912	.07570
"	"	1.002	.1265	1914	.07695
120	106	.8870	.1379	1903	.1071
"	"	.8817	.1375	1894	.1063
100	66	.7566	.1514	1864	.1282
"	"	.7498	.1523	1841	.1305
50	36	.6320	.2582	1538	.2047
"	"	.6330	.2552	1521	.2036
0.0	6	.4952	.3469	1246	.2139
"	"	.4956	.3480	1232	.2164
"	"	.4920	.3451	1232	.2139

4/1/60

	Temp		
4 <sup>00</sup> PM	Reg I (12)	Reg II (15)	Reg IV
	959 (24.0°C)	950 (23.7°C)	996 (25.8)

4/4/60

Check of zero and center selsyn readings  
in Reg I after exp. (56)

Selsyn = 2 at zero

" = 511 at center

198

4/4/60

56-A

Purpose: To check on count-rates of all four  
counters when #1 is at 511 and Rot pos.

is 160 with lift at 7.44 & 7.04

Crit → 1<sup>st</sup> lift 7.44; D<sub>2</sub>O Selsyn = 80.0; Blade out; Fuel Selsyn = 18.11

	I	N	II	III	IV
3 <sup>48</sup> pm	285854	228517	29800	46360	13730
	289136	233128	29980	46750	13920
	290884	234741	30240	47210	13760
	288102	233328	29860	46820	13800
	287895	233996	29570	49330	13700
	288294	235350	29640	46800	13530
	291234	235402	29340	46010	13670
	289521	236583	29620	46610	13590
	289725	237919	29870	47320	13680
	292181	241223	29910	46690	13830
	296949	243234	30520	47670	14190
	297405	245816	30730	47970	14170
Lift changed to 7.04					
4 <sup>40</sup> pm	294070	245446	30390	48310	14380
	296574	247382	30800	48790	14490
	299284	249296	31110	48900	14590
	303065	254878	31150	49840	14780
	308884	258898	31760	50490	14990
	308136	256680	31970	50560	14840
	295388	246708	30590	48440	14330
	287061	241101	29960	46940	13840
4 <sup>28</sup>	Shut Down				

8.11

Exp. 54-A

I/N	II/N	III/N	IV/N
-----	------	-------	------

1250	1304		
1240	1286		
1239	1288		
1234	1279		
1238	1263		
1224	1259		
1237	1246		
1223	1251		
1217	1251		
1211	1240		
1220	1254		
1209	1250		

lift changed to 7.04

1197	1237	1967	5855
1198	1244	1972	5856
1200	1247	1961	5852
1190	1222	1955	5798
1193	1226	1950	5790
1200	1246	1969	5781
1197	1239	1963	5808
1191	1242	1946	5740

4-5-60

EXP No 57

## VOID COEFFICIENT MEASUREMENT

$\frac{1}{2}$ " Alum Tube OD  $\overset{.028}{.035}$  wall suspended  
 From Safety Drive. When "Down", Tip is  $1\frac{3}{8}$ " From  
 Bottom - Up limit switch set so that it moves  
 9 in. Total Travel. - No Selsyn on Drive.

9<sup>45</sup> AM Inst. OK.

10<sup>23</sup> AM Exit Ht with  $\frac{1}{2}$ " OD Al tube inserted to  
 lower limit switch  $1\frac{3}{8}$ " Above Bottom

D<sub>2</sub>O - 80.40" Soln Ht 17.68

10<sup>30</sup> Raise Void 9" slight neg period  
 reestablish crit at same power as above  
 in preparation of measuring pos period for  
 the 9" dia of void.

10<sup>31</sup> D<sub>2</sub>O 80.36 Soln Ht 17.99, at this power  
 for  $18 \times 50 = 900 \text{ sec} = 15'$

10<sup>31</sup> Insert void to lower limit - 9" void added.  
 To measure Pos PERIOD. 209.7 SEC

10<sup>44</sup> End of Period Soln Ht 17.97  
 Shut down by Dump Soln.

D<sub>2</sub>O not dumped or drained between 57 & 58

4-5-60

Exp # 58

## Void Coefficient Measurement

1" Al tube OD .035 wall suspended from safety drive. When "down", tip is  $1\frac{3}{8}$ " from bottom. - Up limit switch set so that it moves 9 in. total travel.

2<sup>35</sup> PM start feeding soln

2<sup>49</sup> Level at log N = 0.01 (10<sup>-2</sup>)

2<sup>55</sup>  $D_{20} = 80.24$  Fuel = 17.54 @ Crit.

Raise 1" Void to 9" Much more React involved  
Raise fuel solution to crit again.

3<sup>05</sup> Fuel = 17.59

lower Void - not ~~to~~ limit (must measure at end)

3<sup>07</sup><sup>1/2</sup> Shut down by draining fuel.

Measurement  $5\frac{3}{16}$ " displacement for period 50.7

202

4/6/60

Exp. 259

Run A

6.92 kg of plexiglas <sup>was</sup> placed in center  
 cyl. of HFIR in the form of a 3" dia rod 18" long  
 in the center surrounded by 10 pieces of <sup>1.25"</sup> dia  
 rod 18" long. Remaining space filled with  
 H<sub>2</sub>O. H<sub>2</sub>O also ~8" above as reflector

Throttly down of fuel feed rate

Soln ht = ~~7.48~~ 0.148

feed 1 min, ht = 2.57"

valve closed some

feed 1 min, ht = 4.00"

valve closed more

feed 1 min, ht = 4.74

9 <sup>58</sup>/<sub>AM</sub>

D<sub>2</sub>O = 80.327

Start feeding Solo into system

9 <sup>37</sup>/<sub>AM</sub>

Crit ht = 16.953 TC-4 ~ .01

Soln ht. raised to 16.998 for pos. period

{ system crit ~ 18 min preceding above period }

T = 130.32 sec. P = 7.09 x 10<sup>-4</sup>

10 <sup>55</sup>/<sub>AM</sub>

Drain Solo Down to 9.255" to Remove Small Plastic  
 Rods from Reg I

11 <sup>12</sup>/<sub>AM</sub>

3" dia rod positioned in center of reg. I.

Exp. 59  
R-50

T = 12.11  
12.16

2		0 F
1	93429	F
2		0 F
1	166851	F
2		0 F
1	291203	F
2		0 F
1	512802	F
2		0 F
1	884103	F
2		1 F
1	1481696	F
2		0 F
1	2461140	F
2		0 F
1	3843021	F
2		0 F
1	66505	F

Plastic



4/6/60

Run B

12<sup>50</sup> Crit ht. = 17,395 { "at" crit, for 16.6 min } period too fast  
 Post period ht = 17,451 T = 86.4 sec. see repeat immediately below

1<sup>08</sup> Shut down

Run C Repeat with 3" dia rod in center

1<sup>34</sup> ~ at Crit (Log W = .01)  
 Crit ht = 17,400 [at crit for 16.6 min] K-4 = .01  
 Post period ht = 17,449 : T = 159.6 sec

2<sup>04</sup> Shut down

Run D

Repeat due to "jump" in 10-4 track during last period

3<sup>19</sup> ~ Crit  
 Crit ht = 17,400

Post period ht = 17,450

T = 113.4 sec

3<sup>45</sup> Shut down

Temp Readings

Time	Reg I #10	Reg II #11	Reg III #15	Reg IV #12	
2 <sup>40</sup> PM	.948 mV	23.6	.914 22.8	.920 23.0	.974 24.3
3 <sup>18</sup>	.991 mV	.959	.935	.990	

plastic

204

Exp # 60

H-7-60

Run A

SWS CC

Reg I



Void coefficient continued using polystyrene tubes 18" long,  $\frac{3}{8}$ " ID,  $\frac{1}{16}$ " wall. Rubber stoppers put in top and bottom ends to trap air. 27 tubes were ~~bundled~~ bundled together and positioned in center of ~~run~~ Reg I

2:00 PM

Inst Check OK - Source in  
Start feeding soln into system

$D_2O = 80.6$ , Fuel = 14.64 just crit

Run B

36 tubes put in bundle in center region

3:50 PM

$D_2O = 80.7$  Fuel = 14.31

Exp. 60

4/8/60

Run C

14 tubes ( $\frac{3}{8}$  ID,  $\frac{1}{2}$  OD) centered in a bundle  
in center of Ref. I

10<sup>30</sup>
 $D_2O = 80.3$ , Fuel = 17.16

Run D

90 tubes put in center region

47 polystyrene  $\frac{1}{2}$  OD,  $\frac{3}{8}$  ID,  $\frac{1}{16}$  wall

43 polyethylene  $\frac{1}{2}$  OD,  $\frac{3}{8}$  ID,  $\frac{1}{16}$  wall

1<sup>00</sup>  
1 PM
 $D_2O = 80.3$ , Fuel = 15.09

Run E

2<sup>00</sup> PM

Drained all water from Ref. I. Put in tight-fitting bottle of water positioned for top refl. Bottle was filled to about 8-9".

 $D_2O = 81.3$ 

Fuel at Crit. = 17.51

Run F

4<sup>00</sup> PM

Inserted 24 one in. dia 2S AL Rods  
18 in high and finished filling Ref. I with  
water  $D_2O = 81.48$

Out fuel ht. 15.77

206

4-11-60

Run H 1~~4~~ - 1" dia al rod  
D<sub>2</sub>O = 80.90 inserted in  
Exit fuel ht. 15.93 - Reg I.

Run H.  
8 - ~~1~~ 1" dia al. rods in Reg I  
D<sub>2</sub>O = 81.0  
Exit fuel ht. - 16.73

Run I

2002 - 1" Dia Al Rods in Reg I

D<sub>2</sub>O = 81.30  
Exit fuel ht = 15.62

Run J

43 polyethylene tube  $\frac{3}{8}$ " I.D. -  $\frac{1}{2}$ " O.D.  
47 " styrene " " "  
No water in Reg I. Top Refl. on.  
Tube had stopped in end.  
D<sub>2</sub>O - 81.61  
Exit fuel ht 14.82"

5/7/60

Exp. 60

plexiglas  $C_5H_8O_2$   
density 1.18-1.20

Poly styrene  $[C_8H_8]_n$   
density 1.06

For Poly styrene, the equivalent vol. of water displaced by plastic

$$2 \left[ \frac{V}{M_{H_2O}} 6.02 \times 10^{23} \right] - 8 \left[ \frac{V \cdot 1.06}{M_S} 6.02 \times 10^{23} \right] = 2 \left[ \frac{V_d}{M_{H_2O}} 6.02 \times 10^{23} \right]$$

$$\frac{V}{M_{H_2O}} - 4 \frac{1.06 V}{M_S} = \frac{V_d}{M_{H_2O}}$$

$$\frac{V}{18} - \frac{4.24 V}{88.104} = \frac{V_d}{18}$$

$$V - .7338 V = V_d$$

$$V_d = .266 V$$

Since Vol. of plastic in single tube is 1.54 in<sup>3</sup>,

$$V_d = .266 (1.54) = .410 \text{ in}^3 / \text{tube}$$

Air void volume = 1.54 + 1.987 in<sup>3</sup>

Hence, equivalent water vol. displaced per tube

is	1.541	1.987	1.987	47 tubes 112.7 in <sup>3</sup> % = 24.16
	<u>-.205</u>	<u>-.205</u>	<u>.410</u>	
		2.192 in <sup>3</sup> /tube	2.397	

per 27 tubes	64.7	59.18 in <sup>3</sup>
per 36 tubes	86.3	78.91 in <sup>3</sup>
14	33.53	

% void	13.87
% void	16.97
% void	18.50
% void	7.19

# Calculation of Equivalent void of 47 styrene + 43 ethylene tubes

47 poly styrene tubes:

$$\text{Void} = 112.7 \text{ in}^3 \quad (\text{including displacement and center void})$$

43 polyethylene tubes:

$$\text{Void} = 73.54 \quad (\text{including addition for plastic and removal for center void})$$

$$\text{Total void} = 186.24 \text{ in}^3$$

$$\text{Total \% void} = 39.93$$

Calculation of % void for 43 polyethylene tubes + 47 styrene tubes with no water in region.

$V_S$  = vol of styrene in 47 tubes;  $V_E$  = vol of ethylene in 43 tubes

$V_E$  = equiv. vol of  $H_2O$

$$8 \left[ \frac{V_S (1.06)}{104} \right] + 2 \left[ \frac{V_E (1.92)}{14} \right] = 2 \left[ \frac{V_E}{18} \right]$$

$$V_E = 0.734 V_S + 1.18 V_E$$

$$V_S = (1.54)(47) = 72.4$$

$$V_E = (1.54)(43) = 66.2$$

$$V_E = 53.1 + 78.1 = 131.2 \text{ in}^3$$

$$\% \text{ Void} = \frac{466.3 - 131.2}{466.3} = 71.8$$

Equivalent vol of  $H_2O$  removed due to displacement by polyethylene

$$2 \left[ \frac{V}{18} \right] - 2 \left[ \frac{V(0.92)}{14} \right] = 2 \left[ \frac{V_d}{18} \right]$$

$$V - 1.18V = V_d$$

$$V_d = V(1 - 1.18)$$

$$= (-.18)V$$

For 43 tubes 18" long

$$\text{Air void volume} = 1.987 \text{ in}^3 \text{ per tube}$$

$$\text{Vol of plastic} = 1.54 \text{ in}^3 \text{ per tube}$$

Eqiv  $H_2O$  displaced per 43 tubes {vol is added}

$$V_d = (-.18)V$$

$$= -.18(1.54) = -.277 \text{ in}^3 \text{ per tube}$$

$$\therefore = (-.277)(43) = -11.9 \text{ in}^3 \text{ for 43 tubes}$$

$\therefore$  Net  $H_2O$  displacement from 43 polyethylene tubes

$$= (1.987)(43) - 11.9$$

$$85.44$$

$$- 11.9$$

$$\hline 73.54 \text{ in}^3$$

Run K

Removed polyethylene tubes.

47 polystyrene tubes remaining - fully Refl.

D<sub>20</sub> 81.92

Cmt Fuel ht. 16.01

Run L

Reg I contains: 47 polystyrene tubes  $\frac{3}{8}$ " I.D. x  $\frac{1}{2}$ " O.D.; 2 -  $1\frac{1}{4}$ " dia. plexiglas rods &21  $\frac{3}{8}$ " I.D. x  $\frac{1}{2}$ " O.D. polyethylene tubes. Fully  
refl. D<sub>20</sub> 82.2

Cmt Fuel ht. 14.93

Dilutions to ~ 140 gm/l

at 120 gm/l in stat 6.3 l

Added at ~ 340 gm/l 6.1 l or 9.38 kg sal  
and mixed. This is ~ 14.25" in Y-12  
plastic bottle

4-12-60

Sample D<sub>20</sub> taken - 7-D



4-12-60

## Expt. 61 A

Preliminary expt with  $\sim 140$  gm/l  
fuel soln &  $\sim .037$  gm B/l in  $D_2O$

$D_2O - 82.28''$

out fuel ht 17.43

## 61 B

Added  $\sim 500$  cm<sup>3</sup> of conc.  $Na_2B_4O_7$   
and mixed (Bottle # 1)

$D_2O - 80.4$

Out fuel ht. 17.20

## 61-C

2<sup>00</sup> PM Added  $\sim 1$  l of conc  $Na_2B_4O_7$

And Mixed

crit ht = 17.49''

$D_2O = 80.42$

## 61 D

Added  $\sim 1/2$  l of conc  $Na_2B_4O_7$

$D_2O 80.43$

out fuel ht 17.86

very nearly full.

Total Borate added

2.04 kg soln

gms  $Na_2B_4O_7$

$2.04 \times 10 = 21$  gm  
3.88

4-13-60

Expt. ~~61D~~ 61E

Repeat of 61D with Reg I Counter in.

 $D_2O \approx 81$ 

Curt fuel ht 18.33

Add  $\sim 1/2$  l of 340 gm/l soln. to slab & mixed.

Expt. 61F

 $D_2O - 80.6$ 11 <sup>00</sup> AM

Curt fuel ht. 18.13

Rot gas = 0.00 ; Reg I = 0.00 ;  $D_2O = \sim 80$  ; Blade out  
Litt pos = 7.0411 <sup>05</sup> AM

Check out of Counters

Rot Pos	Reg I Pos	I	N	II	III	IV	
0.0	0.0	220867	447262	160140	54680	99980	
"	"	223854	456384	161990	55620	100870	
"	"	221264	<del>452521</del>	158360	54680	—	
11 <sup>19</sup> AM	"	216120	450217	157360	54630	98620	
"	"	214840	447432	156010	53740	97730	
"	"	176418?	367291?	153900	53140	— ]?	
"	"	220127	459391	159460	55430	100390	
"	"	224170	467115	160520	55750	101060	
def	"	225723	469929	162480	56220	101780	
	11 <sup>32</sup> AM	Shut down					

To Check on Count-rate of Counters relative  
to Count rate in Exp. 24

Wiff = 7.04,  $D_0 \approx 80$ ; Fuel = 17.95; Blade partway in (no satsyn)  
Rot pos = 160; Reg I = <sup>520</sup>512

Rot Pos	Reg I Pos	I	N	II	III	IV
160	<sup>12</sup> / <sub>PM</sub> <sup>520</sup> / <sub>512</sub>	325618	290612	32150	52980	15400
"	"	320028	285207	31540	51600	15290
"	"	346809	307093	34450	55560	76520
"	"	363574	322261	36190	58180	<del>16</del> 17510
"	"	37839	333995	37360	60520	17990
"	"	392935	346921	38550	62520	18530
"	"	395627	350739	39320	63200	18650
"	<sup>26</sup> / <sub>PM</sub> "	397268	352828	39370	63520	18760
180	558	397828	354123	38920	62750	13540
"	"	395818	353611	38990	62460	13610
200	<sup>31</sup> / <sub>PM</sub> 530	401878	360717	40470	62100	9320
"	"	412644	367740	41070	63070	9640
220	490	400513	356294	41570	58730	6280
"	"	409378	364647	42600	60040	6490
240	440	410166	365607	45320	57680	4680
"	"	409465	363756	44900	57590	4650
260	<sup>45</sup> / <sub>PM</sub> 380	392297	351913	46530	54570	3210
"	"	385517	347949	46400	53870	3290
280	330	381405	346459	51210	52010	2400
"	"	384958	350294	51310	52210	2360

4/13/60

Exp. 61-E

211

Post Loc	Reg. I	I	IV	II	TV	TU
300	280	366491	341292	55310	50230	1790
"	"	355501	332139	53800	48500	1630
360	230	334096	325957	59890	46590	1040
"	"	324206	315829	58070	44760	960
320 <sup>20</sup>	180	295241	305832	52730	43290	1240
"	"	296547	307556	53460	43850	1220
290	130	266507	305632	46170	44230	1860
"	"	264743	302434	45950	43830	1820
260	80	232678	310047	40910	47050	2760
"	"	237554	318170	41810	48020	2890
220	40	195002	319208	36530	51210	5630
"	"	188511	307861	35060	49540	5460
190 <sup>20</sup> <sub>2 PM</sub>	0.0	144625	324718	35030	55640	10170
"	"	154773	344539	38090	59990	11070
160	60	235444	342902	<del>81670</del>	61600	18730
"	"	237169	343719	<del>5840</del>	61290	18620
"	"	240026	345614	<del>129910</del>	61960	18790
"	"	241707	348084	<del>194080</del>	62150	19080
"	"	248140	355008	38810	63580	19280
"	"	249209	354840	39370	63920	—
"	"	248788	353858	39030	64150	19340
140 <sup>55</sup> <sub>2 PM</sub>	100	277539	338773	39380	61320	25760
"	"	273857	332945	37920	60110	24810
120	160	376530	396203	49450	71720	40190
"	"	398337	420255	52940	76460	42880
100	220	440143	426532	60130	76100	56250
"	"	426162	409516	57940	72770	54220

Rot.	Reg. I	I	N	II	III	IV
60	270	441150	412463	89120	64490	78560
"	"	447085	419838	91300	64900	79860
30	320	453591	417344	130730	56790	87680
"	"	464889	426989	133710	56710	89740
0.0	360	478495	435355	151640	50830	92830
"	"	488029	442207	154550	51790	94220
40	400	522507	468006	133800	65900	99070
"	"	536549	479824	137370	67420	102620
80	440	585229	518491	89350	89450	87050
"	"	595814	529417	92560	91560	89120
120	480	640623	565531	72970	106760	59750
"	"	627780	555730	70830	103720	58210
140	520	644673	569452	67660	107110	44940
"	"	678305	590321	70620	111810	47030
160	558	696464	609337	69260	112640	33790
"	"	707361	615918	70540	115430	34420

Thermocouples:

14 - .957 23.7

15 - .971 24.2

14 - .970

13 - .943 after draining

12 - .964 24.1

samples of D<sub>2</sub>O taken

# 8-D & 8-D-1

.0569<sup>m</sup>B/ml

Page III Expt 61.-E

Ret. Pos	Reg. Pos	S/N	I/N	II/N	III/N
		V. 8695	X. 5738	X. 7,340	X. 5124
160	60	7031	1102	1812	5464
140	100	8191 <sup>8208</sup>	1162 <sup>1151</sup>	1810 <sup>1809</sup>	7603 <sup>7527</sup>
"	"	8226	1139	1805	7452
120	160	9502 <sup>9489</sup>	1248 <sup>1254</sup>	1819 <sup>1815</sup>	1020 <sup>1020</sup>
"	"	9476	1259	1810	1020
100	220	1031 <sup>1036</sup>	1409 <sup>1412</sup>	1819 <sup>1802</sup>	1318 <sup>1321</sup>
"	"	1040	1414	1784	1324
60	270	1069 <sup>1067</sup>	2160 <sup>2167</sup>	1563 <sup>1554</sup>	1904 <sup>1903</sup>
"	"	1065	2174	1545	1902
30	320	1086 <sup>1088</sup>	3132 <sup>3132</sup>	1336 <sup>1334</sup>	2101 <sup>2102</sup>
"	"	1089	3131	1328	2102
0.0	360	1098 <sup>1100</sup>	3481 <sup>3488</sup>	1167 <sup>1169</sup>	2132 <sup>2131</sup>
"	"	1103	3495	1171	2130
40	400	1116 <sup>1117</sup>	2858 <sup>2861</sup>	1408 <sup>1407</sup>	2116 <sup>2127</sup>
"	"	1118	2863	1405	2138
80	440	1128 <sup>1127</sup>	1723 <sup>1736</sup>	1725 <sup>1727</sup>	1678 <sup>1681</sup>
"	"	1125	1748	1729	1683
120	480	1274 <sup>1272</sup>	1290 <sup>1282</sup>	1887 <sup>1878</sup>	1056 <sup>1052</sup>
"	"	1129	1274	1866	1047
140	520	1131 <sup>1140</sup>	1188 <sup>1192</sup>	1880 <sup>1887</sup>	7891 <sup>7929</sup>
"	"	1149	1196	1893	7967
160	558	1143 <sup>1146</sup>	1136 <sup>1141</sup>	1848 <sup>1861</sup>	5545 <sup>5544</sup>
"	"	1148	1146	1873	5588

Rot	Reg I	F/N	F/N	F/N	F/N
180	558	1123	1099	1772	3823
"	"	1119	1102	1766	3848
200	530	1114	1121	1721	2583
"	"	1122	1116	1715	2621
220	490	1124	1166	1648	1762
"	"	1123	1168	1646	1780
240	440	1121	1239	1577	1280
"	"	1125	1234	1583	1278
260	380	1114	1322	1550	9121
"	"	1108	1333	1548	9456
280	330	1100	1477	1501	6924
"	"	1098	1464	1477	5673
300	280	1073	1620	1477	4908
"	"	1070	1619	1460	4908
360	230	1025	1837	1429	3190
"	"	1026	1838	1417	3039
320	180	9653	1724	1415	4054
"	"	9639	1737	1425	3966
290	130	8720	1510	1447	6086
"	"	8753	1519	1449	6018
260	80	7506	1319	1517	8903
"	"	7467	1313	1509	9082
220	40	6109	1144	1604	1763
"	"	6122	1138	1608	1773
190	0.0	4453	1078	1713	3132
"	"	4493	1105	1741	3210
160	60	6864	<del>2387</del>	1796	5462
"	"	6901	—	1783	5417
"	"	6944	—	1792	5436
"	"	6944	—	1785	5481
"	"	6988	—	—	—
"	"	6988	1093	1790	5430
"	"	7023	1107	1801	—

684  
507  
3114  
4010  
6052  
899  
908  
896  
1770  
317

I/N      II/N      III/N      IV/N

494	358	122	224
491	355	122	221
489	350	121	—
480	349	121	219
480	349	120	218
480	419 ?	145 ?	— ?
479	347	121	219
479	343	119	216
480	346	120	217

Rot pos 140 & Ref pos 522      Expt cell F      Lift = 704

ave. = 1127

1120	1106	1823	5347
1122	1105	1809	5341
1129	1122	1809	5379
1128	1123	1805	<del>5433</del> 538
1132	1119 III	1811 1805	5386
1133	1111	1802	5341
1128	1121	1802	5317
1126	1115	1800	5317

ave. = 1127

To correct this count rate to midplane vertically  
mult. by 0.997



4/14/60

Samples of fuel taken

14A

14B

140.7

20.2

120.5

14A to Cooper

14B to Harman; 94.2 at. % D

214 4/14/60

Exp. 62

9<sup>15</sup><sub>AM</sub>

Calibration of ~~Q~~ Counters (4-235) Using Reg I Counter.

Reg I counter placed in center (vertically and radially) in Reg IV

D<sub>2</sub>O = 80, Fuel 17.9

I	N	I/N
22965	888127	2585
22617	891026	2538
22547	884414	2549
22550	887343	2541
22548	885355	2546
22305	886124	2517
22224	889077	2499
22509	896887	2509
22812	905392	2519

Avg. = 2534

10<sup>30</sup><sub>AM</sub>

Reg I counter put in center of Reg III (through vent)

I	N	I/N
129366	456954	2831
130816	463107	2824
131005	466533	2808
128607	452685	2840
123125	436402	2820
119214	422538	2821
117237	415607	2820
115532	410097	2818
113609	403959	2812
112028	395911	2829
109848	392747	2796

Avg = 2820

Reg I Counter placed in center of Reg II

I	N	I/N
33034	454790	7263
33301	459227	7251
33564	458802	7315
33287	455619	7306
33273	456179	7293
33339	455604	7317
32827	451058	7277
33215	455153	7297
33351	455919	7315
33164	455319	7283

avg = .07292

4-14-60

2PM

Normalizing Counter in center of Reg I

<u>Nor. Ctr. Reg I</u>	N BF <sub>3</sub>	I/N
359810	468506	7683
364099	473536	7688
367014	477832	7681
366316	476742	7684
370914	482602	7686
379705	494341	7681
377272	493037	7652
376399	492036	7649
377806	494144	7644
375632	494439	7597
373654	495299	7544
377044	499849	7543
375057	499493	7509

7434

216

4-19-60

Expt. 63

Vertical Traverse using fission ctr  
Rot. Pos 162, Reg I pos. center (520)

L. ft Pos	Reg I	N	Reg II	Reg III	Reg IV
1.00	368250	419184	37120	66460	20930
" 9 <sup>45</sup> AM	372607	428072	37390	66730	21160
"	360106	417376	36140	64970	20830
"	354927	414350	35520	64240	20630
"	359545	418633	36100	64750	—
"	365966	427803	32020	65560	20950
"	373219	435232	37500	66920	21080
"	377534	443831	37940	69710	21540
2.00	417215	438408	40360	71110	21740
"	412575	436023	40340	70500	22110
3.00	446011	434294	43160	73860	22870
"	448375	435415	43620	73980	22690
4.00 3 <sup>30</sup> AM	481327	442278	45620	78310	24250
"	489844	451626	46430	79680	24950
4.50	509250	456722	48570	82110	25270
"	514819	462935	49430	83140	25500
5.00	525708	466556	50900	84600	25870
"	530439	469025	51790	86000	26100
5.50	535602	467818	51880	86350	26660
"	529750	462445	51670	85480	25940
6.00	537280	464631	51630	86420	25600
"	541062	467645	52320	86740	25680
6.50	549910	472962	53320	88080	26090
"	558793	479523	53930	88620	26460
"	558230	483021	54710	90010	26790

Dist	I	N	II	III	IV
7.00	555919	485019	54320	90190	26680
"	556915	484047	54330	90150	26650
7.50	563143	488413	55120	91070	26460
"	569417	491634	55800	91780	26350
8.00	565181	491304	55690	92540	26540
"	563446	489822	54910	90630	26190
8.50	565633	495504	55760	92530	26080
"	573520	501553	55220	92410	26130
9.00	574852	508206	54800	93270	25850
"	575016	509341	55860	94250	25970
9.50	582400	520926	56060	94100	26130
"	576092	513753	55010	92780	25680
10.00	573121	522760	54530	93590	25500
"	590193	536572	56420	95990	26240
11.00	569287	541300	53890	93670	24840
"	568136	540216	54050	93540	24640
11.78	534993	533185	50290	88600	22920
"	522772	520043	49710	87850	22590
"	509040	506607	47620	84530	21880
11.00	537477	509901	—	87710	22940
"	540347	515921	50860	88750	23350
"	545277	520134	51310	89630	23620
10.00	552897	502952	52760	90170	24120
"	559149	509205	52970	90630	24360
9.00	572739	506393	54930	92540	25640
"	571806	504173	54950	92390	25760
8.50	583147	510034	56090	93920	26730
"	591193	517358	57070	95370	27100

Lift	I	N	II	TEL	TO
8.00	597087	517332	57780	96100	27350
"	597915	516851	57670	95420	27580
7.50	587668	506759	56860	94570	27260
"	594584	512366	57100	94570	27630
7.00	600752	516119	58580	97070	28410
"	598985	517944	58240	97030	28290
6.50	598839	517726	58030	94760	28900
"	603920	522741	58180	97810	28970
6.00	596599	521532	57900	96080	28820
"	594351	518752	57400	95680	29030
5.50	584716	516039	56960	95680	28910
"	585293	514686	56780	94450	28610
5.00	576750	521984	56390	95310	29230
"	575343	521193	56390	94860	29140
4.00	564359	531136	56520	94570	29350
"	560278	523601	55110	93180	29110
3.00	538337	532032	53200	90140	2-8850
"	548073	541619	53640	92180	29460
2.00	530497	572132	52940	93170	29560
"	537442	573634	53120	92980	29680
1.00	486029	581781	50140	89010	28050
"	493135	587992	50620	90230	28370

Reg I	Lift Pos	I/N	II/N	III/N	IV/N	Reg II	Dist. + Center
		(X.8695)	X0.5738	X1.340	X0.5124		
	1.00	8785	8854	1585	4992		
	"	8703	8733	1558	4943		
	"	8627	8658	1560	4990		
	"	8565	8572	1550	4978		
	"	8588	8623	1546			
6.33	"	8554	<del>8484</del> 8545	1532	4897		
	"	8575	8616	1537	4843	4864	6.1
	"	8506	8548	1525	4853		
5.33	2.00	9516	9206	1622	4958	5014	5.1
	"	9462	9252	1616	5071		
4.33	3.00	1026	9937	1700	5265	5235	4.
	"	1029	1001	1699	5211		
3.33	4.00	1088	1031	1770	5482	550	3.
	"	1084	1028	1764	5524		
2.83	4.50	1115	1063	1797	5537	552	2.
	"	1112	1067	1796	5508		
2.33	5.00	1126	1090	1813	5544	5553	2.
	"	1130	1104	1833	5569		
1.83	5.50	1144	1109	1845	5699	565	1.
	"	1145	1117	1848	5609		
1.33	6.00	1156	1111	1860	5510	550	1.
	"	1157	1118	1855	5490		
0.83	6.50	1162	1127	1862	5516	552	1.
	"	1165	1124	1848	5518		
	"	1155	1132	1863	5546		
0.33	7.00	1146	1120	1859	5501	550	1.
	"	1150	1122	1862	5500		
-0.17	7.50	1152	1128	1864	5417	538	-
	"	1158	1135	1860	5359		

Reg I	Light	I/N	II/N	III/N	IV/N	Reg II
-47	8.00	1150	1133	1883	1870	5410
	"	1150	1121	1850		537
-1.17	8.50	1141	1125	1867	1855	5263
	"	1142	1101	1842		524
-1.67	9.00	1131	1078	1835	1843	5086
	"	1130	1096	1850		509
-2.17	9.50	1118	1076	1806	1806	5016
	"	1120	1070	1805		500
-2.67	10.00	1096	1043	1790	1789	4878
	"	1098	1051	1788		488
-3.67	11.00	1057	9950	1767	1745	4588
	"	1051	1000	1731		457
-4.45	11.78	1003	9432	1661		4298
	"	1005	9559	1689	1675	4343
	"	1004	9399	1668		432
-3.67	11.00	1054	9955	1730		4490
	"	1047	9858	1720	1720	4525
	"	1050	988			451
	"	1048	9865	1723		4541
-2.47	10.00	1099	1049	1793	1786	4795
	"	1098	1045	1779		479
-1.67	9.00	1130	1084	1827	1830	5063
	"	1132	1089	1832		508
-1.17	8.50	1143	1100	1841	1842	5240
	"	1143	1102	1843		524
	8.00	1142	1103			5238
-67	8.00	1154	1114	1857	1850	5286
	"	1155	1115	1846		530
-17	7.50	1159	1122	1866	1855	5379
	"	1160	1114	1845		538
0.33	7.00	1164	1135	1880	1876	5504
	"	1160	1130	1872		548



Wgt	I/N	I/N	I/N	I/N	I/N	Ref II
6.50	1156	1120	1869	5580	556	0.6
"	1155 1156	1113 1116	1871 1870	5542		
6.00	1144	1110	1842	5526	556	1.
"	1145 1145	1106 1108	1844 1843	5590		
5.50	1133	1103	1854	5602	558	1.
"	1135 1135	1103 1103	1835 1845	5558		
5.00	1105	1080	1825	5599	543	2.
"	1104 1104	1081 1081	1820 1823	5652		
4.00	1062	1064	1780	5525	554	3.
"	1066 1066	1052 1058	1779 1780	5559		
3.00	1011	1000	1694	5441	544	4.
"	1012 1012	995 995	1701 1697	5430		
2.00	9272	9253	1628	5166	517	5.
"	9368 932	9255 9260	1625 1621	5174		
1.00	8353	8618	1530	4821	482	6.
"	8384 837	8615 8608	1532 1535	4825		

Expt 64

221

4-21-60 Horizontal Traverse using  
Cd-covered Fission Ctrs lift=7.04

Rat Pos	Reg I Pos	Reg I	N	Reg II	Reg III	Reg IV
340	370	27116	1831785	70340	3860	20
" <sup>30</sup> 340	"	27808	1872127	72680	3760	20
"	"	27653	1876526	72510	3890	<del>40</del>
"	"	27690	1880423	72720	3770	30
"	"	27943	1880824	72650	3820	20
300	400	27414	1899304	74680	4400	30
"	"	27192	1881201	73790	4300	20
260	460	26957	1924413	79010	5610	50
"	"	26862	1927235	79660	5490	30
240	490	27061	1931639	81190	6490	100
"	"	27402	1950455	81910	6590	60
220	520	25496	1853889	79400	7190	70
"	"	25513	1844899	79120	7170	80
200	580	24087	1722357	74640	7840	—
"	"	24125	1716454	73810	7940	100
180 <sup>32</sup>	540	21185	1593437	69380	8770	160
"	"	21558	1583501	69110	8560	150
160	480	18978	1440101	62050	9290	230
"	"	19038	1429692	62420	9490	340
140	420	15371	1170488	49950	8800	340
"	"	16217	1216692	51360	9120	360
120	380	14778	1100351	46130	9440	540
"	"	15666	1143729	48470	9860	620
100	340	19450	1351346	58330	13880	1140
"	"	"	"	"	"	"

Rot Pos	Reg Pos	I	N	II	III	IV
100	340	21757	1472025	63790	15180	1220
"	"	21456	1458636	63330	14950	1280
80	420	12977	1019420	41310	11610	1510
" <sup>10</sup> <sub>2</sub>	"	13391	1056224	43110	12290	1490
70	440	12758	1015329	39990	12210	1830
"	"	12294	971659	38780	12320	1970
100	280	29037	1778897	78170	18060	1490
" <sup>10</sup> <sub>2 PM</sub>	"	30122	1847705	81820	19030	1550
120	220	35338	1922153	86610	17520	1010
"	"	35366	1929133	86250	17620	1010
140	180	36088	1828944	80980	13900	530
"	"	35793	1816083	79980	14090	540
160	130	33980	164263	70970	10750	280
"	"	35143	1657480	71170	10600	280
180 <sup>45</sup> <sub>2 PM</sub>	80	34568	1528521	64230	8070	130
"	"	34241	1503745	62720	7970	130
200	40	35879	1500325	61540	6610	—
"	"	34131	1514711	61640	6480	90
220	0.0	39709	1602509	64430	5970	—
"	"	39198	1573527	63340	5960	100
240	60	37059	1567635	62450	5130	460
"	"	37734	1573781	62560	4920	—
260	130	42219	1945526	78730	5350	30
"	"	42302	1936130	78060	5790	40
280	190	38885	1965708	78560	4810	40
"	"	40518	2041047	81980	4980	20
300	260	31264	1835291	71390	4090	20
"	"	31181	1813638	71190	3890	20

R 4/21/60

Exp. 64

Page I

Lot Nos	Page	I/N	O/N	O/N	O/N
		x 0.8695	x 0.5738	x 1.340	x 0.5124
340	370	1480	3839	2108	
"	"	1485	<sup>3582</sup> 473	2008	
"	"	1473	3863	2072	
"	"	1472	3868	2005	
"	"	1485	3862	2030	
300	400	1443	3932	2317	
"	"	1445	3922	2286	
260	460	1401	4105	2910	
"	"	1393	4133	2848	
240	490	1400	4202	3359	
"	"	1405	4200	3374	
220	520	1374	4282	3878	
"	"	1382	4288	3886	
200	580	1400	4334	4552	
"	"	1405	4298	4624	
180	540	1329	4355	5505	
"	"	1360	4363	5404	
160	480	1371317	4309	6451	
"	"	133	4365	6636	
140	420	1312	4265	7514	
"	"	1332	4220	7493	
120	380	1343	4193	8581	
"	"	1369	4236	8618	
100	340	1439	4317	1027	
"	"	1478	4333	1031	
"	"	1470	4341	1024	
80	420	1273	4053	1139	
"	"	1267	4082	1163	
70	440	1256	3939	1202	
"	"	1265	3990	1267	

Lat Pos	Reg Pos	I/N	II/N	III/N	IV/N
100 -	280 -	1632	4394	1015	
"	"	1630.01631	4428.04411	1029.01022	
120 -	220 -	1838	4506	9115	
"	"	1833.01836	4471.04479	9138.019125	
140 -	180 -	1973	4427	7600	
"	"	1970.01972	4404.04410	7758.0107679	
160 -	130 -	2068	4319	6546	
"	"	2121.02095	4295.04307	6397.006471	
180 -	80 -	2260	4200	5277	
"	"	2276.02268	4170.04185	5298.005288	
200 -	40 -	2391	4102	4406	
"	"	2384.02388	4071.04087	4277.004341	
220 -	0.00 -	2477	4019	3724	
"	"	2490.02484	4024.04022	3786.003755	
240 -	60 -	2363	3985	3273	
"	"	2397.02380	3974.03980	3125.003199	
260 -	130 -	2170	4046	2749	
"	"	2184.02177	4032.04039	2990.002869	
280 -	190 -	1977	3995	2446	
"	"	1985.01981	4016.04006	2438.002442	
300 -	260 -	1703	3890	2228	
"	"	1718.01711	3924.03907	2144.002186	
320 -	320	1546	3856	2017	
"	"	1558.01555	3850.03861	2056.002054	
"	"	1563.01555	3877.03861	2091.002054	

Ret. Co. Reg. I

320

320 Reg I/20	28589	1848830	71300	3730	30
"	29180	1872156	72080	3880	30
"	29532	1888744	73230	3950	30
Temp. Reg. I - slat. 17.7 -	18.3°; Reg. III - 18.8°, Reg. IV 18.8, air 18.3°				

224

Exp. 65

Radial traverse Cd-covered at midplane  
 i.e. repeat of exp 64 after tightening cables  
 shift = 7.04

Rot Pos	Reg I	I	N	II	III
60 <sup>15</sup> PM	560	17774	1214201	50450	14670
"	"	19015	1283632	53660	15850
"	"	19146	1305198	54850	16080
"	"	19484	1310030	54380	16650
"	"	20034	1322137	55300	16990
100	520	22259	1479732	64670	15480
"	"	22598	1497632	66080	16960
120	480	26301	1709132	77040	15940
"	"	26862	1737893	78260	16010
140	430	31656	1980074	91290	16100
"	"	31163	1853904	91130	16350
160	380	33949	2034884	94690	14370
"	"	33230	1995007	91510	13680
180	330	34974	1976838	89390	11340
"	"	34989	1871494	88650	11280
200	280	36431	1918139	85090	8960
"	"	35735	1876852	81740	8880
220	230	37003	1807608	76250	6970
"	"	37266	1835925	78160	6990
240	180	40293	1824957	74380	5810
"	"	40414	1831098	74510	5960
260	130	39412	1617638	64360	4470
"	"	38778	1626292	62980	4390
30	"	37479	1607023	61720	4390

Rot. Pos	Key Pos	I	N	U	TA
280	80	35470	1425549	52940	3320
" <sup>10</sup> / <sub>2PM</sub>	"	35935	1448352	53790	3210
300	40	39768	1521118	56030	3020
"	"	40368	1560722	57770	3270
320	0.0	42781	1572209	57520	3100
"	"	42295	1570937	57090	3020
340	50	43285	1667871	60910	3130
"	"	43577	1678144	61450	3200
300	100	44866	1814740	69620	3800
"	"	45153	1829542	69320	3820
280	150	46591	2028259	81280	5020
" <sup>30</sup> / <sub>2PM</sub>	"	47164	2039627	81700	4890
260	200	48368	2249491	93640	6530
"	"	48639	2263723	94650	6370
240	240	49284	2413480	105240	8280
"	"	34959	1809448	74130	6070
"	"	35010	1829502	73970	5880
220	290	33401	1860936	78060	7090
"	"	32586	1846223	77480	7060
200	340	31776	1800148	82330	8780
" <sup>50</sup> / <sub>2PM</sub>	"	31782	1921724	83630	8780
180	390	29446	1888826	84010	10970
"	"	29672	1901109	84780	10930
160	440	26476	1774723	78800	11800
"	"	25754	1744245	78000	11600
140	480	22075	1530284	66880	11840
"	4	21501	1526847	67570	13320



226

Rot Pos	Reg	I	II	III	TD
120	520	14391	1188432	50620	11560
"	"	16628	1207476	51510	10650
"	"	16846	1219623	51480	10620
100	570	19044	1344088	57630	13490
"	"	19457	1380397	59410	13810
80	520	26168	1847143	80860	21970
"	"	27292	1887317	84100	22500
60	480	28658	2013142	87860	26100
"	"	28870	2031228	89430	26710
50	450	26091	1855624	79320	24570
"	"	25756	1876490	79890	24710
"	"	26030	1893343	80630	25140
1	Reg I - 18.8°C Reg II - 19.3°C Reg III - 18.8°C				
1					
1					
2					
2					
2					
2					

Reg I	Reg II	F/N	B/N	D/N
		1.8695	10.5738	1.340
60	540	1463	4155	1208
"	"	1480	4179	1234
"	"	1466	4203	1232
"	"	1487	4151	1270
"	"	1515	4183	1285
100	520	1504	4369	1045
"	"	1507	4414	1132
120	480	1538	4507	9327
"	"	1545	4502	9211
140	430	1598	4610	8131
"	"	1680	4915	8818
160	380	1666	4648	7054
"	"	1665	4586	6857
180	330	1768	4521	5735
"	"	1870	4738	6028
200	280	1899	4436	4671
"	"	1904	4354	4730
220	230	2046	4217	3855
"	"	2029	4257	3807
240	180	2207	4075	3183
"	"	2207	4069	3255
260	130	2435	3977	2762
"	"	2384	3873	2699
"	"	2332	3840	2731
280	80	2488	3713	2329
"	"	2482	3714	2216
300	40	2614	3683	1985
"	"	2586	3700	1972
320	0.0	2721	3659	1972
"	"	2692	3633	1922

Rot	Mag F	$\frac{P}{N}$	$\frac{Q}{N}$	$\frac{R}{N}$
340	50	2595 <sup>2596</sup>	3652 <sup>3657</sup>	1876 <sup>1892</sup>
"	"	2596	3662	1907
300	100	2471 <sup>2470</sup>	3835 <sup>3812</sup>	2093 <sup>2091</sup>
"	"	2468	3790	2088
280	150	2297 <sup>2304</sup>	4007 <sup>4006</sup>	2475 <sup>2436</sup>
"	"	2311	4004	2397
260	200	2147 <sup>2148</sup>	4163 <sup>4172</sup>	2903 <sup>2858</sup>
"	"	2148	4180	2813
240	240	2042 <sup>1962</sup>	4361 <sup>4167</sup>	3431 <sup>3333</sup>
"	"	1932	4097	3355
"	"	1913	4043	3213
220	290	1794 <sup>1780</sup>	4194 <sup>4196</sup>	3809 <sup>3817</sup>
"	"	1765	4197	3824
200	340	1765 <sup>1709</sup>	4573 <sup>4462</sup>	4877 <sup>4847</sup>
"	"	1653	4351	4818
180	390	1558 <sup>1559</sup>	4449 <sup>4454</sup>	5810 <sup>5779</sup>
"	"	1560	4459	5749
160	440	1491 <sup>1484</sup>	4440 <sup>4456</sup>	6649 <sup>6650</sup>
"	"	1476	4472	6651
140	480	1442 <sup>1425</sup>	4371 <sup>4398</sup>	7739 <sup>8230</sup>
"	"	1407	4425	8722
120	520	1379 <sup>1379</sup>	4260 <sup>4249</sup>	9730 <sup>9086</sup>
"	"	1377	4267	8823
"	"	1381	4221	8707
100	570	1416 <sup>1413</sup>	4287 <sup>4296</sup>	1004 <sup>1002</sup>
"	"	1409	4305	1000
80	520	1416 <sup>1431</sup>	4377 <sup>4416</sup>	1189 <sup>1191</sup>
"	"	1446	4456	1192
60	480	1423 <sup>1422</sup>	4364 <sup>4383</sup>	1296 <sup>1306</sup>
"	"	1421	4403	1315



Exp. 64

Repeat of Radial traverse (6's)

4/25/60

Rot Pos	Reg. I Pos.	I	N	II	III
160	340	18648	1312953	55690	8340
"	"	19524	1378348	59010	8770
"	"	19071	1347089	57120	8630
"	"	18797	1336082	56330	8450
"	"	18764	1337984	56440	8450
"	"	18935	1340688	57100	8470
<sup>19</sup> / <sub>2 PM</sub> "	"	19070	1349728	57070	8500
180	300	20385	1372717	57770	7230
"	"	20825	1377929	57350	7280
200	250	20621	1275040	51580	5520
"	"	22185	1370146	55320	6050
220	200	21535	1246570	48950	4720
"	"	20276	1183242	45750	4260
240	150	41484	2024827	83290	6770
"	"	29309	1481693	58320	4460
"	"	27258	1408451	55650	4510
260	100	28985	1379412	51720	3690
"	"	29158	1372538	51380	3670
280	50	27720	1244308	44210	2750
"	"	27683	1239447	44660	2710
300	0.00	28310	1219110	43130	2540
"	"	27866	1210354	43080	2730
340	40	25225	1135142	38680	2020
<sup>00</sup> / <sub>3 PM</sub> "	"	25494	1147092	40090	2130
320	80	29067	1351687	47930	2590
"	"	29910	1378225	49610	2960

Rot. Pos.	Reg. Res.	E	N	E	E
300	120	32221	1559909	57310	3490
"	"	32397	1568618	57660	3400
280	160	35892	1787489	68110	4560
"	"	35163	1758737	67240	4120
260	200	35875	1905458	75590	5250
"	"	36120	1916158	75770	5300
240	240	37367	2110015	87960	7010
"	"	38592	2170944	92170	7400
220	<sup>320</sup> 280	31983	1956652	81270	7550
"	"	32669	1992489	81900	7490
200	320	29884	1944097	82250	8650
"	"	29715	1944480	82520	8810
180	360	27007	1883954	80950	10130
"	"	26796	1857745	79630	10480
160	400	22775	1685836	72410	10860
"	"	21899	1635892	70020	10510
140	440	17510	1378737	58340	10250
"	"	16479	1303609	54470	9610
120	480	21265	165380	72340	14920
"	"	22748	1749951	76100	15960
100	520	17997	1408793	59900	14270
"	"	16664	1330920	55840	13490
80	560	21182	1633398	69540	18800
"	"	21877	1674610	71010	19170
60	520	29104	2181736	95130	28760
"	"	29534	2213552	97100	29450
80	480	23858	1833802	79280	21490
"	"	23279	1813810	78170	20780

Rot Pos	Reg I	I	W	A	□
100	440	27065	2009352	89460	21190
"	"	26724	1999223	88640	21250
120	400	29863	2128229	96550	20220
"	"	30147	2167228	98140	20380
140	360	34938	2357554	108640	19410
"	"	34507	2296233	105250	18700
160	320	37330	2378741	108340	16160
"	"	37227	2387729	108920	16430
4 <sup>28</sup> pm	Shut Down				

4/26/60 Reg II counter removed and was found to be  
throwing in counts. Repaired  
Reg I counter checked and found OK

230

Exp. 67

Cd-Covered Radial Traverse (repeat of 66 etc.)

4/27/60 Counters replaced.

 $D_2O \approx 80$ , Fuel  $\approx 17.9$  Lift = 7.04

Rot

Recheck of Reg I pos. at center = 498

Rot. Pos	Reg I Pos	I	II	III	Rot	
340 <sup>50</sup> / <sub>2PM</sub>	<del>4</del>	42130	1859 1641112	62500	3640	4
"	"	41301	19093 1678812	63520	3200	
"	"	42613	1979 1730037	65650	3390	
"	"	44333	2042 1790937	68070	3440	1
300	50	44654	2159 1862814	72430	4020	
"	"	45658	2203 1895197	73690	4120	1
-270	100	47739	2488 2099928	85180	5520	
"	"	48411	25057 2110612	85530	5450	
240	150	47633	2733 2269696	96440	7610	
"	"	46315	28320 2199611	93030	7400	1
220	200	30808	1896 1667786	70420	6390	
"	"	29633	1837 1619922	67230	5980	1
200	250	26526	1776 1577488	67480	7120	
"	"	25965	1765 1567627	67230	7050	2
180	300	22982	1686 1507124	65010	7950	
"	"	22450	1651 1479548	63580	7960	2
160	350	20130	1589 1431320	63550	9310	
"	"	20301	1591 1433488	62840	9390	2
140	400	16770	1407 1286532	56220	9760	
"	"	17177	1374 1259232	54840	9820	
120	450	12817	1093 1024252	43420	8940	
"	"	11512	9835 930491	38720	7890	
100	480	8596	7519 725235	29500	6910	
"	"	8573	7378 714219	29060	6770	



Rot Pos	Reg I Pos	I	N	II	III
80	520	6104	<del>5337</del> 525923	20480	5340
"	"	5820	<del>5013</del> 496347	19300	5260
60	560	24917	<del>22037</del> 1895754	83510	24750
"	"	25158	<del>22188</del> 1907927	83930	25160
80	520	21292	<del>1894</del> 1665839	72330	19600
"	"	20563	<del>18270</del> 1615527	69520	18710
100	480	21914	<del>1934</del> 1696389	75190	17850
"	"	21750	<del>19477</del> 1706988	75700	17880
120	450	24712	<del>2197</del> 1890518	86240	17690
"	"	25644	<del>2250</del> 1933382	88480	18200
140	400	28037	<del>2374</del> 2016613	91930	16080
"	"	28013	<del>2399</del> 2036498	93190	16090
160	350	27043	<del>2208</del> 1898412	84910	12660
"	"	26831	<del>21963</del> 1870125	83370	12500
180	300	29942 <sup>o</sup>	<del>19465</del> 1706013	73480	11300 <sup>o</sup>
"	"	25129	<del>18831</del> 1657755	70710	9020
200	250	26533	<del>18357</del> 1621705	67630	7300
"	"	26505	<del>1827</del> 1615804	67730	7430
220	200	28181	<del>17982</del> 1592795	64870	6030
"	"	28100	<del>17873</del> 1585946	63380	5930
240	150	27999	<del>15988</del> 1439154	55330	4390
"	"	26658	<del>15389</del> 1391458	53490	4280
270	100	25404	<del>13493</del> 1239137	45170	2890
"	"	23765	<del>1270</del> 1172846	42400	2760
300	50	33190	<del>1631</del> 1464201	52670	<del>3420</del> <sup>o</sup>
"	"	33260	<del>16714</del> 1495743	—	3010
"	"	34222	<del>1688</del> 1509036	55110	3020

Rot Pos	Reg 2 Pos	I	W	II	III
340	4	38385	18497 1632652	59210	3040
"	"	39862	1901 1672190	60380	3180
80	520	21553	1944 1704121	73420	19400
"	"	22767	1997 1744359	76320	20180
60	560	21102	1880 1656512	70330	20530
"	"	21402	1898 1669310	70780	20840

by 704 i.e. corrected for dead time

Ret. Pos	Reg I Pos (8693)	Reg I / N	Reg II / N (5738)	Reg III / N (1.34)
340	4	2266	3362	1958
"	"	2143	3324	1674 1690
"	"	2153 <sup>2162</sup>	3317 3325	1712
"	"	2171	3333	1680
300	50	2068 <sup>2070</sup>	3354	1861 1866
"	"	2072	3344 3349	1870
270	100	1918 <sup>1925</sup>	3423	2218 2195
"	"	1932	3413 3418	2175
240	150	1742 <sup>1750</sup>	3528	2784 2798
"	"	1759	3534 3531	2811
220	200	1624 <sup>1621</sup>	3714	3370 3317
"	"	1617	3669 3691	3264
200	250	1494 <sup>1482</sup>	3799	4009 4002
"	"	1471	3809	3994
180	300	1363 <sup>1361</sup>	3853	4715 4766
"	"	1359	3851 3853	4821
160	350	1247 <sup>1271</sup>	3999	5859 5880
"	"	1275	3949 3974	5901
140	400	1192 <sup>1221</sup>	3995	6937 6990
"	"	1250	3991 3993	7147
120	450	1172 <sup>1171</sup>	3972	8179 8100
"	"	1170	3934 3950	8022
100	480	1143 <sup>1153</sup>	3923	919 9183
"	"	1162	3930 3926	9175
80	520	1143 <sup>1151</sup>	3837	1000 1024
"	"	1160	3849	1049
60	560	1131 <sup>1133</sup>	3789	1123 1128
"	"	1134	3782 3785	1133
80	520	1124 <sup>1125</sup>	3818	1034 1029
"	"	1126	3805 3812	1024

Pat Pos	Reg I pos	Reg I N	Reg II N	Reg III N
100	480	1133	3887	9229
"	"	1117 <sup>1125</sup>	3886 <sup>3887</sup>	9180 <sup>9210</sup>
120	450	1124	3925	8051
"	"	1137 <sup>1131</sup>	3922 <sup>3923</sup>	8067 <sup>8058</sup>
140	400	1181	3872	6773
"	"	1147 <sup>1174</sup>	3884 <sup>3878</sup>	6706 <sup>6735</sup>
160	350	1224	3845	5730
"	"	1221 <sup>1223</sup>	3795 <sup>3820</sup>	5690 <sup>5710</sup>
180	300	<del>1538</del>	3775	<del>5805</del>
"	"	1334 <sup>1334</sup>	3755 <sup>3765</sup>	4789 <sup>4784</sup>
200	250	1445	3684	3974
"	"	1450 <sup>1448</sup>	3707 <sup>3696</sup>	4066 <sup>4010</sup>
220	200	1547	3607	3353
"	"	1572 <sup>1570</sup>	3544 <sup>3576</sup>	3317 <sup>3335</sup>
240	150	1751	3460	2745
"	"	1732 <sup>1742</sup>	3475 <sup>3467</sup>	2781 <sup>2745</sup>
270	100	1882	3347	2142
"	"	1871 <sup>1870</sup>	3338 <sup>3347</sup>	2173 <sup>2155</sup>
300	50	2034	3229	-
"	"	1989 <sup>2010</sup>	- <sup>3246</sup>	1801 <sup>1795</sup>
"	"	2027	3244	1789
340	4	2075	3201	1643
"	"	2096 <sup>2085</sup>	3176 <sup>3189</sup>	1672 <sup>1655</sup>
80	520	1108	3776	9979
"	"	1140 <sup>1124</sup>	3822 <sup>3798</sup>	10110 <sup>9995</sup>
60	560	1122	3740	10920
"	"	1127 <sup>1125</sup>	3729 <sup>3735</sup>	10980 <sup>10950</sup>

4/29/60 Determination of Dead time Correction for  $\text{BF}_3$   
Normalizer

1<sup>st</sup>  $\bar{J}$  Exp. Normalized amp settings unchanged  
Sources  $\sim 12''$  apart  
 $\bar{J} = 1.471 \times 10^{-7}$  min

2<sup>nd</sup>  $\bar{J}$  Exp. Repeat  
 $\bar{J} = 1.464 \times 10^{-7}$  min

3<sup>rd</sup>  $\bar{J}$  Exp. Repeat  
 $\bar{J} = 0.858 \times 10^{-7}$  min

4<sup>th</sup>  $\bar{J}$  Exp. Amplifier settings (PDL) changed  
(see Richards notes)  
 $\bar{J} = 0.5095 \times 10^{-7}$  min

5<sup>th</sup>  $\bar{J}$  Exp. Amplifier settings returned  
to former values  
 $\bar{J} = 1.232 \times 10^{-7}$  min

For data and Calculations see  
folder (Two Source  $\bar{J}$  Expts.)

4/29/60 The Plateau curve on the BF<sub>3</sub> Normalizer was checked. Chamber was operating on something of a slope (Robres has data and Curve). The voltage setting was changed so as to operate on plateau.  
Prior to the adjustment the count rate for a given source was ~~330~~ 290,000 and after adjustment count rate was 330,000, for same source

5/2/60

Determination of dead time corrections  
by Period method

3<sup>00</sup>  
pm

Periods were obtained for BF<sub>3</sub> normalized and  
Reg I BF<sub>3</sub> miniature counter

Linear portion of data for Normalized period  
sent to K-25 for curve fitting

Plot of Reg I data shows no appreciable  
deviation from linearity up to 2 million C/M

Data is in folder

5/3/60

Period measurement of Reg III counter

Note: Reg II counter also in Reg I connected by jumper

11<sup>15</sup>

but counts are not consistent - apparently due to

amplifier

D<sub>2</sub>O = 81 Fuel 18.8 Blade used for period

5/5/60 10<sup>00</sup> AM Check out of Instruments

Normalizer (BF<sub>3</sub>) settings

PDL = 19 Rise time = 1.2 μs

Gain = 4 HV = 1600

#4 preamp connected to Reg II chamber

#3 preamp " " Reg III "



5/5/60  $1 \frac{00}{\mu\text{m}}$  Period run on normalizer to get  
correction factor

## Expt 68

Vertical Traverse Cd-Covered  $U^{235}$  fis. Ctrs.  
 $D_2O \sim 80.6$  Fuel = 18.5 Rot Pos = 161

Lift Pos	Reg I	N	Reg III <del>Reg II</del>	Reg II <del>Reg III</del>	$10^{-4} \sim 3$ 2 min Cts.
11.78 <sup>39</sup>	21906	2275641	4170 <del>53540</del>	53546 <del>4170</del>	"
"	23672	2477916	4510	58710	"
"	24135	2538116	4650	60330	"
"	24718	2551940	4620	60450	"
11.00	17248	1766827	3410	43700	2 min Cts
"	27587	2818530	5330	69050	4 " "
9.60	26757	2553575	5190	67370	"
"	31041	2977110	6210	79330	"
8.00	32873	3033389	6520	83800	
"	34728	3206225	7000	89180	
6.50	35724	3271240	7220	90930	
"	36613	3335299	7390	92720	
5.00	40684	3813530	8060	103680	
"	43540	4071170	8830	110860	
3.50	34229	3401291	6880	86350	
"	35923	3525672	7040	89450	
2.00	31420	3401171	6190	77140	
"	31349	3477421	6110	78830	
3.00	30554	3150940	5910	76860	
"	30232	3097930	5780	75390	

Lift Pos	Reg I	N	Reg III	Reg <del>III</del> II	4 mi cts
4.50	28492	2722816	5440	71310	"
"	27137	2591733	5150	67680	"
6.00	38339	3472634	7440	95500	"
"	38463	3542570	7640	97860	"
7.50	38601	3421418	7430	95090	"
"	35257	3242229	6900	89930	"
9.00	37699	3482906	7220	94820	"
"	37110	3474929	7340	94630	"
10.50	34290	3360071	6680	86410	"
"	31196	3079685	6100	77910	"

Notes: Reg IV pre-amp and amp & scaler used with Reg II chamber

	Lift Pos.	Reg I / N	Reg III / N	Reg II / N	Reg I / N	Reg II / N	Reg III / N
F	11.78	9630	1832	2353	X.8695	X.5738	X.134
967	"	9655	1820	2369	930	2288	1765
	"	959 <sup>1021</sup>	1832 <sup>1825</sup>	2377			
	"	969	1810	2368			
987	11.00	976 <sup>977</sup>	1930	2473	964	2429	1934
	"	978	1891	2449			
X1	9.50	1048 <sup>1046</sup>	2032	2638	1046	2651	2058
	"	1043	2085	2664			
987	8.00	1084 <sup>1084</sup>	2149	2763	1070	2736	2137
	"	1083	2183	2781			
985	6.50	1092 <sup>1095</sup>	2207	2779	1076	2737	2178
	"	1098	2215	2779			
970	5.00	1067 <sup>1068</sup>	2114	2718	1036	2639	2078
	"	1069	2168	2723			
979	3.50	1006 <sup>1012</sup>	2022	2538	991	2485	1968
	"	1019	1997	2537			
979	2.00	923 <sup>913</sup>	1820	2268	894	2220	1750
	"	902	1757	2267			
985	3.00	970 <sup>973</sup>	1874	2439	958	2399	1843
	"	976	1866	2433			
X1	4.50	1044 <sup>1047</sup>	1997	2418	1047	2613	1992
	"	1047	1987	2409			
979	6.00	1104 <sup>1095</sup>	2142	2750	1072	2698	2103
	"	1086	2156	2762			
979	7.50	1128 <sup>1107</sup>	2172	2779	1084	2718	2105
	"	1087	2128	2773			
979	9.00	1082 <sup>1075</sup>	2073	2722	1052	2666	2049
	"	1068	2112	2723			
987	10.50	1020	1988	2571	1003	2518	1958
	"	<del>976</del> 1016	<del>1984</del> 1984	<del>2533</del> 2551			
	"	1012	1981	2530			

5/6/60

Exp. 70

Run A

BF<sub>3</sub> Normalizer

BF<sub>3</sub> mixture in kg

waiting

counting

135160F
160000F
162254F
18974F
198703F
24296F
247639F
30192F
314554F
37008F
397025F
45296F
496056F
55332F
641510F
67534F
805935F
83470F
999746F
101332F
1231364F
124255F
1461476F
152789F
1531557F
162821E

# Void Coefficient Measurements

239.

5/6/60

Exp. 69

2<sup>00</sup>

System Crit at Fuel Selsyn = 18.08

2nd Tad selsyn = 18.40

Blade up 3rd Cd-Covered counters in  
Reg II + III ~~at Rot. pos of 340 and diff = 7.04~~  
lowered to bottom  
no void

200<sup>5/6/60</sup>  
7<sup>00</sup>

Exp. 70

Run A

1C-3 Calibrated Normalizer and Reg I BF<sub>3</sub>

Chamber attached to Print Out scales

14 polystyrene tubes containing air [rubber stoppers] clustered  
in center - Center region filled with H<sub>2</sub>O otherwise

Crit <sup>fuel</sup> Selsyn 17.27 | crit → | tad Selsyn 18.77

Period Fuel 17.29 | | Period Selsyn 20.05

3<sup>30</sup>

Leveling to Crit with Tad Selsyn = 18.77  
still Crit.

240

5-9-60

## Expt 70 Run A'

Recheck of Run A.

System crit at 17.31" Tadadder 12.99  
 Tadadder to 14.24" for  
 period. After period moved Tad back  
 to 12.99 and system still crit.

Expt. 70

Run B.

36- $\frac{1}{2}$ " OD ~~tube~~ tube containing air in Reg I  
 1C3 & 1C4 recalibrated | water outside  
 crit height 16.38" tube  
 & Tadadder at 10.05

Period: lig level 16.41 TA 11.50  
 not crit at same Tad. height  
 crit at Tad = 10.26..

11<sup>55</sup> A Shut down by lowering Tadadder to 99.543

12<sup>10</sup> Insert source

Log N (Red) reads  $8 \times 10^{-13}$

" (blue)  $1.4 \times 10^{-11}$

Both <sup>log</sup> instruments need lead shielding

Add 2" lead on Red log N

Temp.	Reg I	16.7
	Reg III	17.0 °C
	Reg IV	17.3
	Gas.	18.0

EXPT 70  
Run B'

Repeat of Run B to check on sh.

Crit  $14.39''$  & Tad =  $10.22$ 

Tad. to 11.50 for period

level After Period lig level =  $16.40$  + A =  $10.25$ EXPT 70  
Run C47 -  $\frac{1}{2}''$  O.D. x  $\frac{3}{8}''$  I.D. Polystyrene tubes dry inside

43 - " " Polyethylene " " "

Tubes surrounded by water

Crit at  $15.21$  & Tad =  $9.56$ Period  $15.237$  + A  $10.80$ level After Period lig level =  $15.218$  + A =  $9.79$  $3^{28}$  PM Dump Soln to  $9.38$ 

## Exp 70 Run D

47  $\frac{1}{2}''$  O.D. x  $\frac{3}{8}''$  I.D. Polystyrene Tubes } dry inside

43 " " Polyethylene Tubes } out out.

Polyethylene bottle filled with  $H_2O$  inserted for  
center region I top reflectorCrit At lig level =  $14.948$  + A =  $9.25$ Period " " =  $14.97$  " =  $10.50$ Crit at  $14.957$  Tad =  $9.58$ 

Shut down

242

5-10-60 Exp # 70

9<sup>46</sup> AM E.R.R. worked on soln lig level  
 Zero checked Approx 0.02"  
 Calib checked on IC-3-4 By DWM (OK)

## Run E

47- Polystyrene Tubr  $\frac{1}{2}$ " ODX  $\frac{3}{8}$ " ID

43 Polyethylene " " " "

28 of the tubes were filled with H<sub>2</sub>O  
 All other + interstitial spaces are in  
 air

System out at 14.76; Tod at ~~12.15~~ 12.10

For period; Tod. at 13.40; soln ht 14.795

11<sup>20</sup> level After Period lig level 14.764 + A 12.10  
 Drain soln to 8.98"

## Expt 70 Run F

1<sup>32</sup> PM No water or plastic in reg I  
 except for stop refl. can

System out 17.59 Tod. at 11.75"

For period raised Tod to 13.00"

2<sup>02</sup> level After Period lig level 17.58 + A 11.82  
 Drain soln to 9.95"

Reg III - 17.2°

Reg IV - 18.0



5-11-60

Expt 71

LWG &amp; KF cc

## Run A

8-1" Dia. Al rods clustered in center  
of Reg F  
crit at 14.61"

## Run B

9<sup>10</sup> AM

14-1" Dia Al Rods clustered in center  
of Reg I

crit Ht = 15.89"

## Run C

10<sup>00</sup> AM

20-1" Dia. Al Rods randomly spaced  
in Reg I

crit at 15.56

## Run D

24-1" Dia. Al rods randomly spaced  
(except that spaces very nearly full)

crit at 15.76

Expt 71

Run E

11<sup>25</sup> To test crit conditions with H<sub>2</sub>O  
only use Reg I  
crit at 17.69"

Test for ~~the~~ height reading at just ~~the~~ zero  
check very closely.

Temp Reading	Reg I	20.2° C
slat 20.1	Reg III	19.2
	Reg IV	19.8

5-11-60

Sampler of Fuel soln taken  
# 15A, 15B & 15C  
L sent to Cooper

Sample of D<sub>2</sub>O taken 9-D

Sampler 9-D and 15B to Harman

EXPT 72

Zero Calibration

Selsyn reading	Jadadder ht.
0.120	8.45
0.110	8.00
0.097	7.50
0.090	7.00
0.084	6.50
0.078	6.00
0.069	5.50
0.057	5.00
0.047	4.50
	4.00

→ 99.879  
99.651  
99.436

## Expt. 72

5-12-60

## Reactor height calibration

calib. at top!

Fuel assembly	17.66"	rod added ht	3.60"
	17.68		4.60
	17.69		5.60
	17.735		6.60
	17.785		7.00
	17.855		7.40
	17.935		7.80
	18.035		8.20
	18.11		8.60
	18.20		9.00
	18.29		9.40

5-12-60

## Expt 73 - A

## Control Rod Calibration

Out at 18.48 Control Rod at zero.

For period  
 Run control rod back " " " 6.25"  
 still out

For 2<sup>nd</sup> period control rod raised to 3.00"

Lowered rod to sub. crit.

crit at 18.30 with rod at 3.00"

Raised rod to 7.00" for 3<sup>rd</sup> period

Lowered " for check on crit position: 4.78

Raised rod from 4.78 to 9.00 for period.

Lowered " crit at 5.10

5-13-60 Exp # 73-B JRF SWH cc

Purpose: Control Rod Calibration

Crit HT  $18.48^{13}$ " Control Rod 7.0"

Per HT 18.13 " " 11.0"

9<sup>22</sup> AM

lower Control Rod to 7.0"

Crit at 6.68

lower Power level with Tad Adder

Crit HT 17.86 Control Rod 9.0"

Per HT 17.86 " " 14.0"

Crit HT After Period 17.86 " " 21.45"

Per HT 17.86 " " 18.00"

Crit at 12.00

lowered Control Rod to 7.0" And

leveled with TA Crit HT 18.11

Per HT 18.11 Control Rod 10.0"

Crit at 7.08

2" OD. Tadadder Calibration

37.78 CC/m

16A & B taken sent to Harman

100 g/L

$$67 \frac{D}{D+H}$$

(65-70)

$$\textcircled{1} \frac{D}{D+H} = 65-70$$

$$\textcircled{2} 0.000275 \frac{6^{235}}{\text{atom}} \text{ born in}$$

$\rightarrow 100 \text{ g/L}$

$\textcircled{3}$  B Adjust B  
in repl -

9<sup>00</sup> AM 5-16-60

5-16-60

241

Expt. 74 A

Test reactivity at near full

crit. at 17.70	Fad.	<del>+3.41</del>
Pos. period 17.904	"	<del>17.27</del>
crit 17.697		13.37
		$\frac{34 \text{ cm}^3}{17 \text{ cm}^3} \approx \frac{0.90 \text{ "}}{.1 \text{ "}} \approx 2 \text{ "}$

74 B

crit 17.90	<del>+4.30</del>
pos. period 18.35	16.28
crit. at 17.937	14.50
	$\frac{67.3 \text{ cm}^3}{16.4 \text{ cm}^3} \approx \frac{1.78 \text{ "}}{.10 \text{ "}} \approx 141$

1<sup>st</sup> Period from 17.70" → 17.9" using 50% photo neut.  
 $\rho = 2.37 \times 10^{-4}$  ( $T = 432$ )  
 $\rho/\lambda = 11.85 \times 10^{-4}$

2<sup>nd</sup> Period from 17.94 → 18.35  
 $\rho = 6.52 \times 10^{-4}$  ( $T = 124$ )  
 $\rho/\lambda = 15.9 \times 10^{-4}$

1<sup>st</sup> period  $\rho/\lambda_{\text{ad-ah}} = 3.39 \times 10^{-4}$

2<sup>nd</sup> period  $\rho/\lambda_{\text{ad-ah}} = 4.76 \times 10^{-4}$

5-16-60

Added 4l of H<sub>2</sub>O to fuel tank.

248

5-17-60

## Expt 75A

After adding 6 l. of H<sub>2</sub>O and mixing  
Test for critical conditions

906

Crit HT 14.61" TA 18.65

Pos Per HT 14.632 " 19.94 T=207

Crit at " 18.66

$$P_T = 4.26 \times 10^{-4}, P_{\text{lim}} = 3.33 \times 10^{-4} \times \frac{2.8}{0.1384} = 3.28 \times 10^{-2}$$

Drained added 2<sup>nd</sup> 6 l H<sub>2</sub>O & mixed

Tempr. Reg I - 24.1; Reg III 24.1; Reg IV 25.7; Slot 24.5

## EXPT 75B

After 2<sup>nd</sup> addition of 6 l. H<sub>2</sub>O

1050

Crit HT 12.926 TA 12.72

Pos Per TA 14.00 T=169 sec

Crit HT 12.936 TA 12.72  
1.28

$$P = 3.15 \times 10^{-4}, P_{\text{lim}} = 4.02 \times 10^{-4} \times \frac{1}{0.1384} = 2.90 \times 10^{-3}$$

## 75-C

12<sup>45</sup> Add 6 l H<sub>2</sub>O and Mix (3<sup>rd</sup> addition)  
test for Crit HT 11.94 TA 18.08

Positive Period TA 19.38 T=144 sec

Crit at 18.06

$$\Delta TD = 1.29$$

$$\rho = 5.65 \times 10^{-4}$$

$$\rho_{\text{lim}} = \frac{5.65}{1.29 \times 0.1384} = 3.16 \times 10^{-2}$$

5-17-60

249

Exp # 75-D

Add 6 L  $H_2O$  <sup>to soln</sup> And Mix [Total of 24L  $H_2O$ ]  
 test for crit HT

2<sup>42</sup>

Crit HT	11.34	+ A	6.62
---------	-------	-----	------

Pos Per	11.369	T = 134 sec	7.87
---------	--------	-------------	------

Crit. at	11.34		6.62
----------	-------	--	------

$$\rho = 5.98 \times 10^{-4}$$

$$\frac{\rho}{\dot{m}} = \frac{5.98 \times 10^{-4}}{.01384 \times 1.25} = 3.46 \times 10^{-2} / \text{in fuel}$$

Temp Reg I: 24.7; slab 25.1; Reg III 24.7, Reg II 25.1  
 Added ~ 100 gm  $Na_2B_4O_7$  to  $D_2O$  Refl.

S mixed

5-18-60

Expt 76 A

Test on crit condition

9<sup>36</sup>

Crit HT	12.44	+ A	17.80"
---------	-------	-----	--------

Per HT	12.46	+ A	19.00"
--------	-------	-----	--------

After Per

Crit HT	12.44	+ A	17.80
---------	-------	-----	-------

9<sup>50</sup>

Dump soln	AND $D_2O$	T = 17.9	$\rho = 4.77 \times 10^{-4}$
-----------	------------	----------	------------------------------

$$\frac{\rho}{\dot{m}} = \frac{4.77}{.01384 \times 1.20} = 2.87$$

Added ~ ~~122~~<sup>212</sup> gms  $Na_2B_4O_7$  S  
 mixed



250

Expt 76 B Total 372

Crit. Cond. after adding 212 gm.

1 <sup>31</sup> PM	Crit Ht 13.755	+ A	11.40
	Per .. 13.776	+ A	12.61
	After Per 13.752	+ A	11.34

2<sup>02</sup> Dump Soln AND D<sub>2</sub>O

$$T = \frac{2.11}{1.19} \text{ sec (6 photos)} \rho = \frac{4.20}{4.27} \times 10^{-4}$$

$$\rho/\bar{c} = \frac{4.20}{0.1384 \times 1.27} = 2.39 \times 10^{-2}$$

5-19-60

Expt. 76 C

Crit Condition after adding another  
500 gm Na<sub>2</sub>BuO<sub>7</sub> Total ~ 812 gm

60  
872

With no D<sub>2</sub>O in refl. fuel was pumped  
up to full with only a small increase  
in Mkt. level.

12<sup>33</sup>

Cont Exp # 76C

start feeding D<sub>2</sub>O into system Reactor1<sup>09</sup>

Crit Ht 15.245	+ A	20.22
----------------	-----	-------

1<sup>21</sup>

Crit Ht 15.246	+ A	15.29
----------------	-----	-------

Per Ht 15.27	$\rho = 3.38 \times 10^{-4}$	+ A	16.50
--------------	------------------------------	-----	-------

level After Period		15.29
--------------------	--	-------

Crit Ht 15.245		<u>1.21</u>
----------------	--	-------------

1<sup>37</sup>Dump Soln AND D<sub>2</sub>O

$$\rho/\bar{c} \text{ fuel} = \frac{2.44 \times 10^{-2}}{2.02}$$

Temp. Ref I - 23.7, Ref III - 26.1, Ref IV 25.4

5-20-60  
Expt. 74 D

251

After adding another 1200 gm  $\text{Na}_2\text{B}_4\text{O}_7$  & mixing (Total 2072)

Preliminary crit ht: 17.19, Dumped  $\text{D}_2\text{O}$  for further mixing.

Crit ht. 17.193      Tad. 15.25  
Pos. period 17.21      16.50

level After Period

Crit ht 17.193      + A 15.25

147. Dump soln AND  $\text{D}_2\text{O}$

$$T = 313 \text{ sec } q = 3.07 \times 10^{-4} \quad S/\text{in} = \frac{3.07}{1.25 \times 0.01384} = 1.78 \times 10^{-2}$$

5-23-60

Expt. 76 E

Added ~ 300 gm  $\text{Na}_2\text{B}_4\text{O}_7$  to  $\text{D}_2\text{O}$  & mixed

902 Crit ht 17.44      Dumped  $\text{D}_2\text{O}$  for check on mixing

Crit ht. 17.43      Tad. 15.25  
Pos. pu.      "      ~~00080~~ 80

Out. at

99910 - 90  
00080 - 80  

---

1.70

$$T = 274 \text{ sec } q = 3.42 \times 10^{-4} \quad \frac{q}{C} = \frac{3.42}{1.70 \times 0.01384} = 1.45 \times 10^{-2}$$

252

5-23-60

Expt 76 F

Added 300 gm  $\text{Na}_2\text{B}_4\text{O}_7$  & mixedPreliminary cut ht. 17.52 Dumped  $\text{D}_2\text{O}$   
for mixing

Cut ht. 17.54 TAP 899 "

Posttime period " 10.50

cut at " 887

1.63 "

$$F = \frac{278500}{252} \quad \rho = 3.38 \times 10^{-4} \quad \frac{P}{\omega} = \frac{2.38 \times 10^{-4}}{1.63 \times 0.01384} = \frac{1.56 \times 10^{-2}}{2.26 \times 10^{-2}}$$

5-24-60

Expt. 76 G

Added ~600 gm  $\text{Na}_2\text{B}_4\text{O}_7$  to system  
and mixed.Preliminary test; not cut full, Dumped  
 $\text{D}_2\text{O}$  for further mixing

Repeat still 2nd critical full

10<sup>45</sup>Add 4L  $\text{D}_2\text{O}$  to  $\text{D}_2\text{O}$  system

Jumps. Reg I 22.4, Reg III 22.5, Reg IV 24.2

5-24-60

253

### Expt 76H

After adding 4 l pure D<sub>2</sub>O to P<sub>2</sub>O  
system & mixing

sub. crit tube full: Fuel to 20.4

Added 4 l more D<sub>2</sub>O to system

### Expt 76I

Test for crit with total of 8 l. D<sub>2</sub>O added  
slightly sub with fuel at 23.49"

Added 2 l D<sub>2</sub>O & mixed.

### Expt 76J

Crit. with fuel at 21.4

Added 2 l D<sub>2</sub>O & mixed

### Expt 76K

Crit. at 20.7"

5-25-60 Repeat as check of reactivity

crit ht 20.73

Added 6 l D<sub>2</sub>O & mixed

Expt 76 L

Test for crit. with total of 18l D<sub>2</sub>O  
added.

crit at 19.44

Temp. Reg I - 22.5, Reg II - 25.1, Reg IV 22.9

Expt 76 M

Test for crit. with total of 28l D<sub>2</sub>O  
added.

crit. ht. 18.32

Expt. 76 N

Test for crit with total of 34l D<sub>2</sub>O  
in system

crit at 17.58"

Repeat after dumping D<sub>2</sub>O

crit at 17.71

4<sup>00</sup> PM Reg & relay = 510 when counter is at center  
 = 8 " " " " edge

5-25-60 Sample of fuel taken #17A, 17B  
 17B sent to Harman; ~ 70.5 at 3 D

Sample 10-D-1 & 2 taken of D<sub>2</sub>O  
 Harman: 99.8 at 3 D

5-26-60

Expt. 76-0

Test for crit. condition with cd-  
 covered counter in reactor & same D<sub>2</sub>O  
 poison as 74N

Not crit except with source when  
 counter rotated to 340 & fuel at 23.8"

Added 6l pure D<sub>2</sub>O to system & mixed.

17A: 113.7  $\frac{\text{mg D}}{\text{ml}}$  sp gr. 1.226 at 23°

$\frac{g^B}{l}$  in eq 2 = 2.35

256

Exp. 77

5/26/60 Cd-covered 235 Radial traverse

2 <sup>30</sup>

Cent ht  $\approx 22.8$ ; Reg I selcyn = 510 at center and 8 at wall

10-4  $\approx 8$

Rot Pos	Reg II Pos	N	I	II	III	IV	Rot Pos.	
			5 min counts					107
<del>107</del>	<del>520</del>						130	
107	520	3486430	92380	141610	434 <sup>x64</sup> +48	27824	"	
"	"	3490220	90970	141320	429 <sup>x64</sup> +2	27458	171	
130	400	4050280	108510	161940	415 <sup>x64</sup> +27	26587	"	
"	"	4006660	108260	159530	410 <sup>x64</sup> +3	26283	21	
171	305	3927040	117240	149050	273 <sup>+27</sup>	17499	250	
"	"	4108590	123070	156370	287 <sup>x64</sup> +2	18410	"	
210	240	4351950	<del>142320</del> 152740	152740	211 <sup>x64</sup> +68	13565	300	
"	270	4467650	144730	156090	219 <sup>x64</sup> +0	14016	"	
250	165	3916880	141240	124500	135+0	8640	346	
"	"	3990040	144520	126320	135+20	8660	"	
300	110	3602120	139050	103390	91 <sup>x64</sup> +62	5886	97	
300	115	3425620	131100	98020	85+7	5447	104	
346	92	3172920	125770	88390	72+54	4662	161	
"	"	3081990	121940	85100	69 <sup>x64</sup> +40	4456	191	
97	460	3175490	82030	126050	412 <sup>x64</sup> +46	26414	"	
"	"	3408730	88110	135860	441+25	28249	"	
104	500	4100490	106360	165510	513+41	32873	"	
161	279	4414280	134750	168940	340+44	21804	"	
191	237	4843910	157200	175520	278 <sup>x64</sup> +43	1783	"	
4	44	shut down						

HFIR Exp. 77

Rot Pos.	Reg I Pos	I/N	II/N	III/N
		.3745	.4077	1.184
107	520	.02649 <sup>2628</sup>	.04062 <sup>4019</sup>	.007980 <sup>7923</sup>
"	"	.02607	.04049 <sup>4019</sup>	.007867
130	400	.02679 <sup>2690</sup>	.03998 <sup>3989</sup>	.006564 <sup>6562</sup>
"	"	.02701 <sup>2690</sup>	.03980 <sup>3989</sup>	.006559 <sup>6562</sup>
171	305	.02985 <sup>2990</sup>	.03795 <sup>3800</sup>	.004456 <sup>4468</sup>
"	"	.02995 <sup>2990</sup>	.03806 <sup>3800</sup>	.004480 <sup>4468</sup>
210	240	.03270 <sup>3257</sup>	.03509 <sup>3501</sup>	.003117 <sup>3127</sup>
"	"	.03239 <sup>3257</sup>	.03493 <sup>3501</sup>	.003137
250	165	.03605 <sup>3614</sup>	.03179 <sup>3172</sup>	.002205 <sup>2218</sup>
"	"	.03622 <sup>3614</sup>	.03165 <sup>3172</sup>	.002170 <sup>2178</sup>
300	110	.03860 <sup>3844</sup>	.02870 <sup>2866</sup>	.001634 <sup>1612</sup>
"	115	.03827 <sup>3844</sup>	.02861 <sup>2866</sup>	.001590
346	92	.03963 <sup>3940</sup>	.02785 <sup>2773</sup>	.001469 <sup>1457</sup>
"	"	.03956 <sup>3940</sup>	.02761 <sup>2773</sup>	.001445 <sup>1457</sup>
47	460	.02583 <sup>2574</sup>	.03969 <sup>3977</sup>	.008318 <sup>8302</sup>
"	"	.02584 <sup>2574</sup>	.03985 <sup>3977</sup>	.008287 <sup>8302</sup>
704	500	.02594	.04036	.008017
761	279	.03052	.03826	.004939
791	237	.03245	.03623	.003681



Expt 78

257

Cd-covered U<sup>235</sup> Vertical Traverse  
 Reg I-520, Rot. Pos = 161

5/27/60

Temp Reg I = 22.5°, Reg III = 24.4°, Reg IV = 24.2°

Lift	Norm	Reg I	Reg II	Reg III	Reg IV
<del>Pos</del>		5 min. counts			
11.77	2997840	71210	99320	740 <sup>x16</sup> +1	11840
"	3406370	83710	111020	208 <sup>x64</sup>	13310
10.50	3802060	94480	135670	<del>266<sup>x64</sup></del> 474 <sup>x12</sup>	17024
"	3922740	97260	140200	262 <sup>x64</sup>	16768
9.00	2618850	67090	98210	185 <sup>x64</sup> +0	11840
"	2568290	65990	95990	181 <sup>x64</sup> +32	<del>11610</del> 11540
7.50	2745500	71430	105810	203 <sup>x64</sup> +12	13004
"	2955550	76520	113630	219+0	14016
6.50	2902940	74040	111780	210 <sup>x64</sup> +61	13501
"	2863450	73560	110160	207+0	13248
5.00	3568870	87900	132430	248+33	15905
"	3588160	88960	133610	250+39	16039
3.50	3795160	85840	130820	245+7	15687
"	3803750	86450	129910	249+48	15984
1.50	3574380	65290	101180	189+18	12114
1.50	3197110	58130	90410	169+46	10862
1.00	3686320	62590	97340	183+54	11766
2.50	2858620	58370	89500	169+40	10856
4.00	2540300	59050	88950	167+32	10720
5.50	2264480	56640	84950	156+53	10037
7.00	2181790	55930	83500	155+29	9949
8.50	2267780	58250	84960	161+44	10348
10.00	2866530	71530	102350	194+1	12417
11.50	3650530	84000	118760	219+25	

check count

HFIR Exp. 28

Li++ Pos	F/N	<del>F/N</del> <sup>II</sup>	<del>F/N</del> <sup>III</sup>	
11.77	.02375 <sup>2416</sup>	.03313 <sup>0329</sup>	.003949	.0392
"	.02457	.03258	.003907	
10.50	.02485 <sup>2482</sup>	.03568 <sup>0357</sup>	.004477	445
"	.02479	.03574	.004274	
9.00	.02561 <sup>2565</sup>	.03750 <sup>03745</sup>	.004521	452
"	.02569	.03737	.004523	
7.50	.02602 <sup>2604</sup>	.03853 <sup>0385</sup>	.004736	474
"	.02585 <sup>2588</sup>	.03843	.004742	
6.50	<del>.02344</del>	.03850	17	
	.02551 <sup>2560</sup>	.03850	.004650	444
"	.02569	.03847	.004627	
5.00	.02463 <sup>2471</sup>	.03709 <sup>0371</sup>	.004456	446
"	.02479	.03723	.004470	
3.50	.02261 <sup>0221</sup>	.03414 <sup>0341</sup>	.004133	417
"	.02273	.03415	.004202	
1.50	.01826 <sup>0182</sup>	.02831 <sup>0283</sup>	.003389	0339
"	.01818	.02827	.003396	
1.00	.01698	.02640	.003192	
2.50	.02041	.03131	.003798	
4.00	.02324	.03501	.004220	
5.50	.02501	.03751	.004432	
7.00	.02563	.03827	.004559	
8.50	.02568	.03746	.004563	
10.00	.02495	.03570	.004331	

1.78

6-1-60

List Pos

Rot. pos. = 161

Reg I pos = 520

N

I

II

III

IV

11.78 <sup>205</sup> / <sub>PM</sub>	165100	407470	40320	<sup>464</sup> 48+20	3092	52+17	3345
"	178430	437110	43360	<sup>44</sup> 49+37	<del>313</del> 3173	57+48	3696
10.50	191030	498170	50550	56+30	3614	67+20	4308
"	189680	493930	50730	55+54	3574	66+4	4228
9.00	188300	516260	53370	58+59	3771	73+37	4709
"	190090	516900	53400	57+17	3729	71+43	4587
8.00	191230	530380	55580	62+14	3982	75+12	4812
"	197480	546630	56920	61+49	3953	75+29	4829
7.00	196190	539410	57270	62+47	4015	79+12	5068
"	192560	529580	56070	62+32	4006	75+42	4842
6.00	192380	516040	54970	60+45	3885	76+55	4919
"	195660	525930	56040	60+43	3883	76+35	4899
5.00	197010	506540	54600	59+56	3832	75+6	4806
"	194400	496540	53770	57+33	3681	74+55	4791
4.00	394190	950600	103800	116+7	7431	<sup>464</sup> 143+59	9211 <sup>Change 6</sup> 2 <sup>min</sup>
"	407050	887040 ?	107620	116+51	7475	148+22	9494
2.50	409640	870020	96020	108+61	6973	133+23	8535
"	396620	841260	92670	106+53	6837	131+41	8425
1.00	398660	684950	77820	97+51	6259	112+27	7195
"	399690	687640	78200	98+22	6294	114+47	7343
2.00	388810	772620	85320	99+37	6373	124+24	7960
"	384330	400150 ?	84280	96+14	6158	122+7	7815

2 260

Exp. 79

Lift Pos	N	I	II	III	IV
3.50	354600	825100	87860	99+10 6346	126+35 8099
"	343170	797120	86350	97+51 <del>6259</del> 6654	121+0 7744
4.50	344850	857720	92490	101+23 8099	128+22 8244
" 3 <sup>23</sup> PM	357670	181740	96160	106+43 6827	134+26 8582
5.50	345760	912250	96720	104+50 6706	134+25 8601
"	341080	895920	94550	102+25 6553	131+28 8392
6.50	335400	912900	95640	104+23 6679	134+32 8416
"	333440	905280	94570	104+14 6670	130+23 8343
7.50	341860	945950	97490	106+13 6797	133+22 8534
"	344660	951450	98250	110+51 7091	133+25 8547
8.50	345830	950220	96920	106+11 6795	130+32 8352
"	337770	926010	94730	104+55 6711	127+16 8144
10.00	340030	893980	90250	99+0 6336	120+4 7684
"	340980	899570	90000	99+20 6356	118+50 7602
11.00	352080	887240	87280	99+46 6382	114+4 7300
"	368100	925980	91400	101+12 6476	119+12 7628
11.78	385180	919600	88480	101+36 6800	112+23 7191
" 4 <sup>13</sup> PM	395490	946340	92660	105+12 6732	112+37 7205
10.50	399950	1027020	102590	113+29 7261	135+51 8691
"	411610	1051990	105370	118+45 7597	141+11 9035
9.00	403250	1092420	101360	122+37 7845	149+47 9573
"	398880	1081480	110010	119+22 7638	146+49 9393

19674

Z	List	I/N	II/N	III/N	IV/N
		X0.3623	0.3944	1.148	0.3433
8099	11.78	2468	2442	1872	2026
	"	2449 <sup>2457</sup>	2430 <sup>2435</sup>	1778 <sup>1825</sup>	2091 <sup>205</sup>
7744	10.50	2608	2646	1892	2255
	"	2604 <sup>2606</sup>	2674 <sup>2660</sup>	1884 <sup>1888</sup>	2229 <sup>224</sup>
844	9.00	2742	2834	2002	2501
8582	"	2719 <sup>2730</sup>	2810 <sup>2822</sup>	1961 <sup>1980</sup>	2412 <sup>2460</sup>
8601	9.62	8.00	2774	2906	2082
	"	2767 <sup>2770</sup>	2882 <sup>2893</sup>	2002 <sup>2040</sup>	2445 <sup>2517</sup>
8392	8.62	7.00	2749	2918	2046
	"	2750 <sup>2750</sup>	2918 <sup>2915</sup>	2077 <sup>2055</sup>	2514 <sup>2583</sup>
8416	7.42	6.00	2669	2857	2019
	"	2687 <sup>2675</sup>	2864 <sup>2860</sup>	1984 <sup>1995</sup>	2503 <sup>2556</sup>
8343	6.62	5.00	2554	2771	1945
	"	2554 <sup>2554</sup>	2767 <sup>2767</sup>	1893 <sup>1925</sup>	2464 <sup>2439</sup>
8534	5.62	4.00	2411	2633	1857
	"	<del>2419</del>	2643 <sup>2637</sup>	1836 <sup>1845</sup>	2332 <sup>2336</sup>
8547	4.12	2.50	2124	2344	1702
	"	2121 <sup>2123</sup>	2337 <sup>2340</sup>	1723 <sup>1715</sup>	2123 <sup>2083</sup>
8352	2.62	1.00	1718	1952	1570
	"	1720 <sup>1719</sup>	1956 <sup>1954</sup>	1574 <sup>1572</sup>	1837 <sup>1804</sup>
8144	3.62	2.00	1987	2194	1639
	"	1941 <sup>?</sup>	2192 <sup>2193</sup>	1602 <sup>1620</sup>	2033 <sup>2047</sup>
7684	5.12	3.50	2326	2534	1789
	"	2322 <sup>2324</sup>	2516 <sup>2525</sup>	1823 <sup>1805</sup>	2284 <sup>2256</sup>
7602	6.12	4.50	2487	2682	1908
	"	5081	2688 <sup>2684</sup>	1908 <sup>1838</sup>	2399 <sup>2382</sup>
7300	7.12	5.50	2638	2797	1939
	"	2626 <sup>2630</sup>	2792 <sup>2782</sup>	1921 <sup>1930</sup>	2460 <sup>2487</sup>
7628	1.81				
7191	1.62	1	1.78	1.62	1.81

Exp. 79 (cont) page II

	Light	7/N	□/N	□/N	□/N
8.12	6.50	2721 <sup>2718</sup>	2851 <sup>2844</sup>	1991 <sup>1996</sup>	2509 <sup>2506</sup>
	"	2714	2836 <sup>2844</sup>	2001 <sup>1996</sup>	2502 <sup>2506</sup>
9.12	7.50	2767 <sup>2764</sup>	2851 <sup>2851</sup>	1988 <sup>2023</sup>	2496 <sup>2488</sup>
	"	2760	2850 <sup>2851</sup>	2057 <sup>2023</sup>	2479 <sup>2488</sup>
10.12	8.50	2748 <sup>2745</sup>	2802 <sup>2803</sup>	1965 <sup>1976</sup>	2415 <sup>2413</sup>
	"	2741	2804 <sup>2803</sup>	1986 <sup>1976</sup>	2411 <sup>2413</sup>
11.62	10.00	2629 <sup>2634</sup>	2654 <sup>2647</sup>	1863 <sup>1863</sup>	2260 <sup>2245</sup>
	"	2638	2640 <sup>2647</sup>	1863 <sup>1863</sup>	2229 <sup>2245</sup>
2.62	11.00	2519 <sup>2517</sup>	2478 <sup>2491</sup>	1812 <sup>1785</sup>	2073 <sup>2073</sup>
	"	2515 <sup>2517</sup>	2483 <sup>2491</sup>	1759 <sup>1785</sup>	2072 <sup>2073</sup>
3.40	11.78	2387 <sup>2390</sup>	2297 <sup>2320</sup>	1687 <sup>1695</sup>	1866 <sup>1844</sup>
	"	2392	2342 <sup>2320</sup>	1702 <sup>1695</sup>	1822 <sup>1844</sup>
2.12	<del>7.50</del> 10.50	2568 <sup>2562</sup>	2565 <sup>2563</sup>	1815 <sup>1830</sup>	2173 <sup>2184</sup>
	"	2556 <sup>2562</sup>	2560 <sup>2563</sup>	1845 <sup>1830</sup>	2195 <sup>2184</sup>
0.62	9.00	2708 <sup>2710</sup>	2762 <sup>2760</sup>	1945 <sup>1929</sup>	2373 <sup>2364</sup>
	"	2711	2757 <sup>2760</sup>	1914 <sup>1929</sup>	2355 <sup>2364</sup>
	1.62				

6/2/60

Exp. 80

261

Purpose: Determine relative counting efficiency of 235 counters with following amplifier settings (these are settings for experiments 77, 78, 79, 80, 81)

	Gain	RT	PDL
C-1	32	0.2	10
C-2	32	0.2	15
C-3	32	0.2	15
C-4	32	0.2	15

10<sup>30</sup>

Region I counter (~~and pump~~) placed in center of Reg IV (vertically and radially)

#1 Counter (in IV)	Normalizer		$\frac{I}{N}$
71810	2758340	10 min count	0.02603
80730	3200340	"	0.02522
82860	3346580	"	0.02476
88970	3553860		0.02503
			<u>AVG. 0.02524</u>

See page 264

262

6/2/60

1<sup>00</sup>/<sub>8</sub> m

Reg I counter placed in center of (vent of) region III

Reg I (in Reg III)	Norm	$\frac{I}{N}$
169710	2617880 10 min counts	0.06482
185520	2872610	0.06458
173710	2698420	0.06437
		<u>.06459</u>

See page 244

Reg I counter (in Reg III)	Normalizer	
848670	2782960	0.3049
861710	2851660	0.3022
838500	2771810	0.3025
		<u>.3032</u>

See page 244



6/3/60

Exp. 81

 $\frac{20}{1 \text{ mi}}$ 

Radial traverse; have 235 chambers

Left pos. = 7.04

Center of Reg I = 514

Instruments checked

Rot Pos	Reg I Pos.	Norm	I Crt ht	II ~ 17.5	III	IV	
0.0	514	360200	1007570	256160	84 <sup>x256</sup> 21548 <del>44</del>	<sup>x256</sup> 78+224	1 mi count 20036
"	"	266840	740280	183980	<sup>x64</sup> 231+27 14811	<sup>x64</sup> 227+29	power level sum counts 14537
"	"	226720	629470	156090	<sup>x64</sup> 193+50 12402	<sup>x64</sup> 189+4	12100
40	480	226570	627000	133170	172+32 11040	208+27	13339
"	"	225090	624610	132540	173+9 11081	206+25	13209
80	450	218070	602080	87710	126+34 8098	199+49	12785
"	"	221640	610490	88880	127+35 8163	201+31	12895
120	400	227130	622420	74740	100+30 6430	159+3	10179
"	"	228640	623400	74980	99+62 6398	159+15	10191
161	350	222680	604170	65100	71+32 4576	87+39	5607
"	"	451010	1214790	130500	143+27 9179	174+45	4 mi count 11181
181	300	460220	1219710	127540	131+59 8443	128+57	8249
"	"	482800	1278260	133750	136+63 8767	139+14	8910
200	250	441470	1132210	115790	107 <sup>54</sup> 7032	88+48	5680
"	"	422500	1078450	110670	102+9 6537	86+18	5522
240	200	413290	912710	98020	91+27 5851	41+63	2687
"	"	425040	1040040	100150	97+7 6215	42+42	2730
280	150	420060	860890	88070	99+2 6338	21+34	1378
"	$\frac{30}{2 \text{ mi}}$	449370	1024310	93910	107+67 6915	23+61	1533
320	90	750780	1526680	143400	196+32 12576	23+1	1473
"	"	859040	1758980	165430	227+47 14575	25+21	1621
360	50	776460	1343660	144140	203+61 13053	17+47	1135
"	"	725870	1260330	135100	191+37 12261	15+23	983

Pat	Reg I	Norm	I	II	TOL	TV	
320	00	799200	1005080	153720	<sup>x64</sup> 210+0	13440	<sup>x64</sup> 22+55
"	"	749070	851840	143950	197+54	12662	21+38
280	60	623450	1122390	130940	<sup>145+20</sup> <del>130</del>	9300	32+14
"	"	702440	1167390	148070	163+48	10480	37+32
240	140	864910	1940650	202840	191+46	12270	87+52
"	"	893430	1996250	208790	194+44	12460	92+15
200	200	874100	2139110	227700	219+39	14055	173+43
170	280	897950	2311310	253230	265+27	16987	301+47
140	340	941470	2479090	286130	355+11	22731	500+3
100	420	969090	2577390	342560	491+44	31468	789+37
50	500	896300	2397780	471850	<sup>x254</sup> 158+23	40471	<sup>x254</sup> 216+82
0.0	530	780710	2092610	522060	<sup>x254</sup> 165+126	42366	<sup>x254</sup> 189+184

Ref. Pos.	Reg. Pos.	I/N	II/N	III/N	IV/N
		x.3623	x.8944	x.1148	x.3433
000	514	2797	<del>7111</del>	5982	<del>5562</del>
"	"	2774	6894 689	5551 551	5456 0539
"	"	2776 <sup>7115</sup>	6884	5470	5337
40	480	2767 2771	5877 588	4872 490	5887 587
"	"	2774	5888	4922	5867
55	1463 80	2761 2758	4023 402	3713 3683	5863 584
38	1382 " "	2754	4010	3683	5818
4	2062 120	2740	3290 3285	2830 2815	4481 447
"	" "	2726 <sup>2733</sup>	3279	2798	4457
32	2400 161	2713	2923 291	2054 2045	2518 250
2	562 " "	2693 <sup>2703</sup>	2893	2035	2479
5	5903 181	2650	<del>2720</del>	1834 1825	1792 182
43	1115 " "	2647 <sup>2649</sup>	2770	1815	1845
-47	19311 200	2564 <sup>2558</sup>	2622	1593 157	1286 129
"	" "	2552	2619 262	1547	1306
3	32003 240	2206 <sup>233</sup>	2371 234	1415 144	6501 646
37	50533 " "	2447	2356	1462	6423
54	55378 280	2049 <sup>2144</sup>	2096 209	1509 1525	3280 335
186	48570 " "	2279	2089	1539	3411
	320 490	2033 <sup>2043</sup>	1910 192	1675 1685	1961 192
	" "	2047	1925	1696	1887
	360 50	1731 <sup>1733</sup>	1856 186	1680 1685	1462 141
	" "	1735	1861	1689	1354
	320 0.0	1270 <sup>1200</sup>	1923 192	1681 1685	1830 1836
	" "	1137	1921	1690	1844
	280 60	1800	2100 210	1492	3307 334
	" "	1661 <sup>1730</sup>	2108	1491 149	3416
	240 140	2243	2345 234	1418 140	6497 656
	" "	2234 <sup>224</sup>	2337	1394	6607



Exp. 81-B

Pos.	Page & Pos.	I/N	II/N	III/N	IV/N
	515	2914	3491	2980	5048
	"	2888	3447	2969	5616
	"	2844	3414	2881	6403
	"	2813	3395	2914	8553
	"	2791	3364	2897	7956
	"	(2633)	3348	2903	7671
	"	2761	3333	2881	7545
	"	2749	3307	2818	7079
	"	2744	3291	2840	6852
	"	2724	3289	2844	7339
	480	2709	3090	9006	5275
	"	2673	3029	7982	3292
	"	2667	3022	8131	3460
	"	2678	3026	7974	3974
		2674	3012		

r=3

6/6/60

Exp. 81-B

265

Partial rerun of 81 because of lack of reproducibility in Reg. I.

9:15 AM Instruments checked OK

Lat. Pos.	Reg. I Pos.	Normalized	Reg. I 4 min. counts	II	III	III	IV	V
20	S15	542790	1582070	189500	252+48	16176	428+11	27403
"	"	552660	1596500	190530	256+45	16414	484+62	31038
"	"	602650	1713840	205770	271+52	17361	602+58	38586
"	"	696860	1959810	236590	317+21	20309	931+20	59400
"	"	706210	1981670	237610	319+48	30444	877+62	56190
"	"	682670	1798070	228570	309+43	19819	818+17	52369
"	"	685600	1893480	228550	308+38	19750	808+20	51732
"	"	695390	1912140	230020	306+20	19604	769+12	49228
"	"	727030	1995560	239340	322+42	20650	778+26	49888
"	"	776150	2114550	255350	345+2	22082	989+69	56905
41	480	789230	2138770	242320	111+2	7106	650+34	41634
"	"							
"	"							
"	"							
11:05 AM	"	772960	2066260	234180	96+26	6170	397+45	25453
"	"	782110	2086120	236970	99+24	6360	447+19	28627
"	"	800940	2145680	242410	99+51	6387	497+26	31834
"	"	829850	2219360	249770	103+60		551+9	

Reg. I finally stabilized at count rate of lower curve when plotted of data on 6/13/60 (Exp 81)  
 Note that lower rate not in center

266

6/6/60

A recheck of Normalization  
Exp. 81-C1:30  
pm

4 min counts

Reg I Counter in Reg II	Normalizer	Reg I/N
265,240	827,710	<del>3204</del>
247650	784630	3156
231120	736190	3139
? 125590 (225590?)	713470	(3161?)
225650	714580	3158
133,020 (233020?)	734610	3171
		av. = 0.3157

Reg I in Reg III	norm.	I/N
2:40 pm 51750	790920	0.06543
105240	1603250	0.06565
111950	1711600	0.06540
<del>1711600</del>		
117210	1783830	<del>9647</del> 0.06570
121970	1848590	0.06598
128660	1964560	0.06549
		av. 0.06561

Temp: Reg I - 22.3, Reg III - 21.9, Reg IV - 23.4

6/7/60

	I/N	II/N	III/N	IV/N
	2917	3047	2138	4046
	2861	2994	2147	2572
	2833	2960	2088	2591
	2796	2924	2065	2517
70	2803	2920	2063	2547
	2776	2902	2017	
	2766	2895	2048	
	2671	2901		
	2752	2879		
	2731	2867		
	2668	2879		
	2754	2878		
	2749	2870		
	2740	28617		
one	2732			

3.4



6/6/60

3:45 PM

Reg I Counter  
in Reg II

Norm

I/N

44410	1828180	0.02429
43140	1756040	0.02456
42520	1738490	0.02465
43850	1805230	0.02429
46160	1872660	0.02465
		av. 0.02445

7/60 8:00 AM Instruments checked OK

To determine Reg I counter count rate in center of Reg I (i.e. chamber is centered vertically, not put back on lift at 7.04)

~~Reg I count rate~~ N

	Reg I	Norm	II	III	IV		
8:45 AM	2726320	934580	284790	78+17 <sup>1256</sup>	19985	147+184 <sup>756</sup>	37816
	2840660	992930	297360	333+7 <sup>144</sup>	21319	399+2 <sup>44</sup>	25538
	2832050	999530	295870	326+15	20879	404+49	25905
	2836510	1014170	296500	327+18	20946	398+56	25528
	2849730	1016560	296930	327+51	20979	404+44	25900
	2936020	1057610	307020	340+0	21760	424+46	27182
	2975630	1075660	311460	339+8	21704	455+1	29121
	2910780	1089380	316050	348+40	22312	482+3	30851
	3121260	1133930	326560	360+12		670+20	
9:25 AM	3103700	1136260	325790	359+31		659+2	
	2978760	1116200	321390	353+39		685+41	
	3079720	1118200	321860	358+12	3	570+11	

Reg I

Norm

II

III

IV

3126920

1140730

327390

359+53

811+58

3205770

1169960

334810

369+17

881+10

71

6/8/60 Void Coefficient Measurements

14,  $\frac{1}{2}$ " OD polystyrene tubes filled with air were placed in a bundle in the center of Reg. I

11<sup>00</sup> AM

Crit fuel selsyn = 16.87 -

P<sub>2</sub>O selsyn = 80.09

Tad = 995.22

selsyn rezeroed (see below)  
just crit after 2/10 min

Tad moved to (raised) 994.00

994.22

selsyn goes up when tad goes down

for period

11<sup>25</sup> AM

Tad returned to 995.18; just crit

11<sup>30</sup> AM

Sheet down

## Run B

1<sup>00</sup> PM

Fuel solution selsyn zeroed (was not off ~~but 0.3 to 0.5 above~~) no void in center. Plus Reg I counts out. Reg II + III Counters at top and rotated 360°.

Solution selsyn = 17.56\*

P<sub>2</sub>O " = 80.92

tad = 995.26

} just crit

1<sup>10</sup> PM

Sol selsyn = 17.61"

tad = 99.40

} for gas period

levelled after period Tad = 995.55 i.e. just crit

\* Value too low; 17.59 agrees better with 17.61 for pos. period

270

6/8/60

## Run C

36 polystyrene tubes in <sup>close packed</sup> bundle in center of no. I2  $\frac{30}{PM}$ 

Solu Selsyn	=	16.31	} just crit
D <sub>2</sub> O Selsyn	=	~80	
Tad Selsyn	=	995.50	

Solu Selsyn	=	16.328	} for period
Tad Selsyn	=	994.25	
D <sub>2</sub> O Selsyn	=	~80	

2  $\frac{55}{PM}$ 

Re leveled at tad = 995.60 i.e. just crit

## Run D

47 polystyrene tubes &amp; 43 Polyethylene Tubes

3  $\frac{45}{PM}$ 

Solu Selsyn	=	15.13	} just crit
D <sub>2</sub> O Selsyn	=	<del>99.60</del> ~80	
Tad Selsyn	=	99.60	

Solu Selsyn	=	15.16	} for period
D <sub>2</sub> O	=	~80	
Tad Selsyn	=	99.45	

Solu Selsyn	=	<del>15.38</del> / 15.14"
Tad Selsyn	=	99.60

with air inside tubes &amp; water in between

6/9/60

## RUN E

9 net. checked, ok.

47 polystyrene tubes &amp; 43 polyethylene tubes - no water inside or outside (tubes dried)

D<sub>2</sub>O 79.89 Fuel ht. at cut 14.76

out. Td ad 995.81

Positive period:

Fuel ht 14.82 Td ad 994.31

Cut after period:

Fuel 14.79, TD  $\begin{array}{r} 995.83 \\ 994.31 \\ \hline 1.52 \end{array}$ 

## Run F

47 Polystyrene tubes & 43 Polyethylene tubes with 28 of the tubes filled with H<sub>2</sub>O (randomly spaced)

Fuel 14.72 TD 996.15 cut

Period: Fuel at 14.76 TD 994.90

Cut after Period 14.74 TD  $\begin{array}{r} 996.20 \\ 994.90 \\ \hline 1.30 \end{array}$

272

Expt.

6/9/60

Run G

Only air in Reg I - fully refl.

crit Fuel 16.82 T.D. 996.60

Period: Fuel 16.84 TD 995.35

Crit: Fuel	16.85	T.D.	996.60
			235.35
			<u>1.25</u>

Reg III = 22.5°C, Reg IV = 22.5°.

X

Run H

Reg I: 47 Polystyrene tubes air inside &amp; outside randomly spaced. % Void = 88.58

crit fuel ht. 15.67 T.D. 996.60

Pos. Period: 15.69 " 995.45

After period crit. Fuel ht.	15.67	"	996.70
			5.45
			<u>1.25</u>

Repeat Expt 82 Run A

6/10/60

14 Polystyrene Tubes filled with air surrounded by H<sub>2</sub>O.

10.55

crit fuel ht 16.99 T.D. 997.12

Pos. period 17.05 " 995.50

crit 17.02 997.12

6/10/62

# Expt 83 Run A

273

8-1" dia al. rods in center  
instr checked, ok.

Crit fuel ht: 16.43 - T.D. 996.96

Por. period: 16.47 TD 995.71

cut at 16.46 " 997.01

Reg I - 19.3°C, Reg II 23.4°, Reg III 22.5°

## Run B

14-1" dia al. rods centered in Reg I

Crit fuel ht 15.74, TD = 996.92

Por. period: 15.78, " 995.41

After (period) Crit fuel ht 15.76 " 994.61

## Run C

20-1" dia. al. rods centered in Reg I

Crit fuel ht. 15.42" T.D. 996.29

Por. period 15.44 " 994.79

cut. at 15.42 " 996.26

274

Run D

24 rods in reg  $\bar{t}$

3 <sup>45</sup> p.m.

Fuel soln relay = 15.50

Tod = 99.650

} just cut

Fuel relay = 15.53

Tod = 99.500

} for per period

Out. Fuel ht

15.50

99.647

99.500

1.47



10-3-60

275

Preliminary run prior to foil test  
of Ratio of act. at center of island to center of fuel  
annulus.

Inst. checked and safety set.

Fuel system zero ~ ~~99.600~~ 99.600 ?

Crit. fuel ht. 17.37 D<sub>2</sub>O Full

Pos. period 17.40

Drained D<sub>2</sub>O to 69.0

one jog on lead caused ~.2 rise in fuel

hence fuel full at ~ 17.40

∴ Fuel zero at ~ -.30"

10-4-60 <sup>7/2</sup> Foil Activity Ratio Run

Inst. checked, OK. safety set.

#2 foil centered in Reg I

#3 foil " " Reg II vertically & Radially

Crit at 17. ~~36~~ 36

Fuel at 17.48 for approach

1C-3-.01, 1C-4-.01 for foil activation

Time 20 min.

276

10-6-60 2<sup>nd</sup> Foil activation run

using  $U^{235}$  and 37%  $U^{235}$  foils

9 mts. checked & safety set

Crit at 17.34 on sel syn; IC-3 at ~0.25

2:03 PM

Shut Down - Dump 50/10

10-10-60

Expt # 1

277

Critical Parameter Studies with fuel in place of H<sub>2</sub>O in Reg I, Reflected as in Expt. 4 except Reg. I top not reflected. Tad adder tube is connected to Reg. I  
Insts. checked & safety set.

crit at  $10.81 + 0.30$  zero correction.

Expt. 2

Removed End Reflectors. Reg III D<sub>2</sub>O + B as in Expt 4. of HFIR. Top refl. can still in place. Side refl. at ~18" high.

crit at  $13.08 + 0.3 = 13.38$  Am Temp. ~ 75°F

278

10-10-60

EXPT 3

Drained out all reflectors - system bare except for Al. cans.

15.75 in I.D.

20.70 slightly sub. Uncorrected

20.74 " super. "

Crit.  $20.72 + 30 = 21.02'' \approx 53.4 \text{ cm.}$

D<sub>2</sub>O zero at 53.1

10-13-60 Sample #18 Taken and sent to Cooper (Fuel)  
Use previous anal. result. Result of alms  
one not consistent with sp. gr.

105.9 gm U<sup>235</sup>/lit sp. gr = 1.226

H/U<sup>235</sup> = 70.9

EXPT. 4

D/U<sup>235</sup> = 166.3

%D in Fuel Added side D<sub>2</sub>O + B refl to height of  
soln = 70.1 Fuel. Reg IV empty  $\hookrightarrow$  2.35 g/l

Crit.  $13.36 + 3 = 13.66'' \text{ fuel}$

D<sub>2</sub>O at 66.8 - 53.1 = 13.7''  $\approx$  34.8 cm.

4 B

Raised D<sub>2</sub>O to Full  $\approx$  71.0

Crit Fuel  $13.18 + 3 = 13.48''$



system

10-11-

(red)  
of value

of

10-13-6



ors - system


rracted-

3, 4 m.

ner (Fuel)  
Result of above

✓  
10-13-6

height of



10-11-60

279

### Expt 5

Fuel in Regions I & II, H<sub>2</sub>O in Reg. III.  
(D<sub>2</sub>O drained and system washed out)

No. top or bottom refl.

Critical  $\left\{ \begin{array}{l} \text{H}_2\text{O at } 65.4 - 53.1 = 12.5'' \\ \text{Fuel at } 12.14 + 3 = 12.44'' \approx 31.4 \end{array} \right.$

HFIR Soln. Assembly Removed from Room

### Expt 6

10-13-60

Installed 20" Dia. Ann. Type A1. Cylinder Bare.

" 6" cross safety. Fuel relsyn gressed.

Contact stuck on Fuel Feed switch causing a sharp rise on all instr. (see attached graphs). Experiment stopped for repair of switch. Feed valve remained open when switch was in off position. Contacts to be put in series rather than parallel.

## Expt. 6B

Resumed after Repair of Switch, 20" Ann.  
Type cyl. bare.

Crit at 12.37  $\approx$   $\frac{31.4}{.4}$  cm ~~bottom correction~~

safely lowered slowly  $\frac{31.8}{.4}$ , At contact with fuel  
it caused about a 100 sec. positive period.

## Expt. 6C

Same as above except inserted BF<sub>3</sub>  
counter about 3" from center radially  
with bottom of counter approx 1 inch above  
bottom. Rossi Alpha technique attempt  
to measure neutron lifetime.

Crit at 12.45"



10-14-60

## Expt. 6 D

Same as above  
inst. checked

	crit at 12.34"	6000 CPM	$(7.5 \times (3 \times 10^{-12}))$
	Sol ht. 12.39	15000 CPM	" $(10 \times 10^{-12})$
12 <sup>13</sup> PM	Sol ht 12.40	40,000 CPM	" $(3 \times 10^{-11})$
12 <sup>15</sup> PM	Dump SolN		

## EXP 6 E

Moved BF<sub>3</sub> counter - Raised 6".

	SolN H+	12.352	2000 CPM
3 <sup>33</sup> PM	SolN H+	12.382	3500 CPM
3 <sup>54</sup> "	SolN H+	12.393	10,000 CPM
3 <sup>55</sup> "	Dump SolN		

## Salvage Bottles

#1 - 593125 ~ 75 gm soln  
 #2 - 593126     "     "  
 #3 - 593127     "     "

11-1-60 D<sub>2</sub>O Samples taken as follows

Sample # 1 A - 1B Pure D<sub>2</sub>O Drum # 1  
 "     # 2A - 2B Used D<sub>2</sub>O Drum # 2  
 "     # 3A - 3B Used D<sub>2</sub>O (with Poison) Drum # 3

11-10-60

Resample of UO<sub>2</sub>F<sub>2</sub> - 74-84-3

Reg. 593128

9 Items 3

rec. 6-30-58

Gr. 62 gm

$\frac{20}{42}$  gm net

Material to be shipped to Hanford

16-7-60

D<sub>2</sub>O sent to ORNL for Recovery:

SRS 9446	584 lb.	New Drum	204.0 *
	<u>71</u>		<u>-99.5</u>
net	513		104.5

\* Tax taken on another identical type drum.

"Note" Entered 3-26-64

Salvage Material  $2\text{H}_2\text{O}_2(\text{NO}_3)_2$  from HFIR #1

Shipped to Y-12 on waybill # 109 10-25-60

Ref No	593125	593126	593127	(A)
Gross wt.	16.80	19.23	15.83	Combust

Net wt	3.70	3.07	2.92	Dry
--------	------	------	------	-----

Net wt	13.10	16.16	12.71	
--------	-------	-------	-------	--

Estimated U	45g	118g	248g	50g
-------------	-----	------	------	-----

Estimated total 461g

1-18-61

1-18-61 The following Drums of D<sub>2</sub>O was  
shipped to y-12 for storage (Mr. Brotherton)  
Bldg 9204-

"Note" #1 (7919) Pure D<sub>2</sub>O (As Received)  
Corrected Gr 292.16 lb } 84.250 Kg = 185.35 lb  
wt 5-7-64 + 72.83 } 72.83  
Net 219.33 lb } 112.52 lb

There was possibly a mistake in original wt c.c.

#2 Pure D<sub>2</sub>O Drained from system  
Before Boron was Added 3-28-60  
Gr 239.8 lb (shipped to J.A. Auvie 7-19-60)  
+ 84.15  
Net 155.65 lb

#3 D<sub>2</sub>O Contaminated with Boron (Distilled  
At X-10) 0.00024 mg/ml Boron  
Gr 474.0 lb  
+ 101.5  
Net 372.5 lb

#4 D<sub>2</sub>O Contaminated with Boron (Distilled  
At X-10) 0.00020 mg/ml Boron  
Gr 311.0 lb  
+ 98.5  
212.5 lb

Charge 4435-70