

BOOK50R

Notes:

"HFIR CE3" on front

"HFIR CE3 I" on spine

Blank pages: inside front cover sheets, page opposite page 1, 1, 2, 10, 13, 14, 17, 34, 48, 55, 78, 80, 82, 88, 90, 92, 96, 98, 110, 120, 132, 136, 144, 146, 148, 152, 154, 156, 158, 160, 166, 168, 170, 172, 174, 178, 180, 182, 184, 186, 194, 196, 198, 200, 204, 206, 210, 220, 222, 224, 230, 292, 293, 298, 299, page opposite 300, inside back cover sheets

-pages 48/49 slip of paper between pages

-pages 250, 252, 260, 273 has a photo attached to each page

Scanned by:

Sheila Finch

RSICC /Oak Ridge National Lab.

August 13, 1999

March 16, 1964

On Friday, March 13, R. Knight and Dwan used new punch to obtain 4 ea 2 mil x 1/8 x 1 1/2 in foils for calibration of scintillators

Ludwig at 9202 Y-12 cleaned and weighed these foils. Dwan reweighed them in grams in 108.

Ludwig	Dwan	Average	labeled
.1027	.1025	.1026	- 1026
.1028	.1025	.1027	- 1025
.1030	.1028	.1029	- 1029
.1056	.1054	.1055	- 1057

Mounted foils in 25 mil al. with Teflon tape

March 20, 1964

wt. $\frac{1027}{1055} = .9735$ Counting $\frac{1027}{1055} = .9718$
 Ratio

Foils 1026 and 1029 together and labeled 1029

Check for counter losses by foil method of source using 1029 as std.

$\frac{1027}{1026 + 1029} = .54104$ $\frac{1055}{1026 + 1029} = .54326$ Sum 1.08430
 1.0802

Counted together 1.07610

Count loss ~ .0082

1027 Counted .54104 53283 .0041

1055 " .55191 55191

1.09295 108474

1.01736 101736

0.07559 .06738

av .07149

stacked foil loss with 2 layers of

From counting ratios having two foils
in same pkg 1029 + 1025
Counting ratio

$$54104 \times 2 = 1.08208$$

~~2~~

losses in std $1/1.08208$ ~~2~~

because of self $= 1 - 0.92414 = \underline{\underline{.07586}}$
abs.

Correction for weight of U in foil because
of self absorption
~~(1.1027)~~?

$$\text{FOIL WT} = \text{RATIO} \times \text{WT. OF STD (1027)} \times \frac{.92998}{(1 + .07586 \times \text{FOIL RATIO}) \times \underline{\underline{.92714}}}$$

$$\text{WT} = \text{RATIO} \times .095458 (1 + .07586 \times \text{FOIL RATIO})$$

March 23, 1964

Repeat of Foil Calibration for self abs. corr.

Average value from 4 detn of $\frac{1025}{1024} \rightarrow .53586$ $\times 2$

1.07172

Therefore the losses were 7.172%


USING 1025 AS STD

~~$${}^{235}\text{U FOIL WT} = \frac{\text{MEASURED COUNTING RATE}}{1.07172} \times 0.10279 \text{ U} \times .932$$~~

~~$$\times (1 + .07172 \times \text{COUNT RATIO})$$~~

~~$${}^{235}\text{U} = \text{COUNT RATIO} \times 0.089311 (1 + .07172 \times \text{Count Ratio})$$~~

3-24-63



Linear Approx. to Foil Self Shielding

$$\int_0^b S dx e^{-\mu(b-x)} = S \int_0^b e^{\mu(x-b)} dx = \frac{Sb}{\mu b} \left[e^{\mu(x-b)} \right]_0^b$$

$$= Sb \left[\frac{1 - e^{-\mu b}}{\mu b} \right] = Sb \left[\frac{1 - 1 + \mu b - \frac{(\mu b)^2}{2} + \frac{(\mu b)^3}{6}}{\mu b} \right]$$

$$= Sb \left[1 - \frac{\mu b}{2} + \frac{(\mu b)^2}{6} - \dots \right]$$

Actual Counting Rate Ratio for foils of thickness b_1 and b_2

$$\text{Ratio} \left(\frac{b_1}{b_2} \right) = \frac{ESb_1 \left[1 - \frac{\mu b_1}{2} + \frac{(\mu b_1)^2}{6} - \dots \right]}{ESb_2 \left[1 - \frac{\mu b_2}{2} + \frac{(\mu b_2)^2}{6} - \dots \right]}$$

If $b_1 = 2b_2$, ~~So~~ Counting ratio = 1.86616, $b_2 = 0.1027g$

$$1.86616 = 2 \frac{1 - \frac{2\mu b_2}{2} + \frac{4(\mu b_2)^2}{6}}{1 - \frac{\mu b_2}{2} + \frac{(\mu b_2)^2}{6}} \quad \times 0.932 \text{ wt } 2.0^{235}$$

$$0.93308 = \frac{1 - \mu b_2 + \frac{2}{3}(\mu b_2)^2}{1 - \frac{\mu b_2}{2} + \frac{(\mu b_2)^2}{6}}$$

If $\mu b_2 = .144$ $(\mu b_2)^2/6 = .020736/6 = .003456$

$$1 - .144 + .013824 = .869824$$

$$1 - .072 + .003456 = .931456 = .933083$$

If $\mu b_2 = .146$ $(\mu b_2)^2/6 = .021316/6 = .003553$

$$1 - .146 + .014212 = .868212$$

$$1 - .073 + .003553 = .930553 = .933007$$

From Graph plot

$\therefore \mu b_2 = 0.1584$ $(\mu b_2)^2/6 = .025091/6 = .004182$

$$0.14584 \quad 1 - \mu b_2/2 + \mu b_2^2/6 = 1 - .0797 + .004182 = .924482$$

Unknown Foil with std. of $b_2 = 0.1027g$

$$\text{Obs. Count Rate Ratio} = \frac{b_1 (1 - \mu b_1/2 + (\mu b_1)^2/4)}{b_2 (0.92484)} \quad \times .932$$

$$\frac{b_1}{b_2} = \text{C.R.R.} \times .92484$$

$$\frac{1 - \mu b_1/2 + (\mu b_1)^2/6}{2} \quad \therefore \frac{\mu b_1}{2} = \frac{\mu b_2}{2} \times \frac{b_1}{b_2} \approx \frac{\mu b_2}{2} \times \text{C.R.R.}$$

$$\text{Foil Wt} = \frac{\text{C.R.R.} \times (.92484) \times (0.1027) \times (.932)}{(1 - \frac{\mu b_2}{2} \times \text{C.R.R.})}$$

$$(1 - \frac{\mu b_2}{2} \times \text{C.R.R.})$$

for value of $\frac{\mu b_2}{2}$, use $\left[\frac{\mu b_2}{2} - \frac{(\mu b_2)^2}{4} \right]$ of .07516

Denominator must equal .92484 when CRR = 1


$$FOIL WT = \frac{C.R.R. \times 0.088522}{1 - 0.07516 C.R.R.}$$

An alternate form would be (for ease in calculation)

$$FOIL WT = C.R.R. \times 0.088522 (1 + 0.081268 CRR)$$

SA-2 and SA-1 now have DD-2 amplifiers!

3-30-64 Counters adjusted, so that $E_s = 400$
 $E = 86$ $\Delta E = 600$ is the
 proper settings, $E = 75$
 is somewhat too low.



Counts on 37% foil and U^{238} (Sugar Q) showed
 the lowest peak distorted by U^{238} gamma rays
 at these settings Bkg SA-2 = 118, SA-1 = 199.5 or 200

$$\left(\frac{1029}{1025}\right) CRR = 1.85278$$

$$\frac{CRR}{2} = .92639 = \frac{1 - \mu b_2 + \frac{4}{6} (\mu b_2)^2}{1 - \frac{\mu b_2}{2} + \frac{(\mu b_2)^2}{6}}$$

$$\mu b_2 = \sim .1622 \quad 1 - \frac{\mu b_2}{2} + \frac{(\mu b_2)^2}{6} = 0.923285, \quad b_2 = \text{unknown}$$

$$b_2 = \frac{CRR \times .923285 \times 1.027 \times .932 \text{ wt\% } U^{238}}{1 - \mu b_2/2 + (\mu b_2)^2/6} \rightarrow 1 - \frac{\mu b_2}{2} + \frac{(\mu b_2)^2}{6}$$


when CRR = 1 $\mu b_2/2 = .076715$

$$b_2 = CRR \times \frac{.088378}{(1 - .076715 CRR)}$$

$$\begin{array}{r} 1.56 \\ 20.25 \\ \hline 21.81 \end{array}$$

Measurements of position of fission counter and assembly

Inside thimble to blow tanks



counter tip to preamp housing back
71 5/8 in

From DWG	Counter Tip to U foil plating	7/8"
"	" to center of U	2 3/8"
"	to end of U	3 7/8"

Diam center post 1.319

at Top of Baffle	center post	To thimble	3 1/2 in
at Cap	"	"	2 1/2
Below "	"	"	2 1/16

Distance from Ring Mount for full element to thimble
 at Baffle plate 1 7/16
 Below cap (8 in above plate) 1 3/8

$$\begin{array}{r}
 0.66 \\
 .50 \\
 \hline
 3.50 \\
 \hline
 4.66
 \end{array}$$

Removable Fuel Plates

TUNER PLATES

Useable Punched foils

1 IE-6-A

Received on 4/13/64

2 IE-8-A

3 IE-13-A

4 IE-19-A

5 IE-10-B

6 IE-6-D

7 IE-3-E

8 IE-7-E

9 IE-15-E

10 IE-6-F

11 IE-18-F

12 IE-7-G

Foils Punched in wrong location

1 IE-10-F

2 IE-3-G

3 IE-15-G

No foils punched

1 IE-9-A

Outer Plates

Fails not Punched

Received 4/13/64


1. OE-4-N
2. OE-11-N
3. OE-2-M
4. OE-6-W

Fails Punched

Received 4/14/64

1. OE-4-F
2. OE-7-F
3. OE-8-F
4. OE-13-F
5. OE-16-F
6. OE-6-G
7. OE-8-G
8. OE-9-G
9. OE-15-G
10. OE-16-G
11. OE-2-I
12. OE-15-I


Fission Chamber Thimble & drive assembly installed on 4/15/64



Selsyn set at 21.81 when up against end of thimble
 When counter is lowered, counter increases
 to read directly distance from center line.
 limits: Up 21.81
 Down 34.34

Measurements of control cylinders 4/15/64

DWH
RC
JH



Limit switch settings

down 999.501

up 998.877


up 26.0.6

down 25.506

Safety

up 20.62

down 997.52



HFIRCE 3-1

Instrument Check on 4-17-64 Source 10 m.c.v

PM-1	Low Trip	OK	Alarm Trip	OK	
IM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK		
IC-3	Responds	Calibration	✓		
IC-4	Responds	Calibration	✓		
CRM		Meter Trip			

Preliminary Check on 4-18-64

- Room 113 Pressure Differential 1/4"
- Red Light On and Personnel Check
- Scrams and Bldg, Alarm Reset ✓
- Source Inserted ✓
- Safety Withdrawn ✓
- Controls Set Knver at 10.00 Outer Inserted (999.50)
- Reflector Water Be
- Moderator Water


Not able to get critical because
1/8" pipe plug not inserted in thermocouple
location on base of outer fuel annulus

Dwyer

Control Rods (ORNL Div E 42486 Rev. A)

Cu-Ag (btk) - 4 3/4 Ag Plated - A1

No target.



HFIR CE 3-2

No target

Instrument Check on 4-20-64 Source 10 mcY

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 > 3 x 10⁻¹¹ Meter Trip OK Fast Trip OK
 IC-2 > 3 x 10⁻⁴ Meter Trip OK
 IC-3 Responds Calibration ✓
 IC-4 Responds Calibration ✓
 CRM Meter Trip clock 2526

Preliminary Check on 4-20-64

Room 113 Pressure Differential 1 1/4"
 Red Light On and Personnel Check OK
 Scrams and Bldg, Alarm Resct OK
 Source Inserted OK
 Safety Withdrawn to 20.62
 Controls Set Inner at 10.00 Outer at 999.50
 Reflector Water none
 Moderator Water none

92% A
not correct
rec'd. R > 1

Critical - positive period.


	Inner	Outer	Water	Safety
$R > 1$	13.20	13.20	25.885	20.62
$R = 1$	13.12	13.12	25.885	20.62
$R = 1$	12.95	12.95	27.170	27.03 (28.05 no change)

BOR sections each inserted 7.5 in.

150.4 sec period \rightarrow 7.11 $\frac{1}{in}$; displacement of both rods 0.08"

$$\frac{7.11}{.08} = 90 \frac{1}{in} \text{ for both rods.}$$

Noted fission chamber did not record a single count with log N at 0.75 (IC-4)



Instrument readings at $k=1$:

IC-1 5.7×10^{-10} (on 10×10^{-10} scale)

IC-2 6.7×10^{-10} (on 10×10^{-10} scale)

No response on Fission Counter. (PMS output found to be ~ 2 volt Q1743 scale)

IC 3 1.2×10^{-11}

IC 4 2.2×10^{-9}

did not work on this pulse generator took amp to shop.

C-4 Saturated - blocked on XIK

C-3 Responds.

Found smaller mounting ring on fission counter not correct and rollers too tight. Replaced with #2 element ring.

Expt. 3

no target

Instrument Check on 4-21-64 Source 10-mev

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Responds	Calibration			
IC-4	Responds	Calibration			
CRM		Meter Trip			Clock 2526


Preliminary Check on 4-21-64

Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check
 Scrams and Bldg. Alarm Reset
 Source Inserted
 Safety Withdrawn
 Controls Set Inner 10.00 Outer 999.49
 Reflector Water 6" above Be (by measurement)
 Moderator Water _____

Condition	Inner	Outer	Safety	Water	Comment
$k > 1$	14.62	14.62	26.13	26.27	$\rho = 2.04$ Positive period.
$k = 1$	14.55	14.55	26.13	26.27	Inst. readings p22

^{10²⁰} Raised Outer Control to 14.6 and returned to 14.55 to have $k=1$.
 there appears to be a dependence on readings as to how
 critical is approached. Can move Inner control as
 much as 0.1" with little response. Roller found damaged
 (inner control guide)

2
 1
 1
 1
 mp



Added 5ml Triton X-100 to Mod H₂O - upon stirring etc decided
to discard. Added ~ 60 H₂O to barrel + 5ml Triton X-100

¹⁰³⁰ Pumped up in fuel element and drained.

¹¹⁰⁶ N.B. C-4 jammed at IC-4 = 1.1×10^{-10} amp
3 = 1.8×10^{-9} amp

EXP - 4

Instrument Check on 4-22 Source 10 mc \checkmark

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 3 x 10⁻¹¹ Meter Trip OK Fast Trip OK
 IC-2 3 x 10⁻¹¹ Meter Trip OK
 IC-3 Response Calibration OK
 IC-4 " Calibration OK
 CRM Meter Trip

Preliminary Check on 4-22

Room 113 Pressure Differential DWA
 Red Light On and Personnel Check DWA CC
 Scrams and Bldg, Alarm Reset DWA
 Source Inserted DWA Response on 1 2 3 & 4
 Safety Withdrawn DWA 20.62
 Controls Set Inner 14.50 Outer 999.49
 Reflector Water ~6 in above Be
 Moderator Water 26.12 on Lig Level Selym.

Condition	Inner	Outer	Source	Safety	Mod	
11:04 21 SEP 51 Pos Per	14.51	14.51	Out	26.03	25.73	150.4 sec p = 7.1 f slightly +
k=1 (w)	14.51	14.44 14.435	"	"	"	"
Post. Per	14.51	14.51	"	"	(26.36)	708.4 sec p = 1.75 f
k=1	14.51	14.46	"	"	"	"

Critical positions above without target

4/23/67

Measurements made with dial indicator showed very poor reproducibility upon reversing directions, more than 50 mil lag of control rods. Tightened cables both inner and outer, and lowered rollers on inner control at top. Meas on inner Control

Approaching setting from same direction dial reading

.000
.098
.099
.098

Approaching setting from opp. direction

.016
.015

Inner moved ~ 2 mils when outer changed from up to down
Outer " " ~ 4 mils " " inner changed from up to down

Meas on Outer indicates that there is approx
0.1 - .02 inch lag of rod motion on reversing direction

Changed limit switch on Outer control, now set lower at 0.01.

4/22/63

EXP #5

Purpose: Critical control pod positions with Target.

	Cond.	Inn	Out	Safety	Mod.	Ref. H ₂ O	
13 ⁵²	Pos Per	14.10	14.10	26.00	27.06	~6" above Be	59.1 sec
14 ⁰⁴	k=1	14.10	13.91	"	"	"	P=14.6
	k=1	→ 14.00	14.00	"	"		
	+	14.005	14.005				

Repeat approach to Critical (for Reproducibility)

14 ³⁰ PM	Pos Per	14.10	14.10	26.00	26.83	6" above Be	38.68 sec
14 ⁴²	k=1	"	13.87	"	"		P=19.4
	k=1	13.98	13.98				

4-23-64

1 PM No counts on IAC fission counter (HP1R) with
 IC-4 = 3×10^{-9} (Counter on Noise Pulses)

3¹² PM Noted Fission Pulses in HP1R F.C. (C2)

Reactivities:

Motion of Rod	Reactivity
Outer \uparrow	-1.5 β
" \downarrow	+1.4 β
Inner \downarrow	-0.8 β
" \uparrow	+1.9 β

Instrument Check on 4-23-64 Source 10mex

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Responds	Calibration	JH		
IC-4	Responds	Calibration	JH		
CRM		Meter Trip			

purpose: check reproducibility of controls.

Preliminary Check on 4-23-64

Room 113 Pressure Differential	1.4
Red Light On and Personnel Check	JH
Scrams and Bldg, Alarm Reset	JH
Source Inserted	JH 1 2 4 respond.
Safety Withdrawn	20.63" \rightarrow 26.00
Controls Set	Inner 14.38" Outer .01
Reflector Water	26-in - above Be.
Moderator Water	26.73"

Condition	Inner	Outer	Safety	
A) $k > 1$ pos. per.	14.53	14.53	26.00	$\rightarrow P = 14.4 \pm$
$k = 1$	14.53	14.38	"	
B) Moved outer control down to 13.18 and returned to 14.38; $k < 1$ neg. period				
$k = 1$	14.53	14.39 ⁵		
C) Moved outer control up to 14.45" and returned to 14.39 ⁵ ; $k > 1$ pos. period				
$k \approx 1$	14.53	14.37 ⁸		
$k = 1$	14.41	14.53		
D) Moved inner control up to 14.00 and returned to 14.41 ² ; $k < 1$ neg. period				
$k = 1$	14.40 ⁵	14.53 (overshot)		
E) Moved inner control down to 14.47 and returned to 14.40 ⁵ ; pos. period				
$k = 1$	14.38 ⁴	14.53		
F) $k > 1$ + Per	14.53 \uparrow	14.53 \uparrow		$P = 14.4 \pm$
$k = 1$	14.45 ⁵ \uparrow	14.45 ⁵ \uparrow		
	13.745	14.37 ⁵		

~~Measured counter CI (PSN 1055) to Region between
Fuel Channels~~

Reactivity: $1.76 \text{ div/sec} \rightarrow 38.2 \text{ sec} \rightarrow 19.5 \%$

displacement of outer rod $0.205''$ $\$0.97/\text{in}$
" of outer + inner $0.100''$ $\$1.95/\text{in}$

Expr. 7 with target.

Acc. in beam hole

Condition	Inner	Outer	Safety	H ₂ O core	Ref.
R>1	13.34 ⁵	14.05 ⁵ 13.97	14.05	26.00	26.79 6" above Be
R=1	13.34 ⁵	14.05 ⁵ 13.76 ⁸	13.84 ⁸	"	" "
R=1	13.24	13.95	13.87	13.95	" "
R=1	13.25 ↓↑	13.96	13.88	13.96	" "

N.B. Selsyn on Outer = 0.08 when Top of Outer control = 6 1/16 in above Be above readings in error

N.B. Inner selsyn = 00.00 Measures 4 2 1/2 in above Be. Should be 4 1 13/16. See p 16
Selsyn = 00.71

Changed inner .71 → 0
 " outer .08 → 0
 Down Up
 Inner 24.81
 Outer 99.94 25.98

Expr. 8

with target

Instrument Check on 4-24-64 Source 10 mCi

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 > 3x10⁻⁴ Meter Trip OK Fast Trip OK
 IC-2 > 3x10⁻⁴ Meter Trip OK
 IC-3 Response Calibration J11
 IC-4 Response Calibration J11
 CRM Meter Trip

Preliminary Check on 4-24-64

Room 113 Pressure Differential 1.4
 Red Light On and Personnel Check J11
 Scrams and Bldg, Alarm Reset J11
 Source Inserted ✓ Response 1 2 3 + 4
 Safety Withdrawn 26.00"
 Controls Set Inner 13.34 Outer 0
 Reflector Water 6" above Be
 Moderator Water 26.58"

Condition	Inner	Outer
k>L	13.94 ⁵	13.97
k=L	13.34 ⁵	13.79 ⁵
k=L	13.56	13.56
	14.00	13.07
	13.00	14.21
	12.00	15.48
	11.00	16.93 ⁵
	10.00	18.67
	9.00	20.96
	8.00	25.90
	24.75	6.90
	24.00	7.01 ⁵

cont'd

Expr 8.

Condition	Inner	Outer
k=1	23.00	7.22
	22.00	7.51 ⁵
	21.00	7.85
	20.00	8.27
	19.00	8.79 ⁸
	18.00	9.44 ⁵
	17.00	10.19
	16.00	11.05
	15.00	11.98
	14.00	13.04 ⁵

Expr. 9.

Subcritical pulsing: 3PN1

Acc. @ 150 kV 0.9 ma. target current 4 ma; pressure = 10⁻⁵

Burst width 300 ns @ 220 cps.

TMC 20 μs chom. Bkg. rate 2 delay time 2 μs disc. 4; Mem 1/2

Arrangement: RSH-150-S BE3 Detector @ 1500 v. (NICC PS)

DD-2 (Y-140341) gain 50 x 1.1 positive PHS with 2 ea.

100 Ω Terminal resistors on cable to TMC; +2.4 pulse.

condition Inner Outer Safety

k=1 13.56 00.00 26.00

Experiment 10 - 3PN2

k=1 13.56 2.00 26.00

Exp. 11 3PN3

k=1 13.56 4.00 26.00

Exp. 12 3PN4

k=1 13.56 6.00 26.00

Exp. 13 3PN5

k=1 13.56 8.00 26.00

3PN - Summary on P 5-0

4/24/64 (RSN 1055)
Moved counter C1 to region between fuel elements

Reactivity: $T = 47.8 \text{ sec}$ $\rho = 14.9 \text{ \mu}$ 2.2 div/sec

displacement of Outer 0.175 in. $\rightarrow 4.97/\text{in}$

Reactivities: $5.5 \text{ dir/sec} \rightarrow T = 119.5 \text{ sec} \rightarrow \rho = 8.57 \phi$

Displacement of Outer = $.09 \text{ in.} \rightarrow \frac{.095}{\text{in}}$

Expr. 14

with Target.

Instrument Check on 4-27-64 Source 10mc8

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-11}$	Motor Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-11}$	Motor Trip	OK		
IC-3	Responds	Calibration	JH		
IC-4	Responds	Calibration	JH		
CRM		Meter Trip			

Preliminary Check on 4-27-64

Room 113 Pressure Differential	1.4"
Red Light On and Personnel Check	JH
Scrams and Bldg. Alarm Test	JH
Source Inserted	JH Response 2+4
Safety Withdraw	JH 26.00
Controls Set	inner 11.00 outer 999.54
Reflector Water	6" above Bc.
Moderator Water	26.79"

Conditions	Tuner	Outer	Safety	Pos	Per
	13.56	13.66	26.00		
	13.56	13.57	26.00		level
	13.605	13.605	20.62		level

Pulse at critical: (summary p50) 3PN-6
 Acc. 150Kv with 0.5Lama. Vac. $\sim 8 \times 10^{-5}$ Beam current 0.8 μ A
 40 cps @ 800 μ s delay
 TMC: Disc 4; Bkg 2; Delay $\times 2$; ch. width 160 μ s
 Insert safety to 10.00"
 accumulate counts @ 300 cycles.

Reactivity: $3.56 \text{ dec/dec} \rightarrow T = 77.4 \text{ sec} \rightarrow \rho = 129$

Outer rod displacement = $0.215 \text{ in} \rightarrow \dagger 0.56/\text{in}$

Inner + Outer " " = $0.095 \text{ in} \rightarrow \dagger 1.26/\text{in}$

Expr 15

4.5" Dia Styrofoam.

Instrument Check on 4-28-64 Source 10 meV

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 >3x10⁻¹¹ Meter Trip OK Fast Trip OK
 IC-2 >3x10⁻¹¹ Meter Trip OK
 IC-3 Responds Calibration JT
 IC-4 Responds Calibration water Removed for service.
 CRM Meter Trip

Preliminary Check on 4-28-64

Room 113 Pressure Differential 1.7"
 Red Light On and Personnel Check JT
 Scrams and Bldg, Alarm Resct JT
 Source Inserted 011 2+4 Responds
 Safety Withdrawn set at 26.00
 Controls Set Inner 10.00 outer 999.93
 Reflector Water 6" above Re.
 Moderator Water 26.59"

Purpose: Evaluate Styrofoam in island.

Styrofoam: Dia = 4.5" length = 24 3/8" top of Styrofoam level with core

Condition	Inner	Outer	Safety
k=2	12.00	12.00	26.00
R=1	12.00	11.78 ⁵	26.00
10 ¹⁵ R=1	11.90 ⁵	11.90 ⁵	26.00

Reactivity: $3.65 \text{ dir/sec} \rightarrow T = 79.3 \text{ sec} \rightarrow \rho = 11.8 \%$

Expr. 16

Outer rod displacement = $0.23 \text{ in.} \rightarrow \$0.51/\text{in.}$

Inner + " " " = $0.105 \text{ in.} \rightarrow \$1.12/\text{in.}$

Expr. 17

Reactivity $1.72 \text{ dir/sec} \rightarrow T = 37.4 \text{ sec} \rightarrow \rho = 19.8 \%$

Inner + Outer rod displ. = $0.10 \text{ in.} \Rightarrow \$1.98/\text{in.}$

Expr. 18

Reactivity: $2.16 \text{ dir/sec} \rightarrow T = 46.9 \rightarrow \rho = 17.1 \%$

outer rod displacement = $0.17 \text{ in.} \rightarrow \$1.50/\text{in.}$

Inner + Outer " " " = $0.075 \text{ in.} \rightarrow \$2.28/\text{in.}$

Expr 16

with Styrofoam

4 3/16" Dia x 24 3/8" long.

67% void

Condition	Inner	Outer	Safety	Water
k > 1	11.91	11.91	26.00	26.75
k = 1	11.91	11.68	26.00	26.75
k = 1	11.80 ⁵	11.80 ⁵	26.00	26.75

Expr 17

no Styrofoam

Preliminary foil exposure to determine Power level + time.

[HIFR*2] U-7 foil 2. 5.4.81 mg ~ 3/4 off center in island.

Condition	Inner	Outer	Safety	Water
k > 1	14.16	14.16	26.00	26.58
k = 1	14.06 ⁵	14.06 ⁵	26.00	26.58

30 minute exposure

Shut down @ 2:35:40

Expr 18

with Styrofoam

2 3/16 Dia x 24 3/8 in island.

18.6% void.

Condition	Inner	Outer	Safety	H ₂ O
k > 1	13.45 ⁵	13.45 ⁵	26.00	26.48 Pos Per
k = 1	13.45 ⁵	13.28	26.00	26.48 level
k = 1	13.37 ⁵	13.37 ⁵	26.00	26.48

Foils:

Inner: IE 8 A location 37A

Outer: OE 16G 78B

Norm: foil 4B in Plate 10F in 17th slot from 37A.

Start 10:25:21 Expose for 30 min at $\left\{ \begin{array}{l} 1.0 \text{ on IC-3 } (10^{-9}) \\ 5.2 \text{ IC-2 } (3 \times 10^{-9}) \end{array} \right.$

Shut down 10:55:21

Expt 22

Reactivity: $1.98 \text{ dir/dec} \rightarrow T = 43 \text{ sec} \rightarrow \rho = 18.1\%$

Outer rod displacement = $0.30 \text{ in.} \rightarrow 1.60\%$

Expt. 23

Reactivity: $2.5 \text{ dir/dec} \rightarrow T = 55.2 \text{ sec} \rightarrow \rho = 15.3\%$

Inner rod displ. = $\sim 0.26 \rightarrow 59\%$

Expr 19 with Styrofoam 4 3/16" Dia

3PN-7 see page 50

8 EXP 20 - 3PN-8 8.00
9 EXP 21 - 3PN-9 0.00

Expr. 22 Foil Exposure with 4 3/16" dia Styrofoam

Instrument Check on 4-29-64 Source 10mcT

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	>3x10"	Meter Trip	OK	Fast Trip	OK
IC-2	>3x10"	Meter Trip	OK		
IC-3	Respects	Calibration	JII		
IC-4	out	Calibration			
CRM		Meter Trip			

Preliminary Check on 7-29-64

Room 113 Pressure Differential 1.4"
Red Light On and Personnel Check JII
Scrams and Bldg. Alarm Reset JII
Source Inserted JII Response on 2 + 3
Safety Withdrawn 26.00 in.
Controls Set In: 11.805 Outer: 0
Reflector Water 6" above Be
Moderator Water 26.51 in.

Condition	Inner	Outer
R>1	11.80	12.15
R=1	11.80	11.85

4 3/16" Styrofoam	Expr 23	Safety	H ₂ O
R>1	11.80	12.06	26.00 26.71
R=1	12.00	12.00	21.64 "

Cycle Safety from 21.64 to 10.0 for 3PN-10 see p 50

4/23/64

Installed Fission Counter.

Exp 24

with Styrofoam
4 3/16" Dia.

Instrument Check on 4-30-64 Source 10mcV

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	23x10"	Meter Trip	OK	Fast Trip	OK
IC-2	23x10"	Meter Trip	OK		
IC-3	Repeats	Calibration	JK		
IC-4		Calibration			
CRM		Meter Trip			

Preliminary Check on 4-30-64

Room 113 Pressure Differential	1.4"
Red Light On and Personnel Check	JII
Scrums and Bldg. Alarm Reset	JII
Source Inserted	No
Safety Withdrawn	26.00
Controls Set	Inner 0 Outer 0
Reflector Water	6" above Be
Moderator Water	25.44"

Purpos: Pulse neutron control with

Condition	Inner	Outer	Safety	
k<1	9.00	9.00	26.00	3PN-11 (p.50)

Exp 25

k<1	6.00	6.00	26.00	3PN-12 p.50
-----	------	------	-------	-------------

Exp 26

k<1	9.00	4.00	26.00	3PN-13 p.50
-----	------	------	-------	-------------

Exp. 27

k<1	2.00	2.00	26.00	3PN-14 p.50
-----	------	------	-------	-------------

Exp. 28

k<1	2.00	2.00	26.00	3PN-15 p.50
-----	------	------	-------	-------------

Expn 29

Foil:

Inner: IE-3E location 37A

Outer: OE-9G location 78B

Norm.: foil 6 in plate IE-10F in 17th slot from 37A

Island: foil 3 of IE-10-F centered

Start 9⁵² 17 Expose for 30 min. at
$$\left\{ \begin{array}{l} 1.0 \text{ IC-3 } (10^{-9}) \\ 5.2 \text{ IC-2 } (3 \times 10^{-9}) \end{array} \right.$$
Shutdown 10²³ 17

Counting data

Bg	Fission counter position	Fission counter			Instrument Reading	
		IC-3	C-4		IC-2	IC-3
	c/m	c/m	c/m			
BRg	21.81	0	100	902	—	—
	21.81	26,508	35630	153276	5.1 (3×10^{-9})	1.0 (10^{-9})
	22.81	17829				
	23.81	11460	ave. of 13 counts.			
	21.81	26221				

Expn 30

21.81 3272 4339 14408 5.3 (3×10^{-9}) 0.1 (10^{-9})

ave. of 5 counts.

1925
T=4
P=1
3

Expr 29

{ no target }
{ no void. }

Instrument Check on 5-4-64 Source 10mc

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-5}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Responds	Calibration	JT R.		
IC-4		Calibration			
CRM		Meter Trip			

Preliminary Check on 5-4-64

Room 113 Pressure Differential	1.4
Red Light On and Personnel Check	JT
Scrams and Bldg. Alarm Reset	JT
Source Inserted	JT responds 12 + 3.
Safety Withdrawn	26.00
Controls Set	Inner 14.06, Outer 0.0
Reflector Water	above bc.
Moderator Water	26.98"

Foil Exposure

1.725 μ /sec
T = 37.5
 \Rightarrow P = 19.84
 \approx 19.92 μ /m

Condition	Inner	Outer	Safety	
k > 1	14.06	14.31	26.00	Start 9:57 17
k = 1	14.085	14.085	26.00	Stop 10:27 17

Expr. 30

with Styrofoam

2.28 μ /sec
T = 49.5 sec
P = 16.54
 \approx 16.61 μ /m

			Safety	H ₂ O
3 7/8" Dia 24 3/4" long.				
k > 1	12.05	12.05	26.00	26.67
k = 1	12.05	11.78	"	"
k = 1	11.92	11.92	"	"

+	R	0	1	5	6	3
+	R	0	1	5	3	3
+	R	0	1	4	9	3
+	R	0	1	6	0	3
+	R	0	1	9	4	3
+	R	0	1	5	9	3
+	R	0	1	3	7	3
+	R	0	1	5	3	3
+	R	0	1	5	2	3
+	R	0	1	5	8	3
				15.5	1	
+	R	0	1	4	9	3
+	R	0	1	5	5	3
+	R	0	1	5	5	3
+	R	0	1	5	9	3
+	R	0	1	5	3	3
+	R	0	1	5	4	3
+	R	0	1	5	9	3
+	R	0	1	5	5	3
+	R	0	1	5	5	3
				2.14	3	4
				5	3	5

Rod sensitivities
with target.

Expt. 31

Instrument Check on 5-5-64 Source 10 mcg

PM-1	Low Trip	OK	Alarm Trip	OK	
FM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Responds	Calibration	JH		
IC-4		Calibration			
CRM		Meter Trip			

Preliminary Check on 5-5-64

Room 113 Pressure Differential	1.3"
Red Light On and Personnel Check	JH
Scrams and Bldg, Alarm Reset	JH
Source Inserted	JH 1 2 + 3 Respond
Safety Withdrawn	> 6.00
Controls Set	Inner 0.0 outer
Reflector Water	> 6" above Be
Moderator Water	26.53

2 PM	Condition	Inner	Outer	Condition	Inner	Outer
1.	K > 1	8.17	25.90	15.	K > 1	10.00 19.01
2.	K < 1	8.17	23.86	16.	K < 1	10.00 18.50
3.	K > 1	8.32	23.86			
4.	K < 1	8.32	23.16			
5.	K > 1	8.51	23.16			
6.	K < 1	8.51	22.40			
7.	K > 1	8.70	22.40			
8.	K < 1	8.70	21.75			
9.	K > 1	8.90	21.75			
10.	K < 1	8.90	20.72			
11.	K > 1	9.20	20.72			
12.	K < 1	9.20	19.71			
13.	K > 1	9.60	19.71			
14.	K < 1	9.60	19.01			

Expt.	page	3PN-No.	Inner	Outer	Safety	Cycles	Ch. width	Bkg	Del.
9	35	1	13.56	0.00	26.00	76543	20	x2	x2
10	35	2	"	2.00	"	167659	20	2	2
11	35	3	"	4.00	"	61669	40	2	2
12	35	4	"	6.00	"	59978	40	2	
13	35	5	"	8.00	"	59249	40	2	
14	37	6	13.605	13.605	20.62 cycle 10.00	^{200/} 13612	160	2	
14	43	7	10.00	10.00	26.00	28744	80	2	
20	43	8	8.00	8.00	26.00	~36000	40	2	
21	43	9	0.00	0.00	26.00	39640	40	2	
23	43	10	12.00	12.00	21.64	12202	160	4	
24	45	11	9.00	9.00	26.00	47335	40	2	
25	45	12	6.00	6.00	26.00	46943	40	2	
26	45	13	4.00	4.00	26.00	53361	40	1/2	
27	45	14	2.00	2.00	26.00	54532	40	2	
28	45	15	0.00	0.00	26.00	49423	40	2	
29	57	16	13.56	0.0	26.00	15846	80	1	
35	57	17	13.56	0.0	26.00	10271	80	2	
36	57	18	13.56	0.0	26.00	8779	80	2	
37	57	19	10.00	0.0	26.0	41982	40	2	
38	57	20	8.00	0.0	26.0	48197	40	2	
39	57	21	6.00	0.0	26.0	52888	40	2	
40	57	22	4.00	0.0	26.0	139184 139184	20	2	
41	57	23	4.00	0.0	26.0	55346	40	2	
42	57	24	2.00	0.0	26.0	53361	40	2	
43	57	25	0.0	0.0	26.0	92108	40	2	
44	59	26	0.0	0.0	26.0	84240	40	2	
45	59	27	15.49	0.0	26.0 K=1	5709	160	A	

Delay	Disc	Mem.	Burst	Rep. rate	Target Current	Current (ma.)
x 2	4	1/2	300	220	4 μ a	0.9
2	4	"	300	220	"	"
2	4	"	500	130	"	"
2	4	"	500	130	"	"
2	4	"	500	130	"	"
2	4	1/2	800	40	.8 μ a	.82
2	4	1/2	700	80	3 μ a	
2	4	1/2	600	135	5 μ a	
2	4	1/2	400	135	5 μ a	146 KV .8
2	4	1/2	800	38	0.6 μ a	146 KV .8
2	4	1/2	600	125	4.2 μ a	145 KV 0.85
2	4	1/2	500	130	4.8	0.90
2	4	1/2	450	128	4.8	0.90
2	4	1/2	400	138	4.6	0.95
2	4	1/2	400	138	5.0	0.95
2	4	1/2	600	130	4.0	.9
2	4	1/2	600	130	4.6	.9
2	4	1/2	800	140	7.5	.93
2	4	1/2	500	140	6.2	.93
2	4	1/2	500	115	5.4	.93
2	4	1/2	500	130	6.2	.92
2	4	1/2	300	220	6.2	.82
2	4	1/2	500	130	6.2	.92
2	4	1/2	800	230	8.0 6.2	.92
2	4	1/2	600	270	5.5	.91
2	4	1/2	400 400	127	4.0	.91
2	4	1/2	800	200	.8	.82

3. PN	Est. λ	Cal. λ	
1	1591	1432 \pm 15	7.1
2	1867	1406 \pm 12	6.9
3	1430	1360 \pm 20	6.6
4	1298	1284 \pm 10	6.4
5	1134	1100 \pm 10	5.4
6	210	199 \pm 1	3.1
7	674	680 \pm 3	3.1
8	850	920 \pm 3	4.2
9	1476	1425 \pm 6	6.5
10	224	2198 \pm 11	1
11	859	830 \pm 3	3.8
12	1105	1220 \pm 5	5.1
13	1265	1270 \pm 5	5.8
14	1383	1350 \pm 70	6.2
15	1396	1410 \pm 10	6.4
16	414	402 \pm 2	2.2
17	412	402 \pm 2	2.2
18	418	402 \pm 2	2.2
19	993	930 \pm 10	5.1
20	1343	(1230 \pm 40)	6.8
21	1600	(1500 \pm 100)	8.2
22	1889	1854 \pm 100	10.0
23	1806	(1700 \pm 25)	9.4
24	2011	(1870 \pm 40)	10.2
25	2193	(2000 \pm 60)	11.1
26	2011	(2000 \pm 60)	11.1
27	171	180 \pm 1	-

Island

T

V

T $\frac{3}{4}$ Control Cyl.

1500 \pm 35) repeat calculations
 1850 \pm 40)

Expt 32

Instrument Check on 5-6-64 Source 10 mc

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Responds	Calibration	JII		
IC-4		Calibration			
CRM		Meter Trip			

Preliminary Check on 5-6-64

Room 113 Pressure Differential	1.3"
Red Light On and Personnel Check	JII
Scrams and Bldg. Alarm Resct.	JII
Source Inserted	JII 1, 2 + 3 respond
Safety Withdrawn	26.00
Controls Set	Inner 10.00 Outer 6.00
Reflector Water	6" above biflector
Moderator Water	26.76"

Continue Apr. 31.

	Condition	Inner	Outer	Condition	Inner	Outer	
17	K > 1	10.00	18.00	29	K > 1	11.85	15.90
18	K < 1	10.00	18.50	30	K < 1	11.85	15.49
19	K > 1	10.25	18.50	31	K > 1	12.15	15.49
20	K < 1	10.25	17.74	32	K < 1	12.15	14.96
21	K > 1	10.65	17.74	33	K > 1	12.52	14.96
22	K < 1	10.65	17.25	34	K < 1	12.52	14.57
23	K > 1	10.98	17.25	35	K > 1	12.85	14.57
24	K < 1	10.98	16.70	36	K < 1	12.85	14.21
25	K > 1	11.25	16.70	37	K > 1	13.20	14.21
26	K < 1	11.25	16.28	38	K < 1	13.20	13.80
27	K > 1	11.60	16.28	39	K > 1	13.50	13.80
28	K < 1	11.60	15.90	40	K < 1	13.50	13.38

(over)

54

5-6-64

Exp # 32 (Cont)

11⁴⁴ AM

Condition Inner outer

Condition

Inner

outer

41 K > 1 13.85 13.38

68 K < 1 19.70 8.17

42 K < 1 13.85 13.00

69 K > 1 20.55 8.17

43 K > 1 14.20 13.00

70 K < 1 20.55 7.76

44 K < 1 14.20 12.69

71 K > 1 21.60 7.76

45 K > 1 14.50 12.69

72 K < 1 21.60 7.41

46 K < 1 14.50 12.26

73 K > 1 22.70 7.41

47 K > 1 14.85 12.26

74 K < 1 22.70 7.04

48 K < 1 14.85 11.81

75 K > 1 24.81 7.04

49 K > 1 15.29 11.81

76 K < 1 24.81 6.76

50 K < 1 15.29 11.48

51 K > 1 15.75 11.48

52 K < 1 15.75 11.13

53 K > 1 16.05 11.13

54 K < 1 16.05 10.84

55 K > 1 16.40 10.84

56 K < 1 16.40 10.54

57 K > 1 16.80 10.54

58 K < 1 16.80 10.15

59 K > 1 17.20 10.15

60 K < 1 17.20 9.71

61 K > 1 17.85 9.71

62 K < 1 17.85 9.25

~~63 K > 1 18.25 9.25~~

63 K > 1 18.50 9.25

64 K < 1 18.50 8.95


65 K > 1 19.15 8.95

66 K < 1 19.15 8.55

67 K > 1 19.70 8.55

5/7/64 Installed $\frac{3}{4}$ Control Cylinder

Limits	up	down
Inner	99820	24.77
Outer	26.05	800.00 89894



Resistivity: $2.52 \text{ hr/sec} \Rightarrow T = .54.8 \text{ sec} \Rightarrow \rho = 15.4 f$

Inner cyl. displ = $0.276 \Rightarrow f.56/\text{in}$

with target.

Expt 33

Instrument Check on 5-8-64 Source 10mc

RPM-1	Low Trip	OK	Alarm Trip	OK	
RPM-2			Alarm Trip	OK	
IC-1	>3x10 ⁻⁴	Water Trip	OK	Fast Trip	OK
IC-2	>3x10 ⁻⁴	Meter Cal.	OK		
IC-3	Responds	Calibration	JII		
IC-4		Calibration			
CRM		Meter Trip			

Preliminary Check on 5-8-64

Room 113 Pressure Differential	1.3"
Red Light On and Personnel Check	JII-CC
Scrams and Bldg. Alarm Reset	JII
Source Inserted	JII
Safety Withdrawn	12.70 → 26.00"
Controls Set	Inner 0.0 Outer 0.0
Reflector Water	6" above Be
Moderator Water	26.47"

Condition	3/4		Safety	ZPN
	Inner	Outer		
R>1	15.62°	0.0	26.00	
R=1	15.35	0.0	26.00	
R=1	15.515	0.0	20.77	
Expt	Inner	Outer	Safety	ZPN
34	13.56	0.0	26.00	16
35	13.56			17
36	13.56			18
37	10.00			19
38	8.00			20
39	6.00			21
40	4.00			22
41	4.00			23
42	2.00			24
43	0.00			25

Reactivity: $1.45 \text{ div/dec} \Rightarrow T = 31.5 \text{ sec} \Rightarrow \rho = 22 \text{ f}$

Tuner rod displacement = $0.355'' \Rightarrow \rho = 1.62 \text{ in.}$

Reactivity: $2.25 \text{ div/sec} \rightarrow T = 48.9 \text{ sec} \rightarrow \rho = 16.6 \%$

Inner rod displacement = $0.243 \text{ in} \Rightarrow \phi = .68 \text{ /in}$

$53 \text{ div/sec} \rightarrow T = 1152 \text{ sec} \Rightarrow \rho = 1.09 \%$

$\Rightarrow k = 1.00007$

Outer $3/4$ control
w/ Styrofoam Void $4\ 3/16$ " dia.

Expt. 47

Condition	Inner	$3/4$ Outer	Safety	Island H_2O
2.25 dir/sec $k > 1$	11.23	0.0	26.00	26.72
$k = 1$	10.98 ⁷	0.0	26.00	"
$k = 1$	11.38 ⁵	0.0	20.77	26.72
3 PN-29 (p.100) cycle Safety to 10.00"				
53 dir/sec $k \geq 1$	11.38 ⁵	0.0	20.77	26.68

Expt 48 w/ $4\ 3/16$ " dia. Styro. Void.

Instrument Check on 5-12-64 Source 10 mci

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Responds	Calibration	JII		
IC-4		Calibration			
CRM		Meter Trip			

Preliminary Check on 5-12-64

Room 113 Pressure Differential	1.3"
Red Light On and Personnel Check	JII
Scrams and Bldg, Alarm Reset	JII
Source Inserted	JII
Safety Withdrawn	26.00"
Controls Set: In: 0.0 out: 0.0	
Reflector Water	6" above Be.
Moderator Water	

Condition	Inner	$3/4$ Outer	Safety	
K441	0.0	0.0	26.00	3PN-30 (p.100)

Reactivity $2.46 \text{ d}/\text{sec} \rightarrow T = 53.5 \text{ sec} \Rightarrow \rho = 15.6 \%$

Inner cyl. displ. = $0.21 \Rightarrow \$74/\text{in}$

Reactivity: $2.234 \text{ d}/\text{sec} \rightarrow T = 48.5 \text{ sec} \Rightarrow 16.7 \%$

Inner cyl. displ. = $0.19 \Rightarrow \$88/\text{in}$

Expt 49

Installed target contained in sealed Al. cylinder.

⇒ Target + void.

Condition	Inner	Outer ^{3/4}	Safety	H ₂ O	
k > 1	12.59	0.0	26.00	26.41	
k = 1	12.38	0.0	26.00	26.41	
k < 1	0.0	0.0	26.00	26.41	3PN-31 (p.100)

Expt 50 Target + Void 3/4 control Cyl.

Pulse at critical

Instrument Check on 5-13-64 Source correct

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-3			Alarm Trip	OK	
IC-1	2.3×10^{-4}	Meter Trip	OK	Fast Trip	OK
IC-2	2.3×10^{-4}	Meter Trip	OK		
IC-3	Response	Calibration	OK		
IC-4	Response	Calibration	OK		
CRM		Meter Trip			

Preliminary Check on 5-13-64

Room 113 Pressure Differential	<u>1-3</u>
Red Light On and Personnel Check	<u>C.C.</u>
Scrams and Bldg. Alarm Reset	<u>C.C.</u>
Source Inserted	<u>C.C.</u>
Safety Withdrawn	<u>26.00</u>
Controls Set Inner	<u>0.0 Outer 0.0</u>
Reflector Water	<u>6" above bc</u>
Moderator Water	<u>26.69</u>

Condition	Inner	Outer	Safety	
k > 1	12.56	0.0	26.00	
k = 1	12.37	0.0	26.00	level
k = 1	12.676	0.0	20.74	

5/13/64 Have put 6 mils of Cd on 4th quad. of $\frac{3}{4}$ control cylinder
 Rubber cemented 3 pieces 2 mils thick $13\frac{1}{16} \times 10$.
 When control cylinder is fully inserted 10" cadmium covers
 the top half of the core.

Reactivity: 4.067 $\text{d}/\text{sec.} \Rightarrow T = 88.4 \text{ sec} \Rightarrow \rho = 10.8\%$
 Inner cyl displ = 0.249 $\Rightarrow \phi = 43.4\%$

Expt. 50 cont'd.

Cycle safety to 10" for 3PN-32 (p100)

End of Pulsing

Condition	Inner	Outer	Safety
R=1	12.675	0.0	20.74

Expt. 51

target + Void; Modified 3/4 control

Condition	Inner	Outer	Safety	H ₂ O
88.4 sec 10.24 43.4 9/10 R > 1	16.425	999.99	26.00	26.67
R = 1	16.176	999.99	26.00	26.67

Instrument Check on 5-14-64 source 10mc

PM-1	Low Trip	6K	Alarm Trip	6K	
PM-2			Alarm Trip	OK	
IC-1	> 5 x 10 ⁻⁴	Meter Trip	OK	Fast Trip	OK
IC-2	> 3 x 10 ⁻⁴	Meter Trip	OK		
IC-3	Responds	Calibration	JH		
IC-4	Responds	Calibration	JH		
CRM		Meter Trip			

Preliminary Check on 5-14-64

Room 113 Pressure Differential	1.3"
Red Light On and Personnel Check	JH CC
Scrams and Bldg, Alarm Reset	JH
Source Inserted	JH
Safety Withdrawn	26.01
Controls Set	Inner 0.0 outer 0.0
Reflector Water	6" above Be.
Moderator Water	

Reactivity: 3.734 $\Delta k/k$ $\Rightarrow T = 81.1 \text{ sec} \Rightarrow P = 11.6 \%$

Inner cyl. displ. 0.255 in $\Rightarrow \beta = 44 \%$

Reactivity: 2.308 $\Delta k/k$ $\Rightarrow T = 51.4 \text{ sec} \Rightarrow P = 16 \%$

Inner cyl. displ. = 0.315 $\Rightarrow \beta = 59 \%$

Reactivity: 2.867 $\Delta k/k$ $\Rightarrow T = 62.3 \text{ sec} \Rightarrow P = 14 \%$

Inner cyl. displ. 0.27 in $\Rightarrow \beta = 52 \%$

Expt 52

	Condition	Inner	3/4 Mod. Outer	Safety	H ₂ O	
81.1 sec	R > 1	16.44	999.99	26.00	26.635	
11.04	R = 1	16.185	999.99	26.00	26.635	
44.64 sec	R < 1	13.56	999.9	26.00	26.635	3 PN-33 (p100)
	R < 1	13.56	999.9	26.00	26.635	3 PN-34
Expt 53 =>	R < 1	0.0	"	"	"	3 PN-35
		Expt 54				
	R > 1	16.95	999.99	20.76 26.00	20.76 26.635	
	R = 1	16.635	999.99	20.76 26.00	20.76	3 PN-36
	R = 1	16.635	999.99	20.76 26.00	20.77	end

Expt 55

Removed To. + Void and put in Styrofoam void 4 3/16" dia.

62.8 sec	R > 1	14.60	999.99	26.00	26.665	
1.24 sec	R = 1	14.33	"	"	"	
52.4 sec	R < 1	13.56	"	"	"	3 PN-37

Expt 56

R < 1	13.56	999.99	26.00	26.665	3 PN-38
-------	-------	--------	-------	--------	---------

Expt 57

R < 1	0.0	999.99	26.00	26.665	3 PN-39
-------	-----	--------	-------	--------	---------

Reactivity: $1.934 \frac{\text{dir}}{\text{sec.}} \rightarrow T = 42.0 \rightarrow P = 18.4 \text{ f}$

Inner cyl. displ. = $0.35'' \Rightarrow f_{53}/\text{in}$

Expr 58.

Modified 3/4 Control Cylinder - 4 3/16 dia Styrofoam Void.

Pulse at critical:

Instrument Check on 5-15-64 Source 10 med

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	> 3x10 ⁻¹¹	Meter Trip	OK	Fast Trip	OK
IC-2	> 3x10 ⁻¹¹	Meter Trip	OK		
IC-3	Responds	Calibration	JII		
IC-4	Responds	Calibration	JII		
CRM		Meter Trip			

Preliminary Check on 5-15-64

Room 113 Pressure Differential 1.4"

Red Light On and Personnel Check JII C.C.

Scrams and Bldg. Alarm Reset JII

Source Inserted C.C.

Safety Withdrawn C.C.

Controls Set Inner 0 Outer 0

Reflector Water 6" above Be

Moderator Water 26.41"

Condition Inner Outer Safety

K>1 15.15 999.99 20.77

K=1 14.80 " "

3 PN-40 cycle safety to 10"

end K=1 14.80 999.9 20.77

5-21-64

Removed $\frac{3}{4}$ outer control cylinder and reinstalled
 $\frac{4}{4}$ outer control cylinder. (See pp 16 and 56)

Drive nut on Safety worn excessively causing binding,
 also motor was smoking - both replaced.

Set outer control at $6\frac{1}{16}$ " above B_e and set by at 0.0.

Limits	up	down
inner	998.21	24.77
outer	26.045	0.0
safety	20.75	997.52

Expt 59

With target

Instrument Check on 5-22-64 Source 10mc

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 > 3 x 10⁻⁴ Meter Trip OK Fast Trip OK
 IC-2 > 3 x 10⁻⁴ Meter Trip OK
 IC-3 Responds Calibration JIT
 IC-4 Responds Calibration JIT
 CRM Meter Trip

Preliminary Check on 5-22-64

Room 113 Pressure Differential 1.2"
 Red Light On and Personnel Check JIT
 Scrums and Bldg, Alarm Resct JIT
 Source Inserted JIT
 Safety Withdrawn 26.00"
 Controls Set Inner 0.0 Outer 0.0
 Reflector Water 6" above Be.
 Moderator Water

Condition	Inner	Outer	Safety	T = 41.3	P = 18.6
1.9 ^{div} / _{sec} R > 1	13.75	13.75	26.00		
R = 1	13.75	13.55	"	1.93/in	
R = 1	13.57	13.75	"	1.103/in	
R = 1	13.66	13.66	"	1.204/in	

Relocated Rhodite chamber - Expt. 60

Condition	Inner	Outer	Safety	T = 107.9 113.3	P = 9.3 8.9
4.867 ^{div} / _{sec} R > 1	13.66	13.75	"		
R = 1	13.66	13.66	"	1.101/in	
9.6 ^{div} / _{sec} R < 1	13.56	13.66	"	T = -200.6 -198.9	P = -7.7 -8.2
				1.777/in	

5-22-64

Rechecked zero position of control cylinders.

Inner cyl. $4\frac{13}{16}$ " above PC. \rightarrow selayn reads zero.Outer cyl. $6\frac{1}{16}$ " " " " " "

limits:	Inner	Outer	Safety
down	24.70 998.77	999.93	997.41
up	998.14	26.09	20.76

Rhoette

$$6.5 \text{ dir/sec} \Rightarrow T = 141.2 \text{ sec} \Rightarrow 13.44$$

$$13.54 \rightarrow 1.35 \frac{\text{in}}{\text{min}}$$

$$2.067 \text{ dir/sec} \Rightarrow T = 44.9 \text{ sec} \Rightarrow \rho = 17.64$$

$$16.14 \rightarrow 1.34 \frac{\text{in}}{\text{min}}$$

$$6.34 \text{ dir/sec} \Rightarrow T = -137.8 \text{ sec} \Rightarrow \rho = -13.94$$

$$13.34 \rightarrow 1.48 \frac{\text{in}}{\text{min}}$$

Expr 61

With target

check critical position of rods.

Condition	Inner	Outer	Safety	H ₂ O	T=42.0	P=18.4
1934 $R > 1$	13.55	13.90	26.00	26.69		
$R = 1$	13.55	13.71	"	"	4.77%	
$R = 1$	13.62 ^s	13.62 ^s	"	"	Rhoette	17.54

Expr 62

Instrument Check on 5-25-64 Source 10mc

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Response	Calibration	JH		
IC-4	Response	Calibration	JH		
CRM		Meter Trip			

Preliminary Check on 5-25-64

Room 113 Pressure Differential	1.4"
Red Light On and Personnel Check	JH
Scrams and Bldg. Alarm Reset	JH
Source Inserted	C.C
Safety Withdrawn	no
Controls Set	Inner 24.70 Outer 0-0
Reflector Water	6" above bc
Moderator Water	26.40"

Purpose: check critical with safety inserted with target

Condition	Inner	Outer	Safety
R=1	24.70	13.37	997.42
R<1	24.70	13.27	"
R>1	"	13.49	"
R=1	"	13.37	"
R<1	13.53	26.09	"

Rhosette

$$\frac{3.03}{2.716} \text{ div/sec} = \frac{65.8}{5.9} \text{ sec period} = 11.15 \neq$$

+12.94 $\frac{1}{2}$

Expt. 63

Foil

Inner. IE - 76 location 37A

Outer. OE - 86 location 78B

Norm. foil 5 in plate IE 10F in 17th slot from 37A

Begin 8³⁰ AM Expose for 30 min. at 4 on { IC-3 10⁻⁹
 IC-4 10⁻⁹
 IC-2 3x10⁻⁹

Shutdown 9⁰² AM.

Condition	Inner	Outer	Safety
$R > 1$	13.76	26.09	997.42
$R = 1$	13.62	26.09	"

Expt. 63 Foil Exposure with target.

Instrument Check on 5-18-64 Source 10 mCi

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Responds	Calibration	JH		
IC-4	Responds	Calibration	JH		
CRM		Meter Trip			

Preliminary Check on 5-26-64

Room 113 Pressure Differential	1.4"
Red Light On and Personnel Check	JH C.C.
Scrams and Bldg, Alarm Reset	JH
Source Inserted	C.C.
Safety Withdrawn	26"
Controls Set	Inner 13.62 Outer 0.0
Reflector Water	6" above Be
Moderator Water	1" above Reflector H ₂ O → Selwyn not op.

Condition	Inner	Outer	Safety
$R > 1$	13.62	13.85	26.00
$R = 1$	13.64	13.64	26.00

Shut down with scram button

Rhoette:

IC2 1.45 to 5.6 on 3×10^{-10} scale

Rho meter 5×10^{-9} to 2×10^{-8}

	Condition	Inner	Outer	Safety	H ₂ O		
1.	R > I	24.70	7.16	26.00	~27.00	20.5	+19.3
2.	R < I	23.02 ⁶	7.16 ⁵	26.00	27.00	25.5	-14.9
3.	R > I	23.02 ⁶	7.44 ⁵			16.2	+14.4
4.	R < I	22.07 ⁵	7.44 ⁵			17.6	-13.7
5.	R > I	22.07 ⁵	7.72			18.0	+15.7
6.	R < I	21.32	7.72			11.8	-11.4
7.	R > I	21.32	7.95			12.6	+11.5
8.	R < I	20.75	7.95			13.2	-10.5
9.	R > I	20.75	8.17			12.8	+11.7
10.	R < I	20.23	8.17			13.8	-10.5
11.	R > I	20.23	8.38			11.0	1.0
12.	R < I	19.78 ⁵	8.38			14.6	-10.6
13.	R > I	19.78 ⁵	8.60			13.5	10.6
14.	R < I	19.38	8.60			14.0	-10.1
15.	R > I	19.38	8.81			11.4	+10.0
16.	R < I	19.00	8.81			14.4	-11.3
17.	R > I	19.00	9.04			11.4	+10.2
18.	R < I	18.64	9.04			12.7	-10.6
19.	R > I	18.64	9.26			11.1	10.9
20.	R < I	18.29 ⁵	9.26 ⁵			12.7	-10.9
21.	R > I	18.29 ⁵	9.48 ⁵			11.3	+10.6
22.	R < I	17.95	9.48 ⁵			15.0	-12.0
23.	R > I	17.95	9.72			11.1	10.1
24.	R < I	17.65	9.72			12.6	-10.4
25.	R > I	17.65	9.94 ⁵			12.3	11.6
26.	R < I	17.35	9.94 ⁵			16.2	-11.0
27.	R > I	17.35	10.17 ⁵			12.2	10.8
28.	R < I	17.06	10.17 ⁵			14.8	-10.6

Expr. 64 w/Target

	Condition	Inner	Outer		Result
29	R>1	17.06 ⁵ .275	10.40		12.2 10.7
30	R<1	16.78 ⁵	10.40 ⁵ .225		12.5 -10.4
31	R>1	16.78 ⁵ .265	10.62 ⁵		11.6 10.4
32	R<1	16.52	10.62 ⁵		15.3 -10.2
33	R>1	15.17 ⁵ .24	12.10 ⁵		11.6 10.8
34	R<1	14.93	12.10 ⁵ .247		15.5 -10.7
35	R>1	14.93 ⁵ .245	12.35 ²		16.7 12.2
36	R<1	14.68 ⁵	12.35 ² .243		16.8 -11.6
37	R>1	14.68 ⁵ .213	12.59 ⁵		11.6 10.6
38	R<1	14.46 ⁷	12.59 ⁵ .25		14.6 -10.4
39	R>1	14.46 ⁷ .237	12.84 ⁵		13.4 11.9
40	R<1	14.23	12.84 ⁵ .24		14.6 -10.6
41	R>1	14.23 ⁵ .15	13.08 ⁵		11.8 10.5
42	R<1	14.01 ⁵ .235	13.08 ⁵		13.4 -10.7
43	R>1	14.01 ⁵	13.32		10.9 10.2
44	R<1	11.65	16.00 ⁸ .308	68.1m	16.9 -13.8
45	R>1	11.65 ⁵ .16	16.30 ⁸	1.32	10.3 9.6
46	R<1	11.47	16.30 ⁸ .269	91	13.5 -10.4
47	R>1	11.47 ⁵ .183	16.57 ⁷	1.32	10.9 9.8
48	R<1	11.28 ⁵	16.57 ⁷ .283	87	13.5 -10.7
49	R>1	11.28 ⁵ .175	16.86	1.32	11.1 9.9
50	R<1	11.11	16.86 ⁵ .315	60	12.0 -10.4
51	R>1	11.11 ⁵ .18	17.13 ⁵	1.34	10.4 9.3
52	R<1	10.93	17.13 ⁵		13.7 -10.7
53	R>1	9.73 ⁵ .177	19.70		10.9 9.6
54	R<1	9.56	19.70 ⁵ .41		16.0 -12.1
55	R>1	9.56 ⁵ .18	20.11		11.8 10.2
56	R<1	9.38	20.11 ⁵ .424		11.0 -12.1
57	R>1	9.38 ⁵	20.53 ⁴		11 9.6

Expr 64 (cont'd) w/target.

	Condition	Inner	Outer		Results
58	R < 1	9.22 ⁴ 7.5 .15	20.53 ⁴ .406	12.6	-10.3
59	R > 1	9.22 ⁴ .15	20.94	10.5	9.4
60	R < 1	9.07	20.94	13.4	-10.7
61	R > 1	9.07	21.39 ⁴ .45	11.2	10.
62	R < 1	8.85 ⁴ .22	21.39 ⁴ .570	20.1	-15.3
63	R > 1	8.85	21.97	11.2	9.6
64	R < 1	8.93 ⁵ .11	21.97	12.5	-9.8
65	R > 1	8.73 ⁵ .15	22.52	11.6	10.5
66	R < 1	8.58 ⁵	22.52	13.1	-9.8
67	R > 1	8.58 ⁵ .205	23.15 ⁵ .635	11.9	9.9
68	R < 1	8.38	23.15 ⁵ .10	28	-19.2
69	R > 1	8.38	24.25 ⁵	11.8	9.3
70	R < 1	8.23 ⁵ .15	24.25 ⁵	13.9	-10.9
71	R > 1	8.23	25.51 1.25.5	9.8	9.0
72	R < 1	8.01 ⁵ .215	25.51	12.1	-12.3
73	R < 1 R > 1 not	8.01 ⁵	26.08 ⁵		5.6

Expt. 65
Instrument Check on 5-27-64 Source Comet

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 $> 3 \times 10^{-4}$ Meter Trip OK Fast Trip OK
 IC-2 $> 3 \times 10^{-4}$ Meter Trip OK
 IC-3 Responds Calibration JN
 IC-4 Responds Calibration JN
 CRM Meter Trip

Preliminary Check on 5-27-64

Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check JN C.S.
 Scrams and Bldg. Alarm Test: JN
 Source Inserted no
 Safety Withdr. 26.00"
 Controls Set Timer 13.62 Outer 0.0
 Reflector Water 6" above Bc
 Moderator Water 26.78"

Expt.	Condition	Timer	Outer	Safety	
65	k<1	13.62	0.0	26.00	3PN-41
66	k<1	"	"	"	3PN-42
67	k<1	13.00	0.0	26.00	3PN-43
68	"	12.50	0.0	"	3PN-44
69	"	12.50	12.00	26.00	3PN-45
70	"	12.50	0.0	"	3PN-46
71	"	12.00	"	"	3PN-47
72	"	14.00	"	"	3PN-48
73	"	8.00	"	"	3PN-49
74	"	6.00	"	"	3PN-50
75	"	2.00	"	"	3PN-51
76	"	0.00	"	"	3PN-52

Expt 78 Foil Exposure

Foils:

Inner: IE 15 E located in slot 97A

Outer OE 4 F " " " 209B

Norm foil 6B of IE 10 F - Slot 17 from 37A

Begin exposure at 8 ⁵⁵ AM	Expose for 30 min at	1	IC 3 ($\times 10^9$)
		4.5	on IC 4 ($\times 10^9$)
End " at 9 ²⁵ AM		4.5	IC 2 (3×10^9)

Expt 77 Foil Exposure w/target
 Instrument Check on 5-29-64 Source connected

M-1 Low Trip OK Alarm Trip OK
 M-2 Alarm Trip OK
 IC-1 > 3x10⁻¹¹ Meter Trip OK Fast Trip OK
 IC-2 > 3x10⁻¹¹ Meter Trip OK
 IC-3 Responds Calibration JH
 IC-4 Responds Calibration JH
 CRM Meter Trip

Preliminary Check on 5-29-64

Room-113 Pressure Differential 1.4⁴
 Red Light On and Personnel Check JH CC
 Scrums and Bldg, Alarm Resct. JH
 Source Inserted JH
 Safety Withdrawn 26.00
 Controls Set Inner 13.62 Outer 0.0
 Reflector Water 6" above Be
 Moderator Water same as Be. H₂O relays not op.

2.116 d/Sec	Condition	Inner	Outer	Safety	
T=46 sec	R>1	13.65	13.80	26.00	
R=17.3	R=1	13.63 ²	13.64 ⁵	26.00	\$108/in
	R=1	13.64 ³	13.64 ⁵	26.00	

shut down by scum buttons

Expt	Cond.	Inner	Outer	Safety	3PM
78	R<1	24.70	0.0	26.00	55
79	R<1	24.70	0.0	26.00	56
80	R<1	24.70	0.0	"	57
81	R<1	0.0	26.09	"	58

Expt. 82 Foil Exposure

Foil

Inner IE-18F located in slot 37A

Outer OE-15-I located in slot 78B

Norm. ϕ C of IE10F " " " 17 from 37A.

Begin Exposure at $11^{18}A$ expose for 30 min. at 10 IC-3 (10^{-8})
 6.5 IC-4 (10^{-8})
 End Exposure at $11^{49}A$ 3.8 IC-2 (3×10^{-8})

Expt 82 Foil Exposure w/target
 Instrument Check on 6-1-64 Source low

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 $> 3 \times 10^{-4}$ Meter Trip OK Fast Trip OK
 IC-2 $> 3 \times 10^{-4}$ Meter Trip OK
 IC-3 Responds Calibration JW
 IC-4 Responds Calibration JW
 CRM Meter Trip

Preliminary Check on 6-1-64
 Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check JW C.C.
 Scrums and Bldg, Alarm Reset JW
 Source Inserted JW
 Safety Withdrawn 26.00
 Controls Set Inner 13.62 Outer 4.00
 Reflector Water 2" above fl
 Moderator Water

	Condition	Inner	Outer	Safety	
1.993 div/sec	$k > 1$	13.63	13.85	26.00	
$T = 42 \text{ sec.}$	$k = 1$	13.63	13.64	26.00	1.89 div
$\rho = 18.44$	Shut down with scum button				

Expt. 83 w/target

Instrument Check on 6-2-64 Source 10 med

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Responds	Calibration	JH		
IC-4	Responds	Calibration	JH		
CRM		Meter Trip			

Preliminary Check on 6-2-64

Room 113 Pressure Differential 1.47
 Red Light On and Personnel Check JH
 Scrams and Bldg, Alarm Reset JH
 Source Inserted Acc.
 Safety Withdrawn 26.00
 Controls Set Inner 0.0 outer 26.09
 Reflector Water 6" above Be
 Moderator Water ~24.00

Condition	Inner	Outer	Safety	SPN
K<1	0.0	26.09	26.00	59

Expt 84

Pulse at critical	K	Time	Inner	Outer	H ₂ O	SPN
1.633 disp/sec	K>1	8.33	26.09	20.76 26.00	~26.00	121/sec
T=35.5 sec.	K=1	8.18	26.09	20.76	26.71	3PN-60

Expt 84a

Rhotta = 19.2 sec.	K=1	8.18	26.09	20.76	26.71	3PN-61
--------------------	-----	------	-------	-------	-------	--------

Expt 85

R=1	24.70	6.99	20.76	26.71	3PN-62
-----	-------	------	-------	-------	--------

Phase. Expr. 86 W/Turget
 Instrument Check on 6-3-64 Source 10min

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 > 3x10⁻⁴ Meter Trip OK Fast Trip OK
 IC-2 > 3x10⁻⁴ Meter Trip OK
 IC-3 Responds Calibration JH
 IC-4 Responds Calibration _____
 CRM 1 Meter Trip _____
 Preliminary Check-on 6-3-64
 Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check JH C.C.
 Scrams and Bldg, Alarm Reset JH
 Source Inserted C.C.
 Safety Withdrawn 20.77 in.
 Controls Set In. 24.70 Out. 0.0
 Reflector Water 6" above Be.
 Moderator Water 12" above Refl. Water.

	Condition	Inner	Outer	Safety	H ₂ O
<u>1.266 dwt/sec</u>	<u>k>1</u>	<u>24.70</u>	<u>7.15</u>	<u>20.77</u>	<u>1.149/in</u>
<u>T=27.5 sec</u>	<u>k=1</u>	<u>24.70</u>	<u>6.99¹⁶</u>	<u>20.77</u>	<u>3PN-63</u>
<u>P=23.8</u>					

Expt. 87

W/T+V

Instrument Check on 6-4-64 Source 10mcX

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Responds	Calibration	JH		
IC-4	Responds	Calibration	JH		
CRM		Meter Trip			

Preliminary Check on 6-4-64

Room 113 Pressure Differential	<u>1.4"</u>
Red Light On and Personnel Check	<u>JH CC</u>
Scrams and Bldg, Alarm Reset	<u>JH</u>
Source Inserted	<u>out</u>
Safety Withdrawn	<u>26.00"</u>
Controls Set	<u>Inner 24.70 Outer 0.0</u>
Reflector Water	<u>6" above Pc</u>
Moderator Water	<u>~ Bc</u>

	Condition	Inner	Outer	Safety	
Expt. 87	K<1	24.70	0.0	26.00	3PN-64
Expt. 88	K<1	"	"	"	3PN-65
2.133 hr/sec. Expt. 89	K>1	12.62	12.64	"	} $\phi .91/in$
T=26.4	K=1	12.62	12.45	"	
p=17.2	K=1	12.54	12.54	"	
	K=1	12.63 ⁵	12.63 ⁵	20.77	3PN-66
90	K<1	13.60	0.0	26.00	3PN-67
91	K<1	0.0	0.0	26.00	3PN-68

Fails

Inner IE 8A location 97A

Outer OE 16G " 209B

Norm foil 4B of IE10F in 17th slot from 37A

Begin exposure at 11⁰⁶/AM Expose for 30min. at $\begin{cases} 1 \\ 5 \\ 4 \end{cases}$ on $\begin{cases} IC3 & (10^{-8}) \\ IC4 & (10^{-8}) \\ IC2 & (3 \times 10^{-8}) \end{cases}$

End " " 11³⁸/AM. 5.5 IC1 (3 x 10⁻⁸)

Expt. 92 Foul Exposure w/target
 Instrument Check on 6-5-64 Source 10mcX

FM-1 Low Trip OK Alarm Trip OK
 FM-2 Alarm Trip OK
 IC-1 > 3 x 10⁻¹¹ Meter Trip OK Fast Trip OK
 IC-2 > 3 x 10⁻¹¹ Meter Trip OK
 IC-3 Responds Calibration JH
 IC-4 Responds Calibration JH
 CRM Meter Trip

Preliminary Check on 6-5-64

Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check JH CC
 Scrums and Bldg, Alarm Reset JH
 Source Inserted C.C.
 Safety Withdrawn 26.00"
 Controls Set Inner 13.64 Outer
 Reflector Water 6" above Be
 Moderator Water ~ Be.

	Condition	Inner	Outer	Safety	Rhoette
2.233 in/sec	$k > 1$	13.64	13.80	26.00	15.14
$T = 48.5 \text{ sec}$	$k = 1$	13.64	13.63	26.00	19.84

Shut down by interrupting magnet current on safety.

Expr. 93 w/target
 Instrument Check on 6-9-64 Source comet

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK		
IC-3	Responds	Calibration	JH		
IC-4	Responds	Calibration	JH		
ERM		Meter Trip			

Preliminary Check on 6-9-64

Room-113-Pressure Differential	<u>1.4"</u>
Red Light On and Personnel Check	<u>JH</u>
Scrams and Bldg. Alarm Reset	<u>JH</u>
Source Inserted	<u>JH</u>
Safety Withdrawn	<u>0.0 (9973.1)</u>
Controls Set Inner	<u>0.0</u> outer <u>0.0</u>
Reflector Water	<u>~ 6" above bc</u>
Moderator Water	<u>26.64"</u>

	Condition	Inner	Outer	Safety	
2.350 dwt/sec T = 5166 P = 16.14	k > 1	17.36	17.36	9973.1	1.12
	R = 1	17.36	17.21	"	1.07
	R = 1	17.21 ⁵	17.36	"	1.11
	R = 1	17.28 ⁶	17.28	"	1.05
5.0 dwt/sec T = 10816 P = -22.1	k < 1	17.20	17.20	"	-1.33

Expn. 100 w/target.
 Instrument Check on 6-10-64 Source 10mc

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Respond	Calibration	JH		
IC-4		Calibration	JH		
CRM		Meter Trip			

Room Preliminary Check on 6-10-64
 Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check JH
 Scrams and Bldg. Alarm Reset JH
 Source Inserted JH
 Safety Withdrawn 0.0
 Controls Set Inner 0.0 Outer 0.0
 Reflector Water 6" above bc
 Moderator Water 26.25"

Condition	Inner	Outer	safety	
$k > 1$	17.36	17.36	9973.1	3PN-76
$k = 1$	17.28	17.29	9973.1	3PN*
$k < 1$	17.24	17.24	9973.1	78
"	17.00	17.00	"	78
"	17.00	17.00	"	78
"	16.75	16.75	"	79
"	16.75	16.75	"	80

2.36 dw/sec
 $T = 32.3$
 $P = 16.1$

Expn. #
 $T = 2.173$ 101
 $P = 7.3$ 102

$k_{eff} = 1.9954$ (A) (0.0064)

3PN*

1.8 dw/sec

EXP	RUN	PAGE NO.	3PN NO.	CONDITION /k	INNER (IN)	OUTER (IN)	SAFETY (cm)	Chan. width	Bkg	Delay	Disc.	Mem.	Burst width	Exp. Rate
46	*	59	28	R=1	15.53 ⁵	0.0	20.57	160	4	4	4	1/2	800	25
47	*	61	29	R=1	11.38 ⁵	0.0	20.	160	4	2	4	1/2	800	23
48		61	30	R<1	0.0	0.0	26.00	40	2	2	4	1/2	400	128
49		63	31	R<1	0.0	0.0	26.00	40	4	4	4	1/2	300	128
50	*	63	32	R=1	12.67 ⁵	0.0	20.77	160	4	4	4	1/2	800	39.8
52	*	65+2	33	R<1	13.56	999.99	26.00	40	4	4	4	1/2	800	127
52	*	65+2	34	R<1	13.56	999.99	26.00	80	4	4	4	1/2	800	126
53	*	65+2	35	R<1	0.0	999.99	26.00	40	4	4	4	1/2	600	117
54	*	65+2	36	R=1	16.63 ⁵	"	20.77	160	4	4	4	1/2	800	39.8
55	*	67	37	R<1	13.56	999.99	26.00	80	4	4	4	1/2	800	125
56	*	67	38	R<1	13.56	"	"	80	4	4	4	1/2	800	90
57	*	67	39	R<1	0.0	"	"	40	2	4	4	1/2	500	129
58	*	68	40	R=1	14.80	"	20.77	180	4	4	4	1/2	900	40
65		83	41	R<1	13.62	0.0	26.00	20	4	16	4	1/2	350	195
66		83	42	R<1	13.62	0.0	26.00	40	4	8	4	1/2	500	121
67		83	43	R<1	13.00	0.0	26.00	40	4	8	4	1/2	500	122
68		83	44	R<1	12.50	0.0	26.00	40	4	8	4	1/2	600	121
69		83	45	R<1	12.50	12.00	26.00	40	4	8	4	1/2	600	119
70		83	46	R<1	12.50	0.0	26.00	40	4	8	4	1/2	480	119
71		83	47	R<1	12.00	0.0	26.00	40	4	8	4	1/2	480	119
72		83	48	R<1	11.00	0.0	26.00	40	4	8	4	1/2	480	119
73		83	49	R<1	9.00	0.0	26.00	40	4	8	4	1/2	480	119
74		83	50	R<1	6.00	8.0	26.00	40	4	8	4	1/2	480	119
75		83	51	R<1	2.00	0.0	26.00	40	4	8	4	1/2	480	124
76		83	52	R<1	0.0	0.0	26.00	40	4	8	4	1/2	180	124
78		85	53	R<1	24.70	0.0	26.00	80	4	4	4	1/2	480	143
78		85	54	R<1	24.70	0.0	26.00	40	4	8	4	1/2	480	120
78		85	55	R<1	24.70	0.0	26.00	40	4	8	12	1/2	200	117
79		85	56	R<1	24.70	0.0	26.00	40	16	8	4	1/2	200	117
								80	8	4	4	1/2	480	63

Acc ✓	acc current	Beam current	yno.	Spt. λ	Cal λ	Island Condition
145	.8 ma	1 μa	14233	189	179±1	3/4 Cont W/Target
146	.87	1.2	22189	211	202±1	3/4 cont W/4 3/16 Styro V.
145	.90	4.0	150493	1437 ^{6.3}	(1250±20) ^{6.3}	4 3/16 Styro. Void 3/4
145	.96	4.0	137125	1725 ^{7.9}	(1660±30) ^{7.8}	T + Void, 3/4
145	.87	2.0	21647	218	212±1	W/T+V. 3/4
145	.84	4.0	100019	682 ^{2.4}	(610±10) ^{2.4}	3/4 C-Mod. W/T+V
148	.84	2.0	71006	608 ^{2.3}	(600±10) ^{2.4}	"
145	.86	4.0	247402	1785 ^{6.4}	1750±10 ^{7.0}	"
145	.86	1.2	12008	261	249±2	"
145	.90	4.0	21850	312 ^{1.4}	325±5 ^{1.4}	3/4 C-Mod W/4 3/16 Styro V.
145	.95	4.0	21060	323 ^{1.4}	325±5	"
145	.95	6.0	18458	1290 ^{5.6}	1300±10 ^{5.6}	"
144	.86	1.6	36682	230	232±1	"
146	.91	6.0	247790	1548 ^{7.78}	1520±20 ^{7.30}	4/4 control W/T
145	.93	6.0	115605	1430 ^{7.19}	1370±20 ^{6.99}	"
145	1.01	8.1	75061	1444 ^{7.22}	1400±25 ^{7.26}	"
145	1.01	10.4	20853	1535 ^{7.72}	1450±25 ^{7.37}	"
145	.96	8.0	69291	834 ^{4.20}	780±10 ^{3.91}	"
145	1.04	10.4	53777	1515 ^{7.62}	1430±15 ^{7.10}	"
145	1.04	10.4	120072	1567 ^{7.98}	1500±25 ^{7.65}	"
145	1.02	10.0	178204	1599 ^{8.04}	1560±30 ^{7.58}	"
145	1.02	10.0	152161	1738 ^{8.74}	1735±40 ^{8.76}	"
145	1.06	10.0	197100	2038 ^{10.25}	1990±25 ^{9.86}	"
145	1.10	11.8	97805	2302 ^{11.58}	2120±15 ^{10.85}	"
145	1.10	12.0	95956	2303 ^{11.58}	2200±20	"
145	1.05	7.0	8307	931 ^{4.8}		
145	1.05	11.5	29180	991 ^{4.70}	971±4	
145	.94	2.0	138162	1001 ^{5.04}		
145	.94	2.0	154847	1028 ^{5.02}		

Expr	page	3-PN No.	Condition	Inner	Outer	Safety	Chan. width	Bay	delay	disc	Mem.	Burst width	Rep Rate	Acc KV	relat I
80	85	57	k<1	24.70	0.0	26.00	80	8	4	4	1/2	400	69	145	0.
81	85	58	k<1	0.0	26.09	26.00	80	8	8	4	1/2	800	71	145	0.
83	{89}	59	k<1	0.0	26.09	26.00	80	8	16	4	1/2	800	70	145	0.
		87	59	k<1	0.0	26.09	26.00	80	8	16	4	1/2	800	70	145
84	89	60	k=1	8.18	26.09	20.77	160	8	16	4	1/2	900	36	145	0.
84a	89	61	k=1	8.18	26.09	20.77	160	8	16	4	1/2	900	36	145	0.
85	89	62	k=1	24.70	6.99	20.77	160	8	16	4	1/2	900	36	145	0.
86	91	63	k=1	24.70	6.99	20.77	160	8	16	4	1/2	900	36	145	0.
87	93	64	k<1	24.70	0.0	26.00	40	4	16	4	1/2	480	100	145	0
88	93	65	k<1	24.70	0.0	26.0	40	4	16	4	1/2	480	100	145	1
89	93	66	k=1	12.635	12.635	20.77	160	8	16	4	1/2	1600	36	145	0.
90	93	67	k<1	13.60	0.0	26.00	40	4	16	4	1/2	600	117	145	1
91	93	68	k<1	0.0	0.0	26.00	40	4	16	4	1/2	600	117	145	0
93	97	69	k<1	17.20	17.20	9973.1	160	4	16	4	1/2	900	32.4	145	0
94	97	70	k<1	17.20	17.20	9973.1	80	4	16	4	1/2	800	70.0	145	0
95	97	71	k<1	16.50	16.50	9973.1	40	4	16	4	1/2	400	100	145	1
95	97	71	k<1	15.00	15.00	9973.1	40	4	16	4	1/2	400	100	145	1
96	97	72	k<1	16.00	16.00	9973.1	40	4	16	4	1/2	400	100	145	1
97	97	73	k<1	16.5	16.5	9973.1	40	4	16	4	1/2	400	100	145	1
98	97	74	k<1	17.00	17.00	9973.1	320	4	2	4	1/2	500	20	145	1
99	97	75	k<1	17.00	17.00	9973.1	160	4	4	4	1/2	500	30	145	1
100	99	76	k<1	17.24	17.24	9973.1	640	2	2	4	1/2	1000 320	8.5 275	138	1
101	"	77	k<1	17.24	17.24	9973.1	1280	2	2	4	1/2	1280	9.2	138	1
102	"	78	k<1	17.00	17.00	9973.1	640	2	2	4	1/2	640	8.0	145	1
103	"	79	k<1	16.75	16.75	9973.1	320	2	4	4	1/2	1280	18.0	145	1
104	"	80	k<1	16.75	16.75	9973.1	40	4	2	4	1/2	1280	20.0	145	1
105	111	81	k<1	16.50	16.50	9973.1	80	4	16	4	1	1280	15	145	1
105 ¹	111	82	k<1	16.75	16.75	9973.1	80	4	16	4	1/2	1280	15	145	1
105 ⁴	111	83	k<1	15.75	15.75	9973.1	80	4	16	4	1/2	1280	45	145	1

relator	I ma	Beam cur. μ a	Cycles	Est λ	Calc. λ	Island
	0.94	2.0	47554	977 ⁴⁷¹	971±4 ⁴⁷⁸	T
	0.90	3.0	66448	1523 ⁷⁴⁶	1315±50 ⁷⁵⁰	↓
	0.74	0.6	344997	1488 ⁷⁴⁸	1325±50 ⁷⁵⁰	
	0.91	3.0				
	0.87	4.0	4486	176	172±1	
	0.82	3.0	17565	187	173±1	
	0.89	2.0	10208	193	195±1	↓
	0.92	2.0	55250	205	195±1	T
	0.91	4.0	125008	559 ²⁴	565±3 ²⁴	T+V
	1.02	8.0	69019	565 ²⁴	565±3 ²⁴	↓
	0.89	4.0	17412	238	236±1	
	1.00	10.0	100023	1123 ⁴⁷	1100±20 ⁴⁶	↓
	0.91	6.0	420134	1794 ⁸⁴	1900±20 ⁸¹	T+V
	0.90	1.9	35006	165		T+ Safety
	0.84	2.1	110008	165		
	1.09	3.2				
	1.05	10.0	260001	1000	905±25	
	1.05	10.0	276441	750	700±25	
	1.05	10.0	198856	605	500±20	
	1.05	2.0	19212	290	280±5	
	1.03	2.6	55115	295	280±5	
	1.01	2.0	5251		170±20	
	1.01	1.2	4357		170±10	
	1.01	1.2	130777		300±10	
	1.03	4.6	43002		450±30	
	1.02	5.0	38522		630±30	
	1.01	3.0	91907		640±40	
	1.0	3.0	125001		580±20	
	1.0	10.0	150004		1250±40	↓

Expt. #	Page	3-PN#	k	Inner	Outer	Safety	Island	Chan. width	By	Delay	Disc	Mem.	Burst width	Cps	KV	I ma	Beam µa
108	115	84	<1	0.0	0.0	26.0	T	40	4	4	4	1/2	1000	30	145	2.0	7.0
110	117	85	<1	24.70	0.0	26.00	T	40	4	8	4	1/2	800	30	145	1.05	6.0
112	121	86	<1	14.06	0.0	26.00	W	40	4	8	4	1/2	480	50	145	1.05	5.0
113	121	87	<1	14.06	0.0	26.00	W	40	4	8	4	1/2	800	120	145	0.94	12.0
114	121	88	<1	0.0	14.06	26.00	W	40	4	8	4	1/2	800	120	145	0.95	14.0
115	121	89	<1	0.0	14.06	26.00	W	10	256	64	4	1/2	800	120	145	0.95	14.0
116	121	90	<1	11.80	0.0	26.00	S	10	64	32	4	1/2	500	210	145	0.94	11.5
117	121	91	<1	11.80	0.0	26.0	S	40	32	8	4	1/2	480	100	145	1.05	10.5
118	121	92	<1	0.0	11.8	26.0	S	40	32	8	4	1/2	480	100	145	1.04	10.5
127	135	93	<1	99812	99812	26.0	T	80	2	2	4	1/2	800	70	145	.92	7.5
128	135	94	<1	"	"	"	"	10	37	64	4	1/2	800	240	145	.92	20.0
129	137	95	<1	"	"	"	"	10	2	2	4	1/2	200	320	144	1.06	17.0
-	-	96	<1	13.63	13.63	0	T	40	8	8	4	1/2	500	110	145	1.01	12.0
175	153	114	<1	0.0	0.0	26.00	T	40	4	4	4	1/2	600	100	145	.98	8.0
176	153	115	<1	0.0	0.0	26	T	160	4	8	4	1/2	1000	35	145	1.08	8.0
177	153	116	<1	15.23	0.0	26	T	20	4	8	4	1/2	600	200	145	.92	6.0
178	153	117	<1	26.17	0.0	26	T	20	4	8	4	1/2	600	200	145	.92	6.0
179	153	118	<1	15.23	2.0	26	T	40	4	8	4	1/2	600	110	145	.92	8.0
180	153	119	<1	15.23	4.0	26	T	40	4	8	4	1/2	600	100	145	.95	8.0
181	153	120	<1	15.23	6.0	26	T	40	4	8	4	1/2	600	100	145	.95	8.0
182	153	121	<1	15.23	8.0	26	T	20	4	32	4	1/2	600	180	145	.96	14.0
183	153	122	<1	0	75.23	26	T	20	4	16	4	1/2	600	180	145	.94	6.0
184	161	123	k=1	15.2	15.2	20.7	T	160	8	8	4	1/2	1000	36	145	.83	2.0
190	161	127	k<1	0.0	25.58	26	T	20	8	32	4	1/2	640	170	145	.88	10.0
191	163	125	k<1	26.87	0	26	T	20	8	32	4	1/2	900	160	145	.85	9.0
193	167	126	k<1	15.23	0	26	T	20	8	16	4	1/2	640	150	145	.82	6.0
194	167	127	k<1	15.61	0	26	W	40	4	16	4	1/2	640	110	145	.97	14.0
195	169	128	k=1	15.63	15.63	20.77	W	160	8	8	4	1/2	1000	30	145	.90	4.0

Estimate	Calc.	Cycles	$\frac{1}{T_{eff}}$
8374	5500 ± 500	615618	
1577	1500 ± 30	226673	
2258	1800 ± 50	240008	
2200	2000 ± 200	646656	
3412	3 200	913471	
4329	3400 ± 800	⁵⁴⁴⁴⁶⁷ 2130	
1540	1400 ± 40	613025	
1400	—	1015864	
1952	1780 ± 50	715564	
	—	953086	
	3600 ± 200	1700000	
	4000 ± 300	4500000	
	1350 ± 50	750000	118 mg/g Boron in core
Eu₂O₃ Rods			
43021	3000 ± 50	400000	11.70
230100	3000 ± 40	240000	14.872
2132	2122 ± 20	2700000	10.453
1881	1802 ± 15	1622773	8.88
2074	2140 ± 9	180000	10.542
2074	2076 ± 18	110719	10.226
2100	1900 ± 15	110000	9.360
1880	1700 ± 18	740000	8.374
2602	2650 ± 20	1450000	13.054
215	203 ± 3	45016	1
1218	2400 ± 25	1490000	11.823
1989	1828 ± 9		9.005
2319	2160 ± 15	1450000	10.647
2173	2104 ± 26	600000	10.365
2222	203 ± 2	⁴⁴⁷⁰⁷ 1450000	1

Expr #	Page	3PN #	K	Inner	Outer	Safety	Isl.	Ch. width	Bkg	Delay	Disc	Mem	Burst width	Cps	KV	I
196	169	129	R<1	24.75	0	26.00	W	20	8	16	4	1/2	500	150	145	.8
197	171	130	R<1	0	24.75	26.00	W	20	8	16	4	1/2	500	180	145	.95
198	171	131	R<1	0	0	26.00	W	20	8	16	4	1/2	500	180	145	.95
199	173	132	R=1	14.50	14.50	20.78	T+V	160	8	8	4	1/2	10 ²	35	145	.8
200	175	133	R<1	14.41	0	26.00	T+V	20	8	16	4	1/2	400	200	145	.81
202	179	134	R<1	24.75	0	26.00	T+V	20	8	16	4	1/2	400	200	145	.81
203	179	135	R<1	0	24.75	26.00	T+V	20	8	16	4	1/2	400	200	145	.82
204	181	136	R<1	15.23	0	26.00	T+V	20	8	16	4	1/2	400	200	145	1.06
207	183	137	R<1	0	0	26.00	T+V	20	8	16	4	1/2	400	200	150	1.08
209	185	138	R<1	15.23	0	26.00	V	20	8	16	4	1/2	400	200	150	0.95
210	187	139	R<1	15.61	0	26.00	V	40	8	16	4	1/2	600	100	150	0.97
211	187	140	R<1	24.75	0	26.00	V	40	8	16	4	1/2	600	100	150	0.97
212	187	141	R<1	0	24.75	26.00	V	40	8	16	4	1/2	600	100	150	1.06
213	187	142	R<1	0	0	26.00	V	20	8	32	4	1/2	600	100	150	.97
214	189	143	R=1	14.02	14.02	20.78	V	160	8	8	4	1/2	1000	38	148	.95
215	189	144	R<1	0	Rotated 0	26.00	V	40	8	16	4	1/2	600	100	150	1.01
216	189	145	R<1	15.61	Rot 0	26.00	V	40	8	16	4	1/2	600	100	150	1.00
217	189	146	R<1	15.61	Rot 0	26.00	W	20	8	32	4	1/2	600	180	150	.91
218	189	147	R<1	0	Rot 0	26.00	W	20	8	32	4	1/2	600	180	150	.91
219	191	148	R=1	14.09	Rot 13.975	20.78	V	160	8	8	4	1/2	1000	38	146	.94
220	191	149	R<1	15.23	Rot 0	26.00	T+V	40	8	16	4	1/2	600	100	150	1.00
221	191	150	R<1	0	Rot 0	26.00	T+V	20	8	32	4	1/2	600	180	150	1.00
222	191	151	R<1	15.23	Rot 0	26.00	T	20	8	32	4	1/2	600	180	150	1.0
223	191	152	R<1	0	Rot 0	26.00	T	20	8	32	4	1/2	600	180	150	1.0
224	193	153	R<1	0	R 3/4 0	26.00	T	20	8	32	4	1/2	600	180	150	1.0
225	193	154	R<1	15.23	R 3/4 0	26.00	T	40	8	16	4	1/2	600	80	148	1.0
226	193	155	R<1	15.23	R 3/4 0	26.00	T	80	8	16	4	1/2	1000	60	148	1.0
227	197	156	R=1	15.23	R 3/4 12.57	20.78	T	160	8	8	4	1/2	1280	38	148	1.0
228	195	157	R<1	0.0	R 3/4 0.0	26.00	V	20	8	32	4	1/2	600	180	150	1.06

Beam I	Cycles	λ_{est}	$\lambda_{cal.}$	λ/λ_c
8.0	1450000	1948	1848 ± 24	9.103
13.0	2250000	2542	2288 ± 32	11.271
13.0	2450000	3010	2887 ± 50	14.222
2.0	89812	258	237 ± 3	1
7.0	2450000	2060	1980 ± 15	8.354
4-6.0	3874977	1606	1495 ± 8	6.308
4.0	3534452	2312	2148 ± 30	9.063
12.0	1341746	1958	1895 ± 11	7.996
14.00	346184	3046	2834 ± 19	11.958
10.0	350000	1465	1412 ± 7	6.28
8.0	111038	1375	1338 ± 8	5.95
8.0	100000	1059	1070 ± 4	4.76
8.0	150000	1645	1600 ± 14	7.11
42.0	450000	2174	2105 ± 8	9.36
54.0	70409	2227	2225 ± 1	1
59.0	760000	1960	1940 ± 10	8.624
82.0	2000000	1375	1348 ± 12	5.85
12.0	500000	2075	2060 ± 14	10.15
12.0	530000	2776	2626 ± 22	12.94
4.0	102.10	226	225 ± 1	1
9.0	130000	1865	1770 ± 25	7.47
15.0	350000	2732	2526 ± 20	10.66
15.0	300000	5162	2096 ± 14	10.33
15.0	500000	2875	2650 ± 30	13.95
7.0	500000	2576	2646 ± 20	14.95
3.8	100000	709	690 ± 4	3.90
3.8	60000	681	690 ± 2	3.90
2.5	43212	187	177 ± 1	1
14.0	770000	1939	1900 ± 10	10.27

Back from shop.

R = 100007

Expt. #	Page #	3PN #	K	Inner	Outer	Safety	Island	Cham. width	BRy	Delay	Disc.	Mem	Burst width	Cps	KV	I
229	199	158	R<1	15.23	R ^{3/4} 0.0	26.00	T+V	80	8	16	4	1/2	1000	60	148	1.0
230	199	159	R<1	0	R ^{3/4} 0	26.00	T+V	20	8	32	4	1/2	600	180	148	1.02
231	201	160	R=1	15.23	R ^{3/4} 9.67	20.86	T+V	160	8	8	4	1/2	1000	35	148	.94
232	203	161	R<1	15.23	R ^{3/4} 0	26.00	T+V	20	8	32	4	1/2	600	100	149	1.13
233	203	162	R<1	15.23	R ^{3/4} 0	26.00	T+V	20	8	32 25.6	4	1/2	600	100	149	1.19
234	203	163	R=1	15.23	R ^{3/4} 0	6.92	V	160	8	8	4	1/2	1000	35	150	.90
235	205	164	R<1	15.23	R ^{3/4} 0	26.00	T+V	20	8	32	4	1/2	600	100	150	0.97
236	205	165	R<1	15.23	R ^{3/4} 0	26.00	T+V	40	8	16	4	1/2	600	100	150	1.00
237	205	166	R<1	15.23	R ^{3/4} 0	26.00	T+V	80	8	8	4	1/2	640	80	150	1.05
238	207	167	R<1	0	R ^{3/4} 0	26.00	T+V	20	8	32	4	1/2	600	180	150	1.20
239	207	168	R<1	15.23	R ^{3/4} 0	26.00	T+V	80	8	16 32	4	1/2	1000	70	150	1.08
240	207	169	R<1	15.23	R ^{3/4} 0	26.00	T+V	40	8	16	4	1/2	630	100	150	.90
241	207	170	R<1	15.23	R ^{3/4} 0	26.00	T+V	40	8	16	4	1/2	630	100	150	.90
243	209	171	R<1	0	0	26.00	T	40	8	16	4	1/2	630	100	150	1.05
244	209	172	R<1	0	0	26.00	T	20	8	32	4	1/2	630	180	150	1.07
245	209	173	R<1	0	0	26.00	W	20	8	32	4	1/2	630	210	150	1.02
246	209	174	R<1	0	0	26.00	V	20	8	32	4	1/2	630	210	150	1.03
247	211	175	R<1	0	0	26.00	T+V	20	8	32	4	1/2	630	210	150	.98
248	211	176	R<1	15.23	14.00	26.00	T	80	8	16	4	1/2	1000	70	150	.81
249	211	177	R<1	15.23	13.00	26.00	T	80	8	16	4	1/2	1000	70	150	.82
250	211	178	R<1	15.23	11.00	26.00	T	40	8	16	4	1/2	630	100	150	.86
251	211	179	R<1	15.23	9.0	26.00	T	20	8	32	4	1/2	630	210	150	.87
252	211	180	R<1	15.23	7.0	26.00	T	20	8	32	4	1/2	630	210	150	.88
253	211	181	R<1	15.23	5.0	26.00	T	20	8	32	4	1/2	630	210	150	.90
254	211	182	R<1	15.23	3.0	26.00	T	20	8	32	4	1/2	630	210	150	.90
255	211	183	R<1	15.23	1.0	26.00	T	20	8	32	4	1/2	630	210	150	.91

Beam I	Cycles	λ_{est}	λ_{cal}	λ/λ_c	
12.0	50000	451	450 ± 1	1.96	
23.0	220000	2509	2410 ± 25	10.48	
8.0	26007	237	230 ± 1.4	1	
28.5	110000	2525	2450 ± 26	10.65	Error: either control or safety subtract B_{eg} from 3PK-161 inserted. π increase
28.0	110000	2656	2550 ± 25	11.09	
3.9	10510	191	185 ± 1	1	
8.0	110000	¹⁰ 832	825 ± 6	3.48	
8.0	110000	²³ 786	780 ± 4	2.29	
8.0	40000	²⁷ 787	780 ± 3	3.29	
20.0	150,000	2509	2430 ± 50	10.57	
10.0	20,000	451	439 ± 10	1.91	
4.0	110,000	1059	1040 ± 20	4.39	$C_d(10,00)$
4.0	100000	631	630 ± 15	2.66	$C_d(15,23)$ end $3/4$ rod.
8.0	120000	2915	2325 ± 400	11.44	$1/4$ rods. slots aligned (R)
16.0	240000	2833	2600 ± 200	12.79	
18.0	270000	2652	2675 ± 100	13.24	
20.0	200000	2495	1982 ± 20	8.81	
20.0	270000	2792	2609 ± 70	11.01	
3.0	37162	486	474 ± 3	2.33	
3.0	40622	711	685 ± 10	3.37	
5.0	59090	1157	1090 ± 40	5.36	
12.0	131666	1500	1511 ± 80	7.43	
14.0	137189	1840	1750 ± 50	8.61	
14.0	154706	2064	2040 ± 60	10.04	
14.0	152385	2127	2070 ± 70	10.18	
-16.0	138525	2127	2080 ± 75	10.23	

Exp 105 w/target

Instrument Check on 6-12-64 Source Co mod

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip	OK
IC-2	3×10^{-11}	Meter Trip	OK		
IC-3	Responds	Calibration	JH		
IC-4	Responds	Calibration			
CRM		Meter Trip			

Preliminary Check on 6-12-64

Room 113 Pressure Differential 1.4"

Red Light On and Personnel Check JH

Scrams and Bldg. Alarm Reset JH

Source Inserted JH

Safety Withdrawn 9973.1

Controls Set Inner 16.50 Outer 16.50

Reflector Water 6" above 60

Moderator Water 26.75"

	Condition	Inner	Outer	3 PN #
105	kci	16.50	16.50	81
105'	kci	16.75	16.75	82
105"	kci	15.75	15.75	83

Foil Exposure:

Foils

		location	
Inner	IE 13 A		146 a
Outer	OE 13 F	"	315 b
Norm	foil 4 of IE 10 F	"	17 th slot from 37 a

Begin timing	8 ²⁶ AM	Expose > 30 min	at	1 on IC-3	10 ⁻⁸ scale
Shutdown	8 ⁵⁶ AM			4 on IC-2	3 x 10 ⁻⁸ "
				5 on IC-1	3 x 10 ⁻⁸ "
				5 on IC-4	10 ⁻⁸ scale (meter)

Expt. 106 w/target.

Expose fails.

Instrument Check on 6-15-64 Source 10 mil

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 7.3×10^{-4} Meter Trip OK Fast Trip OK
 IC-2 7.3×10^{-11} Meter Trip OK
 IC-3 Responds Calibration JN
 IC-4 Responds Calibration Recorder out of op.
 CRM Meter Trip

Preliminary Check on 6-15-64

Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check JN CC.
 Scrams and Bldg. Alarm Reset J.N.
 Source Inserted JN
 Safety Withdrawn 26.00
 Controls Set Inner 13.6 Outer 0.0
 Reflector Water 6" above Be
 Moderator Water 26.77"

	Condition	Inner	Outer	Safety	
1.612 dir/sec	$R > 1$	13.63	13.85	26.00	$1.99/\mu$
$T = 35.2 \text{ sec}$	$R = 1$	13.63	13.64'	26.00	
$P = 20.64$			<small>209</small>		

Interrupt mag. current for shut down at $8.5 \frac{1}{\mu\text{sec}}$

Foil:

Inner: IE-19A, Location 1a

Outer: OE-7F Location 1b

Norm: foil 2 of IE 10F, " slot 17 from 37a

Target foil 1 " " " " 23/32" from center of Island.

Begin exposure at 8⁴⁶, expose for 30 min. at

End exposure at 9¹⁶ AM

1	IC3	10^{-8}
6	IC4	10^{-8}
4.5	IC2	3×10^{-8}
5.2	IC1	3×10^{-8}

Expt 107

w/target

Foil Exposure

Instrument Check on 6-16-64 Source comet

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Responds	Calibration	JH		
IC-4	Responds	Calibration	JH		
CRM		Meter Trip			

Preliminary Check on 6-16-64

Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check JH C.C.
 Scrams and Bldg, Alarm Reset JH
 Source Inserted JH
 Safety Withdrawn 26.00"
 Controls Set Inner 13.63 Outer 0.0
 Reflector Water 6" above B.C.
 Moderator Water _____

	Condition	Inner	Outer	Safety		Rhoctc
1.7 div/sec	K > 1	13.63	13.85	26.00	1.96/w	18.494
TE 26.94 sec	K = 1	13.63	13.64 ²	26.00		
E = 19.98			2.08			

Interrupt magnet current for shutdown.

Expt 108 K < 1 0.0 0.0 26.00 3PN-84

foils

Inner IE-7E location: 37a

Outer OE-2I location: 78b

Nom: foil 1-C of IE 10F location: slot 17 from 37a

Begin Exposure	8 ⁴³ /AM	Expose 30 min.	at	$\left\{ \begin{array}{l} 1 \\ 6 \\ 4.2 \\ 1.7 \end{array} \right\}$	IC 3	10^{-8}
					IC 4	10^{-8}
End	4	9 ¹³ /AM			IC 2	3×10^{-8}
					IC 1	10×10^{-8}

Expr 109 w/target
 Instrument Check on 6-17-64 Source 20mc

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$>3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$>3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Repeats	Calibration	JH		
IC-4	Repeats	Calibration	JH		
CRM		Meter Trip			

Preliminary Check on 6-17-64

Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check JH C.C.
 Scrams and Bldg, Alarm Reset JH
 Source Inserted JH 1 2 3 + 4 respond.
 Safety Withdrawn 26.00
 Controls Set Inner 13.63, Outer 0.0
 Reflector Water 6" above 82
 Moderator Water 26.60"

Condition	Inner	outer	Safety	Rhoete
K > 1	13.63	13.85	26.01	17.89
K = 1	13.63	13.65	26.01	

9 ^{13.5}
 Drop Safety to shut Down

Expr. 110 K < 1 24.70 0.0 26.00 3PN-85

Foil:

Inner IE-6F location 72 a

Outer OE 16F location 155 b

Norm. Foil 1B of IE-10F location slot #17 from 37 a

Reflector water

	Foil	location
From IE-156	4B	in contact with Be.
	4C	2" from Be surface
	4D	4" from Be "
	4E	6" from Be "

foil on radial lines midway between beam^{tube} at 72 a and
radial beam tube at 1a.

Begin exposure at 9⁰⁵ AM Expose 30 min. at $\left. \begin{matrix} 1.0 \\ 6.0 \\ 4.2 \\ 6 \end{matrix} \right\}$ on $\left. \begin{matrix} IC3 & 10^{-8} \\ IC4 & 10^{-8} \\ IC2 & 3 \times 10^{-8} \\ IC1 & 3 \times 10^{-8} \end{matrix} \right\}$

End exposure 9³⁸ AM

Foil Exposure Expr 110 w/target.
 Instrument Check on 6-18-64 Source 10 mc x

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	5.3×10^{-4}	Meter Trip	OK	Fast Trip	OK
IC-2	7.3×10^{-4}	Meter Trip	OK		
IC-3	Responds	Calibration	JH		
IC-4	Responds	Calibration	JH		
CRM		Meter Trip			

Preliminary Check on 6-18-64

Room 113 Pressure Differential 6.4"
 Red Light On and Personnel Check JH C.C.
 Scrams and Bldg, Alarm Reset
 Source Inserted JH
 Safety Withdrawn 26.00"
 Controls Set Inner 13.63 Outer
 Reflector Water 6" above Be.
 Moderator Water 26.85

Condition	Inner	Outer	Safety
K > 1	13.63	18.85	26.00
K = 1	13.63	13.63	26.00

Dropped safety to shut down.

Expr 112 w/o T - w/o V
 Instrument Check on 6-19-64 Source 10 mcd

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 $> 3 \times 10^{-10}$ Meter Trip OK Fast Trip OK
 IC-2 $> 3 \times 10^{-10}$ Meter Trip OK
 IC-3 Responds Calibration JII
 IC-4 Responds Calibration JII
 CRM Meter Trip

Preliminary Check on 6-19-64

Room 113 Pressure Differential 4.4"
 Red Light On and Personnel Check JII - C.C.
 Scrams and Blg, Alarm Reset JII
 Source Inserted No - see Acc.
 Safety Withdraw 26.00
 Controls Set Variable
 Reflector Water 6" above Re
 Moderator Water 21.85"

Expr.	Condition	Inner	Outer	3PA#
112	k<1	14.06	0.0	86
113	k<1	14.06	0.0	87
114	k<1	0.0	14.06	88
115	k<1	0.0	14.06	89

fits:

Inner ← BE-18F Location 37a
 Outer OF 15I " 98b
 Inner IE-7G " 97a
 Outer OE 8G " 207b
 Norm foil 6 of IE 10F " 17th slot from 37a

Begin Exposure at 10^{+8} Expose 30 min. at $\left\{ \begin{array}{l} 1 \\ 6 \end{array} \right\}$ IC3 $\left\{ \begin{array}{l} 10^{-7} \\ 10^{-9} \end{array} \right\}$
 End " " 11^{+6} $\left\{ \begin{array}{l} 4.4 \\ 5.6 \end{array} \right\}$ IC2 $\left\{ \begin{array}{l} 3 \times 10^{-8} \\ 3 \times 10^{-9} \end{array} \right\}$ IC1

Expr. 116 w/ target
 Instrument Check on 6-22-64 Source 10 mcY

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 $> 3 \times 10^{-4}$ Meter Trip OK Fast Trip OK
 IC-2 $> 3 \times 10^{-4}$ Meter Trip OK
 IC-3 Responds Calibration JH
 IC-4 Responds Calibration JH
 CRM Meter Trip

Preliminary Check on JH

Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check JH C.C.
 Scrums and Bldg. Alarm Raset JH
 Source Inserted C.C.
 Safety Withdraw 26.00
 Controls Set I: 13.63 D: 0.0
 Reflector Water 6" above 8c
 Moderator Water 26.83"

Condition	Timer	Outer	Safety
k>1	13.63	13.85	26.00
k=1	13.63	13.64	26.00

Interrupt May current for shutdown

Foil:

Inner IE-6A location 121a

Outer OE-6G location 258b

Norm: 4C of IE10F location: 17th slot from 37aTarget foil 1E of IE 36 2732 from $\frac{1}{4}$ of island at mid planefoil 1G of IE 36 put in ~~slot~~ foil position 3

in plate IE-10F (norm plate)

Begin exposure 10 ³⁰ /AM	Expose for 30 min at	2	IC-3	10 ⁻⁸
		1.1	IC-4	10 ⁻⁷
End exposure 11 ⁰⁸ /AM		3.3	IC-2	10 ⁻¹⁰
		3	IC-1	10 ⁻¹⁰

26-10 reads ~1mm through window

Expr. 119 w/target
 Instrument Check on 6-24-64 Source 60 mc K

PM-1	Low Trip	Alarm Trip	OK
PM-2		Alarm Trip	OK
IC-1	$> 3 \times 10^{-4}$ Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$ Meter Trip	OK	
IC-3	Responds	Calibration	JH
IC-4	Responds	Calibration	JH
CRM	Meter Trip		

Preliminary Check on 6-24-64

Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check JH C.C.
 Scrams and Bldg, Alarm Reset JH
 Source Inserted JH
 Safety Withdrawn 26.00
 Controls Set Inner 13.63 Outer 0.0
 Reflector Water 6" above BC
 Moderator Water ~ 24"

note

Condition	Inner	Outer	Safety	Rhante
k>1	13.63	13.85	26.00	18.05f'
k=1	13.63	13.64	26.00	

Interrupt Magnet current for shut down

Expr. 120	Reinstalled Fission Counter	H ₂ O
k>1	13.63 13.70	26.00 ~26.00
k=1	13.63 13.48	26.00

IC-3 1×10^{-9} scale gives $\sim 2450 \text{ c/m}$

Fission Counter Characteristics

Exp 121 W/Target
 Instrument Check on 6-25-64 Source come 1

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 → 3x10" Meter Trip OK Fast Trip OK
 IC-2 → 3x10" Meter Trip OK
 IC-3 Responds Calibration JH
 IC-4 Responds Calibration JH
 CRM Meter Trip

Preliminary Check on 6-25-64

Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check JH c.c.
 Scrams and Bldg, Alarm Reset JH
 Source Inserted JH
 Safety Withdrawn 26.00
 Controls Set Inner 13.63 Outer 0.0
 Reflector Water 6" Above Be
 Moderator Water 25.97"

Conditions Inner Outer Safety

k > 1 13.63 13.85 26.00

k = 1 13.63 13.64 26.00

Expt 122 - Preliminary run to check critical conditions preparatory to receiving 1 curie source.

Have moved IC-3 from against outside tanks to top of moveable table assembly machine.

Fission counter traverse at critical (IC4 6.410^{-8})

Location	F.C. C/m.	W (6.4/6)	C ₄	C ₃
21.81	42116	39484	23983	23875
23.81	17279	16199	25753	25892
25.81	7060	6619	25977	18486
27.81	3123	2928	24935	22226
29.81	1476	1384	25442	24284
31.81	738	692	26121	24557
26.81	4834	4532	26191	23175
22.81	27053	25362	26315	26176
21.81	42500	39844	25877	26205

Expr 122 w/target
Instrument Check on 6-30-64 Source low

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	> 3x10 ⁻⁴	Meter Trip	OK	Fast Trip	OK
IC-2	> 3x10 ⁻⁴	Meter Trip	OK		
IC-3	Responds	Calibration	JH		
IC-4	Responds	Calibration	JH		
CRM		Meter Trip	1		

Preliminary Check on 6-30-64

Room 113 Pressure Differential	1.4"
Red Light On and Personnel Check	JH C.C.
Scrams and Bldg, Alarm Reset	JH
Source Inserted	JH
Safety Withdrawn	26.00"
Controls Set Inner	13.63 Outer: 0.0
Reflector Water	6" above Bc.
Moderator Water	

Condition	Inner	Outer	Safety
k=1	13.63	13.64	26.00

Expr. 123 w/target + 1 curie source

Condition	Inner	Outer	Safety	Fission Counter @ 21.81"	C ₄	B _F / sec
k<1	7.00	0.0	0.0	7	12	
"	13.63	0.0	26.00	13	23	0.6
"		10.00		19	39	2.6
"		12.00		32	76	13.0
"		13.00		81	190	102 (8.22)
"		13.50		362	897	1280
k=1		13.63		43032	23748	128 x 10 ⁵ (862260)

Foils

Inner IE-6G location 37a

Outer OE 8F " 78b

Norm. 4E of Plate IE3G location: slot 12 from 37a

Reflector Water

Foils of IE3G location

6B Contact

6C 2

6F 4

6G 6

} On radial line bisecting
Tangential beam tube

Begin Exposure at 11 ¹⁷ /AM	Expose 30 min.	at 1.0	IC 4	10 ⁻⁸
		5.0	IC 3	10 ⁻⁸
		6.8	IC 2	3x10 ⁻⁸
End Exposure 11 ⁴⁷ /AM		1.6	IC 1	10x10 ⁻⁸

Foil Exposure

Exp 124

w/target

Instrument Check on 7-1-64 Source 10mic

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Response	Calibration	JT		
IC-4	Response	Calibration	JT		
CSM		Meter Trip			

Preliminary Check on 7-1-64

Room 113 Pressure Differential	1.4"
Red Light On and Personnel Check	JT, CC
Scrams and Bldg, Alarm Reset	JT
Source Inserted	JT
Safety Withdrawn	26.00
Controls Set In:	In: 8.00, Out: 26.08 ⁵
Reflector Water	6" above BL
Moderator Water	27.6"

Condition	Inner	Outer	Safety	Rhette
k>1	8.32	26.08	26.00	42.54
k=1	8.13	26.08	26.00	

Interrupt Mag.

Exp 125

Instrument Check on 7-2-64 Source 10mc

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Response	Calibration	OK		
IC-4	Response	Calibration	OK		
CSM		Meter Trip			

Preliminary Check on 7-2-64

Room 113 Pressure Differential 1.4"
 Red Light Ca and Personnel Check OK
 Scrums and Bldg. Alarm Reset OK
 Source Inserted OK (accelerator)
 Safety Withdrawal 26:00
 Controls Set variable
 Reflector Water 6" above Be
 Moderator Water 26.49"

Condition	Inner	Outer	
K-1	0.0	0.0	check counter response

<u>Expt 127</u>	location	F.C. %/m	c_3	c_4	$\ln N$ $\frac{3}{(1 \times 10^{10})}$	IC-2 $\frac{4}{(5 \times 10^{10})}$
	21.81	420	420	1179		5.1
	24.81	118	410	1177		
	28.81	24	427	1218		
	32.81	5	434	1234		
	21.81	044	457	1256		

Instrument Check on 7-7-64 Source 10 mil
 Expt. 127 w/target.

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	> 3x10 ⁻¹¹	Meter Trip	OK	Fast Trip	OK
IC-2	> 3x10 ⁻¹¹	Meter Trip	OK		
IC-3	Responds	Calibration	JII		
IC-4	Responds	Calibration	JII		
CRM		Meter Trip			

Preliminary Check on 7-7-64

Room 113 Pressure Differential	1.4"
Red Light On and Personnel Check	JII C.C.
Scrams and Bldg, Alarm Resot	JII
Source Inserted	JII
Safety Withdrawn	26.00
Controls Sec In: 13.63	Out: 0.0
Reflector Water	6" above BC
Moderator Water	27.67"

Check critical conditions prior to bringing in 10 curie Sb-source.

Condition	Inner	Outer	Safety	
R > 1	13.63	13.85	26.00	
R = 1	13.63	13.62	26.00	
k < 1	9981.4	9999.2	26.00	3PN-93
Expt 128 k < 1	9981.4	9999.2	26.00	3PN-94

Expt. 12.9

Instrument Check on 7-8-64 Source 10mc

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Responds	Calibration	JH		
IC-4	Responds	Calibration	JH		
CRM		Meter Trip			

Preliminary Check on 7-8-64

Room 113 Pressure Differential	1.4"
Red Light On end, Personnel Check	JH C.C.
Scrams and Bldg, Alarm Reset	JH
Source Inserted	Acc.
Safety Withdrawn	26.02
Controls Set	Inner 9981.4 Outer 9998.2
Reflector Water	6" above Be.
Operator Water	26.80"

Condition	Inner	Outer	
k < 1	9981.4	9998.2	3PN-95

Installed Sb-source

location 1. 5" from control blades

counts in 5 min. 210, 220. ave 0.72 c/sec.

Traverse at critical normalized to 1.0×10^{-8} on IC-3

Position c/min.

21.81 368250

22.81

24.81 98530

28.81 19640

32.81 4640

25.81 65500

Location 2. 3" from control blades

Approach to critical

Inner	Outer	c/min.	M ⁻¹	Inner	Outer	c/min.	M ⁻¹
0	0	80	1.0	20	0	340	
4	4	90	.89	24.25	0	400	1.0
6	6	110	.73	2	450		.89
8	8	130	.62	4	700		.57
10	10	200	.40	6	2050		.195
12	12	430	.19	6.8	1790		.034
13	13	1240	.065				
13.6	13.6	22190	.0036				

Traverse at critical normalized to 1.0×10^{-8} on IC-3

Position	c/min.	Position	c/min.
21.81	38452	33.81	315
23.81	14293	30.81	983
25.81	6474	28.81	2005
27.81	2871	26.81	4458
29.81	1363	24.81	10238
31.81	665	22.81	24623

Exp 130
 Instrument Check on 7-9-64 Source low

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 $> 3 \times 10^{-4}$ Meter Trip OK Fast Trip OK
 IC-2 $> 2 \times 10^{-4}$ Meter Trip OK
 IC-3 Response Calibration JH
 IC-4 Response Calibration JH
 CRM Meter Trip

Preliminary Check on 7-9-64

Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check JH CC
 Scrams and Bldg. Alarm Reset JH
 Source Inserted St source
 Safety Withdrawn 20.00
 Controls Set Scram 0.0 auto 0.0
 Reflector Water 6" above Be
 Moderator Water 27.26

Condition	inner	outer	Rhette
k>1	13.63	13.75	9.41 ϕ
B=1	13.63	13.83 ⁵	

Fission Counter Traverse with St-source

k>1	13.63	13.80	14.959
R=1	13.63	13.83 ⁵	1

8/7/64 Drained Borated Mod. water - flushed system with tap water twice - once with dem. water.

Exp 169

Zero position of controls have changed
noted when both relays are zero

Inner	$41 \frac{45}{64}$	above Be surface	} cf p 72	$41 \frac{13}{16}$
Outer	$5 \frac{63}{64}$	above Be surface		$6 \frac{1}{6}$

Expt 169 W/T

Instrument Check on 8-10-64 Source closed

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Responds	Calibration	JIT		
IC-4	Responds	Calibration	JIT		
CRM		Meter Trip			

Preliminary Check on 8-10-64

Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check East OK
 Scrams and Bldg. Alarm Reset JIT
 Source Inserted JIT
 Safety Withdrawn 26:00
 Controls Set Inner 13.63 Outer 0
 Reflector Water 6" above Be
 Moderator Water ~26.00

Condition Inner Outer

$k > 1$	13.63	13.85
---------	-------	-------

$k > 1$	13.70	13.85
---------	-------	-------

$k = 1$	13.73	13.73
---------	-------	-------

$k < 1$	13.73	13.645
---------	-------	--------

Reset Controls - Expt 169(a)

$k = 1$	13.75	13.75
---------	-------	-------

8/12/64

Added 500 cc N Nitric acid to ~30 l. of moderator water. Pumped up moderator water into core and let stand ~5 min. Repeated twice. Drained acid solution from system. Flushed 4 times with tap water. Flushed twice with demin. water. Filled system with ~30 liters of clean demin. water. JH

Exp 170 W/T

Instrument Check on 8-11-64 Source 10 mcx

PM-1	Low Trip	ok	Alarm Trip	ok	
PM-2			Alarm Trip	ok	
IC-1	$> 3 \times 10^{-4}$	Motor Trip	ok	Fast Trip	ok
IC-2	$> 3 \times 10^{-4}$	Motor Trip	ok		
IC-3	Responds	Calibration	ST		
IC-4	Responds	Calibration	ST		
CRM		Motor Trip			

Preliminary Check on 8-11-64

Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check: ST
 Scrams and Bids, ~~Alarm Reset~~ ST
 Source Inserted ST
 Safety Withdrawn 21.00
 Controls Set Inner 13.73 Outer 0.0
 Reflector Water 6" above Ke
 Moderator Water 26"

Condition	Inner	Outer	Rhette
R>1	13.75	13.90	11.23
R=1	13.75	13.75	

Drained Mod. H₂O - Flushed system with Dem. H₂O and (-6.62t)
 refilled with clean H₂O

Exp 171 check out position of Rods

R=1	13.70	13.70
-----	-------	-------

Expt 172 W/T

Instrument Check on 8-12-64 Source 10 mci

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK		
IC-3	Responds	Calibration	JT		
IC-4	Responds	Calibration	JT		
CRM		Meter Trip			

Preliminary Check on 8-12-64

Room 113 Pressure Differential 1.4"

Red Light On and Personnel Check JT

Scrams and Bldg. Alarm Reset JT

Source Inserted JT

Safety Withdrawn 26.00

Controls Set Inner 13.63 Outer 0.0

Reflector Water 6" above Ec

Moderator Water 22.22

Condition	Inner	Outer	Rhette
$k > 1$	13.63 ⁺	13.80	6.09
$k = 1$	13.63 ⁺	13.72 ⁵	
$k = 1$	13.67	13.67	
$k < 1$	13.67	13.56	-10.244

Expt 173 WIT

Instrument Check on 8-13-64 Source 1.2m

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	7.3×10^{-4}	Meter Trip	OK	Fast Trip	OK
IC-2	7.3×10^{-4}	Meter Trip	OK		
IC-3	Response	Calibration	JH		
IC-4	"	Calibration	JH		
CRM		Meter Trip			

Preliminary Check on 8-13-64

Room 113 Pressure Differential	1.4
Red Light On and Personnel Check	JH
Scrams and Bldg, Alarm Reset	JH
Source Inserted	JH
Safety Withdrawn	2600
Controls Set	In: 24.70 Out: 0.0
Reflector Water	6.2 above BC
Moderator Water	-27.00

	Condition	Inner	Outer	div/sec	T	P	Chottle #/in
1.	R>I	24.71 <small>1.535</small>	7.16	1.55	33.7	21.14	19.62
2.	R<I	23.17 ⁵	7.16 <small>1.27</small>	6.6	-143.4	-13.05	12.22 .223
3.	R>I	23.17 ⁵ <small>1.225</small>	7.43	2.03	44.1	17.82	15.84 1.143
4.	R<I	22.25	7.43 <small>1.255</small>	2.025	-152.7	-11.86	11.09 .321
5.	R>I	22.25	7.66 ⁵	2.55	55.4	15.28	13.35 1.155
6.	R<I	17.87	9.59 <small>1.23</small>	7.05	-153.2	-11.80	11.75
7.	R>I	17.87 <small>1.33</small>	9.84	2.945	64.0	13.80	12.10 1.024
8.	R<I	17.54	9.84 <small>1.24</small>	7.05	-153.2	-11.80	11.60 .776
9.	R>I	17.54 <small>1.307</small>	10.08	3.20	62.5	13.01	11.43 1.034
10.	R<I	17.23 ³	10.08	7.025	-152.7	-11.86	11.50 .810

	Condition	Inner	Outer	in/sec	T	P	Rolette	
11	R > 1	15.50 ^{.26}	11.85 ⁵	2.725	59.2	14.58	12.60	
12	R < 1	15.24	11.85 ⁵	6.55	-142.3	-13.20	11.1	1.068
13	R > 1	15.24 ^{.250}	12.10 ⁵	3.10	67.4	13.30	11.40	1.060
14	R < 1	14.99 ⁵ ^{.24}	12.10 ⁵	6.55	-142.3	-13.20	11.25	1.082
15	R > 1	14.99 ⁵	12.34 ^{.230}	3.35	72.8	12.57	10.84	1.097
16	R < 1	13.67	13.67					
16	R < 1	13.56 ^{.11}	13.67	7.25	-157.5	-11.33	10.62	1.03
17	R > 1	13.56 ^{.23}	13.92	3.26	70.8	12.83	11.05	.966
18	R < 1	13.34 ^{.22}	13.92	6.65	-144.5	-12.91	11.17	1.170
19	R > 1	13.35 ^{.27}	14.19	3.1	67.4	13.30	12.86	.971
20	R < 1	13.11 ⁵ ^{.235}	14.19	6.95	-151.0	-12.06	11.00	1.079
21	R > 1	10.00 ^{.16}	18.60	3.75	81.5	11.56	11.17	
22	R < 1	9.84	18.60	7.35	-159.7	-11.09	10.03	1.415
23	R > 1	9.84	—————					

Sylen on outer control cylinder sticks at 18.60, however motion of cylinder still possible.

8-14-64

Removed control cylinders - Install Eu_2O_3 rods.

See drawings E 49903 - inner

E 49901 - Outer

Inner control:

location of grey-black interface is $46\frac{1}{8}$ " from top of control cylinder. (Re: D. Cheerton X-rays of rods)Outer: location of grey-black interface is $31\frac{1}{8}$ " from top of control cylinder (X-rays)

grey section 5" long.

Black " 22" long.

Locate top of inner cylinder $44\frac{1}{8}$ " above Re." " " Outer cylinder $9\frac{1}{8}$ " " "

Limits	up	Down
Inner	999.98	2686 ⁵
Outer	2558 ⁵ / ₂	999.91

Eu₂O₃

Experiment 174

w/t and Eu₂O₃ Rods

Instrument Check on 8-17-64 Source 10mc

EM-1	Low Trip	OK	Alarm Trip	OK	
EM-2			Alarm Trip	OK	
IC-1	> 3x10 ⁻¹¹	Meter Trip	OK	Fast Trip	OK
IC-2	> 3x10 ⁻¹¹	Meter Trip	OK		
IC-3	Reprints	Calibration	JH		
IC-4	Reprints	Calibration	JH		
CRM		Meter Trip			

Preliminary Check on 8-17-64

Room 113 Pressure Differential	1.4"
Red Light On and Personnel Check	JH
Scrams and Bldg, Alarm Reset	JH
Source Inserted	JH
Safety Withdrawn	26.00
Controls Set In.	0.0
Controls Set Out.	0.0
Reflector Water	6" above Be.
Moderator Water	~ 27"

Condition	Inner	Outer	Safety	Rhoette	In N	T	P
R > 1	15.30	15.29 ⁵	26.00	12.26 ⁴	3.075 div/dec	66.8	13.38 ⁴
R = 1	15.30	15.18	26.00		1.16		
R = 1	15.19 ⁵	15.29 ⁶	26.00		1.27		
R = 1	15.23 ⁵	15.23 ⁵	26.00		2.14		
R < 1	15.23 ⁵	15.15 ⁵	26.00	-10.34 ⁴	1.35 1/2 7.5 div/dec	163	10.78 ⁴

Eu₂O₃

Expt 175

Phase

w/T

Instrument Check on 8-21-64 Source 10mcX

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 > 3 x 10⁻⁷ Meter Trip OK Fast Trip OK
 IC-2 > 3 x 10⁻⁶ Meter Trip OK
 IC-3 Respon Calibration JH
 IC-4 Respon Calibration JH
 CRM Meter Trip

Preliminary Check on 8-21-64

Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check JH
 Screams and Bldg. Alarm Reset JH
 Source Inserted Acc
 Safety Withdrawn 26.00
 Controls Set Var.
 Reflector Water 6" above Be
 Moderator Water ~ 26"

Expt.	Condition	Inner	Outer	Safety	SRN# (p104)
175	R<1	0.0	0.0	26.00	114
176	R<1	0.0	0.0	26.00	115
177	R<1	15.23	0.0	26.00	116
178	R<1	26.87	0.0	26.00	117
179	R<1	15.23	2.0	26.00	118
180	R<1	15.23	4.0	26.00	119
181	R<1	15.23	6.0	26.00	120
182	R<1	15.23	8.0	26.00	121
183	R<1	0	15.23	26.00	122

Expt. 184 W/o Tor Void

Instrument Check on 8-24-64 Source 10 meV

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	OK
IC-1	Meter Trip	OK	Fast Trip	OK
IC-2	Meter Trip	OK		
IC-3	Calibration	OK		
IC-4	Calibration	JH		
CRM	Meter Trip			

Preliminary Check on 8-24-64

Room 113 Pressure Differential	1.4"
Red Light On and Personnel Check	JH
Serams and Bldg. Alarm Reset	JH
Source Inserted	JH
Safety Withdrawn	26.00
Controls Set	Inner 75.65 out 10.04
Reflector Water	~ 6" above Be
Moderator Water	~ 27"

Condition	Turner	Qute	Rhette	On N	T (sec)
k > 1	15.65	15.67	+ 17.44	1.9 ^{dir} / _{sec}	41.3
k = 1	15.65	15.55 ⁻¹²			
k = 1	15.54 ⁵	15.67 ¹⁰⁵			
k = 1	15.62	15.62	+ 2.12		15.23 15.88
k < 1	15.62	?	- 12.124	6.975 ^{dir} / _{sec}	15.6

Expt. 185 W/ Styrofoam Void - 4 3/16 dia.

k > 1	14.00	14.10	+ 16.30	2.117	46
k = 1	17.00	13.42 ⁸			
k = 1	13.98	13.98			

Exp. 186 w/T+void.

Condition	Inner	Outer	Rhoette	div/sec	Temp
k>1	14.38	14.68	+15.524	2.1	45.6
k=1	14.38	14.53 ^{.15}			
k=1	14.44	14.44			

Exp. 187 w/T Rhoette

k>1	15.23	15.40 ^{.125}	15.614
k=1	15.23	15.27 ⁵	
k=1	15.23 ⁶	15.23 ⁶	
k=1	16.00	14.46	
k=1	18.00	12.62 ⁵	
k=1	20.00	11.20 ⁵	
k=1	22.00	10.21	
k=1	24.00	9.58	
k=1	26.00	9.27	
k=1	14.00	16.70 ⁵	
k=1	12.00	19.70	
k=1	10.13	25.61	

Experiment 188 Sensitivity.

	Rhoette			div/sec.	T(°C)	p4	Hum	
1	k>1	19.08	10.30	25.61	1.625	35.3	20.54	
2	k<1	14.53	10.30	24.17 ^{.14}	6.725	146.1	12.69 ^{31.23}	2.31
3	k>1	12.84	10.44 ^{.14}	24.17	2.70	58.7	14.68 ²⁷	19.55
4	k<1	9.91	14.00	16.64	8.0	173.8	9.87 ^{27.46}	15.71
5	k>1	15.09	14.16 ^{.16}	16.64	2.475	53.8	15.59 ^{27.46}	15.91
6	k<1	11.50	14.16	16.93 ^{.21}	7.15	155.4	11.54 ^{27.13}	12.92
7	k<1	12.55	18.00 ^{.195}	12.52 ⁵	6.75	146.7	12.63	
8	k>1	10.04	18.20 ^{.16}	12.52 ⁵	3.95	85.8	11.12	12.14
9	k<1	13.22	18.20	12.36 ⁵	6.25	135.8	14.27	15.97
10	k>1	13.50		12.36 ⁵	2.74	57.5	14.53	

Expn 188

	Condition	Inner	Outer	dist/dec	T (sec)	P(4)	
11	$k < 1$	10.15	20.00 29	$R=1$ 11.20 .97 11.225	8.575	186.3	8.97 1.20
12	$k > 1$	13.28	20.27	11.125 .65	2.775	60.3	23.36 14.39 .72 1.865
13	$k < 1$	11.28	20.27	10.96	7.25	157.5	11.33 1.56
14	$k < 1$	10.27	24.00 .67	9.495	7.45	141.9	10.88
15	$k > 1$	11.18	24.67	9.495 .15	3.45	75.0	12.30 1.35
16	$k < 1$	12.28	24.67	9.345	7.10	154.3	11.70 1.60

Exp. 189 W/H

Instrument Check on 8-25-64 Source COMET

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 $\approx 3 \times 10^{-4}$ Meter Trip OK Fast Trip OK
 IC-2 $\approx 3 \times 10^{-4}$ Meter Trip OK
 IC-3 Responds Calibration JH
 IC-4 Responds Calibration JH
 CRM Meter Trip

Preliminary Check on 8-25-64

Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check JH CS
 Scrams and SILE, Alarm ~~Reset~~ JH
 Source Inserted Acc
 Safety Withdrawn 26:00
 Controls Set Inner 15.23 Outer 8:00
 Reflector Water 6" above bc
 Moderator Water 26.5"

Condition	Inner	Outer	Safety	React
R>1	15.23 ²	15.40	26.00	16:38†
k=1	15.23 ²	15.23 ²	26.00	
R=1	15.26 ⁵	15.26 ⁵	20.77	3PN-123

Exp 190

k=1	0	25.58	26.00	3PN-124
-----	---	-------	-------	---------

TMC

256 - 2 - 80 - 2¹⁰ 1973

256 2 80 2¹⁰ 590

Expt. 191 W/T

Instrument Check on 8-31-64 Source 10mc

FM-1	Low Trip	OK	Alarm Trip	OK	
FM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK		
IC-3	Responds	Calibration	JH		
IC-4	Responds	Calibration	JH		
CRM		Meter Trip			

Preliminary Check on 8-31-64

Room 113 Pressure Differential	1.4 ⁴
Red Light On and Personnel Check	JH
Scrams and Bldg, Alarm Reset	JH
Source Inserted	Acc
Safety Withdrawn	26.00
Controls Set	Inner 26.87 Outer 005
Reflector Water	> 6" above BL
Moderator Water	~ 26.00

Condition	Inner	Outer	Safety	
R<1	26.87	0.05	26.00	3PN-125

Expt. 192 St. Source 3" from Control Blades.

R<1 (13)	9999.8	0.05	26.00
----------	--------	------	-------

10 min. Count F.C. 210 $\frac{354}{1000}$ C-3 ? C-4 1990

R<1 (6)	24.76	0.05	26.00
---------	-------	------	-------

10 min. C. 720 $\frac{1.2}{100}$ 2320 3950

Bkg	Delay	ch.	ct.	cycles
256	2	80	2 ¹⁰	1361
				560, 523, 575
				151, 154
256	2	80	2 ¹³	218, 219
			2 ¹⁵	165, 166

9700 cycles

2 min. Counts

Inner	Outer	F.C.	C-3	C-4
8.00	8.00	45	330	390
12.00	12.00	120	450	810
14.00	14.00	450	770	2080
15.00	15.00	2670	2890	11670
15.20	15.20	11090	11610	40700

58/39

Expt 193 WLT

Instrument Check on 9-1-64 Source 10 mcd

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Responds	Calibration	JH		
IC-4	Responds	Calibration	JH		
CRM		Meter Trip			

Preliminary Check on 9-1-64

Room 113 Pressure Differential 1.4"

Red Light On and Personnel Check JH C.C.

Scrams and Bldg, Alarm Reset JH

Source Inserted Acc

Safety Withdrawn 26.00

Controls Set Inner 15.23 Outer 0.05

Reflector Water 6" above Be.

Moderator Water 26.00

Condition	Inner	Outer	Safety	
K<1	15.23	0.05	26.00	3PN-126

Expt 194

Removed Target; only H₂O in island. Rhoette

Condition	Inner	Outer	Safety	20.43	~ 1.31 #/m
R=1	16.00	15.35	26.00		
R=1	16.00	15.19	26.00		
R=1	15.61	15.61	26.00		3PN-127

Expt. 195 w/o

Instrument Check on 9-2-64 Source 10 mcd

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Responds	Calibration	JII		
IC-4	Responds	Calibration	JII		
CRM		Meter Trip			

Preliminary Check on 9-2-64

Room 113 Pressure Differential 1.4"

Red Light On and Personnel Check JII c.c.

Scrams and Bldg. Alarm Resct JII

Source Inserted JII

Safety Withdrawn 26.00

Controls Set Inner 15.61 Outer 0.0

Reflector Water 6" above Be

Moderator Water 26.00

Condition	Inner	Outer	Safety	Rhettie	
$k > 1$	15.61	15.70 ⁵	26.00	14.63 ⁴	4.6 ^{div} / sec T=100 sec $\rho = 2.884$
$k = 1$	15.61	15.59 ⁵	26.00		~ 90 ⁴ / min
$k = 1$	15.63	15.63	20.77		
Pulse at critical 3PN-128					
$k \leq 1$	15.63	15.63	20.77		Reg. Period 54 ^{div} / sec
			$k = .8927$		T = -1173 sec $\rho = -1.154$

Expt 196

$k < 1$	24.75	0	26.00	3PN-129
---------	-------	---	-------	---------

Expn 197 W/O

Instrument Check on 9-3-63 Source 10mc

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	5.3×10^{-4}	Meter Trip	OK	Fast Trip	OK
IC-2	2.3×10^{-4}	Meter Trip	OK		
IC-3	Response	Calibration	OK		
IC-4	Response	Calibration	OK		
CRM		Meter Trip			

Preliminary Check on 9-3-64

Room 113 Pressure Differential	<u>1.4"</u>
Red Light On and Personnel Check	<u>OK</u>
Scrams and Bldg. Alarm Reset	<u>OK</u>
Source Inserted	<u>Acc</u>
Safety Withdrawn	<u>26.00</u>
Controls Set	<u>Inner 0 Outer 24.75</u>
Reflector Water	<u>6" above Be</u>
Moderator Water	<u>26</u>

Condition	Inner	Outer	Safety	
R-1	0	24.75	26.00	3PN-130

Expn 198

R-1	0	0	26.00	3PN-131
-----	---	---	-------	---------

Expt. 199 W/T+V

Target in Al. con.

Instrument Check on 9-4-64 Source Lowest

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Responds	Calibration	JN		
IC-4	Responds	Calibration	JN		
CRM		Meter Trip			

W/T+V

Preliminary Check on 9-7-64

Room 113-Pressure-Differential 1.4"
 Red Light On and Personnel Check JN c.c.
 Scrums and Bldg, Alarm Reset JN
 Source Inserted JN
 Safety Withdrawn 26.00
 Controls Set Inner 14.4" Outer 0
 Reflector Water 6" above Be
 Moderator Water

Condition	Inner	Outer	Safety	Reflector	dir/Sec	T	P
k > 1	14.40	14.65	26.00	19.694	1.55	33.7	21.144
k = 1	14.40	14.45	26.00				
k = 1	14.71	14.41 ⁺	26.00				
k = 1	14.50	14.50	20.77		3PN-132		
Neg Period		87 dir/Sec	T = -1890.5	=> P = -.7034			
		k = .99551					

Exp. no. 200 W/T+V

Instrument Check on 9-8-64 Source Control

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Responds	Calibration	JA		
IC-4	Responds	Calibration	JA		
CRM		Meter Trip			

Preliminary Check on 9-8-64

Room 113 Pressure Differential 1.4"

Red Light On and Personnel Check JH c.c.

Scrams and Bldg. Alarm Reset JA

Source Inserted A.c.c.

Safety Withdrawn 26.00

Controls Set Inner 14.41, Outer 0.06

Reflector Water 6" above Pc

Moderator Water -26"

Condition Inner auto Safety

kci 14.41 26.00 3PM-133

Folios

Inner IE-3E location Slot 97a

Outer OE-4F " " 207b

Norm foil 4 of IE154 " " 17 from 37a

Begin exposure at 9²³/_{AM}; expose 30 min. Power level on IC1 10×10^{-6} 2

End " at 9⁵³/_{AM}: IC2 3×10^{-8} 5.4

IC3 10^{-8}

IC4 6×10^{-8}

Alarm readings

A: 150

B: 120

C: 260

Foil Exposure Expt 201 W/T

Instrument Check on ~~9-15-64~~¹⁰⁻¹⁻⁶⁴ Source 10 mcd

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 $> 3 \times 10^{-11}$ Meter Trip OK Fast Trip OK
 IC-2 $> 3 \times 10^{-11}$ Meter Trip OK
 IC-3 Responds Calibration
 IC-4 Responds Calibration
 CRM Meter Trip

Preliminary Check on ~~9-15-64~~¹⁰⁻¹⁻⁶⁴

Room 113 Pressure Differential 1.4
 Red Light On and Personnel Check JH C.C.
 Scrums and Bldg. Alarm Reset JH
 Source Inserted JH
 Safety Withdrawn JH
 Controls Set In. 15.23 Out 0
 Reflector Water 6" above BC
 Moderator Water ~ 26

Condition	Turn	Out
k>1	15.22 ⁵	15.40
k=1	15.22 ⁵	15.20 ² 9:55 AM
k=1	15.22 ⁵	15.23 ⁵ 9:58 AM

Expt. 202 w/T+U

Instrument Check on 10-12-64 Source 10mc

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Responds	Calibration	JH		
IC-4	Responds	Calibration	JH		
CRM		Meter Trip			

Preliminary Check on 10-12-64

Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check JH c.c.
 Scrams and Bldg, Alarm Reset JH
 Source Inserted Acc
 Safety Withdrawn 26.00
 Controls Set Inner 24.75 Outer 0.0
 Reflector Water 6" above Be
 Moderator Water ~26"

Condition	Inner	Outer	Safety	3PU ²
k<1	24.75	0.0	26.00	134
Expt. 203 k<1	0	24.75	26.00	135

Expt. 204 w/T+V

Instrument Check on 10-15-64 Source - 10mc

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK		
IC-3	Responds	Calibration			
IC-4	Responds	Calibration			
CRM		Meter Trip			

Preliminary Check on 10-15-64

Room 113 Pressure Differential	1.8"
Red Light On and Personnel Check	JTC cc.
Scrams and Bldg, Alarm Reset	JU
Source Inserted	Acc
Safety Withdrawn	26.00
Controls Set	Inner 15.23, Outer 0
Reflector Water	6" above R
Moderator Water	10.27"

Condition	Inner	Outer	Safety	3PN*
R<1	15.23	.05	26.02	136

Expt 205 w/T+V

R>1	24.75	8.05	26.00
R=1	24.75	7.89	"
"	22.00	8.70	"
"	20.00	9.64	"
"	18.00	10.98	"
"	16.00	12.725	"
"	14.00	14.86	"
"	12.00	17.57	"
"	10.00	21.495	"
"	8.00		"
	9.785	22.00	

W/T+V

Condition	Inner	Outer	Safety	3PN#
R=1	9.11	24.75	26.00	

Exp. 206 W/T+V

R<1	0.0	0.0	26.00	137
-----	-----	-----	-------	-----

Exp. 207 W/T+V

Instrument Check on 10-19-64 Source 10 mic

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Responds	Calibration	—		
IC-4	Responds	Calibration	—		
ERM		Meter Trip			

Preliminary Check on 10-19-64

Room 113 Pressure Differential	1.4"
Red Light On and Personnel Check	JTT C.C.
Scrams and Bldg, Alarm Reset	JH
Source Inserted	AEC
Safety Withdrawn	26.00
Controls Set	Inner 0.0 Outer 0.0
Reflector Water	6" above Be
Moderator Water	> 26"

Condition	Inner	Outer	Safety	3PN#
R<1	0.0	0.05	26.00	137

Exp. 208

Replace T+V with Styrofoam void 4 $\frac{3}{16}$ " Dia

Condition	Inner	Outer	Safety
R>1	14.00	14.10	26.00
R=1	13.97 ⁵	13.92 ⁵	26.00
R=1	14.00	13.95	"
R=1	16.00	11.80	"
R=1	18.00	10.06 ⁵	"
R=1	20.00	8.76 ⁵	"
R=1	22.00	7.85	"
R=1	24.75	2.08	"
R=1	12.00	16.47	"
R=1	10.00	19.90	"
R=1	9.96	20.00	"
R=1	9.17 ⁵	22.00	"
R=1	8.48	24.75	"

Exp. 209

ZPN#

R=1	15.23	0.0	"	138
-----	-------	-----	---	-----

Expn. 210 W/Styrofoam void

Instrument Check on 10-20-64 Source 10 mcd

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Responds	Calibration	JH		
IC-4	Responds	Calibration	JH		
CRM		Meter Trip			

Preliminary Check on 10-20-64

Room 113 Pressure Differential 1.4"

Red Light On and Personnel Check JH C.C.

Scrams and Bldg. Alarm Reset JH

Source Inserted Acc

Safety Withdrawn 26.00

Controls Set Inner 15.61 Outer 0.05

Reflector Water 6" above Be

Moderator Water > 26"

Condition	Inner	Outer	Safety	3PN#
R<1	15.61	0.05	26.00	139

Expn 211

R<1	24.75	0.05	26.00	140
-----	-------	------	-------	-----

Expn 212

R<1	0	24.75	26.00	141
-----	---	-------	-------	-----

Expn 213

R<1	0	0	26.00	142
-----	---	---	-------	-----

Expt. 215 -

Have disconnected outer control cylinder and rotated it $\sim 45^\circ$
 \rightarrow slots are aligned.

Expr 214 w/v

Instrument Check on 10-21-64 Source control

PM-1	Low Trip	Alarm Trip	OK
PM-2		Alarm Trip	OK
IC-1	> 3x10 ⁻¹¹	Meter Trip	OK
IC-2	> 3x10 ⁻¹¹	Meter Trip	OK
IC-3	Responds	Calibration	JN
IC-4	Responds	Calibration	JN
CRM		Meter Trip	

Preliminary Check on 10-21-64

Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check JN C.C.
 Scrums and Bldg. Alarm Reset JN
 Source Inserted JN
 Safety Withdrawn 26.00
 Controls Set Inner 13.975 Outer 10.00
 Reflector Water 1" above Be
 Moderator Water > 26"

Condition	Inner	Outer	Safety	3PN#	Rhette
k > 1	13.975	14.14	26.00		15.429
k = 1	13.975	13.97	26.00		
R = 1	14.025	14.025	21.76	143	R = 1 at end.

Expr 215 Rotated outer cylinder

k = 1 0.0 0.0 26.00 144

216

217 w/w

218 w/w

Outer cylinder in rotated position and clamped to
drive mechanism.

Expt. 219 W/V

Instrument Check on 10-22-64 Source 10mcK
 Source

PH-1 Low Trip OK Alarm Trip OK
 PH-2 Alarm Trip OK
 IC-1 > 3x10⁻⁴ Meter Trip OK Fast Trip OK
 IC-2 > 3x10⁻⁴ Meter Trip OK
 IC-3 Responds Calibration JH
 IC-4 Responds Calibration JH
 Meter Trip

Check on 10-22-64

Room 113 Pressure Differential 1.7"
 Red Light On and Pressure Check JH CC
 Scrams and Block Alarm Test JH
 Source Inserted JH
 Safety Withdrawn 26.00
 Controls Set On: 10.00 Out: 13.975
 Reflector Water 6" above level
 Moderator Water > 26"

Condition	Inner	Outer	Safety
R > 0	14.12	13.975	26.00
R = 1	13.81	13.975	26.00
R = 1	14.09	13.975	20.78 ^{3PN-148}
R = 1	14.04	14.025	20.78 _{R=1 at end}

Expt. 220 W/T+V

R < 1 15.23 0.0 26.00 3PN-149

Expt. 221 W/T+V

R < 1 0 0.0 26.00 3PN-150

Expt. 222 W/T

R < 1 15.23 0.0 26.00 3PN-151

Expt. 223 W/T

R < 1 0 0 26.00 3PN-152

10/26 Outer rod removed and sent to shop to have one quadrant
of Eu_2O_3 removed and replaced by aluminum.

11/2 Outer rod installed - slots aligned.

Rod and sqtsyns set as on p. 150.

Expt. 224

W/T + 3/4 Outer control

Pulse W/T both rods in.

3PN-153

Expt. 225

W/T

Inner Outer safety

15.23

0

26.00

3PN-154

Expt. 226

W/T

15.23

0

26.00

3PN-155

Expr. 227 W/T and 3/4 Rod.

Instrument Check on 11-4-64 Source 10 mcd

PM-1 Low Trip 6K Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 $> 3 \times 10^{-4}$ Meter Trip 6K Fast Trip OK
 IC-2 $> 3 \times 10^{-4}$ Meter Trip OK
 IC-3 Responds Calibration JH
 IC-4 Responds Calibration JH
 CRM Meter Trip

Preliminary Check on 11-4-64

Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check JH
 Rooms and Bldg. Alarm Reset JH
 Source Inserted JH
 Safety Withdrawn 26.00
 Controls Set Inner 0.0 Outer 0.0
 Reflector Water 6" above 6e
 Moderator Water 26.85

Condition	Inner	Outer	Safety
R=1	22.60	0.0	25.00
R=1	21.84	0.0	26.00
R=1	21.43	2.0	"
R=1	20.54	4.0	"
R=1	19.37	6.0	"
R=1	18.08 ⁵	8.0	"
R=1	16.78	10.0	"
R=1	15.52	12.0	"
R=1	14.31	14.0	"
R=1	13.22	16.0	"
R=1	12.22 ⁵	18.0	"

Condition	Inner	Outer	Safety	
$k=1$	11.354	20.00	25.00	
$k=1$	10.70	22.00	25.00	
$k=1$	10.27	24.00	25.00	
$k=1$	10.18	24.75	"	
$k=1$	15.23	12.45 ⁵	"	
$k=1$	15.23	12.58	20.78	3PN-156
$k>1$	15.23	12.58	20.78	end of 3PN156

$$T = 1152 \text{ sec} \Rightarrow 1.0994 \Rightarrow \text{or } .00007$$

$$\therefore k = 1.00007$$

Expr. 228 W/V, 3/4 Rod
 Instrument Check on 11-5-64 Source 10 mcd

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 $> 3 \times 10^{-4}$ Meter Trip OK Fast Trip OK
 IC-2 $> 3 \times 10^{-4}$ Meter Trip OK
 IC-3 Responds Calibration JH
 IC-4 Responds Calibration JH
 CRM Meter Trip

Preliminary Check on 11-5-64

Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check JH C.C.
 Scrams and Bldg. Alarm Reset JH
 Source Inserted Acc
 Safety Withdrawn 26.00
 Controls Set Inner 0.0 Outer 0.0
 Reflector Water 6" above RL
 Moderator Water 26.87"

Condition	Inner	Outer	Safety	
K<1	0.0	0.0	26.00	3PN-157
	Expr 229 W/T+V 3/4 Rod.			
K<1	15.23	0.0	26.00	3PN-158
	Expr 230 W/T+V 3/4 Rod			
K<1	0.0	0.0	26.00	3PN-159

11/5/64 Expt. 231 W/T+V 314 Rod.

Condition	Inner	Outer	Safety
$k > 1$	17.60	0	26.00
$k = 1$	17.35 ⁵	0	26.00
$k = 1$	17.35 ⁵	2.00	26.00

Note: Reactor has $k < 1$ as ^{outer} rod is pulled to 1.82" !

$k = 1$	17.10	4.00	26.00
---------	-------	------	-------

Note: Reactor initially $k < 1$ as rod is moved from 2 to 4.

$k = 1$	16.55 ⁵	6.00	26.00
$k = 1$	15.80	8.00	26.00
$k = 1$	14.92	10.00	26.00
$k = 1$	13.89	12.00	26.00
$k = 1$	12.83	14.00	26.00
$k = 1$	11.81	16.00	26.00
$k = 1$	10.92 ⁵	18.00	26.00
$k = 1$	10.17 ⁵	20.00	26.00
$k = 1$	9.58	22.00	26.00
$k = 1$	9.15 ⁵	24.00	26.00
$k = 1$	9.06 ⁴	24.75	26.00
$k = 1$	15.23	9.37 ⁶	26.00
$k = 1$	15.23	9.67	20.86 3PN-160

11/6/64 Note: Exps. 232 and 233

Have determined replaced quadrant by using γ source and
anticipie detector. Cemented a sheet of cadmium 0.023"
on Al-section \rightarrow it represents 4th quadrant at 13.00"
withdrawn when remaining 3 quadrants are at zero
position.

Expn 232. W/T+V 3/4 Rod + cd.
 Instrument Check on 11-6-64 Source 10mcK

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK		
IC-3	Responds	Calibration	JN		
IC-4	Responds	Calibration	JN		
CRM		Meter Trip			

Preliminary Check on 11-6-64

Room 113 Pressure Differential 1.4
 Red Light On and Personnel Check JN c.c.
 Scrams and Bldg. Alarm Reset JK
 Source Inserted Acc
 Safety Withdraw 26.00
 Controls Set Inner 0 Outer 0
 Reflector Water 6" above R₀
 Moderator Water 26"

Condition	Inner	Outer	Safety	
K=1	0.0	0.0	26.00	3PN-161

Expn 233

K=1	0.0	0.0	26.00	3PN-162
-----	-----	-----	-------	---------

Expn 234 W/Vs 3/4 Rod no cd.

K>1	15.23	6.57	26.00	
K=1	15.23	6.12	26.00	
K=1	15.23	6.92 ⁵	20.86	3PN-163

Expr 238 W/T+V 3/4 Rod

Instrument Check on 11-13-64 Source 10 mCi

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 > 3 x 10⁻⁴ Meter Trip OK Fast Trip OK
 IC-2 > 3 x 10⁻⁴ Meter Trip OK
 IC-3 Responds Calibration —
 IC-4 Responds Calibration —
 CRM Meter Trip —

Preliminary Check on 11-13-64

Room 113 Pressure 6.4"
 Red Light OK
 Scrams and Bldg OK
 Source Insertion Acc
 Safety Withdrawal 26.00
 Controls Set Variable
 Reflector Water 6" above bc
 Moderator Water > 26"

Expr #	Condition	Inner	Outer	Safety	SPN #
238	K<1	0	0	26.00	167
239	K<1	15.23	0	26.00	168
240	K<1	15.23	0	26.00	169

set Cd on 4th Quad. to represent withdrawn condition of 10.23"

241	K<1	15.23	0	26.00	170
-----	-----	-------	---	-------	-----

set Cd on 4th Quad. to represent withdrawn condition of 15.23"

Expt 235 w/T+V 3/4 Rod + Cd.

Instrument Check on 11-12-64 Source 10me f

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-4}$	Water Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$		OK		
IC-3	Responds		JT		
IC-4	Responds		JT		
CRM	Meter Trip				

Preliminary Check on 11-12-64

Room 113 Pressure Differential	1.4"
Red Light On and Personnel Check	JT CC
Scrams and Bldg. Alarm Reset	JT
Source Inserted	Acc
Safety Withdraw	26.00
Controls Set	Inner 15.23 Outer 0.0 + Cd.
Reflector Water	$> 6"$ Bc
Moderator Water	$> 26"$

Expt#	Condition	Inner	Outer	Safety	
235	R<1	15.23	0.0	26.00	3PN-164
236	"	"	"	"	3PN-165
237	"	"	"	"	3PN-166

11-14-64 3/4 Blade removed and sent to shop to have
4th quadrant replaced.

11-20-64 Outer control returned and installed
Salyers reset as on p. 150.
slots are alligned.

Expt. 242 foil Exposure

Inner IE 76 location 72a

Outer DE 86 " 155b

Normalizer: foil 4F of IE 156, 17th slot from 32a

Begin 30 min exposure at 9^{am}. Exposure (ICI) 1.6 on 10×10^{-8} scale

(IC2) 4.2 3×10^{-8}

IC3 10 10^{-8}

End exposure at 9⁴⁰ AM.

IC4 .6 10^{-8}

Expt 242 w/T foil Exposure
Instrument Check on 11-23-64 Source 10 mcf

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-4}$	Water Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Water Trip	OK		
IC-3	Responds		JH		
IC-4	Responds		JH		
CRM	Water Trip				

Preliminary Check on 11-23-64

Room 113 Pressure Differential	1.4"
Red Light On and Personnel Check	JH C.C.
Scrams and Bldg. Alarm Reset	JH
Source Inserted	JH
Safety Withdrawn	JH 26.00
Controls Set	Inner 15.23 Outer 00
Reflector Water	$> 6"$ above level
Moderator Water	28.92

Condition	Inner	Outer	Safety	
$k > 1$	15.23	15.40	26.00	
$k = 1$	15.23	15.28 ⁵	26.00	
$k = 1$	15.23	15.23	26.00	Reset safety on Outer

Interrupt Mag. for shut down.

Expt	$k < 1$	0	0	26.00	w/T	
243	$k < 1$	0	0	26.00	w/T	3PN-171
244	$k < 1$	0	0	26.00	w/T	172
245	$k < 1$	0	0	26.00	w/w	173
246	$k < 1$	0	0	26.00	w/v	174

Expr 247 W/T+V

Instrument Check on 11-24-64 Source come

PM-1 Trip OK Alarm Trip OK
 PM-2 Alarm Trip
 IC-1 $> 3 \times 10^{-11}$ OK Fast Trip OK
 IC-2 $> 3 \times 10^{-11}$ OK
 IC-3 Responds JT
 IC-4 Responds JT
 CRM Motor Trip

Preliminary Check on 11-24-64

Room 113 Pressure Differential 1.4"
 Red Light On and Response Check JT cc.
 Scrams and Bldg. Alarm Test JT
 Source Inserted Acc
 Safety Withdrawn 26.00
 Controls Set Variable
 Reflector Water 6" above Be
 Moderator Water -26.00

Expr.	Condition	Inner	Outer	Safety	Island	3PN*
247	K<1	0	0	26.00	T+V	175
248	K<1	15.23	14.00	26.00	T	176
249	K<1	15.23	13.0	"	T	177
250	K<1	15.23	11.0	"	"	178
251	K<1	15.23	9.0	"	"	179
252	K<1	"	7.0	"	"	180
253	K<1	"	5.0	"	"	181
254	K<1	"	3.0	"	"	182
255	K<1	"	1.0	"	"	183

11/24/64 Drained moderator H_2O .
added H_2O containing $1.48 \text{ g}^B/l$. see notebook II

1/18/65 System has been drained of Borated H_2O - rinsed
with dilute nitric acid and flushed with demin.
 H_2O .

Exp. 295

w/w

Instrument Check on 1-18-65 Source 10 mcd

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip out
 IC-1 $> 3 \times 10^{-11}$ Meter Trip OK Fast Trip OK
 IC-2 $> 3 \times 10^{-11}$ Meter Trip OK
 IC-3 Responds Calibration JH
 IC-4 Responds Calibration JH
 CRM Meter Trip

Preliminary Check on 1-18-65

Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check JH - C.C.
 Scrums and Bldg. Alarm Reset OK
 Source Inserted JH
 Safety Withdrawn 26.00
 Controls Set In: 0.0 Out: 0.0
 Reflector Water None
 Moderator Water

Condition	Inner	Outer	Safety	No Reflector or Isolated H ₂ O
R << 1	26.87	0.0	26.00	
R << 1	25.00	0.0	26.00	
R > 1	25.00	9.25	26.00	4.567 div/sec \rightarrow 9.954
R = 1	24.62 ⁵	9.25	26.00	\approx 26.7 $\frac{1}{in}$
R = 1	25.00	9.18	26.00	192 $\frac{1}{in}$
R = 1	14.78	14.78	26.00	
R = 1	14.92	14.92	20.00	
R = 1	15.58 ⁵	15.58 ⁵	10.00	
R = 1	16.23	16.23	(1915.3)	

At Completion of Expt. 286 checked
0 position on outer rod
and 20" " " inner rod

Outer	97/8"	above Be	999.91	reset	0.00
Inner	24 1/8"	"	20.06	to	20.00

Experiment 296 w/w

Add Reflector - Distand water to expt. 295.

Reflector ~ 6" above Be.

Condition	Inner	Outer	Safety	
R=1	16.19	15.60	26.00	1.30 air/sec → 23.5 f ^{1.34/l}
R=1	16.01 ⁵	15.60	26.00	
R=1	15.84	15.84	26.00	
R=1	15.88	15.88	20.00	
R=1	17.39	17.39	10.00	
R=1	19.45	19.45	(9975.3)	

Expt 297

Repeat part of 286 with relay reset.

Condition	Inner	Outer	Safety
R=1	15.81	15.81	26.00

Drained moderator water - added 0.98 g/l moderator
see notebook 2.

1-19-65

Drained B-moderator, flushed, washed with HNO_3 solution, flushed and filled with demin. H_2O .

Exp. 300 W/W

Instrument Check on 1-20-65 Source 10mc

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 $> 3 \times 10^{-11}$ Meter Trip OK Fast Trip OK
 IC-2 $> 3 \times 10^{-11}$ Meter Trip OK
 IC-3 Responds Calibration _____
 IC-4 Responds Calibration _____
 CRM Meter Trip _____

Preliminary Check on 1-20-65

Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check JH C.C.
 Scrams and Bldg, Alarm Reset JH
 Source Inserted JH
 Safety Withdrawn 26.00
 Controls Set 12.52 Outlets 0.0
 Reflector Water -6" above Be
 Moderator Water -27.00

Condition	Timer	Outlets	Safety	
R>1	15.76	16.00 ⁵	26.00	2.017 dis/sec
R=1	15.76	15.86	26.00	
R=1	15.81	15.81	26.00	
"	16.00	15.60	"	
"	18.00	13.71	"	
"?	20.00	12.26	"	
"	22.00	11.26	"	
"	24.00	10.63	"	
"	25.00	10.44	"	
"	22.70	11.01	"	
"	18.89	13.00	"	
"	16.56	15.00	"	

NB. Expt. 301 Plastic Cyl. w/T

Special Plastic cylinder #2 for island as described in drawing #

Cylinder is water tight and contains concentric cylinders of Plastic. Expts. will be conducted with and without water in cyl.

- a) Cylinder inserted in island - no reflector water - controls fully withdrawn no moderator
- b) Critical positions of controls over core length

Expt. 300 cont'd w/w

Condition	Inner	Outer	Safety
R=1	14.73	17.00	26.00
R=1	13.30	19.00	26.00
R=1	12.20	21.00	26.00
R=1	11.44	23.00	26.00
R=1	11.01	25.00	26.00

Temp of Mod. + Refl. 20°C

Expt. 301 Plastic Cyl. w/T

Have removed safety and inserted plastic cylinders, containing air, into the island.

No reflector water present - no moderator.

Both control cylinders withdrawn to 25.00 in. Apparent neutron source multiplication ≈ 1.15

Expt. 302 Pl. Cy. w/T

add reflector + moderator

Condition	Inner	Outer	Cond.	Inner	Outer
2.517 div/sec k > 1	14.40	14.86 ⁵	R=1	21.94	9.00
R=1	14.40	14.71 ⁵	R=1	18.33	11.00
R=1	14.54 ⁵	14.54 ⁵	R=1	15.97	13.00
R=1	16.00	13.00	R=1	14.12	15.00
R=1	18.00	11.26 ⁵	R=1	12.59	17.00
R=1	20.00	9.92	R=1	11.32	19.00
R=1	22.00	8.97	R=1	10.31	21.00
R=1	24.00	8.36	R=1	9.61	23.00
R=1	25.01	8.16	R=1	9.17 ⁵	25.00

Expt. 303

Multiplication with nothing in island, no reflector
and no moderator - control cylinders at 25.00 in. ~ 1.12
Decaying λ 's present.

Expt. 304 Pl. Cy. w/T + water.

	Condition	Inner	Outer		Condition	Inner	Outer
2.32 λ / sec	k=1	15.24	15.62		k=1	20.82	11.00
	k=1	15.24	15.49 ^s	1	k=1	17.82 ^s	13.00
	k=1	15.35 ^s	15.35 ^s		k=1	15.69 ^s	15.00
	k=1	16.04	14.69		k=1	13.97	17.00
	k=1	18.00	12.85 ^s		k=1	12.58 ^s	19.00
	k=1	20.00	11.45		k=1	11.52 ^s	21.00
	k=1	22.00	10.46		k=1	10.79	23.00
	k=1	24.00	9.84		k=1	10.36	25.00
	k=1	25.00	9.65 ^s				

Mod. water temp. 20°C

1-21-65

Multiplication tests - no Refl. no Mod.

* 2 Pl. cyl. w/T and Water	1.38
empty	1.35
* 1 Pl. cyl. empty	1.41
* 1 Pl. cyl + water	1.31

Exp. 305

#2 Plastic Cylinder (Void)

Instrument Check on 1-21-65 Source 60mc X

FM-1 Low Trip OK Alarm Trip OK
 FM-2 Alarm Trip OK
 IC-1 > 3x10⁻¹¹ Meter Trip OK Fast Trip OK
 IC-2 > 3x10⁻¹¹ Meter Trip OK
 IC-3 Responds Calibration JH
 IC-4 Responds Calibration JH
 DRM Meter Trip

Preliminary Check on 1-21-65

Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check JH c.e.
 Scrams and Bldg. Alarm Reset JH
 Source Inserted JH
 Safety Withdrawn none
 Controls Set Inner 14.84 Outer 0.0
 Reflector Water ~ 6" Above Be.
 Moderator Water ~ 26"

Condition	Inner	Outer	Condition	Inner	Outer
k=1	14.15	13.99	k=1	19.71	9.00
k=1	14.00	13.99	k=1	16.96	11.00
k=1	16.00	7.88	k=1	14.86	13.00
k=1	18.00	10.15	k=1	13.13	15.00
k=1	20.00	8.85	k=1	11.68	17.00
k=1	22.00	7.99	k=1	10.50	19.00
k=1	24.00	7.37	k=1	9.57	21.00
k=1	25.00	7.19	k=1	8.88	23.00
			k=1	8.48	25.00

Expt 30.6

#2 Plastic Cyl. w/w

Condition	Inner	Outer	Condition	Inner	Outer
$k=1$	15.68	15.68	$k=1$	22.13	11.00
$k=1$	16.00	15.33	$k=1$	18.60	13.00
$k=1$	18.00	13.47	$k=1$	16.33	15.00
$k=1$	20.00	12.04	$k=1$	14.55	17.00
$k=1$	22.00	11.04	$k=1$	13.11	19.00
$k=1$	24.	10.41	$k=1$	12.01	21.00
$k=1$	25.	10.22	$k=1$	11.28	23.00
			$k=1$	10.83	25.00

Mod. water Temp. 20°C

1-26-65 Have removed Be reflector and control cylinders
in preparation of HEIRCE-3 Safety tests.

Moderator water sump and Safety sump are set to
read 22.00 in when water is level with top of
fuel plates.

Have placed reflector water in safety system.

Expt. 308 Have moved IC-2 and IC-4 to within 8 in from
surface of fuel element. They are located on a
diameter with fuel plate #1. IC-2 on North.

Expr. 307

Instrument Check on 1-26-65 Source Power

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK		
IC-3	Responds	Calibration	JH		
IC-4	Responds	Calibration	JH		
CRM		Meter Trip			

Preliminary Check on 1-26-65

Room 113 Pressure Differential	1.4"
Red Light On and Personnel Check	JH CC.
Jerams and Bldg. Alarm Reset	JH
Source Inserted	JH
Safety Withdrawn	0
Controls Set	
Reflector Water	none
Moderator Water	25.93

No reflector present.

Condition Safety Moderator H_2O

R < 1 ~ 26.07 25.92 M ~ 1

Add reflector to 26.00 check source response. { IC-2 good
others poor

R < 1 26.00 25.92

R < 1 26.00 27.15

Expr. 308

Have place $2\frac{3}{16}$ " dia Styrofoam cylinder in island.

R < 1	26.00	26.11	M ~ 53	TMC
			43	IC-4
			2.6	IC-2, IC-3

Expr. 309

R < 1	26.00	26.11	212	3PN-256	see p. 294
-------	-------	-------	-----	---------	------------

Expt. 310 : $2\frac{7}{8}$ " Styrofoam void $\sim 31.8\%$ void. $\equiv V_3$

Expt. 311 : $2\frac{9}{16}$ " " " $\sim 25.4\%$ void. $\equiv V_2$

Table of Voids $\equiv V_i$

No.	Dia (in.)	Vol	Void Fraction in Island
1	$2\frac{3}{16}$	18.6	19%
2	$2\frac{9}{16}$	25.4	25.3%
3	$2\frac{7}{8}$	31.8	31.7%
4	$3\frac{1}{4}$	41.1	40.8%
5	$3\frac{7}{8}$	58.4	59%
6	$4\frac{3}{16}$	67	68.5%
7	$4\frac{3}{4}$ $4\frac{1}{2}$	87 79	79.2%

Expt. 312

Have placed borul strip $3" \times 20" \times \frac{1}{4}"$ on drive mechanism adjacent to core on east side. Feil insertion $\sim \frac{1}{2}$ of active core.

Expt 310 w/V₃ 2 7/8" Styrofoam cyl. 24"
 Instrument Check on 1-27-65 Source 10me8

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	> 3x10 ⁻⁴	Motor Trip	OK	Fast Trip	OK
IC-2	> 3x10 ⁻⁴	Motor Trip	OK		
IC-3	Reprints	Calibration	JH		
IC-4	Reprints	Calibration	JH		
CRM		Motor Trip			

Preliminary Check on 1-27-65

Room 113 Pressure Differential	1.4
Red Light On and Personnel Check	JH - CC.
Scrams and Bldg. Alarm Reset	JH.
Source Inserted	JH
Safety Withdrawn	0
Controls Set	
Reflector Water	26.00
Moderator Water	26.02

Condition	Safety	
k > 1	17.70	4.4 div/sec → 95.6 sec → 10.24
k = 1	17.36 ⁹⁴	30 1/2 in.
k < 1	17.26	2.5 div/sec → 467 sec → -34 → 30 1/2 in.

Expt 311 w/V₂

k > 1	20.35	3 div/sec → 65.2 sec → 13.64	Boral strip has negligible effect when ~4" from surface of element.
k = 1	19.40 ⁹⁵	14.3 1/2 in.	

Expt 312 w/V₂ Aux. Boral rod in Refl.

k > 1	26.00	aux rod all in.	3.467 div/sec → 75.3 sec → 12.264
k = 1	20.70	" " " "	2.31 1/2 in.
k < 1	19.97 ⁵	" " " "	7.1 div/sec → 197.7 sec → -834 → 11.4 1/2 in.

Exp. 313 w/1/2

Boral strip repositioned so that full insertion ~ 10" into active core. Rod is against outer surface of core.

Condition	Safety	Boral rod.	
$k=1$	21.49	6 5/8 (ints)	3PN-213 p.295

Exp. 314 w/1/2

$k < 1$	0	6 5/8 (ints)	3PN-214
---------	---	--------------	---------

Preliminary Check on 1-28-65

Room 113 Pressure Differential	1.4"
Red Light On and Personnel Check	JH .c.c.
Scrams and Bldg, Alarm Reset	✓
Source Inserted	JH
Safety Withdrawn	0
Controls Set	
Reflector Water	26.08
Moderator Water	26.25

Instrument Check on 1-28-65 Source 10mcd

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	> 3x10 ⁻⁴	Meter Trip	OK	Fast Trip	OK
IC-2	> 3x10 ⁻⁴	Meter Trip	OK		
IC-3	Responds	Calibration	JH		
IC-4	Responds	Calibration	JH		
IRM		Meter Trip			

Exp. 315 w/1/2

Condition	Safety	Boral rod.	
$k=1$	21.35	5 1/8" into core	3PN-215 p.295

Exp. 316 w/1/2

$k < 1$	10.00	5 1/8" into core	Mod H ₂ O 26.09"	3PN-216
---------	-------	------------------	-----------------------------	---------

2.523 div/sec

Exp. 324: $\rightarrow 54.8$ sec period $\rightarrow 15.4$ $\rightarrow 49.2$ 1/in

Expt. #	Condition	Safety	Boral Rod	Mod H ₂ O Height	Island	SPN #
317	k < 1	10.00	5 1/8" into core	26.15	W	217
318	k < 1	26.00	5 1/8" into core	26.17	W	218
319	k < 1	10.00	" "	26.01	V ₃	219

Instrument Check on 1-29-65 Source 10 meV

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	> 3 x 10 ⁻⁴	Meter Trip	OK	Fast Trip	OK
IC-2	> 3 x 10 ⁻⁴	Meter Trip	OK		
IC-3	Responds	Calibration	JH		
IC-4	Responds	Calibration	JH		
CRM		Meter Trip			

Preliminary Check on 1-29-65

Room 113 Pressure Differential	1.4"
Red Light On and Personnel Check	JH
Scrams and Bldg. Alarm Reset	JH
Source Inserted	JH
Safety Withdrawn	0
Controls Set	—
Reflector Water	26.00
Moderator Water	26.02

Expt. #	Condition	Safety	H ₂ O	B. Rod	Island	
320	k > 1	18.70	26.02	5 1/8	V ₃	2.467 $\frac{dw}{dw}$ → 53.65 → 15.64
	k = 1	18.08	26.02	5 1/8	V ₃	25.24/m
321	Removed 12 fuel location plates					
	k < 1	26.00	20.3	5 1/8	V ₃	
	k = 1	26.00	20.72	5 1/8	V ₃	
	k = 1	16.64	26.05	5 1/8	V ₃	
322	Replaced 12 fuel plates					
	k < 1	10.00	26.18	5 1/8	V ₁	3PN-220
323	k < 1	10.00	26.09	5 1/8	V ₅	3PN-221
324	k > 1	14.60	26.11	5 1/8	V ₅	
325	k = 1	14.28	26.11	5 1/8	V ₅	

Exp. 327: $1.4 \frac{di}{dce} \rightarrow 30.4 \text{ acc} \rightarrow 22.4 \text{ f} \rightarrow 43 \text{ f/in}$

1318 hrs. Reactor screamed for no apparent reason. No trip signals indicated on instruments. ~~Reactor was~~ The reactor was shut down at the time and Cross was in the cell at the work bench.

Expt.	Condition	Safety	H ₂ O	B.rod.	Island	3PN-#
326	k > 1	14.15	26.18	5 1/8"	V ₆	
327	k = 1	13.63	26.18	5 1/8"	V ₆	
328	k < 1	10.00	26.18	5 1/8"	V ₆	222

Instrument Check on 2-1-65 Source 10mcB

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	> 3 x 10 ⁻⁴	Meter Trip	OK	Fast Trip	OK
IC-2	> 3 x 10 ⁻⁴	Meter Trip	OK		
IC-3	Responds	Calibration	JA		
IC-4	Responds	Calibration	JA		
CRM		Meter Trip			

Preliminary Check on 2-1-65

Room 113 Pressure Differential	1.4"
Red Light On and Personnel Check	JA .cc.
Corams and Bldg. Alarm Reset	JA
Source Inserted	ACC
Safety Withdrawn	0.0
Controls Set	
Reflector Water	26.00
Moderator Water	27.33

329	k < 1	0.0	27.33	5 1/8"	V ₆	223
-----	-------	-----	-------	--------	----------------	-----

Expt. 330. Installed Poison post - inserted $3\frac{7}{8}$ " Styrofoam along full length

332. $3.325 \text{ div/sec} \rightarrow 72 \text{ sec} \rightarrow 12.74 \rightarrow 40.3 \text{ 4/in}$

Expt. 336 : $3.062 \text{ div/sec} \rightarrow 66.4 \text{ sec} \rightarrow 13.44 \rightarrow 45.1 \text{ 4/in}$

Expt. 337 - Have placed 30 S.S. - strips $5/8" \times 24" \times 0.30"$ into fuel element. 18 in outer annulus and 12 into the inner. Numbering slots as preceding plate number strips were placed

Inner: 5, 27, 42, 62, 82, 87, 102, 111, 126, 136, 151, (1-10)

Outer: 5, , 63, 83, , 140, 160, , 192, 212, , 244, 264,
, 300, 320, , 350.

$2.4 \text{ div/sec} \rightarrow 52.1 \text{ sec} \rightarrow 15.94 \rightarrow 39.8 \text{ 4/in}$

Expt. 338 - add six S.S. strips to outer annulus

$1.83 \text{ div/sec} \rightarrow 39.7 \text{ sec} \rightarrow 19.074 \rightarrow 38.1 \text{ 4/in}$

36 strips distributed as above worth 62.64

Expt.	Condition	Safety	H ₂ O	B. rod	Island	3PN No.
330	R<1	part out 28.75	28.75	5 1/8	P.P. + V ₅	224
331	R<1	10.00	26.20	5 1/8	V ₇	225
332	R>1	13.64	26.21	5 1/8	V ₇	—
	R=1	13.32 ⁵	26.21	5 1/8	V ₇	—
333	R<1	0	26.25	5 1/8	V ₇	226
334	R<1	out	26.28	5 1/8	P.P. + W	227
335	R<1	out	26.34	5 1/8	P.P. + V ₂	228

Instrument Check on 2-2-65 Source 10mc8

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	> 3 x 10 ⁻⁴	Meter Trip	OK	Fast Trip	OK
IC-2	> 3 x 10 ⁻⁴	Meter Trip	OK		
IC-3	Responds	Calibration	JH		
IC-4	Responds	Calibration	JH		
CRM		Meter Trip			

Preliminary Check on 2-2-65

Room 113 Pressure Differential	1.4 ⁹
Red Light On and Personnel Check	JH C.C.
Scrams and Bldg. Alarm Reset	JH
Source Inserted	JH
Safety Withdrawn	variable
Controls Set	
Reflector Water	— 26.00
Moderator Water	

Expt.	Condition	Safety	H ₂ O	B. rod	Island	
336	R>1	13.90	26.25	5 1/8	V ₆	
	R=1	13.60 ⁵	26.25	5 1/8	V ₆	
337	R>1	15.29	26.25	5 1/8	V ₆	S.S. strips (30)
	R=1	14.89	26.25	5 1/8	V ₆	
338	R>1	15.60	26.25	5 1/8	V ₆	add 6 SS-strips 0.6m
	R=1	15.10	26.25	5 1/8	V ₆	

Expt. 339: Have grouped 12 S.S. strips in successive slots in the inner annulus. From 108-120

$$2.02 \text{ div/sec} \rightarrow 43.9 \text{ sec} \rightarrow 17.87 \text{ } \frac{\text{ft}}{\text{in}} \rightarrow 38.02 \text{ } \frac{\text{ft}}{\text{in}} \quad \text{Value } 58.8 \text{ } \frac{\text{ft}}{\text{in}}$$

Expt. 340: Have left inner annulus grouped and have grouped 24 strips of outer annulus (234-258.)

$$1.64 \text{ div/sec} \rightarrow 35.6 \text{ sec} \rightarrow 20.434 \rightarrow 39.28 \text{ } \frac{\text{ft}}{\text{in}} \quad \text{value } 54.9 \text{ } \frac{\text{ft}}{\text{in}}$$

Expt. 341: Have removed 12 strips from inner annulus. 24 remain grpd as above in outer annulus. Value 31.3

$$2.32 \text{ div/sec} \rightarrow 50.4 \text{ sec} \rightarrow 16.30 \text{ } \frac{\text{ft}}{\text{in}} \rightarrow 41.2 \text{ } \frac{\text{ft}}{\text{in}}$$

Expt. 342 Have removed strips from outer annulus and replaced 12 strips in the inner annulus grouped as in #339. Value 27.3

$$2.30 \text{ div/sec} \rightarrow 49.9 \text{ sec} \rightarrow 16.41 \text{ } \frac{\text{ft}}{\text{in}} \rightarrow 41 \text{ } \frac{\text{ft}}{\text{in}}$$

Expt. 343: Have placed 72 S.S. strips into the inner annulus in alternate slots.

$$1.98 \text{ div/sec} \rightarrow 43.0 \text{ sec} \rightarrow 18.11 \text{ } \frac{\text{ft}}{\text{in}} \rightarrow 19.1 \text{ } \frac{\text{ft}}{\text{in}}$$

Experiment	Condition	Safety	H ₂ O	B. nod.	Island	
339	R>1	15.50	26.29	5 1/8	V ₆	S.S. strips.
	R=1	15.03	26.29	5 1/8	V ₆	"
340	R>1	15.42	26.29	5 1/8	V ₆	"
	R=1	14.90	26.29	5 1/8	V ₆	"
341	R>1	14.67	26.29	5 1/8	V ₆	"
	R=1	14.27 ⁵	26.29	5 1/8	V ₆	"
342	R>1	14.60	26.29	5 1/8	V ₆	"
	R=1	14.20	26.29	5 1/8	V ₆	"
343	R>1	19.51	26.29	5 1/8	V ₆	"
	R=1	18.56	26.29	5 1/8	V ₆	"

Expt. 344. There are now 82 S.S. strips in the inner annulus,
placed in alternate slots.

$$1.98 \frac{\text{div}}{\text{sec}} \rightarrow 43.0 \text{ sec} \rightarrow 18.11 \phi \rightarrow 14.76 \phi/\text{in}$$

Expt. 345. There are now 90 S.S. strips in the inner annulus,
eight additional strips distributed uniformly among others.

$$1.62 \frac{\text{div}}{\text{sec}} \rightarrow 35.2 \text{ sec} \rightarrow 20.58 \phi \rightarrow 6.54 \phi/\text{in} \quad \begin{matrix} 22-24.00 \\ 3.165 \phi/\text{in} \end{matrix}$$

Expt. 345B. $2.82 \frac{\text{div}}{\text{sec}} \rightarrow 61.2 \text{ sec} \rightarrow 14.25 \phi \rightarrow 12.45 \phi/\text{in}$

" C. $4.7 \frac{\text{div}}{\text{sec}} \rightarrow -102.0 \text{ sec} \rightarrow -25.79 \phi \rightarrow$

" D. $37.4 \frac{\text{div}}{\text{sec}} \rightarrow 74.7 \text{ sec} \rightarrow 12.33 \phi$

Expt. 349. 54 S.S. strips uniformly dist. in the inner annulus

$$1.1 \frac{\text{div}}{\text{sec}} \rightarrow 23.9 \text{ sec} \rightarrow 25.86 \phi \rightarrow 26.12 \phi/\text{in}$$

Expt. 350. 42 S.S. strips uniformly dist. in the inner annulus

$$2.05 \frac{\text{div}}{\text{sec}} \rightarrow 44.5 \text{ sec} \rightarrow 17.71 \phi \rightarrow 31.90 \phi/\text{in}$$

Expt. 344

Instrument Check on 2-3-65 Source 10me1

PM-1	Low Trip	6K	Alarm Trip	OK
PM-2			Alarm Trip	OK
IC-1	> 3x10 ⁻¹¹	Motor Trip	OK	Fast Trip
IC-2	> 3x10 ⁻¹¹	Motor Trip	OK	
IC-3	Responds	Calibration	JH	
IC-4	Responds	Calibration	JH	
IC-5		Motor Trip		

Preliminary Check on 2-3-65

Room 113 Pressure Differential	1.4'
Red Light On and Personnel Check	JH CC
Scrams and B12g. Alarm Reset	JH
Source Inserted	JH
Safety Withdrawn	0
Controls Set	
Reflector Water	26.00
Moderator Water	26.34

Expt.	Conditions	Safety	H ₂ O	B. rod	10me1	
344	R>1	21.00	26.34	5 1/8	V ₆	5.5 strips (82)
	R=1	19.77 ³	"	"	"	"
345	A R>1	24.00	"	"	"	5.5 Strips (90 ⁹⁰ thinner)
	R=1	20.85 ⁵	"	"	"	"
	B R>1	22.00	"	"	"	"
	C R<1	20.85 ⁵	"	inserted	V ₆	"
	D R>1	20.85 ⁵	"	out	V ₆	"
346	k=1	21.35	"	6 5/8	V ₆	3PN-229 90SS strips
347	k=1	20.95 ⁵	"	6 7/8 5/8	V ₆	90SS strips
348	k<1	17.60 ⁵	"	5 1/8	V ₆	" " 3PN-200
349	R>1	17.91	"	5 1/8	V ₆	54 SS. Strips
	R=1	16.92	"	5 1/4	V ₆	" " "
350	R>1	16.60	"	5 1/8	V ₆	42 S.S. Stripes
	R=1	16.04 ⁵	"	5 1/4	V ₆	" " "

Expt. 351 36 S.S. strips - uniformly distr. in the inner annulus.

$$1.3 \text{ in/sec} \rightarrow 28.2 \text{ sec} \rightarrow 23.524 \rightarrow 33.70 \text{ } \frac{1}{\text{in}}$$

Expt. 352 all 55 strips removed.

$$1.30 \text{ in/sec} \rightarrow 28.2 \text{ sec} \rightarrow 23.524 \rightarrow 44.8 \text{ } \frac{1}{\text{in}}$$

Expt. 353 120 S.S. strips in outer annulus 1 in every
3rd gap.

$$1.92 \text{ in/sec} \rightarrow 41.7 \text{ sec} \rightarrow 18.494 \rightarrow 22.4 \text{ } \frac{1}{\text{in}}$$

Expt. 354 90 S.S. strips, outer annulus Removed every
4th plate from distribution of Expt. 353

$$0.91 \text{ in/sec} \rightarrow 19.76 \text{ sec} \rightarrow 28.704 \rightarrow 29.29 \text{ } \frac{1}{\text{in}}$$

Expt. 355 60 S.S. strips; outer annulus; every ^{3rd} strip removed
from distribution of Expt. 354. Even distribution.

$$1.84 \text{ in/sec} \rightarrow 39.95 \text{ sec} \rightarrow 19.04 \rightarrow 35.85 \text{ } \frac{1}{\text{in}}$$

Expt. 356. 45 S.S. strips; outer annulus; every 4th strip
removed from distribution of Expt. 355

$$1.36 \text{ in/sec} \rightarrow 29.53 \text{ sec} \rightarrow 22.894 \rightarrow 40.16 \text{ } \frac{1}{\text{in}}$$

Expt	Condition	Safety	H ₂ O	B-rod	Island	
351	k>1	16.22	26.10	5 1/8	1/6	36 S.S. strips (inner)
	k=1	15.522	26.10	5 1/8	1/6	" " " "
352	k>1	14.115	26.10	5 1/8	1/6	no S.S. Strips
	k=1	13.59	26.10	5 1/8	1/6	no S.S. Strips

Instrument Check on 2-4-65 Source 10 mcd

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	> 3x10 ⁻¹¹	Meter Trip	OK	Fast Trip	OK
IC-2	> 3x10 ⁻¹¹	Meter Trip	OK		
IC-3	Responds	Calibration	JH		
IC-4	Responds	Calibration	JH		
CSR		Meter Trip			

Preliminary Check on 2-4-65

Room 113 Pressure Differential	1.4"
Red Light On and Personnel Check	JH .CC
Scrams and Bldg. Alarm Reset	JH A will not trip
Source Inserted	JH
Safety Withdrawn	0
Controls Set	
Reflector Water	26.00
Moderator Water	26.17

Expt	Condition	Safety	H ₂ O	B-rod	Island	
353	k>1	18.00	26.17	5 1/8	1/6	120 S.S. strips (O.A)
	k=1	18.175	26.17	5 1/8	1/6	
354	k>1	17.735	26.17	5 1/8	1/6	90 S.S. S. outer An.
	k=1	16.755	26.17	5 1/8	1/6	
355	k>1	16.09	26.17	5 1/8	1/6	60 S.S. O.A
	k=1	15.56	26.17	5 1/8	1/6	
356	k>1	15.61	26.17	5 1/8	1/6	45 S.S. O.A.
	k=1	15.04	26.17	5 1/8	1/6	

Expt. 357 30 SS Strips. remove every ^{3rd} SS strip from # 356
 $1.792 \text{ in/sec} \rightarrow 38.90 \text{ sec} \rightarrow 19.32 \text{ f} \rightarrow 41.11 \text{ f/in}$

Expt. 358 15 SS Strips; removed every other SS strip from # 357
 $1.68 \text{ in/sec} \rightarrow 36.47 \text{ sec} \rightarrow 20.12 \text{ f} \rightarrow 44.22 \text{ f/in}$

Expt. 359 all SS removed. Temp = 19.5°C

$1.58 \text{ in/sec} \rightarrow 34.30 \text{ sec} \rightarrow 20.90 \text{ f} \rightarrow 45.43 \text{ f/in}$

Expt. 360 45 SSS, \approx space OA. ; 15 SSS, \approx space Inner Annulus.

$2.44 \text{ in/sec} \rightarrow 52.77 \text{ sec} \rightarrow 15.75 \text{ f} \rightarrow 33.51 \text{ f/in}$

Expt. 361 15 SSS \approx space OA. ; 45 SSS. \approx space I A.

$1.6 \text{ in/sec} \rightarrow 34.74 \text{ sec} \rightarrow 20.32 \text{ f}$

Exps.	Condition	Safety	H ₂ O	B. rod	Island	
357	k=1	15.00	25.91	5 1/8	V ₆	30 SS strip OA
	k=1	14.53	25.91	5 1/8	V ₆	
358	k>1	14.50	26.12	5 1/8	V ₆	15 SS strip OA.
	k=1	14.04 ⁵	26.12	5 1/8	V ₆	
359	k>1	14.04	26.08	5 1/8	V ₆	90. SS
	k=1	13.58	26.08	5 1/8	V ₆	
360	k>1	16.50	26.24	5 1/8	V ₆	45 SS strip OA 15 SS strip IA.
	k=1	16.03	26.24	5 1/8	V ₆	
361	k>1	17.66	26.22	5 1/8	V ₆	15 SS OA 45 SS IA.
	k=1	16.91	26.22	5 1/8	V ₆	
362	k<1	13.58	26.21	5 1/8	V ₆	15 SS OA 45 SS IA 3PN-231

Have placed CE-2, suspended from crane, adjacent to CE-3 on west side. core ~2" above CE-3.

Expt. 366. 85 SS strips uniformly spaced in inner annulus of CE-3

Exp. 363 CE-2 + CE-3 + P.P. + V₂

Instrument Check on 2-5-65 Source 10mc

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	
IC-3	Responds	Calibration	JH	
IC-4	Responds	Calibration	JH	
CRM		Meter Trip		

Preliminary Check on 2-5-65

Room 113 Pressure Differential	1.4"
Red Light On and Personnel Check	JH C.C.
Scrams and Bldg. Alarm Reset	JH A does not trip
Source Inserted	JH
Safety Withdrawn	26.
Controls Set	
Reflector Water	26.00
Moderator Water	var.

Exp.	Condition	Safety	H ₂ O	Island	CE-2
363	K > 1	21.35	9.75	P.P + V ₂	4" submerged, flooded.
	K = 1	"	9.485	P.P + V ₂	"
364	K > 1	21.35	16.29 ⁵	P.P.	"
	K = 1	21.35	9.94	P.P.	"
365	K > 1	21.35	13.60	W.	4" Submerged + P.P.
	K = 1	21.35	13.45	W	" "
	K = 1	10.00	14.85	W	" "
	K = 1	0.0	18.22	W	" "
366	K > 1	0.0	19.34 ⁵	W	" "
	K = 1	0.0	18.85	W	" "

- Expt. 367 Have removed CE-2. Removed all SS strips.
Installed Al. platform around base of CE-3 to support steel reflector.
- Expt. 369 $1.96 \frac{\text{div}}{\text{sec}} \rightarrow 42.55 \text{ sec} \rightarrow 18.24 \phi \rightarrow 9.45 \phi/\text{in.} (20.85)$
 $\frac{1}{4}$ Steel refl moved away from core $\frac{1}{2}$ " at center of hemi-cyl.
- Expt. 370 $\frac{3}{4}$ " Steel refl. placed as close to one side of the core as possible,

- Expt. 374 $3 \frac{3}{4}$ " of steel around $\frac{1}{2}$ of core
 $17.25 \frac{\text{div}}{\text{sec}} \rightarrow 374.5 \text{ sec} \rightarrow 3.186 \phi \rightarrow 0.815 \phi/\text{in.} (23.39)$

- Expt. 376. $4 \frac{3}{4}$ " of steel around $\frac{1}{2}$ of core
 $1.62 \frac{\text{div}}{\text{sec}} \rightarrow 35.2 \text{ sec} \rightarrow 20.58 \phi \rightarrow 19.6 \phi/\text{in.} (19.72)$

Expt.	Condition	Safety	H ₂ O	Island	
367	k > 1	21.74	26.11	V ₂	
	k = 1	19.81 ^{1.73}	26.11	V ₂	
368	k < 1	26.00	26.14	V ₂	1/4" Stainless Steel refl. around 1/2 of low.
369	k < 1	26.00	26.15	V ₂	" " "
370	k < 1	26.00	26.14	V ₂	3/4" Steel refl. 180°
371	k < 1	19.7k	26.14	V ₂	" " " 3PN-232

Instrument Check on 2-8-65 Source 70 mcr

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	> 3x10"	Meter Trip	OK	Fast Trip	OK
IC-2	> 3x10"	Meter Trip	OK		
IC-3	Responds	Calibration	9TT.		
IC-4	Int	Calibration			
CRM		Meter Trip			

Preliminary Check on 2-8-65

on 113 Pressure Differential	1.5"	
Light-On and Personnel Check	S/R	C.C.
ams and Bldg, Alarm Reset	S/R	A does not trip
orce inserted	C.C.	
Safety Withdrawn	19.71	
ontrols Set		
lector Water	Rh-00	
erator Water	Was.	

Expt.	Condition	Safety	H ₂ O	Island	Steel Refl.	3PN-#
372	k < 1	19.91	26.56	V ₂	1 3/4"	233
373	k < 1	19.81	26.28	V ₂	2 3/4"	234
374	k > 1	26.00	26.42	V ₂	3 3/4"	235
	k = 1	22.09 ^{3.91}	26.42	V ₂	3 3/4"	
375	k < 1	19.81	26.42	V ₂	3 3/4"	235
376	k > 1	19.64 ⁵	26.14	V ₂	4 3/4"	
	k = 1	18.57 ^{1.050}	26.14	V ₂	4 3/4"	


250

Expt. 377

$6\frac{1}{4}$ " of steel around $\frac{1}{2}$ of core
 $1.70 \text{ div/sec} \rightarrow 36.9 \text{ sec} \rightarrow 19.784 \rightarrow 30.7 \text{ } \phi/\text{in} \quad (17.577)$

Expt. 378

$6\frac{1}{4}$ " of steel around $\frac{1}{2}$ the circumference and
 $\frac{3}{4}$ " of steel around the other $\frac{1}{2}$



Expt. 380

$\frac{3}{4}$ " of steel all around the core.

Expt. 381

$\frac{3}{4}$ " of steel + 4" of lead around 360° of core. (~ 1 " gap in lead)

$1.68 \text{ div/sec} \rightarrow 36.5 \text{ sec} \rightarrow 20.12 \phi \rightarrow 55.9 \text{ } \phi/\text{in} \quad (14.73)$

382

Added 27 lead bricks; 9 col., 3 high, 2" thick.

$1.41 \text{ div/sec} \rightarrow 30.6 \text{ sec} \rightarrow 22.41 \phi \rightarrow 64.03 \text{ } \phi/\text{in} \quad (13.765)$

Eggs	Condition	Safety	H ₂ O	Island	Steel Refl	JPN-#
377	k > 1	17.91	26.01	V ₂	6 1/4"	
	k = 1	17.26 ^{1.45}	26.01	V ₂	6 1/4"	
378	k < 1	26.00	26.26	V ₂	6 1/4" + 3/4"	
379	k < 1	19.81	26.26	V ₂	6 1/4" + 3/4"	236

Instrument Check on 2-9-65 Source 10 mcr

M-1	Low Trip	OK	Alarm Trip	OK	
M-2			Alarm Trip		
IC-1	> 3x10 ⁻⁴	Meter Trip	OK	East Trip	OK
IC-2	> 3x10 ⁻⁴	Meter Trip	OK		
IC-3	Response	Calibration			
IC-4	Response	Calibration			
CRM		Meter Trip			

Preliminary Check on 2-9-65

Room 113 Pressure Differential	1.5"
Red Light On and Personnel Check	SPR C.C.
Scrams and Bldg. Alarm Rcsct	JTT
Source Inserted	
Safety Withdrawn	19.71
Controls Set	
Reflector Water	On
Moderator Water	On

Eggs	Condition	Safety	H ₂ O	Island	Refl.	JPN-#
380	k < 1	19.71	26.36	V ₂	3/4" + 3/4"	237
381	k > 1	15.01	26.32	V ₂	3/4" Steel + 4" lead	
	k = 1	14.65	26.32	V ₂	" "	
382	k > 1	14.04	26.41	V ₂	3/4" Steel + 4" lead + 27 lead bricks	
	k = 1	13.69	26.41	V ₂	" "	"

252

Expt. 383


21°C ; 33 lead bricks added in a 2" layer around 1/2 of core

1.86 dis/sec → 40.38 sec → 18.87 f → 66.21 g/in (13.708)

Expt. 384

72 lead bricks in a 4" layer around 1/2 of core. ~ 1" gap in
4" lead refl. on one side of core (see picture).

1.80 dis/sec → 30.39 sec → 22.503 f → 69.24 g/in (13.285)



Expt. 385 3/4" Steel around 360° of core; 4" lead + 4" lead brick around 180° of core.

Expt. 387 3/4" Steel around 360° of core; 4" lead + 2" lead brick around 180° of core.

Expt. 388 3/4" Steel around 360° of core; 4" lead around 180° of core.

Instrument Check on 2-10-65 Source 10 mC

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip
 IC-1 7 3x10" Meter Trip OK Fast Trip OK
 IC-2 7 3x10" Meter Trip OK
 IC-3 Response - Calibration
 IC-4 Response - Calibration
 CRM Meter Trip

Preliminary Check on 2-10-65

Room 113 Pressure Differential 1.5"
 Red Light On and Personnel Check S/R C.C.
 Scrams and Bldg. Alarm Reset S/R A does not trip
 Source Inserted _____
 Safety Withdrawn _____
 Controls Set _____
 Reflector Water 2.6"
 Moderator Water 26.44"

Expt.	Condition	Safety	H ₂ O	Island	Ref.
383	k > 1	13.75	26.44	V ₂	3/4" steel + 4" lead + 33 lead brick
	k = 1	13.56 ⁵	26.44	V ₂	" " "
384	k > 1	13.44 ⁷	26.31	V ₂	3/4" steel + 4" lead + 72 lead brick
	k = 1	13.12 ²	26.31	V ₂	" " "
385	k < 1	26.00	26.34	V ₂	3/4" steel + (4" lead and 72 brick) ^{on} 180° lead
386	k < 1	19.81	26.34	V ₂	" " 3PN-238
387	k < 1	19.81	26.34	V ₂	3/4" steel + (4" lead and 33 brick ^{around} 180° of lead)
"	"	"	"	"	3PN-239
388	k < 1	19.81	26.35	V ₂	3/4" steel + (4" lead on 180° lead)
"	"	"	"	"	3PN-240

- Expt 389 $\frac{3}{4}$ " Steel and 4" lead around 180° of core. Water around other 180° .
 $1.46 \text{ di/sec} \rightarrow 31.70 \text{ sec} \rightarrow 21.9394 \rightarrow 37.18 \text{ f/in}$ (17.105)
- Expt 390 ($\frac{3}{4}$ " Steel + 4" lead + 2" lead brick) around 180° of core.
 $1.56 \text{ di/sec} \rightarrow 34.30 \text{ sec} \rightarrow 20.9084 \rightarrow 48.62 \text{ f/in}$ (15.635)
- Expt 391 ($\frac{3}{4}$ " Steel + 4" lead + 4" lead brick) around 180° of core. No refl. water.
 Safety at 26.00"
- Expt 392 Same as Expt 391 except safety at 0.00"
- Expt 393 ($\frac{3}{4}$ " Steel + 4" lead + 4" lead brick) around 180° of core.
 $1.48 \text{ di/sec} \rightarrow 32.13 \text{ sec} \rightarrow 21.7614 \rightarrow 51.81 \text{ f/in}$ (15A3)
- Expt 394 $\frac{1}{4}$ " Steel around 360° of core.
- Expt 395 $\frac{1}{4}$ " Steel around 180° of core.
- Expt 396 Clean core. H_2O reflector, temp 22°C
 $1.72 \text{ di/sec} \rightarrow 37.34 \text{ sec} \rightarrow 19.8314 \rightarrow 10.12 \text{ f/in}$ (20.49)

Instrument Check on 2-11-65 Source 10 mc K

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	
IC-3	$> 3 \times 10^{-4}$ Response	Calibration	OK	JTT
IC-4	Response	Calibration	JTT	
CRM		Meter Trip		

Preliminary Check on 2-11-65

Room 113 Pressure Differential	<u>1.5"</u>
Red Light On and Personnel Check	<u>C.C.</u>
Scrams and Bldg. Alarm Reset	<u>JTT</u> <u>A does not Trip</u>
Source Inserted	<u>C.C.</u>
Safety Withdrawn	
Controls Set	
Reflector Water	<u>26"</u>
Moderator Water	

Exps.	Condition	Safety	H ₂ O	Island	Refl.
389	$k > 1$	17.40	26.49	V ₂	($\frac{3}{4}$ " Steel + 4" lead) 180° of core.
	$k = 1$	16.81	26.49	V ₂	" " "
390	$k > 1$	15.85	26.51	V ₂	($\frac{3}{4}$ " Steel + 4" lead + 33 lead brick) 180°
	$k = 1$	15.42	26.51	V ₂	" " " "
391	$k < 1$	26.00	26.31	V ₂	No refl. water; 3PN-241 ($\frac{3}{4}$ " Steel + 4" lead + 72 lead brick) 180°
392	$k < 1$	0.0	26.31	V ₂	" " " " 3PN-242
393	$k > 1$	15.34	26.31	V ₂	($\frac{3}{4}$ " Steel + 4" lead + 72 lead brick) 180°
	$k = 1$	14.92	26.31	V ₂	" " " "
394	$k < 1$	19.81	26.32	V ₂	$\frac{1}{4}$ " Steel around 360° 3PN-243
395	$k < 1$	19.81	26.31	V ₂	$\frac{1}{4}$ " Steel around 180° 3PN-244
396	$k > 1$	21.59	26.31	V ₂	H ₂ O refl.
397	$k = 1$	19.63	26.31	V ₂	" "

Expt. 397 2.48 $\frac{\text{div}}{\text{sec}} \rightarrow 53.84 \text{ sec} \rightarrow 15.573 \text{ f} \rightarrow 11.33 \text{ f/in} \quad (20.72)$

Expt. 398 59 $\frac{\text{div}}{\text{sec}} \rightarrow 1280.9 \text{ sec} \rightarrow 0.99 \text{ f} \rightarrow 0.32 \text{ f/in} \quad (23.94)$

Expt. 399 Have displaced void (V_2) to observe effect. Removed B^N strip
2.52 $\frac{\text{div}}{\text{sec}} \rightarrow 54.71 \text{ sec} \rightarrow 15.411 \text{ f} \rightarrow 11.21 \text{ f/in} \quad (20.28)$

Expt. 400 Have removed V_2

Expt. 401 Have placed V_2 in island
1.19 $\frac{\text{div}}{\text{sec}} \rightarrow 25.83 \text{ sec} \rightarrow 24.748 \text{ f} \rightarrow 46.26 \text{ f/in} \quad (17.523)$

Expt. 402 3 B^N steel strip ~ equally spaced around inner annulus. ($1, 2, 3$)
1.52 $\frac{\text{div}}{\text{sec}} \rightarrow 33.00 \text{ sec} \rightarrow 21.410 \text{ f} \rightarrow 38.93 \text{ f/in} \quad (15.225)$

Expt. 403 2 B^N A.A. ~ 120° apart in inner annulus. ($1, 3$)
2.30 $\frac{\text{div}}{\text{sec}} \rightarrow 49.93 \text{ sec} \rightarrow 16.404 \text{ f} \rightarrow 40.50 \text{ f/in} \quad (14.548)$

Instrument Check on 2-12-65 Source come 8

FM-1	Low Trip	OK	Alarm Trip	OK	
FM-2			Alarm Trip		
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Responds	Calibration	JH		
IC-4	Responds	Calibration	JH		
CRM		Meter Trip			

Preliminary Check on 2-12-65

Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check JH (E)
 Scrams and Bldg, Alarm Reset JH A no trip
 Source Inserted JH
 Safety Withdrawn 0.0
 Controls Set —
 Reflector Water ~26.00
 Moderator Water —

Expt.	Condition	Safety	H ₂ O	Island	Refl.	Temp.
397	k > 1	21.00	26.35	V ₂	H ₂ O	3:20 PM 22°C
	k = 1	19.62 ⁵	26.35	V ₂	"	
398	k > 1	26.00	26.35	V ₂	one B ^N s. strip in Inner Annulus	
	k = 1	22.90	26.35	V ₂	H ₂ O	
399	k > 1	21.00	26.35	V ₂	H ₂ O (only)	V ₂ displaced ~ 1/8"
	k = 1	19.62 ⁵	26.35	V ₂	H ₂ O	"
400	k < 1	00.00	26.35	H ₂ O	H ₂ O only	JPN - 245
401	k > 1	13.80	26.56	V ₆	H ₂ O	"
	k = 1	13.26 ⁵	26.56	V ₆	" "	
402	k > 1	15.50	26.58	V ₆	" "	3 B ^N steel strips
	k = 1	14.95	26.58	V ₆	" "	" IA
403	k > 1	14.75	26.58	V ₆	" "	2 B ^N s.s. inner A.
	k = 1	14.34 ⁵	26.58	V ₆	" "	"

Expt. 404

$$2.392 \text{ div/sec} \rightarrow 51.93 \text{ sec} \rightarrow 15.962 \text{ f} \rightarrow 42.34 \text{ f/in} \quad (13.967)$$

Expt. 405

$$2.86 \text{ div/sec} \rightarrow 62.09 \text{ sec} \rightarrow 14,100 \text{ f} \rightarrow 43.529 \text{ f/in} \quad (13.939)$$

Expt. 406 B^N ss strips #s 1-5 ~ equally spaced around inner annulus

$$2.16 \text{ div/sec} \rightarrow 46.89 \text{ sec} \rightarrow 17,109 \text{ f} \rightarrow 30.55 \text{ f/in} \quad \begin{matrix} 16.622 \\ (16.53) \end{matrix}$$

Expt. 407 B^N ss strips #s 1-5 ~ equally spaced around outer annulus

$$0.67 \text{ div/sec} \rightarrow 14.55 \text{ sec} \rightarrow 33,546 \text{ f} \rightarrow 38.92 \text{ f/in} \quad \begin{matrix} 15.279 \\ (15.14) \end{matrix}$$

Expt. 408 B^N ss strips #s 1, 3, and 4 ~ equally spaced in outer annulus

$$1.74 \text{ div/sec} \rightarrow 37.78 \text{ sec} \rightarrow 19,685 \text{ f} \rightarrow 40.59 \text{ f/in} \quad \begin{matrix} 14.418 \\ (14.34) \end{matrix}$$

Expt. 409 B^N ss strip # 4 in outer annulus.

$$2.24 \text{ div/sec} \rightarrow 49.65 \text{ sec} \rightarrow 16,692 \text{ f} \rightarrow 45.73 \text{ f/in} \quad \begin{matrix} 13.729 \\ (13.67) \end{matrix}$$

Expt. 410 B^N ss strips #s 1-5 in adjacent slots in outer annulus.

$$1.712 \text{ div/sec} \rightarrow 37.18 \text{ sec} \rightarrow 19,884 \text{ f} \rightarrow 41.60 \text{ f/in} \quad \begin{matrix} 14.472 \\ (14.39) \end{matrix}$$

Exps.	Condition	Safety	H ₂ O	Island	Poison Strips (B ⁿ Steel)
404	k > 1	14.15	26.58	V ₆	# 3 minimum
	k = 1	13.77 ³	"	"	" " "
405	k > 1	14.10 ¹	"	"	# 1 " "
	k = 1	13.77 ⁶	"	"	" " "
406	k > 1	16.90 ²	"	"	# 1, 2, 3, 4, and 5
	k = 1	16.34 ²	"	"	" " "
407	R > 1	15.71	"	"	# 1 2 3 4 + 5 outer ann.
	R = 1	14.84 ⁸	"	"	" " "
408	R > 1	TH.666	"	"	# 1 3 + 4
	R = 1	14.17 ⁵	"	"	# 1 3 + 4
409	R > 1	13.91	"	"	# 4
	R = 1	13.54 ⁵	"	"	4
410	R > 1	14.71	"	"	# 1-5 adjacent slots
	R = 1	14.23 ²	"	"	" " "


Expt. 411 $2.54 \frac{\text{dis}}{\text{dec}} \rightarrow 55.14 \text{ sec} \rightarrow 15.327 \text{ } \phi \rightarrow 47.20 \text{ } \phi/\text{in}$ (13.441)
(12.24)

Expt. 412 B^N 1.1 strips #'s 1, 2, 3, 4, + 5 in adjacent slots in inner annulus.
 $1.90 \frac{\text{dis}}{\text{dec}} \rightarrow 41.25 \text{ sec} \rightarrow 18.610 \text{ } \phi \rightarrow 38.77 \text{ } \phi/\text{in}$ (15.41)
(15.33)

Expt. 413 Removed B^N strips. Built at \angle corner of $\frac{1}{4}$ " flat B steel plates backed by 6" of concrete against core.
 $1.72 \frac{\text{dis}}{\text{dec}} \rightarrow 37.34 \text{ sec} \rightarrow 19.830 \text{ } \phi \rightarrow 43.02 \text{ } \phi/\text{in}$ (14.193)

Expt. 414 Removed steel and concrete wall. Placed B^N 1.1 strips #'s 1, 2, 3, 4, + 5 in inner annulus with 5 fuel plates between each B^N strip
 $2.08 \frac{\text{dis}}{\text{dec}} \rightarrow 45.16 \text{ sec} \rightarrow 17.541 \text{ } \phi \rightarrow 32.48 \text{ } \phi/\text{in}$ (16.73)

Expt. 415 B^N 1.1 strips #'s 1-5 in inner annulus with 7 fuel plates between each strip.
 $1.64 \frac{\text{dis}}{\text{dec}} \rightarrow 35.61 \text{ sec} \rightarrow 20.428 \text{ } \phi \rightarrow 31.92 \text{ } \phi/\text{in}$ (16.40)



Instrument Check on 2-15-65 Source 10 mcr

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip
 IC-1 73x10" Meter Trip OK Fast Trip OK
 IC-2 73x10" Meter Trip OK
 IC-3 Response Calibration S/O
 IC-4 Response Calibration S/O
 CRM Meter Trip

Preliminary Check on 2-15-65

Room 113 Pressure Differential 1.6"
 Red Light On and Personnel Check S/O + C.C.
 Scrums and Bldg. Alarm Reset S/O A does not trip
 Source Inserted S/O
 Safety Withdrawn 0.0
 Controls Set
 Reflector Water ~ 26.00"
 Moderator Water

Expt.	Condition	Safety	H ₂ O	Refl.	Refl.
411	k > 1	13.60	26.52	V ₆	H ₂ O only Clean core.
	k = 1	13.28 ²	26.52	V ₆	" " Temp at 0900 21°C
412	k > 1	15.65	26.56	V ₆	" " 8" Strip #1-5 adjacent to ^{inner annulus}
	k = 1	15.17	"	"	" " " "
413	k > 1	14.42 ³	"	"	" 1/4" slotted plate, 6" Concrete block
	k = 1	13.96 ²	"	"	" " " "
414	k > 1	16.50	"	"	H ₂ O only B" Strip #1-5 ^{inner annulus}
	k = 1	15.96	"	"	" " " "
415	k > 1	16.72	"	"	" " " "
	k = 1	16.08	"	"	" " " "

$$B^N \sim 2.169 \text{ w/o}$$

Expt. 416 B^N S.S. Strips #s 1-5 in inner annulus with
10 fuel plates between each strip.

$$2.01 \text{ dir/dec} \rightarrow 43.64 \text{ sec} \rightarrow 17.940 \text{ } \phi \rightarrow 30.51 \text{ } \phi/\text{in}$$

(16.526)
(76.43)

Expt. 417 B^N S.S. Strips #s 1-5 ~ equally spaced in inner annulus.

$$1.94 \text{ dir/dec} \rightarrow 42.12 \text{ sec} \rightarrow 18.360 \text{ } \phi \rightarrow 29.61 \text{ } \phi/\text{in}$$

(16.695)
(76.59)

Expt. 418

Have washed core with weak nitric acid. Drained refl water,
~~was~~ cleaned tank and filled with clean water.

Expt. 419 V_6 in Island, H_2O refl., Clean Core.

$$2.18 \text{ dir/dec} \rightarrow 47.83 \text{ sec} \rightarrow 17.003 \text{ } \phi \rightarrow 50.16 \text{ } \phi/\text{in}$$

(12.65)
(72.59)

Expt. 420 BF_3 detector in core.

$$1.76 \text{ dir/dec} \rightarrow 38.211 \text{ sec} \rightarrow 19.544 \text{ } \phi \rightarrow 49.48 \text{ } \phi/\text{in}$$

(12.753)
(72.67)

Expt.	Condition	Safety	H ₂ O	Island	Ref.	
416	k > 1	16.82	26.42	V ₆	H ₂ Only	5 B ^N strips minus anomalies.
	k = 1	16.23 ²	"	"	"	
417	k > 1	17.00 ⁵	"	"	"	"
	k = 1	16.38 ⁵	"	"	"	"
418	k < 1	26.00	"	"	24" high Cd sheet wrapped around core with 1/8" water between Cd and core.	

3PN-246

Instrument Check on 2-19-65 Source 10 mc Y

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	7.3 x 10 ⁻⁴	Motor Trip	OK	Fast Trip	OK
IC-2	7.3 x 10 ⁻⁴	Motor Trip	OK		
IC-3	Responds	Calibration	S.P.R.		
IC-4	Responds	Calibration	S.P.R.		
CRM		Motor Trip			

Preliminary Check on 2-19-65

Room 113 Pressure Differential	1.5"
Red Light On and Personnel Check	S.P.R. C.C.
Scrams and Bldg. Alarm Reset	S.P.R. A does not trip.
Source Inserted	S.P.R.
Safety Withdrawn	0.0
Controls Set	
Reflector Water	0.0
Moderator Water	0.0

Expt.	Condition	Safety	H ₂ O	Island	Ref.	
419	k > 1	12.82	27.75	V ₆	H ₂ only	Clean Cov.
	k = 1	12.48'	"	"	"	Temp = 25°C
420	k > 1	12.95	26.01	"	"	BF ₃ detector in core.
	k = 1	12.55 ⁵	"	"	"	"
421	k = 1	12.54 ⁵	27.78	"	"	"

Expt. 422 Have rearranged the pieces of styrofoam that make up V_6
 $1.77 \text{ dm}^3/\text{sec} \rightarrow 38.43 \text{ sec} \rightarrow 19.472 \text{ f} \rightarrow 50.974 \text{ f/in} \quad (12.757)$

Expt. 423 Have placed V_2 in Island
 $2.69 \text{ dm}^3/\text{sec} \rightarrow 58.40 \text{ sec} \rightarrow 14.726 \text{ f} \rightarrow 25.835 \text{ f/in} \quad (17.92)$

Expt. 424 : $1.50 \text{ dm}^3/\text{sec} \rightarrow 32.565 \text{ sec} \rightarrow 21.583 \text{ f} \quad 50.78 \text{ f/in} \quad (12.948)$

Expt. 425 : $3.10 \text{ dm}^3/\text{sec} \rightarrow 67.301 \text{ sec} \rightarrow 13.312 \text{ f} \quad 35.50 \text{ f/in} \quad (15.663)$

Expt. 426 : $7.463 \text{ dm}^3/\text{sec} \rightarrow 162.022 \text{ sec} \rightarrow 6.680 \text{ f} \quad 44.24 \text{ f/in} \quad (14.321)$

Expt. 427 $2.36 \text{ dm}^3/\text{sec} \rightarrow 51.235 \text{ sec} \rightarrow 16.119 \text{ f} \quad 48.85 \text{ f/in} \quad (13.335)$

Expt.	Condition	Safety	H ₂ O	Island	Ref.	BF ₃ det. in con.
422	k > 1	12.95	26.15	V ₆	H ₂ O only	"
	k = 1	12.56 ^T	"	"	"	"
423	k > 1	18.30 ²	26.17	V ₂	"	"
	k = 1	17.73 ²	"	"	"	Temp = 26°C

Instrument Check on 2-24-65 Source 10 mc

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	> 3 x 10 ⁻⁴	Meter Trip	OK	Fast Trip	OK
IC-2	> 3 x 10 ⁻⁴	Meter Trip	OK		
IC-3	Responds	Calibration	JH		
IC-4	Responds	Calibration	JH		
CRM		Meter Trip			

Preliminary Check on 2-24-65

Room 113 Pressure Differential	1.4"
Red Light On and Personnel Check	JH. CC
Scrams and Eids, Alarm Test	✓ A does not trip
Source Inserted	JH
Safety Withdrawn	Variable
Controls Set	
Reflector Water	✓ completed Variable
Moderator Water	

Expt.	Condition	Safety	H ₂ O	Island	Ref.	Core Condition
424	k > 1	13.06	26.59	V ₆	H ₂ O	BF ₃ + H ₂ O Temp = 21°C
	k = 1	12.63 ^{5.425}	26.59	V ₆	"	"
425	k > 1	15.85	26.59	V ₆	"	" B ^N (1,2,3,4,5) Lower A.
	k = 1	15.47 ^{5.375}	26.59	V ₆	"	"
426	k > 1	14.39 ⁶	26.59	V ₆	Temp. 21°C	" B ^N (1,2,4) Lower A.
	k = 1	14.24 ^{5.151}	26.59	V ₆	"	"
427	k > 1	13.50	26.59	V ₆	"	" B ^N (4) Lower A.
	k = 1	13.17 ^{.33}	26.59	V ₆	"	" B ^N (4) Lower A.

Expt. 428 2.11 $\frac{\text{dir}}{\text{sec}}$ \rightarrow 45.810 sec \rightarrow 17.377 ϕ \rightarrow 49.65 $\frac{\phi}{\text{in}}$ (12.815)

Expt. 429 2.16 $\frac{\text{dir}}{\text{sec}}$ \rightarrow 46.895 sec \rightarrow 17.108 ϕ \rightarrow 48.74 $\frac{\phi}{\text{in}}$ (13.325)

Expt. 430 3.14 $\frac{\text{dir}}{\text{sec}}$ \rightarrow 68.172 sec \rightarrow 13.189 ϕ \rightarrow 48.14 $\frac{\phi}{\text{in}}$ (13.275)

Expt. 431 3.14 $\frac{\text{dir}}{\text{sec}}$ \rightarrow 68.172 sec \rightarrow 13.189 ϕ \rightarrow 48.31 $\frac{\phi}{\text{in}}$ (13.275)

Expt. 432 1.68 $\frac{\text{dir}}{\text{sec}}$ \rightarrow 36.474 sec \rightarrow 20.125 ϕ \rightarrow 48.97 $\frac{\phi}{\text{in}}$ (13.44)

Expt. 433: Have poured ~8 liters of boiling water into core when water level was 14.03 in. softly inserted. Raised water level to 26.59 in.

Expr 428

Instrument Check on 2-25-65 Source 10mc

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	
IC-3	Responds	Calibration	JIT	
IC-4	Responds	Calibration	JIT	
CRM		Meter Trip		

Preliminary Check on 2-25-65

Room 115 Pressure Differential	1.4"
Red Light On and Personnel Check	JIT (east)
Scrams and Bleg, Alarm Reset	JIT A Responds, does not trip
Source Inserted	JIT
Safety Withdrawn	0.0
Controls Set	
Reflector Water	combined
Moderator Water	

Expr.	Condition	Safety	H ₂ O	Island	Core Condition	Temp
428	R > 1	12.99	26.60	V ₆	BF ₃ + H ₂ O only	Temp
	K = 1	12.64	26.60	V ₆	" " "	71° F (21.7°C)
429	R > 1	13.50	26.62	V ₆	BF ₃ + H ₂ O B ^N (5) INNER	
	R = 1	13.14 ⁹	26.62	V ₆	" " B ^N (5)	
430	R > 1	13.41 ²	"	"	" " B ^N (1)	
	R = 1	13.13 ⁸	"	V ₆	" " B ^N (1)	
431	R > 1	13.41 ¹	"	V ₆	" " B ^N (3)	
	R = 1	13.13 ⁸	"	V ₆	" " B ^N (3)	
432	R > 1	13.34 ⁶	"	V ₆	" " B ^N (4) Outer	
	K = 1	12.93 ⁵	"	V ₆	" " " "	
433	R > 1	12.00	26.59	V ₆	BF ₃ + H ₂ O	Temp Variable
	K = 1	12.65				
1 ⁴⁰ PM	R < 1	12.64	26.59	V ₆	" " " "	
1 ⁵⁶ PM	R < 1	12.64	"	"	" " " "	
1 ⁵² PM	R = 1	12.65	"	"	" " " "	at top of core no TTF

Expt 434 $2.77 \frac{\text{div}}{\text{dec}} \rightarrow 60.139 \rightarrow 14.425 \phi \rightarrow 94.28 \frac{\phi}{\text{in. H}_2\text{O}}$ (19.116) 4

Expt 435 $3.2 \frac{\text{div}}{\text{dec}} \rightarrow 69.475 \rightarrow 13.008 \phi \rightarrow 63.15 \frac{\phi}{\text{in.}}$ (20.534) 4

Expt 436 $1.13 \frac{\text{div}}{\text{dec}} \rightarrow 24.533 \rightarrow 25.473 \phi \rightarrow 101.53 \frac{\phi}{\text{in.}}$ (19.319) 4

Expt 437 $1.2 \frac{\text{div}}{\text{dec}} \rightarrow 26.053 \text{ sec} \rightarrow 24.625 \phi \rightarrow 34.11 \frac{\phi}{\text{in.}}$ (21.314) 4

Expt 438 CE-3 moved to a position 8" from east wall of tank.
CE-2 placed beside CE-3, walls in contact.

12 fuel plates removed from each core.

$2.08 \frac{\text{div}}{\text{dec}} \rightarrow 45.16 \text{ sec} \rightarrow 17.54 \phi \rightarrow 1.096 \frac{\phi}{\text{in.}}$ (14.70) 4

Expt 439 12 fuel plates replaced in each core.

$2.72 \frac{\text{div}}{\text{dec}} \rightarrow 59.05 \text{ sec} \rightarrow 14.61 \phi \rightarrow 1.249 \frac{\phi}{\text{in.}}$ (14.944) 4

Expt.	Condition	Safety	H ₂ O	Island	Core Condition
434	k > 1	26.00	19.21 ⁸	V ₆	H ₂ O only 12 foil plates removed.
	k = 1	"	19.065	"	"
435	k > 1	26.00	20.67 ¹	V ₃	"
	k = 1	"	20.46 ⁵	"	"
436	k > 1	26.00	19.48 ⁶	V ₇	"
	k = 1	"	19.23 ⁵	"	"
437	k > 1	26.00	21.79 ⁵	V ₂	"
	k = 1	"	21.07 ³	"	"

Instrument Check on 3-1-65 Source 10 mcV

IM-1	Low Trip	OK	Alarm Trip	OK	
IM-2			Alarm Trip		
IC-1	> 3x10 ⁻⁴	Meter Trip	OK	Fast Trip	OK
IC-2	> 3x10 ⁻⁴	Meter Trip	OK		
IC-3	Responds	Calibration	J.T.T.		
IC-4	Responds	Calibration	J.T.T.		
CRM		Meter Trip			

Preliminary Check on 3-1-65

Room 113 Pressure Differential	1.4"
Red Light On and Personnel Check	J.T.T. (East)
Scrams and Bldg. Alarm Reset	J.T.T. A. does not trip
Source Inserted	S.F.D.
Safety Withdrawn	for safety
Controls Set	
Reflector Water	0.0
Moderator Water	0.0

} Combined

Expt.	Condition	H ₂ O	CE-2 Isl.	EE-3 Island	Notes
438	k > 1	14.81 18.98	H ₂ O	H ₂ O	12 plates removed from each core
	k = 1	14.65 18.82	"	"	
439	k > 1	15.022 19.192	"	"	12 plates replaced in each core.
	k = 1	14.905 19.07	"	"	

270

Expt 440 0" Sep. , P.P. in CE-3.

$$1.37 \frac{\text{div}}{\text{sec}} \rightarrow 29.74 \text{ sec} \rightarrow 22.79 \rightarrow 1.055 \frac{\text{g}}{\text{in}} \quad (16.286)$$

Expt 441 Cores Separated $\sim \frac{5}{16}$ " , H₂O in both islands.

$$1.03 \frac{\text{div}}{\text{sec}} \rightarrow 22.36 \text{ sec} \rightarrow 26.84 \phi \rightarrow 1.551 \frac{\text{g}}{\text{in}} \quad (15.14)$$

Expt 442 1.84 $\frac{\text{div}}{\text{sec}}$ \rightarrow 39.95 sec \rightarrow ~~17.97~~ 19.00 ϕ \rightarrow 1.152 $\frac{\text{g}}{\text{in}}$ (16.385)

Expt 443 P.P. in CE-3 , 1" Sep.

$$1.84 \frac{\text{div}}{\text{sec}} \rightarrow 39.95 \text{ sec} \rightarrow \text{18.97} \rightarrow 19.00 \phi \rightarrow 59.0 \frac{\text{g}}{\text{in}} \quad (17.915)$$

Expt. 444 Have put a 3 1/4" Dia Styrofoam void in safety to simulate poison post. Put safety + void in CE-3

check critical water height with Expt. 443.

Safety + Void worth $\sim 12.5 \phi$ more than P.P. in this geometry

Expt 445 Safety + V in CE-2, P.P. in CE-3, 1" Sep.

$$2.11 \frac{\text{div}}{\text{sec}} \rightarrow 45.81 \text{ sec} \rightarrow 17.38 \phi \rightarrow 43.2 \frac{\text{g}}{\text{in}} \quad (22.589)$$

Expt 446 Have removed 12 fuel plates from each core.

$$2.47 \frac{\text{div}}{\text{sec}} \rightarrow 53.63 \text{ sec} \rightarrow 15.62 \phi \rightarrow 1.211 \frac{\text{g}}{\text{in}} \quad (15.989)$$

26)

4)

385)

915)

Expt.	Condition	H ₂ O	CE-2 Island	CE-3 Island	
440	k > 1	16.43 20.60	H ₂ O	H ₂ O + P.P.	
	k = 1	16.214 20.381	"	"	
441	k > 1	15.255 19.425	H ₂ O	H ₂ O	} Cores separated ~ 5"
	k = 1	15.032 19.255	"	"	
442	k > 1	16.495 20.665	"	"	} Cores separated ~ 1"
	k = 1	16.335 20.505	"	"	

Instrument Check on 3-2-65 Source 10 mcr

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	173 x 10 ⁻¹¹	Meter Trip	OK	Fast Trip	OK
IC-2	33 x 10 ⁻¹	Meter Trip	OK		
IC-3	Responds	Calibration	S.P.R.		
IC-4	Responds	Calibration	S.P.R.		
GRM					

Preliminary Check on 3-2-65

Room 113 Pressure Differential	1.4"
Red Light On and Personnel Check	S.P.R. C.C.
Scrams and Bldg. Alarm Reset	S.P.R. A does not trip
Source Inserted	S.P.R.
Safety Withdrawn	No safety
Controls Set	
Reflector Water	0.0 } combined
Moderator Water	0.0 }

9)

Expt.	Condition	H ₂ O	CE-2 Island	CE-3 Island	
443	k > 1	18.13 22.30	H ₂ O	H ₂ O + P.P.	} ~ 1" separation
	k = 1	17.805 21.975	"	"	
444	k = 1	18.02 22.195	H ₂ O	Safety + Void.	"
445	k > 1	22.857 27.02	Safety + V	H ₂ O + P.P.	"
	k = 1	22.455 26.625	"	"	"
446	k > 1	16.025 20.19	H ₂ O	H ₂ O	" 12 fuel plates removed from each core.
	k = 1	15.896 20.06	"	"	

272

Expt 447 12 fuel plates removed from each core. Cores spaced 2" apart.
 $1.95 \frac{\text{div}}{\text{sec.}} \rightarrow 42.34 \text{ sec} \rightarrow 18.30 \phi \rightarrow 85.1 \phi/\text{in} \quad (18.277)$

Expt 448 Have replaced 24 fuel plates.

⑦

Expt 449 P.P. in CE-3
 $1.57 \frac{\text{div}}{\text{sec.}} \rightarrow 34.09 \text{ sec} \rightarrow 20.99 \phi \rightarrow 40.4 \phi/\text{in} \quad (21.945)$

Expt 450 P.P. in CE-3; Safety + $3\frac{1}{4}$ " void in CE-2.

The top of the fuel plates reads 26.17" on the H₂O level relay.


Expt ~~449~~⁴⁵¹ Repeat 448 to check critical H₂O level.
 $1.42 \frac{\text{div}}{\text{sec.}} \rightarrow 30.83 \text{ sec} \rightarrow 22.31 \phi \rightarrow 113.8 \phi/\text{in} \quad (18.599)$

Expt 452 3" separation.
 $2.68 \frac{\text{div}}{\text{sec.}} \rightarrow 58.18 \text{ sec} \rightarrow 14.76 \phi \rightarrow 41.0 \phi/\text{in} \quad (21.82)$

Expt 453

Expt 454 Have removed 24 fuel plates.
 $1.28 \frac{\text{div}}{\text{sec.}} \rightarrow 27.79 \text{ sec} \rightarrow 23.72 \phi \rightarrow 58.6 \phi/\text{in} \quad (20.63)$

Expt.	Condition	H ₂ O	CE-2 Island	CE-3 Island	Notes
7) 447	k > 1	18.42 (22.59) 18.205	H ₂ O	H ₂ O	~ 2" separation 24 fuel plates out
	k = 1	22.37	"	"	"
448	k > 1	18.736 22.90	"	"	"
	k = 1	22.35 22.295	"	"	"
449	k > 1	26.46	"	H ₂ O + P.P.	"
	k = 1	21.775 25.94	"	"	"
450	k << 1	26.21 30.38	Safety + V.	H ₂ O + P.P.	"
451	k > 1	18.75 22.90	H ₂ O	H ₂ O	"
	k = 1	18.534 22.70	"	"	"
452	k > 1	21.56 25.73	"	"	3" separation
	k = 1	21.20 25.37	"	"	"
453	k << 1	25.82 29.99	"	H ₂ O + P.P.	"
454	k > 1	20.90 25.07	H ₂ O	H ₂ O	24 fuel plates out
	k = 1	20.495 24.66	"	"	"



274

Expr. 455 4" sep. 24 fuel plates out
 $3.03 \frac{\text{div}}{\text{sec}} \rightarrow 65.78 \text{ sec} \rightarrow 13.53 \phi \rightarrow 17.0 \frac{\phi}{\text{in}} \quad (23.33)$

Expr 456 Have replaced 24 fuel plates.

$8 \frac{\text{div}}{\text{sec}} \rightarrow -173.69 \text{ sec} \rightarrow -9.87 \phi$

$61.47 \frac{\text{div}}{\text{sec}} \rightarrow -140.47 \text{ sec} \rightarrow -13.49 \phi$

Expr 457 6" separation. V_2 placed in CE-3.

$0.94 \frac{\text{div}}{\text{sec}} \rightarrow 20.41 \text{ sec} \rightarrow 28.20 \phi \rightarrow 44.8 \frac{\phi}{\text{in}} \quad (21.88)$

Expr 458 24 fuel plates removed. V_2 in CE-3

$3.13 \frac{\text{div}}{\text{sec}} \rightarrow 67.95 \text{ sec} \rightarrow 13.22 \phi \rightarrow 49.9 \frac{\phi}{\text{in}} \quad (20.902)$

Expr 459 24 fuel plates replaced. 0 separation

$1.33 \frac{\text{div}}{\text{sec}} \rightarrow 28.88 \text{ sec} \rightarrow 23.193 \phi \rightarrow 93.5 \frac{\phi}{\text{in}} \quad (18.645)$

Instrument Check on 3-3-65 Source 10 mcV

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip
 IC-1 7.3×10^{-4} Meter Trip OK East Trip OK
 IC-2 7.3×10^{-4} Meter Trip OK
 IC-3 Responds Calibration J.T.T.
 IC-4 Responds Calibration J.T.T.
 CRM Meter Trip

Preliminary Check on 3-3-65

Room 113 Pressure Differential 1.4"
 Red Light On and Personnel Check
 Scrans and Bldg. Alarm Reset A does not trip
 Source Inserted S.F.R.
 Safety Withdrawn No safety
 Controls Set
 Reflector Water 0.0 } Combined
 Moderator Water 0.0 }

Expt.	Condition	H ₂ O	CE-2	CE-3	Separation	Notes
			Island	Island		
454 455	k > 1	23.86 28.07	H ₂ O	H ₂ O	4" separation	24 fuel plates removed.
	k = 1	23.065 27.23	"	"	"	
455 456	k < 1	25.87 30.04	"	"	"	24 fuel plates replaced.
456 457	k > 1	22.30 26.47	H ₂ O	V ₂	6" separation	
	k = 1	21.67 25.84	"	"	"	
457 458	k > 1	21.077 25.247	"	"	"	24 fuel plate removed.
	k = 1	20.814 24.97	"	"	"	"
458 459	R > 1	18.81 22.98	Safety + V	H ₂ O + P.P.	0 sep.	24 fuel plates in.
	R = 1	18.56 22.732	"	"	"	"

CE-3 removed. CE-2 placed on pedestal in center of tank

Expt. 460

H₂O level relay reads 21.76" when H₂O is at top
of fuel plates V₃ 12 fuel plates removed.
- 10.03 $\frac{\text{diag}}{\text{sec}}$ \rightarrow 217.76 sec. \rightarrow ~~5.17~~ - 7.34 ϕ

Expt. 461

V₆ 12 fuel plates removed .29
2.04 $\frac{\text{diag}}{\text{sec}}$ \rightarrow 44.29 sec \rightarrow 17.77 ϕ \rightarrow 61.28 ϕ/in (20.91)

Expt. 462

V₄ 12 fuel plates removed .44
1.58 $\frac{\text{diag}}{\text{sec}}$ \rightarrow 34.30 sec \rightarrow 20.91 ϕ \rightarrow 47.52 ϕ/in (22.62)

CE-2

277

Instrument Check on 3-5-65 Source 10mc K

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	7.3×10^{-4}	Meter Trip	OK	East Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Responds	Calibration	SfR.		
IC-4	Responds	Calibration	SfR.		
CRM		Meter Trip			

Preliminary Check on 3-5-65

Room 113 Pressure Differential 1.4"

Red Light On and Personnel Check SfR. + C.C.

Scrams and Bldg. Alarm Reset A does not Trip

Source Inserted SfR.

Safety Withdrawn

Controls Set

Reflector Water } Combined

Moderator Water }

Expt.	Condition	H ₂ O	Safety	Island	
460	k < 1	26.79 26.55	26.00	V ₃	12 fuel plates removed
461	k > 1	21.06 20.82	26.02	V ₆	" "
	k = 1	20.77 20.53	26.02	V ₆	" "
462	k > 1	22.91 22.67	26.01	V ₄	" "
	k = 1	22.47 22.23	"	"	" "

~~Reflected GE 3~~



Red values are converted to correspond to a reading of 22.00" at top of fuel plates.

463	V_5	12 fuel plates removed	$2.76 \frac{\text{dir}}{\text{sec}} \rightarrow 59.92 \text{ sec} \rightarrow 14.46 \phi \rightarrow 32.86 \frac{\text{g}}{\text{in}}$	(21.03)
464	V_7	12 fuel plates removed	$1.41 \frac{\text{dir}}{\text{sec}} \rightarrow 30.61 \text{ sec} \rightarrow 22.41 \phi \rightarrow 44.82 \frac{\text{g}}{\text{in}}$	(21.12)
465	Replaced 12 fuel plates, V_2		$3.74 \frac{\text{dir}}{\text{sec}} \rightarrow 81.20 \text{ sec} \rightarrow 11.59 \phi \rightarrow 23.18 \frac{\text{g}}{\text{in}}$	(21.75)
466	V_6		$3.96 \frac{\text{dir}}{\text{sec}} \rightarrow 85.97 \text{ sec} \rightarrow 11.10 \phi \rightarrow 39.64 \frac{\text{g}}{\text{in}}$	(21.55)
467	V_5		$1.24 \frac{\text{dir}}{\text{sec}} \rightarrow 26.92 \text{ sec} \rightarrow 24.17 \phi \rightarrow 38.37 \frac{\text{g}}{\text{in}}$	(21.85)
468	V_4		$3.04 \frac{\text{dir}}{\text{sec}} \rightarrow 66.00 \text{ sec} \rightarrow 13.50 \phi \rightarrow 4.87 \frac{\text{g}}{\text{in}}$	(24.55)

Removed CE-2. Replaced CE-3.

H₂O Selsyn reads 21.84" when water at top of fuel plates. Reset to

469 read 22.00" when water at top of fuel plates.

469	V_4	12 fuel plates removed	$3.98 \frac{\text{dir}}{\text{sec}} \rightarrow 86.41 \text{ sec} \rightarrow 11.06 \phi \rightarrow 92.17 \frac{\text{g}}{\text{in}}$	(19.59)
-----	-------	------------------------	--	---------

CE-2

279

Instrument Check on 3-8-65 Source 10mc K

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip _____
 IC-1 $> 3 \times 10^{-4}$ Meter Trip OK Fast Trip OK
 IC-2 $> 3 \times 10^{-4}$ Meter Trip OK
 IC-3 Responds Calibration S.P.R.
 IC-4 Responds Calibration S.P.R.
 CRM Meter Trip _____

Preliminary Check on 3-8-65

Room 113 Pressure Differential 1.5"
 Red Light On and Personnel Check S.P.R. C.C.
 Scrams and Bldg. Alarm Reset S.P.R. Alarm does not trip
 Source Inserted S.P.R.
 Safety Withdrawn _____
 Controls Set _____
 Reflector Water } Combined
 Moderator Water }

CE-2 Core

Eyes	Condition	H ₂ O	Safety	Island	
463	k > 1	21.25 21.01	26.00	V ₅	12 fuel plates removed
	k = 1	20.81 20.57	26.00	"	
464	k > 1	21.37 21.13	"	V ₇	"
	k = 1	20.87 20.63	"	"	
465	k > 1	22.08 21.84	"	"	12 fuel plates replaced
	k = 1	21.57 21.33	"	"	
466	k > 1	21.72 21.48	"	V ₆	"
	k = 1	21.44 21.20	"	"	
467	k > 1	22.24 22.00	"	V ₅	"
	k = 1	21.37 21.13	"	"	
468	k > 1	26.40 26.16	"	V ₄	"
	k = 1	23.59 23.35	"	"	

Removed CE-2 and placed CE-3 on pedestal in center of tank.

469	k > 1	19.65 19.33	26.00	V ₄	12 fuel plates removed
	k = 1	19.33	"	"	"

- 470 V_5 12 fuel plates removed. ^{.205}
 $1.78 \text{ dir/dec} \rightarrow 38.65 \text{ sec} \rightarrow 19.40 \text{ q} \rightarrow 94.63 \text{ q/in} \quad (18.977)$
- 471 H_2O Temp $70^\circ F$ 14.40 hrs. ^{.18}
 $2.4 \text{ dir/dec} \rightarrow 52.11 \text{ sec} \rightarrow 15.93 \text{ q} \rightarrow 88.50 \text{ q/in} \quad (18.91)$
- 472 B^N SS Strip #1 placed in I.A. ^{.17}
 $2.36 \text{ dir/dec} \rightarrow 51.24 \text{ sec} \rightarrow 16.12 \text{ q} \rightarrow 94.82 \text{ q/in} \quad (19.14)$
- 473 B^N SS Strip #1, 2 in I.A. ^{.13}
 $3.72 \text{ dir/dec} \rightarrow 70.76 \text{ sec} \rightarrow 11.64 \text{ q} \rightarrow 89.54 \text{ q/in} \quad (19.35)$
- 474 B^N SS Strip #1, 2, 3 in I.A. ^{.14}
 $3.74 \text{ dir/dec} \rightarrow 81.20 \text{ sec} \rightarrow 11.59 \text{ q} \rightarrow 82.79 \text{ q/in} \quad (19.59)$
- 475 B^N SS Strip #1, 2, 3, 4 in I.A. ^{.14}
 $4.18 \text{ dir/dec} \rightarrow 90.75 \text{ sec} \rightarrow 10.65 \text{ q} \rightarrow 76.07 \text{ q/in} \quad (19.86)$
- 476 B^N SS Strip #1, 2, 3, 4, + 5 in I.A. ^{.15}
 $4.86 \text{ dir/dec} \rightarrow 105.51 \text{ sec} \rightarrow 9.48 \text{ q} \rightarrow 63.20 \text{ q/in} \quad (20.18)$
- 477 5 B^N SS Strip + 20 SS Strip in I.A. ^{.50}
 $1.66 \text{ dir/dec} \rightarrow 36.04 \text{ sec} \rightarrow 20.27 \text{ q} \rightarrow 40.54 \text{ q/in} \quad (20.84)$

CEC(3)

Expt.	Condition	H ₂ O	Safety	Island		
77)	470	k > 1	19.08	26.00	V ₅	12 fuel plates removed
		k = 1	18.875	26.00	V ₅	" " " "
1)	471	k > 1	19.00	26.00	V ₆	" "
		k = 1	18.82	"	"	" "
2)	472	k > 1	19.22	"	"	" B ^N SS-#1 IA.
		k = 1	19.05	"	"	" "
3)	473	k > 1	19.41	"	"	" B ^N #2, 3 IA.
		k = 1	19.28	"	"	" "
4)	474	k > 1	19.66	"	"	" B ^N #2, 3, 4 IA.
		k = 1	19.52	"	"	" "
5)	475	k > 1	19.93	"	"	" B ^N #2, 3, 4 IA.
		k = 1	19.79	"	"	" "
6)	476	k > 1	20.22	"	"	" B ^N #2, 3, 4, 5 IA.
		k = 1	20.07	"	"	" "
34)	477	k > 1	21.09	"	"	" 5 B ^N IA. + 20 SS.
		k = 1	20.59	"	"	" " "

282

Washed out relay tube with alcohol.

478

 $2.6 \frac{\text{div}}{\text{sec}} \rightarrow 56.45 \text{ sec} \rightarrow 15.08 \phi \rightarrow 31.42 \frac{\phi}{\text{in}} \quad (21.84)$

479

Change in reading from Expts 477 to 478 due to alcohol in relay tube. Drained tube and rinsed with dist. H_2O .
Set relay to read 22.00" at top of fuel plate.

H_2O Temp = 70°F at 1140 hrs.

 $5.82 \frac{\text{div}}{\text{sec}} \rightarrow 126.36 \text{ sec} \rightarrow 8.20 \phi \rightarrow 82 \frac{\phi}{\text{in}} \quad (20.72)$

480

12 fuel plates replaced; V_6 ; 5 B^N SS strips + 20 SS strips

 $1.57 \frac{\text{div}}{\text{sec}} \rightarrow 34.09 \text{ sec} \rightarrow 20.99 \phi \rightarrow 31.80 \frac{\phi}{\text{in}} \quad (21.78)$

481

V_6 ; 5 B^N SS strips + 10 SS strips

 $5.14 \frac{\text{div}}{\text{sec}} \rightarrow 111.59 \text{ sec} \rightarrow 9.06 \phi \rightarrow 90.6 \frac{\phi}{\text{in}} \quad (21.12)$

$(75.5 \frac{\phi}{\text{in}})$

482

V_6 5 B^N SS strips

 $4.20 \frac{\text{div}}{\text{sec}} \rightarrow 91.19 \text{ sec} \rightarrow 10.62 \phi \rightarrow 88.5 \frac{\phi}{\text{in}} \quad (20.91)$

$(66.38 \frac{\phi}{\text{in}})$

483

V_6 4 B^N SS strips.

 $2.74 \frac{\text{div}}{\text{sec}} \rightarrow 59.49 \text{ sec} \rightarrow 14.54 \phi \rightarrow 96.93 \frac{\phi}{\text{in}} \quad (20.50)$

484

V_6 3 B^N SS strips

 $5.11 \frac{\text{div}}{\text{sec}} \rightarrow 110.94 \text{ sec} \rightarrow 9.11 \phi \rightarrow 113.87 \frac{\phi}{\text{in}} \quad (20.18)$

485

V_6 2 B^N SS strips

Instrument Check on 3-9-65 Source 10mcf

4)	11-1	Low Trip	OK	Alarm Trip	OK	
	11-2			Alarm Trip		
	11-1	2×10^{-4}	Meter Trip	OK	East Trip	OK
	11-2	2.3×10^{-4}	Meter Trip	OK		
	11-3	Responde	Calibration	S/P.R.		
	11-4	Responde	Calibration	S/P.R.		
	11M		Meter Trip			

Preliminary Check on 3-9-65

Room 113 Pressure Differential 1.5"
 Red Light On and Personnel Check S/P.R. + C.C.
 Scrums and Bldg. Alarm Reset S/P.R. A does not trip
 Source Inserted S/P.R.
 Safety Withdrawn _____
 Controls Set _____
 Reflector Water _____
 Moderator Water _____ } Combined

Expt.	Condition	H ₂ O	Safety	Island	
478	b > 1	22.16	26.00	V₆	12 fuel plate removed B^NSS #1-5 + 20SS
	b = 1	21.68	"	"	in I.A.
479	b > 1	20.77	26.00	"	12 fuel plates removed B ^N SS #1-5 + 20SS
	b = 1	20.75	"	"	"
480	b > 1	22.11	26.00	"	12 fuel plates replaced B ^N SS #1-5
	b = 1	21.45	"	"	+ 20SS strip I.A.
481	K > 1	21.17	"	"	5 B ^N SS + 10SS I.A.
18)	b = 1	21.07 (21.05)	"	"	"
482	b > 1	20.87	"	"	5 B ^N SS I.A.
	b = 1	20.75 (20.71)	"	"	"
483	b > 1	20.57	26.00	"	B ^N SS #1-4 I.A.
	b = 1	20.42	"	"	"
484	b > 1	20.22	"	"	" #1-3 I.A.
	b = 1	20.14	"	"	"
485	b > 1	"	"	"	" #1-2 I.A.

284

Temp = 70°F

485

 V_6 , 2 B^N SS strips
 4.7 $\frac{\text{dir}}{\text{sec}} \rightarrow 102.04 \text{ sec} \rightarrow 9.72 \text{¢} \rightarrow 121.5 \frac{\text{¢}}{\text{in}} \quad (19.83)$

486

 V_6 , 1 B^N SS strips
 3.15 $\frac{\text{dir}}{\text{sec}} \rightarrow 68.39 \text{ sec} \rightarrow 13.16 \text{¢} \rightarrow 109.67 \frac{\text{¢}}{\text{in}} \quad (19.61)$

487

 V_6 , No strips
 3.78 $\frac{\text{dir}}{\text{sec}} \rightarrow 82.07 \rightarrow 11.50 \text{¢} \rightarrow 127.78 \frac{\text{¢}}{\text{in}} \quad (19.37)$

488

 V_6 , No strips, safety control
 1.64 $\frac{\text{dir}}{\text{sec}} \rightarrow 35.61 \text{ sec} \rightarrow 20.43 \text{¢} \rightarrow 49.83 \frac{\text{¢}}{\text{in}} \quad (12.565)$

489

 V_6 , 1 B^E SS strip I.A.
 2.88 $\frac{\text{dir}}{\text{sec}} \rightarrow 62.53 \text{ sec} \rightarrow 14.03 \text{¢} \rightarrow 48.38 \frac{\text{¢}}{\text{in}} \quad (13.35)$

490

 V_6 , B^E SS strips #'s 1 & 2 I.A.
 4.49 $\frac{\text{dir}}{\text{sec}} \rightarrow 97.48 \text{ sec} \rightarrow 10.08 \text{¢} \rightarrow 41.14 \frac{\text{¢}}{\text{in}} \quad (14.378)$

491

 V_6 , B^E SS strips #'s (1, 2, 3) I.A.
 1.15 $\frac{\text{dir}}{\text{sec}} \rightarrow 24.97 \text{ sec} \rightarrow 25.23 \text{¢} \rightarrow 34.56 \frac{\text{¢}}{\text{in}} \quad (15.791)$

492

 V_6 , B^E SS strips #'s (1, 2, 3, 4) I.A.
 3.86 $\frac{\text{dir}}{\text{sec}} \rightarrow 83.80 \text{ sec} \rightarrow 11.32 \text{¢} \rightarrow 28.30 \frac{\text{¢}}{\text{in}} \quad (17.10)$

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip
 93) IC-1 > 3x10⁻¹¹ Meter Trip OK Fast Trip OK
 IC-2 > 3x10⁻¹¹ Meter Trip OK
 IC-3 Responds Calibration S/O.
 IC-4 Responds Calibration S/O.
 1) CRM Meter Trip

Preliminary Check on 3-10-65

Room 113 Pressure Differential 1.5"
 Red Light On and Personnel Check S/O.
 7) Scrams and Bldg, Alarm Reset S/O. A does not trip
 Source Inserted S/O.
 Safety Withdrawn
 Controls Set
 05 Reflector Water } Combined.
 Moderator Water }

Exp.	Condition	H ₂ O	Safety	Island	
5) 485	k > 1	19.87	26.00	V ₆	B ^N SS #1-2 I.A.
	k = 1	19.79	"	"	" " "
486	k > 1	19.67	"	"	B ^N SS #1 I.A.
	k = 1	19.55	"	"	" " "
7) 487	k > 1	19.41	"	"	No Strip.
	k = 1	19.32	"	"	" " "
11) 488	k > 1	26.56	12.71	"	"
	k = 1	"	12.30	"	"
489	k > 1	"	13.50	"	B ^E SS Strip #1 I.A.
1) 490	k > 1	"	13.21	"	B ^E SS Strip #1 I.A.
490	k > 1	"	14.50	"	B ^E SS Strip #1-2 I.A.
	k = 1	"	14.25 ⁵	"	" " "
491	k > 1	"	16.15 ⁶	"	B ^E SSS # (1,2,3) I.A.
	k = 1	"	15.42 ⁶	"	" " "
492	k > 1	"	17.30	"	" #0 (1,2,3,4) I.A.
	k = 1	"	16.90	"	" " "

286

493 V_6 , B^E SS strips #1a (1,2,3,4,5) I.A.
 $4.96 \frac{\text{div}}{\text{dec.}} \rightarrow 107.69 \text{ sec} \rightarrow 9.32 \phi \rightarrow 18.64 \frac{\phi}{\text{in}}$ (19.25)

494 V_6 , B^E SS strips #1a (1,2,3,4,5,6) I.A.
 $-71.2 \frac{\text{div}}{\text{dec.}} \rightarrow -1545.8 \text{ sec} \rightarrow -0.86 \phi$

495 V_6 , B^E SS strips #1a (1,2) adjacent plots in I.A.
 $2.67 \frac{\text{div}}{\text{dec.}} \rightarrow 57.97 \text{ sec} \rightarrow 14.80 \phi \rightarrow 42.29 \frac{\phi}{\text{in}}$ (13.845)

496 V_6 , B^E SS strips #1a (1,2) 5 fuel plates apart I.A.
 $2.91 \frac{\text{div}}{\text{dec.}} \rightarrow 63.18 \text{ sec} \rightarrow 13.93 \phi \rightarrow 43.53 \frac{\phi}{\text{in}}$ (14.21)

497 V_6 , B^E SS strips #1a (1+2) 10 fuel plates apart I.A.
 $1.85 \frac{\text{div}}{\text{dec.}} \rightarrow 40.17 \text{ sec} \rightarrow 18.93 \phi \rightarrow 43.02 \frac{\phi}{\text{in}}$ (14.40)

498 V_6 , B^E SS strips #1a (1+2) 15 fuel plates apart I.A.
 $2.33 \frac{\text{div}}{\text{dec.}} \rightarrow 50.59 \text{ sec} \rightarrow 16.26 \phi \rightarrow 42.23 \frac{\phi}{\text{in}}$ (14.388)

499 V_6 , B^E SS strips #1a (1+2) 25 fuel plates apart I.A.
 $2.18 \frac{\text{div}}{\text{dec.}} \rightarrow 47.33 \text{ sec} \rightarrow 17.00 \phi \rightarrow 42.5 \frac{\phi}{\text{in}}$ (14.42)

500 V_6 , B^E SS strips #1a (1+2) 45 fuel plates apart I.A.
 $2.26 \frac{\text{div}}{\text{dec.}} \rightarrow 49.07 \text{ sec} \rightarrow 16.60 \phi \rightarrow 40.49 \frac{\phi}{\text{in}}$ (14.413)

Expt	Condition	H ₂ O	Safety	Island		
493	k > 1	26.56	19.50	V ₆	B ^E 555	#0 (1,2,3,4,5) I.A.
	k = 1	"	19.00	"	"	"
494	k < 1	"	26.00	"	"	#0 (1,2,3,4,5,6) I.A.
495	k > 1	"	14.02	"	B ^E 555	(1-2) adj. I.A.
	k = 1	"	13.67	"	"	"
496	k > 1	"	14.37	"	"	I.A.
	k = 1	"	14.05	"	"	"

Instrument Check on 3-11-64 Source 10mcY

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	> 3x10 ⁻⁴	Meter Trip	OK	Fast Trip	OK
IC-2	> 3x10 ⁻⁴	Meter Trip	OK		
IC-3	Responds	Calibration	S.F.R.		
IC-4	Responds	Calibration	S.F.R.		
CRM		Meter Trip			

Preliminary Check on 3-11-64

Room 113 Pressure Differential	1.6
Red Light On and Personnel Check	S.F.R. & C.C.
Scrams and Bldg. Alarm Reset	S.F.R.
Source Inserted	S.F.R.
Safety Withdrawn	
Controls Set	
Reflector Water	} Combined
Moderator Water	

497	k > 1	26.53	14.62	V ₆	B ^E 555	(1+2) I.A.
	k = 1	"	14.18	"	"	"
498	k > 1	"	14.58	"	"	"
	k = 1	"	14.19 ⁵	"	"	"
499	k > 1	"	14.62	"	"	"
	k = 1	"	14.22	"	"	"
500	k > 1	"	14.61	"	"	"
	k = 1	"	14.20	"	"	"

288

- 501 V_6 , B^E SS strips # (1+2) 180° apart I.A. $.182$
 $6.1 \frac{\text{div}}{\text{sec}} \rightarrow 132.44 \text{ sec} \rightarrow 7.89\phi \rightarrow 43.35 \phi/\text{in} \quad (14.329)$
- 502 V_6 , No strips $.35$
 $2.1 \frac{\text{div}}{\text{sec}} \rightarrow 45.59 \text{ sec} \rightarrow 17.43\phi \rightarrow 49.80 \phi/\text{in} \quad (12.465)$
- 503 V_6 , B^E SS strip #1 O.A. $.302$
 $3.00 \frac{\text{div}}{\text{sec}} \rightarrow 65.13 \text{ sec} \rightarrow 13.63\phi \rightarrow 45.13 \phi/\text{in} \quad (12.939)$
- 504 V_6 , B^E SS strips #1/2 (1+2) O.A. $.22$ 180° apart
 $4.12 \frac{\text{div}}{\text{sec}} \rightarrow 89.45 \text{ sec} \rightarrow 10.77\phi \rightarrow 48.95 \phi/\text{in} \quad (13.49)$
- 505 V_6 , B^E SS strips #1/2 (2,3,4) O.A. $.57$ 90° apart
 $1.34 \frac{\text{div}}{\text{sec}} \rightarrow 29.09 \text{ sec} \rightarrow 23.09\phi \rightarrow 40.51 \phi/\text{in} \quad (14.875)$
- 506 V_6 , B^E SS strips #1/2 (1-6) O.A. $.53$
 $2.1 \frac{\text{div}}{\text{sec}} \rightarrow 45.59 \text{ sec} \rightarrow 17.43\phi \rightarrow 32.89 \phi/\text{in} \quad (16.235)$
- 507 V_6 , B^E SS strips #1/2 (1-8) O.A. $.577$
 $2.94 \frac{\text{div}}{\text{sec}} \rightarrow 63.83 \rightarrow 13.83\phi \rightarrow 23.97 \phi/\text{in} \quad (18.884)$
- 508 V_6 , B^E SS strips #1/2 (1-10) O.A. $.81$ > 30 plates apart
 $3.62 \frac{\text{div}}{\text{sec}} \rightarrow 78.59 \text{ sec} \rightarrow 11.88\phi \rightarrow 14.67 \phi/\text{in} \quad (20.78)$
- 509 V_6 , B^E SS strips #1/2 (1-11) O.A. $.299$ > 30 plates apart
 $26.05 \frac{\text{div}}{\text{sec}} \rightarrow 565.57 \text{ sec} \rightarrow 2.17\phi \rightarrow 0.73 \phi/\text{in} \quad (24.01)$
- H_2O Temp = $70^\circ F$ at 1400 hrs.
- 510 V_6 , No strips $.10$
 $3.44 \frac{\text{div}}{\text{sec}} \rightarrow 74.69 \text{ sec} \rightarrow 12.33\phi \rightarrow 123.3 \phi/\text{in} \quad (19.33)$
- 511 V_7 $.09$
 $4.22 \frac{\text{div}}{\text{sec}} \rightarrow 91.62 \text{ sec} \rightarrow 10.58\phi \rightarrow 117.56 \phi/\text{in} \quad (19.55)$
- 512 V_5 $.13$
 $2.56 \frac{\text{div}}{\text{sec}} \rightarrow 55.58 \text{ sec} \rightarrow 15.24 \rightarrow 117.23 \phi/\text{in} \quad (19.48)$

	Expt.	Condition	H ₂ O	safety	Island		
9)	501	b > 1	26.53	14.42	V ₆	B ^E 555 (1+2)	I.A.
		b = 1	"	14.23 ⁵	"	"	"
6.5)	502	b > 1	"	12.64	"	No Strips	
		b = 1	"	12.29 _{1.75}	"	"	"
9)	503	b > 1	"	13.09	"	B ^E 555 #1	O.A.
		b = 1	"	12.78 ⁸	"	"	"
7)	504	b > 1	"	13.60	"	" # (1+2)	"
		b = 1	"	13.38	"	"	"
7.5)	505	b > 1	"	15.16	"	" # ₀ (1,2,3,4)	"
		b = 1	"	14.59	"	"	"
3.5)	506	b > 1	"	16.50	"	" # ₂ (1-6)	"
		b = 1	"	15.97	"	"	"
8.4)	507	b > 1	"	18.37 ²	"	" # ₂ (1-8)	"
		b = 1	"	17.79 ⁵	"	"	"
8)	508	b > 1	"	21.32	"	" # ₂ (1-10)	"
		b = 1	"	20.51	"	"	"
9.1)	509	b > 1	"	26.00	"	" # ₂ (1-11)	"
		b = 1	"	23.01	"	"	"
3.5)	510	b > 1	19.40	26.00	"	No Strips	
		b = 1	19.30	"	"	"	"
	511	b > 1	19.59	"	V ₇	"	"
5)		b = 1	19.50	"	"	"	"
	512	b > 1	19.55	"	V ₅	"	"
8)		b = 1	19.42	"	"	"	"
	513	b > 1	"	"	V ₄	"	"

~~Discard~~ Discard on H₂O safety broke.

290

Replaced wire on relay water level indicator.
 Checked and reset relay to read 22.00" at top of fuel plates.

513

 V_4

$$4.16 \frac{\text{dis}}{\text{sec}} \rightarrow 90.32 \text{ sec} \rightarrow 10.69 \overset{.10}{\text{ft}} \rightarrow 106.9 \text{ ft/in} \quad (20.12)$$

514

 V_3

$$2.44 \frac{\text{dis}}{\text{sec}} \rightarrow 52.97 \text{ sec} \rightarrow 15.76 \overset{.265}{\text{ft}} \rightarrow 59.47 \text{ ft/in} \quad (20.968)$$

515

 V_2

$$4.15 \frac{\text{dis}}{\text{sec}} \rightarrow 90.10 \text{ sec} \rightarrow 10.71 \overset{.15}{\text{ft}} \rightarrow 71.40 \text{ ft/in} \quad (22.00)$$

516

 V_1

$$1.12 \frac{\text{dis}}{\text{sec}} \rightarrow 24.32 \text{ sec} \rightarrow 25.61 \overset{3.39}{\text{ft}} \rightarrow 7.55 \text{ ft/in} \quad (24.15)$$

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip _____
 IC-1 $> 3 \times 10^{-4}$ Meter Trip OK Fast Trip OK
 IC-2 $> 3 \times 10^{-4}$ Meter Trip OK
 IC-3 Responds Calibration S/R
 IC-4 Responds Calibration S/R
 CRM Meter Trip _____

Preliminary Check on 3-12-65

Room 113 Pressure Differential 1.6"
 Red Light On and Personnel Check S/R. + e.c.
 Scrums and Bldg. Alarm Reset S/R.
 Source Inserted S/R.
 Safety Withdrawn _____
 Controls Set _____
 Reflector Water _____ } Combined
 Moderator Water _____ }

Expt	Condition	H ₂ O	Safety	Island
513	k > 1	20.17 ^(20.18)	26.00	V ₄
	k = 1	20.07	"	"
514	k > 1	21.10	"	V ₃
	k = 1	20.83 ⁵	"	"
515	k > 1	22.09	"	V ₂
	k = 1	21.94	"	"
516	k > 1	26.37	"	V ₁
	k = 1	22.99	"	"
517	k << 1	26.37	"	H ₂ O only

5 IC-3
 M → CI IC-2
 ~1 IC-2

Expt #	Page #	SPN #	R	Safety	Mod #20	Island	Ch. W.	Bkg	Del.	Disc	M	Burst width	Cps	KV	I ma.	I μ a	Cycles	2 out	2
309	227	212	R<1	26.00	26.11	V ₁	160	4	8	4	1/2	10 ³	30	150	0.91	3	24003	-219.9	21
313	231	213	R=1	21.49	26.08	V ₂	160	2	8	4	1/2	10 ³	35	150	1.0	6	—	—	—
314	231	214	R<1	0	26.08	V ₂	20	8	32	4	1/2	630	210	150	1.03	20	657975	-1938	20
315	231	215	R=1	21.35	26.25	V ₂	160	7	8	4	1/2	10 ³	35	150	1.0	6	30909	-181	177
316	231	216	R<1	10.00	26.09	V ₂	40	8	16	4	1/2	630	120	150	.98	10	310000	-1028	104
317	233	217	R<1	10.00	26.15	W	40	8	16	4	1/2	630	120	150	.97	10.5	360 mtr	-1269	130
318	233	218	R<1	26.00	26.17	W	80	8	16	4	1/2	1000	71	150	.97	10	103653	-502	49
319	233	219	R<1	10.00	26.01	V ₃	40	8	16	4	1/2	630	120	150	.97	10	300,000	-970	97
322	233	220	R<1	10.00	26.18	V ₁	40	8	16	4	1/2	630	120	150	.97	10	340 mtr	-1091	112
323	233	221	R<1	10.00	26.09	V ₅	40	8	16	4	1/2	630	120	150	.99	12	300 mtr	-687	66
328	235	222	R<1	10.00	26.18	V ₆	80	8	16	4	1/2	1000	70	150	.98	11	140 mtr	-533	54
329	235	223	R<1	0.0	27.33	V ₆	40	4	32	4	1/2	10 ³	120	150	.90	10	420000	1301	131
330	237	224	R<1	out P.P.in	26.75	PP +V ₅	40	4	32	4	1/2	10 ³	120	150	.90	12	250000	837	83
331	237	225	R<1	10.00	26.20	V ₇	40	4	32	4	1/2	10 ³	120	150	.93	12	170000	493	47
333	237	226	R<1	0	26.25	V ₂	40	4	32	4	1/2	10 ³	120	150	.94	12	290000	1033	110
334	237	227	R<1	out	26.28	P.P	20	8	32	4	1/2	630	220	150	.93	16	620000	1841	18
335	237	228	R<1	out	26.34	P.P +V ₂	40	8	16	4	1/2	630	120	150	1.02	13	220000	1548	15
346	241	229	R=1	21.35	26.34	V ₆	160	2	16	4	1/2	2500	34	150	1.04	16	30,000	-192	185
348	241	230	R<1	13.60	26.34	V ₆	80	8	16	4	1/2	1000	70	150	1.07	13	170000	-559	55
362	246	231	R<1	13.58	26.21	V ₆	80	4	16	4	1/2	1000	70	150	1.05	16	100,000	-423	42
371	249	232	R<1	19.81	26.14	V ₂	40	4	32	4	1/2	1000	120	148	1.02	18	266766	-761	73
372	249	233	R<1	19.81	26.56	V ₂	40	4	32	4	1/2	1000	120	146	1.01	18	160,000	-568	55
373	249	234	R<1	19.81	26.28	V ₂	80	4	16	4	1/2	1000	70	145	1.01	10	60,000	-386	37
375	249	235	R<1	19.81	26.42	V ₂	160	2	16	4	1/2	2000	32	145	0.98	8	60,000	-246	24
379	251	236	R<1	19.81	26.26	V ₂	80	4	16	4	1/2	1000	70	143	1.05	10	200,000	-673	67
380	251	237	R<1	19.81	26.36	V ₂	40	4	32	4	1/2	1400	120	148	1.02	23	340,000	-1444	147
386	253	238	R<1	19.81	26.34	V ₂	160	2	16	4	1/2	2000	32	150	1.1	15	60,000	-517	51
387	253	239	R<1	19.81	26.34	V ₂	80	4	16	4	1/2	1000	70	150	1.1	14	127,845	-582	57
388	253	240	R<1	19.81	26.35	V ₂	40	4	32	4	1/2	1400	120	150	1.1	30	230,000	-725	71

Acorn
12-16-70

$\frac{1}{4} \times 3"$
Boral
Dist S

#	λ_{cal}	$\frac{3}{2} \lambda_c$	S	S
9	217±1	1.23	2.23	
-	-	-	-	6 9/4
38	208±9	11.76	10.76	6 9/8
1	177±1	1	0	5 1/2
28	1046±5	5.91	4.91	5 1/8
69	1306±7	7.38	6.38	"
12	495±2	2.80 ± 0.03	1.80	"
10	972±4	5.49	4.49	"
91	1125±5	6.35	5.35	"
87	660±4	3.72	2.72	"
33	548±3	3.09	2.09	"
01	1317±8	7.93	6.43	"
37	830±3	4.68	3.68	"
23	470±3	2.65	1.65	"
33	1108±5	6.25	5.25	"
11	1846±8	10.41	9.41	"
48	1547±7	8.73	7.73	"
2	185±1	1	90 S.S. Stripes (inner annulus)	
59	559±2	3.02	"	
8	425±2	2.80 ± 0.18	15 S.S. St. (CA) 45 S.S. (EA)	
1	735±3	4.15 ± 0.18	3 1/4" Steel Ref. 1/2 element	
8	555±2	3.13 ± 0.14	3 1/4" " " "	
1	375±1	2.12 ± 0.09	2 3/4" " " "	
1	248±1	1.40 ± 0.06	3 3/4" " " "	
?	678±2	3.24 ± 0.16	6 1/4" " " around 180°; 3 1/4" Steel Ref. around other 180°	
4	1470±10	7.03 ± 0.38	3 1/4" 360°	
7	525±2	2.46 ± 0.13	3 1/4" Steel 360° + (4" lead + 4" lead bricks) 180° of core.	
2	577±2	2.76 ± 0.14	3 1/4" Steel 360° + (4" lead + 2" lead bricks) 180° of core	
5	710±10	3.40 ± 0.21	3 1/4" Steel 360° + 4" lead 180°	

← +12.3 + 49 ⇒ 1.15

EPR 374
 From diff. with curve for project
 22.109" → 19.51" = 18.94
 0.1895 = $\frac{1}{10} - 1 = \frac{248}{10} - 1$

$\lambda_c = 209 \pm 10$
 determined from EPR's 374 & 375

Expt #	Page #	SPH #	K	Safety	Mod H ₂ O	Island	ch. w.	Reg	Del	Disc	M	Band width	cps	KV	I ma	I ma	cycles	Rest	
391	255	244	K<1	26.00	26.34	V ₂	20	4	64	4	1/2	1400	180	150	1.06	31	130,000	-2533	✓
392	255	242	K<1	0.00	26.31	V ₂	20	4	64	4	1/2	1400	180	148	1.06	31	130,000	-4828	✓
394	255	243	K<1	19.81	26.32	V ₂	40	4	32	4	1/2	1400	110	148	1.23	30	300,000	-1290	12
395	255	244	K<1	19.81	26.31	V ₂	40	4	32	4	1/2	1400	110	150	1.1	26	200,000	-666	66
400	257	245	K<1	0.00	26.35	H ₂ O	20	4	64	4	1/2	1400	180	150	1.13	50		-2181	22
418	263	246	K<1	26.00	26.42	V ₆	10	4	128	4	1/2	1400	240	150	1.16	65	1,539,607		28

at 2 cal 7/20
533

528

90 1285 ± 5 6.15 ± .32
1/4 360

6 665 ± 3 3.18 ± .17
1/4 180

81 2235 ± 14
2700 ± 24 13.40 ± .74

Safety 0.0 H₂O only.
Cd sheet around core

1.5

3.54

12.5
9

15.2

5.5

16
10

29

300

Page

HFIRCE-3

3 U foil calibration of counting system