

BOOK59R

Notes:

"CE-2 1961, 62" on spine

Blank pages: inside front cover sheets, 2, 4, 6, 22, 96, 218, 281, inside back cover sheets

-page 56 has small sheet attached

-pages 97, 101, and 248 has graph sheet attached on each

-pages 109, 149, 215, 217(2), 245, 247 have a sheet attached to each

-page 152 has (8.5x11) sheet attached

-pages 204/205 has (8.5x11) sheet between pages

-page 221 has long thin sheet attached

Scanned by:

Sheila Finch

RSICC /Oak Ridge National Lab.

August 17, 1999

HFIR CE #2
High Flux Isotope Reactor
Critical Experiment # 2

Contents	Page
Fuel Element	
Fission Counter Position	5
Safety Position	5
Inner Control Plate Position	5
Outer " " "	5
Power Distribution Plate	7

Time

— 56

Fuel Element.	U	U ²³⁵
363 alloy plates (outer)	6001 g	5589 g
165 U ₃ O ₈ " (inner)	<u>2394</u>	<u>2230</u>
	8395	7819 g
6 alloy " (outer)	98	91
6 U ₃ O ₈ " (inner)	<u>87</u>	<u>81</u>
Total	8480	7991 g

Diameters O.D. Inner 10.590
 I.D. Outer 11.366
 water gap $= 776/2 = 0.388$

water gap was reduced

with 0.062 Al cylinder \therefore water = 0.326"

May 12, 1961

Up limit switch set so that physical tip of counter is $\frac{7}{32}$ " from bottom of reactor. A physical stop also indicates the same position. ^{Selwyn 19.13}

(Drive motor stalls when drive hits stop)

Bottom of reactor is _____ inches from the reactor midplane.

Inner and Outer control plates rest on bottom when selwyns read zero. Inner changed to read 44.23, 0999.81
Safety reads zero when down.

May 16, 1961

After Diagonal Bracing lifting outer control cylinder deflects superstructure $1\frac{1}{2}$ Thous.
Lifting inner also $1\frac{1}{2}$ thou total 0.003 in.

May 17, 1961

Set Inner and Outer control selwyns @ 22.00
when top of Inner Control $39\frac{1}{4}$ in from Be
Outer Control 26 in. from Be

Source PN 467 Polonium Beryllium
Later source changed to -M-228 Pu-Be

May 12, 1961

Inspection of the center punchout foil from the removable plates (Inner and Outer) revealed that a number were somewhat mutilated (7 out of 27) and all had file marks on them. Tunnell, Magnuson, Fox, Cheverton, ~~Hobbs~~, Taboada, Cooke, Kucera all discussed the poor quality of the foils. This was due to a number of factors. The description of how they were made was

- ① foils half punched out
- ② " " half punched remainder
- ③ Filed to a loose fit and worked over
- ④ Formed the curve.

Although no one would admit a poor job, a later telephone conversation with Taboada revealed that they were going to ^{do} ~~make~~ the job over with extra plates that they may find. (Max to Min in weights of the 27 were 15%.)

3 0.002 in foils $\sim 1/8$ " \times 1.5" were
cut ~~with~~ from package reactor scrap.

#1 = 113.4 mg 235 U #2 ~~106.4 mg~~ #3 = ~~112.5 mg~~
105.7 mg 235 U

6-2-61

#2 = 115.1 mg or 107.3 mg 235 U

PN-467 to be used in HFIR Exp.

MAY-17-1961

9

Changes in Multiplication without water on core, Clock Reads 1358 hours.

	IC-1	IC-2	IC-3	IC-4	IN _N ^{etc}	OUT _{EN}	Conditions
①	$.7 \times 10^{-12}$	1.5×10^{-12}	6×10^{-13}	4×10^{-12}	22.0	22.0	Safety In 0.44
②	"	"	"	"	"	"	Withdrawn 32.45
							Safety
③	1.3×10^{-12}	2.5×10^{-12}	1.2×10^{-12}	7.5×10^{-12}	44.24	44.02	32.45
④	"	"	"	"	"	"	.45
							With no water the effect of safety is negligible.
⑤	$.8 \times 10^{-12}$	1.3×10^{-12}	6×10^{-12}	3.5×10^{-12}	.05	999.81	32.45
							Dropped Safety no change
⑥	"	"	"	"	"	"	0.45

Conclusion

1 there is ~~block~~ some reactivity associated with the control cylinders and it has correct sign.

Installation IC-2 & IC-4 on top of Be
 IC-1 & IC-3 outside tank & midplane

May 17, 1961

EXPERIMENT 1
HFIR CE #2

INSTRUMENT CHECK W. M-22

IC-1 Fast 10×10^{-12} OK Trip
 IC-1 Meter " OK "
 IC-2 " " OK "
 IC-3 Response Only
 IC-4
 PM-1 Lo OK Trip
 PM-1 Hi ~~OK~~ Not checked
 PM-2 " " " "

PURPOSE

To check multiplication with control plate

Water height 11.52
 Insert Safety 32.45 \rightarrow 0.45
 IC-2 $1.7 \times 10^{-12} \rightarrow 1.7 \times 10^{-12}$

IC-2 F. Water Ht

3²⁰ 1.7×10^{-12} 11.52
 3³⁰ 2.0×10^{-12} 15.56
 3³⁴ 2.2×10^{-12} 18.07
 3⁷ 2.2×10^{-12} 20.10
 4⁰ 2.6 21.44
 4² 3.1 22.60
 4⁵ 3.5 23.55 Insert safety
 4⁸ 2.7 23.46 .44
 5⁸ 23.10

} maybe leak
or air bubbles.

IC-2 Water Ht
 4⁰² 4.3×10^{-12} 25.64
 0⁷ 4.7×10^{-12} 26.30
 1⁰ 5.3×10^{-12} 27.35

Insert safety to inspect ^{actual} water height
 1⁴ 3.9×10^{-12} 27.24 .43 Turn off lig. level adjust
to preserve water Ht mont.
 Drain H₂O

4¹⁸ 1.2×10^{-12} O
 Rin Inner Control Plate down.

No water seen above core, re measured
 position of max. water Ht and core should
 have been flooded by more than six inches
 or 6 in above the Beryllium (lower shelf.)
 or 7 1/2" above the fuel.?? The reactivity
 changes after core should be flooded
 are not understood.

RWTM.

Inspection of the core indicates that
 the water was never over the fuel.
 The obvious conclusion is that there was
 an air bubble in the manometer leg
 causing an erroneous reading. This
 will be checked tomorrow.

May 18, 1961

C-4 finally working. Set voltage so that pulses on scope max ~ 100 V.
 Set PHS @ 20 on both C-3 and C-4 1550 - 1750
 resp. Overnight count with C-3 in Radial Hole
 C-4 suspended in air near Be.
 C-3 70661 x 256 in 15 hours. O.M.U.
 C-4 7810 x 256 " " " "

EXPERIMENT #2

HFIR CE#2

INST CHECK

IC-1 Fast Scram OK
 Meter Trip OK
 IC-2 Meter Trip OK
 PM-1 Lo OK
 " Hi OK

PM-2 Response to gamma source not adequate, previously a deflection of 10-20 μ c on meter was observed with 10 mc of radium directly on scintillator. Now only observable when test button is pushed.

IC-3 and IC-4 response OK
 Cable limit lights OK

Under scram the safety rod automatic reverse works, but the lights on the ~~fast~~ drain valves do not indicate valve position. Putting switch to drain also does not light the drain pilot light when programmed.

9⁰⁵ AM Start adding H₂O Control Plate Inner .05 Outer .81

IC-2	IC-4	H ₂ O
	5×10^{-12}	11.9
2.2×10^{-12}	6.5×10^{-12}	15.4
2.9×10^{-12}	9.5×10^{-12}	18.3
4.0×10^{-12}	1.3×10^{-11}	20.6
4.8×10^{-12}	1.6	22.0
5.4	1.8	22.9
5.8	2.0	23.9
6.4	2.2	24.7

Insert Safety ~~and Remove~~ Check bubbles in tube none found

1.35	24.5	
6.5	2.2	27.0

Walkdown Safety

Very little change in multiplication for last 2.5 inches, consistent with a flooded core

Interlocks that prevent motion of inner plate when outer is not down are working.

May 18, 1961 EXP #2 (cont)

937 Begin to move Inner Control plate down to observe change in multiplication.

Inner Control IC-2 IC-4
3.51 7.0×10^{-12} 2.4×10^{-11} Change in

Multiplication observed.
6.0 7.8×10^{-12} 2.5×10^{-11}
9.0 9.4×10^{-12} 3.2×10^{-11}
11.0 1 1.15×10^{-11} 4.0

Move source outward in H_2O
12.0 1.25 4.3
14.0 1.6×10^{-11} 5.5×10^{-11} 26.5

Insert Safety
14.0 1.75 2.4
16.0 2.0×10^{-11} 7.0×10^{-11}

Remove and Insert source
18.0 2.7×10^{-11} 9.0×10^{-11}
20.0 3.3×10^{-11} 1.1×10^{-10}
22.0 3.5 1.2 26.0 Leak perhaps!

Insert Safety 3.5×10^{-11}
Withdraw Safety
22.0 3.4 1.15
26.0 3.1 1.00

This decrease in multiplication

was not expected.

Add water back from 25.8 \rightarrow 27.5 inches
Inner Control IC-2 IC-4 H_2O Safety
30.00 2.4×10^{-11} 8×10^{-11} 27.3 32.45
34.00 1.75 6 27.1 "
38.00 1.5 5 " "
44.23 1.35 7.4 27.05 "

\downarrow Call limit on - not off - Insert Safety to investigate
22.0 needs adjusting - remove Safety
22.0 3.6×10^{-11} 1.1×10^{-10} 26.6 32.45

Inner constant at 22
Outer

1.0 3.5 1.6⁺
On moving outer to 1.0 multi decreased
do not understand
2.5 3.5 1.0
4.0 3.6 1.1

Multiplication now increasing OK
to proceed,
5.0 4.0 1.3
6.0 5.0 1.6⁺ 26.5 32.45
7.0 6.9×10^{-11} 2.2×10^{-10}

Insert Safety 3.4×10^{-10} .44

Withdraw Safety From the time to
equi, we are not much sub crit.

May 18, 1961 EXP #2 (Cont)

Outer Plate IC-2 IC-4

8.00

After 3' still rising, near critical Jerk source, from period it indicates that we are only a few dollars subcrit. Proceed to crit with ~~rod~~ control plate end source moving out at constant power.

11³³ AM Source Out, reactor slightly subcritical @ 8.55 on Outer plate

11⁴¹ Inner Outer Source Safety Ref Inlet Fuel H₂O
 22.00 8.56 Out 32.46 None 25.97
 22-8.56 = 13.44 in. inserted on gray window = 6.56 inches.

Critical conditions @ 5×10^{-10} on IC-4

Insert Safety, Reduce power to 0, apparent slight pos. period after waiting 4'.

Move Outer plate for + period
 8.71 +111 sec $\lambda^{235} S = 9.06 \phi$

Note → Lower trip setting on IC-2 to 60 to allow Inst to shut down.

$$\frac{9.06 \phi}{0.15} = 60.4 \phi/\text{inch}$$

Safety worth more than #5 when island dry

EXP #3

Purpose: To get critical with control plates more symmetric - set Inner at 15.30

Source In, Safety cocked, Core flooded, and then get critical moving Outer plate from 0.0

IC-2	IC-4	Outer
5.5×10^{-10}		0
5.0×10^{-10}		1.5
5.0×10^{-10}		5.0
5.5		8.5
9.0		11.0

Insert Safety and withdraw

IM

CRIT COND				H ₂ O	Fuel
INNER	OUTER	SOURCE SAFETY	Ref Inlet	H ₂ O	H ₂ O
15.30	14.01	OUT 32.46	0		27.00
⊕ Period +111 sec			$S = 9.06 \phi$		
14.16					

Drain H₂O IC-4 = 5×10^{-10} @ critical

22.00	22.00	20.00
15.30	14.01	14.69
6.70	7.99	
	6.70	5.31" - Thickness of Gray Window
	14.69	6.70
		7.99
		20.00"

May 18, 1961

Note

① Inspection of Tank below core (by Cross) has shown that there is a leak on the pipe threaded into the collar. This was to be back welded but wasn't.

② Adjusts S limit switch on inner control plate cable.

③ Will attempt to repair leak from below Friday A.M. when we have to be shut down for delivery and for removal of FBR materials in EAST cell.

④ Moved U-233 min. fiss counter to first ring of $\frac{1}{2}$ " holes in Be.

MAY - 18 - 1961

EXP #4

Purpose: Repeat #3, more symmetrical
Insert source, withdraw safety set inner control @ 14.65

at 8.05 on Outer control plate relay clicks but control plate does not move.

Drain water.

Note

Inspection revealed a jammed control plate drive. *DWR*

May 19 - 1961

Removed PN 467 source so that Mihalego can use it on the FBR materials. Readjust stroke of source drive and use Pu BE source M-228 which can not go down between fuel but must be placed adjacent to top of core when fully inserted. M-228 is several times stronger but can not be placed as well.

DWR

BF₃ counters detect the source with ease w. or w/o H₂O!

May 19, 1961

Inner Control Plate	up	000.05	
	Down	44.2	
Outer Control Plate	Down	999.82	
	up	777.8 43.96	
NP. Sockets	Up	32.45	30.29
RY	Down	0.42	998.25
Fiss. Counter	Up	19.15	4.84
	Down	999.93 ⁺	24.08
Fuel lig level	Down	99.	
Ref Island lig lev	Down	992.9	

Both discs repaired by removing bearing blocks and screw and brass push rod tube.
Selsyn reset at limit.

May 22, 1961

Inner control plate reads 22.00 when gray section is at midplane. Up = 0.05
down = 44.24

Outer control plate reads 22.00 when gray section is at midplane (Top of outer control plate is 26.0 inches above beryllium)
999.82 → 43.96

Safety selsyn reset so that cadmium starts to enter core when selsyn reads 20.0
selsyn reads zero when cadmium fills core. Upper limit = 30.29 lower 998.25

Fission counter reads directly distance of tip from core. Up limit = 4.84
lower limit = 24.08

Corrugated Flexible hose replaced the hose between tank bottom and core — no interference with counter drive.

May 23, 1961

EXPERIMENT #5

PURPOSE: Repeat #3 with control plates more symmetrical. Set down at 14.65. Source in and response on IC-3 and IC-4 from below 10^{-13} to 5×10^{-13} and 3×10^{-12} respectively, also noted on IC-1 and IC-2 when set on 10×10^{-12} scales.

PM-2 Source in contact $\sim 1 \mu a$
on test $\sim 3 \mu a$

PM-1 Hi and Lo trips OK

EC-1 Fast trips Scrapped H₂O, Safety

IC-1 Meter Trips Trip Safety OK

IC-2 Trip OK

IC-3 and 4 response OK

Red Light on Personnel check OK, Source in Safety withdrawn.

Set flow rate on filling with throttle valve in series with feed valve. 8 in / min.

Near crit @ 14.91. go on pos period to raise power @ 15.05

INNER OUTER SAFETY Counter H₂O Read IC-4

14.65 15.05 30.29 1.84 26.89 +

" 14.905 " " " 0 5.5×10^{10}

Lower H₂O to ~ 1 and repeat.

Exp #6

Purpose: Repeat #5 for reproducibility check

	INNER	OUTER	SAFETY	COUNTER	FUEL H ₂ O
	14.65	14.94	30.29	4.84	27.76

Note

Close to critical but not very stable
Push Scram Button to shut down
Drain only to ~ 1"

Checked liquid level and discovered
some air bubbles.

The line to the lig level can get
trapped air in it, and perhaps it should
be relocated or made of plastic tubing,
only.

AWG

IC-2 and IC-4 have been placed at
near midplane against East wall ~ 2 1/2' from Tank.

May 23, 1961

- IC-1 Scram dropped Safety Fast and Slow OK
- IC-2 Scram check damaged H₂O Meter OK
- IC-3 Response OK
- IC-4 " " "
- PM-1 Lo and Hi Tripped OK
- PM-2 " " N.G.

Exp #7

Repeat #5 and 6 for reproducibility, lig. level
tube leveled so that jet should not get air
trapped. Source In, Inset set at 4.70, Safety
withdraw Scrams out. Initial H₂O rate 3.8 in./min
Water @ 27.38 Inset and withdraw Safety to
be certain that it is withdrawn.

	INNER	OUTER	SAFETY	COUNTER	FUEL H ₂ O	Reactor NEA Sub	IC-3	IC-4	S
	14.70	14.81 ⁺	30.29	4.84	27.37	3			
CRIT	"	14.83	"	"	"	∞	3.3x10 ⁻¹¹	4.4x10 ⁻¹¹	0
10 ⁴⁸ AM	"	14.98	"	"	"	1120			8.534
CRIT	"	14.84	"	"	"	∞	1.4x10 ⁻⁹	1.6x10 ⁻⁹	0

Drain water and repeat for reproducibility

$$\frac{8.54}{14} = 60.94/in$$

May 23

EXP #8

Purpose Repeat #7 for reproducibility
Source in, after control down, safety withdrawn

INNER	OUTER	SAFETY	COUNTER	F ₀₀₂ H ₂ O	IC-3	IC-4	Reamid	React
14.70	14.84	30.29	4.84	27.46	9x10 ⁻¹²	1.1x10 ⁻¹¹	-	Slight Sub.
"	14.99	"	"	"	X	X	+219s.	5.16¢
"	14.90	"	"	27.35	4.4x10 ⁻¹⁰	4.6x10 ⁻¹⁰	∞	0

5.16/09 = 56 μ /in

Crit Pos changed .06 in on 3

EXP #9

Repeat 7 and 8

14.70	14.94	30.29	4.84	27.78	x	x	+159s.	+6.77¢
-------	-------	-------	------	-------	---	---	--------	--------

Drain H₂O Insert Safety, to shut down

EXP #10

Repeat #9 without moving rods.
Insert source safety, raise H₂O then withdraw Safety,

14.70	14.99	30.29	4.84	27.50	x	x	+217s	5.16¢
"	14.885	"	"	"	4.9x10 ⁻¹⁰	5.0x10 ⁻¹⁰	∞	0

Move Rod in for negative period - withdraw ^{to 15.0} for restoring orig power and level.

14.885

Continue this run by inserting safety partially and withdrawing outer rod. Safety to be inserted no further than 10 inches.

	Outer	Safety		
	14.98	24.00		
.18/2	15.16	22.01		
.35/2	15.51	20.00		
.45/2	15.96	18.00		
.34	16.30	16.99		
.45	16.75	16.00		
.55	17.30	15.01		
.74	18.02	13.99	IC-3	IC-4
.93	18.93	13.00	~ 3.2x10 ⁻¹⁰	4 x 10 ⁻¹⁰

Drop ~~Insert~~ Safety remaining distance, still worth many dollars #3-5 Insert Source

EXP #11

Withdraw Safety to go critical Insert Outer control to 18 in.

	17.99	13.01	Superit.	T	9
Out	14.70	18.88	13.01	1.3x10 ⁻¹¹	1.9x10 ⁻¹¹
	14.70	19.18			∞
		18.93		1.1x10 ⁻⁹	1.4x10 ⁻⁹

$\frac{8.3}{.25} = 33.2 \text{ } \mu$ /inch

May 23, 1961

EXP #12

Purpose: Approach to crit. with safety in, ^{white} control in
 Insert source, set inner control to 44.24 (down)
 set outer control to 43 (UP)

Safety at 998.25, fully inserted. Water
 will be added slowly and only to
 high multiplication. ~~H₂O will be~~

H ₂ O	IC-3	IC-4	
0	$\sim 8 \times 10^{-13}$	2×10^{-12}	
11.7	4.4×10^{-12}	7.5×10^{-12}	
11.8	7.5×10^{-12}	1.3×10^{-11}	
12.2	1.8	2.3	→ Milt ~ 10 Drain H ₂ O

It is apparent that the system can be
 made critical with safety down and
 control plates with white sections in place

EXP #13

Purpose: Approach to crit with safety inserted
 and Outer control plate at 22.00 (gray section
 inserted) and Outer inner @ 44.24 (white
 section inserted)

0	$\sim 8 \times 10^{-13}$	2×10^{-12}	
14.9	3.5×10^{-12}	5.4×10^{-11}	
15.7	5.5×10^{-12}	8×10^{-12}	
16.3	1×10^{-11}	1.3×10^{-12}	
16.7	1.8	2.4	M = ~ 10 Drain

Concluded that system ~~could~~ be made critical
 with Outer gray inserted and safety inserted
 by raised water.

May 24, 1961

Set up dial indicator to check sag of
 assembly when water added to bottom half
 of assembly. 21" of H₂O in Bottom of Tank
 deflected Be 0.004 in., later assumed to
 be 0.005 in.

Re routed line to liq. level indicator, but it
 is believed that air gets trapped in the 3/4"
 main field and drain line to feed system -

Some simple exp in battery jar proved that the condition
 of the surface, i.e. the grease on the alum, was most
 important to determine whether bubbles collected
 on the surfaces. Aerosol OT wetting agent
 did not prevent bubbles from collecting.

Thermo couple put in core! pos. 2 on
 RG-30-83 recorder Temporary

May 24, 1961
Inst Check

- PM-1 LO Tripped Safety and Dump Valve. OK
- PM-2 HI Bldg Alarm trips only.
- IC-1 Fast Trip OK
- IC-2 Meter Trip OK
- IC-2 " " "
- IC-3 and 4 Response OK
- PM-2 No response,
- Cable limits on control plates OK.
- Personnel and light check OK C.C.
- LogN inst Calib. OK

EXP #14

Purpose: To evaluate reproducibility for repeated ^{approaches} attempts to get critical by varying H₂O levels.

Set inner control plate @ 14.80, outer @ 999.82
Withdraw safety, Fission count @ 4.84 → 10.00
Insert source.

Temp 24.5°C before H₂O pumped into core
" 25.0 after " " " "

INNER	OUTER	SAFETY	ISLAND REFLECTOR	Fuel H ₂ O	IC-4
14.80	14.67	30.29	21" Thick	27.97	1.7 x 10 ⁻⁹
Approx. Crit					
	14.83				+116 8.75 f
14.80	14.67	30.29	21"	27.97	1.0 x 10 ⁻⁹
Crit and drain H ₂ O					

EXP #15

Purpose: Repeat #14

Insert source lower control (outer) to 6.35

No bubbles observed in manometer leg-level lines
core drained to below 1" but pipes not drained.
Core temp after filling 25°C.

INNER	OUTER	SAFETY	ISLAND REFLECTOR	Fuel	IC-4
14.80	14.83	30.29	21"	27.98	+ Period 7 x 10 ⁻⁹ +1875 → 5.88 f

Drain and repeat
EXP #16

Insert source, lower outer control and add H₂O.
When Full T = 25 1/4 °C

14.80	14.83	30.29	21"	28.06	+202 5.50 f
Drain H ₂ O Lower outer, raise inner.					

May 25, 1961

Dial Indicator set at zero
Add H₂O to tank 2 1/2" to 4 3/2" dial Ind - 4 mils

Recirculation line for fuel H₂O temporarily connected with plastic hose down to core.

Just Check

- IC-2 Trips OK Dump H₂O and drop Safety
- IC-4 OK
- IC-3 OK
- IC-1 Trips Meter OK
- " Fast Trip OK
- PM-1 Lo } Trips OK
- " Hi }

10 mc gamma source used CC DSQ
PM-2 No Response to probe in meter.

EXP #17

Purpose: Critical Position before circulation
Air Temp before run 25.5
H₂O Temp 26.0+

Selsyn reads 28.0 H₂O level ~5" above fuel plates or 7" above fuel
Flood core to selsyn reading of 32.5
set circ. valve open ~~to~~ circulate only for a few seconds 28.47

May 25 EXP #17 cont

Inner	Outer	Safety	Ref Island H ₂ O	Fuel H ₂ O	IC-4
14.70	14.54	30.24	43 1/2"	28.44	1.1 x 10 ⁻⁹

10⁵³ AM approx crit

14.70	14.67	30.29	43 1/2"	28.44	+141 Δ = 7.504
11 ⁰³				Temp 25 3/4	Start Circ
11 ⁰⁸				Temp 26-	Stop Circ

(Inserted meter to shut down)
Circulation sucks air in the manometer tubes.

EXP #18

PURPOSE: To check reproducibility after circulation. Insert source.

14.70	14.67	30.29	43 1/2"	28.36	+178 Δ = 6.16
				Temp 25 3/4	Insert rod
				max IC4	8.5 x 10 ⁻¹⁰

Pinch plastic tube

11 ³⁷	Start circulation	25 3/4 °C	No bubble seen.	JRF.
11 ⁴⁷	Stop circ	26 1/4 °C	Unpinch tube	

EXP #19

Purpose: To check reproducibility after circulation

14.70	14.58	30.29	43 1/2"	28.43	2.4 x 10 ⁻¹⁰
"	approx. 14.67	"	"	"	+282 sec → 4.11 Δ
				Temp = 26 1/4 °C	max 2.2 x 10 ⁻¹⁰

May 25, 1961

Inner Outer Safety Island Fuel H₂O IC-4
Insert control Outer to 11.5', remove
to 14.67 for repeat period.

14.70 14.67 30.29 43 1/2 28.42 Max. 5x10⁻¹⁰
Temp 26 1/4 267 4.31 d
+ 5 → 5 φ
lower outer control insert source

12²⁸ Start circ. T = 26.0 +
38 Stop " T = 26 1/2

EXP #20

14.70 14.63 30.29 43 1/2 28.42 2.6x10⁻¹¹
approx crit.

14.70 14.67 30.29 43 1/2 28.40 Max
[IC-4 = 1.7 x 10⁻¹⁰ 0.233 in Be = 1920 C/MIN]
T = 26 1/4 °C +424 sec β = 2.81 φ

1¹³ Lowered control blade
punched right glass line
1¹⁵ started circulating pump
2¹⁵ stopped " " T = 29.5
2¹⁷ started " " T = 29.5
2³² stopped " " T = 30 1/4 °C

May 25, 1961

EXP #21

Purpose: Check Temp coef and
Reproducibility

Inner Outer Safety Island Fuel H₂O IC-4
14.70 14.67 30.29 43 3/4 28.3x 2x10⁻¹¹
Subcrit

14.70 14.82 " " " +173 sec = 6.30 φ
Max 4.3x10⁻¹⁰

14.705 (Critical) 4.3x10⁻¹⁰
T = 30.0 °C

14.67 (Negative period) -978 → -1.3 φ
Drain and mix with barrel
and pump back up.

EXP 21

Purpose: Reproducibility and Temp effect.
T = 27.5 °C

14.65 approx crit 1.9x10⁻¹¹
14.70 14.67 30.29 43 3/4 28.29 +761 sec +1.6 φ
Max 4.4x10⁻¹¹

EXP #22 21A

Purpose: Reproduce after circ for 3/4 min.
14.70 ~ 14.65 ~ critical T = 27.5 °C
14.67 critical (10' wait) 27 1/4 °C
may be fraction of crit upon crit. Drain.

Conclusions:

- ① overall core temp coeff is negative
- ② either (A) if circulation adds bubbles then a negative void coeff
(B) if circulation removes bubbles then a positive void coeff.
- ③ Control plate motion only is very reproducible, less than a cent (0.2%) change in reactivity from plate motion from crit and returning
- ④ Perhaps a single thermo couple in the middle of the core is insufficient but no indications were present that showed otherwise. It is believed that the single temp measurement is representative of the core.

May 26, 1961

Inst Check

- IC-1 Fast OK Tripped drain & Safety.
- IC-1 Metering OK
- IC-2 Metering OK
- IC-3 Response OK
- IC-4 Response OK
- PM-1 HI Trip OK
- PM-1 LO Trip OK
- PM-2 ~ 1/2 sec response.

EXP #21 B

PURPOSE: Critical position

	INNER	OUTER	SAFETY	ISL-REFL	FUELED	IC-4
Initial	000.05	999.81	998.25	993.	993.	
	↓		30.29		↓	
	22.00				28.	
			Check safety OK			
			↓			
			3.00			8×10^{-12}
			6.17			1.1×10^{-11}
						$.9 \times 10^{-11}$
			Decrease in multiplication or leakage			
	k_4		10.00	28.36		5.5×10^{-11}
C-4 near Top of Be	65x256+47	12.00				4.0×10^{-11}
	55 +136	14.07	28.55			3.6×10^{-11}
	46 +34	16.12				3.0×10^{-11}
	32 +8	21.00	28.97			2.2×10^{-11}
	23 +139	24.00				1.2×10^{-11}
		26.10	29.30			$.7 \times 10^{-11}$

By Measurement H₂O covers the Be 4" when safety read 26.10.

Drain system requires 30-40 sec.

Removed Island-Reflector feed and drain system from scan bus.

Moved IC-1 and IC-3 str. to top of the Be.

EXP # 21

Purpose: The next series of approaches to critical are being made to evaluate the multiplication due to the island-reflector water.

- ① Raise Island-Reflector water to 22" very little change in mult.
 - IC-3 $9 \times 10^{-13} \rightarrow 1.2 \times 10^{-12}$
 - IC-4 $1.5 \times 10^{-12} \rightarrow 1.0 \times 10^{-13}$ - change in leakage.
- Drain

21 Cont

- ② Raise Fuel H₂O to 11.0 in.
- Raise Refl. H₂O to 20.0 in
- IC-1 and IC-3 increased
- IC-4 decreased
- Raise Fuel to 18.4 IC-1 and IC-3 increase.
- Drain Refl H₂O 20.15 → ○
- IC-1 decreased then increased.

IC1	IC2	IC3	IC4	Ref	Fuel
7.5×10^{-12}	$.9 \times 10^{-12}$	8×10^{-12}	5.5	0	24.7
9.0	1.1	9.5	6.5	1.0	
					Slight increase in Mult.
9.5	1.0	10.0	6.2	4.0	24.3
					Slight decrease Mult
7.5	.75	7.8	4.8	7.0	24.4
					Decrease in Mult.
10^{-12} 5.0	.5	5.5	3.3	11.0	24.5
4.0	.85	4.0	1.5	22.0	

~~Remove~~

Now move outer rod only until mult. increases to 8×10^{-12} on IC-3

	IC-3	IC-4	Ref	Fuel	Safety
	1.5	1.3			5.0
	4.5	1.4			10.0
8.5	8.5				12.25
	1.2				30.24
					98.25

Safety appears to be worth more than the Island Reflector H₂O. Withdraw Safety, Insert Outer, drain H₂O Island.

Repeat the previous series start with higher multiplication

Instr	Outer	Safety	Island Refl	Fuel H ₂ O	IC-1	2	3	4
22.00	999.81	30.29	0	26.1	10.	1.1	10	7.5 x 10 ⁻¹²
22.0	70.00	30.29	0	26.1	23	3.5	25	20

Start to add Island - Refl. H₂O but this added too much reactivity, Mult too high. Drain and set Outer plate lower.

6.00					15	2.2	16	14
"	"	"	1.3	"	26	3.4	27	22
"	"	"	2.5	"	26	3.3	27	22
"	"	"	7.05	"	10	1.3	11	8.5
"	"	"	15.14	"	4	.4	4.4	2.5
"	"	"	22.09	"	38	.25	4.0	1.3

Drain, Increase in power.

Scrammed system (OK)

"	6.00	998.24	30.29	26.1	2.5	.5	2.5	2.5
"	"	30.29						

Magnet wire is not located properly and will have to be changed.

Safety is worth more with island empty

Note

than island ^{reflector} ~~critical~~ when filled.

IN	OUT	SAF	ISL REF	FUEL H ₂ O	IC	2	3	4
				25.4	12.5	1.9	12.5	10.5 x 10 ⁻¹²
22.00	6.00	30.28	0	27.6	13.5	2.1	14.	13.
"	"	"	2.03	"	27	3.8	29	23
"	"	"	22.08	28.2	3.5		7	1.3
"	12.85	"	"	"	14		14	2.6
"	13.50	"	"	"	30		32	4.5

~~Insert Safety~~

Remove Source, not far from critical Insert Source

Approx Critical Cond

22.00 13.93 30.28 24.01 28.17 @ IC-3 = 2.0 x 10⁻¹¹
 @ IC-4 = 1.2 x 10⁻¹²

22.00
 13.93

8.07"

Black insertion

20

8.07

11.93"

gray window.

Drain Outer
 Drain Fuel
 Drain Island Refl

May 26, 1961

The 3" air operated drain valve on the Island-Reflector system was replaced with a manually operated valve. System can be drained remotely through the feed valve if pump is off.

Magnet leads changed for a coil headphone type. Upper limit on safety changed to 28.27" Safety now 8" above coil when withdrawn.

EXP #22

PURPOSE: Determine control plate position at critical. Set inner @ 17.50 outer @ 17.81 Safety @ 28.27 Source In Add Reflector Island H₂O to 26.04", add Fuel H₂O to 23.0" Withdraw Reactor to 10.0. Insert Safety and withdraw.

Approx Crit Cond

INNER	OUTER	SAFETY	Island	Fuel	IC-3
17.50	17.65	28.27	25.44	27.7	1.2x10 ¹¹
	18.00				+Period
	17.76				166sec 6.53¢

level T=27°C
shut down.

$$\frac{6.53}{.24} = 27.2 \text{ ¢/inch}$$

22.00	12	
17.50	17.76	20
4.50	4.24	8.74

gray window

11.26"



May 29, 1961

Inst. Check

IC-1 Fast OK

-1 MTR OK

2 MTR OK

IC-3 Response OK

4 " OK

PM-1 Hi OK

-1 Lo OK used to trip safety & drain thro

-2 $\frac{1}{2}$ no response.

Moved IC-1 and IC-3 now 1" plastic between chamber and Beryllium

Moved IC-2 and IC-4 into thimble located chambers at reactor midplane and $\sim 1\frac{3}{8}$ inches from beryllium.

IC-2 is between radial and tangential

hole IC-4 is between radial and through hole.

May 29, 1961

EXP # 23

Purpose: Check reproducibility of #22

INNER	OUTER	SAFETY	ISLAND REFL.	FUEL #20	IC-4
17.50	17.75	28.27	26.19	26.77	Level 2×10^{-11}
	18.00	↓			1525 May 1×10^{-11} 7.03 ϕ
		17.00			

Insert safety to shut down, insert source $\frac{7.03}{.25} = 28.1 \text{ } \mu\text{in.}$

EXP #24

Purpose: Comparison of Safety to Outer Control

17.50	28.07	17.00	26.14	26.77	level 3×10^{-11}
					Insert outer control to 0
					Insert source

EXP #25

Purpose: Comparison of Safety to Outer and Inner. Set Inner at 22.00

22.00	15.86	17.00	26.24	26.78	level 3×10^{-11}
					Insert safety, insert source
"	16.93	16.03	27.14		3.5×10^{-11}
"	18.70	15.02			3.5×10^{-11}
"	21.87	14.29			3.3×10^{-11}

Insert Safety Outer and Source.

EXP # 26

Purpose: Check multiplication with safety fully inserted. Position inner ~~with~~ at 4 (down white in)

Inner Outer	IC-3	IC-4
22.00 999.81	1.15	2.2×10^{-12}
44.24 999.81	1.2	2.1×10^{-12}
44.24 22.00	2.2	3.2×10^{-12}
44.24 28.67	6.0	12×10^{-12}

Mult ~ 10

System can be made critical with white sections pulled into core and safety in. One gray section is subcritical.

... Do as planned ...

EXP # 27

Purpose: Repeat # 23 and # 22

Inner Outer Safety Island Refl Fuel IC-4
 17.50 18.00 28.27 26.22 26.79 + 148 sec May 1961
 T = 23.5°C Pa period 7.19 ϕ
 Drain H₂O Insert Outer

Exp # 28

Purpose: Reproducibility or draining.

17.50 18.00 28.27 26.20 27.02 + 148 sec 7.19
 T = 23.5°C + 283 sec 4.42 ϕ

$\Delta p = 2.77 \phi$

Push screw ~~button~~ to shut down
 Runne Incom up
 Outer down
 Drain Refl. Island H₂O

Wds

Handwritten signature and initials, possibly 'L. R. K.' or similar.

May 31, 1961

17 ml of wetting agent Triton X-100 added to Fuel H₂O. A section of grease was visible in storage tank, and tank should probably be cleaned. Dwdm.

Triton X-100 has only C-Hand 0.

May 31, 1961

Instrument Check:

- IC-1 Fuel OK
- " MTA OK
- IC-2 MTA OK Scrammed H₂O & Safety
- PM-1 Hi
- " Lo
- PM-2 < /μs response
- PT-3 ~~is~~ Out for repair
- IC-4 Response OK

EXP #29

Close Refl. Island drain valve, insert source ^{with draw safety} fill reflector island fill fuel, withdraw outer, check safety for react change. IC-4 Calib check OK.

Purpose: To check reproducibility with wetting agent in Fuel water.

Inner	Outer	Safety	Refl. Isl.	Fuel H ₂ O	Temp	IC-4	React
17.50	17.70	28.27	27.02	27.22	26 3/4 °C	3.8 x 10 ⁻¹¹	Level
"	↓	"	"	"	"	"	+111 sec
"	18.00	"	27.00	27.21	26 1/2 °	2 x 10 ⁻⁹ Max	+9.064

Drain H₂O, insert Outer, insert source.
 $\frac{9.06}{.30} = 30.2 \text{ f/in}$

EXP #30

Purpose: Reproducibility of react with draining Fuel H₂O

17.50	17.82	28.27	27.01	27.28	26.0 °C	2.5 x 10 ⁻¹¹	Level
"	↓	"	"	"	"	"	+209
"	18.00	"	27.03	27.21	25 3/4 °C	2 x 10 ⁻⁹ max	+5.344

Insert outer, drain H₂O (fuel); insert source

$\Delta g \approx -3.72$

$\frac{5.34}{.18} = 29.7$

May 31, 1961

EXP #31

Purpose: Repeat react. @ outer plate setting of 18.00 after draining & filling

Inner	Outer	Safety	Refl. Island	Fuel	Temp	IC-4	React
17.50	17.82	28.27	27.04	27.65	25 1/2 °C	2.2 x 10 ⁻¹¹	Level
"	↓	"	"	"	"	"	233
"	18.00	"	27.04	27.33	25 1/4 °C	1 x 10 ⁻⁹ max	+5.24 +4.88 f

Insert Outer Drain H₂O Insert Source, open pinch clamp on line to Fuel H₂O Manometer. $\frac{4.88}{.18} = 27.1 \text{ f/in}$.

EXP #32

Purpose: Repeat #31

17.50	17.82	28.27	27.04	27.70	25 1/2 °C	2.7 x 10 ⁻¹¹	Level
"	↓	"	"	"	"	"	233
"	18.00	"	27.08	27.70	25.0 °C	1 x 10 ⁻⁹ max	+224 + 5.03 f

Insert outer & safety. But not drained.
 $\frac{5.03}{.18} = 27.9 \text{ f/in}$.

Circulate Fuel H₂O for 10'

EXP #33

Purpose: React after circulation.

17.50	17.81	28.27	27.07	27.70	25 °C	2.5 x 10 ⁻¹¹	Level
"	↓	"	"	"	"	"	233
"	18.00	"	"	"	"	1 x 10 ⁻⁹ Max	+222 + 5.08 f

Insert outer control plate, insert safety, insert source

$\frac{5.08}{.119} = 26.7$

Add more Triton X-100 and circulate and heat.

May 31, 1961

- add ~ 30 me Triton X-100
- 3²⁵ Circulate for 12'
- 3⁴⁰ T = 25 1/2 Start heating Varian @ 10
- 3⁴⁶ 26°C " @ 100
- Discovered no power to heaters.
- 3⁵⁵ Stop circ.

EXP # 34

Purpose: Repeat react check with more X-100 and circ.

Inner outer Safety Ref. Del. Fuel IC-4 T React

17.50	18.00	28.27	27.09	27.66	1.8x10 ⁻⁶ 26 1/2 ~ level
"	18.00	"	"	"	26°C ± 226 sec ± 5.00

Shut down by inserting outer, safety draining Fuel H₂O
 Drain Refl Del. H₂O and Raise inner control to 000.05.

	Summary	Run	4 in
Initial react @ 18.00	9.06 ±	29	27 37.2
Lower H ₂ O & Raise H ₂ O	5.34 ±	30	27 38.1
" "	4.88 ±	31	27 30.2
" "	5.03 ±	32	27 29.7
after circ	5.08 ±	33	27 27.1
" " and max. circ	5.00 ±	34	27 27.9
			27 26.7
			27 27.9
			27 28.1 ± /in

The initial change in reactivity of ~ 4 ± is not understood.

DwM.

May 31, 1961

The H₂O in the fuel system appears to have considerable particulate matter in suspension

The H₂O in the reflector-island system appears to have considerable fine crystalline material in suspension.

ALW

June 1, 1961
 Inst Check
 IC-1 MTRC Trip OK - Scanned Safety and drain H₂O
 - 1 Fuel " "
 - 2 Meter " "
 - 3 Out for repair
 - 4 Response OK
 PM-1 Hi Trip OK
 - 1 Lo Trip OK
 PM-2 < 1/2 in response.

Exp # 35

Purpose: Determine worth of fuel plates, react with all plates in, close drain valve, insert H₂O. Insert source, raise safety, set inner control to 17.50, raise reflector island H₂O

Inner	Outer	Safety	Ref. Id	Fuel Temp	IC-4	React.
17.50	17.79	28.27	26.91	27.42 25 1/2	3.4 x 10 ¹¹	Level
"	18.00	"	"	"	1 x 10 ⁹ max	+189s +5.86

Insert control plate, source and drain H₂O
 $\frac{5.86}{.21} = 27.9 \text{ } \phi/\text{in.}$

Exp # 36 (Repeat of 35)

17.50	18.00	28.27	26.94	~27	25 1/2	1 x 10 ⁹ max +224s +5.03
-------	-------	-------	-------	-----	--------	-------------------------------------

Remove 6 inner plates.

Average react of control 28.1 ϕ/in

EXP # 37

Purpose: React with 6 removable plates.

Inner	Outer	Safety	Ref. Id	Fuel Temp	IC-4	React.
17.50	17.09	28.27	26.94	~27	24 3/4	2.4 x 10 ¹¹ Level
"	17.29	"	"	"	24 1/2	1. x 10 ⁹ max +199s +5.59

Drain H₂O Insert outer, insert safety, raise inner
 $\frac{5.59}{.20} = 28.0 \text{ } \phi/\text{in.}$

$\frac{5.59}{28.1} = 0.20 \text{ } \therefore \text{crit pos.} = 17.09 \text{ w.o. plate}$

$\frac{5.03}{28.1} = 0.18 \text{ } \therefore \text{crit pos} = 17.82 \text{ w. plate}$
 $\Delta = 0.72 \text{ in or } 20.5 \text{ } \phi$

Worth of inner removable plate
 $\frac{3.42}{\text{plate}} \text{ } \phi/\text{plate.}$

Remove 6 outer removable plates

EXP # 38 (React w. 12 plates removed)

17.50	16.44	28.27	26.94	~27	24°C	3.0 x 10 ¹¹ Level
"	16.64	"	"	"	"	1 x 10 ⁹ max +172s +6.33

Insert outer control safety, and drain Fuel H₂O

$\frac{6.33}{.20} = 31.7 \text{ } \phi/\text{inch.}$

$\frac{17.09}{16.44} = \frac{28.1}{31.7} \times 29.9$

$.65 \text{ in} \times 29.9 = 19.4 \text{ } \phi \text{ or } 3.23 \text{ } \phi/\text{plate}$

All plates were cleaned. (Fluorine grease removed)

June 1, 1961 IN OUT SAF REFL ISL FUEL TEMP IC-4 REACT

EXP #39 Insert inner removable plates

Purpose: React with only 6 outer plates removed.

17.50	16.99	28.27	27.01	727	24°C	3.3 x 10 ⁻¹¹	Level
"	17.19	"	"	"	"	1 x 10 ⁻⁹ + 185	5.94

Insert outer control & safety and drain fuel H₂O

$\frac{5.94}{2} = 29.7 \text{ g/in.}$

Insert outer removable plates.

EXP #40 Purpose: React with all plates inserted, repeat of 35-36.

17.50	17.68	28.27	27.04	727	23 $\frac{3}{4}$ °C	4.6 x 10 ⁻¹¹	Level
"	17.88	"	"	"	23 $\frac{3}{4}$ °C	1 x 10 ⁻⁹ max +	+

Insert control, set values for circulation
 3:13:30 start circ. 3:17:30 stop

EXP #41 Purpose: Repeat #40 after circ.

17.50	17.69	28.27	27.04	727	24.0°C	3.3 x 10 ⁻¹¹	Level
-------	-------	-------	-------	-----	--------	-------------------------	-------

3:26 Set voltage at 25° start heat - doesn't work

3:50 Circ raised Temp to 25°C

17.76	25°C	Level
-------	------	-------

5: Start circ to increase T to 20°C

17.76	25 1/2	Level
-------	--------	-------

17.76	26°C	Level
-------	------	-------

ISL
 INN OUT SAF REFL FUEL TEMP IC-4

17.76 26 1/4

3:19 Start heat w. voltage @ 25

3:20 " " @ 50

23 " " @ 100

24 28 1/4

25 29 1/4

26 30 1/2

28 32

32 ~18.06 Heat off 35 2.3 x 10⁻¹¹ ~ level

34 ~18.07 34 1/4 ~ level

36 33 1/2⁺

Temp. change is rapid, ~~not so~~ difficult to maintain power constant.

37 ~17.94 33 1/2 ~ level

38 17.93 33 1/4

Turn heat on to 25, attempt to hold T = 33

44 ~17.83 32 1/2⁺ ~ level

The temperature will take 10-15 to change 5-10° and at least 15-20 to equilibrate.

June 5, 1961

The distribution header for circulation of the island-reflector water has been installed. The fuel water was drained and system flushed with water from the island reflector system. The bottom of the 55 gal drum was painted with glyptal after drying, and the glyptal dried over the weekend. The pipe welds on barrel bottom were belly treated.

Deionized water fresh from the column was added to the fuel system, 132.88 kg, and 12 g of Triton X-100 wetting agent, so that the concentration of wetting agent is 90 ppm.

132.88 kg = 2 1/4 in in barrel

$\frac{132.88}{.997} = 133.3 \text{ l} = 2 1/4 \text{ in.}$

133.3 l / in
2.15

Measured ID of Barrel 2 1/2 in.

$\frac{\pi}{4} D^2 = 397.6 \text{ in}^2$

or $397.6 \times 16.387 = 6.515 \text{ l/in.}$

Def: 2.15 l/in

Circulate thru barrel for 30' to mix wetting agent.

2.15 x 21 = 44.8 l in plumbing

bottom, C.S.

Safety now has a limit switch to indicate when safety is dropped down

June 5, 1961

check of recorders

25°C = 25 on #1

25°C = 23.5 on #2

Boiling H₂O (Bar = 29.16 → 740.7 mm Hg → 99.3°C)

= 99.4 on #1

= 97.6 on #2

down

ERR Adjusted #2 to agree with #1

Moved inner control plate from down to up observed ~12" scratch on gray section southside. No other scratches found.

Moved inner down and then up. with source in and safety withdrawn. slight change in multiplication observed. IC-3 $1 \times 10^{-12} \rightarrow 1.2 \times 10^{-12}$

IC-4 $2.2 \times 10^{-12} \rightarrow 3.5 \times 10^{-12}$

6-28-61 - Water sample taken in A.M. of 6-6-61, water was murky but analysis says 12.8 ± solids

8.1 g. solids

7.0 ± solids, 5 g. solid

June 6, 1961

Orig H₂O

① IC-1 - 2 - 3 - 4 all in thimbles around the core, IC-2 & 4 4" above mid plane.

② Reset ~~and~~ Island Reflector lig level - (off 1/8") measured depth 2 1/4" above Re (read 25.03) set lig. level to 24.73.

June 6, 1961 Instrument Check: IC-1 fuel & mtr ok
IC-2 mtr ok, but a crammed H₂O & safety; PM-1 high & low ok.
IC-3 and IC-4 ok.

G	T	Net
29.12	2.22	26.90
28.65	2.20	26.45
28.6	2.20	26.40
28.85	2.22	26.63
28.65	2.25	26.40
		<hr/>
		132.88
Weighed 12 g of Triton X-100		
		<hr/>
		132.88

1333

31.2

dy = .21

.215 x 21 =

Filled system island-reflector to 27.00 in.
 set valves for circulation, ^{-26.93} move steam dist header
 11:59 AM Turn on pump. lower inner control.
 -lower & raise ^{S₄T₂} little effect.

10⁵ 2.92 lig level in fuel region
 10⁶ 2.85

June 6-1961 Expt. 42
 Purpose: Preliminary Temp. Coef. Run
 9 mm Outer Safety Refl. Island Fuel H₂O IC-4 Reactivity
 17.50 17.94 ~28 26.74 ~31.0 ^{22 x 10⁻¹⁰} Level
 Shut down for turning on heat

EXP 43
 6-6-61 Purpose: Prelim Temp Coeff R
 See Temp recorder for rod
 position vs heat.
 17.80 ~Critical when started but some
 heat had been turned on.
 Max Outer pos. 18.55
 430 Inspection after shutdown showed
 Be covered with m m bubbles.
 added 42 ml of Triton X-100 to Island H₂O

18.55 - 17.80 → 0.75 in @ 28.1 β /in
 = 21.4 β max. reactivity
 change on rod.

Storage Tank 48" x 48" OD useful H_t ~ 42 in

$$Volume = \frac{\pi}{4} \times \frac{48^2}{12^2} \times 42 \text{ ft}^3 = \frac{\pi}{4} \times \frac{4^2}{1^2} \times \frac{42}{12} = 14\pi \text{ ft}^3$$

$$= 44 \text{ ft}^3 = 1245 \text{ L}$$

$$\frac{3}{3735 \text{ L}} \rightarrow 3735000 \text{ cc}$$
 100 ppm ~ 374 ml Triton X-100

6-6-61 Start H₂O thru heat exchanger ~ 4⁰⁰ PM and circulation
 continued all night to cool H₂O.

6-7-61 7³⁰ AM T = 21°C in island Reflector H₂O. Stop circulating
 no bubbles seen on Be surfaces.

1 m. Out Saf Refl. Fuel Temp IC-4
 17.50 18.14 ~27 " ~~26.7~~ ~31 .24 1.3 x 10⁻¹⁰
 10⁰⁰ started heating fuel H₂O only at full
 capacity

6-7-61 Inst. check OK

IC-1 Fast & Meter OK, IC-2 MTR Trip Safety and Water drain OK

IC-3 & IC-4 response OK, PM-1 Hi & Lo trips OK PM-2 no response.

Stirrer w. 1/4 hp motor mounted vertically on south rim of tank. Added 160 ml of Triton X-100 total wetting agent now 200 ml or about 50 ppm. in ~~the~~ Island-reflector.

EXP#43 Purpose: Preliminary temp. coeff. determination.

Set inner @ 17.50 safety @ 28.27 add fuel H₂O.

9m out ref. Refl. Fuel Temp IC-4
17.50 18.14 ~ 28 26.7 ~ 31 24 1.3x10⁻¹⁰ Level

10²⁵ started heating fuel H₂O only at full capacity

10⁴⁴ ~ outer 18.34 at ~ 29° in fuel region

10⁴⁵ ~ 18.44 at ~ 31° " " "

10²⁰ ~ 18.56 at ~ 32.5° " " "

10²⁵ ~ 18.65 at ~ 34

10³⁰ ~ 18.69 at ~ 34.5

10³⁵ ~ 18.72 at ~ 35.0

10⁴⁰ ~ 18.74 at ~ 35.5

10⁴⁵ ~ 18.79 at ~ 35.5⁺

Started heating Island-refl. water 42 KW

10⁵⁰ ~ 18.68 ~ 36.5° fuel

10⁵⁵ ~ 18.74 ~ 37.5

Time	Outer	av. Fuel Temp
11 ⁰⁰ AM	~ 18.77	38.5 ^o C
11 ⁰⁵	~ 18.79	39.5
11 ¹⁰	~ 18.79	40.5
11 ¹⁵	~ 18.82	41.5
11 ²⁰	~ 18.82	42. (+)
11 ²⁵	~ 18.83	~ 43
11 ³⁵	~ 18.86	~ 45 ⁽⁺⁾
11 ⁴⁵	~ 18.87	~ 46.5 ⁽⁺⁾
12 ⁰⁰	~ 18.90	~ 48.5

" stopped heating fuel water

12 ⁰⁵	~ 18.65	~ 46
10	18.47	
15	18.40	
20	.35	
25	.33	
30	.30	~ 46
35	.29	47
40	18.35	48
45	18.37	48

Turn on heat (5KW) for Fuel

12 ⁰⁵	18.94	55
1 ⁰⁰	19.04	57.5
1 ²²	19.43	63
1 ³⁰	19.50	64.5
1 ⁴⁵	19.64	67
2 ⁰⁰	19.74	69

Turned off 5KW on Fuel heater

2 ¹⁰	19.18	65
2 ¹⁵	19.10	65
2 ²⁰	19.02	~ 65
2 ²⁵	19.03	—
2 ³⁵	19.02	~ 67
2 ⁴⁰	19.04	—

2. ⁴⁵

19.09 68.5
 turned heat on 5 KW.
 2⁵⁰ 19.44 71.0
 2⁵³ Turned heat off of Inytron 30 KW controller
 av. Temp (8-12) was 70.5°
 2⁵⁵ 19.85 Fuel Temp 73.5
 3⁰⁰ 20.04 " 74.75
 cut back on variac to 95% on 12 KW
 3⁰³ " " to 90% on 12 KW
 3⁰⁵ 20.10 F. Temp 74
 3¹² Turned 12 KW to 87%
 3¹⁵ 20.15
 3¹⁷ Turned 12 KW to 83%
 3²⁰ 20.35 77.5 F. Temp.
 3²⁰ Turned 12 KW to 80%
 3²⁵ " 12 KW to 70%
 3²² 20.22
 3²⁵ Turned 12 KW to 64%
 3³¹ 20.38
 3⁴² Turned 12 KW to 60%
 3⁴⁵ " " to 55%
 3⁵⁰ " " to 45%
 3⁵² 20.22
 3⁵⁷ Turned 12 KW to 35%
 4⁰¹ 20.30 78.5 F. Temp.
 4⁰⁴ Turned 12 KW to 30%

G-661

4⁰⁷ Turned 12 KW to 25%
 4⁰⁸ 20.25
 4¹¹ 20.22
 4²¹ Turned 12 KW to 20%
 4²⁷ " " to 15%
 4²⁷ 20.24
 4³⁵ adjusted position of outer control after
 allowing it to drift as is shown on
 chart. These changes may be assoc. with
 a slight drift in fuel temp.
 5⁰⁴ 20.25
 5⁰⁹ Turned 12 KW to 14%
 5¹⁰ 20.17
 5¹⁵ After last adj. continued to rise in react.
 for ~2 min. and then began to drift
 down sharply with no change in rod
 position or any observable change in
 Temp.
 5³⁸ Reached bottom of react. chips and started
 up. Rod still at 20.17 - later reversed.
 See 1C-2 chart.
 5⁵² Raised power level.
 " No observable change in any Temp
 since about 5¹⁵
 6⁰⁷ 20.28
 " Noted a slight rise in fuel Temp
 in the past several minutes.
 React went down and then back upward.

6²⁰ Adjusted control cyl: 20.22
 6²⁴ ~~20.21~~ 20.21 Reactivity dropping down
 6²⁷ 20.27
 6³⁴ 20.29 , 6³⁵ 20.27
 6⁴⁰ 20.25 , 6⁵⁰ 20.19 , 6⁵⁵ 20.32
 7⁰⁰ PM 20.29

Reactivity instability at constant temperature 20.32 — 20.19 ΔCR: .13 in.
 Fuel temp = 79°C

7⁰⁰ Turn off 5KW heat, increase variac on Refl Island system to 20
 7⁰⁵ 19.67 , 7¹⁰ 19.44 Fuel ≈ 72°C — increase variac to 25
 7¹⁵ 19.41 inc. Variac to 30. → 35
 7²⁰ 19.28 → 40. → 50
 7²⁵ 19.23 → 70
 7³⁰ 19.20 → 100 (to heat up to rising)
 35 19.15 @ 100
 36 Turn on full heat to increase ~ 1°C on for 8 minutes Refl Island 25.28
 37 Variac back to 80 T ~ const @ 72+
 7⁵⁵ 19.28
 54 Variac to 90
 8⁰⁰ 19.27
 05 19.24
 10 19.27
 15 19.27
 20

Shut down to inspect BE and start cooling H₂O from heat X. Insert safety and Outer control, start cooling H₂O and heat 90.

Insert Source,

No bubbles on BE — less than 0.2 m/hr above reactor nothing detected on floor on 2610
 H₂O is rather murky

8³⁶ Near crit again (~ 5')
 Inner Outer Safety Refl Isl X Fuel T
 8³⁵ 17.50 19.32 28.27 25.07 69°C
 8⁴² 19.22
 8⁵⁰ 19.14
 9⁰⁰ 19.10
 9¹⁰ 19.05
 20 18.99 61°C
 30 18.92
 40 .88 58.5°C
 50 .89 57°C
 10⁰⁰ .84
 10⁰⁵ .82
 10¹⁰ 18.78 57°C
 10³⁰ 18.74
 10⁴⁰ 18.74 52 1/2°C
 50 .73
 11⁰⁰ 18.70 50.75°C
 10 .68 50°C

Shut down insert control, safety source

Turn off cooling water 12KW variac to 60

11¹⁵ Sub crit 49 1/2°C
 Source out. near crit. ~~24.70~~
 20 Variac → 50
 21 18.64 21.04
 30 18.64
 35 18.64
 40 18.64 50°C

EXP # 45 (Cont.)

11⁴⁰ Turn on SKW fixed Heaters Rfl Island Variact 0
#14 point on TR-4 seems to be a

defective TC (re #37) reads 2°C low.

	Outer	Fuel Temp
11 ⁵⁰ PM	19.10	~56°C
12 ¹² AM	19.38	59°+
12 ¹⁷ AM	19.38	
12 ²⁰	19.42	59.5
12 ²⁵	19.42	
12 ³⁰	19.42	60°C (Critical)

Shut Down insert Control, Safety, Source

turn off SKW Heater

12³⁵ turn on Cooling Water

12⁴⁸ source out Approx Crit

	Outer	Fuel temp
12 ⁵⁵ AM	18.76	51°
1 ⁰⁰	18.68	50°
1 ¹⁰	18.63	49°
1 ²⁰	18.60	
1 ³⁰	18.57	
1 ³⁰	18.57	45.5°C
1 ⁴⁰	18.56	
1 ⁵⁰	18.55	44°C
2 ⁰⁰	18.55	
2 ¹⁰	18.54	42.5°+
2 ²⁰	18.52	
2 ³⁰	18.52	
2 ⁴⁰	18.53	

	Outer Control	Fuel temp
2 ⁵⁰ AM	18.50	40°
3 ⁰⁰	18.49	
3 ¹⁰	18.48	
3 ²⁰	18.48	38°
3 ³⁰	18.48	
3 ⁴⁰	18.47	
3 ⁵⁰	18.47	
4 ⁰⁰	18.49	36°
4 ¹⁰	18.48	
4 ²⁰	18.50	
4 ³⁰	18.52	35°
4 ⁴⁰	18.55	
4 ⁵⁰	18.54	
5 ⁰⁰	18.52	
5 ¹⁰	18.55	33°
5 ²⁰	18.54	
5 ³⁰	18.55	
5 ⁴⁰	18.54	
5 ⁵⁰	18.54	
6 ⁰⁰	18.56	31.5°
6 ¹⁰	18.54	31°
6 ²⁰	18.54	
6 ³⁰	18.54	30.5°
6 ⁴⁰	18.54	
6 ⁵⁰	18.54	
7 ⁰⁰	18.55	30°

Cont Next Page

6-8-61

EXP #45 CONT

Time	Outer Control	Fuel Temp
7 ¹⁰ AM	18.55	30
7 ²⁰	18.54	29.5
7 ³⁰	18.55	
7 ⁴⁰	18.55	~ 28.5
7 ⁵⁰	18.53	~ 28.5
8 ⁰³	18.55	~ 28.5
8 ¹²	18:55	~ 28.0
8 ²²	18:55	~ 28.0
8 ³⁰	18:55	~ 27.5
8 ⁴⁰	18:55	~ 27.5
8 ⁵⁰	18:55	~ 27.0
9 ⁰⁰	18:56	~ 26.5
9 ¹⁰	18:55	~ 26.5
9 ²⁰	18:55	~ 26.0
9 ²³	Shut down: insert control. SAFETY.	
9 ³⁵	Fuel water level at 30.45	
	Refl. " " "	24.92

Expt 46 shut off water to control header, Mixer on
 Raised Island-refl. H₂O to 27.65"
 10⁵⁶ cut with outer control at 17.98 Temp ~ 25.5
 out. control to 18.25 for period, T=172 → 4.05x10⁴ → 6.334
 Level at 18.03 after period $\frac{6.33}{77} = 28.8$ H₂O
 Inadvertently left fuel H₂O pump on while
 changing valves and found that water
 spurts out at top of source gauge tube

Expt. 47

Set valves for recirculation of fuel and
 island-refl H₂O
 inner outer Refl. - island Fuel 14-9 React.
 17.50 18.33 ~28 27.98 ~33
 Av. temp about 25.5°C
 Valve to main island-refl. header closed &
 inner-control header wide open
 Reactivity seems to be oscillating
 12¹⁷ Turned on 5KW to ~25% 100% after 3 min. at 25%

Time	Outer Control	Fuel Temp.
12 ²⁰	18:33	26.5°C "12207"
12 ³⁰	18:57	26.5°C 31.5°C
12 ⁴⁰	18:74	33.8°C
12 ⁵²	18.74	34.6°C
1 ⁰⁰ PM	18.79	35.0°C
1 ¹⁰	18.79	35.5°C
1 ¹¹	Turned on all heat: strong positive effect	
1 ¹³	18.37	Fuel av. 39.5
1 ¹⁴	18.49	
1 ²⁰	18.65	41.5°C
1 ²⁵	18.73	43.0°C
1 ³⁰	18.80	45.0°C
1 ³⁵	18.85	46.0°C
1 ⁴⁰	18.89	47.5°C
1 ⁴⁵	18.90	48.5°C
1 ⁵⁰	19.01	49.5°C
1 ⁵⁵	18.95	50.5°C

over

	Outer Control	H ₂ O Island Ref.	Fuel Temp
2:00 PM	18.98		51.5 Be = 35.5c 1-R-W = 47%
2:10	19.02		
2:20	19.12	27.7	
3:00	19.18		57.0°C
Heat OFF as follows			
2:31	5KW OFF	30KW OFF	12KW at 90%
2:41	30KW ON	5KW OFF	12KW at 90%
2:53	30KW OFF	5KW OFF	12KW at 90%
3:10	18:67		51.0°C
3:20	18:61		51.0°C
3:30	18:65		51.0°C
3:47	18:64	Island Ref. 27.62	51.0°C Be = 49%
4:00 PM	19.08	5KW ON at 2:48	12KW OFF 55.0°C fuel
4:11	19.16		56.0°C
4:20	19.16		
4:30	19.23	27.6	56 3/4°C
4:40	19.20	27.6	57°C
4:40	Turn on all heat (5 + 12 + 30) kW		
Immediate change of react is positive and control rod position changes rapidly for the next 5 minutes max change ~ 0.4 in			
4:50	19.26	27.6	Be = 52c 64°C
5:02	19.53		67.5
5:10	19.65		
5:25	19.74	27.6	57+ 76.5
5:41	19.90		
5:50	20.00	27.55	61.5 75.5
6:00	20.06		
6:15	20.30		66 79.5
Turn off 30KW and 5KW and set 12KW Variac @ 90 in order to level			

	Control Outer	Reflector Island H ₂ O	B & T (+16)	Fuel Temp
6-8-61 EXP 46				
6:20 PM	19.80	27.50	67°C	74.5°C
6:30	19.34	27.47	67.5	71.5
6:35	Variac	90 → 75		
6:40	19.26	27.44	68	70.5
45	.20		68.3	70.0
50	.22		68.5	70.0
55	.19		68.5	70.0
7:00	.24	27.40	68.6	70.0
5KW ON 12KW Variac To zero				
7:00 PM	19.74	27.39	69.0	73.5
20	.85			74.3
30	.95		69.0	74.5
35	.90			
40	.95			
45	.93	27.36		
Shut down to start cooling cycle. Start Cooling H ₂ O Heat off Insert Outer rod, safety and source				
<u>EXP #47</u>				
Withdraw safety and outer rod to get crit (and source)				
Shut down again to				
Open manual valve on heat exch (cooler) and close air operated feed valve.				
7:58				Start getting critical
8:05				Source out approx crit @ 19:04
8:25	18.65	27.30	67	58.0
30	.64			
40	.62		65	56
44	.58			
9:20	.56	27.30	52	60

6-8-61 EXP #47 (Continued) June 8, 1961

		Be	Fuel	
9 ³⁶ PM	18.55	58.5	51	

Shut down (to level at 55°C) Insert into
 Shut off cooling H₂O Variac at 50

EXP #48

9⁴⁵ PM Source On Island near crit @ 18.42

9 ⁵⁰	Outer Ref-Is H ₂ O	Be °C	Fuel °C	
9 ⁵⁰		27.31	58.0	54

9⁵⁵ Turn on Fuel heat 50% for 2 minutes
 Temperature should stabilize @ ~57°C

10 ⁰⁰	18.86	27.31	57.5	57.7
05	18.78	"	57.5	57.3
10	18.83	"	57.5	57.4
15	18.82			

Temp Stable

10¹⁵ 12 kW 50% → 0 5 kW on

10 ²⁵	19.27	27.3	57.5	62
10 ³⁵	19.47			
10 ⁴⁷	19.47			
10 ⁵⁵	19.47			
11 ⁰⁰	19.47	27.3	58	64
11 ⁰⁵	19.47			

Shut down Insert Outer
 control Rod and Safety.

11⁰⁰ Start cooling water through heat exchanger.

Since cooling is so slow, and since no real
 information is gleaned from monitoring at
 critical. H.F.R. #2 CE will be shut
 down until 8⁰⁰ AM. However, the
 fuel H₂O will be left circulating as
 well as the Ref. Island H₂O.
 Scrums will be left to dump
 fuel H₂O if necessary.

8:15 AM Exp #49 6-9-61
 Inst checked Response OK

Purpose: Check level at critical - After cooling

8 ⁴⁰	Cycle fuel temp	32°
	Source out Approx	Crit
	control outer	Fuel temp
		32+ C
8 ⁵⁰	18.37	
9 ⁰⁰	18.36	
9 ¹⁰	18.37	32.5°
9 ¹⁰	18.37	32.5°
	critical	
	TURN ON 5 KW	Heater

Cont Next Page →

8
6-9-61

Time	Control Outer	Fuel Temp
9 ¹⁵ AM	18.54	
9 ²⁵	18.74	39°
9 ³⁵	18.80	40.5
9 ⁵⁰	18.86	
10 ⁰⁰	18.87	41.5 ⁺
10 ¹⁵	18.86	42.0 ⁻
10 ¹⁸		


Ref. Island
Is. H₂O Be Control
27.38 34.5 ~36

shut down & turned off circulation

Water heights	Ref. Is.	Fuel
	27.57	33.40

Drain water systems. - Removal Target

6-12-61
Removed all ion chambers, and noted that condensate had gotten into all, with one battery box shorted out and another measured weak. These battery ~~boxes~~ were replaced. The ion chambers were re-installed in long plastic bags with the opening outside the tank so that no moisture should get in the ion chamber thimbles



6-12-61
Lead bricks in the H₂O were covered with a corrosion deposit, almost a greasy or soapy like product. Spectrographic analysis show lead, Be, Al and lots of impurities. Further work is being done. (These lead bricks were holding down the thimbles, now they are inside the thimbles)

Exp # 50 6-12-61
(Inst check OK)

10²⁸ AM Purpose: Critical position with Target removed
Source in - Inst Response OK

Inner Blade 17.50" Outer Blade 0"
Safety Blade up 28.25"

10³¹ Start Pumping up Island Refl H₂O

11⁰² Fuel H₂O @ 28.75, Start with drawing outer control.

Outer control @ 18³⁰ Insert safety for response, OK.

11¹⁸ Outer = 29.87 approx critical

11²⁴ Outer = 29.93 critical Insert outer

Insert source, set inner control @ 22.00

Fuel H₂O @ 28.56, Refl Island @ 27.32

EXP # 51

	Inner	Outer	F.C	Refl Is	Fuel	Is-4	React
11:47	22.00	17.53	10.01	27.18	28.46	2 x 10 ⁻¹⁰ Max	+1565 → 4.4 x 10 ⁻⁴ → 6.864
11:54		17.27					T = 26 1/2 °C
11:54		17.27		27.24	28.47	2 x 10 ⁻¹⁰	Level 26.54 in

Insert Outer, Insert source set

EXP # 52

6-12-56 Purpose: Critical with plates more asymmetrical
Source In, set Inner @ 19.75.

	Inner	Outer	F.E	Refld	Fuel	IC-4	React
12 ¹⁹ pm	19.75	19.50	10.01	27.20	28.44	$\frac{6 \times 10^{-10}}{700 \text{ sec}}$	$+104.3 \rightarrow 6.1 \times 10^{-4} \rightarrow 9.53 \phi$
12 ³⁵		18.99				6×10^{-10}	Level

$9.53 / .51 = 18.7 \phi / \text{in.}$

By-pass w/ interlock on Inner Rod.

19.50	18.99	27.17	28.39	~ Negative Period.
-------	-------	-------	-------	--------------------

Negative periods are curved

start	19.50	19.25					Nearly Level, $\sim 2 \times 10^{-11}$
12:51	19.50	19.50	10.01	27.17	28.36	5×10^{-10}	$+598 \rightarrow 1.31 \times 10^{-4} \rightarrow 2.05 \phi$
12:51 pm	19.50	19.38	10.01	27.22	28.32	5×10^{-10}	Level.

$T = 255^\circ\text{C}$ $\frac{2.05}{.12} = 17.1 \phi / \text{in.}$

Insert control, remove interlock
Drain H₂O in Fuel Region -

EXP # 53

Purpose: Reproducibility of critical position

~ 2 ¹⁵	19.50	19.50	10.01	27.23	27.62	2×10^{-9}	$+1715 \rightarrow 4.07 \times 10^{-4} \rightarrow 6.36 \phi$
	19.80	19.13	"	"	"	"	Level

$\frac{6.36 \phi}{.37} = 17.2 \phi / \text{in.}$

	Inner	Outer	F.E	Refld	Fuel	IC-4	React
19.50	19.50		21.26			2×10^{-9}	Level

Drop power to 10^{-11} with outer control

19.50	19.35					2×10^{-11}	Approx. Level.
19.50	19.95	21.26	21.24	27.62		2×10^{-9}	$+1335 \rightarrow 5.0 \times 10^{-4} \rightarrow 7.81 \phi$
	19.50						17.4 $\phi / \text{in.}$ Level

Inner Outer Safety Refld Fuel IC-4

2 ³⁴	19.50	19.95	20.35	27.25	27.62	2×10^{-9}	
-----------------	-------	-------	-------	-------	-------	--------------------	--

$T = 25\frac{1}{4}^\circ\text{C}$

Lower power to $\sim 2 \times 10^{-11}$

4 ⁰⁴	19.50	19.73					\sim critical
	19.50	20.45					Pos Period

$T = 25\frac{1}{4}^\circ\text{C}$

$+139s \rightarrow 4.85 \times 10^{-4} \rightarrow 7.58 \phi$

4 ¹⁵	19.50	19.94	20.35	27.29	27.62	$\sim 2 \times 10^{-9}$	
-----------------	-------	-------	-------	-------	-------	-------------------------	--

Insert control,

$\frac{7.58}{.50} = 15.2 \phi / \text{in.}$

6-13-61 IC-4 ion chamber had high leakage current $\sim 2.5 \times 10^{-9}$ at 8⁰⁰ AM
last evening it was 2.0×10^{-10}

6-13-61 INST Check

IC-1 Fuel & MTR Trig OK

IC-2 MTR Trig OK

-3 7×10^{-11}

-4 6×10^{-11}

PM-1 Lo - Scram dropped safety

1 Hi - Trig OK

PM 2 10 mc Rad B₀ Source on top of detector $< 1 \mu\text{a}$ resp.

6-13-61 EXP # 54

Purpose: Temperature coeff without target.

Set inner control plate @ 22.00, withdraw safety to 28.25

Insert source. IC-3 = 9×10^{-13} , IC-4 = 4.5×10^{-13}

Reflet - Isd H₂O 27.51 -5.5×10^{-13} 2×10^{-12}

All temperatures printing $25^\circ\text{C} \pm \frac{1}{2}^\circ$

Fuel H₂O to 32.0 1×10^{-12} 2.8×10^{-12}

Set valves for circulation in both systems
Reflet - Isd all flow valves to 20 with H₂O H₂O Fuel

Inner Outer Safety Refl Isd Fuel Temp IC-4

9:00 PM 22.00 999.82 28.25 27.49 31.22 24.8°C

9:10 ~16 31.15

Insert Outer to pinch tubing on Fuel lig. level.

9:20 Source Out.

9:31 22.00 17.12 28.25 27.34 X 25.0°C 2×10^{-10}

Start Circulation in reflector-island only

9:40 17.35

9:45 17.37 25.0°C

6-13-61 Inner Outer Refl - Isd Fuel
~~Outer~~ ~~Inner~~ Safety Fuel H₂O Temp IC-4

9:45 Start circulation in Fuel system.

9:52 22.00 17.37 28.25 27.18 25.4 2×10^{-10}

9:55 22.00 17.39 " " 25.8

Shut down by inserting Outer Control

9:55 Start 5 KW heat on, start stirrer motor

10:01 Start Insert Source

EXP # 55

10:01 Start withdrawing Outer Control plate

10:12 Source Out.

10:20 22.00 17.76 28.25 27.18 34.5°C 2×10^{-10}

10:25 .79

10:30 .80 35.2°C

Be Temp = 26.4

AT = 8.8

17.80 - 17.39 = 0.41

0.41 / 8.8 = 0.0466

Start Heat Refl. Isd. 30KW + 12KW

10:40 ~17.46 41.0°C

50 .60 45.2°C

11:00 .67 47.5°C

10 .68 49.5°C

20 .69 51.0°C

30 .70 52.7°C

Turn off all heat.

BL (15)

40 17.55 44°C 38°C

50 17.28 41°C

12:00 17.25 39.5°C @ 38°C

10 17.25 39.5°C @ 38°C

15 17.245 39.8°C 38 +

20 17.245 39.0°C

25 17.24 27.04 39.0 38.5

Turn on 5KW heat in Fuel Region

12:25 17.61 45.5

12:45 17.66 46.2 39°C

Exp #55 (Cont)

	INNER	OUTER	REFL. H ₂ O	Be Temp	Fuel Temp
6-13-61 12 ⁵⁰ PM	22.00	17.67	27.05	39	46.6
1 ⁰⁰	"	17.71	27.03	39.1	47.2
1 ¹⁰	"	17.74	27.05	39.5	47.5

1¹⁰ All HTRS ON. $\Delta T = 8.0^\circ C$

$$\frac{17.74 - 17.24}{8.0} = 0.0625 \text{ in}/^\circ C$$

1 ²⁵	22.00	17.58	27.03	40.7°C	55.5
1 ⁴⁰		17.75			
2 ⁰⁰		17.79			
2 ²⁵		17.86			
2 ⁴⁰	22.0	17.88	26.97	52.2°C	67°C

2²⁰ PM Heat off except 12 kW @ 25% 50%

40	17.41		54	56.1
45	(17.32) ~		54.3	55.1
3 ⁰⁰	17.25	26.89	54.4	55.1
3 ¹⁵	17.24		54.4	55.1
3 ³⁰	17.24		54.4	55.1

5 KW Heat ON 12 kW @ 0

3 ³⁰	17.74			
3 ⁴⁵	.82		55.0	62.0
3 ⁵⁵	.85		55.0	57.0
4 ⁰⁰	.85		55.0	62.0

4⁰⁰ Turn all heat ΔT_2

Exp #55 Cont 6-13-61

4 ¹⁰ PM (Cont)	INNER	OUTER	REFL H ₂ O	Be Temp	Fuel Temp
22.00"		17.72"	26.85		
4 ¹⁵	"	17.84	26.87	56.5°C	70°C
4 ²⁵	"	17.97	26.87	58.5°C	73°
4 ³⁵	"	18.03	26.85	60.°	74.5°
4 ⁴⁵	"	18.09	26.80	62.	76.5
4 ⁵⁵	"	18.17	26.80	63.5°C	78.° C
5 ⁰⁵	"	18.20	26.79	65.5	80.
5 ¹⁵	"	18.25	26.75	67.0 C	81.5°C
5 ¹⁷	"	18.25	26.75	67.5°C	81.5°C

turn off 5 KW Heater
" " 30 KW Heater

turn Variac ON 12 KW Heater to 75

5 ²⁵	"	17.92	26.70	68.5°C	75.° C
5 ³⁵	"	17.55	26.68	69.3°	72.5°
5 ⁴⁵	"	17.47	26.66	69.8	71.5
5 ⁵⁵	"	17.48	26.64	70.	71.5
6 ¹⁰	"	17.48	26.62	70.2	71.

turn ON 5 KW Heater

turn Variac ON 12 KW to 0

6 ²⁰	"	17.98	26.59	70.5	74.
6 ³⁰	"	18.08	26.57	70.5	76.
6 ⁴⁰	"	18.14	26.56	70.5	76.5
6 ⁴⁵	"	18.14	26.55	70.5	76.5
6 ⁰⁰	"	18.14	26.51	70.8	76.7

turn OFF 5 KW AND 12 KW Heaters

Cont ON Next Page

7⁰³ PM Shut Down - Insert outer control, Safety + Source
 7⁰⁸ turn ON Cooling H₂O
 7¹⁰ turn off Pump to fuel Region to check H₂O level - 31.54
 7¹⁴ turn ON Pump to fuel Region
 "Note" Island Refl H₂O Ht was checked just before H₂O Ht in fuel Region AND measured 6.25" Above Be - liquid level ^{Indicator} appeared to be OK.

Time	INNER (control)	outer	Refl H ₂ O	Be temp	fuel-temp
8 ⁰⁸	22.0"	17.25"	26.46		
	Source out	Approx Crit	EXP #56		
8 ¹⁰	22.0"	17.15"	26.46	66° C	57° C
8 ³⁰	22.0"	17.22"	26.46	64	56.2
8 ⁴⁵	22.0"	17.22"	26.46	63	55.2
9 ⁰⁰	22.0"	17.20"	26.45	61.5	54.0
9 ¹⁵	22.0	17.21"	26.44	60.	53.
9 ²⁴	22.0	17.20"	26.44	59.	52.5

Shut Down Insert outer control, Safety, Source

10⁴⁵ Cooling H₂O turned Off
 11⁰³ turn ON 5 KW Heater
 11⁰⁶ " off 5 KW Heater
 11⁰⁸ 22.0 17.31 Source out Approx Crit
 11¹³ 22.0" 17.22 26.47 52.5° C 52° C
 11²⁵ 22.0 17.22 26.47 52.5 52

Cont Next Page

Time	INNER (control)	outer	Refl H ₂ O	Be temp	fuel temp
11 ³⁰ PM	22.0"	17.22"	26.47	52.5° C	52° C
	turn ON 5 KW Heater				
11 ⁴⁰	22.0	17.55"	26.47	52.5	57
11 ⁴⁵	22.0	17.65"	26.47	52.5	58
11 ⁵⁵	22.0	17.68"	26.47	52.5	59
12 ⁰⁰	22.0	17.72"	26.47	52.5	59
12 ¹⁰ AM	22.0	17.72"	26.47	53.	59.3°

Shut Down - Insert outer control, AND Safety, Dump fuel H₂O - (turn off Pump) turn ON Cooling H₂O (turn off 5 KW Heater)

8¹⁰ AM 6-14-61 Cooling H₂O OFF
 Be Temp ~ 35° C.

8⁴⁰

Inst Check.

DC - 1
 6-14-61 - 2 MTR Trip OK scrambled Safety & drain
 - 3 4.6 x 10⁻¹¹
 - 4 5.0 x 10⁻¹¹
 PM-1 H: & Lo Trip
 PM-2 Less than 1µs response.

~~26.50~~ Redrtn ~ 26 1/4
 9⁰⁰ Measured H₂O = 4.5 in in Reflector
 Increased H₂O in Refl Island to 27.50
 Restarted circulation 27.41 #

~ 8³⁰ Fuel Water pumped up and circ started
 31.52 Fuel H₂O height

EXP #57

Purpose: Temp Cuff without target.

Source in Inner @ 22.00, safety withdrawn, outer control withdrawn to get critical

9⁴⁸ am Source Out

	Inner	Outer	Safety	Ref. Isl.	Temp Be(16)	Fuel(1-2-3-4)
22.00					34.1	34.6
10 ⁰⁰	17:11		28.25		34.0°C	@ 34.6°C
10 ¹⁰	17:12		"		34.0°C	@ 34.6°C
10 ²⁰	17:14		"		"	"

	INNER	OUTER	SAF	REF. ISL.	Be °C	Fuel
10 ²⁰	Start Heating Fuel H ₂ O SKW ON					
	22.00		28.25	27.25		
10 ⁴⁰	17.53	17.53		27.25	34.3	42.0°C
10 ⁵⁰	22.00	17.56	28.25	27.21	34.5	43.0
11 ⁰⁰		17.62			34.5	43.4
11 ¹⁰	"	17.61	"	27.21	34.6	43.6

11 ¹⁰	all heat on					
11 ²⁰		17.47	"	27.25	37.	53
40		56				
50		62				
12 ⁰⁰		17.65			43.2	59.2

12 ⁰⁴	all heat off except 12kW @ +3%					
12 ¹⁰		17.52			44.6°C	@ 53.0°C
20		17.29			45.2	49.0°C
30		17.10		27.13	45.5	47.2°C
45		17.08			45.7	48.0°C
50		.07			"	"
55		.08		27.11	"	"

12 ⁵⁵	5kW	on	12kW	→	OFF	
1 ¹⁰		17.55			46.3°C	52.5°C
20		17.62			46.5	54.1°C
30		.65			46.6	54.5°C
40		.66				54.9°C
45		.66			46.9	55.0°C

Exp 57

all heaters on (5+12+30)KW

Time	outlet	Be	Fuel
1:45			
1:51	17.53	98.0°C	61.5°C
2:05	17.66	99.0°C	63.5°C
2:18	17.77	51.5°C	66.5°C
2:34	17.85	54.5°C	69.0°C
2:40	17.89	55.5°C	70.5°C

2:48 all heat off except 12 KW @ 70%

Time	outlet	Be	Fuel
2:55	17.77	58.0°C	65.5°C
3:05	17.34	58.6°C	62.0°C
3:15	17.25	59.1°C	61.5°C
3:25	17.20	59.2°C	61.0°C
3:30	22		
3:35		59.5°C	61.0°C

5 Kw on 12 Kw off.

3:45	17.78 17.70	60°C	65°C
3:55	17.82	60.0°C	66.1°C
4:05	17.83	59.5	66.5
4:15	17.85	60	67
4:25	17.85	60.5	67

4:27 turn All Heat ON 5, 12, 30 KW
Cont Next Page

Time	outlet control	Be temp	Fuel temp
4:30 PM	17.53	60.5°C	69°C
4:40	17.82	61.2	72
4:50	17.95	62.5	73.5+
5:00	18.00	63.5	75
5:10	18.02	65	76
5:25	18.09	66.5	78.5
5:35	18.14	67.8	79.

turn off 5 and 30 KW Heaters

turn variac ON 12 KW Heater to 75%

5:45	17.62	68.8	71.5°
5:55	17.38	69.0	69.0°

turn variac ON 12 KW Heater to 83%

5:58			
6:00	17.37	68.7	68.8°
6:10	17.30	68.5	68.2

turn variac ON 12 KW Heater to 95%

6:12			
6:27	17.32	68.5	68°
6:40	17.37		67.5+

turn variac ON 12 KW Heater to 100%

turn ON 5 KW Heater variac to 15%

6:45	17.35	68.3	67.5°C
6:55	17.38	68.1°C	67.5°C
7:00	17.36	68.1	67.5

turn ON 5 KW 100% (12 KW to 0)

7:10	17.80	68.0°C	72.0°C
7:20	17.94	68.0	73.5

cont next Page

	outer Control	Be temp	Fuel temp
7 ³⁰	18.00"	68	74°
7 ³⁵	18.02	68	74.3
7 ⁴⁵	18.05	68.5	74.5
8 ⁰⁰	18.05	68.5	74.8

Shut Down - Insert outer control, Safety, Source
 Turn off 5 KW Heater
 8⁰⁵ turn ON Cooling H₂O

Island Refl H₂O Measured 6 1/4" Above
 Be - liquid level indicator 26.60"



Exp # 58 6-14-61

Purpose: - Check Point ON Cooling / Cycle
 Turn off Cooling H₂O

	outer Control	Be temp	Fuel temp
10 ¹⁵	to Source out	Approx level	
10 ²⁵	17.16	53	52.2°C
10 ²⁸	17.17	53	52.2°C
10 ³⁰	17.19	-	-
10 ⁴⁰	17.20	53	52.5
10 ⁵⁰	17.20	53	52.5
11 ⁰⁰	17.20	53	52.5
	Turn ON 5 KW Heater		
11 ¹⁰	17.56	52.7	57.5
11 ²⁰	17.73	52.7	59
11 ³¹	17.77	52.9	60

Cont Next Page

	outer Control	Be temp	Fuel temp
11 ⁴⁰	17.77	53	60
11 ⁵⁰	17.84	53.2	60.5
12 ⁰⁰	17.82	53.5	60.8

Shut Down - Insert Outer control, AND Safety
 Turn off Pump AND Dump fuel H₂O
 Turn ON Cooling H₂O (Turn off 5KW Heat)

8²⁰ AM JUNE 15, 1961

Liq. Level = 26.75, Refl. H₂O = 4 3/4 in above Be
 Temperature ~ 29.5°C

N.B. The four temperature runs were made with the following flow conditions

- ① Partial Refl. Sol circ thru dist. Header
- ② Full circ flow thru dist header only.
- ③ " " " " " " " "
- ④ " " " " " " " " for crit.

Header for cooling on last run circulation through the 1/2 line in tank aided in cooling faster.

1⁰⁵ PM Purpose: Check Critical At Rm Temp
 turn off Cooling H₂O
 Inst checked Response OK.
 Close Main Circ Valve AND Direct All
 Circ through header.
 H₂O Above Be measured 4 5/8"
 Liquid level indicator 26.72
 Valves changed to pump H₂O into fuel Region
 Source in Inst Response OK

1²⁵ H₂O in fuel Region 31.63. Set values
 to circulate thru Header AND start Pump
 Source out

	INNER (control)	outer	Approx Island Ref1	Crit fuel Ref1	Be temp	fuel temp
	22.00	17.35	26.55	31.55	24.5 C	26 C
1 ⁵²	22.00	17.28	26.55	31.55	24.5	25.8
2 ⁰⁰	22.0	17.30	26.57	"	24.5	25.5
2 ¹⁰	22.0	17.29	26.58	"	24.5	25.5
2 ²⁰	22.0	17.30	26.54	"	24.5	25.5
2 ³⁰	22.0	17.31	26.56	"	24.5	25.5

TURN ON 5 KW Heater

2 ⁴⁰	22.0	17.53	26.55	"	25.0	31.0
2 ⁵⁰	22.0	17.65	26.58	"	25.2	33.5
3 ⁰⁰	22.0	17.69	26.57	"	25.5	34
3 ¹⁰	22.0	17.68	26.55	"	25.5	34.8
3 ¹⁵	22.0	17.68	26.57	"	25.5	35.

Shut Down, Insert outer Control, Safety, AND Dump
 fuel Refl H₂O. turn off 5 KW Heater

June 19, 1961

Report on Smears on wall of tank
 and inst thimble for Be content
 Tank Wall 1ug Be
 Thimble " 2ug Be
 no hazard from this except for
 dry brushing which would get
 the corrosion dust airborne.

Recommend cleaning when wet,
 (by telephone from J. Mouchad)
 SWH

June 19, 1961

Water systems were drained and the dump tanks
 cleaned. New water was added, however
 the purity of the water was not as good as
 previously obtained, cond. meter on Cronins
 deionizer read 1 MA at end of cycle.
 This is not very good H₂O. Analysis on Friday
 read 4.86×10^{-5} mho/cm = 1 MA.

Analysis Monday on tank water (Mixture of
 all water in our drain tank. 4.7×10^{-5} mho/cm
 there was about 14 in of water added today.
 Analysis of H₂O in drain tank 4.7×10^{-5} , 34.2, 26 g solid

June 19, 1961

Add 100 ml of triton x-100 to water in the Island Reflector system and mixed

Add 5 ml of triton x-100 to the water in the fuel system and mixed
 $\frac{5}{12} \times 90 = 38 \text{ ppm}$

N.B. The Reflector-Island system seems to foam more than previously ~ 25 ppm of wetting agent.

June 20, 1961

Instrument Check

- IC-1 Fast Trip OK
- 1 Meter Trip OK
- 2 Meter Trip OK
- 3 Response OK
- 4 " "
- PM-1 Hi Trip OK
- 2 Lo Trip OK - Scrammed - Drop Safety & dump H₂O

JUNE 20, 1961 EXP #60

PURPOSE: ROD CALIBRATION - TARGET REMOVED
outlet at 999.8

Scrams act, safety withdrawal, Inner control act at 22.00.

Ref. Island H₂O plunged up, Fuel H₂O plunged up.

Safety dropped light now working, IC-3 & 4 calib OK

7-7-61 (5 thermocouples in Target) ΔT (TR-4)
Removal of 102. ISL FUEL Average
 INNER OUTER SAFETY REFL Temperatures

8 ⁵⁵	22.00	999.81	28.24	27.53	31.4
					30.2

9⁰⁷ Add fuel H₂O 27.46 31.1 pinch
 manometer tubing

9¹⁰ Start circulation in fuel H₂O and Refl-Is. H₂O

9²⁴ Source out IC-2 ~ $6.5 \times (3 \times 10^{-11})$

Turn off circulation pumps, system is warming slightly from pumping.

9 ⁴⁷	22.00	17.04	27.30	31.20	(Approx Crit)
	..	17.24	25.4 (Pos Per)
10 ¹¹	..	17.03	Level
10 ³²	..	17.24	(Safety 21.31)	..	Level
10 ³⁵	..	17.77	Reduce Power
11 ⁰⁶	..	17.21	(Approx level)
11 ⁰⁸	..	17.44	(Pos Per)
11 ²⁵	..	17.44	(Safety 20.52)	..	(Approx level)
11 ³⁴	..	17.44	..	20.50	(Level)
11 ³⁷	..	16.50	..	20.50	(Reduce Power)

cont Next Page →


	Inner	Outer	Safety	251 Refl	fuel Refl	Ave Temp
1159	22.00	17.37	20.50	27.28	X	
1201	Start Pos Period					24.5
12 ¹⁴ _p		17.64	Start to level w. Safety.			
12 ³¹ _{pm}	22.00	17.64	19.97	27.28	X	
31	Start to lower power with Outer control.					
~36	start to	15.98	level with outer control.			
42		(17.57)			IC-4	
1 ⁰⁰	22.00	17.57	19.97	27.28	$\times 2 \times 10^{-11}$	24.1
1 ⁰¹	22.00	17.84	19.97	27.27	(Pos Per)	
1 ³⁰	22.00	17.84	19.58	27.27	level	
1 ³²	"	16.53	19.58	"	Reduce Power	
1 ⁵⁴	"	17.76	19.58	"	level	
1 ⁵⁸	"	18.04	19.58	"	Pos Per	
2 ¹⁵	"	18.04	19.27	"	24.1	
2 ²⁸	"	18.04	19.26	"	level	
2 ³⁹	"	16.75	19.26	"	Reduce Power	
2 ⁵⁹	"	17.98	19.26	"	2.5×10^{-11}	
3 ⁰⁰		18.24	19.26	Start Pos. Period		
3 ¹⁶		18.24	19.26	end of period		
3 ¹⁹		~(17.05)	28.25			
3 ³¹	22.00	17.025	28.25	27.27	2×10^{-9}	level
Shut Down Insert Control, Safety, And Dump fuel Refl H ₂ O						

EYP #60 Rod Calibration Summary

17.24	8.30 DIV/sec.	180.43 sec	3.89×10^{-4}	6.08	11.91
.44	8.73	189.7	3.73	5.83	17.52
.64	9.10	197.7	3.59	5.61	22.86
.84	9.60	208.6	3.42	5.34	28.06
18.04	9.90	215.1	3.33	5.20	33.01
18.24	10.50	228.2	3.17	4.95	
					33.01

For these calculations J^{235} delayed neutrons only were used to determine react. from stable periods.

D.W.M.



June 21, 1961

IC-4 Beckman Log Amp replaced by ORNL Log Amp. Brown 2 pin recorder tubes replaced.

Inst Check

IC-1 Fast OK Tripped H₂O Fuel Drain and Dropped Safety

-1 MTR Trig OK

-2 MTR " OK

-3 Response 5x10⁻¹¹"

-4 " 6x10⁻¹¹"

PM-1 Hi Trig OK

-1 Lo " "

-2 No response.

EXP #61

PURPOSE: Control Plate Calibration Outer vs. Inner
set inner to 22.0

Withdraw safety, insert source, raise reflector H₂O to 27.6, Fuel to 32.6,

after open circ valves Fuel 31.3 inches, pinch tubing to sig. level. set valves on Refl Island for circulation

9³⁸ AM Start circulation in Refl Island H₂O and Fuel H₂O

9⁵² Stop Circulation - Bypass interlock on inner control.

9⁵³ Source out approx crit.

	Inner	Outer	Safety	Refl H ₂ O	Ave Temp	IC-3	
10 ²⁰	22.04	17.03	28.25	27.44	24.8	3x10 ⁻¹¹	level
10 ²¹	"	17.24	"	"	"	"	Pos Per
10 ⁴⁷	22.04	17.03	"	"	"	1x10 ⁻⁹	level
10 ⁵⁸	21.51	17.24	"	"	24.5	1x10 ⁻⁹	level
10 ⁰⁰	21.51	16.50	"	"	"	"	Reduce Power


Cont Next Page

	Inner	Outer	Safety	Refl H ₂ O	Ave Temp	IC-3	
11 ²⁶	21.51	17.19	28.25	27.42	"	1.4x10 ⁻¹¹	
11 ²⁶	21.51	17.44	"	"	24.5°C	"	+ Pos Per.
11 ³⁹	Start to level with inner control plate.						
11 ⁵²	21.13	17.44	28.25	27.41	"	1x10 ⁻⁹	Level
11 ⁵²	Reduce power with Outer control to 16.01.						
11 ^{56 1/2}	Start to level with outer control.						
12 ¹⁴ PM	21.13	17.39	28.25	27.44	"	9x10 ⁻¹²	Level
12 ¹⁴	"	17.64	"	"	24.7°C	"	Start + finish
	21.13	17.64	28.25	"	"	"	END + finish
12 ⁴²	20.83	17.64	"	27.42	"	1x10 ⁻⁹	level
12 ⁴⁴	20.83	16.34	"	"	"	"	Reduce Power
1 ⁰²	20.83	17.59	"	"	"	1.2x10 ⁻¹¹	level
1 ⁰³	20.83	17.84	"	"	"	"	Pos Per
1 ³²	20.58	17.84	"	"	24.9°	1x10 ⁻⁹	level
1 ³³	"	16.34	"	"	"	"	Reduce Power
2 ⁰⁰	"	17.80	"	"	"	1x10 ⁻¹¹	level
2 ⁰²	"	18.04	"	"	"	"	Pos Per
2 ³⁰	20.36	18.04	"	"	24.5	1x10 ⁻⁹	level
2 ³³	"	16.49	"	"	"	"	Reduce Power
2 ⁵⁸	20.36	17.99	"	"	"	1.1x10 ⁻¹¹	level
3 ⁰⁰	20.36	18.24	"	"	"	"	Pos Per
3 ³¹	20.155	18.24	"	"	24.1°	1x10 ⁻⁹	level
3 ³⁸	22.07	17.03	"	"	"	1x10 ⁻⁹	level

Shut Down - Insert Control AND Dump fuel Refl H₂O

EIP #61 Summary

Innen	Outer	React					Σ S
		Div/Dec.	sec		d		
22.04	17.03	0					
22.06	17.24	8.10	176.0	3.97×10^{-4}	6.20		
21.51	17.44	8.53	185.4	3.80	27.51	5.94	12.14
21.13	17.64	9.00	195.6	3.63	21.57	5.67	17.81
20.83	17.84	9.40	204.3	3.49	15.90	5.45	23.26
20.58	18.04	9.73	211.4	3.38	10.45	5.28	28.54
20.36	18.24	9.97	216.6	3.31		5.17	33.71
20.185	18.24	0					



June 22, 1961

ORNL-log Amp removed from IC-4 chamber, and Beckman log Amp back in service - trouble was in recorder Servo amplifier tubes bad.

Thermo couples in Target-Island region 8,9,11,12,14 on TR-4 cut and poked down below target area and Target ~~is~~ re installed in assembly.

Inst Check

- 1 Fast Trip OK
- IC-1 MTR " "
- 2 MTR " " Trip during test & Safety.
- 3 4×10^{-11} response OK
- 4 6×10^{-11} " "
- PM-1 HI Trip OK
- Lo Trip OK
- PM-2 No Resp.

Av. of cl,

Log N amp. Calib Check OK.

TR-4 and TR-5 checked with TC in control room and TC in H₂O bath with thermometer
TR-5 corrected $\bullet \frac{1}{2}$ and TR-4 3°C off.

EXPERIMENT #62

JUNE 22, 1961

PURPOSE: Control plate calibration for the displacements observed in the temperature coeff. runs with target. Bypass seal on inner control plate. (F.C. in Fuel element)

Red light on & personnel check OK
Inst screws set, power in, inner control @ 17.50, safety withdrawn
Fast Refl-Island H₂O raised to 27.7, Fuel H₂O to .32.

Circulate fuel H₂O for 1 Min., open again H₂O = 30.15.

11²⁵ Start circulate Fuel H₂O and Reflector - Island.
11⁴⁵ Stop Circulation in fuel Region 11⁵⁵ Stop Ref. In.
inner - outer Safety Refl H₂O Fuel H₂O Temp

17.50 17.24 28.25 27.53 30.2

Source out Approx Crit At 11³⁴ AM

11⁵⁰ 17.50 17.23 28.25 27.53 30.2
11⁵⁹ 17.50 17.21 28.25 " " 23.0
12⁰¹ 17.50 17.41 " " " " Pos Per

12¹¹ start to level with outer
12²⁵ 17.50 17.193 28.25 27.51 X 23.0 Level
12³⁰ 17.375 17.41 ~~23.0~~ Level

Reduce power 100 with outer and level
12⁵⁵ 17.375 17.36 1×10^{-11} level
12⁵⁷ " 17.61 Pos Per
12⁵⁸ 17.255 17.61 level
12⁵⁹ 17.255 16.34 Reduce Power

IC-3 Calib OK $9 \times 10^{-12} \rightarrow 7 \times 10^{-9}$ (diode has shifted)
IC-4 Calib OK

Cont Next Page

	inner	outer	safety	island Refl H ₂ O	Ave temp
1 ⁴⁵	17.255	17.56	28.25	27.48	23° level
1 ⁴⁷	17.255	17.81	Pos Per
2 ¹⁴	17.148	17.81	level
2 ¹⁷	17.148	16.50	Reduce Power
2 ⁴³	17.148	17.77	level
2 ⁴⁴	17.148	18.01	Pos Per
3 ¹²	17.04	18.01	level
3 ¹²	17.04	16.50	Reduce Power
3 ³⁰	17.04	17.97	level
3 ³¹	17.04	18.21	Pos Per
4 ⁰⁸	16.94	18.21	level

Call on IC-3 & 4 OK

4¹⁷ 17.49 17.21 28.25 27.47 level
 Shut Down Insert Control, Safety
 Fuel H₂O level after run = 30.14

Insert Check on 6-23-61

IC-1 MTR Trip OK
 Fuel Trip OK
 2 MTR TRIP OK Burn Safety and drain Fuel H₂
 3 ~ 3x10⁻⁴"
 4 ~ 6x10⁻⁴"
 DM-1 Hi Trip OK
 1 Lo Trip OK

8⁵⁰ EXPERIMENT #63 - Purpose: CONTROL PLATE CALIBRATION
 INNER Control Moved to 17.50"
 Source in Inst Response
 Safety Raised to 28.25"
 9⁰⁰ Island Refl H₂O Raised to 27.76
 9²⁰ H₂O in fuel Region Raised to 30.83
 Start Circulating in Island and fuel Regions
 9³⁸ Stop
 Source out - Island Refl H₂O 27.60

	inner - outer	Ave temp	Notes
	17.50 - 17.26	23°	verit. low power
9 ⁴¹	17.50 - 17.41		Pos Per
10 ⁰⁸	17.50 - 17.208		level
10 ²¹	16.948 - 18.21		level
10 ²³	16.948 - 16.22		Reduce Power
45	16.948 18.16		level 3x10 ⁻⁴ "
10 ⁴⁵	16.948 18.48 18.42		Pos Per
11 ¹⁴	16.84 18.42		level
11 ¹⁵	16.84 16.50		Reduce Power
11 ³⁴	16.84 18.37		Approx level
11 ³⁵	16.84 18.64		Pos Per

Cont Next Page

11 ³⁶	Island Refl H ₂ O	27.57	Ave temp
	INNER - Outer		22.5°C
12 ⁰¹	16.745 -	18.64	level
	"	17.50	Reduce Power to ~ 2 x 10 ⁻¹¹ on IC-4
12 ⁰⁸	start to level		
16	16.745	18.57	level at response
40	16.745	18.87	Pos Perial
12 ⁵⁴	16.645	18.87	level
	16.645	18.50	Reduce Power
1 ¹⁸	16.645	18.82	level
1 ¹⁹	16.645	19.10	Pos Per
1 ⁴⁷	16.55	19.10	level
	16.55	17.35	Reduce Power
2 ⁰⁸	16.55	19.38	level
	16.55	19.38	Pos Per
2 ³³	16.45	19.38	level
2 ³⁴	16.45	17.50	Reduce Power
2 ⁵⁸	16.45	19.30	level
2 ⁵⁹	16.45	19.68	Pos Per
3 ²⁸	16.348	19.68	level
3 ²⁹	16.348	17.50	Reduce Power
3 ⁴³	16.348	19.61	level
3 ⁴⁶	16.348	20.00	Pos Per
4 ¹²	16.248	20.00	level
4 ²¹	17.50	17.19	level

Island Refl H₂O 27.57 Fuel H₂O = 30.00
 Shut Down Insert outer Control, Safety

6-26-61 Inst. Check

- IC-1 Fast Trip Scrammed
- 1 Meta Trip OK
- 2 MTR Trip OK
- 3 3 x 10⁻¹¹
- 4 6 x 10⁻¹¹
- PM-1 HI Trip OK
- 1 LO Trip OK
- PM-2 No Response.

Expt 64

6-26-61

Check on reproducibility of Expt 63
 Inner control moved to 17.50
 Safety raised to 28.2cc
 Source in (first step) inst. response noted
 Refl. island water raised to 28.75
 Raised fuel H₂O to 32.4
 Started circulation of fuel H₂O 11⁰⁶
 Stopped " " " 11²⁰
 Inner outer
 17.50 Fuel Temp 22.5 -
 17.50 17.21 Level
 Shut down by lowering safety and
 Outer control to zero.
 Island H₂O 28.73 30.55 Fuel H₂O

11²⁴
11⁵⁰

Drained fuel H₂O
 Raised safety to remove target for
 insertion of stopper
 Moved inner control

Removed target and put stopper in each end of 20 tubes uniformly distributed over trap area (see diagram)

Expt 65

Purpose to determine void coefficient of replacing water with air in 20% of approx 80 open tubes in target assembly. Island refl. water still at 28.76"

Inner control to 17.50, steam circuit ret.

Source in, safety up to 28.13


Fuel H₂O added to ~~32.70~~ 32.70

Started circulation of fuel water at 32.0

Stopped " " " " 33.5

Inner	Outer	Safety	Island-refl.	air fuel temp.
17.50	15.915	28.13	28.64	238

* Put cork in each end of open target tubes



Red cross refer to Expt 65
 Blue " " " " 66 (added cork)
 Green " " " " 67 " "
 Orange " " " " 68 " "

Inst. Check.

- IC-1 fast trip screamed system
- " meter " ok
- IC-2 trips ok.
- IC-3 3×10^{-11}
- IC-4 6×10^{-11}
- PM-1 high and low trips ok., scrams reset

Expt 66

Purpose: cont. of void coef. with trapped air in 19 more tubes: total of 39

See sketch on page 109

Source in (inst response moved inner control to 17.50

Safety up to 28.66.

Island-refl. water up to 28.15

Fuel H₂O up to 32.58 Circulation on 9³⁰

Circulation off at 9³⁹

Inner	outer	safety	Island-refl.	Av. Fuel Temp.	React. Level
17.50	14.87	28.66	28.15	22.2	Level

Safety in, outer control down for shut-down

Drained fuel water.

Expt 67

Conf. of void coef. Expt. (Corks in 20 more tubes - total of 59)

Source in, Safety set. Red light on
 Circulation of fuel water at 12²¹
 Safety up to 28.03"
 Island-refl. H₂O still at 28.10
 Fuel H₂O at ~ 31.9", Circulation off at 12³²

Inner	outer	Island-refl.	Av. Fuel Temp.	React. Level
17.50"	13.95"	27.99"	22.6	Level

Shut down by inserting outer control and dumping fuel water.

Expt 68

Purpose: cont. of void coef. Expt., filled

Remainder of tubes with cork stopper

Source in, inner control to 17.50

Safety up to 28.12, Island-refl. at 28.13

Raised fuel H₂O to ~ 32"

Started circulation at 2⁰⁵

Stopped " at 2²⁰

Inner	outer	Island-refl.	Av. Fuel Temp.	React. Level
17.50	13.19	28.01	23.1°C	Level

Shut down with outer control & drained fuel H₂O

Expt 69

Purpose: Crit. control cyl. position at room temp. with target assembly out.

Source in, Inner Control to 22.00"
 Safety to 28.15", Island Refl. at 28.03"
 Fuel H₂O to 32.77", Circulation started 3³⁰
 Stopped circulation of fuel at 3⁴⁴

Inner C.	Outer C.	Island Refl.	Ab. fuel Temp.	React.
22.00	16.20	27.94	23.1	Level

Expt 70

Purpose: Effect of circulating Island-refl H₂O on above expt.

Start Circulation in Refl - Island
 Source in Safety at 28.28
 Island-refl. circulation off at 9⁴⁵

Inner C.	Outer C.	Island-refl	Ab. fuel Temp.	React.
22.00	14.18	27.93	22.6	Level

Changed position of inner control stepwise.


19.50 17.90 " " "

18.85 18.85 " " "

Shut down with safety and fuel H₂O to ~~inner~~ outer control

6-28-61

²³³U Fission Counter now located in 1/2" hole in Be at 45° East of Bldg North. Close to core.



Center of counter at reactor midplane.
 L.A. settings 1.0 x 32, 0.2 μs, - Input
 PHS = 5. Max pulse height obs. ~ 20 volts

6-29-61 Inst Check.

IC-1 fast trip scrammed system
 " meter " ok

IC-2 " " "

IC-3 ~ 3 x 10⁻¹¹

IC-4 ~ 4 x 10⁻¹¹

PM-1 high & low trips ok.

scram Reset.

6-29-61

Expt 71

Purpose: preliminary foil run 0-14 & T-2 Removable plates in place of U-9 & O-27

Source in, Inner Control, 17.50 safety set., Refl. at ~~27.87~~ 28.80

Inner outer 92-refl control peg
17.50 16.89 28.24 21.4 Level

IC-3: 1×10^{-9}

IC-4: 4.5×10^{-9}

IC-2 $4 \phi \times 3 \times 10^{-9}$

Run time 2 min.

N.B. Prior to Expt 71, The distribution header for circ Island reflector H_2O was removed as well as all thermocouples that extended thru this header into the fuel region

TR-4 pts #s 1, 2, 3, 4, 6, 7

Counting Rate of Fission Counter IC-2 ~ 4.6

24.00 $(2 \times 256 + 114) / 3 = 209$

18.01 8 + 87 2135

14.01 42 + 39 10791

13.00 64 + 222 16606

12.01 77 + 35 19747

11.00 125 + 77 32077

9.99 264 + 87 67671

27.87 \approx 5.5" above Be

Inner Outer

P-1 F-2 Pos 2 $\sim 45^\circ$ from North

P-2 F-4 Pos 1 North

T-2 Pos 4 (4th clockwise from N)

T-2 has U-1-1 foil in foil hole. and T-2-4 in T-2-3 hole

Fuel plate locations for next exp.

~~T-7~~ O-36 Removed from Pos 1 (North)

U-9 O-27

U-13 Removed from 4

On Expt # 71 U^{233} Min Counter was in Be, but no counts observed.

Counter now moved to between the fuel annuli $\sim 45^\circ E$ of North, at midplane.

6-30-61 Inst. Check:

1-C-1 Fast Trip scrambled system

" " Meter Trip ok.

1-E-2 " " "

1-C-3 $\sim 5 \times 10^{-11}$

1-C-4 $\sim 5 \times 10^{-11}$

Scram Reset, Red light on

Purpose: Fail Irradiation in Position 1 and 2 (for plate)

				Removed
F-4	Plate # F-2 F-4	in position	b-1	O-34
P-2	" F-2 P-2	"	a-1	T-7
F-2	" P-1 F-2	"	b-78	O-27
P-1	" F-2 P-1	"	a-37	U-9
"	T-2	"	a-97	U-13

L U-1-1 in position 4

Source in, safety up to 28.16

Inner control to 17.50, Island refl. to 28.44

8:45 Fuel water up to 31.90

9:11 with outer control at 17.43 pos. period

9:14.5 started clock

cut at outer control: 17.09

1-C-2 at 5.1×10^{-10} , 1C-3 1.4×10^{-9}

1C-4 at 3.0×10^{-9}

U²³³#2 - 68,900c, in 3 min

9:34.5 Shut down with safety and control

Fuel water dropped to level of top of fuel ~ 22

With Fuel H₂O covering Fuel plate

observed read 22.08 changed to 21.98.

6 1/4" above Be = 28.37

change to 28.27

Purpose: to check on the react. value of thermocouples. Put in 5 thermocouples evenly spaced around void between fuel annuli. Each cut to ~ 24" to reach from bottom to top of core 3" counter between fuel annuli

Put back in original plates: a-1; T-7; b-1; O-34, a-37; U-9; b-78; O-27; a-97; U-13

140

Reaction set, red light on, source in, safety up to 28.28, Island refl H₂O: 28.29 Fuel H₂O up to 30.9

Inner	Outer	I.R. H ₂ O	F.H ₂ O	Control Temp.	React. Level
17.50	17.765	28.29"	30.9	~ 21.5°	Level

shut down with safety & outer control

6-30-61

Purpose: Recheck after removal of 5 thermocouples. Counter between fuel annuli

Source in, safety up to 28.44

Island refl and Fuel Water unchanged; 28.29 & 30.9

Inner	Outer	I.R. Refl.	F.H ₂ O	Control Temp.	React. Level
17.50	14.94	28.03	30.67	~ 21.3	Level

Shut down using safety and inner control

Removed U²³³ counter from fuel region

118
6-30-61

Expt 75

Purpose: Evaluate effect of removal of
U²³³ counter from core
Source in, Safety up to 28.29"
Is-refl at 28.04, Fuel H₂O at 30.67

Crt. Cont:		Control	React.
Inner	Outer	Ref. Temp.	Level
17.50	14.84	~21.2	

Shut down

5:04 PM Drained Reflector Island Water!
gwm

7-3-61 Inst. Check

- IC-1 Trips on meter
- " scrambled ~~to~~ fast trip
- IC-3 - 3×10^{-11}
- IC-4 - 5×10^{-11}
- PM-1 High and low trips ok.

Scram reset.
Red light on

Expt. 76 7-3-61 119

Purpose: foil Exposure Repeat of Exp #72
for Higher Power level

9⁴⁵ AM Source in Inst Response OK
Safety Raised to 28.86"
9⁵⁵ Inner Control Set At 17.50
10⁰³ Island Refl H₂O 28.65"
10¹⁴ Fuel Region H₂O Raised to 31.44
10²² Source out Approx. Crt +
Outer control
17.12
10²⁵ 17.34 Pos Per to Raise Power level
10³⁰ Start timing foil 20 MIN foil Exposure
ON BECKMAN IC-2 3×10^{-9} Avetemp
10⁴⁷ 16.96 IC-2 8×10^{-9} 22.3°C level
Note: 10⁵⁰ Sat Down Drop Safety, Insert outer control
U²³³ counter not in core
11²⁰ Move inner to 28.00
Drain H₂O to top of fuel ~20 m/hr

Purpose: Fission Counter Traverse

^{U²³⁵} Nor. Fis. Ctr in core

135

Inner Control Set At 17.50"

Safety Raised to 28.26

Island Refl H₂O 28.66

Source in Inst Response OK

152

Fuel H₂O Raised to 31.47"

Remove Source to check Counter

154

Source in Inst Response OK

205

Source out

Super Crit

outer Control

17.06

Super Crit

16.96

Level

Position

NOR. FIS. CTR

FIS. CTR

C.R
1 min. counts

4.89*

~~6240~~

81,503 18.10 + 41 x 254

← changed power h.

5.00

3630

81,883 19 + 178

22.54

"

3720

81,200 317 + 52

21.83

6.00

3870

50,243 198 + 50

13.11

"

3640

49,511
~~49,511~~ 193 + 101

13.60

7.00

3700

30,159
~~30,159~~ 117 + 209

8.15

8.00

3760

18,723
~~18,723~~ 73 + 33

4.98

9.00

3990

11,022
~~11,022~~ 43 12

2.76

10.00

3750

6533 25 132

1.74

11.00

3730

3813 14 229

1.02

12.00

3700

2264 8 216

.612

13.00

3760

1515 5 + 235

.403

5.50

3840

69,560 271 184

18.11

* inches from core

5.00	4,180	359+245	92149	
13.00	122490	187+52	47928	raised Power Level ^{22.05} .391
14.00	126220	123+94	31582	ONIC-4 .250
15.00	122680	78 ⁴⁴	20014	.163
16.00	127770	51 ²¹³	13269	.104
17.00	128940	34 ⁵⁰	8754	.0679
18.00	130130	22+27	5659	.0435
19.00	129200	8 ¹⁷³	2221	.0172
20.00	129880	5 ²¹⁹	1999	.0115
21.00	130490	4 ⁶²	1090	.0083
22.00	130 650	2 ²¹⁰	722	
"	130650 ²⁶¹³⁰⁰	2 ²⁴⁹	761	>1483 .0057 / .0055
23.00	129310	2 ¹⁵	527	.0058
"	129930 ²⁵⁹²⁴	1 ²⁴⁷	503	>1030 >.0040
24.00	128710	1 ⁹³	349	
"	128080 ³⁸⁵³⁸	1 ¹⁰⁰	356	1077 >.0028
"	128580	1 ¹¹⁶	372	

3 ³⁶ Shut Down Insert ~~upper~~ outer control, Safety, And Dump Fuel H₂O

Dumped Mand refl. Water

INST CHECK 7-5-61 W. 10mc Ra-Be Source

- IC-1 Fast Trip DC (10 x 10⁻¹²)
- 1 MTR " "
- 2 MTR " " (10 x 10⁻¹²)
- PM-1 HI " " Scram Safety & dump H₂O
- 2 LO " "
- IC-3 9 x 10⁻¹¹ Calibration
- IC-4 6 x 10⁻¹¹ Calibration

after reset. JLF & N. W. M.

EXP # 78

PURPOSE: REACT. EFFECT OF FUEL, H₂O and ALUM in Fuel element, U²³³ counter in core

Source in, Safety Cyl. up to 28.26

Inner control Cyl at 17.50

Island refl. H₂O at 28.84

Fuel H₂O at 31.2

Crit. with Outer control at 16.95

Pos Period 17.20

Shut down to remove U²³³ counter by insertion of safety and outer control

Expt. 79

Purpose: React. effect of ~~original~~ fuel plate removal of U²³³ counter

Source in, Safety up to 28.26"

All water heights same as above expt.

Pos. Period 17.10 Level @ 16.84

U²³³ counter ~ 0.12 in on outer control

7-5-61 EXP # 79 (Cont)

Adjust Inner and Outer to get a symmetrical rod position at Critical IC-2 = 0.68 x 3 x 10⁻¹⁰

Inner 17.24 Outer 17.24

(with target) 7-7-61 D.W.M.

Adjust Inner and Outer to get Outer at 18.00

so that it will be within the calibrated range for plate insertion and ^{removal} withdrawal experiments

IC-2 = 0.68 x 3 x 10⁻¹⁰

Inner 16.825 Outer 18.00

Shut down with Outer and Safety, Inner to 26.0
Remove 6 inner fuel plates.

EXP # 80

PURPOSE: CRITICAL COND. w.o. 6 inner fuel plates

Inner 16.825 Outer 17.65 Pos Period

" 16.825 " 17.335 Level @ IC-2 = 0.68 x 3 x 10⁻¹⁰

Insert safety and Outer control, then Inner to 30.0

Insert source.

Insert Aluminum Inner Plates, 1 thru 6 in a-1, a-37, a-72, a-97, a-122 a-147

7-5-61

EXP #81

Purpose: Crit Cond with 6 inner al. plates.

Inner 16.825	Outer 19.445	Pos Per
16.825	19.075	Level

Shut down by inserting Outer and Safety, Ammto 30

Remove Al Plates, Insert fuel plates

EXP #82

Purpose: Repeat #79, Crit Cond. with fuel plates inserted.

1¹⁰ Source in Inst Response OK
 INNER control set at 16.825"
 Safety Raised to 28.26"

1³¹ Source out
 INNER control Outer Control Approx Crit

16.825 18.00 " "
 1⁴³ 16.825 17.99 level

Shut Down Insert Outer Control and Safety

Removed 6 outer Fuel Plates

Exp #83 7-5-61

2⁰² INNER control set at 16.825"

Source in Inst Response OK

cont next page

2⁰⁷ PM EXP #83 cont 7-5-61 125

Safety Raised to 28.26

2¹⁷ Source out

INNER control outer

16.825	17.61	Pos Per to Raise Power
16.825	17.26	Level

Shut Down with safety and outer control

Inserted 6 Al Plates in Outer Ring

Expt 84

Purpose: Determine Effect of insertion of 6 Al plates in Outer Fuel Ring

Water: 15-refl = 28.8; Fuel = 31.2

Source in, Safety up to 28.26

INNER control	Outer control	W. Temp. 21.2°
16.825	18.675	

4²⁵ Shut Down Insert outer control, safety AND Dump fuel H₂O

Inst check

- IC-1 fast trip scrammed system
- " meter " ok
- IC-2 " " "
- IC-3 out for repair.
- IC-4 $\sim 2 \times 10^{-11}$
- PMI - high & low trips ok.
- scram circuit set.

Expt 85 7-6-61

Purpose: React. effect of filling all
 steam holes with water
 all removable fuel plates back in core
 source in, safety to 28.26"

10²³ AM Inner control at 17.50
 Island Refl H₂O 28.41"
 Fuel H₂O 31.24"
 10⁴² Source out
 Inner (control) outer
 17.50 16.82 Approx Crit
 10⁴⁸ 17.50 17.00 T=207.5 $\approx 5.39\%$ Pos Per
 11⁰⁶ 17.50 16.83 $\rho = 3.145 \times 10^{-5}$ level
 Shut Down Insert Outer Control And Safety

7-7-61

Inst. Check:

- IC-1 fast trip ok
- " meter " "
- IC-2 " " "
- IC-3 out for repair
- IC-4 $\sim 3 \times 10^{-11}$ response
- PM-1 low level trip scrammed system
- " high " " ok.
- instr set.

Expt 86

Purpose: Irradiation of O-32 reverse plate
 in position b-78 & T-2 in a-37 for
 flux data.

source in, safety up to 28.26
 Inner control set at
 9¹⁹ AM Island Refl H₂O 28.63"
 fuel H₂O 31.33
 9²⁹ Source out
 Inner (control) outer
 17.50 17.16 Pos Per to Raise Power level
 9³⁷ Start timing 20' foil Exposure at 3×10^{-9} ON IC-2
 9⁵² 17.50 16.865 (crit) 7.8×10^{-9} " "
 9⁵⁷ Shut Down Insert outer control, Drop Safety

Note

Remove target & installed ^{9/16" OD ss.} target rod containing 4 - 1/2 OD Al Spacing rings

Original removable plates all back in fuel

Island Refl H₂O 28.52

Source in, Safety to 24.08

Inner control cyl. at 18.50

1 32 PM Fuel H₂O 31.70

1 45 Source out Approx Crit

Inner (control) outer

18.50 19.535 ~ Level

1 52 20.45 17.21 Pos Per to Raise Power level

2 10 20.195 17.21 level

Shut Down Insert outer Control, Dump fuel H₂O

Exp # 88

7-7-61

Added 6 - 1/2" O.D. polystyrene tubes filled with air around central target rod. Tubes ≈ 24" long centered vertically in core

Source in, Safety up to 24.08"

3 08 PM Inner control set at 20.195

Source out

Inner (control) outer

20.195 16.42 Pos Per

cont next page

3 21 Inner (control) outer
20.195 16.18 $\frac{8.0}{24} = 33\frac{1}{2}$ level
Raise Safety to 28.26" Slight ^{increase} Raise

1 20 lower Safety to 24.08" level

1 28 Raise Safety to 28.26

20.195 16.17 level

1 30 Shut Down Insert outer Control, Dump fuel H₂O

Exp # 89

7-7-61

Added 12 - 1/2" OD Tubes Filled with Air to previous 6 - Total of 18

Source in, Safety up to 24.08

Fuel H₂O at 31.46

Inner control at 20.195

4 06 Inner (control) outer Source Out

20.195 14.425 $\frac{9.5}{22} \approx 43\frac{1}{2}$ Pos Per

4 18 20.195 14.205 $\frac{9.5}{22} \approx 43\frac{1}{2}$ Level

Shut down with safety & Inner Control & Fuel H₂O

7-10-61

Inst check.

IC-1 system scrammed with fast trip

" meter trip ok.

IC-2 " " "

IC-3 out for repair

IC-4 ~ 4.5×10^{-11}

PM-1 high & low trip ok.

scram reset.

Increased magnet current to 50 ma 90V DC
1970 mariac

Expt 90 7-10-61

Void coef using 36 air filled
 $\frac{1}{2}$ " OD plastic tubes

Source in, Safety up to 24.08

Inner control to 20.195

Island-repl. 28.53

Fuel H₂O 33.02

9¹⁰

Source out

Approx Crit

Inner (Control) Outer

Slightly Super "

20.185 11.525

9¹²

20.185 11.70

10.3 ϕ Pos Per

9²⁶

20.185 11.473

level

9³⁴

20.195 11.47 $\frac{10.3 \phi}{.227} = 45.4 \phi$ inch level

Shut Down Dump fuel H₂O, Insert outer
Control

Expt. 91

7-10-61

Void coef. using 60- $\frac{1}{2}$ " OD plastic
tubes filled with air

Source in, Safety up to 24.08

Inner control Set At 20.195

fuel H₂O 32.34"

10²²

10²⁹

Source out

Approx Crit

Inner (Control) Outer

20.195 8.11

Slightly Super Crit

10³¹

20.195 8.30

$\frac{8.81 \phi}{.232} = 38.0 \phi$ Pos Per

10⁴⁶

20.195 8.068

level

Shut Down Insert Outer Control, Dump fuel H₂O

Exp # 92

7-10-61

Void coef. using central cyl. of
styrofoam - 4 $\frac{5}{16}$ " in Dia. made up of
2" Discs stacked together on $\frac{5}{16}$ " OD S.S.
target rod. Length 24 $\frac{9}{16}$ " centered vert.

Source in, Safety at 24.08, Scrams set,
Inner control at 20.195,

Fuel water 31.90

1²⁹

Source out

Slightly Super Crit

Cont Next Page

1²⁹
 INNER (Control) Outer
 20.195 5.96 Slightly Pos
 1³¹
 20.195 6.10 180.4 sec 388 f Pos Per
 1⁴⁴
 20.195 5.87 6.06 level
 Shut Down Insert Outer Control, Dump Fuel H₂O

$$\frac{6.06}{.23} = 26.34/in$$

2³⁰ PM

Exp # 93 7-10-61

Void coef. using a central cyl.
 of styrofoam 3 7/8 in. in dia. & 24 1/2" long

Source in, safety set at 24.08
 Inner control set at 20.195
 Fuel water at 31.34

2⁵⁰

Source out Approx Crit

INNER (Control) Outer " "

20.195 6.73

20.195 6.90 T164 P = 4.22 x 10⁴ Pos Per

2⁵²

3¹⁸

20.195 6.69 6.594 21 = 31.4% level

Shut Down Insert Outer Control, Dump fuel H₂O

Target re-installed in trap region for fast run

Inst. Check.

IC-1 Fast trip scrammed system
 " Meter " ok.
 IC-2 " " "
 IC-3 out for repair
 IC-4 5x10"
 PM-1 high & low trips ok.
 Alarms reset.

Exp # 94 7-11-61

Purpose: Foil exposure: P-1 in a-97, P-2 in a-72

P-1-4 in
 T-2 center
 & U-1-1 in
 center of P-1

T-2 in a-37, F-2 in b-209 & F-4 in b-155

INNER Control Set At 17.50"

Safety Set At 28.86

Island Refl H₂O 28.56

9¹⁵

Source in Fuel H₂O 31.72"

9²⁵

Source out
 Outer control 16.95 Crit

Shut Down to install Counter -
 Insert Outer Control, Safety, Source

cont. Expt 95

Repeat of above after preliminary
 Critical pt.

9⁴⁹

Source out Approx level
 Outer control 17.05"

9⁵¹

17.05" Approx level
 17.25 Pos Per to Raise Power level
 cont Next Page

9⁵⁷ Outer Control
 17.25 Pos Per to Raise Power level
 10⁰⁸ start timing foil Exposure 3×10^{-9} on IC-2
 U²³³ counter jammed scaler on x256 -
 had to turn off

Counted on U²³⁵ Fis. ctr at 15.00" for 20 min.
 during irradiation; Total counts = 2621 x 256

10²⁷ 17.058 IC-2 8×10^{-9} level
 10²⁸ Shut Down Drop Safety, And insert outer
 Control

Expt 96

Void Coef. Using central cylinder
 of Styro foam $3\frac{1}{2}$ " in Dia. $52\frac{1}{2}$ " long

Inner Control 20.195"
 Safety 24.08"
 Island Refl H₂O 28.51"
 Source in Inst Response OK
 Fuel H₂O 31.21"

1³⁰ Source out Super Crit
 Outer Control

9³² 9.24" " "
 9.38 5.4 div \rightarrow 117.3 \rightarrow 5.56 \rightarrow 8.69 Pos Per
 1⁵³ 9.182 .198 \rightarrow 43.9 $\frac{4}{2}$ level

Shut Down Insert Outer Control, Dump fuel H₂O

Void Coef. Using a central cylinder of
 styrofoam $2\frac{3}{4}$ " in dia


Source in, Inner Control at 20.195"
 Safety up to 24.08"

Island Refl H₂O 28.49
 Fuel H₂O 31.58

3³³ Source out
 outer Control

13.155 Approx Crit
 13.30 7.23 \rightarrow 157.15 \rightarrow 4.36 \rightarrow 6.81 $\frac{4}{2}$ Pos Per
 13.15 15 \rightarrow 45.4 $\frac{4}{2}$ level

Shut Down Insert Outer Control, And
 Dump fuel H₂O



7-12-61

Removed M-228 Source to return for
 recanning; 1.14×10^6 N/sec
 Installed M-43 " ; 1.28×10^6 N/sec

Mr. Whitehead Lubricated screw on safety
 drive to eliminate chattering.

7-12-61

Inst Check:

- IC-1 Fast trip ok
 - " Meter " "
 - IC-2 " " Scrammed system
 - IC-3 ~ 4.3×10^{-11}
 - IC-4 ~ 4.3×10^{-11}
 - PM-1 high & low trips OK.
- Scram Circuits Reset

Expt 98

Void Coef Using central cyl. of styro foam $4\frac{3}{4}$ " in dia.

It is not possible to use the safety for this expt. because of the large dia. of the styro foam. Must use extreme care in approach to critical.

Source in, Island-refl H₂O 28.51
 Fuel H₂O at 31.51
 Inner control at 20.195

10⁵⁴

Source out Slightly Super Crit
 Outer Control

10⁵⁷

7.32" Approx Crit
 7.50" Pos Per
 7.28 level

11¹⁶

Shut Down Insert outer Control, Dump Fuel H₂O
 $6.1 \text{ div } 132.6 \text{ sec } 504 \rightarrow \frac{7.884}{.22} = 35.8 \text{ \$/in}$

7-12-61

Expt 99 x

Void Coef. with Target in + 24-1/2" OD polystyrene tubes filled with air & forming a ring around outside of target assembly. Water in all Al tubes in target.
 Again Safety cannot be used because of lack of space

Source in, Island-refl. 28.34"
 Inner Control at 17.50
 Fuel water at 31.40

14⁶

Source out
 Outer Control

14⁸

13.94
 14.10 6.1 div $\rightarrow 132.65 \rightarrow 5.04 \rightarrow \frac{7.884}{.18} = 43.8 \text{ \$/in}$ Approx Crit
 13.92 Pos Per level

20⁷

Shut Down Insert Outer Control, Dump fuel H₂O
 Circuit, Crit ~~for~~, considered for removal of T.C. 14.19

Expt. 100 x

Void Coef. with Target in + 24-1/2" OD polystyrene tubes filled with air. All Al. tubes in target filled with air.

Source in, Safety out of Assembly
 Inner Control at 17.50
 Water: Island-refl = 28.22; Fuel = 32.00

Cont Next Page

3²⁵ PM Outer Control Source out Approx Crit
 11.19" " "
 3²⁷ 11.35" 6.45 div → 140.25 → 9.8 × 10⁴ Pos Per
 3⁴⁵ 11.18 = $\frac{7.54}{.17} = 44.1 \text{ } \mu\text{m}$ level
 Shut Down Insert Outer Control, Dump fuel H₂O

7-13-61 Off Crit ~~pos~~ ~~correcting for~~ ~~time~~ ~~of~~ ~~the~~ ~~rod~~ 11.45

Inst. check:

- 1C-1 Fast Trip screamed system
- 1C-1 meter " ok.
- 1C-2 " " "
- 1C-3 ~ 5 × 10⁻¹¹
- 1C-4 ~ 5 × 10⁻¹¹
- PM-1 high & low trips ok.
- Red light on, scream reset.

Expt 101

Recheck of previous rod positions

Source in, Inner Control = 17.50, Safety @ 28.28

Del. Ref = 28.45 Fuel H₂O = 32.78.

9¹¹ Source out
 outer Control

9¹⁵ 16.85 Approx Crit
 17.05 152 sec Pos Per
 $\frac{14.82}{.23} = 64.4$ Cont Next Page

9³⁵ outer Control Temp ~ 21.0°C
 16.82 level
 Shut Down Insert Outer Control, Safety, AND
 Dump fuel H₂O

Expt # 102

7-13-61

Removed Al Spacer from Annulus
 between Inner and outer fuel annulus
 Spacer is 0.051" thick. & 2.5" high + 4 v shaped
 spacers 25" Long

Source in, Inner Control at 17.50

Safety up to 28.24, Is.-refl = 28.35

Fuel water.

10³⁷ Source out
 outer Control

10³⁹ 14.55
 14.75 130 sec $\frac{7.976}{.20} = 39.9$ Approx Crit
 14.55 Pos Per
 .20 Level

Shut Down Insert Outer Control, Safety AND
~~Dump fuel H₂O~~

7-13-61

Expt 103

Foil Exposure radially with Al-spacer cylinder out

Source in, Safety at 28.28
Island-refl at 28.32, Fuel H₂O at 31.39
Inner Control at 17.50

11⁴⁹

Source out
Outer Control

14.63

Slightly Super
Pos Per

11⁵¹

14.78

11^{59.5}

Start timing foil Exposure on IC-2 $.3 \times 3 \times 10^{-9}$

12¹⁷

14.58

level

12^{19.5}

Shut Down IC-2 $7.8 \times 3 \times 10^{-9}$

Note

Drop Safety, Insert Outer Control

Expt. 104

7-13-61

Target out as in Expt 99 & 70 but with thermocouples removed from fuel region. Control positions symmetrical.

Source in, Safety at 28.08
Island-refl. at 28.23", Fuel H₂O = 31.56
Inner control preliminary position 18.80

2³¹

Source out

INNER (Control) Outer

18.80

18.56

Approx Crit

2⁴⁰

18.695

18.695

" "

2⁴²

18.695

18.90

Pos Per

3⁰³

18.69

18.69

level

Shut Down Insert outer Control, Safety

7-14-61 Inst. Check
 IC-1 Fast Trip scrambled system
 " Meter " ok
 IC-2 " " "
 IC-3 ~ 4 x 10⁻¹¹ "
 IC-4 ~ 4 x 10⁻¹¹ "
 PM-1 high and low trips ok.

12²⁵ Island Refl H₂O 13.77 to check counter
 Source in

Exp # 105 7-14-61
 Purpose: Fission Counter traverse, AND Flux
 Normalization

133 Source in Inst Response ok
 Island Refl H₂O 28.52", fuel H₂O 31.23"
 Inner Control 18.70"
 Safety 27.00"

152 Source out
 Outer Control
 18.96 Super Crit
 18.85 Approx level
 19.05 Pos Per
 18.33 Reduce Power level
 18.54 Neg

159 Shut Down to move counter & (BF₃)
 200 Insert Outer Control, Safety
 205
 242

C-4 Miniature counter BF₃ placed at 2 and at
 center of island L.A. = 16 x 0.5 μs PHS = 30 HV = 1600
 V-100370
 C-3 Travelling F.C. x 16 x 0.2 μs PHS = 30 C-3
 U²³³ Min Counter x 32 x 0.2 μs PHS = 5
 C-1 U²³³ between fuel annulus at mid plane

Count Time	U ²³³	Pos	F.C.	BF ₃	IC-2
5'	2510	5.00	4 x 256 + 125	1608 x 256 + 239	.22 x 3 x 10 ⁻¹¹
5'	10730	5.00	4 x 256 + 88	1602 + 17	.22 x 3 x 10 ⁻¹¹
5'	1210	5.00	5 x 256 + 55	1828 + 183	.24 x 3 x 10 ⁻¹¹
	1250	5.00	4 x 256 + 217	1878 + 159	.25
	1290	5.00	5 x 256 + 102	1884 + 61	.25
	3750 x $\frac{5}{3}$		22 + 2.293	8800 + 2.57	

$\frac{6250}{256} = 24.41$ $\frac{F.C.}{BF_3} = 0.002760$
 $\frac{BF_3}{F.C} = 362.35$

EXP # 106 Counts

5'	20700	5.00	103 + 3	1452 + 220	.50 x 3 x 10 ⁻¹⁰
5'	21650	5.00	105 + 50	1490 + 37	.51 x 3 x 10 ⁻¹⁰
5'	20410	5.00	101 + 16	1436 + 84	.49
5'	19810	5.00	98 + 110	1380 + 134	.48
	20643		407 + 0.70	5758 + 1.855	
	$\frac{20643}{256} = 80.63$				

$\frac{BF_3}{F.C} = 14.13$ 25.64
 ~ 0.0390

144

Exp # 106

7-14-61

Purpose: Fission Counter traverse AND Flux Normalization with BF3 Counter in contact with Be (outside) Vertical center line

3⁰⁰ PM

Source in

INNER Control 18.70" Safety 27.01"

Island Refl H₂O 28.41" Fuel H₂O 31.24"3¹²

Source out

outer Control

19.05

Pos Per

3²³

18.85

 $.4.7 \times 3 \times 10^{-10}$ TC-2 Approx level3⁵⁴

18.81

 $.45 \times 3 \times 10^{-10}$ level3⁵⁵

18.91

Pos Per

4¹⁷

18.84

level

4²²Shut down Insert Out, drain Fuel H₂O

July 17, 1961

9⁰⁰ AM

Found limit of counter travel @ 23.68

reset to 24.08 on selysp, change of 0.4 in.

C_1
 C_3
 FISS COUNT
 C_4
 U^{233} Pos Count BF³

	C_1	C_3	FISS COUNT	C_4	
	U^{233}	Pos	Count	BF ³	
5'	18770	8.00	17+233 ⁴⁵⁸⁵	1327 +147 ²⁴⁴	
5'	28940	11.00	5+244 ⁰⁵²⁷	2050 + 5	
5'	63380	14.00	3+152	920 —	.0145
5'	186780	18.00	1+210	466 —	.00249
5'	575250	19.00	3+18	1042 —	.00181
5'	926390	20.00	4+171	1195 —	.00129

level
 $.45 \times 3 \times 10^{-10}$
 + period

:/ 185000 c/m
 3100 c/sec of $\sigma = 10 \mu\text{sec}$: CN = .03

l
o

Inst Check on July 17

FC-1 MTR TRIP OK
 -1 Fast " OK
 2 MTR Trip And Safety OK
 3 5×10^{-11}
 4 6×10^{-11}
 PM 1 TRIP HI OK
 1 TRIP LO OK
 2 \leftarrow pa response

Expt 107

PURPOSE: REPEAT #106 COUNTING RATIOS.

Source in, scrams Reset

Safety at 27.01, Inner Control at 18.70

Island-refl. 28.53, Fuel Water 32.95

10⁰⁰ AM Source Out + Period Inner 18.70 Outer 18.91

M.W. U^{233} between Fuel Annuli @ d 32×1 $0.2 \mu s$ - PHS = 5

M.W. BF_3 outside Beryllium 16×1 $0.8 \mu s$ + PHS = 20

Fission Counter (Tower) movable 16×1 $0.2 \mu s$ + PHS = 30

System Level with Outer Control at 18.77

	U ²³³	MOV. U ²³⁵ Counter	$\frac{U^{235}}{U^{238}}$	BF ₃	$\frac{BF_3}{U^{233}}$	
5'	2460	5.00	179 x 256 + 17308	14145965	147 x 256 + 193	15.38
5'	6940	8.00	67 x + 156	2.49	439 x + 93	16.21
5'	15620	11.00	54 + 188	.897	1025 + 186	16.81
5'	33410	14.00	29 + 71	.224	—	
5'	70050	17.00	9 + 239	.036	—	
5'	154070	20.00	12 + 18	.0200	1891	50-2 MM 3.5 x 10 ¹⁰
5'	375640	24.00	6 + 245	.0047	1864	
5'	231370	22.00	8 + 7	.0089		
5'	100860	18.00	14 + 171	.0372		
5'	44250	14.00	21 + 62	.123		
	20550	10.00	61 + 61			
		7.00				

Movable Fission Counter stopped counting!
 ERR in vest: gating. Found cable to preamp
 snagged! also found 15 pin connector loose & Limit at 23.78
 Shut down with safety & Outer Control

Reset Allysyr for limits of 4.84 ↔ 34.08
 run up and down 3X

ERR replaced LA on C-3 (Mov Fiss Counter)

17

7-17-Cel

Expt 108

Repeat of Fis. Ctr. traverse in
Bottom refl.

Source in, Safety upto 27.60
15-refl 28.39, Fuel H₂O 32.80

Inner Control at 18.70

Slightly super at 18.90 on Outer Control
Outer C. at 18.78 Level

Shut down with Safety, Fuel/Water
& Outer control

5' Counts

IC-2	U^{233}	Pos	Scale $\times 256$	Counts	Scale $\times 256$			
6.1×10^{-11}	9090 ^{6.72}	5.00	640 + 19	163859	573 + 109	146789	18.03	16.15
$4.2 \times 3 \times 10^{-10}$	7910 ^{7.04}	8.00	180 + 134	46214	1185 + 28	303388	2.58	16.93
2.8×10^{-10}	38540 ^{7.24}	11.00	130 + 225	33505	—		0.869	
5.5×10^{-10}	77420 ^{7.19}	14.00	64 + 228	16612	—		0.215	
$3.8 \times 3 \times 10^{-9}$	156600	17.00	24 + 1	6145	—		0.0392	
$7.2 \times 3 \times 10^{-9}$	315900	20.00	13 + 103	3431	—		0.0109	
4.4×10^{-9}	640130	24.00	7 + 148	1940	—		0.00303	
3.2×10^{-9}	481900	22.00	11 + 204	3020			0.00627	
	204040	18.06	32 + 17	8209			0.0402	
	87190	14.00	76 + 109	19565			0.224	
	37370	10.00	215 + 65	55105			1.475	
	17080	7.00	447 + 155	114587			6.71	
	8450	5.00	595 + 207	152527			18.05	
		4.84 ↓						
	8370	5.00	449 + 74	115018			13.74	
✓		5.5 ↓						
	6690	5.0 ↓	450 + 89	115289			17.23	

150

7-18-61

Inst. Check

IC-1 Fast trip scrammed system

" meter " ok

IC-2 " " "

IC-3 ~ 4×10^{-11}

IC-4 ~ 6×10^{-11}

PM-1 high & low trip ok.

Scrams reset.

Expt 109

7-18-61

To provide neutron source for
inst check-out

Source in, Inner control 18.70

Safety 27.15, Island ~~28.78~~⁵⁴

Fuel H₂O = 31.2

Outer control 18.82 level

Shut down with safety outer control
& Fuel water.

ERR finds no reason for erratic counts

recommends changing settings on Small U²³³
counter. PDL Knot fixed.

Inst Check on 7-19-61.

IC-1 Fast Trip OK Scream Safety & drain H₂O.
 -1 Meter Trip OK
 -2 Meter Trip OK
 -3 6 x 10 -" } Calibration OK
 -4 5 x 10 -" }
 PM-1 Hi
 -1 Lo

PM-2 < 1/2 pa Response.

EXP #110

PURPOSE: Counter Normalization (Repeat)
 and Travers of Tower F.C.

Source In, Inner @ 18.70 Outer 999.82, Refl Idl → 28.40, Fuel H₂O → 32.4

Time	Out	In	Pos	Per
9 ²⁵	18.70	19.15	Pos	Per
9 ³⁴	"	18.83	~	Level
9 ⁵⁰	"	18.82		Level
"	"	18.90		for traverse outward
"	"	18.79		Part of inward trav.
11 ²⁷	"	to 18.73	"	12" downward
12 ⁰⁸	"	to 18.81		
12 ²²		to 18.81		

Note ~ 12³³ Shut down by programming reactor

2³⁰ Noted that H₂O not completely drained level at ~ 28.5, concluded that the reset button was pushed too soon and stopped draining after ~ 4 in. were drained.
 Avon

EXP #110

TOWER F.C.

Traverse

5" — 24"

C-1	Y-119060	x16	0.8 μ s	- 20	U ²³³
3	123800	x16	0.2 μ s	+ 30	U ²³⁵
4	119059	x16	0.8 μ s	- 20	BF ₃

U²³⁵



July 19, 1961

Foils	T-3	1	Beryllium Contact
		2	2" from Be
		3	4"
		4	In T-2 cuttopos 4-A-37
		5	6" from Be
		6	Center of Island on 52
		7	5" from fuel

For foil normalization.

Inst Check for July 20, 1961.

50-1 Fast Trip OK

-1 Meter " "

-2 Meter " "

-3 4×10^{-4} -4 8×10^{-4}

} Calibrated DWN/

PM1 Hi Trip OK

Lo " "

Source H₂O and SafetyPM 2 < 1/2 μ region

EXP #111

PURPOSE: FULL IRRADIATION FOR FLUX NORMALIZATION

Foil locations are given above.

Safety = 28.13

Source IN, Refl. lev = 28.5, out to 18.70, Fuel H₂O to 32.4(Refl. lev H₂O to 30.0⁺, no evidence of filled thimble for inst, drained in to 28.5)

Source out out to 19.17 on Positive Period

out to % = 19.25 - 18.81 = .44 $\frac{108.6 \text{ sec} \rightarrow 9.38}{44} = 21.3 \frac{\phi}{\text{in}}$ 9:09:45 Start timing foil Exp. Rn @ $3 \times 10 \times 10^{-9}$ 9:19 out to 18.815 level at $.8 \times 10 \times 10^{-9}$

9:29:45 Drop Safety, lower out to

Instrument Check on July 31 1961 Source 10mc &

PM-1 OFFSCALE Low Trip OK Alarm Trip OK
 PM-2 < 1mc response source in contact Alarm Trip
 IC-1 10x10⁻¹² scale Meter Trip OK Fast Trip OK
 IC-2 10x10⁻¹² Meter Trip OK swamped safety & Moderator drain
 IC-3 5x10⁻¹¹ Calibration
 IC-4 6x10⁻¹¹ Calibration
 CRM Meter Trip

Preliminary Check on 7-31-61

Room 113 Pressure Differential 0.5 in H₂O Normal
 Red Light On and Personnel Check ✓ C.C.
 Scrums and Bldg, Alarm Reset ✓ C.C.
 Source Inserted Use Accelerator for source
 Safety Withdrawn 28.10
 Controls Set INNER 17.50 Outer 999.82
 Reflector Water 28.55
 Moderator Water 33.40

308

Acceleration source off
 Outer Control

EXP#112

318

11.54 "

Approx level

348

11.63

Pos Per


11.54 Very unstable Shut Down
 to investigate investigate

4:40 PM

Insert outer control, safety, Dump fuel H₂O
 Found leak in target, loose Nut
 on Bottom of Rod (~1/4 in) of H₂O poured
 from can surrounding target assembly.
 Positive period was not stable, showing
 an increase in reactivity with time.

Before #112, a can to surround the target and keep it dry was fabricated 4.78" OD from 0140 wall alum, a hole in the bottom of the can for the target rod was to be sealed with rubber and nuts. ~~nut~~ threads were ground to reduce leakage there.

Plastic for the top reflector target was not yet available.



Aug 1, 1961

upon inserting target in assembly, thread was stripped.

Instrument Check on Aug 1, 61 Source 10mc

PM-1	OFFSCALE	Low Trip	OK	Alarm Trip	Range Bell on Test
PM-2	10×10^{-12}	No Response		Alarm Trip	
IC-1	10×10^{-12}	Meter Trip	OK	Fast Trip	OK
IC-2	10×10^{-12}	Meter Trip	OK		
IC-3	5×10^{-12}	Calibration			
IC-4	5×10^{-12}	Calibration			
CRM		Meter Trip			

Preliminary Check on 8-1-61

Room 113 Pressure Differential	<u>0.5"</u>	<u>C.C.</u>
Red Light On and Personnel Check	<u>✓</u>	<u>C.C.</u>
Scrams and Bldg. Alarm Reset	<u>✓</u>	<u>C.C.</u>
Source Inserted	<u>Use Accelerator for Source</u>	
Safety Withdraw	<u>28.10"</u>	
Controls Set	<u>INNER 17.50, Outer 999.81</u>	
Reflector Water	<u>28.54"</u>	
Moderator Water	<u>32.54"</u>	

EXP # 113

Purpose: Positive Period to check counter saturation before giving up.

11¹⁰ INNER Control Moved to 22.00"
Accelerator off
outer control

11¹⁵ 16.11 Approx Cvit
12⁰⁷ 16.25 Pos Per
16.15 $3.25d / 0.10 = 32.5d/in$ level
Shut Down Insert Outer Control, Safely

Aug 1, 1961

Printing scales indicated approx 10% losses at 5,000,000 counts in 0.9 min. This reduces to ~1% losses at 10⁹ cps. This was on LI I + DD-2 and on BF₃ + 0.2RS on 204-B L.A. Awdm

When starting positive period at 5x10⁻¹², there is evidence of source in room.

Exp # 114 - PN-90

1 ¹² PM	Inner Control	22.00"			
	Safety	28.10"			
	Island Refl H ₂ O	27.97	Fuel H ₂ O	32.51"	

Use Accelerator for source

"Note"

M-43 Source Removed from Assembly and Put in Corridor Source Well. On Long Rod

Outer

Inner	Outer	Crit at	Rfl H ₂ O	Fuel H ₂ O	Safety
22.00	999.82	16.45	27.95	32.51	28.10

Neutron target source in Radial beam hole 130 kv

200 μs 100 cps 256 ch. 20 μs wide Bkg x 16 delay x 2

Total number of pulses x 10⁵

LI I 6292 @ 800 V

DD-2 Amp x 1.1 x 5 PHS @ 750

IC-3 5x10⁻¹²

IC-2 2.7x10⁻¹¹

IC-4 4.9x10⁻¹¹

EXP² 115 PN-91

Dinner 22.00

Enter 8:15 (16.15 @ Crit)

No changes on accelerator or TMC

IC-2 = 3.1×10^{-11} IC-3 = 8.5×10^{-12} IC-4 = 2.5×10^{-11} 2⁵⁰ pm Start Pulsing for 260000 pulses3³¹ pm Stop "

w.o. target

Exp = 116 PN-92

Dinner 22.00

Enter 12.15 (16.15 @ Crit)

(LiI)

200 μ s, 40 cps, 40 μ s Ch Delay x16 Delay x2IC-2 = 1.3×10^{-11} IC-3 = 6.5×10^{-12} IC-4 = 1.5×10^{-11} Pulsed for 1.3×10^5 cycles @ 40 cps

w.o. target

Instrument Check on Aug 2, 61 - Source 10mc

PM-1	off Scale	Low Trip	OK - Scram	Alarm Trip
PM-2	X			
IC-1	$> 10 \times 10^{-12}$		OK	OK
IC-2	$> 10 \times 10^{-12}$		OK	
IC-3	5×10^{-11}		Count OK	
IC-4	5×10^{-11}		Count OK	
GRM		Motor Trip		

Scram c.c.

Preliminary Check on 8-2-61

Room 113 Pressure Differential	0.05"	C.C.
Red Light On and Personnel Check	✓	C.C.
Scrams and Bldg. Alarm	✓	C.C.
Source Insertion	Use Accelerator for Source	
Safety Interlock	28.10	
Controls Set	Inner 22.0" Outer 999.82	
Reflector Water	28.58"	
Moderator Water	32.49"	

EXP #117 - PN-93

Accelerator @ 130 kv - 100 RPS 200 μ s BurstTMC ^{DISC # 4} Phy X16 Delay X2 Ch W 20 μ s 256 Ch, 2" Preset Count

Detector LiI @ 800 v DD-2 X1.1 X5 PHS 750

(Data discarded. Discovered a gain shift in Pulse Height) IC-2 @ 3.1×10^{-11}

Detector LiF @ 800 v DD-2 X0.8 X10 PHS = 750

Gain adjusted so that neutron pulses between 80 - 100 v on scope

IC-2 @ 2.6×10^{-11}

Inner @ 22.00 Outer @ 5.15 Safety 28.10

Fuel H₂O 32.4 Refl. H₂O 28.07

Aug 2, 1961

EXP #118 — PN-94

Inner 22.00 Safety @ 28.10

Outer 10.15 Fuel 32.40 Refl 28.08

Accelerator @ 130 kv 200 μ s @ 100 RPSTMC 20 μ s Ch Bkg x 8 Delay x 2 Disc 4
2¹⁶ print count.

Det. LiI @ 800v DD-2, 0.8 x 10 PHS @ 750

Pulse height on scope 80-100 volts.

IC-2 = 2.75×10^{-11} IC-3 = 8.00×10^{-12} IC-4 = 2.0×10^{-11}

W. O Target

EXP #119

PN-95

Inner 22.00 Safety 28.10

Outer 14.15 Fuel H₂O 32.40 Refl 28.04Accelerator @ 130 kv 200 μ s @ 100 RPSTMC 40 μ s Ch Bkg x 4 delay x 2 Disc 4

LiI @ 800v DD-2 0.8 x 10 PHS @ 750

Scope P.H. 80-100 volts.

W. O Target

Aug 2, 1961

PN-96 EXP # 120

Same as EXP # 119 except 80µs ch
and lower Rep Rate

Inner	22.00	Safety	28.10
Outer	14.15	Fuel H ₂ O	32.78
		Ref.	28.02

Accelerator 130kv 200µs @ ~~10~~²⁵ RPSTMC @ 80µs ch. Bk₂ x 8 Delay x 2 Disc 4

L:I @ 800V @ 292 DD-2 @ x0.8 x 10 PHS @ 750

PH on scope 80-100 V.

W.O. Target

PN-97 EXP # 110

Inner 22.00 Safety 28.10

Outer 15.15 Fuel & Refl H₂O Unchanged

Accelerator @ 130 kv 200µs @ 10 RPS

TMC @ 80µs ch Bk₂ x 8, Delay x 2, DISC @ 4

Det L:I 6292 @ 800 V (80-100 PH on scope)

DD-2 x 0.8 x 10 PHS @ 750

W.O. Target

H¹⁰ Shut Down Insert Outer Control, Safety,
AND Dump fuel H₂O

Instrument Check on Aug 3, 1961 Source 10 mc X

PM-1	OFF SCALE	Low Trip	OK	Alarm Trip	OK
PM-2	No Response			Alarm Trip	
IC-1	$> 10 \times 10^{-12}$	Meter Trip	OK	Fast Trip	OK Screamd OK
IC-2	$> 10 \times 10^{-12}$	Meter Trip	OK		
IC-3	2.5×10^{-11}	Calib.	Down		
IC-4	2.5×10^{-11}	Calib.	Down		
CRV					

Preliminary Check on Aug 3, 1961

Room 115 Pressure Differential Down
 Red Light On and Personnel C.C
 Scraps and OK
 Source Int. Use Accelerator For Source
 Safety 28.10"
 Controls Set INNER 17.50" Outer 999.81
 Reflector Water Solve zone OK 28.57"
 Moderator Water: " " " 32.64"

Experiment #111 P

Target Inserted - Critical Run before
 pulsing for rod calibration.
 9²⁰ Accelerator off
 9³¹ Outer Control 17.04 Approx level
 17.50
 9³⁶ Outer 17.20 IC-3 = 1.25×10^{-11} Approx level
 Inner 17.41
 Insert Safety to Make Reactor Sub Crit

EXP #112 Pulsing with Safety Inserted
 PN-98 target Inserted. ^{Inn 17.41} over 17.20

Acc 150 kv 200 μ s Burst 150 cps Rep Rate, TMC 10 μ s channels
 pky X64 Delay X16 Disc X4 LiI 6292 @ 800 v. 00-2 750
 X0.8 X10' P83 750 (20-100 v)

EXP#113 PN-99 Safety Removed Outer = 00.00
Inner = 17.41

Data Control fully inserted Safety removed to 28.10.
Inner at 17.41, the value when crit. was detem at 17.20
on the Outer. (Outer Crit = 17.20)

Accelerator @ 130 kv, 200µs burst, 110 cps rep rate

TMC 20µs Ch Bkg x 32 Delay x 2 Disc x 4

Det LiI, 6292 @ 800V DD-2 x 0.8 x 10 PHS = 750 (80-100)

Accelerator tripped off and there
are two channels of data that
must be eliminated! 75 and 149

IC-3 5×10^{-12} IC-4 1.9×10^{-11}
IC-2 = $1 \times 3 \times 10^{-10}$

EXP#114 PN-100 Safety @ 28.10 Outer @ 6.20
(Outer at Crit F 17.20) Inner @ 17.41

IC-2 = 2.5×10^{-11} IC-3 = 5×10^{-12} IC-4 = 1.8×10^{-11}

Acc 130 kv, 200µs burst 110 cps Rep Rate

TMC 20µs Bkg x 16 Delay x 2 Disc x 4

Det. LiI 6292 @ 800V DD2 x 0.8 x 10 PHS = 750, (80-100 pulses)

EXP#115 PN-10f Safety @ 28.10 Outer 10.20 Inner 17.41
IC-2 = 2.2×10^{-11} 6.5×10^{-12} 2.0×10^{-11}

Acc @ 130 kv, 200µs burst 100 cps Rep Rate TMC 20µs x 16 Delay x 2

Det LiI 6292 @ 800V DD-2 x 0.8 x 10 PHS = 750 (80-100 pulses)

750
v. 11

Exp # 116 PN-102 Inver 17.41 Outen 14.20 (Out @ 17.20)

Safety 28.10 Rfl H₂O 28.31 Final Mod H₂O 32.62

IC-2 = 1.4×10^{-11} , IC-3 0.95×10^{-11} IC-4 = 2.4×10^{-11}

Acc @ 130kr 200 μ s Burst 50 cps Rep Rate TMC 40 μ s Pkg x 8 Delay 2

Det L:I, 6292 @ 800 DD2 x 0.8 x 10 PHS = 750 (80-100 v pulses)

Exp # 117 PN-103 Inver 17.41 Outen 16.20 (Out @ 17.20)

Safety 28.10 Rfl H₂O 28.31 Final Mod H₂O 32.64

IC-2 = 1.9×10^{-11} 1×10^{-11} 1.9×10^{-11}

Acc @ 130kr 200 μ s Burst 20 cps TMC 80 μ s Pkg x 4 Delay x 2 Disc 4

Det L:I 6292 @ 800 DD2 x 0.8 x 10 PHS = 750 (80-100 v pulses)

Instrument Check on Aug 4, 61 Source 10mc/x

PM-1	<u>Recorder OFF Scale</u>	Low Trip <u>OK</u>	Alarm Trip <u>OK</u>
PM-2	<u>No Response</u>		Alarm Trip
IC-1	<u>$> 10 \times 10^{-12}$</u>	Meter Trip <u>OK</u>	Fast Trip <u>OK</u>
IC-2	<u>$> 10 \times 10^{-12}$</u>	Meter Trip <u>OK</u>	<u>Scrammed</u>
IC-3	<u>5×10^{-11}</u>	Calibration	
IC-4	<u>6×10^{-11}</u>	Calibration	
CRM		Meter Trip	

Preliminary Check on Aug 4, 61

Room 113 Pressure Differential 0.05 in H₂O
 Red Light On and Personnel Check C.C.
 Scrams and Plug, Alarm Reset C.C.
 Source Installed Use Accelerator for Source
 Safety Withdrawn 28.10"
 Controls Set INNER 17.41 outer 999.81
 Reflector Water 28.58"
 Moderator Water 32.89"

after lig N₂ on accelerator pressure dropped to 5×10^{-6}

Exp # 118 PN-104 Outer @ 00.00, Inner @ 17.41
 (Same as PN-⁹⁹98) Acc 130 kv. 200 μ s burst 150 cps
 TMC 10 μ s Channels, Bkg x16 Delay x2 Disc @ 4
 Det LiI 6292 @ 800 v DD-2 @ 0.8×10 PHS = 75% (80-100v)
 Safety 28.10 Refl 27.88 Fuel 32.90
 added H₂O after PN-104

Exp 119 PN-105 Outer @ 00.00 Inner @ 22.00
 Safety 28.10, Refl. 28.58 Fuel 32.90
 Acc 130 kv 20 μ s burst, 100 cps TMC 20 μ s Bkg x16 Delay x2 Disc 4
 Det LiI 6292 @ 800 v DD-2 @ 0.8×10 PHS = 75% (80-100v)

EXP #120 PN-106 Outer @ 00.0
Inner @ 44.00

Note: Moving inner control from 22.00 → 44.00 (gray → white) decreased reactivity when Outer black section is in core!

Acc @ 130 kv 200 μs burst 100 cps TMC 20 μs Ch. Bkg x32 Delay x2
Det L:I 6292 @ 800v DD2 @ 0.8 x 10 PHS = 750 (80-100 v pulses)

Gas H₂ Gas OK

Exp. #121 PN-107 Outer @ 00.0 Inner 12.00

Acc @ 132 kv 200 μs Burst 160 cps Rep Rate TMC 10 μs, Bkg x32

Det. L:I 6292 @ 800v PHS @ 750 (80v-100v pulses)

Exp #122 PN-108 Outer 00.0 Inner 00.05

Acc. @ 132 kv 200 μs Burst 300 cps TMC 10 μs Bkg x32

Delay x2 Mem = 1/2, Det. L:I 6292 @ 800v DD-2

x 0.8 x 10 PHS = 750 (80-100 v)

EXP #123 PN-109 Outer 22.0 Inner 0.05

Acc @ 132 kv 200 μs Burst 150 cps TMC 10 μs Bkg x32

Delay x2 Mem 1/2 Det L:I 6292, 800v DD-2 0.8 x 10

PHS = 750 (80-100v pulses)

Aug 7, 1961 6.3 x 10⁻⁶ mm Hg w.o. Lig. N₂
5.0 x 10⁻⁷ mm Hg w. Lig N₂

Instrument Check on Aug 7, 61 Source 10 mc / 8

PM-1	Low Trip OK	Alarm Trip OK
PM-2	No Response	
IC-1	2.10 x 10 ⁻¹²	OK - Scrammed
IC-2	2.10 x 10 ⁻¹²	OK
IC-3	5 x 10 ⁻¹¹	OK
IC-4	6 x 10 ⁻¹¹	Calibration OK
CRM	Motor Trip	

Preliminary Check on Aug 7, 1961

Room 113 Pressure Differential .06"
Red Light On and Personnel Check C.P.
Scrams and Bldg, Alarm Reset ✓ C.C.
Source Inserted Use Accelerator for Source
Safety Withdrawn 28.10
Controls Set INNER .05" Outer 43.95"
Reflector Water 28.46"
Moderator Water 32.46"

Exp #124 - PN-110 Outer 43.95, Inner @ 00.05

Safety 28.10 Rifle H₂ 28.43, MOD. FUEL H₂ 32.50

Acc 135 kv 200 μs Burst 150 cps Rep Rate

TMC 10 μs Ch, Bkg x 32 Delay x2 DISC 4 Mem 1/2

Det L:I 6292 @ 800v DD2 Gain x 0.85 x 10 PHS 750 (80-100v pulses)

Acc. Tripped 2 x, one channel in TMC dropped to zero on last trip.

10² Lower both cylinders with acc. source on.
Put Min BF₃ Counter on DD-2 amp.

EXP #125 PN-111 Inner @ 44.00 Outer = 00.00
 Acc 132 kv. 200 μ s 150 cps
 TMC 40 μ s Ch, Bkg x32, Delay x2 Disc 4
 Det. Min BF₃ @ 1700v DD-2 @ 1.1 x 200 PHS = 450
 (Pulse ~40-100v) LiI Removed

EXP #126 PN-112 Inner @ 22.00 Outer = 00.00
 Acc 135 kv 200 μ s 150 cps Beam 200 S.F. = 55
 TMC Ch. 40 μ s Bkg x16, Delay x2 Disc = 4
 Det Min BF₃ @ 1700v DD-2 @ 1.1 x 200 PHS = 450
 (Pulse 40-100v)

EXP #127 PN-113 Inner 12.00 Outer = 00.00
 Acc 135 kv 200 μ s 150 cps D. Diff. 200 S.F. = 55
 TMC Ch. 40 μ s Bkg x32 Delay x2 Disc = 4
 Det Min BF₃ @ 1700v DD-2 @ 1.1 x 200 PHS = 450
 (Pulse 40-100v)

added lig. N₂, Mid section of Inner control
 is magnetic!

EXP #127 PN-114 Inner 00.05 Outer 00.00
 Acc. 135 kv 200 μ s 300 cps B.D. 200 SF 55
 TMC Ch 40 μ s Bkg x32 Delay x2 Disc = 4 Mem 1/2
 Det Min BF₃ @ 1700v DD-2 @ 1.1 x 200 PHS = 450
 Pulse (40-100v) IC-2 = 2.7×10^{-10} .
 Target current ~ 3 μ a $\frac{200}{3333} = 6\%$ Duty Cycle

EXP #128 PN-115 Inner 00.05 Outer 00.00
 Acc 135 kv 1.1 ma ⁵⁰/₂₀₀ μ s 300 cps B.D. 200
 SF 55 Target 3 μ a $\frac{50}{3330} = 1.5\%$ Duty Cycle
 TMC Ch. 40 μ s Bkg x32 Delay x2 Disc 4 Mem 1/2
 Det Min. BF₃ @ 1700v DD-2 @ 1.1 x 200 PHS = 450

H²¹ Shut Down Insert Safety, Dump fuel H₂O

Instrument Check on Aug 8, 61 Source 10 mcd

PM-1 off Scale	Low Trip OK	Alarm Trip OK
PM-2 No Response		Alarm Trip
IC-1 $> 10 \times 10^{-12}$	Meter Trip OK	Fast Trip OK
IC-2 $> 10 \times 10^{-12}$	Meter Trip OK	Scrammed
IC-3 5×10^{-11}	Calibration	
IC-4 6×10^{-11}	Calibration	
CRM	Meter Trip	

Preliminary Check on Aug 8, 61

Room 113 Pressure Differential	0.05 in H ₂ O	Down
Red Light On and Personnel Check	CC & Down	
Screws and Etdg, Alarm Test	✓	CC.
Source Inserted	Use Accelerator for Source	
Safety Withdraw	28.0"	
Controls Set	Inner 6.0" Outer 6.0"	
Reflector Water	28.61"	
Moderator Water	32.86	

CC and Down

Exp #129 PN-~~115~~¹¹⁶ Inner = Outer = 6.00 in.
 Acc. 135 kv 1.0 ma 100µs burst @ 300 cps 4 1/2 µa Target
 TMC 10µs Bkg x32, Delay x2 Disc @4 Mem 1/2
 Det Min BF₃ counter @1700v DD-2 1.1x200 PH5 450
 (40-100 v pulses) IC-2 = $.275 \times 3 \times 10^{-9}$

EXP 130 PN-117 Inner = Outer = 10.00 in.
 Acc 135 kv 0.85 ma <2µa target 150µs burst @ 150 cps
 TMC 10µs Bkg x32 Delay x2 Disc @4 Mem 1/2
 Det Min BF₃ @1700v DD2 1.1x200 PH5 450
 IC-2 = 4.0×10^{-10}
 Inadvertently cleared cycles after acc kicked off.

Exp 131 PN-118 Inner = Outer = 14.00
 Acc 135 kv 0.78 ma 1µa target 200µs 150 cps
 TMC Ch 10µs Bkg x16 Delay x2 Disc=4 Mem 1/2
 Det Min BF₃ @1700v DD2 @1.1x200 PH5=450
 IC-2 = 3.35×10^{-10}

Exp #132 PN-119 Inner = Outer = 16.0"
 Acc 135 KV 0.74 ma 200µs 50 cps
 TMC Ch 40µs Bkg 8 Delay x2 Disc=4 Mem 1/2

Exp #133 PN-120 Inner = Outer = 17.0"
 Acc 135kv 0.70 ma Target <1µa 200µs 30cps
 TMC Ch 80µs Bkg 4 Delay x2 Disc=4 Mem 1/2
 Det Min BF₃ @1700v DD-2 @1.1x200 PH5=450
 IC-2 = 4.1×10^{-10}

4:18 PM Shut Down Insert Outer Control, Safety
 And Dump fuel H₂O

Instrument Check on Aug 9, 61 Source 10 mc &

PM-1	Low Trip <u>350 x 1 [Side 1/4"]</u>	Alarm Trip <u>No Trip on side</u>	Trip OK source <u>OK</u>
PM-2	<u>No check</u>	Alarm Trip	
IC-1	<u>> 10 x 10⁻¹²</u>	Meter Trip <u>OK</u>	Fast Trip <u>OK</u>
IC-2	<u>> 10 x 10⁻¹²</u>	Meter Trip <u>OK</u>	
IC-3	<u>5 x 10⁻¹¹</u>	Calibration	
IC-4	<u>6 x 10⁻¹¹</u>	Calibration	
CRM	Meter Trip		

Preliminary Check on Aug 9, 61

Room LL3 Pressure Differential	<u>0.06"</u>
Red Light On and Personnel Check	<u>✓ C.C.</u>
Screams and Bldg. Alarm Reset	<u>✓ C.C.</u>
Source Inserted	<u>Use Accelerator for Source</u>
Safety Withdrawn	<u>20.58" changed to 28.50"</u>
Controls Set	<u>INNER 17.30" Outer 2.0"</u>
Reflector Water	<u>28.77"</u>
Moderator Water	<u>32.52"</u>

Note: New instrument installed for PM-1! 750v.
Condenser installed in Philips gauge on acc.

Exp #134

Purpose crit pt of controls with counts
^{U233} and BF₃ in core.

	Inner	Outer	Safety	Fuel Mod. H ₂ O	Ref H ₂ O	
¹⁴⁴	17.33	17.33	28.10	32.53	28.61	Crit
	17.488	17.488	20.58	32.53	28.63	Crit

Exp #135 PN-121

Pulsing at Critical Invar = Outer = 17.488
Safety @ 20.59, Insert safety to ~15.0
to reduce neutron level, pulse for
500 cycles and repeat

Acc 185kv 320µs 70 cps

TMC Ch 80µs Bly X8 Relay X2 Disc 4 Mem 1/1

Det Min BF₃ @ 1700v DD-2 @ 1.1 x 200 PHS = 450

Pulse ~ (40-100v)

System critical at end of run, level for 5'

4²³ PM Shut Down Insert Outer Control, Safety,
Dump fuel H₂O.

Instrument Check on Aug 10⁶¹ Source -10 mc δ

PM-1	350	Low Trip	2"	Alarm Trip	contact
PM-2					
IC-1	716×10^{-12}	Meter	OK	Scram	OK
IC-2	710×10^{-12}	Meter	OK		
IC-3	5×10^{-11}	Calibrat	Done		
IC-4	5×10^{-11}	Calibration	Done		
CRM		Meter Trip			

Preliminary Check on Aug 10, 1961

Room 113 Pressure Differential	0.05" H ₂ O	DWM
Red Light On and Personnel Check	9:00 AM	C.E.
Scrams and Bldg, Alarm Reset	<input checked="" type="checkbox"/>	C.C.
Source Inserted	Use Accelerator Source	
Safety Withdrawn	20.59"	
Controls Set	INNER 17.488" Outer 999.81	
Reflector Water	28.75"	
Moderator Water	32.70"	

EXP 136 PN-122

Critical at 17.49 on both Safety 20.59"

Pulsing at crit; inserting safety to 15.0, withdraw to 20.59
200 pulses between shut-downs.

Acc 135 kv S.F. = 65 0.66 ma 64 μ s 20 cps

TMC Ch 160 μ s Bkg x 8 Delay x 2 Disc 4 Mem 1/1

Det Min BF₃ @ 1725 v DD2 1.1 x 200 PHS = 450 (40-100 v)

Start @ 10⁰⁷ approx 1 cycle/min of 200 pulses

INNER Outer Safety Island H₂O Fuel

12⁵² 17.49 17.49 20.595 28.58 32.66 Crit

Shut Down Insert Safety

EXP 137 PN-123

Inner = Outer = 17.33 Safety Inserted
to 998.28 (worth of Safety)

Acc 135 kv 0.82 ma 1/2 μ s Target 100 μ s 330 cps

TMC Ch. 10 μ s Bkg x 32 Delay x 2 Disc 4 Mem 1/2

Det Min BF₃ @ 1725 v DD2 1.1 x 200 PHS 450 (40-100 v)

[Approx. Refl. 28.74 Fuel 33.02]

8-10-61

EXP # 138

INNER Outer Safety Refl H₂O Mod H₂O

22.00" 999.81" 28.10 28.74 33.02

2¹⁰ " 13.43 " " " Crit

Insert Safety for Pulsing

EXP # 139 PN-124

Inner 22.00 Outer 13.43 Safety 28.10

(Worth of Safety for controls asymmetric)

Acc 135 kv 0.82 ma ~ 1.4 μ a Press 1.8×10^{-5}

S.F. 66 B.D. 200 (5KV) 100 μ s, 170 cps

TMC Ch 10 μ s Bkg x 32 Delay x 2 Disc. 4 Mem 1/1

Det Min BF₃ @ 1725 v DD2 1.1 x 200 PHS 450 (40-100 v)

EXP # 139 PN-125

100 cps repetition rate (everything else

same as PN-124

4²⁷ Shut Down Insert Outer Control, Dump Fuel H₂O

Instrument Check on Aug 11, 1961 Source 10 mc Y

2cm 347
 PM-1 350 Low Trip 2" scrapped Alarm Trip OK
 PM-2 Alarm Trip
 IC-1 $>10 \times 10^{-12}$ Meter OK Trip OK
 IC-2 $>10 \times 10^{-12}$ Meter OK
 IC-3 5×10^{-12} Calibration Swan
 IC-4 5×10^{-12} Calibration Swan
 CRM Meter Trip

Preliminary Check on Aug 11, 1961

Room 113 Pressure Differential 0.07"
 Red Light On and Personnel Check ✓ C.C.
 Scrums and Bldg, Alarm Reset ✓ C.C.
 Source Inserted U.S.C. Accelerator
 Safety Withdrawn 20.59"
 Controls Set INNER 22.0" Outer 999.81
 Reflector Water 28.60"
 Moderator Water 32.46"

EXP #140 Purpose: Determine critical positions
 prior to pulsing with source at 22.00 (asymmetric
 control position) and safety at 20.59
 Inner Outer Safety Mod Fuel Refl.
 22.00 13.686 20.59 32.47 28.44

EXP 14# PN-126

Pulsing at critical, Inner 22.00 Outer 13.686

Safety 20.59

Ace 135 kv ma μ a target.640 μ a burst at 20 cps, 200 cycles
between shut down.TMC Ch160 μ s Bkg 8 Delay x2 Disc 4 Mem 1/1Det. Min BF₃ @ 1725 DO-2 x1.1 x 200 PHS 450

Recheck Crit Outer 13.686

12⁴⁰Shut Down Insert Outer Control, Safety and
Dump fuel H₂O

Aug 11, 1961

#2 standard cut in half -	} all sent to Blosser.
# 0-16-3 " " "	

Results from Blosser

0-16 34.36 U

III 35.85 U

69.41 xU

Country

65.89

.9314

= 70.74 Total U

#2 57.02

#2 61.20

118.22 weighed 115.1

Instrument Check on Aug 14, 1961 Source 10 mc 8

PM-1	Low Trip 35°	2"	Alarm Trip OFF SCALE 1/4"	(Zero 380)
PM-2			Alarm Trip	
IC-1	$> 1.0 \times 10^{-12}$	Meter Trip OK	Scrammed Fast Trip OK	
IC-2	$> 1.0 \times 10^{-12}$	Meter Trip OK		
IC-3	4×10^{-11}	Calibration		
IC-4	6×10^{-11}	Calibration		
CRM		Meter Trip		

Preliminary Check on 8-14-61

Room 113 Pressure Differential	0.07"
Red Light On and Personnel Check	✓ C.C.
Scrams and Beam Stop	✓ C.C.
Source Intensity	45c Accelerator
Safety Margin	20.575"
Controls	INNER 22.00" Outer 999.81
Reflector Water	28.63"
Moderator Water	33.19"

8:57 AM Source Removed

EXP #142

	INNER	Outer	
	22.0"	16.48"	Approx Crit
<u>9:4</u>	22.0"	16.465"	Crit

EXP #143 PN-127

Pulsing at Crit without Target

Inner = 22.00 Outer 16.465 Safety
20.575" to 15.00" (pulsing at crit for
200 cycles, then shut down.)

Acc 135KV 0.67mc 0.2µ Target S.F. = 65

~~640µs~~ 640µs 20cps Total

TMC 160µs Chy 8, Delay 2 Disc 4 Mem 1/1
Det BF3 @ 1225 DDZ pulse (40-100)

12¹⁷ Re-check for Critical, After Pulsing

INNER Outer Refl H₂O fuel H₂O Safety
 22.00" 16.465" 28.43" 33.05" 20.575 Crit
 Shut Down Insert outer control, safety, AND
 Dump fuel H₂O. - Insert inner control, Drain
 Refl H₂O.



Exp # 144 8-14-61

Purpose - checkout of RHOETTE #1 from Brookhaven
 (React Analog Computer)

2¹⁷ INNER - Outer Safety Refl H₂O fuel H₂O
 22.00" 16.465" 20.57 — 33.55" ~ crit

RHOETTE #1 IC-2 Outer

0.0 ± 2.0 4.55 × 10⁻⁹ 16.49 Level Level

16.49

6.5 ± 0.2 φ

16.69

Pos Per

(IK ≈ 4.5 × 3 × 10⁻⁸ ≈ 2.8 × 10⁻⁸ IC-3)

2⁴⁵ MY 9.5 φ 16.20

Pos 10⁻⁸ φ 16.79

Pos Per

0 6.0 × 3 × 10⁻⁸ 16.475 Level Level

Insert Safety 15.00

- # 1.6

Change Rod Positions so that

Inner at 17.50 at Crit Outer ~ 28.40

+ # 0.5 17.75

+ 0.01 17.50

0.00 17.50 28.35

RNO ETE Inner Outer
 0.79 16.25 28.35
 (Rod Calibration 71%)
 + ~~14.5~~ 4 12.75 28.35
 15.0
 14.5
 14.2

Levelled at high Power

Dropped Safety, worth more than \$9.999.
 Adjust Outer to 20.00 at Crit.
 Inner = 18.55

Net period out to 37.5 Calit 40%

Ready to Crit at High Power

Inner	Outer	Rhette	Calit	Power
19.56	18.21	0.00	level	
	17.20	-28.2	-30.0	-
	19.34	+25.	+27.4	
	16.97	-36.	-26.0	
	19.0	+18.5	+20	
	17.53	-18.7	-20	
	18.58	+8.9	+10	

"Note"
 8³⁰

8-15-61

Inserted target in Reactor AND
 Greased Control Rod on Safety Drive

PM-1	Low Trip	✓	Alarm Trip	✓	
PM-2	No check		Alarm Trip		
IC-1	$> 10 \times 10^{-11}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 10 \times 10^{-11}$	Meter Trip	OK		
IC-3	$\sim 5 \times 10^{-11}$	Calibration	OK	Dum	
IC-4	$\sim 6 \times 10^{-11}$	Calibration	OK	"	
CRM		Meter Trip			

Preliminary Check on 8-15-61

Room 113 Pressure Differential	0.07"
Red Light On and Check	✓ CC
Scrams and Blg. Report	✓ CC
Source Inserted:	U.S.C. Accelerator
Safety Withdrawn	28.10"
Controls Set	Inner 17.50" Outer 999.81"
Reflector Water	Approx 6" Above Be
Moderator Water	33.50"

10¹⁰ AM EXP # 145 - Check Out Rhoette # 1
 INNER outer Source off

	17.50	17.10				Slightly Super Crit
	17.50	17.06				Crit
10 ²⁵	16.72	18.50	Rhoette	Period	Calc	Crit (A)
	"	18.70	.050	.0517	.055	Pos Per (B)
	"	18.485	-.064	-.0673	-.064	level (C)
	"	18.25				Neq Per (D)
	"	18.90	.102	.101	.104	Pos Per (E)
11 ²⁵	"	18.48	00	00		level (F)
	"	18.00	-.130	x	-.134	Neq Per (G)
11 ³⁸	"	19.00	.126	.126	.127	Pos Per (H)
11 ⁴³	"	17.20	-.383		-.374	Neq Per (I)
11 ⁴⁹	Shut Down Insert Outer Control, and Safety					

182

Exp # 146

8-15-61

Purpose - Period Meas. to check Rhoette #1
use Accelerator for source

1²⁰ PMINNER - Outer Safety Refl H₂O fuel H₂O

16.72 999.81 28.10" 6" Above Be 33.48"

2²⁴

16.72 18.498

~ Crit

2³¹

16.72 18.485

level

16.72 18.73

Pos Per

A

16.72 18.48

level

B

trouble with Rhoette #1

3⁵⁸

16.72 18.88 + .0944 .098 Pos Per

C

" 17.20 - 0.3804

Neg Per

D

4¹⁰

" 18.90 + 0.100

.104

Pos. P.

E

Note 4¹⁷

Shut Down Drop Safety, Insert outer controls
and Dump fuel H₂O



"Note"

8-16-61

8³⁰ AM

Installed Source M-43 on Source
Drive. (on Assembly) RM # 113

Removed BF₃ counter from between
fuel annuli so that source
could be used!

Instrument Check on 8-16-61 Source 10MC 8

PM-1	Low Trip	OK	Alarm Trip	OK	(Zero 337)
PM-2	Not tested		Alarm Trip		
IC-1	$> 10 \times 10^{-10}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 10 \times 10^{-10}$	Meter Trip			
IC-3	$\sim 5 \times 10^{-11}$	Calibration	OK Down		
IC-4	$\sim 6 \times 10^{-11}$	Calibration	" "		
CRM		Meter Trip			

Preliminary Check on 8-16-61

Room 113 Pressure Differential	0.07"
Red Light On and Personnel Check	✓ C.C.
Scrams and Blg, Alarm Reset	✓ C.C.
Source Inserted	✓ Inst Response OK
Safety Withdrawn	28.10"
Controls Set	INNER 16.72 outer 999.81
Reflector Water	Approx 6" Above Be
Moderator Water	32.70"

Exp # 147 8-16-61

Purpose: Check out of Rhoette #1

Source out

outer rho

18.535
18.90 + 0.134¢

18.36 0.00

" -0.30

Raised safety

19.00 0.158

17.20 0.35

19.10 0.180

Super crit

Pos Per A

level B

Dropped safety

Pos Per C

Neg Per D

115

129

Note

130

131

184

Expt 147 cont.

	outer	Rho	Level
149	18.34	0.00	
202	19.10	0.180	Pos Per E level
212	18.36		level
	7.32		Neg
252	19.358	Safety 20.58	Pos Per F level
	18.95		level
255	lower Safety to measure Reactivity		
	shut Down Insert outer Control, Dump fuel H ₂ O		

→ Neg. Reactivity on Driving in Outer Control. cyl.

Position in.	Time from start - sec	RHO dollars	Repeat
17.26	15	0.33	0.33
16.14	30	0.74	0.73
15.03	45	1.20	1.20
13.92	60	1.70	1.70
12.81	75	2.30	2.21
11.70	90	2.80	2.81
10.59	105	3.30	3.45
9.48	120	3.60	4.00
8.37	135	3.85	—

→ Neg. Reactivity on driving in safety from 20.58"

Distance into core in.	Time Sec.	-Rho dollars	
2.8	10	0.57	$20.6 - 2.8 = 17.8$
5.7	20	1.79	$-5.7 = 14.9$
8.5	30	3.70	$-8.5 = 12.1$
11.4	40	6.20	$-11.4 = 9.2$
14.2	50	7.8	$-14.2 = 6.4$
17.0	60	8.7	$-17 = 3.6$

Instrument Check on 8-17-61 Source _____

PM-1 _____ Low Trip OK Alarm Trip OK
 PM-2 _____ Alarm Trip _____
 IC-1 $> 10 \times 10^{-11}$ Meter Trip OK Fast Trip OK
 IC-2 $> 10 \times 10^{-11}$ Meter Trip OK
 IC-3 $\sim 5 \times 10^{-11}$ Calibration OK 287
 IC-4 $\sim 6 \times 10^{-11}$ Calibration OK "
 CRM _____ Meter Trip _____

✓ Preliminary Check on 8-17-61

Room 113 Pressure Differential 0.07"
 Red Light On and Personnel Check ✓ C.C.
 Scrams and Bldg, Alarm Reset ✓ C.C.
 Source Inserted ✓ Inst Response OK
 Safety Withdrawn 28.10"
 Controls Set INNER 17.50 Outer 999.81
 Reflector Water 6.75" Above Be
 Moderator Water 32.82"

Expt 148

Put target into A1 can before insertion in trap region. Then filled can with water for zeroing in expt. with outer control at 17.21

Outer inner	safety	P	Fuel H ₂ O
17.21	17.095	28.111"	0.0 33.2"

Ref water \sim 7 in above Be

8-17-61

187

Expt. 149
Target in Al. can - dry inside

	inner	outer	safety	P	Fuel H ₂ O	Ref
11:50 AM	17.095	12.28	28.10	0.0	32.70	up ~7" above

Shut Down Insert outer control, Safety AND
Dump fuel H₂O

Expt 150

Air in all Al tubes in Target (stopped
in each end). Al can surrounding target
filled with water.
Source out

1:45

	inner	outer	safety	Ref H ₂ O	Fuel H ₂ O	
1:53	17.095"	13.25"	28.10"	6.75" Above Be	32.80"	~ Crit
"	"	13.45"	"	"	"	Pos Per
"	"	13.25"	"	"	"	Crit

Shut Down Insert outer control, Dump fuel H₂O
20.93% Void

EXPT 151

Repeat of Expt. 149 except that a ^{6"} reflector
added on top of al can containing
target (no water inside)

P	Inner	Outer	Safety	Fuel H ₂ O	Ref H ₂ O
3 ³⁹	17.095	12.14	28.10	33.70	up Crit
"	"	12.135	"	"	Crit

Shut Down Insert Outer Control, Safety AND
Dump fuel H₂O
47.27 To Void

PM-1 Low Trip ok. Alarm Trip ok.
 PM-2 Alarm Trip
 IC-1 $> 10 \times 10^{-10}$ Meter Trip ok Fast Trip ok.
 IC-2 $> 10 \times 10^{-10}$ Meter Trip ok
 IC-3 $\sim 5 \times 10^{-11}$ Calibration ok PK7
 IC-4 $\sim 4 \times 10^{-11}$ Calibration ok "
 CRM Meter Trip

Preliminary Check on

Room 113 Pressure Differential 0.68 "
 Red Light On and Personnel Check ✓ C.C.
 Scrams and Bldg, Alarm Reset ✓ C.C.
 Source Inserted ✓ quiet response noted
 Safety Withdrawn 28.01
 Controls Set
 Reflector Water 5.75" Above Be
 Moderator Water 32.42"

Experiment: 152 GOLD FOIL FISSION FOIL

Irradiation without targets

1.1 cm dia 5 mil gold foil

In trap # 57 .2407 g bare 1" below ϕ
 65 .2407 g .030" cd 1" above ϕ

In T-2-4 U-2-5 in position a-37

9:05 Source out

Inner - Outer

18.80 18.80

" 19.20

Approx Crit

Pos Per

9:20 Start timing 1hr Exposure IC-2 1×10^{-9}

10:20 18.83 18.83 IC-2 = 2.8×10^{-9} Crit

Shut Down insert outer Control, And safety to 8.73"

Removed foils from target Area And Inserted Safety to 0.

8-18-61

Expt. 153

Target in Al can Dry inside except
that 39 $\frac{3}{8}$ OD Al tubes filled with water
and corked.

Preliminary Check on _____
Room 113 Pressure Differential 0.08
Red Light On and Personnel Check ✓
Screams and Bldg. Alarm Reset ✓ JK7
Source Inserted ✓
Safety Withdrawn 2800'
Controls Set Inner at 17.095
Reflector Water Up 5.75" Above BC
Moderator Water 32.80"

110

Source Out

INNER - Outer

17.095 - 12.17

Approx Crit

" 12.37

Pos Per

129

" 12.162

Crit

Shut Down Insert outer Control AND Safety

Dump fuel H₂O % Air Void 36.8%

Al can 0.042 in by meas
subtract ~ .001 for curvature
error
thickness ~ 0.041

Removed U²³³ fis. ctr from core

Instrument Check on 8-21-61 Source 10 mc gm

PM-1 Zero 380 Low Trip 350 Alarm Trip off scale
 PM-2 _____ Alarm Trip _____
 IC-1 10×10^{-12} Meter Trip OK Fast Trip OK
 IC-2 10×10^{-12} Meter Trip OK _____
 IC-3 5×10^{-11} Calibration OK Swm _____
 IC-4 5×10^{-11} Calibration " " _____
 CRM _____ Meter Trip _____

Preliminary Check on _____

Room 113 Pressure Differential 0.08"
 Red Light On and Personnel Check OK Swm
 Scrams and Bldg, Alarm Reset OK JKF
 Source Inserted
 Safety-Withdrawn
 Controls Set _____
 Reflector Water up ~ 6" above Bz
 Moderator Water 33.8"

"Note"

EXP #154 : Purpose: Gold Foil in target, Fuel plate

Irradiation for Flux per fission.

Gold Foil # 14 0.2407 g

T-5 0-26 fuel plates.

Start timing exposure IC-2 @ 3×10^{-9}

Level at IC-2 @ 8×10^{-9}

9:03 AM Source out drain 18.80 out 19.30 + Period.

9:08

Start Clock

9:13

Inner: 18.72 Outer: 18.72 Level

10:08

Insert Safety, Outer and Inner.

1:04

Drain fuel H₂O.

Foil Cd

0-26	1.0×10^{11}	total fissions per plate	15.30g
T-5	1.7×10^{11}	total fissions per plate	13.40g

$$\frac{2311}{13.4} \times 1.7 \times 10^{11} = 2.93 \times 10^{13}$$

$$\frac{5680}{15.30} \times 1.0 \times 10^{11} = 3.71 \times 10^{13}$$

Total fissions = 6.64×10^{13} = 1.84×10^{10} fission/sec
 = .584 watts
 3.15 fission/watt

Gold Foils

Exp #152 Bare Ratio = 13.57
Cd

$\frac{Cd}{Bar}$ Ratio = 0.07368 - $\lambda = .92632$

Exp #154

8625
Heiko Walker
PN-98

Using 3" x TL Counter tube 10' = .00178081
 Decay time = 150' $e^{-\lambda t} = .973618$
 apparatus = 60' $1 - e^{-\lambda t} = .01063742$

$$SA = \frac{1.965 \times 10^5 \times .9263 \times 2.972 \times 10^{-6}}{1.781 \times 10^{-3} \times .9736 \times 1.064 \times 10^{-2}} = \frac{0.9866 \times 10^{10}}{1.84495 \times 2.972 \times 10^{-6}}$$

$$2.932 \times 10^4 = Q N \sigma$$

$$Q = \frac{2.932 \times 197 \times 10^{-24}}{.2407 \text{ gm} \times .6025 \times 10^{24} \times 98.8 \times 10^{-24}} = \frac{40.31 \times 10^{-4}}{.019}$$

$$Q = 3.43 \times 10^7 / \text{watt} = 3.63 \times 10^{15} / 100 \text{ mW} = 2.12 \times 10^7$$

Foil Calc

$$2.63 \times 10^{14} = 4.31 \times 10^{15} / 100 \text{ mW}$$

.8432 flux disp and w/ shielding factor
for ¹⁹⁸Au in H₂O.

2nd Foil Run EXP #161 p 203 #21 Au Foil

Exp. time 3" - 4" PM 8-29-61 $1 - e^{-\lambda t} = .01063742$

Count time 5' $1 - e^{-\lambda T} = .000089080$

Decay time 4" PM \rightarrow 3³⁰ PM = 23hr 12Min $e^{-\lambda t} = .9978634 \times$
 $.781944$
 $= .780273$

$$S.A. = \frac{1163041}{4.153} \text{ c/MIN} \times \frac{.73937 \times 10^{-5}}{4.675 \times 10^{-5}} \times 2.972 \times 10^{-6} \times 10^{-5}$$

$$= \frac{4.675 \times 10^{-5}}{4.153 \times 10^{-5}} \text{ of } E = .019$$

$$S.A. = 2.4605 \times 10^7$$

This counting rate is probably too high
so that there are some counting
losses. ————— count later.

Foil Calc

Count Foil 9³⁰AM 9-5-61 20' count
 1,076,949 Total Counts Bkg subtracted

$$SA = \frac{1.077 \times 10^6 \times 3.2008 \times 2.972 \times 10^{-6}}{.00355845 \times .178107 \times .81063742 \times 6.742 \times 10^{-6}}$$

$t_{decay} = 161 \text{ hr } 20'$
 $t_{count} = 20'$
 $t_{exp} = 60'$
 3''-4'' PM 8-29

SA = 0.4748 x 10⁺⁶

$P^{-1} = \frac{.178743 \times 25}{.996441 \times 55} = .178107$

Average

SA = 24.74 x 10⁶ (411 km)

Self absorption correction 0.975

Flux depression and fitself shielding 0.8432

Cadmium Ratio .9263

Corrected for abs in Cd .9263 x .9678 = .8965

$$\frac{.8965}{.975 \times .8432} = 1.0905$$

S.A. = 26.98 x 10⁶ = $\phi N_{220} \times .8862$ $N = \frac{.2407 \times .6025}{197} = 0.0007362 \times 10^{22}$

$$\phi = \frac{26.98 \times 10^6}{0.0007362 \times 10^{22} \times 98.8 \times 10^{-24} \times .8862} = 0.4186 \times 10^9$$

$\phi = 0.4186 \times 10^9$ $\frac{\phi}{\text{watt}} = \frac{0.4186 \times 10^9}{8.69} = 4.82 \times 10^7$
 4.91

$\frac{\phi}{\text{Fission/sec}} = \frac{0.4186 \times 10^9}{.278 \times 10^{12}} = 1.506 \times 10^{-3}$ $\times 3.2$
 1.533

$\times 3.2 \times 10^8$ fission / 100 MW 4.68
 $\phi = 4.82 \times 10^{15}$
 4.91

Foil Calc.

Phone 9-5-61 from Wyatt

0-18	Ba	1.65×10^{12}
	Mo	1.53 "
	Ce	1.46 "
		$\frac{4.64}{3} = 1.55 \times 10^{12}$

T-5 (T-4)	Ba	2.81 "
	Mo	2.41 "
	Ce	2.35 "
		$\frac{7.57}{3} = 2.52 \times 10^{12}$

Total fissions inner annulus $\frac{2311}{13.45} \times 2.52 \times 10^{12} = 433 \times 10^{15}$
 analysis (14.35) .406

Outer annulus $\frac{5680}{15.49} \times 1.55 \times 10^{12} = 568 \times 10^{15}$
 analysis (15.28) 1.001 $\times 10^{15}$

fissions/sec = 0.278×10^{12}

watts = 8.69 watts $\times 273 = 8.53$ watts

2nd foil count = 1.0011×10^6 in 20' @ 2' PM

t decay = 16.6 hr $\times 10^4 \times .16943650 \times .99821919 = .169135$

SA = $\frac{1.0011 \times 2.972 \times 10^6}{3.5585 \times 10^{-3} \times .169135 \times 10.6374 \times 10^{-3} \times 6.4023 \times 10^{-6}} = 0.4647 \times 10^6$

3rd foil count = 0.991152×10^6 in 20' @ 4:25

SA = $\frac{.99115 \times 10^6 \times 2.972 \times 10^6}{3.5585 \times 10^{-3} \times 10.6374 \times 10^{-3} \times .165438 \times 37.8532 \times 10^{-6} \times 6.2624 \times 10^{-6}} = 0.4704 \times 10^6$


Av = 0.4700 SA = $\frac{0.4700 \times 10^6}{.019} = 24.74 \times 10^6$

Counter Eff = .019

Instrument Check on 8-25-61 Source 10mc ✓

PM-1 Zero @ 350 Low Trip OK @ 350 Alarm Trip OK
 PM-2 _____ Alarm Trip _____
 IC-1 $> 10 \times 10^{-12}$ Meter Trip OK Fast Trip OK
 IC-2 $> 10 \times 10^{-12}$ Meter Trip OK _____
 IC-3 5×10^{-11} Calibration OK _____
 IC-4 6×10^{-11} Calibration OK _____
 CRM _____ Preliminary Check on 8-25-61 _____
 Room 115 Pressure Differential OK
 Red Light On and Personnel Check OK
 Scrams and Bldg. Alarm Reset ✓ 8K7.
 Source Inserted ✓
 Safety Withdrawn ✓ 2812
 Controls Set Inner to 1721
 Reflector Water ~ 6" above Be
 Moderator Water 33.5

Expt 155
 Added 3 Cd straps to target outer
~~periphery~~ Periphery: .025" th. x 1/2" wide x 24.5"
 long and 120° apart.



Inner outer
 20.46 20.15 $T=138$ $P=4.87 \times 10^{-4}$ ~ 7.6¢
 20.14 20.15 + period
 just out

$$\frac{7.6 \text{ ¢}}{0.32 \text{ in on inner}} = 23.8 \text{ ¢/in}$$

Pulsing of Assembly used in Expt 153
 inserted. BF_3 ctr. in core

Fuel H₂ at ~~28~~ 32.7, Safety at 28.00

Inner Outer

17.33

17.23

- to correspond to
 critical position without
 Cd. in Target.

PN-128 Inner 17.33 Outer 17.23 - React of 3 ea $\frac{1}{2}$ " x 4"
 Acc 135 kv SF 67 ~1 μ a $\times 0.25$ ea
 strips
 on target
 200 μ s @ 70 cps

TMC Ch 40 μ s Delay X2 Bkg X 8 Disc 4

DET MIN BF_3 ^{@ 1725} DD-2 @ 14 x 200 PHS 450 (40-1000)

Instrument Check on 8-28-61 Source Y

PM-1	_____	Low Trip	<u>ok</u>	Alarm Trip	<u>ok.</u>
PM-2	_____	_____	_____	Alarm Trip	_____
IC-1	<u>> 10 x 10⁻¹⁰</u>	Meter Trip	<u>✓</u>	Fast Trip	<u>scrapped</u>
IC-2	<u>> 16 x 10⁻¹¹</u>	Meter Trip	<u>✓</u>	_____	_____
IC-3	<u>~ 4 x 10⁻¹¹</u>	Calibration	<u>ok JKJ</u>	_____	_____
IC-4	<u>~ 6 x 10⁻¹¹</u>	Calibration	<u>" "</u>	_____	_____
CRM	_____	Meter Trip	_____	_____	_____

Preliminary Check on _____

Room 113 Pressure Differential 0.09" H₂O
 Red Light On and Personnel Check ✓
 Scrams and Bldg. Alarm Reset ✓
 Source Inserted out of room, use accel.
 Safety Withdrawn 28.07
 Controls Set inner at 17.33, outer 17.23
 Reflector Water ~ 6" above Bc
 Moderator Water 32.87

Exp #157 Pulsing with 6 pc Cd $\frac{1}{2}$ " x 24" x 0.025PM-129 Pulsing with 6 pc Cd $\frac{1}{2}$ " x 24" x 0.025

Outer @ 17.33 Inner @ 17.23 Safety @ 28.11 Refl ~ 28.0

Fuel 33.69 IC-2 = 2.3×10^{-10} 110 cps 100 μ s BurstTMC 20 μ s

System arced over 3 times, on the third
 the isolation power went off.

Investigation of this resulted in finding
 a back contact of the binding post screw
 to the female banana plug on
 the output of the filter unit. (52)

2nd decade of Monroc fixed

EXP #158 Repeat. #157

PN-130 Pulsing with 6 pc $\frac{1}{2}$ " x 24" x 0.025"
Cd around target assembly.

Acc = 135KV 0.93 ma \approx 0.5 pa

100 μ s @ 110 cps

TMC Ch 20 μ s Bkg 8 Delay 2 Disc 4

Det Mu BF₃ @ 1725V DDZ 1.1 x 200 PH5 450

pulses 40-100 v

accelerator tripped 11. Got a channel on the
(Calman on top of the three void tubes
closely spaced on target)

8-28-61

Expt 158

Pulsing 9 pcs. $\frac{1}{2} \times 24 \times .025$ cd
strips.

Island Refl. ~ 6" above Be, Fuel H₂O = 33.2"
Safety 28.10

Inner C. 17.33" Outer Control = 17.23

PN-131 9pc Cd $\frac{1}{2} \times 24 \times 0.025$

Inner 17.33 Outer 17.23

Acc 135 kv 1 ma 1.5 μ a 100 μ s @ 150 cps

TMC Ch 10 μ s Bkg 16 Delay 82 Disc 4

Det Min BF₃ @ 1725 @ PHS 450 Pulse.

3³⁹ PM

Exp # 159

8-28-61

Pulsing 12 Pcs $\frac{1}{2} \times 24 \times .025$ cd
strips

Island Refl H₂O 6" Above Be, fuel H₂O 33.72

INNER - Outer Safety

17.33" 17.23" 28.10"

PN-132 12pc Cd $\frac{1}{2} \times 24 \times 0.025$

Inner 17.33 Outer 17.23

Acc 135KV 96 ma μ a 100 μ s @ 150 cps

TMC 10 μ s Bkg 16 Delay 2 Disc 4

Det ML BF₃ @ 1725V DD 2 1.1 X 200 PHS 450

power (40 - 120V on scope)

PM-1	Low Trip	ok	Alarm Trip	ok
PM-2			Alarm Trip	
IC-1	$> 10^{-11}$	Water Trip	ok	Test Trip ok
IC-2	$> 10^{-11}$	Water Trip	ok	
IC-3	$\sim 4 \times 10^{-11}$	Calculation	ok	ok?
IC-4	$\sim 5 \times 10^{-11}$		ok	"
CRM	Water Trip			

Preliminary Check on 8-29-61

Room 113 Pressure Differential .09" H₂O
 Red Light On and Personnel Check not on sub-crit test
 Scrums and Bldg, Alarm Reset ✓
 Source Inserted _____
 Safety Withdrawn 28.03
 Controls inner 0.00 outer 0.00
 Reflector Water $\sim 6"$ above Be
 Moderator Water 33.3"

Expt. 160

Check on effectiveness of M-226
 in ^{bottom of} radial beam hole at a
 start-up source using fix. ctr in
 bottom refl.

Target out, all water up &
 Safety up

A. $\text{Counts}/10 \text{ min} = 497 \times 10 + 13 = 796.5$ ^{counts} ~~min~~
 IC-4 = .009, IC-3 = .0015

Put Safety down to zero; IC-4 = .007
 IC-3 = .0008

B. $\text{Counts}/10 \text{ min} = 198 \times 10 + 14 = 3182$ ^{counts} _{min}
 Removed source:

C. $\text{counts}/10 \text{ min} = 9$

202-29-61

Expt 160 cont

With safety still down put normal
M-43 back in with large source M-22c
out of room. (against top of fuel element)

$$IC-3 = .0015, \quad IC-4 = .0005$$

$$\text{Counts/10min} = 25 \times 16 = 400 = 40 \frac{\text{Counts}}{\text{min}}$$

Raised safety to 28.06"

$$IC-4 = .0025$$

$$IC-3 = .0008$$

$$\text{Counts/10min} = 99 \times 16 + 14 = 1598 = 159.8 \text{ cts/min}$$

Min. BF^3 cts removed from core
before Expt 160

M-43 Back on source rod drive

8-29-61

Expt 161

203

Gold foil in target region (Targets out). Fuel Plate irradiation for flux per fission

Gold foil No. 21, 0.2407 gm Au.

T-4 in pos 37

O-18 " for 78

Refl. H₂O ~ 6" above Be, Fuel H₂O = 33.5
Safety at 28.00, alarm reset

3⁰⁰ pm Inner 18.70 Outer 18.70 ~ crit.

" " " 19.32 for pos. period

Start at 3⁴ 3×10^{-8} on IC-2

level at 8×10^{-5} " " ; IC-1 @ $3.6 \times 3 \times 10^{-7}$

Both ln units off scale

10 m. 6 ft straight out from center of Rm 108 door, negligible in Rm 217

1/2 m. at center of water window in Rm 112

Inner 18.70 outer 18.76 at level.

4⁰⁷

18.70 " 18.755 level

IC-2 = 8×10^{-8} IC-1 $3.6 \times 3 \times 10^{-7}$

lns back on scale at ~ $3-4 \times 10^{-8}$ on IC-2 ~~to~~ with

4¹¹

Shut Down Insert ~~Inner~~ and Outer Control
lower Safety to 2" and Dump Fuel H₂O

4²⁴

ln's near level at ~ 10^{-10} Refl. up

Note increase to ~ 1.5×10^{-10} after draining
Refl. 92% 0.8% at plywood cover adj. to control.

204
8-31-61

Exp # 162

With Inner Control at zero and Outer Control at 22.00" inserted 5-9" wide strips of .025" Cd + 1-10" wide strip between Inner and Outer Controls leaving approx. a 1" gap in the annulus. Strips were 48" long with top edges attached ~ 1/4" above top of outer control cylinder. In this position the strips reached to about 1/4" above fuel zero.

"Note" → Removed Source M-43 from Assembly and Installed BF-3 ct
Instrument Check on 8-31-61 Source

PM-1	Low Trip	ok	Alarm Trip	ok
PM-2			Alarm Trip	
IC-1	> 10 ⁻¹¹	Meter Trip	ok	Fast Trip ok
IC-2	> 10 ⁻¹¹	Meter Trip	ok	
IC-3	~ 5x10 ⁻¹¹	Calibration	ok gkz	
IC-4	~ 6x10 ⁻¹¹	Calibration	ok gkz	
CRM		Meter Trip		

Preliminary Check on 8/31-61

Room 113 Pressure Differential 0.08"
Red Light On and Personnel Check ✓ C.C.
Screams and Bldg. Alarm Reset ✓ C.C.
Source Inserted Use Accelerator
Safety Withdrawn 28.02"
Controls Set Inner 00.04 Outer 22.0"
Reflector Water 6" Above Bc
Moderator Water 34.07"

Without Target

3PN-92

NUMBER OF POINTS 116

ESTIMATE 3

PARAMETERS

VARIANCES

B 1	2 18866193	73752937
B 2	5 12636702	5 66815240
B 3	4-19227582	3 29874945

VARIANCE Y

1 21686130

PN-133 Pulsing with 0.025 Cd between controls

Inner 0.04 Outer 22.00

Acc 135KV 1.06 ma 3µa Target

100µs @ 330 cps (3000µs) 3%

TMC ch 10µs Bkg 16 DELAY 2 DISC 4 MEM 1/2

DET MIN BF₃ 1725 DD-2 1.1x200 PHS=450

(Pulses 40-100+ volts) w.o Target

PN-134 Repeat of above

Acc 135KV 0.97 ma 2µa Target

100µs @ ¹⁷⁰330 cps

TMC ch 10µs Bkg 16 Delay 2 Disc 4 Mem 1/2

DET MIN BF₃ 1725 DD-2 1.1x200 PHS 450

(Pulses 40-100+ volts)

w.o. Target

359 Shut Down Insert Safety, Dump Fuel H₂O

"Note"

Salvage obtained from Dissolving foils

#0-16-1, 0-16-2, U-2-1, AND U-2-2

for Chemical Analysis, (by Mr Cooper), was

Added too U/235 Salvage on West End.

total U APPROX 0.25 g date 9-1-61 C.C.

9-1-61 Target Inserted

Instrument Check on 9-1-61 Source γ

PM-1	Low Trip	ok	Alarm Trip	ok
PM-2			Alarm Trip	
IC-1	$> 10^{-11}$	Meter Trip	ok	Fast Trip <u>scrapped</u>
IC-2	$> 10^{-11}$	Meter Trip	"	
IC-3	$\sim 5 \times 10^{-11}$	Calibration	ok	
IC-4	$\sim 4 \times 10^{-11}$	Calibration	ok	
CRM	Meter Trip			

Preliminary Check on 9-1-61

Room 113 Pressure Differential $0.09''$

Red Light On and Personnel Check C.C.

Scrums and Bldg, Alarm Reset C.C.

Source Inserted Use Accelerator

Safety Withdrawn $28.04''$

Controls Set INNER 0.04'' Outer 22.0''

Reflector Water 6'' Above Ben

Moderator Water 33.77''

Exp # 163

9-1-61

9¹² AMSame as ^{EXP 2} 162 except target inserted

PN-135 Inner 0.04 Outer 22.0 with 0.25 Cd

ACC 135 kv 1.0 ma $2\frac{1}{2} \mu a$ 100 μs @ 330 cpsTMC Ch 10 μs , Delay x 16 Delay 2 Disc 4 Mem 1/2DET Min BF₃ at Midplane @ 1725 v

DD-2 1.1 X 200 PHS 450

Pulses 40-100 v.

Exp # 164

9-1-61

207

10²⁰

INNER 22.0" Outer 0.00"
Ref1 H₂O 6" Above Be fuel H₂O
Safety 28.04"

Inserted Cd-strips as in Expt. 162,
with top edges of strips at top of outer
C. in its new position (0.00). This means
that strips extend ~ 22" below bottom
of fuel & 8" above. Target in.

PN-136 Inner 22.0 Outer 00.0
with 0.025 Cd between

Acc 135kv 1.0ma μ a 100 μ s 170cps
TMC @ 20 μ s Bkg 16 Delay 2 Disc 4 Min 11/
OET M₂ BF₃ @ 1725 DDZ 1.1X200 PH5450

11⁵⁰

Drain #20

208

Exp # 165

9-1-61

10⁴ PM Inner 0.04" Outer 00.00"
 Refl H₂O 6" Above Be Fuel H₂O 33.19"
 Safety 28.09"

6-cd strips between Inner & Outer
 Control cyls as in Expt. 164

PN-137 Inner = 00.04 Outer 00.00

Cd between controls

HALF Mummy

135 KV 10 ma 100 μ s 330 cps

tmc ch 20 μ s Bkg x16

153 shut down: Safety inserted.

Fuel Water slightly below top of Fuel plates
 at a reading of 22.02"

After draining 25.1 kg water system
 reads 5.24"

22.02
 5.24
 16.78

16.78" \approx 25.2 l, ¹⁵⁰⁰ ~~1490~~ l/m.; 30 l in core

0.59 l/cm in core

2 1.12" water in barrel
 $\times 6.575 = 137.5$ l

+ d.v. = 4.412 Total = 162 l

9-5-61

Drained fuel water out into a 30 gal drum and weighed back into system

100 lb. kg

Added 57 gm H_3BO_3 and stirred

Instrument Check on 9-5-61 Source

PM-1	Low Trip	ok	Alarm Trip	ok
PM-2			Alarm Trip	
IC-1	7×10^{-11}	Meter Trip	ok	Fast Trip
IC-2	5×10^{-11}	Meter Trip		scrammed
IC-3	$\sim 4 \times 10^{-11}$		ok	ok
IC-4	$\sim 6 \times 10^{-11}$		ok	ok

CRM

Preliminary Check on

Room #13 Pressure Differential 0.09"
 Red Light On and Personnel Check
 Scrams and Blg, Alarm Reset
 Source Inserted
 Safety Withdrawn 28.0"
 Controls Set Inner 17.50" Outer 999.81"
 Reflector Water $\sim 6"$ above Be
 Moderator Water $\sim 28.0"$

Expt 164

critical conditions after adding 57 gm H_3BO_3 to 100 l Fuel Water ≈ 0.100 g/l B, ≈ 3 g/l total

T=102, 9.7 & 152

Inner	19.40	Outer	19.60	↑	for period
"	19.40	"	19.08		Level
"	19.275	"	19.275		" 18.7 g/l

225- Shut Down insert Outer Control, Safety
 And Dump Fuel H₂O

* Lost ~ 5.7 l thru sight. Glass; Left 94.3 l

~~3~~ ⁴⁰ PM Added 54 gm H_3BO_3 too fuel H_2O And Stirred, Total now ~ 108 gm in 94 l. 0.201% B. Purpose: Check Critical Conditions (6.03% Total)
Ref H_2O 6" Above Be - fuel H_2O 28.40"
Safety 28.05"

	Inner	Outer		
3 ⁵⁷	19.275"	999.81"	Source out	
	24.80"	28.80"		Approx Crit
	24.80	25.50"	$\rho = 6.73113$	Pos Per
	24.80	26.00" $T=92$	$\rho = 10.54$	Pos Per
4 ¹²	24.80	24.91	1.09 inch	level
4 ¹⁷	24.84	24.84	9.6 1/inch	level

Shut Down Insert Outer Control, Safety
And Dump fuel H_2O

Measured height in drum after adding 100 kg water was $15\frac{1}{8}$ ".

After spill over of sight glass height in drum was $14\frac{1}{4}$ ".

See p. 56 for 6.5 1/in max diam of barrel

PM-1 Low Trip Scrammed Alarm Trip ok
 PM-2 Alarm Trip
 IC-1 > 10" Motor Trip ok Fast Trip ok.
 IC-2 > 10" Motor Trip ok.
 IC-3 ~ 5x10⁻¹¹ Calibration ok Dur
 IC-4 ~ 5x10⁻¹¹ Calibration " "
 CRM Preliminary Check on

Room 113 Pressure Differential 0.09" H₂O
 Red Light On and Personnel Check ✓
 Sirens and Bldg. Alarm Reset ✓
 Source Inserted ✓
 Safety Withdrawn 28.02
 Controls Set Inner 25.0" Outer 999.81"
 Reflector Water ~ 6.5" above 13e
 Moderator Water 28.31"

Exp # 168 9-6-61

8⁵² AM Purpose: Repeat of Exp # 167
Inner outer Source Out
24.84 24.84 Approx exit
24.84 25.75 5.9 div → 128 sec Pos Per
24.85 24.85 became = 8.09 # Level
.89

9¹⁵ Shut Down Insert Outer Control, Safety
And Dump Fuel H₂O 9.7 d/inch

Since inner was moved, period does
not give us a rod sensitivity point! Duh
Water temperature measured 23.6°C in dump barrel

212
9-6-61

Exp # 169

Added 98 gm H_3BO_3 to the ~ 94 l
fuel water storage. Total now 206 gm
 $\approx 0.3835\% B$; 11.5 g B in core

9⁴⁸

Source in Safety 28.03"

Ref H₂O 6" Above Bc Fuel H₂O 28.03"

Inner Outer

25.0" 999.81"

Inner 31.54 outer 31.34

Level

31.54 32.00" T=97, P= $\frac{10.14}{43}$

Pos Per

10³⁰

31.54 31.57

level

10³⁵

31.555 31.555

level

Shut Down Insert outer Control, Safety
AND Dump fuel H₂O

Rad Sens 23.5 d/l

Added 65g Boric Acid to fuel
water storage; Total now 271g. $0.504\% B$

Exp 170

9-6-61

15,129 B
Total

12²⁵

Source in Safety 28.01"

Ref H₂O 6" Above Bc Fuel H₂O 28.15"

Inner Outer
35.00" 999.81"

12⁴⁰

33.32 33.32

Source out Approx Crit

33.32 33.51

$76.1 \text{ sec} \rightarrow 7.75 \times 10^{-4} = 12.14$ Pos Per

1⁰⁵

33.32 33.32 level with outer only level

Shut Down Dump fuel H₂O, Insert outer
Control, AND Safety.

$\frac{12.14}{.19} = 63.7$ inch

Exp # 171

9-6-61 213

Added 120 gm H_3BO_3 to fuel water system and mixed. Total now 391 gm
 $0.7288 \text{ g/g B} \approx 21.82 \text{ g in core}$

2 ¹⁴

Source in Safety 28.02 28.16
Ref1 H₂O 6" Above Be fuel H₂O ~~27.72~~

INNER Outer
33.50" 999.81

2 ³⁰

35.31" 35.31 Source out Approx level

35.31 35.47 89.1 sec 6.9 x 10⁻¹ Pos Per

2 ⁴⁵

35.31 35.29 $\frac{10.84}{.}$ level

Shut Down Insert outer Control, Safety, Dump fuel H₂O

Exp # 172 9-6-61

Added 120 g H_3BO_3 , Total 511 g
 $0.9519 \text{ g/g B} \approx 28.537 \text{ gm B in core}$

3 ³⁷

Source in Safety 28.01

Ref1 H₂O 6" Above Be fuel H₂O 28.47"

INNER Outer
36.00" 999.81"

3 ⁵⁵

37.41 37.41 Source out Approx Crit

37.41 37.61 $\bar{f}=95, \rho=10.2$ Pos Per

37.41 37.385 $\bar{S} = \frac{10.2}{.225} = 45.3$ level

37.40 37.40 level

4 ¹⁷

Shut Down Dump fuel H₂O, Insert outer Control, And Safety

PM-1 Low Trip ok Alarm Trip ok
 PM-2 Alarm Trip
 IC-1 710⁻¹¹ Meter Trip ok Fast Trip overammed
 IC-2 710⁻¹¹ Meter Trip ✓
 IC-3 ~ 5x10⁻¹¹ Unstable
 IC-4 ~ 6x10⁻¹¹ ok yk7
 CRM Meter " "
 Preliminary Check on
 Room 113 Pressure Differential 0.09" H₂O
 Red Light On and Personnel Check ✓
 Scrums and Bldg. Alarm Reset ✓
 Source Inserted ✓
 Safety Withdrawn 28.10
 Controls Set INNER 37.40" Outer 999.81"
 Reflector Water 6" Above Be
 Moderator Water 28.53"

Expt 173

Replaced Original plates as follows:

- A-1 - P2 for Flux Traverse
- B-1 - F4 in fuel
- A37 P1
- B78 F2

Source Out

INNER - Outer

37.40" 37.90" T=60, P=144 $\frac{1}{.78}$ Pos Per

Start timing 20 min foil Exposure, IC-2 3×10^{-9}

37.40 37.62 level

IC-2 = 7.8×10^{-9} IC-4 2.6×10^{-8}

Shut Down Drop Safety, Insert Outer Control

Exchanged Source M-228⁴³ for Source M-228


Note 10¹²

Note

Expt. 174

Normalizing U²³³ Counts 5 min. Fis. Ctr. Fis. Ctr. Fis. Ctr. U²³³ Ratio

U ²³³ Counts	5 min.	Fis. Ctr.	Fis. Ctr.	Fis. Ctr.	U ²³³ Ratio
12,800	5.00	1067+48	273,200	21.34	
13,220	7.00	387+85	99,100	8.12	
11,840	9.00	135+179	34,725	2.99	2.93
12,010	11.00	51+57	13,112	1.072	
12,450	13.00	70+145	4,200	0.944	
3 min (594970)		(increased Power) 3 min			
1355,180	13.00	(956+189)	24,990	0.420	
1353,930	15.00	231+111	59,260	0.167	
587,850	17.00	97+59	24,880	0.070	
584,200	19.00	43+84	16,090	0.0189	
582,200	21.00	24+41	8,180	0.0106	
577,930	24.00	11+215	3,030	0.0052	
574,860	22.00	24+188	4,330	0.0081	
572,500	20.00	29+149	7,570	0.0132	
345,720	18.00	69+35	17,690	0.0309	
344,730	16.00	88+80	22,610	0.0654	
345,120	14.00	206+118	72,840	0.211	
103,780	12.00	512+50	131,150	0.381	
23,570	10.00	407+241	104,450	1.004	
	8.00	249+28	63,830	2.71	



Instrument Check on 8-8-61 Source Y

PM-1	Low Trip	<u>ok</u>	Alarm Trip	<u>ok</u>
PM-2			Alarm Trip	
IC-1	<u>7×10^{-11}</u>	Meter Trip	<u>ok</u>	Fast Trip <u>scrammed</u>
IC-2	<u>7×10^{-11}</u>	Meter Trip	<u>"</u>	
IC-3	<u>5×10^{-11}</u>	Calibration	<u>ok</u>	
IC-4	<u>6×10^{-11}</u>	Calibration	<u>ok</u>	
CRM		Meter Trip		

Preliminary Check on 8-8-61

Room 113 Pressure Differential 0.09" H₂O
 Red Light On and Personnel Check ✓
 Scrams and Bldg, Alarm Reset ✓
 Source Inserted ✓
 Safety Withdrawn 28.12
 Controls Set 37.5 outer!
 Reflector Water 2.6" above Bc
 Moderator Water 28.6"

Exp 175-

9-8-61 Repeat of Exp # 174

10⁰⁰ AM Source out

INPER - Outer

37.50	37.70		Pos Per
37.55	37.55	IC-2 $\sim 5 \times 3 \times 10^{-10}$	Level
37.55	37.55	IC-2 7.5×10^{-9}	Level
37.55	37.55	IC-2 $2.6 \times 3 \times 10^{-9}$	
37.55	37.55	IC-2 $2.8 \times 3 \times 10^{-9}$	

12³⁰

Shut Down Insert Outer Control, Safety
 And Dump Fuel H₂O

Note Found Bad Jelsyn on Fission Counter
 Drive. (Replaced by Mr. Richard)

EXPT 175							
U233 Total	Fis. Ctr. Position	Fis. Ctr. Counts X 256	Fis. Ctr. Counts Total	U ²³⁵ U ²³³ Ratio	Time	IC-2	
12960	5.00	1110 ⁺¹⁴	284,176	21.93	5 min.		0.15×10^{-9}
12,430	7.00	393 ⁺¹⁴⁷	100,755	8.11	"		
12,450	9.00	143 ⁺⁹⁴	36,702	2.95	"		
12,960	11.00	54 ⁺¹⁸⁶	14,010	1.081	"		
431,630	13.00	736 ⁺³⁷	188,453	0.437	3 min		7.5×10^{-9}
435,770	15.00	296 ⁺¹⁵³	75,929	0.174	"		
432,230	17.00	127 ⁺¹⁰⁸	32,620	0.0755	"		
430,940	19.00	57 ⁺¹⁵³	14,745	0.0342	"		
430,310	21.00	28 ⁺¹⁷	7,185	0.0147	"		
714,590	"	46 ⁺²¹⁷	11,993	0.0168	5 min		
719,010	23.88	16 ⁺²¹⁸	4,314	0.00600	"		
719,570	22.00	32 ⁺²²⁰	8,412	0.0117	"		
714,640	20.00	65 ⁺¹⁵³	16,790	0.0235	"		
713,880	18.00	139 ⁺¹⁵³	35,750	0.0501	"		
706,470	16.00	307 ⁺¹⁶⁹	78,770	0.112	"		
422,850	14.00	436 ⁺⁵	111,600	0.264	3 min		
420,220	12.00	1056 ⁺⁹⁹	270,400	0.644	"		
38830	"	98 ⁺¹⁶⁵	25,260	0.650	"		6.6×10^{-9}
48,910	16.00	447 ⁺¹⁵⁷	114,560	1.68	5 min		
72,390	8.00	1254 ⁺²⁰⁷	321,300	4.44	"		
9930	6.00	471 ⁺²⁷	120,600	12.15	"		
10340	5.00	776 ⁺¹⁷⁶	198,880	19.22			

Expt 176

U ²³³	Fis, Ctr. Pos.	Fis, Ctr x 25k	Fis. ctr Total counts	U ²³⁵ U ²³³			
13160	5.00	1194 ⁺¹⁰⁹	305,773	23,24	5 min		
13530	9.00	159 ⁺²⁴²	40,946	3.03			
711,480	13.00	1251 ⁺¹⁶⁸	320,424	0.450			
733,940	17.00	228 ⁺⁸⁴	58,452	0.0796			
764,500	21.00	47 ⁺²⁴³	12,275	0.0161			
978,080	24.00	16 ⁺¹	4,097	0.00604			
469,220	19.00	93 ⁺¹⁷⁶	23,984	0.0358			
672,440	15.00	488 ⁺¹⁰²	125,030	0.186			
755,30	11.00	327 ⁺²⁴⁴	83,956	1.112			
14,020	7.00	475 ⁺⁴⁰	121,690	8.68			
13,990	5.00	1251 ⁺¹¹⁶	320,372	22,90	✓		

Exp # 176

9-8-61

217

9

148

Repeat of Exp # 175

Source in Safety 28.04"

Ref1 H₂O 6" Above Be fuel H₂O 28.42

152

INNER - Outer fission ctr

37.55 37.75 5.0" Pos Per

37.55 37.55 IC-2 = $5 \times 3 \times 10^{-10}$ level

37.55 37.55 IC-2 = $7.2 \times 3 \times 10^{-10}$ level

37.55 37.55 IC-2 = $2.8 \times 3 \times 10^{-9}$ level

3³⁰

Shut Down Insert outer control, Safety AND

Dump fuel H₂O

2
2.55
)
as
was
are
was
h
input

September 11, 1961

Foils punched from the HPFIRE #2 fuel plates had been counted for their natural background from the uranium, a 0.18 mev gamma in U^{235} . The counters SA 1 and 2 were set with at $E = 75$ $\Delta E = 1000$, (gain adjusted so that peak of Cs^{137} occurred at $E = 400$.) This setting of the analyzers did not count ~~then~~ the lower ^{energy} peak observed in this uranium and believed due to other isotopes of uranium. By comparison to a weighed metal piece in SA 1 and SA 2, then the uranium was determined after correction for the self abs. of the 0.18 Mev gamma ray in uranium and also the abs. in the aluminum of the foil. This calibration was completed in June.

On ~ Sept 6-7, Cherverton reported by phone that Beaver had said that there was a possibility that the HPFIRE uranium was partially irradiated uranium because the isotopic analysis was different - how different not specified. As a result of this the 3x3" NaI crystal was used with the S.A. of the 20 channel analyzer and the TMC 256 channel analyzer CV-110 and Plug-in 210 with high level input.

gain on phototubes was adjusted so that with LA. gain of $\times 4$ the Cs^{137} peak occurred in channel 66

Gain was increased to for counting the Uranium and 0.18 μ sec occurred in channel 71. The details of the spectrum under high resolution showed four peaks in both standard and foil U-2-4 (Baseline at 30)

U-2-4		Std Metal	
16	5418	144-128-16	5414
31	16304	161-128-33	19243
54	8749	182-128-54	8382
71	31657	149-128-71	32191

Background has been subtracted by the TMC by counting in the subtraction mode for a live time equal to the time needed to collect 32768 counts in peak at Ch 71. Although there are significant differences in the peak at Ch 31 - 33, this region was excluded in counting on SA1 and 2. The slight differences in 54 and 71 peaks are partly statistical and partly real, but it is hard to find anything that would be larger than 1%. For details see tape

Back subtracted

U-2-4

73	90000
1	7
2	65500
3	16
4	3642
5	3759
6	2048
7	1582
8	1429
9	1753
10	2022
11	2275
12	2600
13	3517
14	4583
15	5152
16	5418
17	5073
18	4740
19	4484
20	4153
21	3811
22	3525
23	3226
24	2927
25	2627
26	2326
27	2025
28	1724
29	1423
30	1122
31	821
32	520
33	219
34	186
35	157
36	124
37	95
38	66
39	37
40	8
41	14450
42	13361
43	11715
44	9993
45	9012
46	7858
47	6971
48	6179
49	5176
50	4376
51	3596
52	3435
53	2967
54	3038
55	3280
56	4037
57	5074

40	2000
49	4037
50	5074
51	6419
52	7646
53	8508
54	8749
55	8714
56	8285
57	7528
58	6866
59	6303
60	6297
61	6523
62	7261
63	8551
64	10549
65	13358
66	16938
67	21311
68	25345
69	28407
70	30945
71	31657
72	31096
73	28297
74	25319
75	21152
76	17156
77	13262
78	10391
79	7808
80	5979
81	4440
82	3251
83	2312
84	1833
85	1378
86	924
87	600
88	492
89	384
90	235
91	108
92	156
93	104
94	155
95	86
96	29
97	124
98	27
99	114
100	63
101	65524
102	50
103	5
104	79
105	17
106	36
107	19
108	1
109	76
110	91
111	65420
112	5
113	86

113		86
114		35
115		47
116		39
117		26
118		60
119	1	113
120		66
121	655	17
122		7
123	655	30
124		54
125		14
126	655	32
127		22
128		66

Bkg Subl.
Standard
U metal

129		14
130		32
131		9
132	31	63
133	33	57
134	20	01
135	17	35
136	15	94
137	17	59
138	20	51
139	23	35
140	26	18
141	35	46
142	44	27
143	51	71
144	54	14
145	51	45
146	49	97
147	48	91
148	48	64
149	51	55
150	59	48
151	67	61
152	76	70
153	84	43
154	93	83
155	107	09
156	126	87
157	143	10
158	161	88
159	176	83
160	188	30
161	192	43
162	188	31
163	175	12
164	156	85
165	138	02
166	116	62
167	101	72
168	85	77
169	72	46

169	7246
170	6393
171	5232
172	4222
173	3363
174	2918
175	2830
176	2989
177	3718
178	4580
179	5911
180	6982
181	7955
182	8382
183	8070
184	7999
185	7193
186	6683
187	6306
188	5807
189	6268
190	6867
191	8337
192	10454
193	12934
194	16445
195	20577
196	24895
197	24569
198	30839
199	32191
200	31429
201	29433
202	25736
203	21699
204	17802
205	13988
206	10979
207	8485
208	6321
209	4683
210	3568
211	2635
212	1960
213	1396
214	1068
215	782
216	510
217	421
218	289
219	225
220	197
221	130
222	178
223	79
224	79
225	209
226	99
227	62
228	116
229	104
230	51

230	51
231	100
232	40
233	60
234	54
235	30
236	65
237	103
238	73
239	97
240	125
241	78
242	78
243	73
244	41
245	43
246	85
247	41
248	27
249	56
250	77
251	655 33
252	79
253	74
254	48
255	43
256	44


collected in
 $\frac{1}{2}$ transferred
to $\frac{2}{2}$

3x3 XTL NAI 9.3 cm

sample distance 20 cm

L.A. Hi-Level deposit on

TMC.



222

9-11-61

Instrument Check on 9-11-61 Source

PM-1	Low Trip	ok	Alarm Trip	ok
PM-2	Low Trip		Alarm Trip	
IC-1	710 ⁻¹¹	Meter Trip	Fast Trip	
IC-2	710 ⁻¹¹	Meter Trip		
IC-3	~ 4 x 10 ⁻¹¹	Calibration		
IC-4	~ 6 x 10 ⁻¹¹	Calibration		
CRM		Meter Trip		

Preliminary Check on 9-11

Room 113 Pressure Differential 0.09"

Red Light On and Personnel Check Scrams and Bldg. Alarm Source Inserted

Safety Withdrawn 28,00

Controls Set

Reflector Water ~ 6" above Be

Moderator Water 28.03"

EXPT. 177

Foil Irradiation for flux normalization

Target out

T-3-6 1m center of island

T-3-4 " " " a-37 (T-2 plate)

T-3-1 contact with Be

T-3-2 2" from Be

T-3-3 4" " "

T-3-5 6" " "

T-3-7 5" above fuel next to island

U-1-3 7" " " " "

Inner Outer

38.56

38.56

~ level

10 ⁴¹ Start timing 20 min foil Exposure IC-2 3×10^{-9}
 11 ⁰¹ Stop foil Exposure IC-2 7.6×10^{-9}
 Shut Down INSERT Outer Control, Dump fuel H₂O

Analysers And lower safety to 8.5"
 0.95 mg B/ml Removed two samples of Fuel Water for B anal.
 Sp Gr. = 1.0042 Added 60 gm H₃BO₃ Total 570 #181A
 @ 24°C 10-9-61 this addition of H₃BO₃ was from Lot No. 22105 Balance Boic Acid
 Instrument Check on 9-12-61 Source Circuit
SWR

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 10^{-11}$	Meter Trip	OK	Fast Trip Scrammed
IC-2	$> 10^{-11}$	Meter Trip	✓	
IC-3	$\sim 5 \times 10^{-11}$	Calibration	OK	
IC-4	$\sim 5 \times 10^{-11}$	Calibration	" "	
CRM		Meter Trip		

Preliminary Check on
 Room 113 Pressure Differential 0.09" water
 Red Light Control Panel Check ✓
 Scrams and Emergency Stop ✓
 Source Indicator ✓
 Safety Emission 28.50
 Controls Room 39.50 Outer -
 Reflector Water ~ 6" above Be
 Moderator Water 28.2

Target replaced in island.

229-12-61

Expt. 178

Test for crit control rod position
after adding 60 gm H₃BO₃ Total 571

10-9-61 (RAN, 22105)
DWR

≈ 1,062 g/l; 31.9 g/B in core 570

	INNER - Outer		
8 ⁵³	38.90	38.90	Source out
9 ⁰⁶	38.90	39.22	Approx level
9 ¹⁴	38.90	38.90	T=11, ρ=12.03¢ = 37.6¢/m Per
9 ²⁸	44.245	36.61	level
	36.92	43.95	level

Shut DOWN Insert outer control, Safety
And Dump fuel H₂O

10-9-61
Rod No 22105
DWR

Added 60 gm. Boric Acid to fuel water
and mixed. 6.7 g/l ≈ 1,173 g/l; 35.2 g Total in core
Total 630g

Exp # 179 9-12-61

11 ²¹	Source in	Safety	28.02
	Ref H ₂ O 6" Above Bc	Fuel H ₂ O	28.02
	INNER	outer	
	39.75	25.83	
	40.83	40.83	Source out
11 ⁴⁰ AM	40.83	41.30	Approx Crit
			POSITIVE PERIOD
		99.3 am 9.9¢	ρ = 23.6¢/m
	40.83	40.88	

Evidence that the reactivity is not
stable - position changed from .86 to .88
in ~ 5 minutes.

Moderator H₂O @ 27.71, pumped to 28.42
 no change in level.
 40.86" 40.86" level @ 5.7×10^{-10} on IC-2

10-9-61
 Lot # N62205
 DWPM

Added 60 gm Boric Acid and mixed.
 Total 697 - 7.34 g/l

Experiment # 180 Determine Crit Pos w. 690

gm Boric Acid. Reflector H₂O ~ 28.9", Source in
 Moderator H₂O → 28.54 Safety to 28.03 (Inner = 40.86)
(outer = 0)

Inner 43.90 outer 43.95

Subcritical

Added 3l of water to fuel water
 storage 7.12 g/l total vol ~ 97l

EXPT. # 181

Source in Safety 28.04"

fuel H₂O 6" Above Bc fuel H₂O 28.23"

Inner - Outer

43.97 - 43.95" source out Sub Crit

Shut Down

Added 1l water to fuel water
 storage. total vol ~ 98l.

~ 7.05 g/l
 (36.67 dwm)

$.175 \times 7.05 = 1.234 \text{ g B/l}$

~ 3.70 g in core

226

EXPT # 182 9-12-61

Source in Safety 28.00"
 Refl H₂O 6" Above Be fuel H₂O 28.74"
 Inner Outer
 43.90 32.81
 43.90 43.95
 43.90 42.58
 43.06 43.06
 Shut Down

$T = 123 \text{ sec}$ $\frac{8.44}{13} = 6.44 \text{ in.}$
 Source out Super Crit Level

233

Inserted:
 Q-1, - P2, Q-37, - P-1
 D-1, - F-4, B-78, F-2

Instrument Check on 9-13-61 Source 8

PM-1	Low Trip	ok	Alarm Trip	ok screamed
PM-2			Alarm Trip	
IC-1	> 10"	Meter Trip	ok	Fast Trip ok
IC-2	> 10"	Meter Trip	ok	
IC-3	~ 5 x 10"			
IC-4	~ 5 x 10"			
CRM				

Preliminary Check on 9-13-61

Room 113 Pressure Differential 0.09"
 Red Light On and Personnel Check ✓
 Scrums and Bldg. Alarm Reset ✓
 Source Inserted ✓
 Safety Withdrawn 28.07"
 Controls Set INNER 43.90" - Outer 30.00"
 Reflector Water 6" Above Be
 Moderator Water 28.58"

9-13-61

Expt. 183

227

Flux traverse in fuel. For plate positions see opposite page

8 ⁵²	Inner 43.33	Outer 43.33	~ Level
	43.90	43.95 ^{259 sec}	4.454 Pas Per
9 ¹⁶	Start timing 20 min foil Exposure IC-2 3×10^{-9}		
9 ³⁰	43.35	43.35	IC-2 7.8×10^{-9} level
9 ³⁶	Stop Exposure IC-2 7.8×10^{-9}		

Note

Drop Safety Insert Outer Control

Note

9-13-61 Samples #2 AND 2A taken from fuel H₂O system approx 100g per sample

9-14-61 Sample #2 sent to (Mr Laing x-10) for analysis
Analysis 1.19 mg/ml Sp Gr. = 1.0070 @ 24°C

Exp # 184 9-13-61

2⁴⁵

Purpose:

use Accelerator for Source - Safety 28.04
 Refl H₂O 6" Above Be fuel H₂O 28.68"
 INNER - Outer
 22.00" - 00.00"

PN-138 Inner 22.00 Outer 00.0 Boron Poisoned

CARE CRIT AT 43.36 EXP#184 TOTAL 558.390

ACC 135KV 1.07ma 4.5MVA 100MUS 330 cps

TMC 10MUS BKG X32 DELAY X2 DISC 4

DET MINBF₃ @1750 DD 2.11 X 20 PHS 450

2 Breakdown

EXP = 185

PN-139 EXP 185 INNER 0.05 OUTER 0.00 BORON

POISON CORE CRIT AT 43.36

ACC 135KV 1.10 MA 5MUA 100MUS 330 CPS

TMC CH 10 MUS BKG 32 DELAY 2 DISC 4

DET MIN BF3 AT 1750V DD2 1.1X 200 PHS 450

1 Breakdown

Instrument Check on 9-14-61 Source 8

PM-1	Low Trip	ok	Alarm Trip	scrapped
PM-2			Alarm Trip	
IC-1	$> 10^{-11}$	Meter Trip	ok	Fast Trip ok
IC-2	$> 10^{-11}$	Meter Trip	ok	
IC-3	$\sim 5 \times 10^{-11}$	Calibration	ok	
IC-4	$\sim 5 \times 10^{-11}$	Calibration	ok	
CRM				

Preliminary Check on

Room 113 Pressure Differential 5.09"
 Red Light On and Personnel Check ✓
 Scrams and Bldg. Alarm Reset ✓
 Source Inserted Acc. source
 Safety Withdrawn 28.10
 Controls Set
 Reflector Water $\sim 6''$ above Be
 Moderator Water 28.59"

Expt 186 A

Pulsing at critical
 inner outer

44.0

43.95"

Pos. Period

237 sec \rightarrow 4.80 ϕ

Inner	Outer	Safety	
43.36	43.36	28.1	level @ 6.0×10^{-10} nsec-2
43.90	43.95	20.58	slightly sub
43.90	43.95	20.68	level.

Shut down to move limit switch.

Exp # 186 B 9-14-61

Use Accelerator for source

Safety 21.04"

Ref1 H₂O 6" Above Be fuel H₂O 28.60

INNER - Outer Safety

43.74 - 43.74 21.04 level

11¹⁵ Shut Down Insert Safety AND outer control to 35.0"

EXP # 187 - React @ 32.00.

~~Inner 32~~

PN-140 INNER 32.00 OUTER 32.00 SAFETY 25.10

CRIT AT 43.36 TOTAL 643055

ACC 135 KV ^{0.96} MA 1MVA SF 60 100 MUS 170 CPS

TMC CH 10 MUS BRG ~~16~~ DELAY 2 DISC MEM 111

DET MIN BF3 AT 1750 DD2 01.1 X 200 PHS 450

Pos 1 Breakdown

230

9-14-61

Expt 188

~~Continuation of Expt 188~~ for pulsing
at critical

INNER	outer	Safety	
43.85	43.85	20.99	level

Insert safety to 14.0 for shutdown
withdraw to 20.99 pulses for 200 cycles
and repeat many times.

PN-141 INNER OUTER 43.85 SAFETY 20.99 CRIT

Acc 135kr ^{0.7MA} 400 ~~MS~~ MUS 20 CPS

TMC CH160 MUS BKG 4 DELAY 2 DISC 4 MEM 1-1

DEF MINBF3 AT 1750 DD2 1HX 200 PMS 450

329

Check Critical After Pulsing PN-141
 INNER - Outer Safety Refl H₂O fuel H₂O
 43.85 43.85 20.99 6" Above Bc 28.58
 Shut Down Insert Outer Control, Safety
 And Dump Fuel H₂O

level on IC-344

Instrument Check on 9-15-61 Source 10 mci Y

PM-1	<u>>50 μ</u>	Low Trip	<u>OK</u>	Alarm Trip	<u>OK</u>
PM-2	<u>-</u>		<u>-</u>	Alarm Trip	<u>-</u>
IC-1	<u>>10 $\times 10^{-12}$</u>	Meter Trip	<u>OK</u>	Fast Trip	<u>OK</u>
IC-2	<u>>10 $\times 10^{-12}$</u>	Meter Trip	<u>OK</u>		
IC-3	<u>$\sim 5 \times 10^{-11}$</u>	Calibration	<u>OK</u>		
IC-4	<u>$\sim 5 \times 10^{-11}$</u>	Calibration	<u>OK</u>		
CRM	<u>X</u>	Meter Trip	<u>X</u>		

Preliminary Check on 9-15-61

Room 115 Pressure Differential	<u>OK</u>
Red Light On and Personnel Check	<u>OK</u> <u>e.e.</u>
Scrams and Bldg. Alarm Reset	<u>✓</u> <u>C.C.</u>
Source Inserted	<u>-</u> <u>Acc</u>
Safety Withdrawn	<u>20.99</u>
Controls Set	<u>INNER 22.0" Outer 22.0"</u>
Reflector Water	<u>6" Above Be</u> <u>28.81</u>
Moderator Water	<u>28.81"</u>

EXP #189 X

PN-142 HFIR EXP 189 INNER-OUTER 22.00

SAFETY 20.99

ACC 135KV 1.03 MA 3.0 MUA SF 60 100 MUS

330 CPS ~~CRIT~~ CRIT AT 43.36

TMC CH 10 MUS BKG 16 DELAY 2 DISC 4 MEM 1/2

DET MIN BF3 AT 1750 DD 2 1.1 X 200 PHS 450

BETWEEN FUEL ANNULI AT MID PLANE

1 Breakdown

EXP 189 B

PN-143 HFIR EXP 189 INNER-OUTER 12.00

SAFETY 28.0

Acc 135 KV 1.0 MA 3.0 MUA 100 MUS 330 CPS

CRIT AT 73.36

TMC CH 100 MUS BKG 16 DELAY 2 DISC 2 MEM/2

DET MIN BF7 AT 1750 DD2 1.1x200 PHS 450

No Breakdowns

EXP 190

PN-144 HFIR EXP 190 INNER 0.05 OUTER 22.0 SAFETY 28.0

Same as 189

1 Breakdown

EXP 191 A

PN-145 HFIR EXP 190 INNER OUTER 7.00

1 Breakdown

EXP 191 B

PN-146 HFIR EXP 191 INNER OUTER 17.00

3 Breakdown

EXP 192

PN-147 HFIR EXP 192 INN=OUT 27.00

No Breakdown

EXP 193

PN-148 HFIR EXP 193 INN=OUT = 27.0

Bay 8 CH 40 μ s (110 CPS 100 μ s)

No Breakdown

Room 113 Pressure Differential 0.09"
 Red Light Control Panel Check
 Screws and Slags
 Source Instrument accel. S.
 Safety Withstand 28.01
 Controls Set INNER 43.90 Outer 00.00"
 Reflector Water 28.6 6" Above Be
 Moderator Water 28.68 6" Above Be

Instrument Check on 9-18-61 Source Accelerator

PM-1 Low Trip OK Alarm Trip OK
 EM-2 Alarm Trip _____
 IC-1 > 10⁻¹¹ Meter Trip OK Fast Trip scrapped
 IC-2 > 10⁻¹¹ Meter Trip _____
 IC-3 ~ 4 x 10⁻¹¹ Calibration OK
 IC-4 ~ 6 x 10⁻¹¹ Calibration OK
 CRM Meter Trip _____

EXP 194

PN-149 HFIR EXP 194 INNER 43.90 OUTER 0.00

ACC 135KV 1.1 MA 4 MUA 100 MUS 330 CPS
 TMC CH 10 MUS BKG 8 DELAY 2 DISC 4 MEN 1/2
 DET MIN BF3 DD2 1.1 x 200 PH3 = 450
 5 ACC Breakdowns Ch ²⁰ 19 lat during run.
 Ch 38 - 62

EXP 195

PN-150 HFIR EXP 195 INNER 43.90 OUTER 12.00

ACC 135KV 1.05 MA ~4 MUA 100 MUS 330 CPS
 TMC CH 10 MUS BKG 16 DELAY 2 DISC 4 MEN 1/2
 DET MIN BF3 @ 1750

EXP #196 (Repeat 194)

PN-151 EXP 196 IN 43.90 OUT 0.0

ACC 135KV 1.1MA 100MUS 330CPS

TMC 10MUS BKG 16 DELAY 2 DISCY MEM 1/2

EXP #197

PN152 EXP 197 IN=43.90 OUT=22.00

ACC 135KV 1.05MA 2MUA 100MUS 220 CPS

TMC 20MUS CH BKG 16 MEM 1/2

EXP 198

PN153 HFIRCE2 EXP198 IN 43.90 OUT 32.00

ACC 135KV 0.9MA 1MUA 200MUS 130CPS

TMC 40MUS BKG X16 MEM 1/2

EXP #199

PN154 HFIRCE2 EXP199 IN 43.90 OUT 32.00

ACC 135KV 0.8MA 0.5MUA 400MUS 35CPS

TMC 160MUS BKG 16 MEM 1/2

EXP #200

PN 155 HFIRCE2 EXP 200 IN 22.00 OUT 43.95

ACC 135KV 1.0MA 2.5MUA 100MUS 330CPS

TMC 10MUS BKG 16 MEM 1/2

EXP 201

PN-156 HFIRCEZ EXP 201 IN 00.05 OUT 43.95
 ACC 135KV 1.0MA 3.5MUA 100MUS 330CPS
 TMC 10MUS BKG 16 DELAY 2 DISC 4 MEM 1/2
 Total 868526

1/2

EXP 202

PN-157 Total 120000 cycles
 ACC 135KV 1.0MA 9.5MUS 300MUS 330CPS
 (Memory overflowed in many channels)
 Same as ^{PN} 156 IN 0.05 OUT 43.95

00

05

0

15

Instrument Check on 9-19-61 Source ✓

PM-1 _____ Low Trip screamed Alarm Trip ok
 PM-2 _____ Alarm Trip _____
 IC-1 710⁻⁴ Meter Trip ✓ Fast Trip ✓
 IC-2 510⁻¹¹ Meter Trip ✓
 IC-3 5x10⁻¹¹ Calibration ok
 IC-4 6x10⁻¹¹ Calibration ok
 CRM _____ Meter Trip _____
 / Preliminary Check on _____

Room 113 Pressure Differential 0.09"
 Red Light On and Personnel Check ✓
 Scrums and Bldg, Alarm Reset ✓
 Source Inserted Occid. S.
 Safety Withdrawn 20.99
 Controls Set INNER 43.90 Outer 00.00"
 Reflector Water 6" Above Be
 Moderator Water 28.32"

Exp # 202 9-19-61

9¹⁰ AM Pulsing at critical
 INNER Outer
 43.90 43.95" Sub Crit

9²³ Increase Power level with Accelerator (2.45×10^{-3})
 And measure Neg Per. T=217, 7.34
 Shut Down to Add H₂O to fuel H₂O system

9³² Added 1/2 l of water to fuel water storage tanks and mixed.

Use Accelerator for Source Safety 20.99"
Ref H₂O 6" Above Be fuel H₂O 28.52"

INNER - Outer

10⁰⁸

43.90 - 28.49

10³⁵

43.90 - 43.95

Approx Crit

43.75 - 43.75

level

10⁴⁰

Insert Safety to make Sub Crit

Raise Safety to make Crit

43.75 43.75

PN-158 HFIREXP 203 INNER OUTER 43.75

SAFETY 20.99 AT CRITICAL. SAFETY TO 14.0

AFTER 200 CYCLES TOTAL

ACC 135 KV 0.85 MA 600 MUS 10 CPS

TMC CH 320 MUS BRG 4 DELAY 2 DISC 4 MEM 1/1

DET MIN BF3 AT 1750 DD2 1.1 X 200

PHS 750

1³³

Stop Pulsing AND Check Critical Cond

INNER Outer Safety

43.75 43.75 20.99" Slightly Sub Crit

-1150 sec -1.2 ϕ

Shut Down Insert Safety, Outer Control

Dump fuel H₂O

238

Exp # 204

9-19-61

Safety 28.11"

Ref H₂O 6" Above Be fuel H₂O 28.52

INNER - Outer

00.05 43.95

PN-159 HPIC EE2 EXP 204 INNER 00.05

OUTER 43.95

ACC 135KV 1.1 MA 100 MUS 330 CPS

TMC 10 MUS BKG 16 DELAY 2 DISS 4 MEM 1/2

DET 4 1/8 in above MID Plane

EXP 205

PN-160

ACC 135KV 1.1 MA 14 MUA

DET 4 1/8 in. ABOVE MID PLANE

N.B. Fourth digit on MC-205 printed 4 for 8
on channel 15 ^{8.5000 37} and a 4 for 9 on ch 28.

Monroe adjusted core on 4 ~~4~~
in 4th column.

Instrument Check on 9-20-61 Source

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	$> 10^{-11}$	Meter Trip	OK	Fast Trip	scrapped
IC-2	$> 10^{-11}$	Meter Trip	✓		
IC-3	2.4×10^{-11}	Calibration	OK		
IC-4	2.4×10^{-11}	Calibration	OK		
CRM		Meter Trip			

Preliminary Check on 9-20-61

Room 113 Pressure Differential $0.1'' \text{ H}_2\text{O}$

Red Light On and Personnel Check

Scrams and Bldg, Alarm Reset

Source Inserted *Accel. S.*

Safety Withdrawn *Safety removed for min. BF₃ counter*

Controls Set *INNER 0.04" Outer 43.95" [insertion]*

Reflector Water *6" Above Bc*

Moderator Water *2.6" Above Bc 28.37"*

EXP # 206

Target out; Safety out
BF₃ counter in center of island

PN-161 HFIRCE #2 EXP 206 INNER 0.05 OUT 43.95

SAFETY ~~STO~~ ^{Removed} TARGET REMOVED

ACC 135 KV 0.9 MA 100 MUS 330 CPS

TMC 10 MUS BKG 32 DELAY 2 DISC 4 MEM 1/2

DET MIN BF3 @ 1750 AT CENTER OF
TARGET REGION

No breakdowns

240

Exp # 207

9-20-61

INNER - Outer
43.90 43.95

PN-162 EXP 207 INNER 43.90 OUTER 43.95 SAFETY ~~ON~~

Remove Target Remove.

ACC 135KV 0.75 MA 400 MUS 17 CPS

TMC 160 MUS BKG 8 DELAY 2 DISC 4 MEM 1/1

DET MIN BF3 CENTER OF TARGET REGION

No Breakdowns

Shut down

PM-1	Low Trip	<u>ok</u>	Alarm Trip	<u>ok.</u>
PM-2			Alarm Trip	
IC-1	<u>> 10⁻¹¹</u>	Meter Trip	<u>ok</u>	Fast Trip
IC-2	<u>> 10⁻¹¹</u>	Meter Trip	<u>ok</u>	
IC-3	<u>~ 4x10⁻¹¹</u>	Calibration	<u>ok</u>	
IC-4	<u>~ 6x10⁻¹¹</u>	Calibration	<u>ok</u>	
CRM		Meter Trip		

Preliminary Check on 9-21-61

Room 115 Pressure Differential 0.1" H₂ORed Light On and Personnel Check ✓Screams and Bldg. Alarm Reset ✓Source Inserted AcceleratorSafety Withdrawn Removed from systemControls Set INNER 00.04 Outer 00.00"Reflector Water 6" Above BeModerator Water 28.25"

Installed 2nd min. BF₃ counter in central target region. Each ~ 3/4" on opposite sides of center of reactor

11 ²²/_{AM}

Exp # 208 9-21-61

PN-163 HFIRCE #2 EXP 208 INNER 0.05 OUTER 0.00

SAFETY REMOVED TARGET REMOVED TOTAL 750000

Acc 135 KV 0.9 MA 1.5 MUA SF 55 100 MUS 330 CPS

TMC 10 MUS BKG 16 DELAY 2 DISC 4 MEM 1/2

DET 2 MIN BF₃ IN TARGET REGION PHS OUTPUT

PARALLELED ON DD-2 AMPLIFIERS.

DD2 1.1X200 PHS 450 Pulse HT ~ 40-100V

ON BOTH VOLTAGE 1750

PN-164 Same as PN-163 EXCEPT BURST WIDTH = 300MUS
Acc. has + spikes on neutron yield?

EXP 209

PN-165 IN = OUT = 12.0

ACC = 135KV 0.9 MA 1.5 MUA 190 MUS 330 CPS

TMC = 20 MUS BK&16 DELAY 2 DISC 4 MEM 1/2

EXP 210

PN-166 IN = OUT = 22.0

ACC = 135KV 0.88 MA 0.8 MUA 200 MUS 220 CPS

TMC = 20 MUS BK&16 DELAY 2 DISC 4 MEM 1/2

EXP 211

PN-167 IN = OUT = 32.0

ACC = 135KV 0.85 MA 0.5 MUA 200 MUS 220 CPS

TMC = 20 MUS BK&16 DELAY 2 DISC 4 MEM 1/2

(Punched & printed ~~EXP 212~~ ^{wire} - punched tapes agree)PN-168 Same as above but ¹²⁸ ~~256~~ channels @ 110 CPS
(long wait at end)

EXP 212

PN-169 IN = OUT = 37.0

ACC 135KV 0.80 MA 300 μ S 70 CPS

TMC 40 MUS BK&16 DELAY 2 DISC 4 MEM 1/1

4³⁰ PM: Shut down by draining H₂O
and IN = OUT = 0

Instrument Check on 9-22-61 Source 8

PM-1 Low Trip ok Alarm Trip ok
 PM-2 Alarm Trip
 IC-1 7 10⁻¹¹ Meter Trip ok Fast Trip ok
 IC-2 7 10⁻¹¹ Meter Trip ok
 IC-3 ~ 5 x 10⁻¹¹ Calibration ok
 IC-4 ~ 6 x 10⁻¹¹ Calibration ok
 CRM Meter Trip

Preliminary Check on 9-22-61

Room 113 Pressure Differential 0.1"
 Red Light On and Personnel Check ✓
 Scrams and Bldg, Alarm Reset ✓
 Source Inserted Accelerator
 Safety Withdrawn Safety Removed From System
 Controls Set Inner 32.0" Outer 3.45"
 Reflector Water 6" Above Be
 Moderator Water 28.50"

Exp # 213 9-22-61

With accelerator on not pulsed and
 2 μ a, on target 1

Target	IC-1	IC-2	IC-3	IC-4	IN	OUT
135KV 2 μ a	1.6 x 10 ⁻¹¹	3.6 x 10 ⁻¹⁰	1.4 x 10 ⁻¹¹	1.4 x 10 ⁻¹⁰	32.0	3.45
@ 20 μ a	1.5 x 10 ⁻¹⁰	3.3 x 10 ⁻⁹	1.2 x 10 ⁻¹⁰	1.25 x 10 ⁻⁹	32.0	3.45
@ 30-35MA 60 μ a	.35 x 10 ⁻⁹	0.80 x 10 ⁻⁸	3.2 x 10 ⁻¹⁰	3.2 x 10 ⁻⁹	"	"

1/1

PN-170 EXP 214 IN = 0.0 OUT = 32.0 SAFETY AND TARGET REMOVED
 ACC 135KV 0.83MA 1 MUA 2×10^{-5} MMHG 300 MUS @70CPS
 TMC 40 MUS BKG 16 DELAY 2 DISC 4 MEM 1/1

EXP 215

PN-171 EXP 215 IN = 0.05 OUT 43.95 SAF & TAR Removed
 ACC 135KV 0.93MA ~1 MUA 2×10^{-5} MMHG 150 MUS 110 CPS
 TMC 20 MUS BKG 16 DELAY 2 DISC 4 MEM 1/1

EXP 216

PN-172 EXP 216 IN = 43.96 OUT = 0.00 SAF & Target Removed
 ACC 135KV 0.93 N/MUA 1.8×10^{-5} MMHG 150 MUS 110 CPS
 TMC 20 MUS BKG 16 DELAY 2 DISC 4 MEM 1/1

PN-173 1500 MUS Burst 110 CPS 20 MUS ch 25G
 Target = 11 MUA

PN-174 Same as above but run 3X longer
 and includes above data total data 4 X PN-173

EXP 217

PN-175 IN = 43.90 OUT = 22.0 Saf. and Targ Rem.
 Acc 135KV 150 MUS 100 CPS
 TMC 20 MUS BKG 64

PM-1 Low Trip ok Alarm Trip ok

PM-2 Alarm Trip _____

IC-1 710-11 Meter Trip ok Fast Trip ok

IC-2 12-11 ok

EXP # 218 and 219

Counting Data


M-226

7.50×10^6

M-227

7.96×10^6

1.55×10^7



Counting Data

IC-1	IC-2	IC-3	IC-4	Inner	Outer	Reflector	Moderator	Time	Scaler	Counts	M
4.3×10^{-11}	4.0×10^{-11}	4.6×10^{-11}	1.4×10^{-10}	43.90	0.00	17' 0	0	5' ^{5.00}	$445^{x256} + 115$	114 035	
3.7×10^{-11}	3.6×10^{-11}	4.2×10^{-11}	1.2×10^{-10}	0.04	0.00	0	0	5'	402 + 4	102 916	
2.1	1.5	2.5	4.2×10^{-11}	0.04	0.00	12'	28.7	5'	146 + 6	37 382	
2.7	1.9	3.6	5.6	12.0	12.0	"	"	5'	166 + 217	42 713	1.14
5.0	3.3	6.0	1.0×10^{-10}	22.0	22.0	"	"	5'	261 + 241	67 057	1.79
4.1	2.75	5.5	0.85	37.0	37.0	"	"	5'	213 + 16	54 544	1.46
5.4	3.6	6.0	1.2	37.0	37.0	"	"	5'	283 + 218	72 666	1.94
7.1	4.6	8.5	1.4	32.0	32.0	"	"	5'	328 + 53	84 021	2.25
9.3	6.1	1.1×10^{-10}	1.8	34.0	34.0	"	"	5'	402 + 27	102 939	2.75
1.5×10^{-10}	9.6	1.7	3.0	36.0	36.0	"	"	5'	586 + 115	150 131	4.02
2.8	1.8×10^{-10}	3.1	6.5×10^{-11}	38.0	38.0	"	"	5'	1022 + 205	261 837	7.00
6.5	4.2	7.5	1.3×10^{-9}	40.0	40.0	"	"	5' 8.00	658 + 123	168 571	21.06

x4.67

Sources in Radial Beam Hole.						TIME	Pos.	Scaler	Counts	M
0.2×10^{-11}	$.6 \times 10^{-10}$	2.3×10^{-12}	1.7×10^{-11}	43.90	00.00"	5'	5.00	17 + 206	4 558	
.1	.55	1.0	1.3	0.04	00.00"	5'		10 + 197	2 757	0003627
0.2	.60	2.0	1.8	12.0	12.0	5'		14 + 113	3697	1.34
0.35	.6	4.0	2.2	17.0	17.0	5'		24 + 18	6162	2.24
.4	.6	6.0	2.5	22.0	22.0	5'		33 + 5	5453	3.07
.55	.65	6.	2.6	27.0	27.0	5'		39 + 210	10194	3.70
.93	.68	1.1×10^{-11}	3.6	32.0	32.0	5'		57 + 156	14 748	5.35
1.5	.75	1.6	4.8	34.0	34.0	5'		82 + 210	21 202	7.69
2.85	.85	3.4	8.3	36.0	36.0	5'		140 + 42	35 882	13.01
5.6	1.05	6.5	1.4×10^{-10}	38.0	38.0	5'		259 + 179	66 483	24.11
1.15×10^{-10}	1.45×10^{-10}	1.3×10^{-10}	2.6	40.0	40.0	5'		512 + 154	131 224	47.60
1.65	1.75	1.9	3.6	41.0	41.0	5'		728 + 60	186 428	67.62
Source removed from Rm 113.						5'		+14		

6" above Sc

PM-1	Low Trip	<u>OK</u>	Alarm Trip	<u>OK</u>
PM-2			Alarm Trip	
IC-1	<u>7/10⁻¹¹</u>	Meter Trip	<u>OK</u>	Fast Trip <u>OK</u>
IC-2	<u>7/10⁻¹¹</u>	Meter Trip	<u>OK</u>	
IC-3	<u>5 x 10⁻¹¹</u>	Calibration	<u>OK</u>	
IC-4	<u>2.6 x 10⁻¹¹</u>	Calibration	<u>OK</u>	
CRM		Meter Trip		

Preliminary Check on _____

Room 113 Pressure Differential OK

Red Light On and Personnel Check OK

Scrams and Bldg. Alarm Reset OK

Source Inserted M-226 - M-227 center of Target Region

Safety Withdrawn Not Installed

Controls Set IN 0.05 OUT 0.50

Reflector Water To 6" above R

Moderator Water To 28.

EXP # 218

Purpose - Counting rate (source multiplication)
vs. Control Plate Position.

M-226 and M-227 at midplane of target region
each approx $1/2$ from axis of full element
(a target region)

EXP # 219

Source moved to Radial Beam Hole.

BF-3 Counters located in Be

Use Accelerator for Source Safety 28.07
 Refl H₂O 6" Above Be fuel H₂O 28.34

Inner - Outer

43.90 00.00"

Purpose: Source Multiplication using 14 MeV
 neutron source.

EXP # 221

PN-176 Counter in Beryllium. IN 0.05 OUT 0.00

ACC 135KV 1.1 MA 300 MUS ^{S7} CPS

TMC 40 MUS BKG 64 DELAY 2 DISC

DET BF3 TWO EA 90' From Source

in 2nd row of 1/2 holes in Be.

On the morning of 9-25-61, the press without lig Ni
 was 1×10^{-5} and would pump down to 2×10^{-6}
 only.

9-26-61 9×10^{-6} w. @. lig Ni

1.5×10^{-6} w. lig Ni

With Target Installed

6 μ a on accelerator @ 135 kv.

2' Count time

Moderator H₂O 28.2

Reflector H₂O 6" above Be

IC-1	IC-2	IC-3	IC-4	Inner	Outer	Scaler		
1.7×10^{11}	6.4×10^{10}	1.7×10^{11}	2.2×10^{10}	0.04	0.00	42 +10	$10\ 762$	1.0
2.2	6.3	2.4	2.4	12.0	12.0	48 +112	12400	1.15
5.6	7.0	6.2	3.5	22.0	22.0	100 +87	25687	2.39
8.8	6.4	1.0×10^{10}	1.0	32.0	32.0	144 +186	37050	3.44
3.6×10^{10}	8.0×10^{10}	4.5	9.5×10^9	37.0	37.0	470 +87	$120\ 407$	11.19
1.5×10^9	1.5×10^9	1.7×10^9	3.2×10^9	40.0	40.0	643 +165	769490	71.5
						x4.67		

Instrument Check on 9-26-61 Source 10mc Ra Be
source

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2	X		Alarm Trip		
IC-1	$> 10 \times 10^{-12}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 10 \times 10^{-12}$	Meter Trip	OK		
IC-3	$\sim 6 \times 10^{-11}$	Calibration	OK		
IC-4	$\sim 6 \times 10^{-11}$	Calibration	OK		
CRM		Meter Trip			


Preliminary Check on 9-26-61

Room 113 Pressure Differential OK
 Red Light On and Personnel Check ✓
 Scrams and Bldg, Alarm Reset PM-1 only
 Source Inserted accel S.
 Safety Withdrawn 28.00
 Controls Set 121 D. 05 Out 000
 Reflector Water $\sim 6''$ above Be
 Moderator Water 28.7

Expt. 222

Repeat of Expt 221 with both controls
 in S counter in Be

In tuning up the accelerator the pulsing
 frequency was set close to 60 cps (~ 59.4)
 and the neutron yield varied with the beat
 frequency of ~ 1 cps. The response of IC-2 is ^{on next page}
 This tuning was not a deliberate attempt to
 achieve large modulation but to peak the
 accelerator and seems to be very sensitive
 to the various combinations of the voltages.
 See



PN-177 HFIR EXP #222 PULSING BERYLLIUM
 IN 0.05 OUT 0.00 TARGET INSERTED SAFETY 28.0
 ACC 133KV 1.05MA 1.2 MVA 200 MUS 58.6 CPS
 (Beat Frequency ~ 0.1 CPS) Press ~ 1.6 x 10⁻⁵ mm Hg
 TMC 40 MUS BKG 64 DELAY 2 DISC 0.5
 DET 2 ea MIN BF3 DET IN BE @ AT 1750
 2 ea DD2 1.1 x 200 PHS = 450
 EXP #223

PN-178 HFIR #2 EXP 223 PULSING BERYLLIUM
 IN=OUT = 22.00 TARGET INSERTED SAFETY 28.0
 ACC 133KV 1.05MA 1.2 MVA 200 MUS 58.6 CPS
 (60 Beat Freq =) 60 cycle modulation
 has decreased to non detectable amplitudes.
 Pressure 1.6 x 10⁻⁵
 TMC 40 MUS BKG 64 Delay x2 DISC 0.5
 DET 2 ea MIN BF3 IN BERYLLIUM AT 1750 VOLTS
 2 ea DD2 1.1 x 200 PHS 450 outputs parallel.

BF-3 Counters Inserted Between Inner and Outer Fuel Annulus at mid Plane

Accelerator for Source Safety 28.08"

Ref H₂O 6" Above Be fuel H₂O 28.56"

Inner - Outer

43.83" 0.0"

1:36 PM 43.90 43.95

Sub Crit

-543 Neg period -1.65 x 10⁻⁴ or -2.6 φ

EXP # 225

PN-179 ASSEMBLY -2.6 φ SUBCRIT No Breakdown

INNER = OUTER = 32.0 SAF = 28.0

ACC 135KV 0.85MA 0.4MUA 1.7 x 10⁻⁵ mmHg

100 MUS 100 CPS

TMC 20 MUS BKG 64 DELAY 2 DISC 0.5

DET 2 ea BF3 COUNTERS Pulse Amplitudes

matched at 20 to 50 volts - ch 1 0.9 x 100 PHS 200

Counters between Fuel Annuli: ch 2 1.1 x 100 PHS 200

EXP # 226 A

PN-180 ASS. -2.6 φ Subcrit

IN = OUT = 22.0 SAFETY 28.0

ACC 135KV 1.05MA 2.0MUA 1.7 x 10⁻⁵ mmHg

100 MUS 150 CPS

TMC 10 MUS BKG 64 DELAY 2 DISC 0.5

DET 2 ea BF3

No Breakdown

8:10 AM Added 500 ml H₂O (Deminevalized) to fuel H₂O system and mixed

Instrument Check on 9-27-61 Source

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	> 10 ⁻¹¹	Meter Trip	OK	Last Trip scrambled s.
IC-2	> 10 ⁻¹¹	Meter Trip	OK	
IC-3	~ 5 x 10 ⁻¹¹	Calibration	OK	
IC-4	~ 4 x 10 ⁻¹¹	Calibration	OK	
CRM		Meter Trip		

Room 113 Pressure 0.1"

Red Light Control Panel

Scrams and 210, 210, 210

Source Inserted Accelerator

Safety Withdrawn 28.01

Controls Set Inner 43.90 Outer 0.0"

Reflector Water 6" Above Be

Moderator Water 28.32"

Exp # 227 9-27-61

Purpose: Check Crit Pos on Controls

Inner Outer Accelerator Off

	43.90	43.95		Super Crit
11:15 AM	43.35	43.35		level
	43.90	43.95	T=239 ± 4.77 φ	Pos Per
	37.0	37.0	(see next page)	for Pulsing

Expt 228 9-27-61

270 270

PN-181 HFIREXP 227 INNER = OUTER = 37.0
 WITH TARGET ~~DEF~~ ~~BT~~ ~~OR~~ +4.84 excess CRITA 43.35
 ACC 135KV 1.0MA 200MUS 70CPS
 TMC 40MUS BKQ 16 DELAY 2 DISC 0.5 MEM 1/1
 DET 2EA MIN BF3 IN FUEL ANNULUS
 PHS = 200 NO Breakdown

PN-182 HFIREXP 228 IN = OUT = 27.0
 ACC 135KV 1.0MA 200MUS 160CPS (256 ch)
 TMC 10MUS BKQ ¹⁶32 Delay 2 DISC 0.5 MEM 1/1
~~DEF~~ NO Breakdown

PN-183 HFIREXP 229 IN = OUT = 17.0
 ACC 135KV 1.0MA 200MUS 160CPS (256 ch)
 TMC 10MUS Bkg 32 Delay 2 DISC 0.5 MEM 1/1

PN-184 HFIR Exp # 220 IN = OUT 12.0"
 ACC 135KV 1.0MA 300 μ S 325CPS
 TMC 10MUS Bkg 32 Delay 2 DISC 0.5 MEM 1/2

PM-1 Low Trip OK High Trip OK
 PM-2 Low Trip OK High Trip OK
 IC-1 7 10⁻¹¹ OK
 IC-2 7 10⁻¹¹ OK
 IC-3 ~ 5 x 10⁻¹¹ OK
 IC-4 ~ 5 x 10⁻¹¹ OK
 CRM —
 Room LLS 0.1"
 Red Light ✓
 Screens ✓
 Source acc 5.
 Safety ✓ 28.04"
 Controls 1.2" & out at 7.00"
 Reflector Water ~ 4" above Be
 Moderator Water 18.02"

EXPT ~~223~~ 231 PN-185

PN-185 HFIREXP 231 IN = OUT = 7.0
 ACC 135KV 1.0MA 5.5MUA 200MUS 320CPS
 DUTY CYCLE 200/3125 = 0.064
 Total Beam 5.5/0.064 = 86 MUA
 TMC 10MUS BKQ 32 DELAY 2 DISC 0.5 MEM 1/2

PN-186 HFIR #2 EXP 232 IN = 0.05 OUT = 0.0
 Same as 185

PN-187 Use Time of flight logic 211
 with 8 μ S channels

PN-188 211 with 16 μ s channels

EXP #233

PN-189 212 with 10 μ s channels

IN = 22.00 OUT = 0.00

ACC 135KV 1.0MA 5.0MUA 1.9×10^{-5} mm Hg

TMC 10 MUS BKG 32 } 200 MUS 320 CPS

MEM 1/2

#234

PN-190 IN 43.9 OUT = 0.00

ACC 135KV 1.0MA 5MUA 1.9×10^{-5} mm Hg

200 MUS 320 CPS

TMC 10 MUS BKG 32 MEM 1/2

#235

PN-191 IN = 43.9 OUT = 22.0

ACC 135KV 0.9MA 1MUA 1.7×10^{-5} mm Hg

200 MUS 100 CPS

TMC 40 MUS BKG 32 MEM 1/2

#236

PN-192 IN = 43.9 OUT = 32.0

ACC 135 0.95MA

1.7×10^{-5} mm Hg

200 MUS 65 CPS

(56 ch)

TMC 40 MUS BKG 32 MEM 1/1

#237

PN-193 In = 43.9 Out 37.0

Acc 135KV 0.9MA 1.6×10^{-5}

400 MUS 35 CPS

TMC 80 MUS BKG 16

#238

PN-194 In 37.0 Out 43.95

Acc 135KV 0.9MA 1.6×10^{-5}

400 MUS 35 CPS

TMC 80 MUS BKG 16

Instrument Check on 9-29-61 Source Y

PM-1	Low Trip	<u>ok</u>	Alarm Trip	<u>ok</u>	
PM-2			Alarm Trip		
IC-1	<u>> 10⁻¹¹</u>	Motor Trip	<u>ok</u>	Fast Trip	<u>ok screened</u>
IC-2	<u>> 10⁻¹¹</u>	Motor Trip	<u>ok</u>		
IC-3	<u>~ 5 x 10⁻¹¹</u>	Calibration	<u>ok</u>		
IC-4	<u>~ 5 x 10⁻¹¹</u>	Calibration	<u>ok</u>		
CRM		Motor Trip			

Preliminary Check on 9-29-61

Room 113 Pressure Differential	<u>0.1"</u>
Red Light On and Personnel Check	<u>✓</u>
Scrams and Bldg. Alarm Reset	<u>✓</u>
Source Inserted	<u>Accelerator</u>
Safety Withdrawn	<u>28.06</u>
Controls Set	<u>INNER 43.90 Outer 22.0"</u>
Reflector Water	<u>6" Above Be</u>
Moderator Water	<u>28.48"</u>

Exp # 239 9-29-61

Adjusted accelerator at near 60 cycle so that the peak to peak 1.1 to 1.5 on log N, then changed frequency to 100 CPS. Acc could be adjusted so that the peak to peak was ~ 10 to 1.

PN-195 EXP #239 Inner 43.9 Outer 22.0
 Acc 135KV 0.95MA 1 MUA 200 MUS 100 CPS
 TMC 20MUS BRG 32 1.5 x 10¹⁵ neutrons

EXP #240

PN-196 HFIR EXP #240 In 22.0 Out 43.95
 Same as 195

EXP #241

PN-197 HFIR EXP #241 In = 0.05 Out = 43.95
 ACC 135KV 0.97MA 3.5 MUA 150 MUS
 320 CPS TMC 10 MUS BRG 32 MEM 1/2

EXP #242

PN-198 HFIR EXP #242 In = 0.05 Out = 22.0
 TMC ACC Same as above

Exp 243 9-29-61

125

Check Crit Position on Control Rods
 Safety 28.06
 Refl H₂O 6" Above Be fuel H₂O 27.83"
 INNER - Outer
 43.90" 43.95" Slightly Super crit

135

Shut Down Insert Outer Control, Safety
 And Dump fuel H₂O.

9-29-61
 "Note"

Samples # 3, AND 3A taken from fuel H₂O
 system Approx 100g ea - H₃BO₃ conc 1.2g/l
 sample # 3 sent to X-10 for Analysis
 Born Analysis 1.23 mg/l ml Sp. G. = 1.0040 @ 23.0°C

Oct 9, 1961

Results from Mass Spect Lab on isotopic analysis of the new batch of Boric acid

B-10 19.80 atom percent
B-11 80.20 " "

Telephone call revealed no comparison to standard boron. (If these results are compared to some in 1958, Std Boron was 19.66 and sample was 19.60)

They will re run analysis with Argon Std.

A chunk of notebook revealed that no entry was made to denote when new batch of boric acid was used.

By comparison to a full bottle of boric acid, 187 g of boric acid have been removed (Bottles may weigh differently also) It is therefore concluded that the last 180 g added (in 3 additions) were from the new batch labeled S.T. Baker lot No 22105. (except previous was lot K-252, ^{possible} (Manufacture B&A Chem. Co. Inc. Allied Chem and Dye Corp.)

Dale Magnusson

"Note"

10-9-61

Source M-228 Installed in source Drive ON Assembly

Instrument Check on 10-10-61 Source 10 mc/8

PM-1 Contact	OK	OK
PM-2 ~ Contact		OK
IC-1 >10 x 10 ⁻¹²	OK	OK
IC-2 >10 x 10 ⁻¹²	OK	
IC-3	Not so good	Very Instable
IC-4	"	"
ORC		

Preliminary Check on 10-10-61

Room 113 Pressure 0.05"
Red Light On and Normal Check ✓ c.c.
Screams and Bldg. ✓
Source Inserted M-228
Safety Withdrawn 28.01"
Controls INner 22.0" Outer 22.0"
Reflector Level Approx 5 7/8" Above Be
Moderator Water 28.5"

The 3/4 partial outer control plate has been installed and the setpoints set at 22.00 when the inner and outer controls measure 39 1/4 and 26 in. above the Be seal page 5. (These were 39 5/16 and 26 1/16, when the millwrights finished their work) Limit switch on bottom changed so that outer does not rest on bottom. No fission or BF₃ counters are in core.

EXP # 244 10-10-61
Sub crit

9²⁸ AM Source out IN
INNER Outer
44.20 44.01 -289 sec → 5.24
Source out Sub Crit Neg Per
Shut Down Insert Source Outer Control, Safety

Accelerator developed a leak in the target section when moved back to Rm 213. Min press without trap cell $\sim 1.5 \times 10^{-5}$, min press with trap cold 6×10^{-6}
min press w.o. target section $\sim 10^{-7}$ mm Hg. Leak found in bellows flange $\rightarrow 3 \times 10^{-7}$ mm Hg entire system down

9⁵⁵ AM Added 500 ml H₂O to fuel H₂O system and mixed with pump for 10 min.

EXP # 245 10-10-61

12⁵⁷ Purpose: Check critical pos of controls
Source IN Safety 28.05"
Ref1 H₂O 5⁷/₈" Above Be - fuel H₂O 29.19

	Inner	Outer	
	44.20	29.97	
1 ¹²	44.20	44.01	source out
1 ²⁶	43.02	43.02	level

Note Shut Down - trip with IC-2, lower outer control.

Oct-11-1961

Press in Acc 1.0×10^{-5} no liq N₂
" " " 4.0×10^{-7} w. liq N₂

Diff. Pump probably needs cleaning and oil replaced.

Instrument Check on 10-11-61 Source 10 mc/Pa Be Y

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2				OK
IC-1	Meter	OK		OK
IC-2	Meter	OK	Dropped safety.	
IC-3	Calib.			
IC-4	Calib.			
CRM				

Instrument Check on 10-11-61

Room LMS Panel	OK
Red Light Control	✓
Screws and Wdg	✓
Source Enclosed Use Accelerator	
Safety Watchman	28.09
Controls for	INNER 43.91" Outer 00.07"
Reflector Water	Approx 6" Above Be
Moderator Water	28.46"

"Note" 2 BF-3 counters mounted between fuel annuli, output checked 20-50 volts in pulse PHS set at 200
10-11-61 Removed Source M-228 from Assembly

Exp # 246 10-11-61

Purpose: Check Crit Pos on Controls
Source - Accelerator Safety 28.69
Ref H₂O 6" Above Be fuel H₂O 28.36

10⁵⁴ AM
11⁰⁶

INNER Outer
43.91 44.01 (Accel off) Slightly Super Crit
44.20 32.0" for Pulsing Sub Crit
Shut Down to check Accelerator

Exp # 247 10-11-61

12⁴¹

Accelerator for Source Safety 28.01"
Ref H₂O Approx 6" Above Be fuel H₂O 28.34
INNER #4. Outer
44.20" 32.0"
Shut Down - (Dump fuel H₂O) to change BF-3 CR

Exp # 248 10-11-61

Accelerator for Source Safety 28.01"
Ref H₂O Approx 6" Above Be fuel H₂O 28.30
INNER - Outer
44.20" 32.0"

PH ~ 10-30 volts on surge
PAS set at 100

PN-199 HFIR EXP 248 IN: 44.20 OUTER 32.0

3-4 OUTER CONTROL

Acc 135KV 0.75 MA 1.8 x 10⁻⁵ mm Hg 0.5 MDA

S.F. 65, ~~700~~ 400MUS AT 70 CPS

TMC 40 MUS BKG 16 Delay 2 DISC 4 MEM 1/1

DET West BF3 ch #1 1750 0.9 x 100 PHS=100

Only → East BF3 ch #2 2000 0.9 x 100 PHS=100

EXP # 249

PN-200 HFIR EXP 249 Inner 44.20 Outer 22.0

3/4 Outer control 22.0 } 200 MUS AT 110 CPS

ACC 135KV 0.85 MA 1 MDA

TMC 20 MUS BKG 16 Delay 2 Disc 4 Mem 1/1

DET Same as @ 199

Monitor printing 9 for 3 in 2nd decade

(line)

10-12-61

8⁰⁰ AM Acc Press 1.0 x 10⁻⁵ mm Hg w.o. lig. H₂

8¹⁵ 1.2 x 10⁻⁶ " " w. lig. H₂

8²² 7 x 10⁻⁷ " " " "

Instrument Check on 10-12-61 Source 10 m.c. case

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	OK
IC-1	2.10 x 10 ⁻¹²	Water Trip	OK	Fast Trip OK
IC-2	7.10 x 10 ⁻¹²	Water Trip	OK	
IC-3	4 x 10 ⁻¹¹	Calibration		
IC-4	6.5 x 10 ⁻¹¹	Calibration		
CRM		Water Trip		
		Preliminary Check on	10-12-61	
	Room 113 Pressure Differential			
	Red Light On and Personnel Check			
	Scrams and Blg, Alarm Reset			
	Source Inserted	Accel		
	Safety Withdrawn	28.05"		
	Controls Set	INNER 44.20"	Outer 12.0"	
	Reflector Water	Approx 6" Above Be		
	Moderator Water	28.5"		

Accelerator for Source Safety 28.05"
Ref1 H₂O 6" Above Be fuel H₂O 28.54"

8³⁰ AM

INNER Outer
44.20 12.0"

PN-201 HFIR EXP 250 INNER 44.20 ~~OUTER~~ 3/4 OUTER
12.0 .

Acc 135KV 0.95 MA 3.5 MUA 200 MUS AT 170 CPS
1.7 x 10⁻⁵ mm Hg

TMC CH 10 MUS BKG 16 Delay 2 Disc 4 Mem 1/1
Det same as 200 and 199

EXP # 251 inner 44.20 outer (3/4) 17.00

PN-202 HFIR EXP 251 IN 44.20 3/4 Outer 17.00

Check 60 cycle ±10% counting rate ~10,000 CPS.

Acc 135 KV 0.93 MA 1.5 MUA 200 MUS AT 110 CPS

1.7 - 2.0 x 10⁻⁵ mm Hg

TMC CH 20 MUS BKG 16 Delay 2 Disc 4 Mem 1/1

Det same as 201, 200, 199.

Exp # 252

PN-203 HFIR CE No. 2 252 IN 44.20 3/4 Outer 27.00

Acc 135KV 0.93 MA 1.5 MUA 200 MUS AT 110 CPS

1.2 x 10⁻⁵ mm Hg (un changed)

TMC CR 20 MUS Bkg 16, Delay 2, Disc 4, Mem 1/1

Det same

EXP 253

PN-204 HFIR EXP 253 inner 44.20 3/4 Outer 37.00

Acc 135KV 0.83 MA 4.0 Spa 500 MUS AT 19 CPS

TMC CH 160 MUS BKG 16 Delay 2 Disc 4 Mem 1/1

EXP 254

PN-205 HFIR EXP 254 inner 44.20 3/4 Outer 40.00

Acc 135KV 0.80 MA 4.0 MUA 500 MUS AT 10 CPS

TMC CH 320 MUS BKG 8 Delay 2 Disc 4 Mem 1/1

EXP 255 inner 44.20 3/4 Outer 0.08

False alarm from PM-1
low trips — Restarted run

(2 months of high current press ~ 2 x 10⁻⁶ needed)

PN-206 HFIR EXP 255 In 44.20 3/4 OUT 0.08

Acc 135KV 1.0 MA 2.5 MUA 100 MUS AT 340 CPS

TMC CH 10 MUS BKG 16 Delay 2 DISC 4 MEM 1/2

Reduce counting rate or power
by a factor of 10 and use 7 min of flight
unit 256 Ch 8µs, everything else
the same.

PN-207 TF unit Gas Channels 100µs Burst 2500 CPS

N.B. Only Ch 2 Counter used for PN-199-207
ERR did not disconnect both counters



Instrument Check on 10-13-61 Source 10 Mc Pu Be

PM-1	<u>750 μa</u>	Low Trip <u>OK</u>	Alarm Trip <u>OK</u>
PM-2			Alarm Trip <u>OK</u>
IC-1	<u>>10 x 10⁻¹²</u>	Meter Trip <u>OK</u>	Fast Trip <u>OK</u> <small>Dropped safety</small>
IC-2	<u>>10 x 10⁻¹²</u>	Meter Trip <u>OK</u>	
IC-3	<u>Very unstable</u>	Calibration	
IC-4	" "	Calibration	
CRM		Meter Trip	

Preliminary Check on 10-13-61

Room 113 Pressure Differential ✓
 Red Light On and Personnel Check ✓
 Scrums and Bldg, Alarm Reset ✓
 Source Inserted Accelerator
 Safety Withdrawn 28.10
 Controls Set INNER 44.20" Outer 0.08"
 Reflector Water Approx 6" Above Be
 Moderator Water 28.80"

Checked pulses from both miniature fission counters, gains set on both DD2 amplifiers at 1.1 X 100 and high voltage adjusted to give "neutron" pulses from about 10 v to 30 volts PHS set at 100 on both amplifiers.

EXP # 256

PN-208 HFIR#2 EXP # 256 INNER 44.20 3/4 Outer 0.08

Same as PN-207 and PN-206

Acc 135KV 0.93 MA 1.5 MUA 1.7 - 2.0 mm Hg

100 MUS AT 170 CPS

TMC CH 10MUS BKG 16 Delay 2 Disc 4, MEM 1/1

EXP # 257

PN-209 HFIR#2 EXP 257 In 44.20 3/4 Out 12.00

Acc 135KV 0.9 MA 1 MUA 2.2 x 10⁻⁵ mm Hg

100 MUS at 170 CPS

TMC 10MUS BKG 16 Delay 2 Disc 4 Mem 1/1

Instrument Check on 10-16-61 Source 10 Mc Pu Be

PM-1		Low Trip <u>OK</u> <small>Trips Safety</small>	Alarm Trip <u>OK</u>
PM-2			Alarm Trip <u>OK</u>
IC-1		Meter Trip <u>OK</u>	Fast Trip <u>OK</u>
IC-2		Meter Trip <u>OK</u>	
IC-3		Calibration <u>OK ?</u>	
IC-4		Calibration <u>Out for Repair</u>	
CRM		Meter Trip	

Preliminary Check on 10-16-61

Room 113 Pressure Differential ✓
 Red Light On and Personnel Check ✓
 Scrums and Bldg, Alarm Reset ✓
 Source Inserted Accelerator
 Safety Withdrawn 28.03
 Controls Set INNER 8.46" Outer 0.08"
 Reflector Water Approx 6" Above Be
 Moderator Water 28.48"

10-16-61

On Friday Oct 13, the Boric acid solution was drained from the moderator system and stored in a Barrel. The system was flushed with tap water and rinsed down with deionized water and allowed to drain over the weekend. ~ 78 liters (78.08kg) of distilled water from 9201-2 was added, the distilled water purifying system in 9213 not in good condition for making pure water

Exp # 258

Purpose: To determine critical control position with pure H₂O and 3/4 Outer control, 2 BF₃ counters in fuel element.

945

Source - Accelerator

Inner Outer

950

17.40 0.08" Sub Crit

17.40 15.67 Slightly Super Crit

1015

17.40 15.85 150 s. → 7.1 φ Pos Per

17.40 15.615 Crit

Shut Down Insert Outer Control, AND Dump Fuel H₂O

Exp # 259 (Check Crit Pos.)

Inner Outer (acc. source, Mod H₂O to 28.7)

17.40 15.615 Sub Crit Ic-3 = 7.810"

17.40 15.85 195 s. → 5.7 φ Pos. Period.

17.40 15.65 Crit

↓
17.24 15.95 Crit

1115

Shut Down

10-16-61

These experiments #258 & 259 indicate a control plate change of ~1.6 in from full to 3/4 plate which corresponds to only 45% if we use the original control calibration. However, if we assume that the boric acid solution has coated the fuel element with boron, that has not been removed then this critical plate position is an indication that the amount of boron on the fuel element surfaces is a sizeable amount. Perhaps some nitric acid in the water will help remove this boron.

"Note"

10-16-61

Sample #4 (Approx 100ml) taken from fuel H₂O system AND sent to Mr Norris Bldg 9734 for Analysis. Boron Analysis 0.4^{+0.4} - .2 μg/ml

$$0.4 \times 10^{-6} \times 3.0 \times 10^4 = 0.012 \text{ g in fuel element.}$$

Instrument Check on 10-17-61 Source 10 mCrA B2

PM-1	710 x 10⁻¹²	Low Trip	OK	scrammed Safety Dump	Alarm Trip	OK
PM-2					Alarm Trip	OK
IC-1	710 x 10 ⁻¹²	Meter Trip	OK		Fast Trip	OK
IC-2	710 x 10 ⁻¹¹	Meter Trip	OK			
IC-3		Calibration				
IC-4		Calibration		Out for Repair		
CBM		Meter Trip	X			

Preliminary Check on 10-17-61

Room 113 Pressure Differential OK

Red Light On and Personnel Check ✓

Scrams and Bldg, Alarm Reset ✓

Source Inserted Accelerator

Safety Withdrawn Push

Controls Set INNER 17.24 Outer 00.08"

Reflector Water Approx 6" Above BC

Moderator Water 28.34

	Exp # 260	10-17-61	
INNER	Outer		
17.24	00.08"		Sub crit
17.40	15.85	18.00 5.94	Pos Per
17.40	15.60	10-2 6.8 x 10 ⁻¹⁰	level

EXP 261

PN-210 HFIR EXP 261 INNER 17.40 Outer 0.08

ACC 135KV 0.95 MA 1MUA 100MUS at 110 CPS

1.6 x 10⁻⁵ mm Hg

TMC Ch 20 MUS Bkg 16 Delay 2 Disc 4

Det 2 Mcr BF₃ counters Pulser 10-60 volts PH-5 = 100

9⁵⁷
9¹³

EXP # 262

PN-211 HFIR EXP #262 INNER 17.40 Outer 10.00

ACC 135KV 0.75 MA 100μS @ 70 CPS

TMC CH 40 MUS Delay 2 Bkg 16 Disc 4 MEM 1/1

EXP # 263

PN-212 HFIR INNER 17.40 Outer 12.0"

ACC 138 KV 0.75 MA 400μs 35 CPS

TMC Ch 80 MUS Delay 2 Bkg 8 Disc 4 MEM 1/1

Exp # 264

PN-213 Same as Exp # 263

EXP # 265

PN-214 HFIR #265 INNER 17.40 Outer 6.0"

ACC 135KV 200μs 70 CPS

TMC Ch 40 MUS Bkg 8

EXP # 266

PN-215 HFIR # 266 Inner 17.40 Outer 14.0

ACC 135KV 0.75 400μs 20 CPS

TMC Ch 160 MUS Bkg 8

Shut down

Instrument Check on 10-18-61 Source 10 mc RaBe

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	OK
IC-1	2.10×10^{-12}	Meter Trip	OK	Fast Trip
IC-2	2.10×10^{-12}	Meter Trip	OK	Dropped Safety
IC-3	5×10^{-11}	Calibration		
IC-4	5×10^{-11}	Calibration		
CRM		Meter Trip		

Preliminary Check on 10-18-61

Room 113 Pressure Differential	0.07
Red Light On and Personnel Check	✓
Scrams and Bldg, Alarm Reset	✓
Source Inserted	Accelerator
Safety Withdrawn	28.0"
Controls Set	INNER 17.40 Outer 0.08"
Reflector Water	Approx 6" Above Be
Moderator Water	28.22"

"Note" Added 26.35 Kg Demineralized H₂O to Refl H₂O System.

Exp # 267 10-18-61

Purpose: Check Crit Pos of Controls with safety at 28.0 + 21.0

	INNER	Outer	Safety	
	17.40	14.90	28.0"	lower Power level
	17.40	15.85	28.0	Pos Perm
907	17.40	15.58	28.0	level
918	17.40	15.90	20.99"	level

Insert Safety to make sub Crit

$$\frac{8.3}{.27} = 30.7 \text{ H/L}$$

Purpose: INNER and OUTER Positions at crit. changing both

INNER	Outer	Safety	
17.40	0.08	28.0"	
17.40	15.58	"	Crit.
18.40	13.95		
20.00	12.14		
22.00	10.86		
25.	10.36		
28.	10.07		
30.	9.71		
32.00	9.16		
35.	8.07		
38.	6.95		
41.	4.74		
44.	3.72		
10 17.4	15.58		
16.0	18.98		
15.4	23.50		
15.0	31.66		
14.6	34.03		
14.0	37.86		
13.6	43.00		

12⁰⁵ Shut Down Insert outer control AND Safety

Exp # 269

Purpose: Pulsing At Critical

	INNER	Outer	Safety	
12 ⁴⁸	17.40	15.90	20.99	Crit
3 ⁵⁴	17.40	15.90	20.99	After Pulsing Crit

PN-216 EXP # 269 Safety 20.99 to 14.00 after

200 pulses from accelerator
 Acc 135KV 1.8×10^{-5} mmHg 400 μ s @ 20 CPS
 TME CH 160 MUS Relay 2 Bkg 4 Dia 4 In 11
 Det 2 Min BF3 10-60 v pulses PHS=100

Instrument Check on 8-19-61 Source 10mc Ra Be 8

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 Meter Trip OK Fast Trip OK
 IC-2 Meter Trip OK Dropped Safety
 IC-3 Out for Repair Calibration
 IC-4 5 x 10⁻¹¹ Calibration OK
 CRM Meter Trip

Preliminary Check on 8-19-61

Room 113 Pressure Differential 0.06"
 Red Light On and Personnel Check ✓
 Scrams and Bldg. Alarm Reset ✓
 Source Inserted Accelerator
 Safety Withdrawn 20.99"
 Controls Set INNER 44.20" Outer 0.08"
 Reflector Water Approx 6" Above Be
 Moderator Water 28.92

EXP # 270 10-19-61

	INNER	Outer	Safety	
8 ⁵⁵	44.20	4.21"	20.99	Approx crit
9 ⁰⁸	44.20	4.57		Pos Per
	44.20	4.22		Crit
	44.20	0.08	For Pulsing	Sub crit

5.03 $\frac{div}{decade} \rightarrow 109.3 \rightarrow 5.88 \times 10^{-4} \rightarrow 9.27 \rightarrow 26.3 \text{ } \mu\text{in.}$

PN-217 INNER 44.20 OUTER 0.08 SAFETY 20.99

CRIT AT 4.22

Acc 135KV 1.7 x 10⁻⁵ mmHg 400µs @ 20CPS
 TMC CH 160 MUS Delay 2 Bkg 4 Disc 4 MEM 11
 DET 2na Min BF3 Pulses 10-60 V PHS 100

EXP # 271

Purpose: Pulsing at critical with 3/4 at 4.23 and In at 44.20

PN-218 INNER 44.20 3/4 OUTER 4.23 SAFETY 20.99
 MOVED TO 14.00 AFTER 200 PULSES.
 ACC 135KV 400µs 20CPS
 TMC 160 MUS Delay 2 Bkg 4 Disc 4 Mem 11
 DET 2na BF3 in Fuel element.

10¹⁸ Check crit before run level at 4.23
 12⁵¹ after run 4.23 level
 #2 Shut Down Insert outer control, Safety and Dump fuel H₂O

Removed target and placed in Al can
 4 5/16 ID x 40" High (47.27% void in target) with
 Sea 1" Plastic Disc placed on top of target 4 1/4" Dia

EXP # 272 10-19-61

Purpose: critical pulse, pulsed, with 47.27% void

	INNER	outer	Safety	Ref H ₂ O	Fuel H ₂ O	Approx
	20.34	0.08"	28.08	6" Above Be	28.59	Crit
3 ²³	20.75	0.08	145µp	Decoder $\rightarrow 4.65 \times 10^{-4}$	7.27"	Pos Per
	20.36	0.08			18.6 µ/in	level
	17.40	8.98				level

No water in 4 5/16 cylinder. Did not leak.

~~some indications that the reactor is not stable now. It is still pulsing. The reactivity at 20.36 is 0.08.~~

Instrument Check on ~~10-20-61~~ ~~10-20-61~~ 10-20-61

PM-1 ^{at 1.9 MA Trip Setting} ~ 40 μ A Low Trip OK Alarm Trip OK
 PM-2 _____ Alarm Trip OK
 IC-1 _____ Meter Trip OK Fast Trip OK Dropped Safety ^{Down H₂O}
 IC-2 _____ Meter Trip OK
 IC-3 Out For Repair Calibration _____
 IC-4 6 x 10⁻¹¹ Calibration OK
 CRM _____ Meter Trip _____

Preliminary Check on 10-20-61

Room 113 Pressure Differential 0.07"
 Red Light On and Personnel Check ✓
 Sorams and Bldg, Alarm Reset ✓
 Source Inserted Accelerator
 Safety Withdrawn 28.01"
 Controls Set INNER 999.93 Outer 0.08
 Reflector Water 6" Above Be
 Moderator Water 28.58"

Exp # 273 10-20-61

PN-219 HFIR #213 INNER 999.93 Outer 0.08"
 with 47.27% Void in target Safety 28
 Acc 135KV 0.85 MA 1.5 MUA 1.6-20 x 60⁻⁵ mm Hg
 70 MUS at 110 CPS
 TMC CH 10 MUS Delay 2 Bkg 16 Disc 4 Mem 1/1
 Det 10-60 volt pulses on 2 BF3 counters #HS = 100

Exp # 274

PN-220 HFIR #274 Inner = 12.00 Outer 0.08
 with 47.27% Void Safety 28
 Acc 135KV 100 MUS AT 110 CPS
 TMC CH 20 MUS Delay 2 Bkg 16 Disc 4 Mem 1/1

Exp # 275

PN-221 HFIR #2 EXP 275 Inner 17.00
 3/4 Outer 0.08 with 47.27% void. Safety 28
 Acc 135 KV 0.85 MA 100 MUS AT 70 CPS
 TMC CH 40 MUS Bkg 8 delay 2 Disc 4 Mem 1/1

Exp # 276

PN 222 HFIR #2 EXP 276 Inner 0.00
 3/4 Outer 8.98 Safety 28.
 Acc 135KV 0.88 MA 100 MUS AT 110 CPS
 TMC CH 20 MUS Bkg 16 delay 2 disc 4 Mem 1/1
 145 Shut Down

10-20-61 Removed target AND Replaced with Styrofoam - 4 3/16" DIA Made up of 2" Discs stacked together on 5/16" OD SS target Rod. Length 24 3/4". Styrofoam Extends from 1" Below core to 3 3/4" Above.

Instrument Check on 10-23-61 Source 10 mc Ra Be source

PM-1	Low Trip $> 500 \mu a$	Alarm Trip OK
PM-2		Alarm Trip OK
IC-1	7.10×10^{-12} Meter Trip OK	Fast Trip OK Dropper Safety
IC-2	$> 10 \times 10^{-11}$ Meter Trip OK	
IC-3	Out for Repair	Calibration
IC-4	5×10^{-11}	Calibration
CRM	Meter Trip	

Preliminary Check on 10-23-61

Room 113 Pressure Differential	0.07"
Red Light On and Personnel Check	<input checked="" type="checkbox"/>
Screams and Bldg. Alarm Reset	<input checked="" type="checkbox"/>
Source Inserted	Accelerator
Safety Withdrawn	24.07
Controls Set	INNER 17.40 Outer 0.08"
Reflector Water	6" Above Be
Moderator Water	28.63"

Exp # 277

Void Coef - with Styrofoam in target Region $4 \frac{3}{16}$ " DIA Discs by 2" thick - length $24 \frac{3}{4}$ "

	INNER	Outer	Safety	level
10 ⁰⁵ AM	16.84"	0.08	24.07	level
	17.00"	0.08		Per
	16.85"	0.08		level

Plate (Rod) In calibration

16.74	3.00
16.37	6.00
15.90	8.00
15.14	10.00
14.28	12.00
13.42	14.00
12.65	16.00
12.01	18.00
11.54	20.00

Inner	Outer
11.30	22.00
11.22	26.00
11.20	29.00
11.15	32.00
10.82	36.00
10.38	40.00
10.23	44.81

Exp # 278 10-23-61

Purpose: Pulsing At Sub-Crit

INNER	Outer	Safety
999.93	0.08	24.07

11²⁵ AM PN-223 INNER 999.93 $\frac{3}{4}$ OUTER 0.08 SAFETY 24.07
 WITH 70.9% ~~VOID~~ ^{4 3/16 in. Dia} STYROFOAM VOID IN TARGET REGION
 ACC 135KV 0.9MA 1MUA 1.7×10^5 mm Hg
 100 μs at 170 CPS
 TMC CH 10 μs BKG x16 Delay 2 Disc 4 Mem 1/1
 DET 2 BF3 COUNTERS IN FUEL ELEMENT
 10-60 Volt gnd PH 5 ON DD 2 @ 100

"Note"

Remove Styrofoam from target Region - target Region is now Empty (Except for H₂O)

Exp # 279

INNER 17.40 Outer 0.08" Safety 24.07"

PN-224

ACC 100 μs @ 110 CPS
 TMC 20 μs Bkg x16 Delay x2, Disc 4 Mem 1/1

"Note" Placed target in Al Can 4 5/16" ID, by 3 1/2" High and inserted in target Region
 5 Plastic Disc (1" thick) Placed on top of target 4 1/4" Dia
 Exp # 280

10-23-61	INNER	outer	safety	Pos Per
3 ²⁴ PM	20.80	0.08"	28.02"	
	11.2	91.35cc → 6.78 x 10 ⁻¹⁰ → 10.16		
	20.25	0.08"		level
	19.96"	3.00"		
	18.90	6.0		
	17.88	8.0		
	16.81	10.0		
	15.76	12.0		
	14.81	14.0		
	13.29	18.0		
	12.57	22.0		
	12.47	27.0		
	12.38	32.0		
	11.92	36.0		
	11.45	40.0		
	11.30	44.01		


428

shut down, drain H₂O

10-26-61

Rossi Alpha Measurements.

An attempt to measure Rossi α with one of the miniature counters is described below



TMC doesn't work if extra triggers come in during sweep time of the 256 channels. Therefore the sweep time of the test. 543 scope will be set longer than the time involved in the 212 logic unit.

Pu Be ²²⁸ Source was remounted in assembly and counter case removed.

TMC 160 μ s Bkg = Delay = 2 Div 0.5 170 x 256 \approx 40 msec

Test 543 5 msec/cm or 50 msec/sweep

IC-4 = 3.0×10^{-12} only a slight indication of correlated counts. MIN BF3 detector probably not sensitive enough.

Shut down

Instrument Check on 10-26-61 Source 10 m =

PM-1	Alarm Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	OK
IC-1	Meter Trip	OK	Fast Trip	OK
IC-2	Meter Trip	OK	Dropped Safety	
IC-3	Out for Repair	Calibration		
IC-4	5 x 10 ⁻¹¹	Calibration		
CRM	Meter Trip			

Preliminary Check on 10-26-61

Room 113 Pressure Differential	0.07
Red Light On and Personnel Check	✓
Serams and Bldg, Alarm Reset	✓
Source Inserted	# M-228 Installed in Source Drive
Safety Withdrawn	28.06"
Controls Set	INNER 14.40 Outer 0.08"
Reflector Water	6" Above Bc
Moderator Water	28.39"

"Note"

3^{PM}
3:00

Exp # 281 10-26-61

Purpose: Check Counting Equipment - Rossi Alpha

INNER Outer

14.40" 14.61" source out slightly sub crit

14.40 14.63 " "

Shut down and place hi I and 6292 detector above fuel element, gain x50 - 500 v on detector 6292 - check later for pulse height with thermal neutrons.

3²⁹

PM-1	> 50 μ s	Low Trip	OK	Alarm Trip	OK
PM-2				Alarm Trip	OK
IC-1	> 10 $\times 10^{-12}$	Meter Trip	OK	Fast Trip	OK
IC-2	> 10 $\times 10^{-12}$	Meter Trip	OK		
IC-3	OUT FOR REPAIR	Calibration			
IC-4	5.5 $\times 10^{-11}$	Calibration	DWM		
CRM		Meter Trip			

Preliminary Check on 10-27-61

Room 113 Pressure Differential	Down
Red Light On and Personnel Check	✓
Scrams and Bldg, Alarm Reset	✓
Source Inserted	Down
Safety Withdrawn	DWM Do Not raise above 26.5 (Control Room)
Controls Set	INNER = 14.00 OUTER = 0.08
Reflector Water	C.C.
Moderator Water	28.72"

Exp # 282

	INNER	Outer	
9 ²⁰	14.40	14.63	(source out) Slightly Sub Crit
	14.40	14.00"	lower Power level
9 ²⁹	14.40	14.63	Slightly Super.
	14.40	14.00"	lower Power level IC-2 IC-4
	14.40	13.50"	" " " " $.07 \times 10^{-12}$ $.06 \times 10^{-12}$ 5×10^{-13}

Insert Outer Control

Removed M-228 from 113. Still some counts on hi I detector, dropped from 8×10^3 to 2×10^3 . IC-4 below 10^{-13} . CRM = 6×10^3 c/min
 14.40 13.50 IC-4 = 3×10^{-13} IC-2 3×10^{-12}

11⁰³ Shut Down
 12-4-61 Note 1 target and 100 in Reactor DWM

This reactor has a source internally that perhaps is making the background counts extremely high for the Rossi- α measurements. It is not known whether this source is a γ -n or Be, γ from previous runs or perhaps an α -n reaction in the fuel element. Crit position not known exactly but Inner = 14.40 Outer = 14.63 was sub crit. 14.40 - 13.50 the power level became constant and was 5×10^{-13} on IC-4 with source in room. This dropped to 3×10^{-13} when the source was removed from 113, and an attempt was made to go critical under these conditions of one CRM and one log N and one linear instrument responding only when there was approximate multiplication.

Nov 22, 1961 water and diff pump off for a 3 weeks on acc. $2 \frac{1}{2} \times 10^{-14}$ open valve to acc.

Note

Smears taken on control cylinders for Be contm.

Results Clean - Readings .5 Micrograms
.5 " "
.3 " "

Instrument Check on 1-26-62 Source 10 mc Ra

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	OK
IC-1	Meter Trip	OK	Fast Trip	OK
IC-2	>10 x 10 ⁻¹²	Meter Trip	OK, Scrammed Safety and water drain	
IC-3	out for Repair	Calibration		
IC-4	~5 x 10 ⁻¹¹	Calibration	own	
CRM	Not in use	Meter Trip	Not in use	

Preliminary Check on 1-26-62

Room 113 Pressure Differential	OK
Red Light Control Personnel Check	✓ CC
Scrams and Alarm Reset	✓
Source Insertion	✓ Resp OK
Safety Withdrawal	28.0"
Controls Set	INNER 10.05" Outer 10.0"
Reflector Water	6" Above Bc
Moderator Water	29.79"

EXP. 283

Purpose: Determine critical position of control plates
 3/4 outer control and inner control plates have been modified (according to drawing) to represent more accurately the controls in the reactor. Holes were drilled in the nickel and silver sections and slots were cut in the 3/4 outer control to simulate the 4 section control in the reactor (Controls were checked for interference before start of Exp #283)

Target Installed, Source M-228 NiV₂O₃

(over)

Time	Source out	Inner	Outer	Notes
1 ²⁹ PM				
		16.42	16.42	Approx Crit
1 ³⁴		16.42	16.67	To increase Power level
2 ⁰⁰		16.42	16.43	Crit
2 ¹⁵		33.87	00.07	Crit

Time	Inner	Outer	Notes
2 ²⁰	33.88	00.07	Crit
	32.84	4.00"	"
	27.51	8.00"	"
	20.95	10.00"	"
	17.68	14.00	"
	17.61	14.00	"
	16.09	17.30"	"
	15.37	20.00"	"
	14.88	30.00"	"
	13.69	38.00"	"
	13.30	44.00	"

4¹⁵ Shut down. Insert control safety drain thro.

1-29-62
Installed 0.67 (4 3/16 o.d.) void in target region, approx centered, styrofoam 1 3/8 below and 3/8 in. above fuel.

Instrument Check on 1-29-62 Source 10mc RaY

PM-1	Low Trip Meter off scale	Alarm Trip Meter off scale
PM-2		Alarm Trip Meter Trip at 100
IC-1	$> 10 \times 10^{-12}$	Water Trip at 100
IC-2	$> 10 \times 10^{-12}$	Water Trip at 100
IC-3	Out for repair	Safety dropped, Pressure off, water drain pipe
IC-4	Calibration OK DWM	(Recorder zero has shifted)
CRM	Meter Trip	

Preliminary Check on 1-29-62

Room 113 Pressure Differential	1" H ₂ O
Red Light On and Personnel Check	OK c.c.
Screams and Bldg. Alarm Reset	DWM
Source Inserted	M-228, Inst response ok IC-1, 2 & 4, Aud
Safety Withdrawn	DWM (28.0)
Controls Set	Med. Inner @ 0.00, 3/4 Outer (Med.) @ 0.0 DWM
Reflector Water	6" Above Be
Moderator Water	29.01

Exp # 284

Time	Source out	Inner	Outer	Notes
10 ⁴⁴ AM				(0.67 void)
		15.43	00.07"	Approx Crit
		14.99	00.07"	Lower Power level Sub Crit
11 ⁰⁴		15.70	00.07	Pos Per

3.13 div/dec → 68.0 sec → 8.4×10^{-4} → 13.1 f

$13.1 / .27 = 48.5$ f/inch

15.43	00.07"	level (@ 4×10^{-10} IC-4)
15.29	4.0"	
14.76	8.0"	
14.29	10.0"	
13.145	13.145	
11.74	17.30	

(Cont)

INNER	outer	
11.11	20.00	level
10.74	30.00	"
10.18	38.00	"
9.84	44.00"	level

12²⁹ Shut Down - Insert outer control, Dump fuel H₂O lower safety

EXP # 285

Preliminary Check on 1/29/62

Room 113 Pressure Differential 1" H₂O down
 Red Light On and Personnel Check down
 Scrums and Bldg. Alarm Reset down
 Source Inserted C.C.
 Safety Withdrawn to 28.0
 Controls Set Both inner and outer fully inserted 0.0 and 0.0
 Reflector Water ~ 28.0 in (6 in above Be)
 Moderator Water _____

Target assembly with 0.473 void installed (with 4 5/16 o.d. aluminum container)

2³²

Source Out
 INNER outer
 18.35" 00.07" Pos Per
 $4.0 \text{ div/decade} \rightarrow 86.9 \text{ sec} \rightarrow 7.04 \times 10^{-4} \rightarrow 11.0 \mu$
 $11.0 / 0.32 = 34.7 \mu/\text{in}$
 18.03 00.07" Level
 17.79 4.00"
 16.81 8.00"

INNER	Outer	
15.97	10.0"	
14.20	14.20	level
13.10	17.30	
12.49	20.00	
12.12	30.00	
11.355	38.00	
11.02	44.00"	level

4²⁷ Shut Down - Insert outer control, Safety And Dump fuel H₂O

Instrument Check on 1-31-62 Source 10 mc/Ra δ

PM-1 Low Trip OK Scrum Check OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 7/6 x 10⁻¹² Meter Trip OK Fast Trip OK
 IC-2 7/0 x 10⁻¹² Meter Trip OK
 IC-3 Out for Repair Calibration
 IC-4 ~ 5 x 10⁻¹² Calibration down
 CRM No A in use Meter Trip

Preliminary Check on 1-31-62

Room 113 Pressure Differential 1" H₂O
 Red Light On and Personnel Check C.C.
 Scrums and Bldg. Alarm Reset C.C.
 Source Inserted Inst Response
 Safety Withdrawn 28.0"
 Controls Set Inner = 0.00 Outer = 0.06
 Reflector Water 6" Above Be
 Moderator Water 28.36"

EXP # 286 : Purpose Control inter comparison w.o. target no voids.

9¹⁸ AM

Inner	Outer
44.19	0.06

Source	Out
Pos	Per

3.4 div/decade \rightarrow 183 acc \rightarrow 3.84×10^{-4} \rightarrow 6.0 f

6.0/2.81 = 2.14 f/in

41.38 0.06

Level

39.09 4.0"

34.59 8.0"

31.63 10.0"

26.58 12.0"

20.38 14.0"

17.85 17.85"

17.18 20.00"

14.43 30.00"

14.96 38.00"

14.56 44.00"

11¹⁹ Shut Down Drop Safety, Dump fuel H₂O

Total Running Time - 1926

FSA

Instrument Check on 3-1-62 Source 10mc/Rad.

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	OK
IC-1	7.0×10^{-12}	OK	Fast Trip	OK
IC-2	7.0×10^{-12}	OK	Scrammed System	
IC-3	4.5×10^{-11}			
IC-4	5.5×10^{-11}			
CRM				

Preliminary Check on 3-1-62

Room 113 Pressure Differential 1"

Red Light On and Personnel Check ✓

Scrams and Bldg. Alarm Reset ✓

Source Inserted Use Accel for Source

Safety Withdrawn 28.0"

Controls Set INNER 0.0 Outer 0.0


Reflector Water Approx 6" Above Be

Moderator Water 29.1"

"Note" Source # 228 Removed from HFIR Rig Target Removed

Exp # 287 3-1-62

Purpose: Pulsing at sub crit with control rods at "zero". target region without any void. BF3 counters located between fuel annulus of core in approx this pos



Centered Vertically

PN-225 EXP # 287 INN=OUTER = 0.00 Target removed

ACC 2.9×10^{-5} mm 115KV .98 ma ~3µa SF 55

Focus = Sol = Max. 100µs @ 150 cps.

TMC CH 10µs Bkg x 32 Delay x 2 MEM 1/1 Disc 4

DET 2 ea BF₃ counters between fuel element annuli

PHS=200 DD-2 1.1 x 200 HV: 1750

PHS=200 " " " HV: 1900

PN-224 Same as PN-225

ACC 117KV .820 ma ~2µa 2.2×10^{-5} mm

100µs @ 150 cps

TMC & DET Same as PN 225

Accelerator was much more stable during this run.

Shutdown by drain Mod. H₂O, Reflector H₂O

Instrument Check on 3-2-62 Source 10 µa

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	Scrammed	Fast Trip	OK
IC-2	$> 10 \times 10^{-12}$	Meter Trip	OK		
IC-3	4.5×10^{-11}	Calibration	Down		
IC-4	5.5×10^{-11}	Calibration	Down		
CRM	X	Meter Trip	X		

Preliminary Check on 3-2-62

Room 113 Pressure Differential 1"
 Red Light On and Personnel Check ✓
 Scrams and Bldg, Alarm Reset ✓
 Source Inserted Use Accelerator
 Safety Withdrawn 28.01"
 Controls Set INNER 17.85 Outer 0.0"
 Reflector Water Approx 6" Above Ba
 Moderator Water 28.6

EXP # 288

PN-227 - Inner = 17.85 Outer 0.00 No target

While setting up conditions for pulsing the accelerator (at 115 kv) arced twice the latter upset the pulsing system so that the beam was on target. The increase in neutron level scrambled the system.

Acc 115 kv 0.73 ma ~1µa 200µs @ 70 cps

TMC CH 40 M05 BKG X 16 DELAY X 2 MEM 1/1 Disc 4

DET see # 294 PN 225.

Press 2.5×10^{-5} mm source on

2.5×10^{-5} 160 ma PScanned

EXP # 289

PN-228 Pulsing at critical

while turning on accelerator scrambled system with too many neutrons.

Critical positions 18.02, 18.02, Safety 21.00

Insert safety to shut down. (for lunch)

after 4456 cycles, the accelerator gave an extra large burst of neutrons and scrambled system - background ratio less than 4. Print out and start over

PN-228 Acc 115 kv 400 μs @ 21 cps
TMC CH 160 μs Bkg x4, Delay x2 Disc 4 Mem 1/1

Repeat - critical

PN-229

Acc 1.5×10^{-5} SF = 50 FOC Max Sol Max 115 KV 0.62 ma
~~400 μs~~ 400 μs @ 21 CPS
TMC CH 160 μs Bkg x4 delay x2 Disc 4 Mem 1/1
DET See 225

Warning in accelerator shut down scrambled

EXP # 290

PN-230

Inner 17.85 Outer 12.00 Safety 28.00
Acc 116KV .67ma SF 50 v/ma 250 μs 39 cps
 2.0×10^{-5}
TMC CH 80 μs BKG x4 Delay x2 Disc 4 MEM 1/1
DET See 225

-Instrument Check on 3-5-62 Source

PM-1 Scramed	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	OK
IC-1 3×10^{-12}	Meter Trip	OK	Fast Trip	OK
IC-2 10×10^{-12}	Meter Trip	OK		
IC-3 5×10^{-12}	Calibration			
IC-4 Respond	Calibration			
CRM	Meter Trip			

Preliminary Check on 3-5-62

Room 113 Pressure Differential 1"

Red Light On and Personnel Check

Scrams and Elog. Done and Reset

Source Inserted Accel OK

Safety Withdrawn 21.01"

Controls Set INNER 999.93 Outer 0.07

Reflector Water Approx 6" Above Bc

Moderator Water

Exp # 290

Purpose: Check Crit Pos with out void And outer control At "Zero"

Accel off Sub crit

	INNER	outer	Safety	Sub Crit
10 ⁰⁰ AM	44.19	0.07	21.01"	Sub Crit
10 ⁰²	44.19	1.81	(to increase Power level)	Pos Per level
10 ³¹	44.19	1.43		level

PN-231 EXP #290 Inner 44.19 outer 1.43 Saf 21.01

Acc 1.6×10^{-5} mmHg 115KV 0.60 ma 1000 μs @ 11 cps
SF = 50 Sol = FOC 2 Max.

TMC CH 320 μs BKG x4 Delay x2 MEM = 1/1 Disc 4

Detectors MinBF3 ① 1550 D02 1.1x20 PHS 150

② 17.50 " " "

Output pulses ~ 30 volt.

At end of Run Reactor not critical
 - 77 dia - Period of 1673 sec, $.509 \times 10^{-4} = 0.008$

New Critical Position 44.19 Inset

1.51 Outer

21.01 Safety

PN-232 Repeat 231 ~~etc~~

- ① False scan accelerator turning on from switching transient,
- ② End false scan acc turning on from switch transient

Found cable on initial pulse loose.

PN 232 EXP #290 continued.

Acc 13×10^{-5} mm Hg 117 kv 0.610 ma 55 SF

800 μ s Burst 21 cps

TMC 160 MDS Bkg x4 Delay x2 Mem // Disc 4

DET PHS changed to 175

4¹⁰ PM INNER - outer Safety

44.19 1.51 21.0" level

Shut Down Insert Safety, Dump fuel H₂O

For PN-232, 231, 229, 228, the accelerator
was pulsed for 200 cycles, neutron level reduced
by inserting safety to 14.00 i and then
withdrawing to critical, This was repeated
at various times -

Don

c 4

o

300

~ June 1, 1961 Sample taken from Island-refl Storage
Tank i: Total solids ~ 7.0 PPM, ignited ~ 5 PPM