

## BOOK 5R

*Notes:*

Blank pages: inside front cover sheets

1, 2, 3, 7, 8, 9, 10, 36, 60, 66, 72, 76, 77, 81, 112, 114-116, 118, 126, 136, 138, 140,  
148, 156, 160, 162, 166, 167, 178, 184, 194, 212, 246-255, 257-300  
back inside cover sheets

-pages 5/6 ripped out

-page 64 has picture taped to it

-2-sided piece of paper between page 132 & 133

-1 graph sheet between page 150 & 151

-1 sheet between page 216 & 217

had to cut & paste a dark printing of words with lighter printing of picture (pg 64).

*Scanned by:*

*Sheila Finch*

*RSICC /Oak Ridge National Lab.*

*March 24, 1999*

U 5006

23U

TAMERTON

4

U233

1<sup>st</sup> Shipment from Hanford

Material received in 3-liter containers - transferred to 15-liter bottles

	Bottle #	BHW #	Element wt	wt % isotope	isotope wt.	Net wt <del>kg</del> kg
15-liter capacity bottles	1	6-28-141	915	98.301	899	4.012
		6-29-148	926	98.294	910	4.114
	2	6-29-149	934	98.294	918	4.117
		6-31-156	950	98.092	932	4.257
	3	6-28-142	890	98.301	875	3.944
		6-29-147	924	98.294	908	4.119
	4	6-31-158	948	98.092	930	4.270
		6-29-146	849	98.294	835	3.783
	5	6-28-144	886	98.301	871	3.871
		6-28-159	971	98.092	952	4.266
	6	6-28-143	912	98.301	897	3.997
		6-31-155	932	98.248	915	4.155
	7	6-29-145	907	98.294	892	4.060
		6-31-157	912	98.092	895	4.022
	8	6-28-140	916	98.301	900	4.001

Total 13.772 kg

13.529 kg

H/U  
233  
89.9

8-3-66

Exp. 1.

Exp. Plan W-6

Experiment conducted in 6 ft-square experimental tank. Purpose: to verify that 12 liters of U(233) nitrate solution in 15-liter polyethylene bottle is subcritical when ~~flooded~~ <sup>submerged</sup>.

The number 7 bottle centered in the tank

Solution height 47.6 cm. Bottle located on  $\frac{1}{2}$ " thick plate.

Zero on scale in control room corresponds to 74.3 cm.

12:30  $R \ll 1$  water height <sup>reads as</sup> 77.8  $\Rightarrow$  72.1 cm.  
 water level ~15 cm above solution.

Have added 3 liters of solution from bottle #3 to #7

Solution ht in #7 now reads 71.2 cm.

$R \ll 1$  water height reads as 62.15 cm  $\Rightarrow$  86.4 cm

~15 cm above solution. There is no evidence

of an exponential rise on the linear instruments  
 i. multiplication is nil.

2:45

Have added remaining 3 liters of bottle 3 to #7.

solution height now ~ 92.4 cm.

$R \ll 1$  water height reads as 83.4 cm ~15 cm above sol'n.


There is an observable curvature on trace

on linear instruments  $\rightarrow$  indication of some




multiplication - probably much less than 5.



9-7-66

Expt. 2 $k \ll 1$  at contact.

$k_{gu}$	2.598	2.852
$k_{gu}^{233}$	2.533	2.740

Expt. 3 $k \ll 1$  at contact.Expt. 4 $k \ll 1$  at contact.

Expt 2  $U^{233}$  solution

Instrument Check on 9-7-66 Source 10 mcd

JTT

C.C.

PM-1	Low Trip	✓	High Trip	✓	
PM-2			High Trip	out	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	✓	High Trip	✓
IC-2	$> 3 \times 10^{-11}$		✓	Response	✓
IC-3	Responds		✓	alarms	✓
IC-4	Responds		✓	diff. Press.	65"
CRM	Meter Trip				

Purpose: determine if two bottles are critical at any separation distance.

Bottle #12 is on fixed table and #11 on movable table.

10 AM

$k \ll 1$  no observable multiplication when bottles are in contact.

Expt 3 same as Expt 2 but with stacks of polyethylene blocks behind each bottle.

10<sup>12</sup> AM

$k \ll 1$  no observable multiplication at contact.


Expt 4 same as Expt 3 but with rearrangement of polyethylene reflectors.

10<sup>25</sup> AM

$k \ll 1$  no observable multiplication at contact.

9-7-66


Exp 5.



$k \ll 1$  at contact.

$R_{gU}$	2.598	2.552	2.462
$R_{gU}^{233}$	2.533	2.740	2.402


Exp 6.



$k \ll 1$  at contact.

$R_{gU}$	3.176
$R_{gU}^{233}$	3.090


Exp 7



$k \ll 1$  at contact

$M \approx 2$

Exp 8



$k \ll 1$   $9 < M < 10$

$R_{gU}$	3.111
$R_{gU}^{233}$	3.028

4-7-66

15

Expt. 5 Determine if 3 containers in contact are critical as a linear unreflected array.

10<sup>55</sup> AM

$k \ll 1$  no observable multiplication at contact

Expt. 6 Determine if 4 containers in a linear unreflected array are critical; zero separation.

11<sup>15</sup> AM

$k \ll 1$  no observable multiplication at contact.

Expt. 7 Determine if 4 containers in a linear array reflected on one side by 6-in-thick polyethylene reflector is critical; zero separation.

11<sup>30</sup> AM

$k \ll 1$  multiplication of about 2 (from linear instruments.)



Expt. 8 Same description as Expt. 7 but have now added bottle #8 to the fixed table - 5 containers against polyethylene reflector; zero separation

3 PM

$k \ll 1$  Multiplication between 9 & 10.

16

9-7-66

Exp. 9

R &gt; 1 at closure

KgU	2.399	3.176	2.598	
-----	-------	-------	-------	--

KgU <sup>233</sup>	2.339	3.090	2.533	
--------------------	-------	-------	-------	--

	2.852	2.462	3.111	
--	-------	-------	-------	--

	2.740	2.402	3.028	
--	-------	-------	-------	--

Total

16.598

16.132

9-7-66

17

Expt 9 Same as Expt 8 with addition of bottle #7  
to movable table. 6 containers in line  
against polyethylene reflector; 3000 rpm rotation

3<sup>20</sup> PM

$k=1$  tables separated 5.55 revs  $\Leftrightarrow$  0.249"

positive period 143 sec  $\Rightarrow$  7.49  $\Rightarrow$  4.93  $\frac{1}{in}$

$k=1$  tables separated 5.78 revs  $\Leftrightarrow$  0.314"

9-8-66

Exp 10

		(6) (7) (9) (11)		(12) (10) (8) (5)	
			→		
kg U	2.356	46.598		2.773	
kg U <sup>233</sup>	2.294	16.132		2.700	RLLI at contact

Exp 11

		(3) (6) (7) (9) (11)		(12) (10) (8) (5) (4)	
			→		
kg U	2.970	26.722		2.825	
kg U <sup>233</sup>	2.890	26.126		2.751	

Exp 12

		(1) (3) (6) (7) (9) (11)		(12) (10) (8) (5) (4) (2)	
			→		
kg U	2.619	27.517		2.895	Totals
kg U <sup>233</sup>	2.552	26.767		2.816	33,031
					32,135

9-8-66

C.C.

Instrument Check on 9-8-66 Source 10mc 8

JW

PM-1	Motor Only	✓	✓
PM-2			✗
IC-1	$> 3 \times 10^{-4}$	Motor Only	✓
IC-2	$> 3 \times 10^{-4}$		✓
IC-3	Responds	Calibration	JW ✓
IC-4	Responds	Calibration	JW ✓
CRM	Motor Only		diff. p.c.s. 2.05 "

Expt. 10 Purpose: Examine linear unreflected array of 8 cylinders in contact.

$10^{15} \mu\text{m}$   $R \ll 1$  no observable multiplication when tables are closed.





Expt. 11 Purpose: Examine linear unreflected array of 10 cylinders in contact.

$10^{18} \mu\text{m}$   $R \ll 1$  no observable multiplication when tables are closed.  
( $\frac{1.8}{1.5} = 1.1$ )

Expt. 12 Purpose: Examine linear unreflected array of 12 cylinders in contact.

$R \ll 1$  no observable multiplication in contact.  
( $1.1 \approx \frac{2}{1.8}$ )





9-8-66

Expt 13

Purpose: Examine criticality of two containers, in contact, and reflected on two sides by 6"-thick polyethylene

$K=1$  multiplication  $\approx 2$  from Lu N and IC-2.

Expt 14

Purpose: Examine criticality of three containers in contact and reflected on two sides by 6"-thick polyethylene.

1:30 PM

 $K=1$ 32.0 Revs. ( $\approx 3.5''$ ) table separationExpt 15



Purpose: Same as 14, except have moved one side reflector 1" from bottles

 $K=1$ 18.4 revs. ( $\approx 1.5''$ ) table separation.Expt 16

Purpose: Examine criticality of linear array of three containers separated by 1" and reflected on two sides of 6"-thick polyethylene reflector.

 $K=1$ 15.7<sup>8</sup> revs.  $\approx 1.2''$  table separation.

Exp. 17



R-21

M-2

Expt 17

Purpose: Same as Expt 16 expansion now  $n_2 = \frac{1}{16}$  $k = 1$   $M = 2$  on  $\ln N$  &  $IC_2$

8/23/66

U<sup>233</sup> Inventory

Rec'd	Bottle No.	Net kg	U kg	<sup>233</sup> U kg
8/22/66	' 1	11.201	2.619	2.552
	' 2	11.835	2.895	2.816
	' 3	12.261	2.970	2.890
	' 4	11.821	2.825	2.751
	' 5	11.743	2.773	2.700
	' 6	10.318	2.356	2.294
	Totals	69.179	16.438	16.003
8/26/66	' 7	10.134	2.399	2.339
	' 8	12.930	3.111	3.028
	' 9	13.188	3.174	3.090
	' 10	11.008	2.462	2.402
	' 11	11.125	2.598	2.533
	' 12	11.934	2.852	2.740
	Totals	70.314	16.598	16.132
9/23/66	13	12.238	2.804	2.688
	14	12.143	2.760	2.691
	15	11.389	2.634	2.566
	16	11.920	2.669	2.605
	17	10.944	2.558	2.490
	18	12.321	3.041	2.867
	19	12.522	2.844	2.776
	20	12.607	2.828	2.760
	Totals	96.084	22.138	21.443

Rec'd	Bottle #	Net, kg	U, kg	<sup>233</sup> U, kg
11/22/66	• 21	12.441	2.770	2.706
	• 22	11.873	2.723	2.659
	23	12.283	2.818	2.750
	• 24	11.885	2.727	2.663
	25	12.702	2.845	2.774
Totals		61.204	13.883	13.552
12/20/66	• 26	12.464	2.892	2.826
	• 27	12.281	2.830	2.764
Totals		24.745	5.722	5.590
Grand Totals		<u>321.526</u>	<u>74.779</u>	<u>72.720</u>

Total wt of solution 321.526 kg

Total wt of Uranium 74.779 kg

$UO_2(NO_3)_2$  has salt factor of 1.66952

∴ there are 124.84504 kg of salt.

$$321.526 - 124.84504 = 196.68096 \text{ kg of } H_2O$$

$$\therefore \frac{H}{U} \approx \frac{1}{9} \frac{196.68096}{74.779} \times 233 = 68.1$$

estimate conc. 330-350 g/l.


## Volume calibration of transfer system

lit.	$\Delta V$	V	lit.	$\Delta V$	V	lit.	$\Delta V$	V
93.48	.4975	.499	87.75	.980	.980	76.50	2.0	2.0
87.60	.495	.993	77.00	.980	1.960	55.80	2.0	4.0
82.00	.500	1.493	66.70	.970	2.930	35.81	2.0	6.0
76.70	.485	1.978	56.66	.980	3.910	16.20	2.0	8.0
71.45	.500	2.478	46.90	.970	4.880	4.0	2.0	10.0
66.10	.485	2.963	37.20	.980	5.860	on Mark	.075	10.075
61.25	.490	3.453	27.60	.980	6.840			
56.25	.490	3.943	17.96	.980	7.820			
51.30	.490	4.433	8.25	.980	8.800			
46.35	.490	4.923	4.0	.980	9.780			
41.45	.490	5.413						
36.64	.490	5.903						
31.76	.490	6.393						
27.03	.480	6.873						
22.20	.490	7.363						
17.40	.480	7.843						
12.60	.485	8.328						
7.80	.485	8.813						
2.90	.490	9.303						
4.0	.480	9.783						

Complete drain from lit 37.60 an  
is ~4.40 liters.

System complies with TM 349  
requirements. *SW*

Schematic of Plumbing System for U<sup>235</sup> Ring Expt.





20" dia cyl has 2,027 l/cm.

3/27

Expr. 18

Have added containers 1 and 27 to system

#1 2.619 kg U

27 2.830 kg U

total 5.449 kg U

Expr. 19 added containers 3 and 8 to systems

#3 2.970 kg U

8 3.111 kg U

total 11.530

3/28

Expr. 20 added containers 7 and 9 to systems

Storage cylinder full; solution standing

0.97" in 20" dia. cylinder

#7 2.399 kg U

#9 3.176 kg U

total 17.105 kg U.

Added 6 boxes of KG 33 rings to 20" dia cylinder

~ 324 rings/box

ring height in cylinder about 27"

relays zero is 0.02"

Instrument Check on 3-27-67 Source 10me

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	-
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Personnel $\checkmark$
IC-3	Responds	Calibration	OK	span out Alarms $\checkmark$
IC-4	Responds	Calibration	OK	span out Press .05
CRM	Meter Trip			

Expt. 18 Purpose Check criticality of bare 20" dia cyl

$k < 1$  tab 37.20 Soln <sup>corrected</sup> 1.74" = 4.42 cm  $\Rightarrow$  8.958 l.

Expt. 19

$k < 1$  tab 25.42 Soln <sup>corrected</sup> 4.30" = 10.928 cm  $\Rightarrow$  22.137 l.

Instrument Check on \_\_\_\_\_ Source \_\_\_\_\_

PM-1	Low Trip	3-28-67	Alarm Trip	_____
PM-2			Alarm Trip	_____
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip		Personnel $\checkmark$
IC-3	Responds	Calibration	OK	span OK Alarms $\checkmark$
IC-4	Responds	Calibration	OK	span OK Press - 0.05"
CRM	Meter Trip			

9<sup>45</sup>/<sub>A</sub> Expt. 20 - Find critical ht in 20" bare cyl.

$k > 1$  tab 31.53 Soln 5.265" +P T = 155.8 sec

10<sup>25</sup>/<sub>A</sub>  $k = 1$  tab 24.10 Soln 5.260  $\Rightarrow$  ~ 8.3¢

U<sup>233</sup>

3/29 sample taken from system after expt. 21

# 1

Gross wt. 74.218 gm

tare " 20.691

net ~ 53.527 gm U

X-10 Sample control # SFA 2159

{	339.1 mg/ml	sp. gr. 1.4682
	340.2 mg/ml.	

Expt. 22 Have added containers 5 &amp; 6 to system

# 5 2.773 kg U

# 6 2.356 kg U

Total 22.234 kg U

3/30

Have added containers 4 and 11

# 4 2.825 kg U

# 11 2.598 kg U

Total 27.657

Added containers 10 and 12

# 10 2.462 kg U

# 12 2.852 kg U

Total 32.971

Instrument Check on 3-29-67 Source 10mc

PM-1	Low Trip	OK	Alarm Trip
PM-2			Alarm Trip
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK
IC-3	Responds	Calibration	OK
IC-4	Responds	Calibration	OK
CRM		Meter Trip	

9<sup>AM</sup> Expr. 21 Check criticality when 20" cgl. contains rings.

Solution height in vessel at beginning 1.49"

$R \ll 1$  tad 39.28 Soln 12.43

Expr. 22 Check criticality with additional solution

$R \ll 1$  tad 39.28 Soln 12.56

Instrument Check on 3-30-67 Source 10mc

PM-1	Low Trip	OK	Alarm Trip
PM-2			Alarm Trip
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK
IC-3	Responds	Calibration	OK
IC-4	Responds	Calibration	OK
CRM		Meter Trip	

8<sup>58</sup> AM Solution standing 17.96" in vessel. Prepare add two more containers.

Expr 23  
 $R \ll 1$  tad 39.28 Soln 22.464"

Expr 24

$R \ll 1$  tad 20.10 Soln 26.75

3/30

Added containers 2 and 21

2 . 2.895 kg u

21 2.770 kg u

Total 38.636

4/3/67

Sight glass tube developed crack - necessary  
to replace before proceeding. Crack noted on Friday

3/31/67 -

Apr. 25

Have added bottle #26 to system

#26 2.892 kg u

Total 41.528

Ex. pr. 25  $k < 1$  tad 20.12 Soln 30.74

Observed solution to be above ring bed.

Drained and observed level when some rings are above solution level. Reading 26.90"

4/3/67

Replaced tube in slight glass. Have pumped all solution into vessel again. Selwyn set to read 30.14 when tad is at 20.12" - This will require blocking zero again when solution is drained.

Instrument Check on 4/3/67 Source 10mc d

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	Alarms	OK
IC-3	Responds	Calibration	OK	Response	OK
IC-4	Responds	Calibration	OK	Peak	- 0.05"
CRM		Meter Trip			

Ex. pr. 26 Attempt criticality with solution above rings.

$k > 1$  tad 22.68 Soln 30.75<sup>2</sup> }

$k = 1$  tad 19.68 30.77<sup>5</sup>

3/5/67 3:45 pm 23.965

Exp. 26

## Background traverses

distance of BF <sub>3</sub> from bottom (in)	c/min			Source present
	C <sub>1</sub>	C <sub>2</sub>	C <sub>3</sub>	
0	970	10270	400	
5	1010	10280	700	
10	1040	10400	400	
15	1000	10280	600	
20	1020	10340	900	
22.5	1060	10150	700	
25	1020	10120	400	
27	1060	10230	100	

## Source out

0	440	1510	100
5	390	1470	400
10	460	1470	400
15	440	1590	300
20	440	1490	200
22.5	480	1550	400
25	470	1470	400
27	440	1450	200

## Exponential Measurement.

Instrument Check on 4-5-67 Source Co-60

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-11}$	OK	Personnel	OK
IC-3	Responds	Calibration	Alarms	OK
IC-4	Responds	Calibration	Press.	$-0.05''$
CRM	Meter Trip			

945

Expr. 27 - Axial traverse with  $\text{BF}_3$  counter.

Make background traverse: Tad 20.15" Sdn 27.985

k=1 Tad 24.78" Sdn 30.78

R=1 " 22.15 " 30.77

Traverse IC-2 ( $3 \times 10^9$ ) 3.6

IC-3 .16

IC-4 2.8

Solution height variable as  $\text{BF}_3$  is moved.

1158

Shutdown: k=1 Tad: 22.725 Sdn: 30.785



Expt. 27 cont'd

Transverse with  $k=1$  Instrument levels recorded on p 35

BF <sub>3</sub> position from bottom (in)	c/m × 10 <sup>-1</sup>			tag position (in)
	C <sub>1</sub>	C <sub>3</sub>	C <sub>4</sub>	
0	577830	198651	218	22.15
1	485380	200908	321	22.15
3	49865	205101	839	22.94
5	50761	207367	1151	21.75
7	51249	188747	1881	21.42
9	60878	206835	2620	21.18
11	60192	204809	3198	'
13	60460	205113	5150	-
15	60744	206352	10735	'
17	61312	207113	14541	'
19	61488	216850	22099	'
21	62166	208982	34920	20.96
23	61527	206952	61223	20.96
25	59522	201026	103217	21.03
27	44780	186363	162153	21.80
29	58883	208237	81031	22.39
30	52710	209869	28577	21.80
28	62384	208193	152976	
26	62981	210362	155748	
24	66006	219565	74668	20.55

## NORMALIZED TRAVERSE

BF <sub>3</sub> Position from Bottom (in)	Norm. to C <sub>3</sub> @ 25"	Norm. to C <sub>1</sub> @ 25"		
0	221	225	.00218	.00108
1	321	354	.00382	.00189
2	563	588	.00570	.00282
3	822	1001	.00970	.00479
4	881	877	.00850	.00420
5	1116	1349	.01307	.00646
6	1061	2109	.01074	.00531
7	2003	2185	.02117	.01046
8	1930	2624	.01961	.00969
9	2546	2562	.02482	.012269
10	3067	3060	.02965	.01465
11	3139	3162	.03063	.01514
12	4142	4128	.03999	.01977
13	5047	5070	.04912	.02428
14	6451	6769	.06558	.03242
15	10458	10519	.10191	.05037
16	10249	10103	.09788	.04838
17	14114	14116	.013676	.06760
18	15966	15697	.15208	.07517
19	20487	21392	.20725	.10244
20	25087	24796	.24093	.11875
21	33591	33434	.32392	.16011
22	47369	46728	.45271	.22378
23	59470	59228	.57382	.28364

Expt. 29 Traverse.

BF<sub>3</sub> position

from bottom (in)	C <sub>1</sub>	C <sub>2</sub>	C <sub>3</sub>	total (in)
22	65095	216877	51104	20.55
20	64464	215195	26855	19.60
18	65117	216223	17173	"
16	64661	215265	10975	19.48
14	57202	202699	6505	23.31
12	59390	199914	4119	23.05
10	58831	198217	3024	22.87
8	59037	209099	2008	"
6	59313	209301	1105	"
4	59262	199102	873	22.72
2	58895	207832	582	22.72
0	59387	209458	219	22.72

Norm. traverse Cor'd.

BF <sub>3</sub> position	Norm to C <sub>2</sub> @ 25"	Norm to C <sub>1</sub> at 25"
From bottom (in)		
24	68364	67333 .65234 .32245
25	103217	103217 1. — .49480
26	148836	147193 1.42605 .70489
27	174913	215534 2.08816 1.032
28	147710	145957 1.41408 .6990
29	78225	81910 .79357 .3923
30	27373	32270 .31264 .1545
0	210	219 .00212 .00195

BF <sub>3</sub> Position (m)	$\times 10^3$			Norm to C <sub>3</sub>	Norm to C <sub>1</sub>	Tail position
	C <sub>1</sub>	C <sub>3</sub>	C <sub>4</sub>			
8	56612	155943	2006	.0204	.0205	21.11
10	57032	156965	3095	.0313	.0314	"
12	56578	155331	4103	.0419	.0420	"
14	56617	155292	6588	.0674	.0673	"
16	55877	152868	9910	.1029	.1026	"
18	56538	154883	15880	.1628	.1625	21.115
20	57081	155215	25059	.2564	.2540	"
22	57960	156624	37854	.3838	.3780	"
24	57436	155566	67977	.6938	.6849	"
25	55130	151269	95265	1.000	1.000	"
23	56417	153924	55937	.57704	.5738	"
21	57989	156981	32624	.3300	.3256	"
19	59771	157554	21081	.2125	.2041	"
17	59621	157660	73620	.1379	.1329	21.095
15	59867	158228	10163	.1020	.098	"
13	60313	159198	5040	.0503	.0484	"
11	60605	159023	3191	.0319	.0305	"
9	61644	150850	2533	.0266	.0238	"

Instrument Check on 4-6-67 Source 10mV

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Alarm Trip OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	Personnel OK
IC-3	Responds	Calibration	OK	Alarms OK
IC-4	Responds	Calibration	OK	Resp -0.05"
GBM		Meter Trip		

Expt. 28 Repeat # 27

k &gt; 1 tad 21.695 solution 30.785

k = 1 21.11 30.782

10<sup>10</sup> AM Shut Down K-1 tad 21.095 Soln Ht 30.782Least square fit of data to  $e^{-\lambda d}$ Expt. 27  $\gamma = 0.2397 \pm .0025$ 28  $\gamma = 0.2337 \pm .0022$

4-10-67

Begin filling tin cans.

	Cylinder No.	Tare wt. kg	Gross kg	Net kg solution	Weight	
					23.96 <sup>5</sup>	
	4/10	1	.324	6.644	6.320	
	4/10	2	.323	6.643	6.320	21.11 <sup>5</sup>
	4/12	3	.324	6.644	6.320	
	4/12	4	.323 <sup>5</sup>	6.643 <sup>5</sup>	6.320	18.32 <sup>5</sup>
	4/12	5	.324	6.644	6.320	
	4/12	6	.325	6.645	6.320	15.50 <sup>5</sup>
	4/13	7	.325	6.645	6.320	<del>24.64</del>
	4/13	8	.323	6.643	6.320	<del>23.90</del>
	4/13	9	.323	6.643	6.320	22.50
	4/14	10	.324	6.644	6.320	0-22.20
	4/14	11	.325	6.645	6.320	19.45
	4/14	12	.324	6.644	6.320	
	4/14	13	.325	6.645	6.320	16.66
	4/28	14	.325	6.644	6.319	<del>15.645</del>
	"	15	.323	6.644	6.321	
	"	16	.324	6.644	6.320	
	"	17	.324	6.644	6.320	
	"	18	.324	6.644	6.320	10.068
	"	19	.324	6.644	6.320	
	"	20	.326	6.646	6.320	
	"	21	.327	6.647	6.320	
	"	22	.324	6.644	6.320	

Cyl. No.	tare wt. kg	Gross wt kg	net wt. kg Soln.	Soln gm
5-1-67 23	.326	6.644	6.318	8.585 3.281
24	.323	6.643	6.320	
25	.324	6.644	6.320	
26	.322	6.642	6.320	
27	.323	6.643	6.320	3.162

Determination of Volume occupied by glass


Vol drained	Δht (in)	Δht (cm)	<sup>cyl.</sup> ΔVol (L)	% Glass $\frac{\Delta Vol - Vol\ drained}{\Delta V} \times 100$	wt
8.8	2.85	7.239	14.673	40.027	wt
8.8	2.79	7.087	14.365	38.738	2
8.8	2.82	7.163	14.519	39.389	2
8.8	2.74	6.960	14.107	37.620	2
4.4	1.39	3.531	7.157	38.517	1
8.8	2.75	6.985	14.159	37.846	2
8.8	2.79	7.087	14.365	38.738	2
17.6	5.577	14.166	28.714	38.705	4
22.0	6.787	17.239	34.943	37.041	5
17.6	5.433	13.880	27.972	37.080	4

weighted Ave 37.980

Ave 38.186

In filling cans 1 and 2 selym changed from  
23.965" to 21.125"  $\Rightarrow$  7.214 cm  $\Rightarrow$  14.622 liters

Exp. 30





Instrument Check on 7-10-67 Source 10mcP

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Personnel OK
IC-3	Responds	Calibration	OK	Alarms OK
IC-4	Responds	Calibration	OK	Press. - 0.05"
CRM		Meter Trip		


Exps. 29 Explore safety of handling 2 units  
 Unit 1 on fixed table #2 on moveable table.  
 $R \ll 1$  at contact (units) no apparent instrument <sup>level</sup> change.

Exps. 30 Same as 29 but with a reflector wall.  
 $R \ll 1$  at unit contact - same result as 29


/// 4-12-67

Flooded unit in the west end area.  
 Estimated multiplication 2 or 3. JT

Expt. 31



Expt. 32



Instrument Check on 4-12-67 Source 10mcX

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Personnel <input checked="" type="checkbox"/>
IC-3	Responds	Calibration	JA	Alarms <input checked="" type="checkbox"/>
IC-4	Responds	Calibration	JA	Press - 0.05"
CRM		Meter Trip		


Expt. 31 Examine condition with 4 curs, 2 on each stringer; 7" spacer between Al. support plates. Units in a plane with zero separation at table closure.  
 $R \ll 1$  Very little multiplication  $\sim 1.05$

Expt. 32 Add reflector to east face, 16" x 30" x 6"  
 $R \ll 1$  Slightly greater multiplication than Expt. 31  $K \sim 1.12$

$$\text{Cell vol.} = (7.22 + 2.282)(7.22 + 0)(7.564) \times 16.387 = 8.50 \text{ litres}$$

$$\text{mass } u = \sim 340 \frac{\text{g}}{\text{cc}} \times 4.4 \text{ l.} = 1.495 \text{ kg } u$$

$$\bar{\rho} = 0.176 \text{ g/cc}$$



Instrument Check on 4-13-67 Source 10mcX

PM-1	<u>                    </u>	Low Trip	<u>OK</u>	Alarm Trip	<u>OK</u>
PM-2	<u>                    </u>			Alarm Trip	<u>                    </u>
IC-1	<u><math>&gt; 3 \times 10^{-4}</math></u>	Meter Trip	<u>OK</u>	Fast Trip	<u>OK</u>
IC-2	<u><math>&gt; 3 \times 10^{-4}</math></u>	Meter Trip	<u>OK</u>		<u>Personnel <math>\checkmark</math></u>
IC-3	<u>Responds</u>	Calibration	<u>JA</u>		<u>Alarms <math>\checkmark</math></u>
IC-4	<u>Responds</u>	Calibration	<u>JA</u>		<u>Pres. - 0.05"</u>
CRM	<u>                    </u>	Meter Trip	<u>                    </u>		<u>                    </u>

Expr. 33 Eight units - unreflected - spaced 7.564" vertically  
 between bases, 2.9/32" E-W and variable to contact N.S.  
 R < 1 at table closure H < 2.

Instrument Check on 4-17-67 Source 10mcX


PM-1	<u>                    </u>	Low Trip	<u>OK</u>	Alarm Trip	<u>OK</u>
PM-2	<u>                    </u>			Alarm Trip	<u>                    </u>
IC-1	<u><math>&gt; 3 \times 10^{-4}</math></u>	Meter Trip	<u>OK</u>	Fast Trip	<u>OK</u>
IC-2	<u><math>&gt; 3 \times 10^{-4}</math></u>	Meter Trip	<u>OK</u>		<u>Personnel <math>\checkmark</math></u>
IC-3	<u>Responds</u>	Calibration	<u>JA</u>		<u>Alarms <math>\checkmark</math></u>
IC-4	<u>Responds</u>	Calibration	<u>JA</u>		<u>Pres. - 0.05"</u>
CRM	<u>                    </u>	Meter Trip	<u>                    </u>		<u>                    </u>

\* No trips on B  
 but responds.


Expr. 34 same as 33 but spacing now  
 NS - 1.27/64 EW 1.23/64 Vertical 7.31"  
 R < 1 at table closure H < 2

Exps. 35-37

Unit Arrangement &amp; Spacing:



$\delta_3$  = vertical sep. between  
containers  
solution surfaces



solution is  $\approx 0.156$ " lower  
 $\begin{array}{r} + 0.9375 \\ \hline 0.24975 \end{array}$

# 36, 37

$$\delta_3 = 7.407 - 6.9575 = 0.4495$$

Summary of Spacings for  $k = 1$ 

Exps.	$\delta_1$	$\delta_2$	$\delta_3$	$\delta_3$ (solution)
35	0.75	1.222	0.3555	0.60525
36	0.8125	1.0025	0.4925	0.6990
37	0.9375	0.9925	0.4495	0.6990

To find vertical separation equal to horizontal

take  $\delta_3 + 0.24975 = \delta_1$  or  $\delta_2$

Instrument Check on 4/18/67 Source 10 meV

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Personnel <input checked="" type="checkbox"/>
IC-3	Responds	Calibration	OK	Alarms OK
IC-4	Responds	Calibration	OK	Press - 0.05"
CRM		Meter Trip		

Expt. 35. Eight, unreflected, array spacing:

$$N.S. = E.W. = 3/4"$$

Vertical Separation of Bases  $7\frac{1}{4} + .063"$

$$R=1 \quad @ \quad 7.95 \text{ rows. } (0.472")$$

Expt. 36 Same unit arrangement - unreflected

$$N.S. = E.W. = 13/16"$$

Vertical Separation of bases  $7.407"$

$$R=1 \quad @ \quad 5.42 \text{ rows } (0.290")$$

Expt. 37 Same

N.S. variable with table closure  $+ 13/16"$

$$E.W. = 15/16"$$

Vertical base separation  $7.407"$

$$R=1 \quad @ \quad 3.70 \text{ rows. } (0.180")$$

Spacing  $\delta_1 =$  East West Horizontal Surface sep.

$\delta_2 =$  North South " Surface sep

$\delta_3 =$  Vertical Surface sep.

$6.958'' + \delta_3 =$  base separation



Instrument Check on 4-19-67 Source 10 mc $\gamma$ 

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			<del>Low Trip</del>	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$		OK	Personnel $\checkmark$
IC-3	Responds	Calibration	OK	Alarm $\checkmark$
IC-4	Responds	Calibration	JH	Press - 0.05"
CRM		Meter Trip		

Exp. 38 Eight unreflected Units

Separation  $\delta_1 = 0.828 = \delta_2$  at closurebase Separation = 7.532" ( $7\frac{15}{32}$  + .063 plate) $\delta_3 = .574$  (+.025 ~ 0.824")

$\$3.73/\text{in}$   
 $\$1.97/\text{cm}$

 $R > 1$  at table closure11.65 div/sec  $\Rightarrow$  253.1 sec  $\Rightarrow$  ~ 5.6  $\phi$  $R = 1$  at 0.68 revs  $\Rightarrow$  .015"

$(3, 2)$  $(1, 4)$  $(7, 6)$  $(8, 5)$

Instrument Check on 4-20-67 Source 10 mcd

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		Personnel
IC-3	Responds	Calibration	JA		Alucos
IC-4	Responds	Calibration	JA		Press - 0.05"
CRM		Meter Trip			

Exp. 39 Eight unit array reflected by 6" Polyethylene Reflector, minus top, in place. Have put units 1, 4, 7, 8, 2 + 3 in position. Checking safety of completing assembly.

$$\delta_1 = \delta_2 = 3^{21/32} \quad \delta_3 = 3.231 \quad \text{see p 50.}$$

$k < 1$  No change in instrument levels.

All units positioned + top reflector in place.

$k = 1$  at 36.46 revs. (4.352")

(2,3)

(1,4)

(7.6)

(5.8)

$$\text{Cell Vol} = \frac{4}{3}\pi (7.2 + 4.094) = 11.394 \text{ m}^3$$

$$\delta_2 = 11.394$$

$$\delta_3 = 10.75 + .063 = 10.813$$

$$m \sim 1.5 \text{ kg}$$

$$\text{Vol} = (11.394)^2 (10.813) (2.54)^3 = 22.6818 \text{ L}$$

$$\bar{\rho} = .0666 \text{ g/cc}$$

Instrument Check on 4-21-67 Source 10mc

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Personnel
IC-3	Responds	Calibration	JA	Alarms ✓
IC-4	Responds	Calibration	JA	Press -0.05"
CRM		Meter Trip		

Expt. 40 ~~Reflected~~ array of eight units. ↓

Refl. thickness 15.24 cm Polyethylene.

Horizontal Spacing  $\delta_1 = \delta_2 = 4^{3/32}$  4.094

Vertical  $\delta_3 = 10.75 + .063 - 6.958 = 3.855''$  ( $+ .25 = 4.105''$ )


$R=1$  at 29.5' revs.

$R > 1$  at 29.3 revs.  $3.53 \frac{\text{rev}}{\text{sec}} \Rightarrow 76.7 \text{ sec} \Rightarrow 214.5 \text{ ft}$

$R=1$  at 29.5° revs. (3.055")

$\frac{2.90}{\text{cm}}$

4/21/67



Instrument Check on 4-21-67 Source 10mc

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	Personnel <input checked="" type="checkbox"/>
IC-3	Responds	Calibration	JA	Alarms <input checked="" type="checkbox"/>
IC-4	Responds	Calibration	JA	Press -0.07"
CRM		Meter Trip		

Expt. 41 Eight units Reflected by 6" thick Polyethylene  
 $\delta_1 = 5^{13/64}$        $\delta_2$  variable to  $5^{13/64}$  at closure  
 $\delta_3 = 11^{27/64} - 6.958$

$\$3.53/in$        $k > 1$  at 9.2 revs.      (0.5715")      4.525 div/sec  $\Rightarrow$  98.3 sec  $\sim 124$   
 $k = 1$  at 9.61 revs.      (0.6055")       $A = .034"$

Expt. 42. Vertical spacing not correct in Expt. 41  
 should have been  $11^{27/32}$ .

Have raised top tier of units by  $3/8"$  and top  
 reflector  $1/2"$

$\$2.87/in$        $k > 1$  at 5.2 revs      (0.276")      6.47 div/sec  $\Rightarrow$  140.6 sec  $\sim 8.64$   
 $k = 1$  at 5.67 revs      (0.306")       $A = .030"$

Instrument Check on 4/25/67 Source 10mc $\gamma$ 

FM-1	Low Trip	Alarm Trip	OK
FM-2		Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK
IC-3	Responds	Calibration	JH
IC-4	Responds	Calibration	JH
CRM	Meter Trip		

Fast Trip OK  
Personnel  $\checkmark$  e.  
Alarms  $\checkmark$   
Press. - 0.06"

Expt. 43

Eight Units - 6" Polyethylene Reflector.

$$S_1 = 5 \frac{3}{8}'' \quad S_2 \rightarrow 5 \frac{3}{8}'' \text{ at closure.}$$

$$S_3 = 12.063 - 6.958 = 5.105$$

R < 1 crack at top of reflector  $\approx \frac{1}{2}''$ 

Adjust top reflector tray again.

R < 1 M  $\approx$  2




5/1/67 Have put Bottles #22 & 24 into the system

# 22 2.732 RgU

# 24 2.727 RgU

Total 46.987 RgU



Sample #2

Net wt. soln 29.67 g

Result SF. A 2161

isotope analysis

U<sup>233</sup> 97.56

U<sup>234</sup> 1.053

U<sup>235</sup> 0.025

U<sup>236</sup> 20.0005

U<sup>238</sup> 1.341

353.2 mg/ml coulometric as U<sup>238</sup>  $\bar{U} = 233.06$

4% g. 1.4750

345 meq/ml

Instrument Check on 5-1-67 Source  $^{10}\text{mcl}$ 

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	Personnel
IC-3	Responds	Calibration	OK	Alarms ✓
IC-4	Responds	Calibration	OK	Pres. $-0.06^\circ$
CRM		Meter Trip		

Expt. 44 Safety check on loading 18 units on fixed table. Have 9 on moveable table & 9 on fixed table.

Multiplication  $\sim 1\frac{1}{2}$  on table closure.

$\therefore$  safe to load remaining 9 units on <sup>fixed</sup> table

Expt. 45 Load remaining 9 units

$R > 1$  at 20.9 revs. (1.72")  $11.35 \frac{\text{cm}}{\text{sec}} \Rightarrow T = 246.6 \Rightarrow \rho = +5.84$

$R = 1$  at 20.88 revs. (1.74")

Spacing for expt. 44 & 45

$$s_1 = s_2 = 2^{21/32}$$


$$\text{base separation} = 9.423''$$

$$s_3 = 9.423 - 6.958 = 2.465''$$

Cell volume = 14.995 liters


$$\bar{c} = \frac{1.5}{14.995} = .10003 \text{ g/cc}$$

Unit locations.



4432 kg/8 unit 5/2/67 Expt. 46  
27 units unreflected

0233



O  
F  
F  
I  
C  
E

Instrument Check on 5-2-67 Source 10mc

PM-1	Low Trip	OK	High Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	Personnel $\checkmark$
IC-3	Responds	Calibration	JH	Alarms $\checkmark$
IC-4	Responds	Calibration	JH	Press. -0.06"
CRM		Meter Trip		

Expt. #6 27 Unreflected units

$$S_1 = S_2 = 2^{29/32} \quad \text{Error repetition } 9.673''$$

$k > 1$  at closure but not above source level.

$k \leq 1$  at closure after raising neutron level with source.

Natural source in system makes establishment of critical difficult. Negative period after source withdrawal  $\sim 2200$  sec - is a small fraction of a cent from  $k=1$ .

$$\text{Cell volume} = 16.1898^3 \text{ l.} \quad \Rightarrow \quad c = \frac{1.5}{16.1898^3} = 0.09265 \text{ g/l.}$$

Instrument Check on 5-3-67 Source 10mc

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	Personnel	✓
IC-3	Response	Calibration	JN	Alarm	✓
IC-4	Response	Calibration	JN	Loss	-0.06"
CRM		Meter Trip			

Expt. 47 Repeat Expt. 46 without source.

$R \approx 1$  at table closure.

Raise neutron level by inserting source.

$R \approx 1$  slight rise in neutron level when source is removed.

Estimate system to be supercritical by a small fraction of a cent. Do not want to run at level necessary to override source in system and measure degree supercritical.

Exps. 48-49

The spacing for these expts is  $\approx$  the stacked density is 92.6% of that estimated by  $K(x)$  vs  $\bar{p}$  plot. The  $N=8$  line on the plot does not emanate from the origin, as assumed, therefore the correction for the estimated density in the reflected array was not applicable.

Necessary to restate to array to original estimate.

Loading for expts. 48+49

79	20	25
12	14	11
23	8	16
26	5	12
13	10	3
26	1	22
21	4	18
27	9	27
24	15	8

Instrument Check on 5-5-67 Source 10mc

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			<del>Alarm Trip</del>	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Personnel $\checkmark$
IC-3	Responds	Calibration	OK	Alarms $\checkmark$
IC-4	Responds	Calibration	OK	Press. - 0.06"
CRM		Meter Trip		

Expt. 48 Reflected (6" polyethylene) 22 unit array.

$$s_1 = s_2 = 5.875'' \quad \text{base separation } 15.583''$$

$R < 1$  at closure. Spacing between moveable plane of units and fixed plane is not correct.

Expt. 44

have moved fixed structure forward  $\frac{3}{16}''$ .


$R < 1$  High multiplication but subcritical.

Cell volume = 66.079 liters


$$\bar{\rho} \approx \frac{1.5}{66.079} = .0227 \text{ g/cc}$$



Loading for expe. 50



Loading for Expe. 51



Instrument Check on 5-8-67 Source 10 meV

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Personnel $\checkmark$
IC-3	Respondo	Calibration	JW	Alarms $\checkmark$
IC-4	Respondo	Calibration	JW	Preso - 0.06"
CRM		Meter Trip		

Expr. 50 27 units reflected by 6" polyethylene.  
 $S_1 = S_2 = 8.483''$  distance between bases  $15.191''$   
 $k > 1$  at 16.6 revs (1.30")  $3.95 \text{ dis/sec} \Rightarrow T = 85.8 \text{ sec} \Rightarrow \rho \sim 13.24$   
 $k = 1$  at 17.15 revs (1.370)  $\sim 1.90 \text{ \$/in}$

Expr. 51

Increased spacing in three directions by  $3/16''$   
 $k > 1$  7.89 revs. (0.470")  $4.0 \text{ dis/sec} \Rightarrow T = 86.92 \text{ sec} \Rightarrow \rho \sim 13.14$   
 $k = 1$  at 8.81 revs. (0.540")  $\sim 1.87 \text{ \$/in}$

$$\text{Vol} = 63.51097 \text{ L.} \Rightarrow \bar{\rho} = \frac{1.5}{63.5} = .02361$$

Instrument Check on 5/9/67 Source 10 mcr

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Personnel ✓
IC-3	Responds	Calibration	5H	Alarms ✓
IC-4	Responds	Calibration	5H	Press. -0.06"
CRM		Meter Trip		

Expt. 52 Repeat Expt. 51

$R > 1$  at 7.89 revs. (0.470") 4.925  $\frac{\text{div}}{\text{sec}} \Rightarrow T = 107.02 \text{ sec} \Rightarrow \rho \sim 11\%$   
 $R = 1$  at 8.70 revs. (0.531) 1.80  $\$/\text{in}$

Expt. 53 Purpose: evaluate effect of Aluminium shelves.  
 Have placed sheets of alum.  $\frac{1}{16}$ " thick (39x30) and  
 (39x15) on top of cans in 1<sup>st</sup> and 2<sup>nd</sup> tiers.

$R > 1$  at 8.30 revs. <sup>(0.500)</sup> 2.1  $\frac{\text{div}}{\text{sec}}$ .  $T = 45.63 \text{ sec} \Rightarrow \rho \sim 20, 2\%$   
 $R = 1$  at 9.65 revs. <sup>(0.609)</sup> 1.85  $\$/\text{in}$

Expt. 54 Same as 53. Have removed al. sheets  
 from 1<sup>st</sup> tier. Now have sheet resting on 2<sup>nd</sup> tier.  
 $R > 1$  at 8.30 revs. <sup>(.500)</sup> 3.525  $\frac{\text{div}}{\text{sec}} \Rightarrow T = 76.6 \text{ sec} \Rightarrow \rho \sim 14.5\%$   
 $R = 1$  at 9.30 revs. <sup>(.580)</sup> 1.81  $\$/\text{sec}$ .

5/16/67

Have removed ruckling rings and loaded cylinder with 23" of  $5/8 \times 5/8$  rings from K-25.

## Counting Data for Expt. 55

BF <sub>3</sub> Position (in)	C <sub>1</sub> c/m × 10 <sup>1</sup>	C <sub>2</sub> c/m × 10 <sup>1</sup>	C <sub>4</sub> c/m × 10 <sup>1</sup>	T <sub>AD</sub> (in)	Norm to C <sub>1</sub> at 23"
3	24575	76523	647	24.66	.00758
5	24804	77239	1101		.01278
7	24932	78028	1723		.0199
9	24869	77300	2501		.0289
11	25224	78289	3723		.0425
13	25422	79081	5848		.0662
15	25019	78219	9018	24.64	.1038
17	24760	77385	14606		.1698
19	23587	73914	21661	24.66 <sup>5</sup>	.2644
21	23622	74063	33658		.4102
23	22968	72131	79787	24.72	1 -
25	24470	76617	39206	24.71 <sup>5</sup>	.4612
26	24229	75595	12443	24.69	.1478
24	23994	74528	71014		.8520
22	24719	76982	65995	24.71	.7685
20	25229	79122	26128	24.71 <sup>8</sup>	.2981
18	25347	79069	18004	24.68	.2045
16	25363	78761	4702		.1328
14	25161	78572	7629	24.65 <sup>5</sup>	.0873
12	25497	78958	4736	24.66	.0535

Instrument Check on 5-16-67 Source 10mc

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	Personnel
IC-3	Responds	Calibration	JH	Alarms
IC-4	Responds	Calibration	JH	Press
CRM		Meter Trip		

Expt. 55 Check for criticality when 14 cans in system.

ht. with 7 containers in system 7.42"

" " 14 " " " 16.97"

$k \ll 1$  No multiplication observed.

Loaded 7 more cans into system now 21.

$k \ll 1$  No observable multiplication.

Soln ht with 21 cans in system is 24.14

Expt. 52 Loaded remaining 6 cans into system.

IC-2	$5 \times 10^{-10}$	$k \approx 1$	Tad at 24.82"	Solution 26.67
IC-3	.55	$k > 1$	Tad at 25.09	26.67 <sup>5</sup>
IC-4	0.9	$k = 1$	24.66	26.67

Make traverse with BF-3 counter.

Pos.	$C_1$	$C_2$	$C_3$	Tad	Norm to C <sub>1</sub>
10	25500	75203	3006	24.66	.0339
8	26017	74895	2172	↓	.0240
6	26425	75670	1599		.0174
4	26335	75418	801		.00896
2	26663	76442	564		.00609

↑ Note decrease from 18" to 2" while  $C_1$  increased in accord with IC-2

Bkg on  $C_4$  at 10" is 120 c/m

BF <sub>3</sub> Position (in)	$C_1$ c/m × 10 <sup>-1</sup>	$C_2$ c/m × 10 <sup>-1</sup>	$C_4$ c/m × 10 <sup>-1</sup>	$t_{CD}$ (in)	Norm to $C_4$ at 23°
2	55420	163912	1210	24.42	.00691
4	56417	165903	1779	"	.00928
6	57114	167540	3596	"	.01993
8	56546	166481	4897	24.40'	.02741
10	57140	167918	6846	"	.03793
12	56802	165629	10762	"	.05997
14	57326	168194	17809	24.41	.09834
16	58413	169616	27235	"	.14759
18	58279	169708	41656	"	.22626
20	57910	168986	59485	"	.32517
22	55216	162159	140011	24.43	.827
24	55470	163697	154994	24.46'	.845
26	58724	161060	29802	"	.16065
25	59865	172833	88764	24.46	.46937
23	61560	177694	194466	"	1. —
21	63002	183438	86213	24.42 <sup>s</sup>	.43318
19	65481	188189	57925	24.42	.28027
17	67364	193604	38730	24.41	.18200
15	68914	197340	24265	24.40	.11146
13	70534	200831	15936	24.39'	.07152
11	70797	200745	10349	24.389	.04628
9	71385	202342	7100	24.385	.03148
7	70818	201182	4717	24.375	.02108
5	72790	205227	3156	24.352	.01372
3	74983	210538	1952	"	.00824
1	76347	213457	1253	24.38	.00519
0	75203	213101	815	"	.00341

~30% glass

Instrument Check on 5-17-67 Source 10mc8

PM-1	Low Trip	Alarm Trip	OK
PM-2		Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK
IC-3	Responds	Calibration	JH
IC-4	Responds	Calibration	JH
CRM		Meter Trip	

Exp. 57 Repeat Exp. 56 Make traverse along axis

	$k > 1$	rad	$24.68^5$	Solution	$26.63$
8 <sup>48</sup> AM	$k = 1$		24.42		$26.63$
9 <sup>35</sup>	shut down		24.38		$26.64^8$

Result of least square fit to  $q = q_0 e^{-\gamma d}$

Exp. 56:  $\gamma = 0.2172 \pm .0096 \text{ in}^{-1}$

Exp. 55:  $\gamma = 0.2156 \pm .0099 \text{ in}^{-1}$

Drained and flushed system. Final rinse had  
~56 g/cc concentration.

All but ~32 g (at 92.5%<sup>233</sup>) returned to John Parrot.



Received from John Panot 26.085 kg U (25.440 kg <sup>233</sup>U)  
 Isotopic Analysis

Isotope	wt/%	sp. gr.	mg/ml
233	97.54		
234	1.047	1.2400	207.5
235	.026	1.2484	209.6
236	.001		
238	1.386	ave. 1.2442	208.6
232	6.47 ppm.		

Ave uranium concentration of solution is 208.6 g/l

as U<sup>238</sup>,

$$g^U/l = 208.6 \frac{233.08}{238.04} = 204.2 \frac{3}{8} g/l.$$

$$g^{233}U/l = 204.2 \times .9754 = 199.2 g/l.$$

Bottle No.	Gross wt g	tare wt. g	Net kg	Vol l.	Total w kg	<sup>233</sup> <sub>U</sub> kg	rad. reading m/hr.	
1	16.050	4.184	11.866	9.54	1.948	1.900	80	
2	16.250	4.159	12.091	9.72	1.985	1.936	60	
3	16.270	4.200	12.070	9.70	1.981	1.932	60	
4	16.500	4.369	12.131	9.75	1.991	1.942	60	
5	16.550	4.419	12.131	9.75	1.991	1.942	60	
6	16.090	4.060	12.030	9.67	1.975	1.926	55	
7	16.250	4.159	12.091	9.72	1.985	1.936	60	
8	15.900	3.994	11.906	9.57	1.954	1.906	65	
9	16.320	4.284	12.036	9.71	1.983	1.934	55	
10	16.200	4.209	11.991	9.64	1.969	1.920	55	
11	15.815	3.759	12.056	9.69	1.979	1.930	65	
12	16.310	4.309	12.001	9.65	1.971	1.922	65	
13	15.900	3.999	11.901	9.57	1.954	1.906	65	
14	6.500	3.750	2.550	2.05	.419	.408	40	
			total		158.896	127.73	26.035	25.440

6-13-67

Transferred bottles 8, 9, + 10 into system

Bottle	Vol. (L)	R <sub>g</sub> U		Total		
8	<del>9.52</del>	1.954				
9	9.71	1.983				
10	<u>9.64</u>	<u>1.969</u>	relays	V	M	
T	28.92	5.906	6.04"	28.92	5.906	

6-14-67

4	9.75	1.991				
7	9.72	1.985				
11	<u>9.69</u>	<u>1.929</u>				
	29.16	5.955	14.38"	58.08	11.861	
3	9.70	1.981				
12	9.65	1.921				
13	<u>9.57</u>	<u>1.954</u>				
	28.92	5.936	22.61	87.00	12.797	
1	9.54	1.948				
5	9.75	1.991				
6	<u>9.67</u>	<u>1.975</u>				
	28.96	5.914	—	115.96	23.711	

Instrument Check on 6-17-67 Source 10mc x

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2				
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Alarm Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Alarm <input checked="" type="checkbox"/>
IC-3	Responds	Calibration	JH	Personnel <input checked="" type="checkbox"/>
IC-4	Responds	Calibration	JH	Pres. - 0.06"
CRM		Meter Trip		

Expt. 58. Check criticality during loading.

System contains ~ 58 L. (Bottles 4, 7, 8, 9, 10 + 11)

$R < < 1$        $t_{\text{ad}} 38.86''$        $\text{selcym } 14.38''$

added Bottles 3, 12, + 13

$R < < 1$        $t_{\text{ad}} 38.86$        $\text{selcym } 22.61$

added Bottles 1, 5 + 6

2 PM

$R > 1$        $t_{\text{ad}} 23.98^5$        $\text{selcym. } 27.22^6$

$k = L$        $t_{\text{ad}} 23.39^5$        $27.22^5$

Make traverse IC4 at 1.0 on end.

Note: Traverse is made with counter parallel to axis but ~ 1" off axis.

6-14-67 Expt. 58 Transverse with C-4 located ~1" off  
axis of cylinder. 1-min counts.

Counter position from Bottom (in.)	Normalizing			Norm to <del>23</del> 23"	
	C-1	C-3	C-4		
1	33419	98606	142	146	.00073
2	34780	105977	171	168	.00084
3	33408	98526	235	240	.00119
4	34590	105439	311	308	.00153
5	33414	98388	408	418	.00208
6	33873	103368	541	547	.00272
7	33925	99501	712	719	.00357
8	33569	102606	901	919	.00457
9	34992	92840	1440	1409	.00700
10	32847	99256	1867	1946	.00967
11	32858	98560	2229	2323	.01155
12	32504	97923	3105	3271	.01626
13	32100	97122	4118	4393	.02184
14	32623	92851	5778	6065	.03015
15	32429	98004	7968	8414	.04183
16	32747	99032	10663	11151	.05543
17	32386	97970	15565	16458	.08181
18	31662	96865	20618	22300	.11085
19	32359	97801	27792	29412	.14621
20	31308	95153	41474	45364	.22550
21	30479	92551	82021	92156	.45811
22	31430	95888	163647	178304	.88635
23	34245	93194	201160	201160	1-

Position (in)	C-1 C/min.	C-3 C/min.	C-4 C/min.	C-4 Norm to 23"	
24	31442	96443	165238	179969	.89463
25	37832	114255	125315	113433	.56388
26	30609	93841	29720	33250	.16529
27	32124	98147	22869	24379	.12119

## Notes:

- ① Count rates recorded at value  $\times 10^{-1}$ .
- ② Traverse made from bottom of vessel beginning at 1" and increasing in increments of 2" to 27"; then returning to bottom from 26" in 2" increments.

$$\gamma = .3011 \pm .0034 \text{ in}^{-1}$$

6-15-67 Traverse. (See Notes p. 87)

C-4 Position (in) from bottom	C-1 (cm)	C-3 (cm)	C-4 (cm)	C-4 Norm to 23"
1	24930	78433	110	.00071
2	27136	79051	128	.00052
3	24253	76385	167	.00111
4	27262	78982	239	.00141
5	23736	74945	290	.00196
6	27070	78728	445	.00244
7	23643	74659	493	.00335
8	26815	78352	745	.00446
9	24323	76778	1012	.00668
10	27468	79530	1575	.00920
11	25187	78899	1747	.01113
12	27036	78805	2651	.01574
13	25363	79436	3256	.02060
14	26765	77814	4820	.02890
15	25516	79938	6471	.04069
16	26796	78161	8986	.05382
17	26357	82203	12821	.07807
18	26549	77473	17651	.10670
19	26467	88416	23118	.14016
20	25660	85402	34813	.21772
21	26083	<del>86450</del>	71809	.4418
22	24429	72176	132433	.86995
23	24957	73570	155501	1.0
24	—	—	—	—
25	25401	74705	88510	.55920

Instrument Check on 6-15-67 Source 10mcX

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			<del>Alarm Trip</del>		
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Personnel	✓
IC-3	Responds	Calibration	SJR	Alarms	✓
IC-4	Responds	Calibration	SJR	Pres.	-0.06"
CRM		Meter Trip			

Expt. 58 Repeat traverse.

9<sup>30</sup> AM.

k=1 tad 24.21" selyn 27.29"

10<sup>30</sup> AM

End traverse - put system on slightly negative

period to seek presence of source in solution.

Set tad on 24.1 IC-4<sup>at 1.0</sup> decreased on  $\frac{1}{8}$  sec period

and leveled off at .34

lowered tad to 23.2 system on 780 sec period.

and leveled off ~.02

lowered tad to 22.3 system showed step decrease

∴ definite inherent source is present.

$$\gamma = .3036 \pm .0033 \text{ in}^{-1}$$



## Fill Cans for Array Expt.

Can No.	Tare wt(kg)	Gross(kg)	Net(kg)	Can No.	Tare wt(kg)	Gross	Net
1	0.324	5.876	5.552	26	0.322	5.877	5.552
2	0.323	5.877	5.554	27	0.323	5.875	5.552
3	0.324	5.876	5.552				
4	0.323 <sup>s</sup>	5.877	5.554				
5	0.324	5.876	5.552				
6	0.325	5.878	5.553				
7	0.325	5.878	5.553				
8	0.323	5.875	5.552				
9	0.323	5.875	5.552				
10	<del>X</del> 0.324	5.865	5.541				
11	0.325	5.877	5.552				
12	0.324	5.876	5.552				
13	0.325	5.877	5.552				
14	0.325	5.877	5.552				
15	0.323	5.875	5.552				
16	0.324	5.876	5.552				
17	0.324	5.876	5.552				
18	0.324	5.876	5.552				
19	0.324	5.876	5.552				
20	0.326	5.876	5.552				
21	0.327	5.877	5.552				
22	0.324	5.877	5.553				
23	0.326	5.877	5.552				
24	0.323	5.875	5.552				
25	0.324	5.876	5.552				

2085 g/cc @ 1.28 sp.gr.

$$\Rightarrow \frac{2085}{1.28} = 1628 \text{ g/soln}$$

salt factor is 1.67

$$H = \frac{(1 - 1.67(1.628))}{.1628 \times .9754} \frac{233}{9}$$

$$= 118.7$$

JH

Sample taken during filling of the cans.

Control No. 16330 returned 7/3/67

(Sample No. 11)

208.1 gU/l (Colometric U<sup>233</sup>)

1.2804 sp. gr.

$$233 @ 97.54\% = 227.27$$

207.5 mg/ml

$$234 @ 1.047 = 2.45$$

209.6

ave sp. gr.

$$235 @ .026 = .061$$

208.1

⇒ ave 208.5 mg/ml.

$$236 @ .001 = .002$$

$$238 @ 1.356 = 3.30$$

$$\therefore \text{gU/l} = 208.5 \times \frac{233.08}{238.04} = 204.05$$

Total 233.08

$$\text{gU}^{233}/\text{l} = 204.05 \times 97.54 = 199.03$$

Ave. Volume of Solution per container

$$= \frac{5.552 \text{ kg soln}}{1.2804} = 4.336 \text{ liters.}$$

$$\text{kg U/container} = 0.88476 \sim 885 \text{ gms. U}$$

$$\cong 863 \text{ g U}^{233}$$

Average OD measurement on 8 cylinders is 7.19775" ⇒ 18.282 cm

∴ " ID (10 mil wall) is 7.17775" ⇒ 18.232 cm.

giving cylindrical area of 261.05 cm<sup>2</sup>


Measurement of height change over last 2 liters of

filling gave ave area of 261 cm<sup>2</sup>; good agreement.

$$\text{height of solution (neglecting ridges)} = \frac{4.336}{2.61} = 16.613 \text{ cm.}$$

6.5404"

Expt. 60



$$\text{Cell vol: } (18.282 + 2.095)^2 (19.05) = 7.9108 \text{ l.}$$

$$\bar{p} = \frac{885}{7.9108} = 111.87 \text{ g/cc}$$

Expt. 60 same arrangement, different spacing.

$$\text{Cell vol} = (18.282 + 1.4605)^2 (18.415) = 7.1775 \text{ l.}$$

$$\bar{p} = \frac{885}{7.1775} = 123.3 \text{ g/cc}$$

Instrument Check on 5-19-67 Source 10mcX

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Personnel $\checkmark$
IC-3	Responds	Calibration	JA	Alarms $\checkmark$
IC-4	Responds	Calibration	JA	Press - 0.06"
CRM		Meter Trip		

Expt. 60 purpose: check criticality of eight unreflected units.  
 $\delta_1 = \delta_2 = 2.0458''$   $19.05''$  between bases.  
 $k < 1$   $M \approx 2$  at table down.

Instrument Check on 5-20-67 Source 10mcX

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Personnel
IC-3	Responds	Calibration	JA	Alarms $\checkmark$
IC-4	Responds	Calibration	JA	Press. - 0.06"
CRM		Meter Trip		

Expt. 60 Check criticality with  $\delta_1 = \delta_2 = 1.4605''$  and  $18.415''$  between bases.  
 $7.25''$  between bases.

$8.87 \frac{1}{\text{hr}}$   $k > 1$  at  $8.9 \text{ revs} \Rightarrow 0.547'' \approx 2.81 \frac{\text{rev}}{\text{sec}}$   $62.8 \text{ sec} \approx 15.964$   
 $k = 1$  at  $9.12 \text{ revs} \Rightarrow 0.565''$

Expt. 62

same unit arrangement as 60.

$$\text{Cell Vol} = (18.282 + 1.4605)^2 (18.7325) = 7.3013 \text{ L.}$$

$$\bar{p} = 0.12121 \text{ g/cc}$$

Expt. 63

$$\text{cell vol} = (18.282 + 1.806)^2 (18.7325) = 7.5552 \text{ L.}$$

$$\bar{p} = 0.11717 \text{ g/cc}$$

Expt. 64

$$\text{Cell Vol} = (18.282 + 1.8771)^2 (18.89) = 7.6767 \text{ L.}$$

$$\bar{p} = 0.11528 \text{ g/cc}$$

Expt. 65

$$\text{Cell Vol} = (18.282 + 1.8771)^2 (18.8087) = 7.6437 \text{ L.}$$

$$\bar{p} = 0.11578 \text{ g/cc}$$

Expt. 62 check for criticality with spacing:  $\delta_1 = \delta_2 = 0.575$  <sup>1.4605 cm</sup>  
 distance between bases =  $7.375$  <sup>18.7325 cm</sup>

7.69  $\frac{1}{in}$   $R > 1$  at 6.4 revs  $\Rightarrow .357''$  5,563  $\frac{div}{sec}$ . 120.9 sec =  $\sim 104$

$R = 1$  at 6.58 revs  $\Rightarrow .370''$

Expt. 63 Reset spacing:  $\delta_1 = \delta_2 = 0.709$  <sup>1.8009 cm</sup> base separation =  $7.375''$  <sup>18.7325 cm</sup>

7.36  $\frac{1}{in}$   $R > 1$  at 2.7 Revs.  $\Rightarrow 0.118''$  7,133  $\frac{div}{sec}$ . 155 sec.  $\sim 8.14$

$R = 1$  at 2.89 Revs  $\Rightarrow 0.129''$

Expt. 64 Reset spacing  $\Rightarrow \delta_1 = \delta_2 = .739$  <sup>1.8771 cm</sup> base separation  $7.437$  <sup>18.8898 cm</sup>

$R < 1$   $M > 10$

Expt. 65 Reset spacing  $\Rightarrow \delta_1 = \delta_2 = .739$  <sup>1.87087 cm</sup> base separation  $7.405''$

4.54  $\frac{1}{in}$   $R > 1$  at closure 2.9  $\frac{div}{sec}$  63.02 sec.  $\sim 15.94$

$R = 1$  at 1.16 revs (.035'')

Σ pr. 66

$$\text{Cell Vol} = (18.282 + 12.954)^2 (32.005) = 29.276 \text{ l.}$$

$$\bar{p} = 0.03023 \text{ g/cc}$$

Σ pr. 67

$$\text{Cell Vol} = (18.282 + 11.684)^2 (29.243) = 26.2591 \text{ l.}$$

$$\bar{p} = 0.033703 \text{ g/cc}$$

Instrument Check on 6-21-67 Source 10mc $\gamma$ 

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			<del>Alarm Trip</del>	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Personnel $\checkmark$
IC-3	Responds	Calibration	JN	alarms $\checkmark$
IC-4	Responds	Calibration	JN	Pres. -0.08"
CRM		Meter Trip		

Expt. 66. Determine criticality of Eight units reflected  
by 15.24-cm-thickness of Polyethylene.

Spacing  $s_1 = s_2 = 5.10$ " <sup>12.954 cm.</sup> Separation of bases is 11.813" <sup>30.005 cm.</sup>

$R \ll 1$  Conclude reflector effect much less than  
for higher concentration.

Instrument Check on 6-22-67 Source 10mc $\gamma$ 

PM-1	Low Trip	OK	<del>Alarm Trip</del>	OK
PM-2			<del>Alarm Trip</del>	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Personnel $\checkmark$
IC-3	Responds	Calibration	JN	alarms $\checkmark$
IC-4	Responds	Calibration	JN	Pres. -0.08"
CRM		Meter Trip		

Expt. 67 Reset spacing  $s_1 = s_2 = 4.60$ " <sup>11.684 cm.</sup> bases separated  
<sup>29.243 cm.</sup>  
<sup>11.513"</sup>

$R < 1$  slight response.



Expt. 69      Cell Vol =  $(18.282 + 11.3716)^2 (28.4124) = 24.98405 \text{ l.}$   
 $\bar{\rho} = 0.03542 \text{ g/cc}$

Expt. 70      Cell Vol =  $(18.282 + 11.3716)^2 (28.730) = 25.2633 \text{ l.}$   
 $\bar{\rho} = .03503 \text{ g/cc}$

Expt. 71      same as 69       $\bar{\rho} = 0.0354$

Sensitivity to tubler separation for Expt. 71 same as for  
 Expts. 40 + 42  $\therefore$  Extrapolate to critical density of 0.0342  
 giving a cell volume of 25.877 l.

$\Rightarrow \delta_1 = \delta_2 = 11.946 \text{ cm}$  vertical sep of 28.508 cm.

Expr. 68 Have raised bottom tier  $4\frac{1}{4}"$

$R < 1$  slight multiplication  $\sim 1.4$

Instrument Check on 6-23-67 Source 10mc X

FM-1	Low Trip	OK	Alarm Trip	OK
FM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-4}$	Motor Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$		OK	Personnel <input checked="" type="checkbox"/>
IC-3	Responds		OK	Alarms <input checked="" type="checkbox"/>
IC-4	Responds		OK	Pres $-0.01"$
CRM	Motor Trip			

Expr. 69 Have reset spacing to  $\delta_1 = \delta_2 = 4.477$  <sup>11.3716 cm.</sup>

Separation of bases is  $11.186$  <sup>28.4124 cm.</sup>

$2.71 \frac{1}{\text{in}}$   $R > 1$  at 5.0 revs. ( $0.261"$ )  $2.58 \text{ div/sec. } T = 56.06 \text{ sec.} \sim 17.9 \text{ f}$   
 $R = 1$  at 6.0 revs. ( $0.327"$ )  
<sub>.066</sub>


Expr. 70 Have increased spacing vertically between units by  $4\frac{1}{8}"$  (i.e., have raised top tier closer to top reflector.) <sup>28.730</sup> All else same as expr. 69

$1.95 \frac{1}{\text{in}}$   $R > 1$  at 2.6 revs. ( $0.112"$ )  $1.12 \text{ div/sec. } T = 24.34 \text{ sec.} \sim 29 \text{ f}$   
 $R = 1$  at 5.0 revs. ( $0.261"$ )  
<sub>.149</sub>

Expr. 71 Checked spacing: found units 2, 3 + 6, 7 about  $\frac{1}{8}"$  too close - reset to original  $4.477"$ . Have removed  $\frac{1}{8}"$  strips from top tier.

$2.71 \frac{1}{\text{in}}$   $R > 1$  at 4.0 revs. ( $0.198"$ )  $1.56 \text{ div/sec. } T = 33.9 \text{ sec.} \sim 24.4 \text{ f}$   
 $R = 1$  at 5.4 revs. ( $0.288"$ )

Exp 7-2.  
Unit Arrangement



Instrument Check on 6-27-67 Source 10meV

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	Personnel ✓
IC-3	Responds	Calibration	JH	Alarms ✓
IC-4	Responds	Calibration	JH	Pres. - .09
CRM		Meter Trip		

Expr. 72 27 unreflected units  $\delta_1 = \delta_2 = 2.75$  <sup>2.796</sup> JH

Vertical sep. of bases ( $9\frac{13}{32} + .063$ )

$R \leq 1$  Multiplication  $\sim 5$

Instrument Check on 6-28-67 Source 10meV

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	Personnel ✓
IC-3	Responds	Calibration	JH	Alarms ✓
IC-4	Responds	Calibration	JH	Pres. - .01"
CRM		Meter Trip		

Expr. 73 27 unreflected units -  $\delta_1 = \delta_2 = 2.75$  <sup>2.796</sup> JH

Vertical sep. reduced by  $\frac{1}{32}$ " from expr. 72.

$R \leq 1$  Multiplication  $\sim 5^+$

In checking spacing have found  $\delta_1 = \delta_2 = 2.796$   
instead of intended 2.75.

$$\Sigma \text{ exp. 29} \quad \text{Cell Vol} = (18.282 + 6.731)^{25.013} (23.892) = 14.94803 \text{ l.}$$

$$\bar{\rho} = 0.059205 \text{ g/cc}$$

$\frac{1}{16}$   $\frac{1}{32}$  Expt. 74 Spacing reset to  $2.75 = \delta_1, \delta_2$   
Vertical sep. same as Expt. 73.

$$R < 1 \quad M \sim 5$$

$\frac{1}{8}$   $\frac{1}{16}$  Expt. 75 Spacing horizontally  $2.75'' = \delta_1 = \delta_2$   
Vertical separation of bases is  $9\frac{1}{32}''$ .

$$R < 1 \quad M \sim 6$$

$\frac{1}{4}$   $\frac{1}{8}$  Expt. 76  $\delta_1 = \delta_2 = 2.75$  Vertical sep.  $9\frac{1}{32}$

$$R < 1 \quad M \sim 6^+$$

Instrument Check on 8-29-67 Source 10 met

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Personnel	✓
IC-3	Responds	Calibration	OK	Alarms	✓
IC-4	Responds	Calibration	OK	Pres. - 0.1"	
CRM		Meter Trip			

$\frac{1}{4}$   $\frac{1}{8}$  Expt. 77 Reset to  $\delta_1 = \delta_2 = 2.65''$

Separation between bases  $9\frac{1}{32}''$

$\$3.19/\text{in}$   $R > 1$  at 3.2 revs. ( $0.148''$ )  $5.65 \frac{\text{div}}{\text{sec}} \Rightarrow T = 122.8 \text{ sec} \Rightarrow$   
 $R = 1$  at 3.6<sup>8</sup> revs. ( $0.179''$ )  $P = 9.9\%$   
 $4.031''$

$\frac{1}{8}$   $\frac{1}{16}$  Expt. 78  $\delta_1 = \delta_2 = 2.65''$  bases  $9\frac{13}{32}$  ( $9.40625$ )  
 $6.731 \text{ cm.}$   $23.892 \text{ cm.}$

$R > 1$  at closure.

$R = 1$  at 1.88 revs. ( $0.032''$ )

The period is not interpretable being a curved line on the LWD chart. The systems

$$\bar{p} = .05921$$

is probably supercritical. Will need to go to higher power to remove inherent source effects.

Expt. 29.

Have placed strip of Plexiglas  $\frac{1}{4}$ " thick by  $1\frac{1}{2}$ " wide and 16" long on top of units 17 and 26 with nylon rope to remove when neutron level is high enough to determine excess reactivity.

\$1.08/in

$k > 1$  at table closure  $27.8 \text{ div/sec}; T = 60 \pm 1 \text{ sec} \sim 2.74$

$k = 1$  at  $0.95 \text{ rev. (0.025")}$

$k_{eff} \sim 1.00004$



$$\text{Exp. 80} \quad \text{Cell Vol.} = (37.76218)^2 (30.4642) = 51.9973 \text{ l.}$$

$$\bar{p} = 0.01702 \text{ g/cc}$$

Instrument Check on 7-11-67 Source 10 mcd

PM-1		Low Trip	<u>not operable</u>	Alarm Trip	<u>ok</u>
PM-2				Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	<u>ok</u>	Fast Trip	<u>ok</u>
IC-2	$> 3 \times 10^{-11}$	Meter Trip	<u>ok</u>		<u>Personnel</u> ✓
IC-3	<u>Responds</u>	Calibration	<u>FN</u>		<u>Alarms</u> ✓
IC-4	<u>Responds</u>	Calibration	<u>FN</u>		<u>Pres. - 0.1"</u>
GM		Meter Trip			

Expt 80. 27 units Reflected by 6" thickness of  
 Polyethylene. Cell size  $h = 14.356''$   $36.4642 \text{ cm}$   $h_{\text{base}} = 14.867''$   $37.7622 \text{ cm}$   
 Reflector box base dimensions are slightly greater  
 than required: should be 44.6" square but is instead  
 $45 \frac{7}{8} \times 45 \frac{3}{16}$   $\times 43$ . This is imposed by tier structure  
 supporting the units. Room temp  $\sim 22^\circ \text{C}$ .

$k > 2$  at 6.4" reso (0.357") 3.41  $\text{ch}/\text{sec}$ ;  $T = 74.1 \text{ sec} \Rightarrow P \approx 14.9 \mu$

$k = 1$  at 7.7" reso (0.458")

$$V_R = 54.1126 \text{ L.}$$

$$\bar{p} = .016355$$

Instrument Check on 7-13-67 Source 10 meV

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	Personnel $\checkmark$
IC-3	Responds	Calibration	OK	Alarms $\checkmark$
IC-4	Responds	Calibration	OK	Pres - 0.1"
CRM		Meter Trip		

Expt. 81 Changed spacing of units; cell is now  
 $38.252$   
 $15.06$  in base  $\times$   $38.982$  height. Reflector

Box inside dimensions are  $45\frac{3}{8} \times 45\frac{3}{16} \times 43.625$ "

$k < 1$   $n \approx 2$

Expt. 82 Have inserted two aluminum sheets resting  
 on top of 1<sup>st</sup> and 2<sup>nd</sup> tiers  $2(39 \times 15)$  and  $2(39 \times 30)$ .  
 Sheets are  $\frac{1}{16}$ " thick.

$k < 1$  no apparent effect on array observable.


Expt. 83 Have removed all sheets and reduced  
 horizontal spacing between units from  $7\frac{7}{8}$  to  $7\frac{1}{16}$ ".

$k < 1$

Expt. 84 Have lowered tiers  $\frac{1}{16}$ " each so that  
 vertical dimension of cell is now  $44.50$ ". height of  
 reflector box is now  $43\frac{5}{16}$ ".

$k < 1$   $n \approx 2$

Exps. 85-92 Unit Arrangement



Exps. 85 Cell Vol =  $(37.8714)^2(36.576) = 52.459 \text{ l}$

$$\bar{p} = 0.01687 \text{ g/cc}$$

Comparison of sensitivity of separation with expro 50, 51  
and correction for aluminium shelves (expro 86, 87)  
extrapolate to critical density of 0.01664 g/cc  
corresponding cell size is  $(38.046 \text{ cm})^3$  by 36.744 cm

Have suffered a cool week: Temp today is 20.8°C in assembly room - Has been sufficient time for units to be at this as an equilibrium temp. JK 7/17/67

111

Instrument Check on 7-17-67 Source 10meδ

PM-1	Low Trip	out	Alarm Trip	O/C
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	Personal ✓
IC-3	Responds	Calibration	JH	Alarms ✓
IC-4	Responds	Calibration	JH	Preo - 0.1"
CRM		Meter Trip		

Expt. 85. Reset spacing: cell size now  $(14.91'')^2 \times 14.40'$

Reflector box  $45 \times 45 \times 43 \frac{3}{16}$ "

$1.23 \text{ } \$/\text{in}$   $k > 1$  at 3 revs. (0.133") 0.66 div/sec;  $T = 14.34 \text{ sec} \sim 32.5 \text{ f}$

$k = 1$  at 7.5 revs. (0.438")  
 $\left. \begin{array}{l} .305 \\ \text{---} \\ .11 \text{ cm} \end{array} \right\}$

Expt. 86 Have inserted the 2 aluminum sheets

over the tops of the cans in the 1<sup>st</sup> two tiers. (see Expt. 82)

$1.37 \text{ } \$/\text{in}$   $k > 1$  at 7.0 revs. (0.402") 2.90 div/sec.  $T = 63 \text{ sec} \sim 16.6$

$k = 1$  at 8.6 revs. (0.523")  
 $\left. \begin{array}{l} .121 \\ \text{---} \\ .045 \end{array} \right\}$

Expt. 87 Have removed aluminum sheet from top of

1<sup>st</sup> tier. Sheet remains on 2<sup>nd</sup> tier.

$1.40 \text{ } \$/\text{in}$   $k > 1$  at 7.0 revs. (0.402") 3.94 div/sec.  $T = 85.6 \text{ sec} \sim 13.3 \text{ f}$

$k = 1$  at 8.2<sup>7</sup> revs. (0.497")  
 $\left. \begin{array}{l} .045 \end{array} \right\}$

Expt. 88 Have removed aluminum sheet  $15 \times 39$ " from second tier on movable half.  $30 \times 39$ " sheet remains on 2<sup>nd</sup> tier of fixed half of array.

Expt. 88 Partial covering of cans in 2<sup>nd</sup> tier.

$k > 1$  2.0 revs (0.402") 4.95 div/sec.

$k = 1$  8.1 revs (0.484")  
0.082

Expt. 89 Have moved 30 x 39" sheet from top of 2<sup>nd</sup> tier  
cans to top of bottom reflector.

$k > 1$  7.0 revs (0.402") 15.55 div/sec.

$k = 1$  7.6 revs (0.451")  
0.049

Expt. 90 Removed aluminium. Inserted sheet of steel  
30 x 39" on top of 2<sup>nd</sup> tier on fixed half of array.

$k < 1$  at 7.0 revs. (0.402")

$k < 1$  at 0.0 revs. (0")  $M = 1.35$

Expt. 91 Moved Steel plate to top of surface of bottom refl.

$k < 1$  at 7.0 revs.

$k < 1$  at 0.

$M = 1.4$  more reactive than  
Expt. 20.

Expt. 92 Removed steel. Repeat Expt. 85.

$k > 1$  at 7.0 revs. (0.402")

15.7 div/sec.  
by only a few cents period bowed.

1.35  $\frac{1}{\mu\text{m}}$

$k > 1$  at 6.0 revs (0.328")

3.8 div/sec.  $T = 826 \text{ sec} \sim 13.7 \text{ t}$

$k = 1$  at 7.35 revs. (0.427")  
0.099

Instrument Check on 7-21-67 Source 10 mc

PM-1	Low Trip	out	Alarm Trip	ok
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Personnel $\checkmark$
IC-3	out	Calibration		Alarms $\checkmark$
IC-4	Resonance	Calibration	OK	Pres. - 0.0"
CRM		Meter Trip		

Selaya zero is 0.05"

Expt. 93 20" diameter aluminum cylinder with  $\frac{1}{2}$ " thick bottom. Check critical height of solution without reflector.

R	Tad	solution	Connected Soln	
>1	31.46	5.37'	5.321	2.38 div/sec; T=56.7 sec
=1	22.95	5.36"	5.312?	

Expt. 94 Have placed sheet of aluminum (20x20x $\frac{1}{16}$ ) adjacent to bottom of vessel.

>1	8.504	5.35°	5.30°	5.40 div/sec; T=112.3 sec
=1	8.23	5.34°	5.29°	

Expt. 95 Have placed sheet of aluminum (18x20x $\frac{1}{8}$ ) adjacent to bottom of vessel.

>1	9.61	5.33°	5.28°	4.325 div/sec; T=93.98 sec.
=1	9.25 <sup>5</sup>	5.33 <sup>4</sup>	-	

.355



Instrument Check on 7-24-67 Source 10mc

PM-1	Low Trip	<del>cont</del>	Alarm Trip	OK
PM-2			<del>Alarm Trip</del>	
IC-1	$> 3 \times 10^{-11}$	Motor Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-11}$	Motor Trip	OK	Personnel <input checked="" type="checkbox"/>
IC-3	<del>Dist</del>	Calibrator		Alarms <input checked="" type="checkbox"/>
IC-4	Responds	Calibrator	OK	Pres - 0.1"
CRM		Motor Trip		

Expt. 96 Repeat Expt. 95.  $1/8$ " thick al. sheet on bottom.

$k$	$T_{ad} \text{ (min)}$	Solution	$S_{lin} \text{ (cm)}$
$> 1$	$12.05^2$	$5.35^6$	$3.64 \text{ div/sec. } T = 79.1 \text{ sec.}$
$= 1$	$11.13^2$	$5.34^2$	

Expt. 97 Repeat Expt. 93 20" vessel.

$> 1$	6.59	$5.37^2$	$6.9 \text{ div/sec. } T = 149.9 \text{ sec}$
$= 1$	$6.33^5$ .255	$5.36^5$ .007	

Summary

7/24/67

Expt	Bottom Al. thickness	$kT \text{ (k=1)}$	
97	.500	5.365	6.9
94	.543	5.347	
96	.626	5.34^2	

0 extrapolate  $5.45^7$

7-24-67 Have installed 15" dia Aluminum cylinders  
of annular type (2" feed pipe on circumference).

System feed valve open 4 turns; Bypass open 2 turns.

Volume per unit length of Tub: 2" I.D.

$$\pi 1^2 \cdot 1 = 3.14159 \text{ in}^3/\text{in}$$

$$= 20.268 \text{ cm}^3/\text{cm}.$$

1" displacement of Tub causes  $(\frac{4}{15})^2$  in displacement  
of solution ht in 15" vessel.  $\approx .0178$ "  
 $\approx .0452 \text{ cm}.$

Expt. No.	Corrected Soln. ht <del>(in)</del>		$\Delta c / \Delta ht.$ %/cm.	$\Delta ht.$ (cm)
	(in)	(cm)		
98	5.975	15.18	11.07	.0131
99	5.985	15.23	10.37	.0176
100	5.960	15.14	10.0	.0130
101	5.940	15.09	10.14	.0140
102	5.951	15.12	9.76	.0210

7-24-67

Expt. 98 Check criticality of 15" dia aluminum cylinder unreflected.

Selayn Zero 0.015<sup>+</sup>

K	Tad (in)	Selayn (in)	
>1	7.68°	5.98'	3.52 dir/sec; T = 76.5 sec. ~ 14.5¢
=1	7.39 .290	5.98°	

Instrument Check on 7-25-67 Source 10mcY

PM-1	Low Trip	out	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	>3 x 10 <sup>-4</sup>	Water Trip	OK	Fast Trip	OK
IC-2	>3 x 10 <sup>-4</sup>	Water Trip	OK		Personnel ✓
IC-3	out	Calibration			Alarms ✓
IC-4	Responds	Calibration	OK		Pres. - 0.1"
CRM		Water Trip			

Expt. 99 repeat 98.

Room Temp. 24.2°C.

K	Tad (in)	Solution (kt, pm)	
>1	6.72	6.02 <sup>5</sup>	3.66 dir/sec; T = 79.5 sec. ~ 14.1¢
=1	6.42 .300	6.005 ?	

Expt. 100 Have placed sheet of aluminum 15 x 15 x 1/16 on bottom of vessel.

>1	6.80	5.98 <sup>5</sup> ?	3.83 dir/sec; T = 83.2 sec. ~ 13.6¢
=1	6.50 .300	5.97 <sup>5</sup>	

Expt. 101 Changed aluminum sheet to 15 x 15 x 1/8"

>1	7.13		solution in vent line - about.
>1	6.50 <sup>5</sup>	5.98 <sup>5</sup>	3.63 dir/sec; T = 78.9 sec. ~ 14.2¢
=1	6.19 <sup>5</sup> .310	5.95 <sup>5</sup>	

7/25/67

Have placed <sup>nominal 10" ID</sup> ~~7.5" ID~~ aluminum cylinder of  
annular type into service.

Radius of cyl. from Fox, Gilley, + Guin Calibration is

$$12.687 \text{ cm} = 4.975'' \quad \text{Area} = 508.29 \text{ cm}^2$$

.0247  $\frac{\text{mm}}{\text{in}}$

7/25/67

Expr. 102 Replaced  $15 \times 15 \times \frac{1}{16}$  aluminum sheet.

R	tad (in)	selagn (in)	
>1	6.35	$5.88^5$	2.06 div/dec.; T=44.8 sec. <span style="float: right;">20.54</span>
=1	$5.88^5$ #65	$5.96^6$	

Expr. 103 <sup>Nominal 10-</sup>  
~~7.5~~ in-ID annular cylinder unreflected -  
 zero is +.063"

>1	6.69	9.81	; 7.38 div/dec.
=1	6.43	9.79	

Expr. 104 Placed  $10 \times 10 \times \frac{1}{16}$  sheet of aluminum on bottom.

>1	6.67	$9.80^5$	3.23 div/dec.
=1	6.18	9.77	

Expr. 105 Placed  $10 \times 10 \times \frac{1}{8}$  sheet <sup>(al.)</sup> on bottom.

>1	6.90	$9.79^5$	2.40 div/dec.
=1	6.27 <sup>1</sup>	$9.76^0$	

8-8-67

8" Dia annular cyl.

Feed valve open 4 turns

By-pass valve open 2 $\frac{1}{2}$  turns.

With 15" head feed rate too slow ~1" in 2 min.

 $\therefore$  close by-pass  $\frac{1}{2}$  turn.at 33.4" solution height, head is sufficient to  
have negligible feed rate.

#107 Have added bottle 10 to system.

#108 " " " 8 " " .

Instrument Check on 8-8-67 Source 10mc $\delta$ 

PM-1		Low Trip	<u>out</u>	Alarm Trip	<u>OK</u>
PM-2				Alarm Trip	
IC-1	<u><math>&gt; 3 \times 10^{-4}</math></u>	Meter Trip	<u>OK</u>	Fast Trip	<u>OK</u>
IC-2	<u><math>&gt; 3 \times 10^{-4}</math></u>	Meter Trip	<u>OK</u>		<u>Personnel <math>\checkmark</math></u>
IC-3	<u>out</u>	Calibration			<u>Alarm <math>\checkmark</math></u>
IC-4	<u>Responds</u>	Calibration	<u>5U</u>		<u>Pres. - 0.1"</u>
CRM		Meter Trip			

Expt. 106 8" dia. annular type cyl. Unreflected.

Selwyn zero is 0.0"

Rm. Temp 23°C

k	Tab (in)	ht (in)
---	----------	---------

<1	39.28	40.538"	exhausted Solution Supply.
----	-------	---------	----------------------------

Expt 107 add 9.25 liters of solution.

<1	39.28	48.85	exhausted Solution Supply
----	-------	-------	---------------------------

Expt 108 add 9.25 liters of solution.

<1	39.28	58.22"	exhausted Solution Supply.
----	-------	--------	----------------------------

Instrument Check on 8-9-67 Source 10 mef

FM-1	Low Trip	<u>out</u>	Alarm Trip	<u>ok</u>
FM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	<u>ok</u>	Fast Trip <u>ok</u>
IC-2	$> 3 \times 10^{-11}$	Meter Trip	<u>ok</u>	Personnel <u>✓</u>
IC-3	<u>out</u>	Calibration		Alarms <u>✓</u>
IC-4	<u>Responds</u>	Calibration	<u>JH</u>	Pres. - 0.1"
CRM		Meter Trip		

Selsyn zero 0.02"

Expt. 109 Nominal 1 1/2-in-dia sphere. (in refl. tanks.)

K	$\tau_{ad}$	Solution (Corrected)	
$> 1$	4.35	9.19	6.975 $\text{dis/sec}$
$= 1$	4.24	9.18'	

Instrument Check on 8-10-67 Source 10 mef

PM-1	Low Trip	<u>out</u>	Alarm Trip	<u>ok</u>
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	<u>ok</u>	Fast Trip <u>ok</u>
IC-2	$> 3 \times 10^{-11}$	Meter Trip	<u>ok</u>	Personnel <u>✓</u>
IC-3	<u>out</u>	Calibration		Alarms <u>✓</u>
IC-4	<u>Responds</u>	Calibration	<u>JH</u>	Pres. - 0.1"
CRM		Meter Trip		

R.T. 23.1 °C

Have removed reflector tanks from sphere.

Expt. 110

K	$\tau_{ad}$	Solution (Corrected)	
$> 1$	8.70	9.20°	6.3125 $\text{dis/sec}$
$= 1$	8.52 <sup>5</sup>	9.18°	



8-10-67

Exp. 111

Drained 4 liters from system and  
added 2 liters of Demineralized water.  
Mix for 20 minutes.

Exp. 112

added 2 liters of Demineralized Water  
mix ~15 min.

Exp. 113

Drained 4 liters of intermediate  
concentration and added 2 liters of water.  
mix for ~25 min.

Exp. 114

added 2 liters of water - mix for 45 min.

Expt. 111

$R$	$T_{ad}$	Solution (corrected)
$> 1$	7.16	9.30 <sup>5</sup>

shut down.

Expt. 112

$> 1$	7.16	9.64
-------	------	------

Expt. 113

$> 1$	9.40	9.57	3 attempts - all same.
-------	------	------	------------------------

drain.

Expt. 114

$> 1$	8.69 <sup>5</sup>	9.7 <del>5</del>	2.61 $\frac{dw}{dt} =$
$= 1$	8.32'	9.67	

Expt. 116

Added 1 liter of water to system; mix 2 hrs.

Expt. 117

Drained 4.6 liters of solution.

added 4 liters of water; mix ~ 30 min.

Instrument Check on 5-11-67 Source 10 mcK

PM-1	Low Trip	out	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	Personnel ✓
IC-3	out	Calibration		Alarms ✓
IC-4	Responde	Calibration	JX	Pres. -0.1"
CRM		Meter Trip		

R.T. 22.95°C

Expr. 115 Repeat Expr. 114 have mixed for 40 min.

k	Tad	Solution (corrected)	
>1	7.47 <sup>5</sup>	9.76 <sup>5</sup>	2.6 div/dec.
=1	7.10 <sup>5</sup>	9.73 <sup>5</sup>	

Expr. 116

>1	7.65 <sup>4</sup>	9.85 <sup>5</sup>	6.525 div/dec.
=1	7.43 <sup>2</sup>	9.82 <sup>5</sup>	

Expr. 117

>1	14.08 <sup>5</sup>	10.32	1.3 div/dec.
=1	13.45 <sup>1</sup>	10.25 <sup>5</sup>	

need dilute with 2 liters more of H<sub>2</sub>O 8/15/67

Expt. 119

Drained ~2.2 liters of solution: add 2 liters  $H_2O$   
mix for 1 hr.

REQUISITION

684536

*Water sample 2  
taken 2/9/68*

REPORT TO

J. T. Thomas

BUILDING NO.

9213

PHONE NO.

35237

000000001	g U/g
	g Ay/g
	g D/g
	g H/g
	g Mo/g
	g P/g
	SPEC.
	ASSAY

<i>Paul</i>	REPT. BY
<i>2-13-63</i>	DATE
	DEPT.

*7*

Instrument Check on 8-18-67 Source Co<sup>60</sup>

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$>3 \times 10^{-11}$	Meter Trip	OK	Fast Trip OK
IC-2	$>3 \times 10^{-11}$	Meter Trip	OK	Personnel $\checkmark$
IC-3	Responds	Self-aligner	5H	alarms $\checkmark$
IC-4	Responds	Self-aligner	5H	Pres - 0.1"
CRM		Meter Trip		

Expt. 118 Repeat Expt 112. R. Temp. 22.6°C

accidental scan by IC-1: no change in  
recorders or meters just fast part of circuit trips.

Sensitivities on IC-1 reset by ERR.

R	T <sub>ad</sub>	Solution	(corrected for) +1.02
>1	7.70	10.18°	3.16 div/sec
=1	7.38 <sup>5</sup>	10.17°	

Expt. 119

>1	6.79	10.67	2.23 div/sec.
=1	6.33	10.63	



Have installed thermocouple inside sphere  $\approx 3\frac{1}{2}$  in.

#12 Sample of solution from Expts. 120-124 taken

4/6/67 141.6 mgU/m.l.  $^{238}\text{U}$  sp. gr. 1.1956 Free  $\text{H}^+$ , N 0.37

$$\text{gU/l} = 141.6 \times \frac{233.08}{238.04} = 138.65$$

$$\text{gU}^{233}/\text{l} = 138.65 \times 0.9754 = 135.24$$

$$\text{gU/g soln} = \frac{138.65}{1.1956} = 115.97$$

good

$$\text{H}^+ / 0.233 = \frac{1 - (1.67611597)}{1.1597 \times 0.9754} \times \frac{2.33}{9}$$

$$= 184.55$$

after Expt. 124 drained 2.2 liters of solution added  
2 liters of  $\text{H}_2\text{O}$  mixed from 1<sup>45</sup> PM to 3<sup>20</sup> PM

Instrument Check on 8-24-67 Source 10mcX

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	Personnel ✓
IC-3	Leopards	Calibration	FA	Alarms ✓
IC-4	Reopards	Calibration	FA	Pres. -0.1"
CRM		Meter Trip		

Expt. 120 Repeat 119.

	k	Tad	Solution Con.	Soln Temp °C	Rm: °C
	>1	3.19 <sup>5</sup>	10.45	22.6 <sup>5</sup>	22.5
8:45 AM	=1	2.78	10.39 <sup>8</sup>	22.6 <sup>5</sup>	22.5

$2.41 \text{ div/sec} \Rightarrow T = 56.72 \text{ sec.}$

Expt. 121 Circulate solution in Reservoir for 12 min. To raise temp.

	>1	2.97 <sup>5</sup>	10.45	24.2	
9:20	=1	2.77 <sup>5</sup>	10.42	24.25	

Expt. 122 Circulate solution for 30 min.

	>1	2.90	10.49	26.4	
9:53	=1	2.63 <sup>27</sup>	10.45	26.4	

$4.775 \text{ div/sec} \Rightarrow T = 103.76 \text{ sec.}$

Expt. 123

Circulate solution for 1 hr.

11:20	>1	2.69 <sup>4</sup>	10.53	29.5	
11:35	=1	2.31 <sup>27</sup>	10.49 <sup>5</sup>	29.5°	

Expt. 124 Circulated solution 1 hr.

12:37	>1	2.71 <sup>1</sup>	10.60 <sup>5</sup>	32.25	
	=1	2.28 <sup>451</sup>	10.55 <sup>5</sup>	32.25	

 $2.79 \text{ div/sec} \Rightarrow 60.63 \text{ sec.}$

Instrument Check on 8-25-67 Source 10 mc Y

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	Personnel $\checkmark$
IC-3	Responds	Calibration	ERR	Alarms $\checkmark$
IC-4	Responds	Calibration	ERR	Pres. - 0.1"
CRM		Meter Trip		

Expr. 125

Inside sphere = 24°C  
Rm Temp = 23.8°C

k	Tad	Solution (conc)	Soln Temp °C	
>1	5.26	10.82 <sup>5</sup>	24.2	6.375 div/sec $\Rightarrow T = 138.53$ sec.
$\frac{9.12}{A}$ =1	5.02 <sup>.24</sup>	10.78 <sup>5</sup>	24.2	

Expr. 126

Circulate solution 13 min. 918 to 930

>1	14.73	10.86	25.3	5.775 div/sec $\Rightarrow T = 125.49$ sec.
=1	14.51 <sup>could</sup>	10.80	25.3	

Expr. 127

Circulate solution 30 min. 955 to 1025

>1	0.69 <sup>.521</sup>	10.98	27.5	3.12 div/sec $\Rightarrow T = 67.80$ sec.
=1	0.17	10.88 <sup>5</sup>	27.5	

Expr. 128

Circulate 30 min. 1049/A to 1119/A

>1	3.93	11.59	29.37	2.54 div/sec $\Rightarrow T = 55.19$ sec.
>1	3.21 <sup>.72</sup>	11.02 <sup>5</sup>	29.37	3.44 div/sec $\Rightarrow T = 74.75$ sec.
=1	2.76 <sup>.45</sup>	10.94	29.37	

Exp. 129 Circulate solution 1 hr. 1<sup>12</sup> PM to 2<sup>13</sup> PM.

R	Tad (in)	Solution (con)	Temp. °C	
>1	8.00 <sup>5</sup>	14.60 <sup>5</sup>	30.5 <sup>5</sup>	7.267 div/dec ⇒ T = 157.81 sec
>1	3.53 <sup>6</sup>	11.00 <sup>5</sup>	30.5	22 div/dec ⇒ T = 478.06 sec.
=1	3.45	10.99 <sup>5</sup>	30.4	

Instrument Check on 9-1-67 Source 10meV

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2					
IC-1	> 3 × 10 <sup>-4</sup>	Meter Trip	OK	Alarm Trip	OK
IC-2	> 3 × 10 <sup>-4</sup>	Meter Trip	OK		Personnel ✓
IC-3	Response	Alarm	OK		Alarms ✓
IC-4	Response	Alarm	OK		Pres. -0.1"
CRM	Meter Trip				

Rm temp. ~~24.4°~~  
 22.5°C

Exp. 130

9 <sup>45</sup> A	k	Tad	Soln	Temp °C	
>1	4.76 <sup>2</sup>	10.75 <sup>1</sup>	22.6 <sup>54</sup>	22.6 <sup>54</sup> Stet	5.085 div/dec ⇒ T = 114.63 sec.
=1	4.48	10.69 <sup>5</sup>	22.6 <sup>5</sup>	22.6 <sup>5</sup>	

Exp. 131 Circulate solution 1 hr. 10<sup>30</sup> A to 11<sup>30</sup> A.

11 <sup>45</sup> A	>1	2.62	10.88	26.62	3.35 div/dec ⇒ T = 72.8 sec.
11 <sup>52</sup> A	=1	2.18	10.80 <sup>5</sup>	26.5	

Instrument Check on 9-11-67 Source Comet

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			<del>Alarm Trip</del>	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast TRIP OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	Personnel $\checkmark$
IC-3	Responds	Calibration	JH	Alarms $\checkmark$
IC-4	Responds	Calibration	JH	Pres.
CRM		Meter Trip		

Expt 132

Temp in sphere  $24.5^{\circ}\text{C}$ 

R	tad	Solution (con)	Temp.	
$> 1$	$8.01^5$	$10.68^5$	$23.3^{\circ}$	$3.1 \text{ div/sec} \Rightarrow T = 67.3 \text{ sec}$
$= 1$	$0.81^5$	$10.61^2$		

Expt 133

Circulate solution  $1\frac{1}{2}$  hrs.

$k > 1$	$4.01^5$	$11.03^5$	$29.8^{\circ}$	$3.9 \text{ div/sec} \Rightarrow T = 84.75 \text{ sec.}$
$k = 1$	$3.52$	$10.88^5$	$29.8^{\circ}$	

Control # 16525

Sample #13 sent.

Result: 105.9 <sup>233</sup>mg/ml  
 9/19/67 sp.gr. 1.1867

Free(H<sup>+</sup>) N = 0.50 N

$$\frac{g}{l} = 105.9 \times \frac{233.08}{238.04} = 103.69$$

$$\frac{g}{g_{solid}} = \frac{103.69}{1.1867} = 87.38$$

$$\frac{z}{V_{233}} = \frac{1 - (1.67(0.0905))}{0.905 \times 0.9754} \times \frac{233}{9}$$

$$= 248.95$$

this value does not check  
 out on curve of  $\frac{g}{g_{solid}}$  vs sp.gr.  
 assume  $\frac{g}{l}$  is correct then  
 sp.gr. should be  $\sim 1.1455$   
 giving  $\sim 0.0905$   $\frac{g}{g_{solid}}$ .  
 or  
 sp.gr. is correct + there should  
 be 111 mg of solution  $\Rightarrow 131.78\%$ .

Instrument Check on 7-14-67 Source 10 mCi

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Personnel ✓
IC-3	Responds	Calibration	OK	Alarms ✓
IC-4	Responds	Calibration	OK	Pres. - .06"
CRM		Meter Trip		

Expt. 134 Unreflected 15" Dia Aluminum cylinder (annular)

R=	Tad	Soln ht (in)	Rm Temp
>1	4.92 <sup>2</sup>	6.48 <sup>8</sup> → 6.45 <sup>8</sup>	22.3°C
=1	3.86	6.46 <sup>6</sup> → 6.44 <sup>6</sup>	
	.22	.18	

zero .02"  
2.59 di/sec ⇒ T = 5628 sec

Expt. 135 placed 1/16" thick 15x15" sq. sheet of al. on bottom.

>1	3.64 <sup>9</sup>	6.47 → 6.45"	7.70 di/sec ⇒ T = 167.32 sec
=1	3.40	6.45 → 6.43	
	.24	.02	

Removed 1/16" thick piece.

Expt. 136 placed 1/8" thick 15x15 in sq. sheet of al. on bottom.

>1	3.55	6.45 <sup>8</sup> → 6.43 <sup>8</sup>	6.20 di/sec ⇒ T = 134.73 sec. Temp 22.8°C
=1	3.30	6.44 <sup>6</sup> → 6.42 <sup>6</sup>	
	.25	.012	

The results of Exps. 137 and 138 are inconsistent. The periods, Tad displacements, solution wt and Temperature are uninterpretable.

Need to measure temperature of solution.

These effects could be caused by a tilting of the reactor vessel.

10/2/67 Have determined that inconsistency of Tad readings are caused by air in Tad line. Re Exps. 137-138



Instrument Check on 9-27-67 Source 10mc

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-4}$	Motor Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$	Motor Trip	OK	Personnel ✓
IC-3	Responds	Calibration	JA	Alarms ✓
IC-4	Responds	Calibration	JA	Press. - 0.1"
CRM		Motor Trip		

Expt. 137 20-in-dia. Aluminum annular cylinder. unreflected.

Selsyn zero - .01"

Rm Temp 19.6°C

R	Tad (in)	Solution ht (in)	
> 1	10.50	5.62	6.3 $\frac{d\theta}{d\text{sec}} \Rightarrow T = 136.90 \text{ sec}$
= 1	8.62	5.61 <sup>5</sup>	

Instrument Check on 9-29-67 Source 10mc

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-4}$	Motor Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$	Motor Trip	OK	Personnel ✓
IC-3	Responds	Calibration	JA	Alarms ✓
IC-4	Responds	Calibration	JA	Press. - 0.1"
CRM		Motor Trip		

Expt. 138 Same as Expt. 137

Rm Temp 22.6°C

R	Tad (in)	Solution ht (in)	
> 1	5.09 <sup>1</sup>	5.61 <sup>8</sup>	4.025 $\frac{d\theta}{d\text{sec}} \Rightarrow T = 87.46 \text{ sec}$
= 1	4.65	5.61 <sup>4</sup>	

73.5°F

146

Exp. 139

Have braced cylinder and inserted  
thermocouple.

Expt. 139 Bare 20" cylinder. Run Temp 22.7°C

k	Tad	Station	Temp	7.334 div/sec ⇒
>1	3.64"	5.64°	23.4°C	
=1	3.37" .21"	5.64°	23.4°	

Expt. 140 Placed 1/8" x 20 x 20" sheet of Aluminum on bottom of cylinder.

>1	5.08	5.49°	24.1°C	7.617 div/sec ⇒
	4.82 <sup>5</sup> .25"	5.49°	24.2	

Expt. 141 Placed 1/16" x 20 x 20" sheet of Aluminum on bottom of cylinder (1/8" sheet removed)

>1	5.05	5.51°	24.3°C	3.74 div/sec ⇒
=1	4.59 <sup>5</sup> .45"	5.51°	24.4°	

Expt. 142 Repeat # 139 Bare 20" dia cyl.

>1	4.12 <sup>9</sup>	5.53°	24.7°C	3.69 div/sec ⇒
=1	3.65 <sup>0</sup> .47"	5.53°	24.8°C	

Instrument Check on 10-2-67 Source Comet

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2				
IC-1	$> 3 \times 10^{-11}$	OK		OK
IC-2	$> 3 \times 10^{-11}$	OK		Personnel <input checked="" type="checkbox"/>
IC-3	Responds	JR		Alarms <input checked="" type="checkbox"/>
IC-4	Responds	JR		Press. $-0.09^\circ$
CRM	Meter Trip			Rm Temp $76^\circ F$

Expt. 143 20" Bare cylinder - repeat expt. 142.

R	T <sub>rod</sub>	Solution	Temp.	
>1	4.70	5.53'	24.5°C	4.21 div/sec.
=1	4.25 <sup>5</sup>	5.53'	24.6 <sup>+</sup> °C	

Expt. 144 Have installed nominal 10-in-dia aluminum cylinder.

Selsyn zero is  $+0.01''$  Rm Temp  $77.5^\circ F$

>1	5.21	11.27'	24.7°C	6.033 div/sec.
=1	4.81 <sup>.40</sup>	11.24 <sup>5</sup>	24.7 <sup>+</sup> °C	

Expt. 145 Placed sheet of  $4\frac{1}{16} \times 10 \times 10''$  aluminum on bottom.

>1	4.97'	11.28	24.8°C	2.4 div/sec.
=1	4.12 <sup>.85</sup>	11.23'	24.8 <sup>+</sup> °C	

Expt. 146 Placed  $\frac{1}{8} \times 10 \times 10''$  sheet of Al. on bottom (Removed  $\frac{1}{16}''$  sheet)

>1	5.00	11.27 <sup>.70</sup>	24.85°C	3.08 div/sec.
=1	4.24 <sup>.76</sup>	11.22 <sup>5</sup>	24.85 <sup>+</sup> °C	

Expt. 147 Repeat Expt. 144

>1	14.48'	11.31 <sup>5</sup>	24.9°C	
=1	air in tank	line	24.9 <sup>+</sup> °C	- Repeat this exp
>1	5.21	11.31	25 <sup>5</sup> °C	5.325 div/sec $\Rightarrow$
=1	4.72	11.27 <sup>5</sup>	26°C	

150

Drained 24 liters of solution and added 4 liters  
of H<sub>2</sub>O following expr. 149.


Have taken sample #14A expr. 148

#14 Control # 16601

133.5 mg/ml  $0.235$  base }  $g \frac{1}{2} = 130.72$

sp gr. 1.1532

free H<sup>+</sup> → N = 0.40



Instrument Check on 10-16-67 Source 10 meV

FM-1	Low Trip	OK	Alarm Trip	OK
FM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Motor Trip	OK at 3/4"	Fast Trip OK
IC-2	$> 3 \times 10^{-11}$		OK	Personnel ✓
IC-3	Responds		JA	Alarms ✓
IC-4	Responds		JA	Pres. - "0.08"
CRM				

Expt. 148 14.36 liter sphere unreflected.

Selsyn Zero  
+0.3"

R #	T <sub>sd</sub> (in)	Solution lit (in)	Solution T °C	
>1	6.42	9.61 <sup>3</sup>	9.52 <sup>2</sup>	25.5°C 4.725 lit/sec.
=1	6.16 <sup>9</sup>	9.60 <sup>9</sup>	9.57 <sup>1</sup>	25.7 13.745 liters

Expt. 149 Have new pump circulating solution for ~1 hr.

>1	5.18 <sup>9</sup>	9.65 <sup>2</sup>	9.62 <sup>2</sup>	25.75°C ? 5.688 lit/sec.
=1	4.95 <sup>0</sup>	9.63 <sup>1</sup>		25.75°C

10/20/67 Sample #15 Control # 16601  
 119.3 mg/ml  $U^{238}$  } 116.81 g/l.  
 spgr. 1.1675  
 Free  $H^+ \rightarrow N$  0.40

After Expt. 150 drained six liters of solution and added  
 four liters of water.

Sampled drained solution #15.

After Expt. 151 added 1 liter of  $H_2O$  mixed 1 hr.

After Expt. 152 Sampled Solution #16  
 added 250cc  $H_2O$  and mixed.

10/24/67 Control # 16615  
 102.9 mg/ml  $U^{238}$  100.76 g/l.  
 spgr. 1.2117 X  
 $H^+ \rightarrow N$  0.36



Instrument Check on 10-17-67 Source 10mc

PM-1 Low Trip OK Alarm Trip OK  
 PM-2 Alarm Trip  
 IC-1  $> 3 \times 10^{-4}$  Meter Trip OK ( $1/2''$ ) Fast Trip OK  
 IC-2  $> 3 \times 10^{-4}$  OK Personnel ✓  
 IC-3 Responds JH Alarms ✓  
 IC-4 Responds JH Pres. - 0.09  
 CRM Meter Trip

Expt. 150 Try for critical at new concentration Rm Temp  $72^{\circ}\text{F}$

R	feed	Solution	Solution Temp $^{\circ}\text{C}$	
$> 1$	$5.12^2$	$9.91^2$	$25^{\circ}\text{C}$	2.22 div/sec.
$= 1$	4.64	$9.88^{\circ}$	$25$	$\sim 13.69 \text{ L.}$

Expt. 151 try new concentration

$> 1$	4.35	$10.68^5$	$25.7^{\circ}$	8.65 div/sec.
$= 1$	$4.12^2$	$10.65^5$	$25.7^{\circ}$	$\sim 14.21 \text{ L.}$

Expt. 152 try new concentration

$> 1$	$4.51^8$	$11.24^8$	$25.5^{\circ}\text{C}$	3.0 div/sec.
$= 1$	3.90	$11.07^8$	$25.5$	

154

after Expt. 153 take sample #17 add 750cc H<sub>2</sub>O  
to system + mix.

10/24/67 control # 16615

104.7 mg/ml as <sup>238</sup>

102.52 g/l.

sp. gr. 1.1442

H<sup>+</sup> → ~~for~~N 0.36

Instrument Check on 10-14-67 Source 10 mci

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	Personnel $\checkmark$
IC-3	Responds	Calibration	SIR	Alarms $\checkmark$
IC-4	Responds	Calibration	SIR	Press. - 0.09"
CRM		Meter Trip		

Expt. 153. Try new concentration in sphere.

R	Tad	Solution	Temp.	
>1	5.10	10.75 <sup>5</sup>	22.4°C	3.24 d/s/Sec.
=1	4.61	10.68 <sup>2</sup>	22.4°C	

## Instrument Check on \_\_\_\_\_ Source \_\_\_\_\_

PM-1	Low Trip	10-20-67	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK ~ 3/4"	Fast Trip OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	Personnel $\checkmark$
IC-3	Responds	Calibration	JR	Alarms $\checkmark$
IC-4	Responds	Calibration	JR	Press - 0.09"
CRM		Meter Trip		

Expt. 154 Try new concentration

>1	6.77	12.48 <sup>5</sup>	22.2°C	4.787 d/s/Sec.
=1	4.18 <sup>2</sup>	11.17 <sup>0</sup>	22.25	
	3.99	11.05 <sup>2</sup>		
	3.79 <sup>5</sup>	10.95		
	3.60	10.915		
	3.39	10.885		
	3.17	10.85 <sup>8</sup>		

Temp	Solution
2.97	10.83 <sup>5</sup>
2.80	10.81 <sup>0</sup>
2.60	10.78 <sup>6</sup>
2.40	10.76 <sup>1</sup>
2.20	10.74
2.00	10.71 <sup>0</sup>
1.80	10.68 <sup>5</sup>
1.60	10.66 <sup>0</sup>
1.40	10.64
1.20	10.62
1.00	10.60
.80	10.58
.6	10.56 <sup>0</sup>
.4	10.54
.2	10.52 <sup>8</sup>
0	10.50 <sup>5</sup>
3.60	10.92 <sup>8</sup>
3.81	10.97
4.00	11.06 <sup>0</sup>
4.20	11.17
4.40	11.28 <sup>0</sup>
4.60	11.38
4.80	11.46 <sup>5</sup>
5.00	11.58

158

after Expt. 155 take sample #18

10/31/67 Control No E 16623

101.8 mg/ml.  $\text{CO}_2$

normality of  
free acid.  $\text{H}^+$  Normal 0.36

99.68 g/l

also

401.2

1.1392

99.09 g/l.

Instrument Check on 10-24-67 Source 10me Y

PM-1	Low Trip	OK	Alarm Trip	OK		
PM-2			Alarm Trip			
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK	
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		Personnel	✓
IC-3	Responds	Calibration	PH		Alarms	✓
IC-4	Responds	Calibration	PH		Pres.	-0.09"
CRM		Meter Trip				

Expt. 155

k	T <sub>sd</sub>	Solution	Temp.	
> 1	4.61	11.21	22.2°	6.5 div/sec
= 1	4.00	10.88 <sup>s</sup>	22.2 <sup>s</sup>	
< 1	1.44	10.57 <sup>s</sup>	22.2 <sup>s</sup>	
> 1	7.13	10.95	22.2 <sup>s</sup>	33 div/sec.
≈ 1	4.00	10.89 <sup>s</sup>	22.2 <sup>s</sup>	
= 1	4.03	10.92	22.2 <sup>s</sup>	

Expt. 156

Have installed 10" dia aluminum annular cgl.

Selsyn Zero +0.02"

> 1	5.00	13.24 <sup>s</sup>	23°	3.075 div/sec.
= 1	3.92 <sup>s</sup>	13.20	23°	

Instrument Check on 10-31-67 Source 10 mc

PM-1 Low Trip OK Alarm Trip cut  
 PM-2 High Trip OK  
 IC-1  $> 3 \times 10^{-4}$  OK Fast Trip OK  
 IC-2  $> 3 \times 10^{-11}$  OK Personnel ✓  
 IC-3 Responds JA Alarm ✓  
 IC-4 Responds JA Pres. -0.1"  
 CRM Water Trip

Expr. 157 10" aluminum cyl. unreflected (Repeat 156)

R	Tub	Solution	Temp	
>1	5.774	13.20 <sup>9</sup>	21.9°C	3.56 div/sec. Rm Temp.
=1	4.68 <sup>5</sup>	13.18 <sup>1</sup>	21.9°C	

10 AM

Expr. 158 Placed 4" x 10" x 10" sheet of Al. on bottom.

>1	5.60	13.26 <sup>5</sup>	22 <sup>+</sup>	3.04 div/sec.
=1	4.53	13.23 <sup>2</sup>	22 <sup>+</sup>	wrong direction! difference due to solution temp. also possible air in line

2<sup>30</sup> P

Expr. 159 Same as 158

>1	5.00	13.20 <sup>7</sup>	air in Tub	1.74 div/sec. line about.
>1	5.45	13.22 <sup>5</sup>		1.74 div/sec.
=1	3.77	13.19 <sup>6</sup>		

Instrument Check on 11-1-67 Source 10mcK

PM-1 Low Trip OK Alarm Trip Trip on E  
~~not set D~~

PM-2 Alarm Trip

IC-1  $73 \times 10^{-4}$  Meter Trip OK Fast Trip OK

IC-2  $73 \times 10^{-4}$  Meter Trip OK

IC-3 Responds JA Personnel ✓

IC-4 Responds JA Alarm ✓

CRM Meter Trip Pres. -0.1"

Expt. 160 10" alum. cyl. with  $\frac{1}{8} \times 10 \times 10$ " sheet  
of alum. on bottom.

K	t <sub>ad</sub>	Solution	Temp.	
>1	2.50	13.20 <sup>5</sup>	22.2	Rm. 2.96 div/dec.
=1	6.37	13.18 <sup>9</sup>	22.2	

Expt. 161 drained to 12" ht. and remove  $\frac{1}{8}$ " thick sheet from bottom.

>1	2.73	13.19 <sup>5</sup>	22.2	2.56 div/dec.
=1	1.57 <sup>2</sup>	13.17	22.2	



Exps. 162-167

To make changes the solution was drained  
to 12" to minimize heating solution by  
pump.

Instrument Check on 11-2-67 Source 10mcV

PM-1	Low Trip	OK	Alarm Trip	<del>OK</del> <i>does not trip on 0.</i>	
PM-2			Alarm Trip		
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Responds	Calibration	JH		
IC-4	Responds	Calibration	JH		
CRM		Meter Trip			

Expr. 162

Placed sheet of Cd  $10.83" \times 10 \times 10"$  on bottom of cyl.

	R	Tad	Sdoyr	Temp.	
$8 \frac{52}{A}$	>1	11.10	13.16 <sup>5</sup>	22.03°C	2.725 div/sec. Rm Temp.
	=1	9.90	13.14 <sup>4</sup>	22.03°C	
	<1	0	12.84 <sup>5</sup>		

Expr. 163 Removed Cd-sheet - base cyl.

$9 \frac{10}{A}$	>1	8.60	13.18	22.03	3.06 div/sec.
	=1	7.50	13.16 (13.15)	"	

Expr. 164 Placed sheet of  $48" \times 10 \times 10"$  Aluminum.

$9 \frac{26}{A}$	>1	3.75	13.14 <sup>4</sup>	22.03	4.65 div/sec.
	=1	2.91	13.13°	22.03	

Instrument Check on 11-3-67 Source 10mc

PM-1 Low Trip ok Alarm Trip no  
 PM-2 Alarm Trip  
 IC-1  $> 3 \times 10^{-11}$  Meter Trip ok Fast Trip ok  
 IC-2  $> 3 \times 10^{-11}$  Meter Trip ok Personal ✓  
 IC-3 Responds Calibration SH alarms ✓  
 IC-4 Responds Calibration SH Press. - 0.1"  
~~IC-5~~ Meter Trip  
 Selsyn zero is  $\pm 0.4$

Expr. 165 Have installed 15" dia alum. vessel (cyl.)  
 with  $\frac{1}{8} \times 15 \times 15$ " sheet of aluminum on bottom.

R	Tud	Solution	Temp.	
>1	2.35	6.92	21.6°C (Rm. Temp)	3.78 div/sec
=1	1.34 <sup>5</sup>	6.91 <sup>5</sup>	21.6°C	

Drained to 6.79" of solution and removed  $\frac{1}{8}$ " thick sheet of al from bottom of cylinder.

Expr. 166 Base 15" dia.

>1	11.54 <sup>5</sup>	6.97 <sup>5</sup>	21.6	3.64 div/sec.
=1	11.10	6.97 (6.93)	"	

Drained to 6.79" of solution and placed sheet of aluminum on bottom  $\frac{1}{16} \times 15 \times 15$ .

Expr. 167 bottom refl'd <sup>(al)</sup> 15" dia cyl.

>1	10.50	6.96	21.6	4.475 div/sec.
=1	10.12 <sup>5</sup>	6.95 <sup>5</sup>	21.6	

168

After Expt. 168 Drained 6 liters of solution and added  
5 liters of  $H_2O$ . mixed to 1<sup>30</sup> pm Est conc. now 83  $\frac{2}{3}$  %

Instrument Check on 11-13-67 Source 10mc

PM-1	Low Trip	OK	Alarm Trip	OK
FM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	Personnel OK
IC-3	Responds	Calibration	JA	Alarms OK
IC-4	Responds	Calibration	JA	Pres. - 0.1"
IRM		Meter Trip		

Zero +1.00"

Expt. 168 16.438 liter sphere

	R	Tad	Solution	Temp.	
	>1	6.80 <sup>5</sup>	10.54	21.6°C	
~11 AM	=1	6.38	10.53 <sup>5</sup>	21.6°C	15.82 l.

Expt. 169 Try new concentration

2<sup>30</sup> P >1 33.00 10.19<sup>0</sup> 29.9°C zero?

21 32.63 10.19<sup>-</sup>

LL1 - -0.6 for zero ∴ R=1 at 10.79"

16045 l.

After Expt. 170 ① Drained 2 liters of solution

② took sample # 79A

③ added 2 liters of  $H_2O$  est. conc. <sup>now</sup> ~75 mg/ml.

11/15/65 Sample # E 16682

85.02 mg/ml

sp gr. = 1.1186

After Expt. 171 ① took sample 20

② added 1 liter of water + mixed.

Sample 20A: 81.34 mg/ml as  $U^{238}$  sp gr. 1.1122

⇒ 79.64 g/l.

After Expt. 172 added 500 cc of  $H_2O$  mixed.

Instrument Check on 11-14-67 Source 10 mc X

PM-1                      Low Trip OK Alarm Trip OK  
 PM-2                      Alarm Trip                       
 IC-1 > 3x10<sup>-11</sup> Meter Trip OK Fast Trip OK  
 IC-2 > 3x10<sup>-11</sup> Meter Trip OK Personnel ✓  
 IC-3 Responds Calibration JH Alarms ✓  
 IC-4 Responds Calibration JH Pres. -0.1"  
 CRM                      Meter Trip                     

Exp. 170

Check zero 0.00" ~ 83 %/l

R	Temp	Solution	Temp.
>1	7.50	10.62 <sup>5</sup>	22.5°C
=1	7.05	10.62	22.5°C.

Exp. 171 Try new concentration, ~ 75 %/l

>1	8.54	11.18	25.8°C
=1	8.23	11.10 <sup>6</sup>	25.8

Exp. 172 try new concentration ~ 73 %/l

>1	8.57	11.58	29.8°C
=1	8.02	11.52 <sup>4</sup>	29.75°C

no more specimens

After Expt. 173 add 1 liter  $H_2O$  + mix.



Instrument Check on 11-15-67 Source 10 mc

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
PM-1	$> 3 \times 10^{-11}$	Water Trip	OK	Test Trip OK
PM-2	$> 3 \times 10^{-11}$	Water Trip	OK	Personnel <input checked="" type="checkbox"/>
PM-3	Responds			Alarms <input checked="" type="checkbox"/>
PM-4	Responds			Pass - 0.1"
PM	Water Trip			

Expt. 173 Try new concentration

R	Temp	Solution	Temp.
71	10.85 <sup>3</sup>	11.36	21.70°C
=1	10.28	11.30 <sup>1</sup>	21.70°C

Expt. 174 Try new concentration

R	Temp	Solution	Temp.
R<	13.22	16.27	24.75°C

174

After Expt. 175 added 400 cc of solution ~ 160 g/l.

After Expt. 176 added 100 cc of solution ~ 160 g/l.

Sample 21A: 76.17 mg/ml as  $U^{238}$  }  $\Rightarrow$  74.58 g/l.  
sp. gr. 1.1063

Instrument Check on 11-16-67 Source 10mcI

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2				
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Personnel
IC-3	Response	Calibration	JH	Alarms ✓
IC-4	Response	Calibration	JH	Pres. -ok"
CRM		Meter Trip		

Expr. 175 Try at lower temp.

k	Tad	Solution	Temp.
≥1	14.82 <sup>5</sup>	15.86 <sup>4</sup>	21.7 °C

Expr. 176

≤1	12.97	13.35	24.3 °C
----	-------	-------	---------

Instrument Check on 11-17-67 Source 10mcI

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-4}$	Meter Trip		Fast Trip
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Personnel ✓
IC-3	Response	Calibration	JH	Alarms ✓
IC-4	Response	Calibration	JH	Pres -ok"
CRM		Meter Trip		

Expr. 177

>1	9.05	12.93	21.0 °C
----	------	-------	---------

=1	6.57	11.40	21.1 °C	zero?
----	------	-------	---------	-------

check zero and find <sup>12.14</sup> 999.21 of 0.00  
-1.79

Instrument Check on 11-20-67 Source 10 mcr

PM-1 Low Trip OK Alarm Trip OK  
 PM-2 Alarm Trip  
 IC-1  $3 \times 10^{-4}$  Meter Trip OK 0" ~~Alarm~~ Trip OK 0"  
 IC-2  $3 \times 10^{-4}$  Meter Trip OK ~1" top Personnel ✓  
 IC-3 Responds Calibration OK Alarm ✓  
 IC-4 Responds Calibration OK Pres -0.1"  
 CRM Meter Trip  
zero is -0.2

Expt. 178 15" aluminum annular cyl.  
 with  $\frac{1}{8}$ " alum. plate on bottom.

R*	Tag	Solution	Temp.
>1	2.83	7.56 <sup>4</sup>	21.3°C
=1	2.44	<sup>some</sup> air in line 7.55 <sup>6</sup>	21.3 est.
<1	0.0	2.43	drained to remove

$\frac{1}{8}$ " alum. from bottom.

Expt. 179 base cylinder

>1	11.34	7.61 <sup>7</sup>	21.4
=1	11.06 <sup>5</sup>	7.60 <sup>5</sup> (7.620)	21.4 est.

Drain to 7.43" and

Expt. 180 Place  $\frac{1}{16} \times 15 \times 15$ " sheet of Al. on bottom

>1	10.42	7.59 <sup>2</sup>	21.5°
=1	10.12	7.59 <sup>5</sup>	21.6°C est.

11 PM

Expt. 181 Installed 10" Aluminum cylinder with

Zero +.04"

$\kappa$	Top	solution	Temp.	Run Temp.
> 1	5.30	17.19	21.7	
= 1	3.81 <sup>4</sup>	17.17 <sup>8</sup>	21.7	
< 1	0	17.075	—	

Expt. 182 Drained to 16.72" Removed  $\frac{1}{16}$ " al sheet.  
10" Base.

< 1	0	16.70	21.8°
> 1	17.00	17.24	21.8°
= 1	14.95 <sup>2</sup>	17.22 (17.18)	21.8
< 0	0	16.7	

Expt. 183  $\frac{1}{16}$  al sheet.

> 1	<del>18.91</del>	17.20	21.9°
= 1	14.54	17.19 <sup>5</sup>	

Expt. 184 Installed  $4\frac{5}{8}$ " dia sphere.

$$x \cdot 80 \text{ g/l} = (x+2) \cdot 75 \text{ g/l} \Rightarrow x = 30$$

$$\text{desire } 47 \text{ g/l} \therefore 20(75 \text{ g/l}) + 12 \text{ H}_2\text{O} = 32 \times 47 \text{ g/l}$$

After Expt. 184 Drained ~12 liters of solution  
and added 12 liters of H<sub>2</sub>O. nice!

After Expt. 185 ① Took Sample #22

② Drained 4 liters of solution

③ added 4 liters of H<sub>2</sub>O.

Sample 22 Control # E 16745 12/11/67

52.73 mg/l as  $\text{O}_2$

sp. gr. 1.0746

Sphere

Instrument Check on 11-28-67 Source 10meV

FM-1                          Low Trip OK Alarm Trip ok  
 FM-2                          Alarm Trip                           
 IC-1 >3x10<sup>-11</sup> Meter Trip OK ~ 0" Fast Trip OK  
 IC-2 >3x10<sup>-11</sup> Meter Trip OK ~ 1" Personnel ✓  
 IC-3 Responds Calibration OK Alarms ✓  
 IC-4 Responds Calibration OK Pres. -0.1"  
 CRM                          Meter Trip                         

Selsyn zero +.035

Expt. 184 Concentration 74.5% <sup>94</sup>/<sub>100</sub> Run Temp 21.1°C

kr	Tad	Solution	Temp
>1	3.04 <sup>5</sup>	9.52 <sup>5</sup>	21.9°C
=1	2.45 <sup>4</sup>	9.52°	21.9°C

Expt. 185 try new concentration ~47% <sup>9</sup>/<sub>100</sub>

>1	3.81	11.46	30.5°C
=1	2.85	11.45 <sup>0</sup>	30.5°C

After Expt. 186 add 1 liter of  $H_2O$  + mix

~ 33 liters in sys.

After Expt. 187 add 400 cc of  $H_2O$  + mix

After Expt. 188 add 200 cc of  $H_2O$  + mix.



Instrument Check on 11-29-67 Source 10 mcd

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	0" Fast Trip OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	1" Personnel ✓
IC-3	Responds	Calibration	JH	Alarms ✓
IC-4	Responds	Calibration	JH	Pres - 0.1"
CRM		Meter Trip		

Expt. 186 new concentration in  $14\frac{5}{8}$ " sphere. 24 9/11

R	Tad.	Solution	Temp.
>1	3.72	12.71 <sup>8</sup>	21.8°C
=1	2.51 <sup>5</sup>	12.71 <sup>5</sup>	21.8°

Expt. 187 try new concentration 24 9/11

>1	3.71	13.26	23.8°C
=1	2.78 <sup>4</sup>	13.25 <sup>9</sup>	23.8°C

Instrument Check on 11-30-67 Source 10 mcd

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	0" Fast Trip OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	1" Personnel ✓
IC-3	Responds	Calibration	JH	Alarms ✓
IC-4	Responds	Calibration	JH	Pres - 0.1"
CRM		Meter Trip		

Expt. 188

>1	2.625	13.50	22°C
=1	1.32	13.44	22°C

Instrument Check on 12-4-67 Source 10mcY

PM-1	Low Trip	OK	Alarm Trip	OK	0"
PM-2			Alarm Trip		
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	0"	Fast Trip OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	1"	Personnel ✓
IC-3	Out	Calibration			alarms ✓
IC-4	Response	Calibration	SM		Pres. -0.1"
EM		Meter Trip			

Expt. 189 new concentration. Run Temp 16°C

R	Tab	Solution	Temp.
>1	5.09 <sup>2</sup>	13.47	17.6
=1	3.855	13.45 <sup>2</sup>	17.6
<1	2.88	13.40	17.6

Expt. 190 Temp Change

>1	5.50	13.29	19.8°C	?
=1	4.567	13.28 <sup>5</sup>	19.8°C	?
<1	3.40	13.25	19.8°C	13.40

check zero and find - .015

Set zero at + .065

186

After Exp. 193 add 300 cc H<sub>2</sub>O + mix

Instrument Check on 12-5-67 Source 10 meV

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	0" Fast Trip OK
IC-2	$\geq 3 \times 10^{-11}$	Meter Trip	OK	1" Personnel ✓
IC-3	Out	Calibration		Alarms ✓
IC-4	Responds	Calibration	JST	Pres. - 0.1"
CRM		Meter Trip		

Expt. 191 Temp change

R	Tab	Solution	Temp.
> 1	5.29"	13.489	20.6°C
≥ 1	4.28	13.485	20.7°C

Expt. 192 Temp change

> 1	5.92	13.68 <sup>0</sup>	25°C
≥ 1	4.83	13.64	25°C

Expt. 193 Temp change.

> 1	5.99	13.80 <sup>9</sup>	28.5°	sphere full + solution in tube.
≥ 1	4.70	13.74 <sup>5</sup>	28.5	
< 1	3.88	13.68		
< 1	2.93	13.61		
< 1	1.89	13.52		
< 1	1.76	13.44 <sup>5</sup>		
≥ 1	4.70	13.70		
1	4.67	13.69 <sup>+</sup>		

188

After Expt 194 took sample 23A+B

Sample 23A Contid # E 16745 12/11/67

45.58 mg/ml to 0238

sp. gr. = 1.0529

44.6 84/8

Instrument Check on 12-6-67 Source 10mcI

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-4}$	Meter Error	OK	0 Fast Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Error	OK	" Personnel
IC-3	Out	Calibration		Alarms ✓
IC-4	Responde	Calibration	OK	Pres. -0.1"
CRM		Meter Trip		

Expt. 194      New Concentration      Rm. Temp 20.9°C

R	Tad	Solution	Temp.		
>1	4.71	13.83 <sup>s</sup>	21.3°C		
=1	3.51	13.79	21.3°C		
<1	3.0	13.75			
	2.75	13.72 <sup>t</sup>			
	2.47	13.71			
	1.99	13.67			
	1.51	13.63 <sup>s</sup>			
	1.26	13.61		Tad	Solution
	.99	13.60		4.00	13.77
	.5	13.56		4.52	13.82
	0	13.52		4.73	13.85 period
	2.27	13.63	R=1	3.51	13.80 <sup>s</sup>
	2.48	13.64			
	2.75	13.66			
	3.0	13.68 <sup>s</sup>			
	3.29	13.71			
	3.51	13.73			

190

1-17-68  
Drained Storage system.

realign zero = 0"

Expt. 195 Installed nominal 10" annular cylinder.  
bottom reflector plate of aluminum  $\frac{1}{8}$ " thick (10x10)

k	Tab	solution	Temp.
<1	39.18	25.01	21°C

exhausted supply of solution -

Instrument Check on 12-7-67 Source 10mc

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	0" Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	1"	Personnel ✓
IC-3	out	Calibration			Alarms ✓
IC-4	Responds	Calibration	JIT		Pres -0.1"
CRM		Meter Trip			

Expt. 196 Installed 15" annular cylinder } zero -0.03

k	Tab	solution	Temp.
>1	5.50 <sup>5</sup>	10.32 <sup>5</sup>	21.3°C
=1	4.26	10.31	
<1	0.0	10.23	drained to remove al reflector

Reflected on bottom by  $\frac{1}{8} \times 15 \times 15$ " al.

Expt. 197 Installed  $\frac{1}{16} \times 15 \times 15$ " bottom reflector

>1	11.62	10.34	21.3°C
=1	10.61	10.33 <sup>5</sup>	
<1	0.0		drained to remove al. refl.

Expt. 198 Unreflected 15"

>1	12.11 <sup>3</sup>	10.35 <sup>3</sup>	21.3°C
=1	11.56	10.35 (10.38)	



192

1-17-68  
to 1-25-68 installed water reflection system

1/25/68 have put ~ 19 l. of solution in storage system  
at 204 g/l.

After Expt. 189 changed chamber on IC-2 to  
submersible type

After Expt. 200 added 0.5 liters of water and mixed.

Helena Poweroff

988983  
(26)

Water Reflected Series

8.62-in dia sphere 5.840 liters

Instrument Check on 1-15-68 Source comet

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Personnel <input checked="" type="checkbox"/>
IC-3	Responds	Calibration	JK	Alarms <input checked="" type="checkbox"/>
IC-4	Responds	Calibration	JH	Pres - 0.1"
CRM		Meter Trip		

Exp. 189 Selwyn reads 0.0  $H_2O \sim 8"$  above sphere

k	Tab	Solution	Temp.	
>1	3.54 19.47	8.90	21.6°C	73 sec period. p ~ 154
=1	19.3 0.5	8.715	21.6°C	? zero not right check again.

Instrument Check on 1-26-68 Source comet

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 10 \times 10^{-4}$	Meter Trip	OK	Personnel <input checked="" type="checkbox"/>
IC-3	Responds	Calibration	JK	Alarms <input checked="" type="checkbox"/>
IC-4	Responds	Calibration	JH	Pres - 0.1"
CRM		Meter Trip		

Exp. 200

k	Tab	Solution	Temp.	
>1	9.14 5.19	7.595	21.9°C	18.2 sec period. p ~ 33.54
=1	4.79	7.595	21.9°C	

Exp. 201

Instrument Check on 1-27-68 Source 10mc

PM-1 Low Trip OK Alarm Trip OK  
 PM-2 Alarm Trip  
 IC-1  $7.3 \times 10^{-11}$  Meter Trip OK Fast Trip OK  
 IC-2  $7.3 \times 10^{-11}$  Meter Trip OK Personnel ✓  
 IC-3 Responds Calibration OK Alarms ✓  
 IC-4 Responds Calibration OK Pres -0.1"  
 CRM Meter Trip  
Delayn zero +.05"

Expt. 201 check new concentration.

R	Temp	Solution	Temp	H <sub>2</sub> O
<1	39.18	8.95"	23.2°C	Full.

Expt. 202 Repeat #201.

>1	Temp	Solution	Temp	Period	Q
4.06	18.30	9.00	23.25	53.8 sec period	Q=194
=1	18.06	9.00	23.25	4	

Instrument Check on 1-30-68 Source 10mc

PM-1 Low Trip OK Alarm Trip OK  
 PM-2 Alarm Trip  
 IC-1  $7.3 \times 10^{-11}$  Meter Trip OK Fast Trip OK  
 IC-2  $7.3 \times 10^{-11}$  Meter Trip OK Personnel ✓  
 IC-3 Responds Calibration OK Alarms ✓  
 IC-4 Responds Calibration OK Pres -0.1"  
 CRM Meter Trip

Expt. 203 Check excess reactivity in sphere. Delayn zero = 0.0

>1	Temp	Solution	Temp	Period	Q
4.766	6.63 <sup>5</sup>	7.99 <sup>5</sup>	22.8°C	46.5 sec period	Q=204 Full Water reflector.
=1	6.40	7.99 <sup>2</sup>	22.8°C		
<1	5.40	7.94 <sup>5</sup>			

drain to check zero delayn reads 0.72

Control # E 16865 2/1/68

Sample # 24 171.2 mg/ml. on 0238

$$171.2 \frac{253.08}{238.04} = 167.63 \text{ } \mu\text{g/l.}$$

Reflector Water sample Reg. # 684535 1/31/68

7.99 ppm U in ~600 liters.

3/20/68

From E.I. Wyatt

Control # 46141

$5.6 \times 10^{-10}$  fission/ml. at 10:00 AM 1-30-68

based on  $^{99}\text{Mo}$  at 4.8% fission yield

and  $^{92}\text{Sr}$  at 6.5% " "

Exp. 207 Repeat 203. Set relay on 0.0

k	T <sub>ad</sub>	Solution	Temp.	40.8 sec period
>1	4.93	7.31	22.8°C	ρ ~ 21.84

<1 drain to ~7.2 system did not respond to tank motion. Air in T<sub>ad</sub> line.

>1 prompt crit. 10:01

2-15-68 Remarks.

To minimize possibility of air entering the system we have relocated the solution <sup>feed</sup> valve to be below the uppermost point of the pump by-pass line. (see page 27)

Sample taken of reflector water shows  $10^{-8}$  ppm uranium. Clean sheet of aluminum immersed in water, allowed to dry, gave no ~~wipe~~ detectable a contamination on wipe. (Water sample 2 on Reg. No. 684536 returned 2/13/68) Reflector water system contains ~165 gals of dem. water.

Added ~17 liters of  $UO_2(NO_3)_2$  to system; concentration ~200  $\mu$ /l. Storage system reads 200  $\mu$ /l (calic pic) at surfaces.

By-pass open 2 turns When open  $2\frac{1}{4}$  turns will not pump against 2" in sphere.

Periods for Expt. 205:

IC-3	located in Paraffin	5.012 $\text{dl}/\text{sec}$	$T = 108.91 \text{ sec}$	10.9	1.91%
IC-4	located in $H_2O$	4.175 $\text{dl}/\text{sec}$	$T = 90.72 \text{ sec}$	12.8	2.25%

Power off relay reads 2897  $\frac{1}{2}$

8.62-in-dia Sphere

Instrument Check on 2-15-68 Source 10 mCi

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2				
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Alarm Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Personnel <input checked="" type="checkbox"/>
IC-3	Respon	Calibration	OK	Alarms OK
IC-4	Respon	Calibration	OK	Press - 0.11"
CRM		Meter Trip		

Expt. 205

10<sup>pm</sup>

Instruments respond as usual - each of IC1, IC2 & PM-1  
 alarm system. Solution pumped into the sphere  
 when unreflected to check delayn reading at full.  
 Have stopped several times during filling, turned  
 off pump and for a short period and restarted to see  
 if air would appear in the system - result is  
 negative. Calibration of tub displacement with  
 solution height shows sphere is full when delayn  
 reads 8.62". System checked for leaks - negative.

Drained solution - pump reflector water.

IC-2 and IC4 are located in reflector tank.

All water in tank gives a 7<sup>7/8</sup>" above top of sphere.

Corresponding to slight glass reading of 67.5 cm.

Time	k	Tub	solution	Temp.	
2:25 pm			7.075		
3:25 pm	>1	25.23	7.08	22.2°C	5.23 L.
	=1	25.08 <sup>2</sup>	7.075	22.2°	

$$(\Delta V)_{\text{tub}} \sim 5.7 \text{ cc} \Rightarrow 2.25 \text{ fl/cc}$$

$$2.25 \text{ fl/cc} \times 50 \frac{\text{cc}}{\text{in}} \times 4.3 \frac{\text{in}}{\text{min}} \times \frac{1}{60} \frac{\text{min}}{\text{sec}} \sim 8 \text{ fl/cc.}$$

2/16/68

Have interchange IC-3 and IC4

IC-3 now in H<sub>2</sub>O reflector tank.

IC-4 in paraffin on Platform.

Ted adds 38 cc of solution per in<sup>3</sup> displacement, when sphere is full.After Expt. 206 took sample #25 ask for  $\left. \begin{array}{l} \text{spec} \\ \text{sp gr} \\ \text{inst. ml.} \end{array} \right\}$ 

added 1.50 liters of water to system and mixed.

After expt. 207 added 1 liter of H<sub>2</sub>O + mixed.

Sample 25: (Expt. 206) Control No. E 16912 2/19/68

204.5 mg/ml as U<sup>238</sup> → 200.24 g/l.

sp. gr. 1.2796

spec. to come



8.622-in ID sphere  
 relay reads 9.897% (power on).

Instrument Check on 2-16-68 Source 10 mc X

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Water Trip	OK	Foot Trip OK
IC-2	$> 3 \times 10^{-11}$	Water Trip	OK	Personnel $\checkmark$
IC-3	Responds		OK	Alarms $\checkmark$
IC-4	Responds		OK	Pres - 0.11"
GRM		Meter Trip		

Expr. 206 Repeat #205 water height 68.5 cm,  
 (~ 8" above sphere)

9<sup>25</sup> A

R T<sub>ad</sub> Solution Temp.

>1 14.11 7.06<sup>5</sup> 23.3°

~ 2009/1

=1 13.95 7.07 23.3° Vol = 5.225 l.

V ~ 17

periods: IC-3 : 3.625 div/sec  $\Rightarrow T = 78.77 \text{ sec}$  14.2 f 2.34<sup>4</sup>/cc

IC-4 : 4.050 div/sec  $\Rightarrow T = 88.01 \text{ sec}$  13 f 2.14

( $\Delta V$ )<sub>Tad</sub> = 6.08 cc  $\Rightarrow$  2.34<sup>4</sup>/cc

Expr. 207 Try new concentration.

1<sup>12</sup> PM

>1 13.29<sup>5</sup> 7.22 - 7.23<sup>5</sup> 26.9°C  
Time out, during period

~ 183.6

=1 13.14 7.23<sup>4</sup> 26.25°C Vol = 5.330

V ~ 18.5

periods: IC-3 4.262 div/sec  $\Rightarrow T = 92.61 \text{ sec}$  ~ 12.5 f 2.12<sup>4</sup>/cc

IC-4 4.587 div/sec  $\Rightarrow T = 99.68 \text{ sec}$  ~ 11.8 f 2.00<sup>4</sup>/cc

( $\Delta V$ )<sub>Tad</sub> = 5.890 cc

2/14/68 Remark on Press differential: Have cleaned  
return air ducts grids - note pressure in room  
increase from  $-0.11''$  to  $0.07''$  of  $H_2O$ .

#26 Control No. E 16918

$194.5 \text{ } ^{238}\text{g}/\text{L} \rightarrow 190.45 \text{ } ^{238}\text{g}/\text{L}$

sp. gr. 1.2529

After Expr. 208 took sample 26.

added 1.5 liters of  $H_2O$  and mix.

Periods Expr. 208 IC-3 ( $H_2O$ ): 6.567 dis/sec.

IC-4 ( $C_25H_52$ ): 6.734 dis/sec.

Periods Expr. 209 solution cooled during period result  
not useable.

After expr. 209 added 1.5 liters + mix.

After Expr. 210 took sample 27.

added 1 liter  $H_2O$  + mix.

#27 Control No. E 16918

$199.4 \text{ } ^{238}\text{mg}/\text{ml} \rightarrow 173.70 \text{ } ^{238}\text{g}/\text{L}$

sp. gr. 1.2357 (23.8°C)

8622<sup>+</sup> IO sphere water Reflected.Instrument Check on 2-15-68 Source 10mer

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK (contact)	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Personnel
IC-3	Response	Calibration	JA	Alarm OK
IC-4	Response	Calibration	JA	Press. = .07
CRM		Meter Trip		

9<sup>AM</sup>

Expt. 208. New concentration; water height in tank 67.5 cm.

R	k	Tab	Solution	Temp.	
~174.3					
V ~ 19.5	9 <sup>21</sup>	> 1	13.43	7.31 <sup>5</sup> - 7.32 <sup>5</sup>	25°C
	9 <sup>32</sup>	= 1	13.32	7.32 <sup>5</sup>	25°C
					5.389 liters

11<sup>AM</sup>

Expt. 209 New concentration; water height in tank 67.5 cm.

R	k	Tab	Solution	Temp.	
~161.9	11 <sup>16</sup> A	> 1	12.87	7.49 - 7.49 <sup>4</sup>	29.5°C
V ~ 21	11 <sup>30</sup> A	= 1	12.73 <sup>8</sup>	7.49 <sup>5</sup>	28.1°C
					5.483 L

1<sup>55</sup>

Expt. 210 New concentration; water height in tank 67.5

R	k	Tab	Solution	Temp.	
~151.1	1 <sup>30</sup> P	> 1	13.30	7.69 <sup>2</sup>	29.95°C
V ~ 22.5	1 <sup>52</sup>	= 1	13.15	7.70 <sup>2</sup>	28.75°C
					5.574 L

periods: IC-3 (H<sub>2</sub>O) ~ 4.4 dis/sec.IC-3 (C<sub>14</sub>H<sub>10</sub>) ~ 4.575<sup>-</sup> dis/sec.

After exper. 211 added 1.5 liters of water + mixed.

Est. vol in system 25 L  $\rightarrow$   $\rho \sim 136$

After Exper. 212 added 875 cc of water + mixed.

$\sim V$  25.875 L  $\sim \rho = 130.9/L$

After Exper. 213 added 360 cc  $H_2O$  + mixed.

$\sim V$  26.235  $\rho \sim 129.6$

Instrument Check on 2-20-68 Source 10mc

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Personnel
IC-3	Responds	Calibration	JH	Alarms OK
IC-4	Responds	Calibration	JH	Pass -0.07
IRM		Meter Trip		

Air Temp at reactor level  $34^{\circ}\text{C}$ 

9:06 AM Expt. 211 New Concentration ; water level in Reflector tank 67.5

9:20 A R Tnd solution Temp.

9:30 A >1 15.30<sup>5</sup> 7.82-7.83<sup>2</sup> 26.5<sup>o</sup>Cp~144.7 =1 15.15<sup>5</sup> 7.83<sup>5</sup> 26.5<sup>o</sup>C 5.633 l.V~23.5 periods: IC-3 (H<sub>2</sub>O) 6.825 div/secIC-4 (C<sub>25</sub>H<sub>12</sub>) 6.725 div/sec

11:48 A Expt. 212 R &gt;1 17.92 8.13 30.25

p~136 R=1 17.76 8.13<sup>4</sup> 29.60<sup>o</sup> 5.742 l.

2:15 P Expt. 213 New Concentration

p~130 2:34 P R >1 15.84<sup>5</sup> 8.37-8.37<sup>5</sup> 30.5<sup>o</sup>CR=1 15.69 8.37<sup>5</sup> 29.9<sup>o</sup>C 5.804

After Exp. 214 Add 300cc H<sub>2</sub>O and mix

$$V = 26.535 \quad \rho = 128.1$$

Experimental Periods

Pos. Period	IC-3	7.8 div/dec	169.5 sec	7.84
	IC-4	8.3 div/dec	180.4 sec	7.2
Neg Period	IC-3	20.5 div/dec	-445.5 sec	-3.6
	IC-4	21.6 div/dec	-469.4 sec	-3.4

Instrument Check on 2-21-68 Source 10mc

PM-1	Low Trip	OK	High Trip	OK
PM-2				
IC-1	$> 3 \times 10^{-4}$	Water Trip	OK	IP OK
IC-2	$> 3 \times 10^{-4}$	Water Trip	OK	Personnel
IC-3	Response	Calibration	OK	Alarmo ✓
IC-4	Response	Calibration	OK	Press - 0.02"
CRM		Meter Trip		

Expt. 214 New Concentration Rm. Temp. at Platform 35.5°C  
water level in reflector tank 68.2 cm.

8 <sup>45</sup> / <sub>A</sub>	R	TAD	Solution	Temp.	
9 <sup>02</sup>	> 1	21.21 <sup>4</sup>	8.44 <sup>2</sup> 844 <sup>9</sup>	27.3°C	
9 <sup>15</sup> / <sub>A</sub>	~ 1	21.11	8.44 <sup>9</sup>	27.4°C	5.819 L.

11 <sup>15</sup>	Expt. 215	New Conc.		Water level	67.0
11 <sup>25</sup>	< 1	16.62	8.76	30.6°C	
11 <sup>28</sup>	< 1	16.75	8.84	30.5	
11 <sup>33</sup>	~ 1	16.87 <sup>5</sup>	8.92	30.1	
11 <sup>36</sup>	> 1	16.87 <sup>5</sup>	8.92	29.8	pos. period
11 <sup>38</sup>	~ 1	16.70	8.82	29.7	
11 <sup>39</sup>	~ 1	16.66	8.80	29.7	
11 <sup>40</sup>	~ 1	16.60	8.77	29.6	
11 <sup>42</sup>	~ 1	16.57	8.74 <sup>8</sup>	29.5	ΔV = 746 cm <sup>3</sup>
11 <sup>44</sup>	< 1	16.40	8.62	29.4	neg. Period
11 <sup>53</sup>	< 1	16.40	8.62 <sup>3</sup>	29.1	5.840 L.

## Summary of solution concentrations for Exps. 208-218

Total mass 3.6605 kg U in system

Expt. No.	Vol (L)	g <sup>U</sup> /L	sp. gr.	H <sub>2</sub> O <sup>233</sup>
206	18.281	200.24	1.2448	126.05
207	19.781	185.05	1.2631	136.92
208	20.781	176.15	1.2504	144.16
209	22.281	164.29	1.2331	154.97
210	23.781	153.92	1.2178	165.76
211	24.781	147.71	1.2086	172.94
212	26.281	139.28	1.1964	183.76
213	27.156	134.79	1.1898	190.23
214	27.516	133.03	1.1877	192.74
215-218	27.816	131.6	1.1850	195.58

$$H_2O^{233} = \frac{233}{9(1.975)} \left\{ \frac{\text{sol'n density}}{\text{w density}} - 1.66929 \right\}$$

8.175  
20.781

↑  
these  
are  
in  
error

4/18/66



Instrument Check on 2-22-68 Source Low

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Test Trip OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	
IC-3	Response	Calibration		
IC-4	Response	Calibration		
CRM		Meter Trip		

Rm Temp. at Platform 29°C

Expt. 216 Repeat 215 new Temp. Water level in reflector tank 68.5cm

8:30	R	Tab	Solution	Temp.	
8:48 AM	> 1	14.92 <sup>5</sup>	8.49 <sup>5</sup> -850	25.3°	(R ~ 1.00053 at full)
	= 1	14.82 <sup>5</sup>	8.49 <sup>6</sup>	25.7°C	5.824 l.

Period IC-3 non linear.

IC-4 9 div/sec 195.6 sec.

9:39 Expt. 217 Have run pump ~30 min. to raise soln Temp.

9:57	> 1	14.83	8.63	27.0°C	(R ~ 1.00006 full)
	= 1	14.59	8.52	27.0°C	sphere has 1.1cc void
10:14	< 1	14.40	8.494	27.0°C	" " 16cc void
	<< 1			26.8°C	

Periods IC-3 6.1 div/sec 132.5 sec R ~ 10.7

IC-4 6.6 div/sec 143.4 sec 9.9

IC-3 -8.1 div/sec -176.0 sec -14.60

IC-4 -9.525 div/sec -206.97 sec -11.54

after  
Expt. 218

took sample # 28

Control No. E 16929 2/27/68

$$134.4 \frac{\text{mg } U^{235}}{\text{ml.}} \rightarrow 131.6 \frac{\text{g}}{\text{L}}$$

$$\text{sp. gr.} = 1.1890 \quad H/U^{235} = 195.5$$

$$M_c = .7685 \text{ g } U$$

2-27-68 Removed 8.62 IO sphere and installed  
15" annular cylinder.

Estimated crit. ht of solution

$$\frac{\pi^2}{(10.95 + 5.15)^2} = \frac{d_0^2}{(19.05 + 5.15)^2} + \frac{\pi^2}{(h + 4)^2}$$

$$(h + 4)^2 = \frac{\pi^2}{.03647 - .004133} = 305.12812 \text{ cm}^2$$

$$h + 4 = 17.4694 \text{ cm}$$

$$h = 13.47 \text{ cm} = 5.303 \text{ in.}$$

Expt. 219 IC-3 and IC-4 outside reflector tank.

If styrofoam is removed from bottom of  
vessel then we have

$$h + 7.5 = 17.4694$$

$$h = 9.9694 \text{ cm} = 3.92496 \text{ in.}$$

Area  $15'' = 0.14335 \text{ cm}^2$

211

Expt. 218 Change Temp.

H<sub>2</sub>O. 68.5

20<sup>2</sup>/<sub>PM</sub>  
2<sup>13</sup>/<sub>PM</sub>

R	T <sub>20</sub>	Solution	Temp.
>1	14.40	8.51 <sup>5</sup>	25.8°C
=1	14.27	8.51 <sup>5</sup>	26.0

$n = 1.00004$  for final solution

Instrument Check on 2-27-68 Source comes

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	Personnel	✓
IC-3	Responds	Calibration	JH	Alarms	✓
IC-4	Responds	Calibration	JH	Press	-0.07"
CRM		Meter Trip			

Expt. 219 15" annular cyl. with styrofoam on bottom.  
zero - .03 and lateral reflector of H<sub>2</sub>O.

R	T <sub>20</sub>	Solution	Water ht.	Temp.	ht of H <sub>2</sub> O above soln.
14 <sup>5</sup> / <sub>PM</sub> >1	14.93	5.31 <sup>15PM</sup> - 5.31 <sup>5</sup>	31.5 cm.	25°C	16.7 cm
=1	14.74 <sup>5</sup>	5.31 <sup>2</sup>	31.5 cm.		16.7 cm
=1	11.01	5.27	43.0		28.31
2 <sup>31</sup> / <sub>PM</sub> =1	13.29 <sup>5</sup>	5.29 <sup>6</sup> 5.30	35.3 cm		20.5

Water level at bottom of cylinder 1.3 cm.

Water thickness on bottom 24.16 cm.

Instrument Check on 2-28-68 Source 10 med

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Personnel ✓
IC-3	Responds	Calibration	OK	Alarms ✓
IC-4	Responds	Calibration	OK	Press - 2.07"
CRM		Meter Trip		

Zero - .03"

Exp. 220 15" annular cyl. styrofoam on bottom

Find critical height with water level at 37.4 cm.

8:30 AM

k	rad	solution	H <sub>2</sub> O	temp.
>1	12.725	5.25 <sup>s</sup>	37.4	24°C
=1	12.52	5.25 <sup>s</sup>	37.4	24°C
<1	12.52	5.25 <sup>s</sup>	36.3	24°C
=1	13.22	5.27 <sup>s</sup>	35.3	24°C

Exp. 221

Removed styrofoam from bottom. Bottom refl. now water

11:25 A

>1	12.62 <sup>2</sup>	4.63 <sup>s</sup>	34.4	25°C	
=1	12.45 <sup>s</sup>	4.63 <sup>s</sup>	31.4	25°C	
=1	12.30	4.63 <sup>y</sup>	32.8		
=1	12.23 <sup>s</sup>	4.63 <sup>y</sup>	33.1		
=1	12.04	4.63 <sup>1</sup>	33.5		
=1	11.84	4.63	34.2		
=1	11.64	4.62 <sup>s-3</sup>	34.9		
>1	11.64	4.62 <sup>s-3</sup>	35.4		
=1	11.46	4.62 <sup>s</sup>	35.4		
=1	11.26	4.61 <sup>c</sup>	36.0		
<1	11.26	4.61 <sup>c</sup> 4.62 <sup>7</sup>	32.2		damp water solid at 4.630

214

$$9\frac{7}{8} \text{ ID cyl} \Rightarrow A = 494.118 \text{ cm}^2$$

Estimate of 10" dia cyl. ht for  $k=1$  with styrofoam.

$$\frac{B^2(\text{ether})}{m} = \frac{B^2(\text{cyl})}{m}$$

$$.03647 = \frac{10^2}{(12.7+5.5)^2} + \frac{\pi^2}{(h+4)^2}$$

$$(h+4)^2 = \frac{\pi^2}{.03647 - .01746}$$

$$(h+4) = (519.17885)^{1/2}$$

$$h+4 = 22.7855$$

$$h = 18.7855 \text{ cm} = 7.40'' \rightarrow 6.8$$

Styrofoam Removed

$$h+7.5 = 22.7855$$

$$h = 15.2855 \text{ cm} = 6.02''$$

$$\text{From Expt. 221 ; } h+5.7 = 22.7855$$

$$h = 17.2855 = 6.81'' \rightarrow 6.2$$

10" Annular Cylinder

Instrument Check on 2-29-68 Source 10 mCi

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	Personnel
IC-3	Responds	Calibration	JA	Alarms ✓
IC-4	Responds	Calibration	JA	Perm. -0.07"
CRM		Meter Trip		

Exp. 222

Water height at bottom of 10" cyl. is 1.8 cm. Thickness bottom refl. 24.7 cm.

Solution rezero is +0.04.

Cylinder has styrofoam on bottom.

9:07 AM	R	Tad	Solution	H <sub>2</sub> O	Temp
9:15	>1	10.62'	6.81 <sup>5</sup>	43.5	25°C
9:25	=1	10.46	6.81 <sup>3</sup>	43.5	25°C
	=1	10.50 <sup>5</sup>	6.81 <sup>5</sup>	43.0	25°C
	=1	10.64	6.82	42.0	25°C

11 AM Exp. 223 Removed styrofoam - bottom refl. now water.

11:20 AM	>1	11.20 <sup>9</sup>	6.13 <sup>5-8</sup>	40.1	25°C
11:30	=1	10.05 <sup>8</sup>	6.13 <sup>5</sup>	40.1	25°C
	=1	11.12	6.14	39.8	25°C
	=1	11.20 <sup>6</sup>	6.14 <sup>4</sup>	39.1	25°C

216

3-1-68 Removed 10" dia cyl; installed 8" diam annular cyl.

Estimated critical ht with Styrofoam is 9.26"

" " " with H<sub>2</sub>O is 8.63"

7/3/80

Page	sp. gr.	$\frac{u}{g}$	Remarks (isotopic)
62	1.4750	353.2	colorometric w/ $^{238}U$
82	1.244	208.6 ( $\frac{33}{238}$ )	isotopic. $^{238}U$ cal.
91	1.2804	204.05	isotopic
134	9/6/67 1.1956	138.65	Free $H^+$ N = 0.37
142	(1.1867)?	103.69	" " <del>0.5</del> N
150	10/6/67 1.1832	130.72	" " 0.4 N
152	10/20 1.1675	116.81	" " 0.4 N
152	10/24 1.2117	100.76	" " 0.36 N
154	10/24 1.1442	102.52	" " 0.36 N
158	10/31 1.1441	99.68	" " 0.36
	1.0392	99.09	—
170	1.1186	83.23	—
180	1.0746	51.62	
188	1.0589	44.6	
200	1.2796	200.24	(spec.)
202	1.2529	190.45	—
210	1.1890	131.6	—
218	1.1848	133.85	
220	1.1544	110.25	
231	1.1401	94.998	
238	1.0683	47.8	
	1.0658	49.7	

Check Parrott's Transfer envelope. —

$H^+ \rightarrow 0.325 N$   
 $e \approx 1.174$   
 pp. 7



8" annular cylinder  
 Area = 324.29 cm<sup>2</sup>

Instrument Check on 3-1-68 Source LO met

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			High Trip	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Personnel
IC-3	Responds	Calibration	OK	Alarm
IC-4	Responds	Calibration	OK	Pres. -0.07
CRM		Meter Trip		
Expt. 224	align zero -0.02"			

Water level at bottom of cylinder is 2.0 cm. (25 cm)

Cylinder has styrofoam on bottom

Time	R	Tad	Solution	H <sub>2</sub> O	Temp.
10 <sup>20</sup>					
10 <sup>32</sup>	>1	11.01 <sup>†</sup>	8.98 <sup>5</sup>	48.5	25°C
10 <sup>45</sup>	=1	10.81	8.98 <sup>4</sup>	48.5	25°C
	=1	10.82	8.98 <sup>4</sup>	48.0	
	=1	10.86	8.98 <sup>4†</sup>	47.8	
	=1	10.89	8.98 <sup>5</sup>	47.5	
	=1	11.01	8.98 <sup>5</sup>	46.1	

11<sup>20</sup> Expt. 225 Removed styrofoam. bottom refl. now Water.

11 <sup>32</sup>	>1	12.11	8.31 <sup>9</sup>	8.32 <sup>1</sup>	46.0	25°C
11 <sup>45</sup>	=1	11.91	8.31 <sup>2</sup>		46.0	25°C
	=1	12.11	8.32 <sup>6</sup>		43.70	25°C

218

3/8/68 to 3/14/68

Sphere leaked when first installed. Crack found in bottom entry tube to sphere. Sphere welded and inside coated with Glyptol.

Recalibrate sphere.

Installed sphere 3/15/68 checked for leaks none observed.

After Expt. 226

Removed 12.7 liters of solution.

Took Sample No. 29.

Added 4.9 liters of  $H_2O$  and mixed 2 hrs.

Total volume of solution ~ 20 liters containing 1.9875 kg U.

3/19/68 Sample 29 Control do. E 16994

$$136.7 \text{ mg/ml as } U^{238} \Rightarrow 136.7 \times \frac{233.08}{238.04} = 133.85 \text{ g/l.}$$

$$\text{sp gr.} = 1.1848$$

$$H/U^{233} = 190.7$$

Instrument Check on 3/15/68 Source 10mc $\gamma$

FM-1		Low Trip	OK	Alarm Trip	OK
FM-2				Alarm Trip	
IC-1	> $3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	> $3 \times 10^{-4}$	Meter Trip	OK		Personal $\checkmark$
IC-3	Responds	Calibration	OK		Alarm $\checkmark$
IC-4	Responds	Calibration	OK		Pres - 0.04"
CRM		Meter Trip			

Selwyn zero -0.03 power off selwyn reads .8914?

Exp. 226 sphere is full at selwyn reading of  $8.69 + .03 = 8.72^{\circ}$

	<del>kg</del>	tad.	Solution	Water	Temp	
10:54 AM	>1	11.06	6.87 <sup>5</sup>	66 cm.	23.7°C	Vol: 6.16 l.
11:08	>1	11.06	6.98 <sup>5</sup>	66 cm.	23.7°C	
11:15	=1	10.92	6.98 <sup>5</sup>	66 cm.	23.7°C	

220

After Expt. 222 took sample 30

Estimated critical conc. at full is 0.94 kg/l.

Need to add 1.2 liters of water

3/18/68 ∴ add + mix. JA

$$\frac{23308}{23804} = .97916$$

3/20/68 Sample 30 Control No. E 16998

112.6 mg/ml as U<sup>238</sup> 110.25 g/l

$$H/U^{233} = 233.7$$

1.1544 sp. gr.

Instrument Check on 3-18-68 Source Comed

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2				
IC-1	$> 3 \times 10^{-11}$	Meter OK	OK	OK
IC-2	$> 3 \times 10^{-11}$	Meter OK	OK	Personnel <input checked="" type="checkbox"/>
IC-3	Responds	Calibration	OK	Alarms <input checked="" type="checkbox"/>
IC-4	Responds	Calibration	OK	Pres -0.05"
CRM		Meter Trip		

Exp. 227 New Concentration

Time	K	t <sub>ad</sub>	Solution	H <sub>2</sub> O	Soln. Temp.	Soln. Vol.
9 <sup>45</sup> AM	K	t <sub>ad</sub>	Solution	H <sub>2</sub> O	Soln. Temp.	Soln. Vol.
9 <sup>13</sup> AM	>1	14.11	8.11 <sup>5</sup>	65.8 cm.	23.8°C	6.798 L.
9 <sup>22</sup> AM	=1	13.97	8.10 <sup>9</sup>	65.8	23.8°C	6.796 L.

Exp. 228 New Concentration

1 <sup>PM</sup>	≤1	12.33	9.00	65.8	26.3°C
1 <sup>55</sup>	≤1	12.33	8.98 <sup>9</sup>	65.8	25.3°C
2 <sup>PM</sup>	≤1	12.67	9.21	65.8	25.1°C

222

3/22/68  
By pass open 1 3/4 turns

6.90 Ross sphere

Instrument Check on 3-19-68 Source 10mc

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	Personnel	OK
IC-3	Responds	Calibration	JK	Alarms	OK
IC-4	Responds	Calibration	JK (poor)	Pres.	-0.05"
ORW		Meter Trip			

Expt. 229 Same as 228 "lower temp".

8 <sup>45</sup>	R	Tad	Solution	H <sub>2</sub> O	Temp.
9 <sup>05</sup>	≤ 1	11.58	9.21	65.8 cm	24.2°C
9 <sup>08</sup>	≤ 1	12.70	10.02	65.8	24.2
9 <sup>14</sup>	≤ 1	14.04	11.00	65.8	24.2
9 <sup>23</sup>	> 1	15.41	12.01	65.8	24.3
9 <sup>40</sup>	= 1	14.32	11.21	65.8	24.4°C
9 <sup>43</sup>	< 1	10.90	8.75	65.8	24.4
9 <sup>48</sup>	> 1	16.00	12.44 <sup>5</sup>	65.8	24.4
10 <sup>11</sup>	≤ 1	14.32	11.22	65.8	24.4
10 <sup>12</sup>	= 1	14.42	11.28 <sup>5</sup>	65.8	24.4
10 <sup>14</sup>	< 1	12.70	10.0	65.8	24.4

3/20/68

Removed 6.96 liter sphere and installed  
15 in dia annular cylinder.

10<sup>35</sup> AM By pass open 2 turns - head at 3.8" reduces feed to zero

reset By pass to 1<sup>3</sup>/<sub>4</sub> head at 3.9 " " " "

Defective bypass valve - need to replace <sup>diaphragm.</sup> gasket.

1<sup>5</sup> PM By pass open 2 turns with new diaphragm.



15" Dia. Annular cylinder.

Instrument Check on 3-20-68 Source 10 mc  $\gamma$

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Post Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		Personnel $\checkmark$
IC-3	Responds	Calibration	5X		Alarms $\checkmark$
IC-4	Responds	Calibration	5X good		Pres -0.05"
CRM		Meter Trip			

Expt 230

setpoint zero is +.03"

Bottom reflector thickness 24.2cm

145  
145  
145

R	T <sub>ad</sub>	solution	water	Temp
21	27.00	4.04	39.5	24°C

seem to have exhausted solution supply.

145

set by pass open 1/2 turn

21	39.18	4.935	39.5	24°C
----	-------	-------	------	------

exhausted supply.

Vol in vessel is ~14.5 liters  $\therefore$  estimate hold-up of system to be about 5.5 liters.

226

3/21/68

Removed 15" dia annular cyl.

Installed 10" dia " " with Styrofoam on both

Bypass open 2 turns.

10" Annular Cyl.

Instrument Check OK 3-21-68 Source 10mc

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$>3 \times 10^{-4}$	OK	Fast Trip	OK
IC-2	$>3 \times 10^{-4}$	OK		Personnel <input checked="" type="checkbox"/>
IC-3	Responds	OK		Alarms <input checked="" type="checkbox"/>
IC-4	Responds	OK		Pres -0.05"
ARM	Meter Trip			

Expt. 231 10" Annular cylinder with Styrofoam bottom refl.

selyr zero -0.025"

bottom refl. thickness 24.4 cm.

	k	Tad	Solution	Water	Temp.
10 <sup>01</sup> AM	>1	4.63	7.72 <sup>3</sup> <sup>→5</sup>	45.0 cm.	25°C
10 <sup>14</sup>	=1	4.43	7.72 <sup>1</sup>	45.0 cm.	25°C
	=1	4.48	7.72 <sup>2</sup>	44.5	25°C
	=1	4.54	7.72 <sup>4</sup>	44.0	25°C
	=1	4.63	7.72 <sup>5</sup>	43.5	25°C

10<sup>55</sup> A Expt. 232 Have removed styrofoam from bottom of cyl.

11 <sup>07</sup>	>1	4.71	7.03 <sup>1</sup>	42.6	25°C
	=1	4.46 <sup>5</sup>	7.02 <sup>8</sup>	42.6	25°C
	=1	4.51	7.03	41.4	25°C

228

3/22/68

Removed 10" dia cyl and installed 8" dia  
annular cyl. with styrofoam on bottom

8" dia Annular Cyls

Instrument Check on 3-22-68 Source 10mc X

PM-1 Low Trip OK Alarm Trip OK  
 PM-2 Alarm Trip  
 IC-1 > 3 x 10<sup>-4</sup> Meter Trip OK Fast Trip OK  
 IC-2 > 3 x 10<sup>-4</sup> Meter Trip OK Personnel ✓  
 IC-3 Responds Calibration FA Alarms OK  
 IC-4 Responds Calibration FA less - 0.05"  
 SRM Meter Trip  
selyn zero reads + 0.07"

Exp. 233

8" cylinder has styrofoam on bottom.

there are 25 cm of reflector water on bottom of vessel.

Time	R	t <sub>adj</sub>	Solution	H <sub>2</sub> O	Temp.
2:01 PM	>1	4.73	10.71 <sup>3</sup>	52.1 cm	25°C
2:20 PM	=1	4.45	10.70 <sup>7</sup>	52 cm.	25°C
	=1	4.63	10.71 <sup>1</sup>	48.9	25°C
	=1	4.73	10.71 <sup>3</sup>	48.6	25°C

2:52 PM Exp. 234 Removed styrofoam from bottom of cyl.

3:27	>1	4.17 <sup>5</sup>	10.08 <sup>1</sup>	<del>47.5</del> 50.9	25°C
	=1	3.73	10.07 <sup>0</sup>	50.9	25°C
	=1	3.76	10.07 <sup>0</sup>	50.2	25°C
	=1	4.17	10.08 <sup>9</sup>	45.8	25°C

230.

3/26/68

Installed 12.985 liter sphere.

Expt. 235

R	T <sub>ad</sub>	rel <sub>exp</sub>
<1	5.55	6.74
	6.32	6.76
	6.62	6.77
	6.92	6.78
	7.30	6.79
	7.60	6.80
	7.95	6.81
<1	8.30	6.82
~1	8.60	6.83

After Expt. 235 took sample #31A+B

Drained 7.4 liters of solution from system

Added 16.4 liters of water and wiped.

12.985 liter Sphere

Instrument Check on 3-26-68 Source low

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-4}$	Water Trip	OK	Alarm Trip OK
IC-2	$> 3 \times 10^{-4}$	Water Trip	OK	Personnel <input checked="" type="checkbox"/>
IC-3	Responds	Distillation		Alarms <input checked="" type="checkbox"/>
IC-4	Responds	Distillation		Pass
CRM		Water Trip		

selsyn zero: 0.0

Expt. 235

	k	Tad	Solution	Water	Soln Temp.	
2:15 PM	>1	8.86	$6.84^{-2}$	66 cm.	24.5°C	9.050 liter
2:18	=1	8.70	$6.83^5$	66 cm.	24.5°C	

Sample 31A Control No. E 17020

92.02 mgU/ml as U<sup>238</sup>

94.998 gU/g.

sp. gr. 1.1401

232

After Expt. 236 added 500 cc of solution from Expt. 206.

After Expt. 237 added 500 cc of solution from Expt. 206



12.985 liter sphere

Instrument Check on 3-27-68 Source 10 me d

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			<del>Alarm Trip</del>	
IC-1	> 3 x 10 <sup>-4</sup>	Meter Trip	OK	Fast Trip OK
IC-2	> 3 x 10 <sup>-4</sup>	Meter Trip	OK	Personnel ✓
IC-3	Responds	Calibration	JK	Alarms OK
IC-4	Responds	Calibration	JK	Pres - 0.05"
CRM		Meter Trip		

Expt. 236 try new concentration

Selwyn: power off in .99198<sup>5</sup> reads 0.0.

K	Tad	Solution	Water	Solution Temp
<1	14.24	12.09	66 cm	24.5°C

Expt. 237 try new concentration

<1	14.10	13.00	66.	29°C
----	-------	-------	-----	------

234

after Expt. 238 added 400 cc of solution from Expt. 206

after Expt. 239 added 400 cc of solution from Expt. 206

12.985 liter Sphere.

Instrument Check on 3-28-68 Source cornet

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	$>3 \times 10^{-11}$	Meter Trip	OK	Fact Trip	OK
IC-2	$>3 \times 10^{-11}$	Meter Trip	OK		Personnel ✓
IC-3	Responds	Calibration	FA		Alarms OK
IC-4	Responds	Calibration	FA		Pres - 0.05"
IC-5		Meter Trip			

Exp. 238 New Concentration.

Depth of water above sphere is 7 in.

Time	K	Tad	Solution	Water	Soln Temp.
8:40 AM	<1	12.28	13.02	66 cm.	25.2°C

1:45 PM Exp. 239 New Concentration

2:02 PM	<1	13.08	15.02	66 cm.	27.5°C
---------	----	-------	-------	--------	--------

236

*After Expt 240 added 200 cc of Solution from Expt 206.*

Instrument Check on 3-29-68 Source 10mcI

PM-1		Low Trip	OK	Alarm Trip	OK
PM-2					
IC-1	$> 3 \times 10^{-4}$	Motor Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Motor Trip	OK		Personnel
IC-3	Responds	Calibration	OK		Alarm OK
IC-4	Responds	Calibration	OK		Pres -0.05"
		Motor Trip			

Expt. 240 new concentration

	k	rad	Solution	H <sub>2</sub> O	Temp.
9:30 AM	±1	14.54	15.02	66cm.	26°C

system subcritical. add 200 cc solution from Expt 206.

	Expt. 241	new concentration			
2:20 PM					
2:44	>1	14.385	14.985 15.005	65-8cm.	27.9°C
2:53 PM	=1	9.82	11.21	65-8cm.	27.5°C

238.

after Expt. 242 took Samples 32A + B

4/4/68 Control No. E 17033

sample 32A

48.82 mg/ml as U<sup>238</sup>

47.803 g/l.

1.0683 sp. gr.

H/U<sup>238</sup> = 549.1

Sample 32B

4-23/68

50.75 mg/ml as U<sup>238</sup>

1.0658

Instrument Check on 4-1-68 Source 10m x

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	> 3x10 <sup>-11</sup>	Water Trip	OK	Fast Trip	OK
IC-2	> 3x10 <sup>-11</sup>	Water Trip	OK	Personnel	✓
IC-3	Responds	Calibration	OK	alarms	✓
IC-4	Responds	Calibration	OK	Pres	-0.05"
CRM		Water Trip			

Experiment 242 Repeat 241 new temp.

8 <sup>40</sup> A	R	Tab	Solution	H <sub>2</sub> O	Temp.
8 <sup>59</sup>	> 1	8.29	10.86 <sup>5</sup>	65.8cm.	25°C
9 <sup>06</sup> A	= 1	7.95	10.82	65.8	25.2°C
	≤ 1	7.55	10.82	61.8	25.2°C
		7.95	10.82 <sup>5</sup>	0	
		8.05	10.85		
		8.15	10.85 <sup>5</sup>		
		8.25	10.86 <sup>0</sup>		
		8.35	10.85 <sup>5</sup>		
		8.45	10.86 <sup>5</sup>		
		8.55	11.05		
		8.65	11.13		
		8.75	11.21		

check full height.

240

Removed spec + installed 10" dia. Annular cylinder  
with styrofoam on bottom.



Exp. 243 10" annular cyl. Reflected / styrofoam bottom.

Refl. thickness on bottom 24.4 cm.

Seleny gas + .04"

2<sup>PM</sup>

225

k	t <sub>ad</sub>	Solution	H <sub>2</sub> O	Temp.
>1	7.66 <sup>5</sup>	12.45 <sup>0</sup>	60.5	26°C
=1	7.14	12.44 <sup>2</sup>	60.5	
≅1	7.17	12.44 <sup>2</sup>	60.0	
=1	7.25 <sup>5</sup>	12.44 <sup>2</sup>	58.9	
=1	7.66 <sup>5</sup>	12.45 <sup>5</sup>	55.5	

Exp. 244 Removed styrofoam.

3<sup>10</sup>

>1	7.42	11.80 <sup>5</sup> (2)	55.0	26°C
=1	6.80	11.79 <sup>5</sup>	55.0	
=1	6.83	11.79 <sup>5</sup>	54.3	
=1	7.42	11.81	50.0	

242

Est ht 18.4"

19.1 w/styrofoam.

Instrument Check on 7-2-68 Source 10mcY

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Personnel $\checkmark$
IC-3	Responds	Calibration	FA	Alarms $\checkmark$
IC-4	Responds	Calibration	FA	Pres - 0.05"
CRM		Meter Trip		

Expt. 245 8" cyl. w/ styrofoam on bottom.

Layn zero  $\pm 0.02$ " 25cm refl. on bottom

k	Tad	Solution	H <sub>2</sub> O	Temp	
<1	-	> 20"	74 cm.	25°C	check expectations before proceeding.

Instrument Check on 4-4-68 Source 10mcY

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Personnel
IC-3	Responds	Calibration	FA	Alarms
IC-4	Responds	Calibration	FA	Pres - 0.04"
CRM		Meter Trip		(Replacing door)

Expt. 246.

k	Tad	Solution	H <sub>2</sub> O	Temp
<1	39.18	26.67	103 cm.	25°C

exhausted solution supply.

Expt. 247 Removed styrofoam from bottom of vessel.

k	Tad	Solution	H <sub>2</sub> O	Temp
<1	39.18	26.87	103 cm.	26°C

exhausted solution supply.

4/4/68 Installed 15" dia annular cylinder  
with styrofoam on bottom.

Instrument Check on 4-5-C8 Source 10 mcd

PM-1	Low Trip	OK	High Trip	OK
PM-2				
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Personnel ✓
IC-3	Responds	Calibration	JH	Alarms ✓
IC-4	Responds	Calibration	JH	Pres. -0.04
CRM	Meter Trip			

Selsyn zero + 0.01

bottom refl. thickness 24.2 cm.

Expt 248 15" cyl. w/ styrofoam bottom reflector.

855	R	Tad	Solution	H <sub>2</sub> O	Temp.
917	>1	4.21	7.71 <sup>05</sup>	48.0	25°C
	=1	3.82	7.71	48.0	25°C
	=1	3.98	7.71	47.0	25°
	=1	4.21	7.71 <sup>2</sup>	46.0	25°
	=1	4.54	7.71 <sup>9</sup>	44.7	25°
	=1	4.76 <sup>8</sup>	7.72 <sup>2</sup>	43.7	25°

Expt. 249 Removed styrofoam from bottom of vessel.

1040	R	Tad	Solution	H <sub>2</sub> O	Temp.
1055	>1	9.39	7.12 <sup>9</sup>	42.0	26°C
	=1	9.06 <sup>5</sup>	7.12 <sup>5</sup>	42.0	26°C
	=1	9.39	7.13 <sup>-</sup>	41.0	26°C

256

92763

