

BOOK62R

Notes:

"CE-2 Pulsing 1960" on spine

Blank pages: inside front cover sheets, 2, 7, 20, 22, 46-49, 80, 93, 115, 144, 146-152, inside back cover sheets

-page 8 has sheet taped to it

-page 14 has sheet taped to it

-page 50 has sheet glued to it

-pages 62/63 has calendar sheet (4/3/63) between pages

Scanned by:

Sheila Finch

RSICC /Oak Ridge National Lab.

August 19, 1999

Page

TABLE OF CONTENTS

3 STD Pile GOLD IRRADIATION - 20 channel analysis Calib.

9 HFIR GOLD IRRADIATION - 211 Min ~~in N(3)~~ ~~in~~

23 HFIRCE#2 EXP# 233

Preliminary experiments for measuring absolute thermal neutron flux in the center of the HFIR flux trap critical experiment.

Preliminary gold foil irradiation in Standard Pile

Gold Foil #7 $\approx 1 \text{ cm}^2$ 1.11cm OD x 0.0055 in.

weight = 0.2616 gm

1-8-60 5:01 PM Began Exposure Slot #1 Std Pile (thermal flux 1.35×10^4

1-12-60 10:57 AM End " " " neut/cm²/sec

Exp Time = 89 hr 56 min.

20 Channel Analyzer with 3x3 NaI (th) Xtal 6363

Photo multiplier voltage ≈ 8000 adj @ gain of 16

so that C_{5137} peak at 660 on E dial + channel

For gold counting, set E dial at 295 therefore first channel at ≈ 300 Mev and gold 411 keV at channel 11.

3x3 NaI Crystal Efficiency @ 411 keV

Bell (ORN L)

Heath (MTR)

Peak / total 0.70

0.76

Peak .50

total .704

Solid angle .0373

total abs 0.026

Peak 0.1825

Peak 0.01976

or 0.0190

Counting data @ E = 295

Start time	1-12-60	4 ¹⁰	5 ⁰³ PM	8 ⁰⁸ AM 1-13-60
End	3:46 PM	4 ⁵⁸	8 ⁰³ AM	11 ⁰⁴ stop
Counter	48'	48'	15 hr	176 Min
Dist	9.3 Foil #7	9.3 Foil #7	Bkg	9.3 cm Foil #7
Total	210 + 60	204 + 33	1374 + 181	651 + 36
1	22 + 8	23 + 13	273 + 14	78 + 9
2	21 + 14	23 + 11	282 + 14	77 + 13
3	31 + 1	30 + 15	422 + 0	108 + 14
4	28 + 14	25 + 14	367 + 2	95 + 1
5	21 + 6	20 + 14	273 + 1	81 + 15
6	23 + 10	27 + 10	263 + 12	93 + 1
7	34 + 4	33 + 5	240 + 14	151 + 15
8	62 + 13	61 + 12	217 + 5	305 + 4
9	144 + 13	136 + 3	207 + 7	633 + 0
10	255 + 14	256 + 9	204 + 9	1046 + 4
11	380 + 12	393 + 0	300 + 12	1329 + 12
12	452 + 15	436 + 9	201 + 4	1319 + 2
13	373 + 9	367 + 13	201 + 5	898 + 14
14	241 + 7	227 + 14	186 + 4	461 + 7
15	121 + 2	117 + 5	185 + 15	210 + 0
16	48 + 13	44 + 5	185 + 3	83 + 3
17	23 + 15	22 + 8	195 + 13	57 + 12
18	14 + 4	13 + 5	185 + 5	42 + 8
19	14 + 12	13 + 5	205 + 7	45 + 15
20	14 + 14	14 + 13	231 + 15	50 + 8
Surplus	21981 ¹⁵⁷ / ₃₅₃₂₅	21541 ¹¹⁰ / ₃₄₆₀₀	205 ⁵¹⁴¹⁰ / ₃₂₁₃	6772 ¹¹⁰ / ₁₁₀ = 107657
	50 + 136	50 + 138	899 + 185	178 + 208

From the plots of net counts, sum of channels 9-20 give a very good area under peak.

Total Background in channels 5-20 $\frac{51410}{900} = 57.122$ c/min

48' Background	2742
176' "	10054

1st Count $A_{set} = \frac{32583}{(35325 - 2742) \times 2.972 \times 10^{-6}} \frac{1}{E} \lambda = .00017831/min$
 $.95795 \times .00851903 \times .61779 \lambda = 2.972 \times 10^{-6} sec^{-1}$
 $e^{-\lambda t_w} (1 - e^{-\lambda t_c}) (1 - e^{-\lambda t_e})$
 $= \frac{0.096837}{.00504165} \frac{1}{E} = 19.207 \frac{1}{E}$

2nd Count $A_{set} = \frac{31918}{(34660 - 2742)} \frac{1}{E} \lambda = .00017831/min$
 $.94574 \times .00851903 \times .61779$
 $= \frac{0.94860}{.0049774} = \frac{19.058}{E} = .0148$

3rd Count

$$A_s = \frac{97603}{107657 - 10054}$$

$$.797355 \quad \text{---} \quad .202645 \times .61729$$

$$\text{sigma} \quad .0308833$$

$$A_s = \frac{290076}{015213} \frac{1}{E} = \frac{19.068}{E}$$

Average 19.058 wt 3
 19.207 wt 3
 19.068 wt 11

$$A_{sat} = \frac{19.091}{E = .0190} = 1.005 \times 10^3$$

	Background				Gold #UP			Sid. (Foot) Over	Bkey	Gold #UP
Time	909-1009	1015-1115	1211-11	131-237	243-259	305-321	328-400	406-438	445-807 AM	
	E=0	E=200	E=400	E=300	E=300	300	300	300	300	812 900
Total	594+124	110+165	91+240	103+24	882+53	877+36	1748+84	1724+87	425+5	2202+80
1	746+1	23+2	13+3	17+6	60+4	61+1	119+14	117+4	275+7	163+6
2	409+8	21+13	12+4	18+15	52+15	55+0	110+10	112+12	276+5	140+8
3	121+10	37+12	21+2	30+10	61+4	59+1	114+14	119+0	437+3	150+0
4	49+12	29+1	17+6	23+15	58+5	59+12	116+11	112+1	350+9	146+14
5	50+4	21+14	12+3	19+1	64+6	67+6	124+2	122+5	265+4	154+9
→ 6	54+9	19+11	12+13	15+9	89+13	95+11	184+6	176+1	268+1	220+8
7	56+10	18+8	12+1	15+6	190+5	189+0	361+10	346+0	237+8	399+3
8	55+3	19+11	12+3	14+8	455+15	471+2	937+1	903+15	227+4	1052+14
9	37+15	17+0	13+9	14+7	1014+12	1075+7	2122+1	2078+8	212+8	2409+7
10	28+12	16+1	11+13	13+6	1888+12	1946+11	3882+10	3758+3	207+6	4569+10
11	26+6	24+4	19+12	17+10	2513+10	2543+0	5058+9	4966+15	268+0	6193+11
12	22+14	17+0	13+9	12+8	2855+2	2830+13	5608+15	5545+6	195+6	7118+3
13	20+15	18+12	11+13	12+4	2208+14	2099+13	4199+10	4205+15	192+13	5561+2
14	22+7	18+10	12+12	11+2	1265+14	1203+2	2435+14	2426+12	188+3	3275+8
15	21+12	17+15	11+2	13+0	566+3	578+7	1038+12	1067+9	186+11	1485+7
16	19+2	15+15	11+0	11+10	191+15	180+7	342+7	351+0	175+2	502+11
17	21+0	13+9	11+8	10+12	62+8	54+5	112+13	117+11	193+1	157+6
18	21+5	15+7	11+8	12+0	23+9	22+3	42+0	46+0	195+8	58+12
19	23+12	14+2	12+7	13+1	17+6	17+4	33+9	33+6	219+10	43+6
20	23+8	15+12	12+14	13+15	16+2	14+10	31+1	32+4	247+3	53+10
Surplus	89+177	66+244	57+214	58+147	26+217	25+189	52+90	51+249	902+35	72+220
Count Time	60'	60'	60'	60'	16'	16'	32'	32'	922'	48'
Σ 6-20	1823+116	386+149	258+142	195+98	13332+140	13256+95	26384+118	26019+94	3144+84	33044+118
(200) C/M	488.88	105.42	71.17	3218	213452	212191	422262	416398	51278	529622
IC-3 Red 0.52x10 ⁻⁹				53633	858	858	1716	1716	55616	2670
IC-4 Blue 0.070x10 ⁻⁹					212594	211333	420541	414682		526952

#65 Gold Foil weight gm

1-19 9⁵⁹ AM Start of Irradiation in center of Annulus. }
 1³⁰ PM End of Irradiation " " " " } 211 MINUTES (Total)

$$\ln N(\text{IC-3}) = 0.57 \times 10^{-9} \quad \ln N(\text{IC-4}) = 0.07 \times 10^{-9}$$

1³⁷ - 2³⁷ Bkg Count $E=300$

2⁴³ Start 1st 16' Count $E=300$ Bkg Corrected Count = 212,594

3⁰⁵ Start 2nd 16' Count $E=300$ 211,353

3²⁸ Start 3rd Ct, 32' Count $E=300$ 420,546

4⁰⁶ Start 4th Ct 32' Count Reverse Side of Foil. 414,682

4⁴⁵ PM Start Bkg Count

1-20 8⁰⁷ AM End Bkg Count } 15 hrs 22' = 922'

8¹² AM Start Foil Count } 18 hr 42'

9⁰⁰ AM Stop " " } 48' 526,952

1-20-60

1st Count $t_c = 16'$ $1 - e^{-\lambda t_c} = .00284778$
 $t_w = 73'$ $e^{-\lambda t_w} = .98907226$
 $t_{exp} = 211'$ $1 - e^{-\lambda t_c} = .03691033$
 $.96842589 \times 9944898 = .96308967$

$$A_{sat} = \frac{212594 \times 2.972 \times 10^{-6}}{.103754 \times 10^{-3}} \frac{1}{E}$$

$$= \frac{6.0897 \times 10^3}{E}$$

2nd Count $t_w = 95'$ $e^{-\lambda t_w} = .98320975 \times .1051125 \times 10^{-3}$

$$A_{sat} = \frac{211333 \times 2.972}{.103348} = \frac{6.0773 \times 10^3}{E}$$

3rd Count $t_c = 32'$ $1 - e^{-\lambda t} = .00568744$
 $t_w = 118'$ $e^{-\lambda t} = \frac{97918732}{.02081264} \times 5.569069 \times 10^{-3}$
 $t_c = 211'$ $1 - e^{-\lambda t} = .03691033$
 $\frac{.118371 \times 10^{-3}}{.03691033} = \frac{205556}{.03691033} \times 10^{-3}$

$$A_{sat} = \frac{420546 \times 2.972 \times 10^{-6}}{210045 \times 10^{-3}} = \frac{6.0804}{.03691033} \times 10^{-3}$$

4th Count $t_c = 32$ $.00568744$
 $t_w = 154'$ $.97292434$
 $t_c =$ $.03691033$
 204.241×10^{-3}

$$A_{sat} = \frac{414682 \times 2.972 \times 10^{-6}}{.204241 \times 10^{-3}} = \frac{6.0342 \times 10^3}{E}$$

5th Count t_{exp} 211' 036 910 33
 t_c 48' .008 519 03
 t_w 18 hr 42'
 $e^{kt} = .99254187$
~~82.489438~~
 $.81871221 \rightarrow .25744547$

$$A_{sat} = \frac{526952 \times 2.972 \times 10^{-6}}{.25744547 \times 10^{-3}} = \frac{6.0832}{E} \times 10^3$$

Weighted Average

$$A_{sat} = \frac{6.072 \times 10^3}{E}$$

$$\text{If } E = 0.0190 \quad A_{sat} = 0.31958 \times 10^6$$

$$\text{Equip th flux} = \frac{0.31956 \times 10^3}{1.005 \times 10^3} \times 1.354 \times 10^4 = 4.3056 \times 10^6 \text{ neut/sec}$$

1-28-60 Counted #65 overnight 7³⁷ to 8⁰⁹ AM-128
 Netals 1,139,618. 1-27-60

$$A_{sat} = \frac{6.084 \times 10^3}{E}$$

1-21-60

Date	1-21-60						
TIME	10 ²² AM	10 ⁴¹ A	11 ⁰⁶ A	12 ⁵⁷ PM	1 ¹⁶ PM		
Count	16'	16'	16'	16'	16'		
Gain	16	16	16	16	16		
E	0	200	400	0	0		
Total	1072 ⁺²⁰	632+224	430 ⁺²¹⁷	1035+59	1030+7		
1	219+6	168+1	1572+6	215+11	253+6		
2	341+3	171+1	1700+1	328+9	341+1		
3	326+0	179+12	1548+9	275+10	279+12		
4	261+5	172+12	985+7	246+4	261+13		
5	266+10	142+14	461+14	252+10	254+2		
6	554+11	105+8	167+0	552+10	548+14		
7	738+10	76+12	52+8	702+6	705+3		
8	433+15	67+1	19+9	417+9	416+7		
9	211+15	53+2	12+10	214+5	207+9		
10	170+1	44+6	10+13	163+12	163+10		
11	177+4	39+15	11+2	153+15	157+14		
12	152+4	38+5	10+6	152+0	154+6		
13	150+3	34+1	7+7	155+10	151+12		
14	149+10	34+12	6+7	150+4	153+7		
15	162+2	39+11 47+14	6+5	159+1	155+1		
16	171+7	47+15 48+5	5+6	170+10	169+2		
17	173+5	49+11 46+10	6+11	170+10	169+9		
18	158+1	46+10 47+10	6+5	158+13	161+12		
19	152+12	47+10 47+10	4+10	143+9	143+1		
20	189+7	1731+12	9+12	179+1	176+12		
Surplus	628+14	387+86	18+88	612+97	609+33		
	5152+3	3888+187			5024+36		
Σ 20	5144+131	3890+155	6596+148	4953+159	5015+180		
(256)	322+137	243+189	412+212	310+47	314+36		
20+Surplus	956+117	631+17	431+20	922+144	923+69		

1-21-60

Additional data taken with 3" Scin XR
and 20 channel analyzer with #65 gold foil
to get peak - Total ratio.

Trouble indicated on 20 channel analyzer
with $t=0$, Total Count \neq 20 channels + surplus.

		Bkg		
0 - 200	5144 + 131	7822		
200 - 400	3890 + 155	¹⁶⁸⁷	add writing 19'	.99661917
400 - 600	6596 + 148	¹¹³⁹	" " 44'	.99218811

Total - Bkg 0 - 200	74 613		
200 - 400	60 708	$\times .99661917 =$	60 914
400 - 600	104 545		$= 105 368$

Total Count ~~Rate~~ = 240,895 $t_w = 44 \text{ hr } 52'$

$$A_s = \frac{715940 \times 2.972 \times 10^{-10}}{0.65 \times 0.53 \times 29 \times 10^{-3}} \times \frac{1}{E} \quad (He \text{ - } t_{exp} = .03691033)$$

$$\text{Total } A_s = \frac{11.0054 \times 10^3 \times 10^{-10}}{E} \times \frac{1}{E} \quad \begin{matrix} .99077434 \\ .62465526 \\ .618892 \end{matrix}$$

$$\frac{\text{Peak}}{\text{Total}} = \frac{6.072}{11.0054} = 0.5517$$

Using data of 1-21-60 only

$$\frac{\text{Peak}}{\text{Total}} = \frac{118500}{240900} = 0.493$$

1-25-60

Standard Counters on #65 gold foil (Estabrook)

Prop. Gas Flow Counter $A_s = 1.79 \times 10^6 / \epsilon$ dis/minScint $A_s = 3.90 \times 10^6 / \epsilon$ Blower 4π (Scint) $A_s = 1.72 \times 10^6 / \epsilon$ 4π Scint #7 = $5423.2 \times / \epsilon$

Telephone Conv. E. Wyatt.

Analysis of Run #6-1 and 6-2 samples

Ba^{140}	2.16×10^9	fissions/ml
Mo^{99}	1.54×10^9	"
Ce^{143}	1.2×10^9	"
Zr^{97}	0.63×10^9	"

λ (gold) = 0.00017824 as per J. Estabrook
 But $e^{-\lambda t}$ and $1 - e^{-\lambda t}$ factors from Bork are OK

1-28-60

20 channel Analyzer was thoroughly checked by E.R. Rohrer from 1-22 thru 1-27.

Foils #28 and #33, both weigh 0.2410 g.

Thermal flux/unit Power Run #2

Start Irradiation	11 ⁵⁸ AM	1-25-60	2.4×10^8 ln N =
End	12 ⁵⁸ PM	1-25-60	2.7×10^9

Thermal flux/unit Power Run #3

Start Irr.	10 ⁵² AM	1-27-60	ln N = 2.3×10^8
End	11 ⁵² AM	1-27-60	ln N = 2.4×10^9

25

2nd Run Results

	Before	After	
Barium ¹⁴⁰	18.66×10^9	6.76×10^9	1.19×10^{10} fms/ML
Mn ⁹⁹	13.86	1.15	1.27×10^{10} "
Ce ¹⁴³	(19.4 - .6) K ₁		1.04×10^{10}
Zr Niob	(21.3 - .36) K ₂		0.82×10^{10}

Foil # 57 Exposed in Std Pile Slot #1
for 599 hours Time out 9:57 AM Jan 26, 1960
(99835 exp Factor)

Foil # 56 exposed in Std Pile Slot #1
in Cd Cover (0.030 in.)
for 359 hr 12 Min $(1 - e^{-\lambda t}) = .97854$
Time out 9:29 A 2-10-60

HFIR CE #2 Φ/MW determinations

EXP #152 Gold Cadmium fraction
in target region

#57 (.2407 gm) bare 1" above midplane

#65 (.2407 gm) Cd Covered 0.030 Cd

Irradiation 9²⁰ AM to 10²⁰ AM 8-18-61

SA-1 and SA-2 used to determine foil
ratio of .07368, Cd Ratio = 13.57

Cadmium absorption \int Ser correction factor
= 0.9678 (.030 Cd.)

$$\text{Corrected ratio} = \frac{.07368}{.9678} = .07613$$

CR = 13.14

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 10 x 10⁻¹² Meter Trip OK Fast Trip OK
 IC-2 Scramed Meter Trip OK
 IC-3 4 x 10⁻¹¹ Calibration _____
 IC-4 5 x 10⁻¹¹ Calibration _____
 CRM Meter Trip _____

Preliminary Check on 3-6-62

Room 113 Pressure Differential 1"
 Red Light On and Personnel Check ✓ CC
 Scrams and Bldg, Alarm Reset
 Source Inserted Accelerator
 Safety Withdrawn 21.02
 Controls Set INNER 999.93 Outer 0.07
 Reflector Water Approx 6" Above Be
 Moderator Water 28.26"

Exp # 291

3-6-62 DWM, DEM CC

Purpose: Pulsing At Critical w/o target AND
 w/o void

INNER	Outer	Safety	level
14.72	44.01	21.02	

Pulsing using only one BF₃ counter, (2) only.

I'm setting up for run need to good 5 times

PN-233 Acc 120KV 0.62 ma 1.9 x 10⁻⁵ mmHg 800µs @ 2/cps

TMC CH 160 MUS Delay 2 BKG 4 DISC 4 MEM 11

DET C-2 1750 W DD2 1/1 X 200 PHS 175

INSIDE TUBE BREAKDOWN 1111

Outside TUBE BREAKDOWN 1

"Note"
 3²⁰

level After Run PN-233
 Shut Down Insert Safety, Dump fuel H₂O
 And outer control

3-7-62 8⁰⁰ AM INSTALLED TARGET ASSEMBLY
WITH 0.47 VOID.

Instrument Check on 3-7-62 Source 10mc/ Ra 5.

PM-1 _____ Low Trip OK Scrammed Alarm Trip OK
 PM-2 _____ _____ OK
 IC-1 _____ Meter Trip OK Test Trip OK
 IC-2 _____ Meter Trip OK _____
 IC-3 4x10" Calibration No - OK DWM
 IC-4 6x10" Calibration No - OK DWM
 CRM X X Meter Trip X X

Preliminary Check on 3-7-62

Room 113 Pressure Differential 1"
 Red Light On and Personnel Check ✓ C.C.
 Scrams and Bldg. Alarm Reset ✓
 Source Inserted Accelerator
 Safety Withdrawn 28.02
 Controls Set INNER 16.0" Outer 0.07"
 Reflector Water Approx 6" Above Be
 Moderator Water 28.17"

Exp # 292 3-7-62 DWM CC

9 ⁴⁰ AM	INNER	outer	safety	
	18.30	0.07	28.02"	Pos. Per
10 ⁰¹	18.04	0.07	28.02"	level
	12.00	0.07	(for Pulsing)	sub crit

Considerable difficulty was experienced with arcing inside (3) and outside (8) the accelerator tube. Acc. was shut down and a 50K resistor put in series with the 10KV supply to focus electrode. (Resistor removed by E.R.R.)
 In 30 minutes, no arcing has occurred ∴ It is concluded that the resistor stabilizes the beam.

11⁵⁵

~~PN-234 WITH TARGET WITH 0.47 void
 CRIT AT 18.04 and 0.00
 INNER 12.00 OUTER 0.00 SAFETY 28.0
 ACC 120 KV 0.76 MA 1 MDA 150 MUS AT 140 CPS
 2×10^{-5} m Hg FOCUS MAX SOLENOID MAX
 SF 60
 TMC CH 20 MUS DELAY 2 BKG 8 DISC 4 MEM 1/1
 DET DD 2 11 X 200 BF₃ HV 1750 PHS 350
 Detector showed spurious counts of low
 amplitude~~

Above data not recorded because of spurious counts in the BF₃ counter

3-8-62 Target Assembly Removed, 2" BF₃ counter installed
 at edge of island in thimble. Safety removed.
 Preparation for Rossi- α measurement with counter in island.
 Instrument Check on 3-8-62 Source 10mc Y

PM-1 _____ Low Trip OK Alarm Trip OK
 PM-2 _____ Alarm Trip OK
 IC-1 _____ Meter Trip OK Fast Trip OK
 IC-2 _____ Meter Trip Scrammed
 IC-3 4 x 10⁻¹¹ Calibration OK
 IC-4 6 x 10⁻¹¹ Calibration OK
 CRM _____ Preliminary Check on _____
 Meter Trip _____
 Room 113 Pressure Differential OK 100 ps
 Red Light On and Personnel Check OK CC
 Scrams and Bldg, Alarm Reset ✓
 Source Inserted Accelerator Source
 Safety Withdrawn No Safety for this experiment only Water Train.
 Controls Set INNER 18.50 Outer 0.07"
 Reflector Water Approx 6" Above Be
 Moderator Water 28.11

26

Exp # 293

3-8-62

Purpose: Attempt to measure Rossi- α with
2" counter in trap.

12⁵⁴ PM

INNER Outer

16.22 16.22

Neg Per

16.20 16.20

Neg Per

12⁵⁹

16.11 16.11

Neg Per

16.00 16.00

Neg Per

Shut Down INSERT Outer, Control, Dump Fuel H₂O.
No Results

Installed 1" BF_3 counter in 2 $\frac{1}{2}$ " O_2 thimble
in flux trap. Removed IC-1 chamber
from thimble placed on top of Beryllium.

EXP # 294. Purpose: Attempt to measure Rossi- α
with 1" o.d. x 6 in. long BF_3 counter
(Model 10502)

Inner Outer

IC 3 IC 4

15.86 15.86

~ crit

 4×10^{-12} 6.5×10^{-12}

15.60 15.60

Sub

 5×10^{-13} 8×10^{-13}


15.45 15.45

Sub

 2.2×10^{-13} 4×10^{-13}

From the above, it is concluded that there
is a source somewhere in the critical assembly.
It seems impossible to operate at low enough power
to get some results for Rossi- α measurements.

System used for Rossi α measurements



H₂O.

PHS 500	1.1 x 1	1400 V	2000 c/m	PHS 20.5 μs
PH 500	1.1 x 1	1400 V	3000 c/m	PHS 2 μs

3³⁷ Shut DOWN Insert outer Control, Dump fuel H₂O

Installed minute BF_3 counter in island (GE model 78" OD) in 1/2" OD S.S. tubing. Counter works @ 1000v and accelerator neutrons. E.R.R. will check out on 3-9-62

Instrument Check on 3-9-62 Source 10 m μ Y

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 Meter Trip OK - Scram & Fast Trip OK
 IC-2 Meter Trip OK
 IC-3 4 x 10⁻¹¹ Calibration
 IC-4 6 x 10⁻¹² Calibration
 CRM Meter Trip

Preliminary Check on 3-9-62

Room 113 Pressure 1"
 Red Light ✓
 Scrams and Alarms ✓
 Source Insulated Accelerator
 Safety Withdrawn No Safety - 3/8" counter in center of island
 Controls Set INNER 999.93 Outer 0.07
 Reflector Water Approx 16" Above Be
 Moderator Water

Note IC-1 now outside tank on ~~east~~ ^{east} side.

EXP # 295

Purpose: Subcritical react. meas. with different detectors
 in diff. location. GE 3/8 in. o.d. BF₃ counter
 in center of island.

PN-234 INNER = 0.00 OUTER 0.07 Repeat 225-226
 with ^{3/8 in. BF₃} ~~new~~ detector in center of island. Exp R295
 Acc 135kv D.V. 55 SF 50 1.2 x 10⁻⁵ m μ f₅₀
 0.77 ma ~1 MVA 200 MUS @ 170 cps
 TMC CH 10 MUS Delay 2 Bkg 16 Disc 4 Mem 1/1
 DET 3/8 BF₃ @ 1300 V DDZ 1.1 X 2 PHS = 100

Note: looked for ripple in target current at 60 cps
 found essentially none! No increase in noise on higher inst.

EXP # 296

INNER = 12.00 Outer 0.07 Safety Removed
 No target 78" 00 counter in 1/2 in. 00 SS
 tube in center of tray

PN-235 Acc 135 kv 0.75 MA < 1 MUA
 110 CPS 200 MUS BURST

TMC CH 20 MUS Delay 2 Bkg 16 Disc 4 Mem 1/1
 Det. See above. IC-4 = 1×10^{-10}

EXP # 297

INNER 17.85 Outer 0.07 Safety Removed
 No target


PN-~~235~~ Acc 135KV 0.73 MA < 1 MUA 200 MUS @ 70 CPS

236 TMC CH 70 MUS Delay 2 BKG 16 DISC 4 MEM 1/1
 Det See above

¹⁴⁰ Shut Down Dump Fuel H₂O

"Note" Installed target Assembly with 0.47 Void (A/CEN)
 And BF3 Counters Between the fuel Annulus
 of Core Centered Vertically

① Not working ② 1900 DD-2 11 x 100
 PH3 = 300



Exp # 298 3-9-62

2:58 PM INNER outer Safety fuel H₂O
 999.93 0.07 27.50 28.51

IC-2 = $.45 \times 10 \times 10^{-10}$ or 4.5×10^{-10}
 3 = 3.5×10^{-11}
 4 = 1.8×10^{-12}

PN-237 Acc 135KV 0.77 MA < 2 MUA 200 MUS @ 170 CPS

4:30 shutdown TMC 10 MUS Delay 2 Bkg 16 Disc 4 Mem 1/1

Instrument Check on 3-12-62 Source 10 mc 8

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	OK
IC-1	$> 10 \times 10^{-12}$	Meter Trip	OK	Scrammed
IC-2	$> 10 \times 10^{-12}$	Meter Trip	OK	
IC-3	5×10^{-11}	Calibration	OK	
IC-4	6×10^{-12}	Calibration	OK	
CRM		Meter Trip		

Preliminary Check on 3-12-62

Room 113 Pressure Differential 1" H₂O
 Red Light On and Personnel Check C.C.
 Scrams and Bldg. Alarm Reset ✓
 Source Inserted Accelerator
 Safety Withdrawn 27.50
 Controls Set INNER 14.20" Outer 0.07"
 Reflector Water Approx 6" Above Be
 Moderator Water 28.5"

Installed Min BF₃ Counter [Ch 0], counter mounted in Shield Kind 55 Tube 4' long. Counters in Ch 1 and Ch 2!

EXP # 299 - PN-238 IC 4 1.3×10^{-10}
IC 3 6×10^{-11}
 Inner 14.20 Outer 0.07 Safety 27.50 IC-2 $.57 \times 3 \times 10^{-10}$
 ACC 300 μ s @ 70 CPS SF 50 1.5×10^{-5} m² Hg 135KV
 Focus = Max Sid = Max
 TMC CH 40 MUS Delay 2 Chg 16 Dice 4 Mem 1/1
 DET \odot 1300 DD2 1.1 x 200 PHS 200 Max P.H. ~ 75
 \odot 1800 1.1 x 200 200 11 ~ 75

EXP # 300 PN-239

Inner 10.00 Outer 0.07 Safety 27.50
 Acc 1.6×10^{-5} m² Hg 135KV 0.74 MA 200 MUS @ 110 CPS
 TMC CH 20 MUS Delay 2 Chg 16

10⁵⁰ AM

Exp # 301 PN-240

INNER 14.20" Outer 10.0" Safety 27.50" Sub crit

ACC 135KV 0.69MA 1.4x10⁵ mmHg SF 50 Foc MAX Sol MAX

400 MUS AT 35 CPS

TMC 80 MUS DELAY 2 BKG 8 DISC 4 MEM 1/1

DET see PN-238

IC-2 0.28x3x10⁻¹⁰ IC-3 3.5x10⁻¹⁰ IC4 2.0x10⁻¹⁰

Moderator water 25.7 in.

Increased Mod. Water to 28.8 in.

Exp # 302

3-12-62

INNER Outer Safety

14.265 14.265 27.50 Slightly Sub

14.20 14.44 27.50 level

" " 21.00 Neg Period

7 div \rightarrow -152.1 sec \rightarrow -11.9 ϕ (-7.6×10^{-4})

Raise power with acc

level

IC-1 ⁵¹ ~~46~~ x 3 x 10⁻¹¹ IC-3 4.5 x 10⁻¹⁰

2 .51 x 10 x 10⁻¹⁰ - 4 2.5 x 10⁻¹⁰

12⁴⁰ 14.48 14.48 21.03 level

Pulsing at crit. 200 pulses safety 21.02 \rightarrow 14.0

and repeated

PN-241 ACC 135 kV 0.67 MA 1000 MUS AT 20 CPS

TMC 160 MUS Delay 2 BKG 4 DISC 4 Mem 1/1

DET see PN-238.

~~Noted that during Run~~

3-12-62

3⁰⁰ PM After run system was subcritical and
 then noted that the ^{reflector} outside } water was down
 about six inches. Pumped H₂O back up
 and system was supercritical a few cents
 $-6.7 \text{ in } -132.6 \rightarrow -9.45 \times 10^{-4} \rightarrow -14.8 \phi$
 $+23 \text{ d. } +500 \rightarrow 1.55 \times 10^{-4} \rightarrow +2.4 \phi$ } 17.1ϕ

Therefore, crit. run must be repeated.

Inspection of ^{hand} dump valve diaphragm showed no
 defects, diaphragm replaced anyway. It could be
 feed valve diaphragm causing trouble.

3-13-62

on drum valve (Ref H₂O)
 The new diaphragm, leaked overite. Inspection showed no
 reason. Replaced with original diaphragm, but tightened $\frac{1}{4}$ turn
 with pipe wrench - no leak detected.

4⁴⁵ PM No leak detected during operation until 4⁵⁵ PM

5:40

Instrument Check on 3-13-62 Source 10 mc X

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 $>10 \times 10^{-11}$ Meter Trip OK Fast Trip scrapped OK
 IC-2 $>10 \times 10^{-12}$ Meter Trip OK
 IC-3 4.5×10^{-12} Calibration OK
 IC-4 5.5×10^{-11} Calibration OK
 CRM Meter Trip

IC-1 Keitchley seems more unstable than previously
 Preliminary Check on 3-13-62

Room 113 Pressure Differential 1"
 Red Light On and Personnel Check ✓
 Scrams and Bldg, Alarm Reset ✓
 Source Inserted Accelerator
 Safety Withdrawn 21.03"
 Controls Set INNER 14.20 Outer 0.07
 Reflector Water Approx 6" Above Bc
 Moderator Water 28.9"

Exp # 303 3-13-62

	INNER	Outer	Safety	Pos Per
<u>9³⁶ AM</u>	<u>14.20</u>	<u>15.42</u>	<u>21.03</u>	
	<u>6.65 div/dec \rightarrow +144.5sec \rightarrow 4.68×10^{-4} \rightarrow +7.34/23 = 31.74/in</u>			
	<u>14.20</u>	<u>15.195</u>	<u>21.03</u>	
	<u>14.20</u>	<u>15.19</u>	<u>21.03</u>	<u>level</u>
<u>10⁴⁰</u>	<u>14.46</u>	<u>14.46</u>	<u>21.03</u>	<u>level</u>

Pulsing at Crit. 200 pulses then insert safety to 14.0 to lower neutron level.

PN-242 Inner = Outer = 14.46 Safety 21.03

ACC 135 Rr 0.67 MA 1000 MUS AT 20 CPS

TMC C4 160 MUS Delay 2 BKG 4 Disc 4 MEM 1/1

DET ① SS 1300 V ② AL 2000 V PHS 200

SYSTEM CRIT & LEVEL AFTER 120 pulses. PULSE HEIGHT MAX 75 V.

148 PM INNER Outer Safety
 19.14 0.07 21.02 Pos Per
 5.33 div/decade \rightarrow +115.8 sec \rightarrow 5.62 $\times 10^{-4}$ \rightarrow + 8.8 ϕ or $\frac{8.8}{.28} = 31.4 \phi/in.$
 204 18.86 0.07 21.02 level

PN-243 Pulsing at Critical. Inner control fully inserted
 Same conditions as PN-242 except for
 control positions! ACC 1000MUS AT 20 CPS
 TMC 160MUS BKG X 4

H¹⁵ System Critical And level After PN-243
 Shut Down Insert Safety, Dump fuel H₂O
 Instrument Check on 2-14-62 Source 10mc X

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	7.10 x 10 ⁻¹¹	Motor Trip	OK	Fast Trip	OK
IC-2	2.10 x 10 ⁻¹²	Motor Trip	OK	scrammed	
IC-3	5.5 x 10 ⁻¹¹	Calibration	OK		
IC-4	6.0 x 10 ⁻¹¹	Calibration	OK		
CRM		Motor Trip			

Preliminary Check on 3-14-62

Room 113 Pressure Differential	Dwgn	1" H ₂ O
Red Light On and Personnel Check	C.C.	
Scrams and Bldg. Alarm Reset	✓	
Source Inserted	Accelerator Neutron Source On	
Safety Withdrawn	21.04	
Controls Set	Inner 999.93	Outer 44.01
Reflector Water	6" Above Be	
Moderator Water	29.2	

EXP: # 305

Purpose: To pulse at critical with Outer control fully withdrawn (target with 0.47 void)

912 INNER OUTER SAFETY
 11.47 44.01 21.04 Pos Period
 3.3 div/decade \rightarrow 71.7 sec \rightarrow 8.12 $\times 10^{-4}$ \rightarrow +12.7 ϕ or $\frac{12.7}{.135} = 94 \phi/in.$

929 11.335 44.01 21.03 level
 Pulsing at crit for 200 cycles - Safety inserted to 14.0 and repeat 24000 pulses
 1.5 to 170 cycles
 PN-244 ACC 2.4 x 10⁻⁵ sec 135KV 0.68MA 1000MUS AT 20 CPS
 TMC CH 160MUS BKG X 4 Delay 2 Disc 4 Mem 1/1
 DET 2MIN BFB See PN-238

critical check after pulsing.

1140 level After Pulsing PN-244
 (Bypassed upper limit (21.03) on safety)

Exp # 306 3-14-62

PN-245 Sub Crit
 INNER Outer Safety
 10.0" 10.00" 27.5" Sub Crit

1058 start Pulsing for PN-245
 ACC 2.2 x 10⁻⁴ 135KV 0.72MA 200MUS AT 10 CPS
 TMC CH 20MUS BKG 16 Delay 2 Disc 4 MEM 1/1
 DET See PN-238

1 Acc. ARE INSIDE TUBE

1247 Shut Down insert outer control, Dump fuel H₂O

Note 11 Lower ~~Inner~~ Inner. Remove Target and Void.
 Reinsert Target assembly.

1 4/8 PM

	INNER	Outer	Safety	
	17.50	0.07	28.00	
2 0/2	16.52	16.52	28.00	level
2 1/0	16.63	16.63	21.03	level

PN-246

Acc 1000 MUS @ 20 CPS

TMC 160 MUS BKG *2

H 0/6

System Critical And level After PN-246
Shut DOWN Insert Controls, Safety AND Dump
fuel H₂O.

Instrument Check on 3-15-62 Source 10mc x

PM-1	Low Trip OK Scrammed	Alarm Trip OK
PM-2	Contact	Alarm Trip OK
IC-1	>10 x 10 ⁻¹¹	Meter Trip OK Fast Trip OK
IC-2	>10 x 10 ⁻¹²	Meter Trip OK
IC-3	5 x 10 ⁻¹¹	Calibration
IC-4	6 x 10 ⁻¹¹	Calibration
CRM	Meter Trip	

Preliminary Check on 3-15-62

Room 113 Pressure Differential	1" H ₂ O
Red Light On and Personnel Check	C.C
Scrams and Bldg, Alarm Reset	Down
Source Inserted	Accelerator Source
Safety Withdrawn	21.04
Controls Set	Inner 999.93 Outer 0.07
Reflector Water	~6" above Beryllium
Moderator Water	28.71"

EXP 308 PURPOSE: Pulsing at critical with controls
Asymmetric, Outer at 0.07, Inner position
withdrawn to critical (leveled)

9 0/2 AM
9 3/5
9 5/0

Inner	Outer	Safety
35.18	0.07	21.04
34.74	0.07	21.04

$$\frac{6 \text{ div}}{\text{div}} \rightarrow 130.45 \rightarrow 5.1 \times 10^{-4} \rightarrow 8.04$$

$$\frac{5.0}{.44} = 11.36 \text{ f/inch}$$

Pos Per
level

Shut Down to Replace Defective Counter
with one mounted in 0.005 in. S.S. tube.

Exp # 309 3-15-62

INNER	Outer	Safety	Fuel H ₂ O	
34.74	0.07	0.0	28.41"	Sub Crit
34.69	0.07	21.04	"	level

C ① 1300 [x 200/1750] = 1486. DD2 1.1x100 PHS-200 Pulses < 75v
 C ② 1950 [x 1.0] = 1950v. 1.1x100 " Pulses < 75v

CRIT for 200 pulses, reduce neutron level with safety to 14.0, signal

PN-247 CRITICAL INNER 34.69 OUTER 0.07 Safety 21.03

ACC 1.9 x 10⁻⁵ mm Hg 135 kV 0.58 1000 MUS AT 20 CPS

TMC 160 MUS BKG 7 Disc 4 Mem 1/1 Aug 2

DET 2 MIN BF₃ counters

1 1/1 PM

System Critical And level After PN-247

INNER	outer	Safety
-------	-------	--------

1 3/0 PM

Exp # 310 3-15-62

INNER	outer	Safety	
13.57	44.01	21.00"	Pos Per
13.50	44.01	21.00"	level

$$11.6 \text{ div/inch} \rightarrow 252 \text{ sec} \rightarrow 2.91 \times 10^{-4} \rightarrow 4.54 \rightarrow 65 \text{ f/in.}$$

H 1/5

System Slightly Super Critical After PN-248
PN-248 Same as PN-247

+3960
Neg. React

Instrument Check on 3-16-62 Source 10 mc⁸

PM-1	Zero 300	Low Trip OK	Alarm Trip OK
PM-2			Alarm Trip OK
IC-1	$>10 \times 10^{-11}$	Water Trip OK	Fast Trip OK Scrammed System
IC-2	$>10 \times 10^{-11}$	Water Trip OK	
IC-3	4×10^{-11}	Calibration	
IC-4	6×10^{-11}	Calibration	
CRM		Water Trip	

Preliminary Check on 3-16-62

Room 113 Pressure Differential	1"
Red Light On and Personnel Check	✓
Scrams and Bldg. Alarm Reset	✓
Source Inserted	Accelerator
Safety Withdrawn	28.02
Controls Set	INNER 999.93 Outer 0.07
Reflector Water	Approx 6" Above Be
Moderator Water	29.0 in

EXP # 311 Pulsing when subcritical

PN-249 INNER 0.00 OUTER 0.07 SAFETY 28.0
 WITH TARGET No Void
 ACC 135 KV ^{0.77} 200 MA 200 MUS AT 170 CPS
 TMC CH 10 MUS BKG 16 Disc 4 Delay 2 Mem 1/1
 Det 2 MIN BF3 COUNTERS PHS 200 ~ 75V pulses.

Note: ¹¹¹ H.V. arc in side accelerator tube. 11 during data collection. Pressure was high at that time ~ 3×10^{-5} mm Hg.

IC 2	$.39 \times 10 \times 10^{-10}$
3	2.4×10^{-11}
4	1.4×10^{-10}

EXP 312 PN-~~249~~ 250

PN-~~250~~ ²⁵⁰ INNER 12.00 OUTER 0.07 SAFETY 28.0 WITH TARGET
 NO VOID ACC 300 MUS AT 110 CPS
 TMC CH 20 MUS BKG 16 Disc 4 Delay 2 Mem 1/1
 DET 2 MIN BF3

11¹⁵ AM EXP # 313 PN-251 3-16-62
 INNER 12.00 Outer 12.0" safety 28.0" with target
 PN-251 WITH TARGET No Void

ACC 400 MUS AT 70 CPS
 TMC CH 40 MUS BKG 16 Disc 4 Delay 2 Mem 1/1
 DET 2 MIN BF3 ~ 75V pulses.

EXP # 314 PN-252

Inner 00.0 Outer 12.0 Safety 28.0
 With Target No Void

ACC 300 MUS AT 110 CPS
 TMC CH 20 MUS BKG 16 Disc 4 Delay 2 Mem 1/1
 DET 2 MIN BF3 ~ 75V pulses.

1³³ PM EXP # 314 PN-253 3-16-62
 INNER 16.60 Outer 0.07 Safety 28.0" with target

ACC 300 MUS AT 110 CPS
 TMC CH 20 MUS BKG 16 Disc 4 Delay Mem 1/1
 DET 2 MIN BF3 ~ 75V pulses.

EXP 315 PN-254
 INNER 16.60 OUTER 12.00 SAFETY 28.0
 WITH TARGET NO VOID
 ACC 500 MUS 70 CPS
 TMC 40 MUS BKG 8

~33° Shut down assembly Remove target
 Install Styro foam void in trap.

"Note" Removed target And Replaced with Styrafoam-
 3-16-62 H 3/16" DIA Made up with 12 Pcs 2" thick Discs
 stacked together on A 5/16" OD SS target Rod.
 Length of Styrafoam 24 3/8" Extending from 1 3/16"
 Below Core to 3 3/16" Above.

Instrument Check on _____ Source _____

PM-1	Low Trip	Alarm Trip
PM-2		
IC-1	Meter Trip	Fast Trip
IC-2		
IC-3		
IC-4		
CRM	Meter Trip	

PM-1	Zero 3.00	Low Trip OK	Alarm Trip OK
PM-2			Alarm Trip OK
IC-1	10 x 10 ⁻¹¹	Meter Trip	Fast Trip OK
IC-2	10 x 10 ⁻¹²	Meter Trip OK	Scrammed
IC-3	3 x 10 ⁻¹¹	Calibration	
IC-4	5 x 10 ⁻¹²	Calibration	
CRM		Meter Trip	

Preliminary Check on 3-19-62

Room 113 Pressure Differential	1"
Red Light On and Personnel Check	✓
Scrams and Bldg. Alarm Reset	✓
Source Inserted	Accelerator
Safety Withdrawn	28.00"
Controls Set	Inner 999.93" Outer 0.07"
Reflector Water	Approx 5.75" Above Be
Moderator Water	29.21"

Exp # 316 PN-255 3-19-62
 INNER 999.93 Outer 0.07" Safety 28.00 (Styrafoam void)

PN-255 No target assembly 0.67 void.
 ACC 135KV 0.75 MA 1MVA 170 CPS 200 MUS BURST
 TMC 10 MUS BKG 16 Delay 2 Dia 4 Min 1/1
 Det O 1300 x 1.75 KV Press ~75V PHS 200
 O 1950 V ~75V "

Exp # 317 PN-256 3-19-62

	Inner	outer	Safety	(Styrafoam void)
	13.15	13.53	28.0	$6.2 \text{ div/sec} \rightarrow 7139.75 \rightarrow 4.97 \times 10^8$ Pos Per level $7.8 \text{ } 4/20 = 0.30 / \text{in}$ level
10/PM	13.15	13.27	"	
	13.175	13.175	"	
	13.495	13.495	21.05	

PN-256 CRIT 200 Pwr limit Safety to 14.00 & Repeat

ACC 1000 MUS AT 20 CPS TMC 160 MUS BKG 4

(CONT)

3⁴⁵ INNER Outer Safety
 13.495 13.495 21.04" slightly Super After
 Pulsing PN-256 $+3000\text{AEC}$
 Negligible

3⁵⁵ Shut Down Insert Safety, Outer Control

Instrument Check on 3-20-62 Source 10 meV

PM-1	Zero 310	Low Trip	OK	Alarm Trip	OK
PM-2				Alarm Trip	OK
IC-1	$>10 \times 10^{-11}$	Meter Trip	OK	Scram	Fast Trip OK
IC-2	$>10 \times 10^{-12}$	Meter Trip	OK		
IC-3	5×10^{-11}	Calibration	by NW9M		
IC-4	5.5×10^{-11}	Calibration	by NW9M		
CRM	x	Meter Trip	x		

Preliminary Check on 3-20-62

Room 113 Pressure Differential	1"
Red Light On and Personnel Check	<input checked="" type="checkbox"/>
Scrams and Bldg. Alarm Reset	<input checked="" type="checkbox"/>
Source Inserted	Accelerator
Safety Withdrawn	21.05"
Controls Set	INNER 999.93 Outer 0.07"
Reflector Water	Approx 5.75" Above Be
Moderator Water	29.37"

Exp # 318: Pulsing at Critical with Modified
 Outer control at 0.08. (Styrofoam Void)
 INNER 16.30 Outer 0.07 Safety 21.05 Pos Per
 $6.9 \text{ di/dsec} \rightarrow +150\text{AEC} \rightarrow 4.55 \times 10^{-4} \rightarrow 7.14 \rightarrow \frac{21}{16} = 44.4 \text{ \%/inch}$
 9⁰⁰ AM Inner 16.14 level

9⁰³ PN-257 CRITICAL INNER 16.14 OUTER 0.07
 To SAFETY 21.05 AFTER 200 PULSES SAFETY N 14.0
 11⁰² Acc $1.7 \times 10^{-5} \text{ mmHg}$ 135 KV 0.67 MA
 1000 MUS AT 20 CPS 24004 BURSTS
 TMC CH 160 MUS BKG 4 Delay 2 Disc 4 Min 1/1
 DET 2 MIN BF3 ~75 Pulses PHS 200
 ① $1.3 \times \frac{2.0}{1.75} \text{ V}$
 ② 1950 V

~11¹⁵ Neg period after pulsing $-7.3 \text{ di/dsec} \rightarrow 1586 \rightarrow 5.37 \times 10^{-4} \rightarrow 0.84 \text{ \%/}$
 after pulsing ~21.03.

11²⁴ AM Exp # 319 PN-258 3-20-62
 INNER 10.0" Outer 0.07 Safety 28.00" (Styrofoam void)

11³¹ to 12⁰⁷ PN-258 SUB CRIT INNER=10.0 Outer 0.07
 Safety 28.0 ACC 500 MUS AT 70 CPS (160000)
 TMC CH 40 MUS BKG 16
 DET 2 MIN BF3

12⁴² Exp # 320 PN-259 3-20-62 (Styrofoam void)
 INNER 10.36 Outer 44.01 Safety 21.05 Pos Per
 $6.55 \text{ di/dsec} \rightarrow 142.3 \text{ sec} \rightarrow 4.75 \times 10^{-4} \rightarrow 7.42 \text{ \%/} + 83 \text{ \%/}$

In 10.27 Out 44.01
 Pulsing at Crit Safety 21.01 \rightarrow 14.0 [24004 CPS]
 Acc 135KV 0.67MA 1000MUS 20 CPS

100-3⁰⁰ PM TMC 160 MUS BKG 4
 DET
 Subcritical after pulsing -2400 sec.

Note: During the time of a run pulsing at critical, approx 2 hrs., the position of the safety seems to change more than previously. On the last run special note was made, at beginning it was 21.05, at end 21.00. Changing from 21.00 to 21.05 made reactor ^{more} critical or slightly positive period. (3/20 see

EXP # 321 Pulsing Subcritical

PN-260 IN 0.00 OUT 10.0 Safety 28.0
 ACC 135KV 0.72 MA 1.5 m² Hg x 10⁻⁵
~~3.00~~ 3.00 MUS AT 110 CPS
 TMC 20 MUS BKG 16
 DET 2 MIN BF 3

Instrument Check on 3-21-62 Source 10 m² Y

PM-1	Zero 340	Low Trip	OK	Alarm Trip	OK
PM-2				Alarm Trip	OK
IC-1	> 10 x 10 ⁻¹¹	Meter Trip	OK	Fast Trip	OK scanned
IC-2	> 10 x 10 ⁻¹²	Meter Trip	OK		
IC-3	5.5 x 10 ⁻¹¹	Calibration	by Dwan		
IC-4	6 x 10 ⁻⁴	Calibration	by Dwan		
CRM		Meter Trip			

Preliminary Check on 3-21-62

Room 113 Pressure Differential 1"
 Red Light On and Personnel Check ✓
 Scrams and Bldg. Alarm Reset ✓
 Source Inserted Accelerator
 Safety Withdrawn 28.00"
 Controls Set INNER 13.50 Outer
 Reflector Water Approx 5.75 Above Be
 Moderator Water 28.77"

Exp # 322 PN-261 3-21-62
 INNER 13.50 Outer 10.00 Safety 28.0 (styrofoam void)
 ACC 135 KV 0.67 MA SF 50 FOC MAX SOL MAX 1.9 x 10⁵ m² Hg
 800 MUS 40 CPS 80000 cycles
 TMC CH 80 MUS BKG 4
 DET 2 MIN BF 3 55 Pulse ~ 75V PHS 200

PN-262 Repeat above but w. Ch 160 MUS Bkg 8
 1000 MUS 20 CPS

EXP # 323 PN-263

Inner 13.50 Outer 0.07 Safety 28.0 styrofoam void
 Acc 135 KV 0.70 MA 400 MUS 70 CPS
 TMC CH 40 MUS BKG 8 Delay 2 Disc 4 Man 1/1

TIMER 2056
 5-4-62

May 17, 1962
Timer Reading 2071
Rover element experiments 2071-2056 = 15 hours.

Critical Experiments for Studying HFIR Control Concepts

- I - Put boron solution into moderator system, determine critical conditions with safety, inner and outer fully withdrawn, Set up pulsed neutron equipment. 3 Days
 - a) Re calibrate safety up to \$5. 1
 - b) Re calibrate inner up to \$5. 1
 - c) Calibrate outer up to \$5. 1
 - d) Calibrate new safety between fuel annuli up to \$5. 1
 - e) Installation and removal of new safety. 1
- II - Dilute boron solution until either a desired symmetrical position of inner and outer control, a desired position of the safety, or a desired boron concentration is reached. 1
 - a) Calibrate safety up to \$5 starting from partially inserted position. 1
 - b) Power distribution with safety partially inserted. 1
 - c) Calibrate inner up to \$5 starting from partially inserted. 1
 - d) Calibrate outer up to \$5 starting from partially inserted. 1
 - e) Calibrate new safety up to \$5 starting from partially inserted. 1
 - f) Power distribution with new safety partially inserted. 1
- III - Repeat II at x different boron concentrations 7x
- Total 15 + 7x

Instrument Check on 5-17-62 Source 10 mcf

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$>10 \times 10^{-12}$	Meter Trip	OK	Fast Trip	OK
IC-2	$>10 \times 10^{-12}$	Meter Trip	OK		
IC-3	4×10^{-11}	Calibration	OK		
IC-4	1×10^{-12}	Calibration	OK		
CRM		Meter Trip			

Source M-229 installed in drive.
 IC-1 located outside tank (HFIR CE 2) at Midplan
 -2 " in original thimble at Midplan
 -3 " " " " " "
 -4 " ~~in original thimble~~ ^{outside tank} at Midplan

Preliminary Check on 5-17-62

Room 113 Pressure Differential	OK	Down
Red Light On and Personnel Check		Down
Scrams and Bldg. Alarm-Reset		Down
Source Inserted	M-229 in drive	Down CC
Safety Withdrawn	Set at 28.0	
Controls Set	Inner 16.50	Outer = 0.07
Reflector Water		
Moderator Water	No Boron	

Exp # 324

Purpose: Check critical position of sym control (inner & outer)
 No counters between fuel annuli; Target inserted no voids.
 [4 ea S.S V strips used to keep alum spacer between fuel annuli were removed in preparation for insertion of cadmium strips which make up new safety.]
 Outer 16.30 Inner 16.30 Level IC-3 = 7.5×10^{-11}
 16.60 Inner 16.30 + Period +145 sec $\rightarrow 4.67 \times 10^{-4}$
 +7.30 $\phi \rightarrow 24.3 \phi/in$

IC3

Inner 15.16 Outer 16.30

- negative to drop power

16.45 16.30

POSITIVE Period

16.30.5

16.30

2×10^{-9}

level

$+22 \text{ sec} \rightarrow 5.38 \text{ in}^4 \rightarrow 8.41 \text{ ft} \rightarrow 58.0 \text{ ft/in inner}$

Shutdown

Installed 4 pieces of cadmium $8\frac{3}{4} \times 24 \text{ in ea} \times 0.025 \text{ in}$ in fresh element water gap. This is a mockup of a new safety. $\frac{1}{8}$ in. holes have been drilled so that it can be positioned at 20, 19, 18, 17, 15, 13, 10, 5 and 0 in, where 0 refers to the top of the bottom of the core and 20 refers to the top of core.

Instrument Check on 5-18-62 Source 10 mo 8

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	OK
IC-1	Meter Trip	OK	Scrammed Fast Trip	OK
IC-2	Meter Trip	OK		
IC-3	4×10^{-11}	Calibration	Down	
IC-4	7.5×10^{-11}	Calibration	Down	
CRM	Meter Trip			

Preliminary Check on 5-18-62

Room 113 Pressure Differential	Down
Red Light On and Personnel Check	C.C.
Scrams and Bldg, Alarm Reset	Down
Source Inserted	Down Inst Response OK
Safety Withdrawn	28.0 New Safety 20.0
Controls Set	Inner 16.3 Outer 0.07
Reflector Water	Approx 4" Above Bc
Moderator Water	~28.0

EXP # 325

INNER 16.30	Outer 19.61	IC-4	Pos Per
		$+78.8 \text{ sec} \rightarrow 11.8 \text{ ft} / 82 = 14.4 \text{ ft/in.}$	
16.30	18.79	6×10^{-11}	Level
16.91	16.91		Level

Drain H₂O, Insert safety, Insert inner then raise outer!

EXP # 326

New Safety @ 19 in.	Moderator 27.9	Inner 16.30	Outer 0.07
Safety 28.0	Source inserted		
Inner	Outer		
16.30	28.85		Pos Period
16.30	23.68	$97.8 \text{ sec} \rightarrow 10.6 \text{ ft} \text{ or } 5.17 \text{ ft}$	Level
17.31	17.31	$= 0.193 \text{ ft/in.}$	Level

(IC-3 plugged in Cab 6 IC4 in cabinet 7)

May 18, 1962

	Inner	Outer	New Safety	Moderator	Conditions
#327	17.31	0.07	18.0	28.77	Source Inserted 178 sec
"	17.31	20.90	"	"	Pos Period $4.03 \times 10^{-4} \rightarrow 6.30 \phi$
"	17.31	20.09	"	"	$6.30/0.81 = 7.78$ cents/inch
	17.87	17.87	"	"	Level
	16.08	Lower power level			
	18.00	17.87	"	"	+173 sec $4.03 \times 10^{-4} \rightarrow 6.30 \phi / 48.5 \phi$ in
IC-4 moved back in tank					
#328	18.00	0.07	17.0	28.4	Source inserted
	18.00	28.02	"	"	+95.9 sec $\rightarrow 10.2 \phi$
	18.00	26.60	"	"	Level $1.42 \text{ in} \rightarrow 7.2 \phi/\text{in}$
	18.67	18.67	"	"	Level Sym
		16.00	"	"	- Period to reduce power
	18.67	19.20	"	"	+ Period 6.73ϕ $.53 = 12.7 \phi/\text{in}$
Shut down					
#329	20.00	0.07	15.0	28.9	Source Inserted Pos safety 28.0
	20.00	31.45	"	"	+96.7 $\rightarrow 9.84 \phi$
	20.00	30.81	"	"	Level $1.64 = 15.5 \phi/\text{in}$
	23.21	23.21	"	"	" Sym
		18.00	"	"	To reduce power
	23.21	25.00	"	"	+98.2 $\rightarrow 9.98 \phi / 1.79 = 5.6 \phi/\text{in}$
	21.50	23.21	"	"	Reduce Power
	24.11	23.21	"	"	+95.2 $\rightarrow 10.2 \phi / .90 = 11.3 \phi/\text{in}$
Shut Down					
#330	29.00	0.12	13.0	28.0	Source Inserted Safety 28.0
	30.00	30.0	"	"	+101.5 $\rightarrow 9.75 \phi$
	30.00	29.36	"	"	Level $9.75/1.64 = 15.2 \phi/\text{in}$
	29.80	29.80	"	"	" Sym
	29.72	30.00	"	"	" $9.75/1.8 = 54.1 \phi/\text{in}$

Instrument Check on 5-21-62 gauges 10 mCi

PM-1	Low Trip OK	Alarm Trip	OK
PM-2		Alarm Trip	OK
IC-1	2.0×10^{-12}	Motor Trip	OK
IC-2	2.0×10^{-12}	Motor Trip	OK
IC-3	1.5×10^{-12}	Calibration	Down
IC-4	6×10^{-11}	Calibration	Down
CRM	X X X	Motor Trip	X X X

Preliminary Check on 5-21-62

Room 113 Pressure Differential	DWM
Red Light On and Personnel Check	CC
Scrams and Bldg, Alarm Reset	Down CC
Source Inserted	DWM
Safety Withdrawn	28.0 DWM New Safety = 10 in.
Controls Set	Inner 38.0 Outer 0.07
Reflector Water	~ 4" above Be.
Moderator Water	28.0 in

	Inner	Outer	New Safety	safety	Conditions
#331	34.55	34.55	10.0	28.0	+154 sec $\rightarrow 6.95 \phi$
"		34.39	"	"	Level $.16 = 43.4 \phi/\text{in}$
	34.50	34.50	"	"	Level Sym
	34.47	34.55	"	"	Level $.08 = 86.8 \phi/\text{in}$
#332	42.0	0.07	5.0	28.0	Moderator to 27.7
	43.07	44.01	5.0	28.0	+109.75 $\rightarrow 9.20 \phi$
	42.59	"	"	"	Level $.48 \rightarrow 19.2 \phi/\text{in}$
	43.07	42.35	"	"	" $1.166 \rightarrow 5.5 \phi/\text{in}$
	44.00	41.39	"	"	"
	42.86	42.86	"	"	Level Sym

Instrument Check on 5-22-61 Source 10 mc Ra 5

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	^{Too noisy on 10 x 10⁻¹²} 2 x 10 ⁻¹²	Water Trip	OK	Fast Trip	OK
IC-2	7 x 10 ⁻¹²	Water Trip	Scrammed		
IC-3	4 x 10 ⁻¹²	Calibration	Swm		
IC-4	6 x 10 ⁻¹²	Calibration	Swm		
CRM		Meter Trip			

Preliminary Check on 5-22-61

Room 113 Pressure Differential	Swm
Red Light On and Personnel Check	Swm
Scrams and Bldg, Alarm Reset	C.C.
Source Inserted	C.C.
Safety Withdrawn	C.C. 28.0
Controls Set:	Inner 28.0 Outer 0.07
Reflector Water	~6 1/4 in above B
Moderator Water	28.3 in - 27.4 (range of values)

~~Exp. 333 Purpose: Pulsing at critical with Inner and Outer contacts removed and with New Cadmium safety inserted 15 in into core position = 5 in / Drilled hole every inch in safety.~~

Exp 333

Reassembled New Safety with polyethylene tape installed 6870 72" plastic scint in alum can now on top of core.

#333	Inner	Outer	New Safety	
	27.75	27.75	14.0	+113 _s → 5.73 x 10 ⁻⁴ → 8.95 f
	"	27.00	"	level 8.95 / .75 = 11.9 φ/in
	27.50	27.50	"	level
	27.34	27.75	"	" 1.41 = 21.8 φ/in

	Inner	Outer	New safety	Plastic Scint. Removed
# 334	33.0	0.07	11.0 in	
	33.60	33.60	"	+ 83.7 sec $\rightarrow 7.25 \times 10^{-4} \rightarrow 11.3 \phi$
	33.60	33.32	"	Level $11.3 / .28 = 40.4$
	33.505	33.505	"	Level
	33.455	33.60	"	Level $11.3 / .145 = 77.9$ 80.7
335	36.00	36.00	9.0 in	+ 79.7 sec $\rightarrow 7.5 \times 10^{-4} \rightarrow 11.7 \phi$
	36.00	35.70	"	level $11.7 / .3 = 39 \phi / \text{in.}$
	35.905	35.905	"	level
	35.87	36.00	"	level $11.7 / .13 = 90 \phi / \text{in.}$
# 336	40.85	40.85	6.0 in	+ 272 sec $\rightarrow 2.72 \times 10^{-4} \rightarrow 4.25 \phi$
	40.85	40.59	"	Level $4.25 / .26 = 16.3$ 16.5
	40.78	40.78	"	level Sym.
	40.75	40.85	"	Level $4.25 / .10 = 42.5$
	Drop Safety to shut down, safety still worth perhaps 5 - 10 dollars. (Pulled later to be -5.88)			
# 337	Installed 6810A + 2" plastic Scint. in Alum housing			
	44.19	44.01	5.0 in	Just critical $37^{-.25 \phi}$ Reactivity worth
	of total safety slightly greater than # 332!!			
	Safety to 21.05! Mod. = 27.9			
338	42.00	39.03	6.0 in	+ 10.5 ϕ
	41.72	39.03		level $10.5 / .28 = 37.5 \phi / \text{in.}$
	40.82	40.82		level Sym.
4 th	Shut DOWN			

Instrument Check on 5-23-62 Source 10 mc Ra γ

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 10 \times 10^{-12}$	Meter Trip	OK		
IC-3	3×10^{-11}	Calibration	Down		
IC-4	6×10^{-11}	Calibration	Down		
CRM		Meter Trip			

Preliminary Check on 5-23-62

Room 113 Pressure Differential	Down
Red Light On and Personnel Check	C.C.
Scrams and Bldg. Alarm Reset	C.C.
Source Inserted	Down
Safety Withdrawn	To 21.05 New Safety at 6.0 in.
Controls Set	In 44.19 Outer 8.8
Reflector Water	~6-7 in above Be.
Moderator Water	

EXP 339 - Measure decay constant at critical
 New Safety at 6.0 (cd inserted 14.0 in) 6810A + 2 in. Plastic
 scintillator on top of fuel element inner annulus @ 1400 v
 HP-460A - HP 460B pulse height on scope max ~0.5 v
 8 pulses from fuel element ~ 3v. Disc on TMC set
 at 2 1/2.

Ion chamber on IC-3 was flooded, chamber replaced
 and put in dry thistle formerly used for IC-1.

	Inner	Outer	Safety	New Safety		
339	44.00	37.81	21.05	6.0	+ 81 sec	11.6 f
"		37.42	"	"	11.6/39 =	29.7 d/in
	40.835	40.835	"	"		level Sym.

PN-264 EXP 339 D.V. 65 → 5.4KV S.F.V = 72
 ACC 140KV .71MA 1.7×10^{-5} mm Hg 1000 MUS @ 10CPS
 SAFETY AT 21.05 FOR 100 CYCLES, INSERTED TO 12.0
 2203 cycles
 IC-3 0.005 → 1.0 IC-4 006 → 1.2
 DET 6810A 1400V + 460A + 460B PH max 6 volt
 TMC CH 320MUS DELAY X2 BKG X4 DISC 2.5
 Level after Presc INNER 40.835 OUTER 40.835 SAFETY 21.05
 $\lambda_{est} = 91.8$ $\lambda_{comp} = 91.8 \pm 2$ New Safety 6.0

EXP 340

PN-265 Inner 40.835 Outer 36.835 Safety 21.08
 New Safety 6.0
 ACC Tuned for max Background ratio of ~ 8
 140KV 500 MUS @ 20CPS SF = 65
 Focus Max

(4032 cycles)
 TMC CH 160 MUS Delay x2 BKG x4 DISC 2.5
 [DISC 4 same BKG Ratio as reduced
 counting rate]
 $\lambda_{est} = 191$ $\# 1.08$
 $\lambda_{comp} = 190 \pm .4$ $\# 1.07$

EXP 341

PN-266 Inner 40.835 Outer 34.835 Safety 21.04
 New Safety 6.0
 ACC 400 MUS @ 40 CPS Total 15006
 TMC CH 80 MUS BKG 8
 $\lambda_{est} = 275$ $\# 2.00$
 $= 266.6 \pm .6$
 $\# 1.90$

Tot des	EST Decay Const	EST. #	λ comp	#
007	366	3.0	363 ± .7	2.95
000	343	2.7	336 ± .6	2.65
000	272	2.0	264 ± .6	1.87
000	196	1.1	198 ± .4	1.15
002	140	.53	139 ± .5	.51
50A	133	.45	¹³² 135 ± .4	.43
1000	208	1.27	206 ± .5	1.24
574	275	2.00	274 ± .5	1.98
000	351	2.8	351 ± .6	2.82
000	512	4.6	506 ± 1.1	4.50
000	651	6.1	633 ± 1.7	5.88
st.				
1502	93	0	92.2 ± .3	Safety Inserted 12.0 after 100 cycles.
run (50-2)		$e^{-\lambda t} = 1 + \lambda T$		$\frac{F}{T} = \frac{.10}{25}$ $T = 2.5 \times 12 = 30 \text{ MIN} = 1800 \text{ sec} \rightarrow t.1\phi$ $\lambda_c = (91.8 + 92.2) / 2 = 92.0$
2527	246	1.7	240 ± .5	1.61
4000	346	2.8	338 ± .7	2.67
3018	461	4.0	455 ± .9	3.95
0000	619	5.7	580 ± 30	5.3
20000	817	7.9	750 ± 50	1 arc during run.
4000	936	9.3		
0000	604	5.6	578 ± 1.5	5.28
2603	501	4.5	494 ± 1	4.37
0000	426	3.6	416 ± .9	3.52
"	598	5.5	579 ± 1.8	5.29
	and approach to sub crit)			
0000	400	3.4	398 ± .7	3.33
"	478	4.2	476 ± .8	4.17
"	288	2.1	288 ± .6	2.13
	382	3.2	376 ± .6	3.09

✓62

Instrument Check on 5-24-62 Source 10 m. Ra 8

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	710×10^{-11}	Meter Trip	OK	Fast Trip	OK
IC-2	710×10^{-12}	Meter Trip	Scrammed		
IC-3	5×10^{-11}	Calibration	AWGN		
IC-4	6×10^{-11}	Calibration	AWGN		
CRM		Meter Trip			

Preliminary Check on 5-24-62

Room 113 Pressure Differential AWGN

Red Light On and Personnel Check C.C.

Scrams and Bldg. Alarm Reset AWGN

Source Inserted AWGN

Safety Withdrawn 21.0 "New Safety" 6.0 in.

Controls Set Inner 44.00 Outer 30.00

Reflector Water 5.6 above Re

Moderator Water 27.3 in.

EXP. Inner Outer Safety New

278 41.20 40.82 21.05 6.0 +

353 40.85 40.82 " " level

40.84 40.84 " " level Syn

EXP 364. ~~Drop~~ New Safety at 0.0 (20 in CO Inserted)

44.00 44.00 28.0 0.0 Mod → 27.0

Pulsing for PN-289 See p 60.

Check for riggle after 292 shows that it is still with us!

APRIL 1963						
S	M	T	W	T	F	S
	1	2	3	4	5	6
7	8	9	10	11	12	13
14	15	16	17	18	19	20
21	22	23	24	25	26	27
28	29	30				
*	*	*	*	*	*	*

WEDNESDAY

3

APRIL

93

272

\$ 5.88

M A 1
M A 2
M A 3
M A 4
M A 5
M A 6
M A 7
M A 8
M A 9
M A 10
M A 11
M A 12
M A 13
M A 14
M A 15
M A 16
M A 17
M A 18
M A 19
M A 20
M A 21
M A 22
M A 23
M A 24
M A 25
M A 26
M A 27
M A 28
M A 29
M A 30
M A 31

Instrument Check on 5-25-62 Source 10 mc Ru x

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	210×10^{-12}	Meter Trip	OK	Fast Trip	OK
IC-2	210×10^{-12}	Meter Trip	Scrammed system	OK	
IC-3	5×10^{-14}	Calibration	Over		
IC-4	7×10^{-11}	Calibration	Over		
CRM		Meter Trip			

Preliminary Check on 5-25-62

Room 113 Pressure Differential	OK
Red Light On and Personnel Check	OK CC
Scrams and Bldg, Alarm Reset	Over C.C.
Source Inserted	M-229 used.
Safety Withdrawn	28.0 (New Cd. Safety Removed)
Controls Set	44.00 0.07 (
Reflector Water	5 1/2 above RL
Moderator Water	27.6 (Contains B solution used previously)

EXP 368

Purpose: check critical position of Inner and Outer Controls with boron solution in moderator water.

INNER	Outer	Safety	
44.00	40.00	28.0	+ 10.9 ϕ
"	39.51	"	Level $10.9 / .49 = 22.2 \phi / in$
41.10	41.10	"	Level Sym.

Drain H₂O and repeat. lower outer control ^{36.00}

EXP 369

41.45	41.10	28.0	+ 6.73 ϕ
41.12	41.10	28.0	level $6.73 / .33 = 20.4 \phi / in$
41.21	41.21	21.0 ϕ	level Sym.

Pulsat Crit see next page.

64

EXP	PN	Inner	Outer	Safety	New Safety	
369	293	41.21	41.21	21.05 21.01	Removed	B+H=2027.0 Safety to 12.0 after each 100 gals
		Level	after	pulling	!	
370	294	41.21	41.21	16.00	x	
371	295	"	"	13.00	x	
372	296	"	"	10.0	x	
373	297	"	"	7.0	x	
374	298	"	"	4.0	x	
5	299	"	"	11.8 0.0	x	
6	300	"	"	0.0	x	
7	301	"	37.21	21.04	x	
8	302	"	33.21	"	x	
9	303	"	29.21	"	x	
380	304	39.21	41.21	"	x	
381	305	37.21	"	"	x	
	306	37.21	"	"	x	
		Printer	Parade	205	Jamner	
5-28-82		Dist	Check	page	67	
382	306	41.37	41.37	21.02	x	Safety to 12 after 100 gals
383	307	37.21	41.21	21.02	x	
384	308	35.21	"	"	x	
385	309	33.21	"	"	x	
386	310	33.21	33.21	"	x	
5-29-	389	33.21	33.21	21.04	x	
390	312	36.21	36.21	21.04	x	
391	313	38.21	38.21	21.04	x	
392	314	39.21	39.21	"	x	

	Channel width	BKG RATIO	BURST μ S	REP RATE	TOTAL CYCLES	EST λ	EST Dollars	Comp λ	H
<i>in 100 g/den</i>	170 ³²⁰	16 ⁴	1500	10	4302	101	0	101.3 \pm .3	
	160	4	800	21	8105	181	.79	180.0 \pm .5	0.78
	80	8	400	39	15008	288	1.85	284 \pm .6	1.81
	80	16B	400	39	12576	✓409	3.05	402 \pm .8	3.18
	40	16	200	71	30000 ³¹¹⁵⁰	518	4.13	510 \pm 1.4	4.04
	20	16	100	110	61651	595	4.89	580 \pm 2	4.74
	20	16	100	110	60000	619	5.13	620 \pm 2	5.13
	"	"	"	"	"	626	5.22	618 \pm 2	5.11
	160	8	800	21	6249	215	1.13	213 \pm .5	1.11
	40	8	200	71	30500	408	3.04	409 \pm 1	3.05
	20	16	100	110	80800	640	5.34	630 \pm 2	5.23
	160	4	800	21	6900	165	0.63	166.6 \pm .5	.65
	80	8	400	39	12596	275	1.72	1	
	40								
<i>not</i>	--	3 channel incorrect from power failure -			down		was 205	!	
	320	4	1500	10	3599	99.7		100.9 \pm .3	^{and} 101.1
	80	8	400	39	17490	275	1.75	273 \pm .7	1.70
	40	8	200	71	27729	419	3.19	407 \pm 1	3.03
	40	8	200	71	27288	569	4.69	558 \pm 13	4.52
	20	16	100	110	98051	903	8.03	895 \pm 5	7.85
	20	^{Delay Delay} 16 32	100	100	80000	923	8.03	893 \pm 3	7.83
	40	8 16	200	67	28277	536	4.36	511 \pm 1.5	4.05
	80	8 4	400	40	13935	305	2.05	302 \pm .7	1.99
	160	4 2	800	21	6532	220	1.20	222 \pm .6	1.20

5-28-62

Wheeling (Monitor) suggested that the calibration 205 was out of adjustment. (Quick release mechanism?) Actual cause of stopping print cycle not determined.

Power failure dropped one channel and caused errors in 2 others of the 128 channels that could be compared. Additional manipulation to output caused errors in nearly all channels probably from turning power on and off repeatedly.

Boron samples taken 4a 4B

4B analyses 1.16 mg B / gm

Instrument Check on 5-28-62 Source Ra 8 10 m

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 10 \times 10^{-12}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 10 \times 10^{-12}$	Meter Trip	OK		
IC-3	4×10^{-11}	Calibration			
IC-4	6	Calibration			
CRM		Meter Trip			

Preliminary Check on 5-28-62

Room 113 Pressure Differential	<u>~1" swan</u>
Red Light On and Personnel Check	<u>C.C.</u>
Serams and Bldg. Alarm Test	<u>swan</u>
Source Inserted	<u>swan</u>
Safety Withdrawn	<u>C.C. 21.04</u>
Controls Set	<u>2 = 41.21 Out. 0.07 → 30.0</u>
Reflector Water	<u>5 1/2 in above 21.</u>
Moderator Water	<u>27.1 in</u>

Exp 382

Purpose: Check crit pos of control - pulse at critical with boron solut. on fuel element.

Inner Outer Safety

41.21	42.40	21.04	+ 8.03 ϕ
41.21	41.62	"	level 10.3 ϕ /in
41.37	41.37	"	level Sym

See p 64 for pulsed crit data.

41.37	41.37	21.02	level After PM 306
-------	-------	-------	--------------------

Instrument Check on 5-29-62 Source 10 mc Ra

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	OK
IC-1	2×10^{-11}	Meter Trip	Scratched	Fast Trip OK
IC-2	2×10^{-12}	Meter Trip	OK	
IC-3	6×10^{-11}	Calibration	Down	
IC-4	2×10^{-11}	Calibration	Down	
CRM		Meter Trip		

Preliminary Check on 5-29-62

Room 113 Pressure Differential	Down
Red Light On and Personnel Check	OK
Scrums and Bldg. Alarm Reset	C.C.
Source Inserted	C.C.
Safety Withdrawn	21.04
Controls Set	Inner 41.37 Outer 0.07 → 30.
Reflector Water	~ 5 1/2 in above Be
Moderator Water	27.0

Exp. 387 Purpose check critical position of inner and Outer controls with force solution as moderator in fuel element.

Inner	Outer	Safety	
41.37	42.55	21.04	+ 8.84 f
41.37	41.63	21.04	level 8.84 / 0.92 = 9.6 f/in
41.47	41.47	21.04	level

9:38

Shut Down

(Time 2-3 PM)

Exp # 388 - Purpose Same as Exp # 387

Inner	Outer	Safety	
41.47	42.50	21.04	+ Period 11.5 f
41.47	41.55	"	level 11.5 / 0.95 = 12.1 f/in

Exp 389-392 See p 64

Instrument Check on 6-4-62 Source 10 mc(8)

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	OK
IC-1	3x10 ⁻⁴ Meter Trip	OK	Fast Trip	OK
IC-2	2x10⁻⁴ 3x10 ⁻⁴ Meter Trip	OK		
IC-3	2x10 ⁻⁴ Calibration	Down		
IC-4	5x10 ⁻⁴ Calibration	Down		
CRM	Meter Trip			

Instrument Check on 6-4-62

Rear 113 Pressure	Down
Red Light Control	C.C
Scrams and Bldg. Alarm	C.C
Source Inserted	C.C
Safety Withdrawn	21.04
Controls Set	Inner 41.47 Outer 12.3
Reflector Water	~ 5 1/2" above BE
Moderator Water	27.3 in

EXP. 393 Purpose -- check crit pos. for changes.

Time	Inner	Outer	Safety	
	41.47	12.0	21.04	
	41.47	42.55	"	+ Period 9.814
	41.47	41.64	"	level 1.91 = 10.84
	41.54	41.54	"	level

Shut Down

Instrument Check on 6-5-62 Source 10mc

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	7.3×10^{-11}	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	Scrammed		
IC-3	3×10^{-11}	Calibration	Swan		
IC-4	5×10^{-11}	Calibration	Swan		
CRM		Meter Trip			

Preliminary Check on 6-5-62

Room 113 Pressure Differential	OK
Red Light On and Personnel Check	C.C.
Scrams and Bldg, Alarm Reset	C.C.
Source Inserted	DWM M-229
Safety Withdrawn	21.04
Controls Set	INNER 41.55 Outer 30.00
Reflector Water	Approx 6" Above Bc
Moderator Water	27.35 c.

Exp # 394 Purpose: Check Crit Pos for Changes

	INNER	outer	Safety	
	41.55	42.55	21.04	+ Period 6/6
9 ¹⁰ AM	41.55	41.825	"	level 7.25 → 8.5 f/in
	41.66	41.66	"	level

Shut Down to insert cd safety between fuel Annuli

Exp # 396

	INNER	outer	Safety	(New Safety)	
	41.66	41.66	21.04	20.0	- Sub Crit

6-7-62

difficulty with accelerator - pressure instable -
 Disassembled Diff pump which was full of tar -
 Pumping still not good but accelerator works

at 28 μ a beam current IC-4 = 1.5×10^{-8} IC-3 1×10^{-9}
 Beam deflected 3×10^{-12} 5×10^{-8}

and just still decaying Bkg ratio $\sim 10^4$

Instrument Check on 6-7-62 Source 10 m - 8

PM-1	Low Trip	Scrammed	Alarm Trip	OK
PM-2			Alarm Trip	OK
IC-1	3×10^{-11}	Meter Trip	OK	Fast Trip OK
IC-2	3×10^{-11}	Meter Trip	OK	
IC-3	4×10^{-11}	Calibration	DWM	
IC-4	6.5×10^{-11}	Calibration	DWM	
CRM		Meter Trip		

Preliminary Check on 6-7-62

Room 113 Pressure Differential DWM

Red Light On and Personnel Check C.C.

Scrams and Bldg, Alarm Reset C.C. M-229

Source Inserted C.C. M-229

Safety Withdrawn 21.04

Controls Set inner

Reflector Water $5\frac{1}{2}$ above BE

Moderator Water 27.4 "

EXP # 397 New Safety at 20.0 (~~40.0~~ operation)
 Purge - Reactivity of Cd inserted to 0.0

See p 72-73 for pressing

72

EXP

Inner

Outer

Safety

New
Safety

DATE

6-7-62

397

41.66

41.66

21.04

20.0

Safety to 12 in after 100 cycles

Measured Neg Period after pulsing

398

41.66

41.66

21.04

19.0

399

"

"

"

18.0

400

"

"

"

17.0

401

"

"

"

16.0

402

"

"

"

15.0

403

"

"

"

13.0

404

"

"

"

11.0

405

"

"

"

9.0

Pulsing with Boron solution

6-8-62

408

32.00

30.00

20.00

X

9

"

28.00

"

X

10

"

26.00

"

X

1

"

24.00

"

X

2

"

22.00

"

X

3

"

20.00

"

X

4

32.00

31.57

21.03

X

Safety to 12 in after 100 cycles

6-13-62

415

31.88

31.88

21.03

X

416

30.00

32.00

20.11

X

417

28.00

32.00

"

X

418

26.00

"

"

X

419

24.00

"

"

X

420

22.00

"

"

X

421

20.00

"

"

X

422

18.00

"

"

X

423

20.00

20.00

"

X

424

23.00

23.00

"

X

PN #	Ch width	BKG	Delay	Nutron Burst μs	REP RATE	Total CYCLES	ESTIMATED		COMPUTED	
							λ	#	λ	#
315	320	4	2	1600	10	3802	120	.20	121.5 ^{±.3}	.20
316	160	4	2	800	21	6002	146	.46	142.4 ± .6	.41
317	160	4	2	800	21	6748	176	.76	171.6 ± .5	.70
318	160	8	2	800	21	7655	208	1.08	210 ± .6	1.08
319	80	8	2	400	38	18995	256	1.56	254 ± .6	1.51
320	80	8	2	400	38	17004	305	2.05	306 ± .6	2.03
321	80	16	2	400	38	15929	426	3.21	425 ± .9	3.20
322	40	16	8	200	69	42549	555	4.55	558 ± 1.2	4.45
323	20	16	16	100	100	53764	698	5.98	675 ± 2	5.68
<i>~ 0.5 g liter</i>										
324	160	4	2	800	10	7848	204	.32	204 ± .8	.31
325	80	4	2	400	38	19677	248	.60	245 ± .8	.57
326	80	4	2	400	38	22680	275	.77	275 ± .9	.76
327	80	4	2	400	38	16849	287	.86	293 ± .8	.88
328	80	4	2	400	38	16877	324	1.09	319 ± .9	1.04
329	80	8	2	400	38	18704	382	1.46	369 ± 1	1.37
330	320	4	2	1600	10		155	0	155.8 ± .6	156.0
331	160	4	2	800	20	10004	156	0	156.2 ± .4	156.0
332	80	4	2	400	38	18148	291	.87	296 ± .9	.90
333	80	8	2	400	38	13918	416	1.67	419 ± 1	1.69
334	40	8	4	200	69	33779	518	2.32	516 ± 1.2	2.31
335	40	8	4	200	69	31734	549	2.65	575 ± 1.4	2.69
336	40	8	4	200	69	33094	640	3.10	618 ± 1.5	2.96
337	20	8	8	100	100	67797	731	3.69	718 ± 2	3.60
338	20	8	8	100	100	68515	852	4.47	860 ± 3	4.51 ?
339	20	8	8	100	100	66623	914	4.86	928 ± 3	4.95 ?
340	20	8	8	100	100	64483	817	4.24	808 ± 3	4.18

Instrument Check on 6-8-62 Source 1.0 mc

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	OK
IC-1	Meter Trip	OK	Fast Trip	OK
IC-2	Meter Trip	OK		
IC-3	6×10^{-7}	Calibration	DWM	
IC-4	6×10^{-6}	Calibration	DWM	
CRM	Meter Trip			

Preliminary Check on 6-8-62

Room 113 Pressure Differential	DWM
Red Light On and Personnel Check	DWM
Scrams and Bldg. Alarm Reset	DWM
Source Inserted	DWM Response noted
Safety Withdrawn	21.04
Controls Set	IN 32.0 $\frac{1}{4}$ ROOT 0.08
Reflector Water	5 1/2 in. above Be.
Moderator Water	

EXP # 406.

Removed half of the boron solution, filled to original level with water. Check critical position of inner and outer controls.

Inner	3/4 Mod Outer	Safety	New Safety
33.95	33.95	21.04	Removed 12.7 ϕ
33.95	33.66	"	level / 0.29 = 43.8 ϕ /in
33.77	33.95	"	" .18 = 70.6 ϕ /in
33.84	33.84	"	level

"Note" 2 samples of boron taken SA & SB

6-25-62 SB = 0.602 mg B/ml

EXP # 407

Added water to barrel from 14 in to 18 7/8 in to dilute boron solution approx 3/4

Inner	Outer	Safety	
32.0"	32.0"	21.04	+ Period 8.13 ϕ
32.0	31.50	21.04	level 8.13/5 = 16.2 μ /in
31.82	32.0	"	level
31.86	31.86	21.04	level
31.765	31.765	28.00	level
32.00	32.00	20.00	level

EXP 408 Inner to 30 for pulsing

EXP 414 Critical pulsing run

32.00	31.57	21.03	level
32.00	31.57	21.03	Slightly After PN 330

Shut Down

Note
4 PM

2 Samples of Boron taken #6A + 6B After EXP # 408

6-25-62	6B = 0.457 mg B / ml
---------	----------------------

Instrument Check on 6-13-62 Source 10 mc 8

PM-1	Low Trip	OK	Alarm Trip	✓
PM-2			Alarm Trip	✓
IC-1	Meter Trip	Scrammed	Fast Trip	✓
IC-2	Meter Trip	OK		
IC-3	7×10^{-11}	Calibration		
IC-4	6×10^{-11}	Calibration		
CRM	Meter Trip			

Preliminary Check on 6-13-62

Room 113 Pressure Differential	Low
Red Light On and Personnel Check	C.C.
Scrams and Bldg, Alarm Reset	C.C.
Source Inserted	Acceleration
Safety Withdrawn	21.04
Controls Set	In 31.8 Out 0.07
Reflector Water	5 1/2 in. Above Be
Moderator Water	27.5 in

Exp. 415

Purson Critical pos. of In and Out control prior to pulsing at critical.

Inner	Outer	Safety	Level
31.88	31.88	21.04	level

PN-331 Pulsing at Critical step 72

Check crit after pulsing, level OK

31.88	31.88	21.03	level After PN-331
31.85	32.00	21.03	level
32.00	32.00	20.11	

Exp # 427

(Drained H₂O after 424 to install cd at 18.0 in pos.)

See p 78 for pulsing Cd insertion Mod → 27.5 in

428 - 428 - 429 - 430 pulsed Cd Safety.

Instrument Check on 6-14-62 Source 10mcK

PM-1	Low Trip	✓ Scram	Alarm Trip	✓
PM-2			Alarm Trip	✓
IC-1	73×10^{-4}	Meter Trip	Fast Trip	✓
IC-2	72×10^{-4}	Meter Trip		✓
IC-3	3×10^{-4}	Calibration	OK Down	
IC-4	6×10^{-4}	Calibration	OK Down	
CRM	Meter Trip			

Preliminary Check on 6-14-62

Room 113 Pressure Differential	Down
Red Light On and Personnel Check	C.C.
Scrams and Bldg. Alarm Reset	Down
Source Inserted	Accelerator Source
Safety Withdrawn	21.04
Controls Set	In 32.00 Out 12.10
Reflector Water	5 1/2" down Bx
Moderator Water	27.2"

Exp # ~~428~~ 431

Purpose: Cal Safety by Pulsing Sub Crit

	Inner	Outer	Safety	New Safety	Level
	32.00	31.68	21.04	Removed	level
4	32.00	31.68	18.00	"	sub crit
11 ⁰⁵ AM	Shut Down.				

78

DATE	EXP	INNER	OUTER	SAFETY	NEW SAFETY	
6-13-62	425	26.00	26.00	20.11	X	
	426	29.00	29.00	"		
	427	32.00	32.00	20.11	18.0	
	428	"	"	20.11	15.0	
	429	"	"	"	12.0	
	430	"	"	"	9.0	
	431	32.00	31.68	21.04	Removed Critical (not pulsed)	
	432	"	"	18.00	X	
	433	"	"	16.00	X	
	434	"	"	14.00	X	
	435	"	"	12.00	X	
	436	"	"	10.00	X	
6-26-62	439a	32.0	32.0	20.50	X	Critical
	440B	32.0	21.0	20.50	X	
	441C	32.0	18.0	20.50	X	
	442D	32.0	20.0	20.50	X	
	443E	32.0	14.0	20.50		
	444F	32.0	15.0	20.50		
6-29-62	448	33.27	33.27	21.04		Crit above & After
	449	31.62	31.62	28.0		No Targets
	450	28.73	28.73	"		
	451	25.47	25.47	"		
	452	24.37	24.37	"		

PN-	CH WIDTH	BKG	DELAY	BURST WIDTH	REP RATE	TOTAL CYCLES	ESTIMATED		comp	
							λ	#		
341	40	8	4	200	68	32090	668	3.28	656 ± 2	3.21
342	40	8	4	200	68	33442	439	1.81	437 ± 1	1.80
343	80	4	2	400	38	17864	312	1.00	303 ± .8	.94
344	40	8	4	200	68	33285	569	2.65	555 ± 14	2.56
345	20	16	8	100	100	61108	1146	6.35		
346	10	16	16	100	160	136665	1107		750	3.81 ?

347	160	4	2	800	21	10653	226	.45	222 ± .8	.42
348	80	8	4	400	38	20000	324	1.28	316 ± .8	1.03
349	40	8	8	200	68	47921	456	1.92	442 ± 1	1.83
350	20	8	8	100	100	69809	608	2.85	593 ± 2	2.80
351	20	8	8	100	100	71943	738	3.73	730 ± 7	3.68

Not present

352	80	8	4	400	38	16007	341	1.20	339 ± .8	1.17
353	40	8	8	200	70	32582	470	2.03	460 ± 2	1.95
354	20	8	16	100	110	59522	629	3.06	600 ± 6	2.85
355	20	8	16	100	110	76958	753	3.86	750 ± 7	3.81
356	20	8	16	100	110	75127		3.46	675 ± 7	3.33
357	160	4	2	800	21	7800			140.6 ± .4	
358	80	8	4	400	38	16416			337 ± .8	1.40
359	40	16	8	200	69	35796			588 ± 2	3.18
360	20	16	8	100	110	81933			820 ± 20	4.83
361	20	16	8	100	110				870 ± 20	5.19

Instrument Check on 6-25-62 Source 10 mc 8

PM-1	Low Trip	Scrammed	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	23×10^{-11}	Meter Trip	OK	Fast Trip	OK
IC-2	23×10^{-12}	Meter Trip	OK		
IC-3	3×10^{-11}	Calibration			
IC-4	6×10^{-12}	Calibration			
CRM		Meter Trip			

Preliminary Check on 6-25-62

- Room 113 Pressure Differential OK
- Red Light On and Personnel Check ✓ CC
- Scrams and Bldg. Alarm Reset ✓
- Source Inserted Response OK
- Safety Withdrawn 21.04"
- Controls Set INNER 31.86 Outer 0.08
- Reflector Water Approx 5 1/2" Above Be
- Moderator Water 37.01"

EXP # 437

Purpose: Critical Position of Controls with safety at 21.04 and at 15.00. (Fail Power dist. to be made with safety inserted to 15.0 in.)

INNER	Outer	Safety	New Safety	Power
31.86	32.14	21.04	Removed	level
[Boron conc 6B 0.457 mg B/ml]				
31.94	31.94	21.04	"	level
33.53	33.53	15.00	"	"
29.77	44.00	15.00	"	"

) Shut Down (

EXP 438: Foil Run
 Plate F 2 in a-1
 F 4 in a-37
 P 1 in b-1
 P 2 in b-78

Set inner @ 29.0 Outer @ 15.00 Safety 15.00 Mod 27.
 Inner Over Safety
 30.00 44.01 15.0 Pos Period

IC-2 = 3.0×10^{-9} Start Timing foil exp. 20'
 level at 8.1×10^{-9}

29.80 Level
 Dropped Safety at 125 PM (watch)

$$\text{Inner control} = \frac{14.6 \text{ } \mu\text{}}{0.2 \text{ in}} = 73 \text{ } \mu\text{/in}$$

Instrument Check on 6-26-62 Source 10 μ Ra Y

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	OK
IC-1	Meter Trip	OK	Fast Trip	OK
IC-2	Meter Trip	Scrammed		
IC-3	3×10^{-11}	Calibration	OK	
IC-4	5×10^{-11}	Calibration	OK	
CRM	Meter Trip			

Preliminary Check on 6-26-62

Room 113 Pressure Differential OK

Red Light On and Personnel Check ✓ CC

Scrams and Bldg. Alarm Reset ✓ CC

Source Inserted Response OK

Safety Withdrawn 21.04"

Controls Set Inver 999.85 Outer 0.08"

Reflector Water Approx 5 1/4" Above Bc

Moderator Water 27.3"

Exp # 439 Check critical position
before pulsing

In 32.0 out 32.0 Safety 20.50 (0.457) g B/R

See page 28 for pulsing experiments.

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	OK
IC-1	7.3×10^{-11}	Water Trip	Scrammed	Fast Trip OK
IC-2	$> 1.8 \times 10^{-12}$			OK
IC-3	5×10^{-11}			OK
IC-4	6×10^{-11}	Calibration		OK
CRM		Water Trip		

Preliminary Check on 6-28-62

Room 113 Pressure Differential	<u>✓</u>	OK
Red Light On and Personnel Check	<u>✓</u>	CC
Scrams and Bldg. Alarm Reset	<u>✓</u>	CC
Source Inserted	Response	OK
Safety Withdrawn	20.50"	
Controls Set	INNER 35.0" Outer 0.08"	
Reflector Water	Approx 5 1/2" Above Bc	
Moderator Water	27.38"	

EXP # 440 6-28-62

Note Target Removed - "H₂O Only in target Region"

Purpose: Check Exit Pos with target Removed

INNER	outer	Safety	(new safety Removed)
34.75	30.70	20.50	Pos Period
34.75	30.32	$> 40.04 / 33 = 26.34\%$	level
33.185	33.185	"	level

EXP # 441

Inserted styrofoam void to top edge of fuel!

33.20		20.50	Pos Period
33.41	33.51	"	"
33.41	33.185	$> 13.44 / 32.5 = 41.24\%$	level
33.24	33.24	28.00	level

EXP # ~~441~~ 442

S.S. Rod in target region

33.36	33.36	28.00	Pos Per
-------	-------	-------	---------

EXP # ⁴⁴²~~444~~ CONT
 INNER Outer Safety $\frac{15.94}{.15} = 1064/in$
 33.21 33.21 28.00" level

⁴⁴³
 EXP # ~~442~~ : Styrofoam void into core 4"
 INNER Outer Safety
 33.15 33.15 28.0" Pos Per
 33.02 33.02 28.0" 11.5 level
 $\frac{11.5}{.13} = 884/in$

3⁴⁰ PM EXP # ~~443~~ Styrofoam void into core 8"
 INNER Outer Safety
 31.85 31.85 28.0" $\frac{13.8}{.23} = 604/in$ Pos Per
 31.62 31.62 28.0 level

EXP 445

Instrument Check on 6-29 Source 10 mc γ

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	OK
IC-1	Meter Trip	OK	Fast Trip	OK
IC-2	Meter Trip	OK		
IC-3	$\sim 5 \times 10^{-11}$ Calibration	OK		
IC-4	$\sim 6 \times 10^{-11}$ Calibration	OK		
CRM	Meter Trip			

Preliminary Check on 6-29

Room 113 Pressure Differential OK
 Red Light On and Personnel Check ✓ CC
 Scrams and Bldg, Alarm Reset ✓ CC
 Source Inserted Response OK
 Safety Withdrawn 28.00"
 Controls Set INNER 29.90" Outer 0.08
 Reflector Water Approx 5 1/2" Above Be
 Moderator Water 27.3"

6-29-62

Exp # 445 cont Styrofoam void into Core 12"
 Inner Outer Safety 5
 28.95 28.95 28.0" + 8.474 = 38.474 Pos Per
 28.73 28.73 " .22 = 38.5 level

940 Exp # 446 Styrofoam void into Core 16"
 Inner Outer Safety 1
 25.90 25.90 28.00" + 11.14 = 39.14 Pos Per
 25.47 25.47 28.00" .43 = 25.8 level
 43

Exp # 447 Styrofoam void into Core 20"
 24.85 24.85 28.0" + 8.514 = 36.514 Pos Per
 24.37 24.37 " .48 = 17.8 level

"Note" Remove Styrofoam void and insert target Rod
 with 24. 1/2 OD SS tubing in target Region

1235 Exp # 448 6-29-62
 Inner Outer Safety
 33.36 33.36 28.0" + 16.04 = 44.04 Pos Per
 33.21 33.21 28.0" .15 = 107 level
 33.27 33.27 21.04 level

See page 78 for pulsing
 for Exp 448 - 452

July 2, 1962

Added 11 liters of H₂O to moderator to get controls to 25.0 at critical. ~~Replaced~~ Target Assembly inserted in target region. Beckman linear amplifier (u.p.a) replaced with E-H Research Lab Electrometer Amplifier and connected in scram ckt. Meter trips on amplifier chassis!

Instrument Check on 7-2-62 Source _____

PM-1	Low Trip	✓	Alarm Trip	✓	
PM-2			Alarm Trip	✓	
IC-1	10 x 10 ⁻¹¹	Meter Trip	OK	Fast Trip	✓
IC-2	E-H 10 x 10 ⁻¹²	Meter Trip	Scrammed		
IC-3	3 x 10 ⁻¹¹	Calibration	Done		
IC-4	5 x 10 ⁻¹¹	Calibration	Done		
CRM		Meter Trip			

Preliminary Check on 7-2-62

Room 113 Pressure Differential	✓
Red Light On and Personnel Check	CC
Scrams and Bldg. Alarm Reset	✓ CC
Source Inserted	✓ Response OK
Safety Withdrawn	28.0"
Controls Set	Tuner 22.0 Outer 2.0"
Reflector Water	Approx 5 1/2" Above Be
Moderator Water	

Exp 453

Inner 30.02 Outer 30.0 Source stuck
 Critical position prob. greater than 30.0
 30.5 30.5 Power Rising ~ Crit.

July 2, 1962

EXP 454

Added 4 l H₂O to Moderator H₂O (Boron)

	INUR	Outer	Safety		
~10 ³ A	31.00	31.00	28.00	+ Period	$\frac{8.47}{.17} = 49.8$
	30.83	30.83	"	Level	.17

EXP 455

Added 10 l H₂O to Moderator H₂O (Boron)

~11 ²⁵	30.40	30.40	28.0	+ Period	$\frac{10.4}{.17} = 50.7$
	30.195	30.195	"	Level	.17

EXP 456

Added 15 l H₂O to Moderator H₂O (Boron)

~1 ¹⁵	29.50	29.50	28.0	+ Period	$\frac{9.09}{.17} = 53.5$
	29.33	29.33	28.0	~level	.17

EXP 457

Removed 75 l ^{old} added 25 l of H₂O.

~2 ⁴³	27.15	27.15	28.0	+ Period	$\frac{10.3}{.17} = 34.3$
	26.85	26.85	"	level	.17

EXP 458

Added ~12 1/2 l H₂O to Moderator H₂O

~3 ³³ P	25.80	25.80	28.0	+ Period	$\frac{9.38}{.17} = 25.4$
	25.43	25.43			.17

Instrument Check on 7-3-62 Source 10 mcR/hr

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	<u>7 x 10⁻¹¹</u>	Meter Trip	OK	Fast Trip	OK
IC-2	<u>2 x 10⁻¹¹</u>	Meter Trip	OK		
IC-3	<u>5 x 10⁻¹¹</u>	Calibration	OK		
IC-4	<u>6 x 10⁻¹¹</u>	Calibration	OK		
CRM		Meter Trip			

Preliminary Check on 7-3-62

Room 113 Pressure Differential	OK		
Red Light On and Personnel Check	✓	C.C	
Screams and Bldg. Alarm Reset	✓	C.C	
Source Inserted	<u>M-229</u>	<u>- Response on IC-2, 3 & 4</u>	
Safety Withdrawn	<u>25.00</u>		
Controls Set	<u>inner 25.0</u>	<u>Outer 10.0"</u>	
Reflector Water	<u>~5 1/2 above Be</u>		
Moderator Water			

Exp # 459 7-3-62

Inner	Outer	Safety	Pos Per level
25.80	25.80	28.01"	
25.41	25.41	28.01	level

[Changed ranges on IC-2 (E-H) and tripped IC-2 meter]

EXP #460: Cont 459 TO determine crit pos with safety at 21.04.

	Inner	Outer	Safety	level
	25.72	25.72	21.04	level
<u>10⁴⁰ AM</u>	25.72	25.72	21.01	After PN. 362 level

90

EIP	CONTROL POSITION (IN)			
	INNER	OUTER	SAFETY	NEW SAFETY

7-3-62 460 25.72 25.72 21.04 X

461 " 22.72 "

462 " 20.72 "

3 " 18.72 "

4 " 16.72 "

5 " 14.72 "

6 " 12.72 "

7 " 10.72 "

8 23.72 25.72 "

9 21.72 " "

470 20.72 " "

1 19.72 " "

2 18.72 " "

3 17.72 " "

4 15.72 " "

5 25.72 25.72 18.00

6 16.00

7 14.00

8 12.00

9 10.00

480 25.72 25.72 21.04

7-10-62 481 25.68 25.68 21.04 X

482 23.68 23.68 "

483 21.68 21.68 "

484 19.68 19.68 "

485 18.68 18.68 "

486 17.68 17.68 "

487 16.68 16.68 "

CRITICAL Target Installed

BORON CONC ~.242912

Check Crit Not Pulsed

Sub Crit -2850 sec

CRIT. w. Target Boron ~0.2 g/l

	PN	CHANNEL WIDTH MS	BKG	Delay	BURST MS	REP RATE CPS	TOTAL CYCLES	ESTIMATED		CALCULATED	
								λ	#	λ	
illed	362	160	4	2	800	20	9000			186 ^{±.5}	186.6
2	3	160	4	2	800	20	9921			225 ^{±.1}	.18
	4	80	4	4	400	38	20911			264 ^{±.1}	.46
	5	80	8	4	400	38	22763			338 ^{±.8}	.81
	6	40	8	8	200	71	54997			410 ^{±1.0}	1.20
	7	40	8	8	200	71	32609			500 ^{±1.0}	1.68
	8	40	8	8	200	71	33463			605 ^{±1.5}	2.24
	9	40	8	8	200	71	43936			715 ^{±.5}	2.83
	370	160	4	2	800	20	8023			247 ^{±.8}	.32
	1	80	4	4	400	38	17239			303 ^{±.7}	.62
	2	80	8	4	400	38	19190			344 ^{±.4}	.84
	3	40	8	8	200	71	39167			400 ^{±.1}	1.14
	4	40	8	8	200	71	37569			473 ^{±.1}	1.53
	5	40	8	8	200	71	37047			555 ^{±.2}	1.93
	6	40	8	8	200	71	29471			750 ^{±.5}	3.02
	7	160	4	2	800	20	8535			209 ^{±.8}	.44
	8	80	8	4	400	38	18776			386 ^{±1.0}	1.07
	9	40	8	8	200	71	41399			550 ^{±.2}	1.95
	380	40	8	8	200	71	33662			730 ^{±.7}	2.41
	1	20	16	16	100	100	67651			920 ^{±.20}	3.93
illed	Neg reactivity										
disc	382	160	4	2	800	20	8002			187.2 ^{±.5}	186.6 aver
2 gk	3	80	4	4	400	30	17341			270 ^{±.7}	.45
	4	80	4	4	600	41	23032			342 ^{±.8}	.84
	5	40	8	8	200	68	32295			458 ^{±.1}	1.45
	6	40	8	8	200	68	34464			550 ^{±.4}	1.95
	7	40	8	8	200	68	35163			665 ^{±1.5}	2.56
	388	20	8	16	100	100	80227			810 ^{±.2}	3.34

186.6 aver

Scin Pulses ~ 5 V. max

Disc 2.5

92

7-9-62 8⁴⁵ AM

0.242 mg/ml

"Note"

2 Samples of Boron taken #7A-7B 7-11-62

Instrument Check on 7-10-62 Source 10 mc Pa 8

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 10 \times 10^{-11}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 10 \times 10^{-12}$	Meter Trip	OK		
IC-3	5×10^{-11}	Calibration	DW		
IC-4	5×10^{-11}	Calibration	DW		
CRM		Meter Trip			

Preliminary Check on 7-10-62

Room 113 Pressure Differential	DW
Red Light On and Personnel Check	C.C.
Scrams and Bldg. Alarm Reset	✓ C.C.
Source Inserted	Response OK
Safety Withdrawn	21.04"
Controls Set	Inner 25.40" Outer 0.08"
Reflector Water	~5 1/2 in. above Be.
Moderator Water	27.45 in.

EXP 481

Purpose: Determine crit pos of controls and determine crit decay constant. (see page 90)

Inner Outer Safety

	26.10	26.10	21.04	$\frac{11.6}{.42} = 27.6$	Pos Per
9 ³⁰ AM	25.68	25.68	21.04		level
10 ⁴³ AM	25.68	25.68	21.01	After PN 382	level

slightly cold after turning off acc.

481-487 pulsing acc p 90

EXP 488. Install new Safety @ 18.0 in
(2 in Cd Inserted)

Control Position (in)

		Inner	Outer	Safety	New Safety	
7-10-62	488	25.68	25.68	21.04	18.0	
	489	"	"	"	16.0	
	490	"	"	"	14.0	
	493	13.75	13.75	21.47	Removed	0.242 g Born
	494	"	13.25	"	"	
	5	"	12.75	"	"	
	6	"	12.25	"	"	
	7	"	11.75	"	"	
	8	"	11.25	"	"	
	9	13.25	13.75	"	"	
	500	12.75	"	"	"	Prob 13.25
	1	12.25	"	"	"	
	2	11.75	"	"	"	
	3	11.25	"	"	"	
	4	12.75	"	"	"	
		Two Section Control				Calib w. -24 g B/l
8-1-62	509	12.60	12.60	28.00	21.0 20.0 18.0 17.0	No Born in Moderator
	511	"	"	"	"	Two Section Control
	513	"	"	"	15.0	
	515	"	"	"	13.0	
	511					
8-26-62	521	12.625	12.625	21.48	Removed	
	522	12.60	12.10	28.0	"	
	523	"	11.60	"	"	
	524	"	11.10	"	"	
	525	"	10.60	"	"	
	526	"	10.10	"	"	

PN μs σ_{μ} σ_{σ} Burst Rate Rep Rate TPR

389 80 4 4 40 38 20932 379 ± 1 1.03
 390 40 8 8 200 68 31668 565 ± 1.4 2.03
 391 20 8 8 100 100 86127 810 ± 2 3.34

EST

392 160 4 2 800 20 9403 149 146.4 ± .3 0
 3 160 4 2 800 20 9645 256 0.72 250 ± .6 0.71
 4 80 8 4 400 38 18092 366 1.46 358 ± .8 1.45
 5 40 8 8 200 68 39094 475 2.19 470 ± 1 2.21
 6 40 16 8 200 68 39568 583 2.91 587 ± 1.5 3.01
 7 20 16 8 100 100 77995 711 3.77 717 ± 2 3.90
 8 160 4 2 800 20 10168 261 0.75 260.3 ± .7 .78
 9 80 8 4 400 38 18157 261 0.75 260.9 ± .7 .78
 400 80 8 4 400 38 20639 502 2.37 504 ± 1 2.44
 1 40 16 8 200 68 32819 640 3.29 625 ± 2 3.27
 2 40 16 8 200 68 35246 755 4.07 755 ± 2 4.16
 3 80 8 4 400 38 19758 381 1.56 387 ± .9 1.64

404 160 4 4 800 21 7129 266 .67 269 ± 1 0.65
 405 80 4 8 400 38 16305 337 1.12 331 ± 1 1.03
 406 40 8 16 200 70 51809 606 2.82 513 ± 1.5 2.64
 407 40 8 16 200 70 43169 822 4.17 825 ± 3 4.06

408 160 4 2 800 20 10000 159 0 162.9 ± .5 0 6.139 × 10⁻³
 409 160 4 2 800 21 9748 279 .77 281 ± .8 .73
 410 80 8 8 800 40 24649 400 1.52 405 ± 1 1.49
 411 80 8 8 400 40 17685 517 2.25 528 ± 1.5 2.24
 412 40 18 16 200 68 43398 667 3.20 655 ± 1.5 3.02
 413 40 8 16 200 68 39462 743 3.67 770 ± 2.2 3.73

July 19, 1962

ADJUSTMENT OF 2 SECTION
CONTROL PLATE


IRIG Meas. Inner control Top $39\frac{1}{4}$ above Be when @ 22.0
 Outer " " 26 " " " @ 22.0
 Controls adjusted the same.

Measured length of stem (Inner)

$39\frac{3}{4}$

($\frac{3}{4}$ in shorter than DWG)

E-42473



July 20,

Reset Inner so that top of control is 39 in
 above beryllium when seleny drive reads 22.0

Inner Adjust up limit switch to stop at 20.45
 Down at 20.50
 at 44.

Outer Adjust outer up limit switch to stop at ~~25.0~~ 25.05
 Down "

Changed seleny on outer (2") Fully inserted 99808
 Fully With 23.05
 Poison top edge of fuel 20.00

Changed seleny on inner (24") Fully inserted 996.45
 with 20.00

Instrument Check on 7-20-62 Source 10 mc / Ra

PM-1	Low Trip	✓	Alarm Trip	✓
PM-2			Alarm Trip	✓
IC-1	Meter Trip	✓	Fast Trip	✓
IC-2	Meter Trip	Scratched		
IC-3	Calibration	DOWN		
IC-4	Calibration	DOWN		
GRM	Meter Trip			

Preliminary Check on 7-20-62

Room 113 Pressure Differential	0.1 in H ₂ O
Red Light On and Personnel Check	X
Scrums and Bldg, Alarm Reset	X
Source Inserted	X Response noted
Safety Withdrawn	X 21.47
Controls Set	In 996.45 out 998.08 (Max Abs. Inserted)
Reflector Water	5" above Be
Moderator Water	27.1 in

EXP 491

Purpose: Determine crit pos of inner and outer 2 section control at delayed critical with ~ 0.242 g/l born in moderate water.

Inner	Outer	Safety	
13.76	13.84	21.47	+56.1 → 15.14 = 13.74
13.76	13.73	21.47	level

12.75 Reduce power to measure + period with inner.

13.84	13.73	21.47	+ per 69.5 → 13.04
13.75	13.73	"	level
13.725	13.725	27.0	level.

Shut down by dropping safety, draining Moderator and inserting inner and outer.

EXP 492

Purpose: Repeat ~~of~~ 491 for reproducibility check
 Inert Order Safety

13.78 13.78 27.00 + 88.7 sec 10.8 f

Shut down by inserting ~~the~~ order & In & Safety
 address H₂O

Instrument Check on 7-23-62 Source 10mc 8

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 Meter Trip OK Fast Trip OK
 IC-2 Meter Trip OK
 IC-3 Calibration OK
 IC-4 Calibration OK
 CRM Meter Trip

Preliminary Check on 7-23-62

Room 113 Pressure Differential OK
 Red Light On and Personnel Check OK
 Scrams and Bldg, Alarm Reset OK
 Source Inserted Inserted OK
 Safety Withdrawn CB 8 27.0
 Controls Set In 99.645 Out 99.803
 Reflector Water ~5" above 20
 Moderator Water 97.0

Check P Height from ^{Plastic} Scintillator ^{on 6810A} HPA HP 13 → 60.2 max
 with PaBe source. 1500 v on 6810A

EXP. 493

Purpose: Critical position of controls at 0.242 g Boron per liter water target assembly, and then control calibrations.

Inner	Outer	Safety	
13.82	13.72	27.0	+ 88.7 sec 692 → 10.8
	↓		6 = 180
	13.66		level.
	↓		
13.82	13.70	21.47	"
	↓		
13.75	13.75	21.47	"

Pulse at critical PM-392 see page 94-95
 level after pulsing at critical

See pages 94-95 for rod calibration

Instrument Check on 7-24-62 Source 10mc δ

PM-1	Low Trip	Swammed	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 10 \times 10^{-11}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 10 \times 10^{-12}$	Meter Trip	OK		
IC-3	3×10^{-11}	Calibration			
IC-4	6×10^{-11}	Calibration			
CRM		Meter Trip			

Preliminary Check on 7-24-62

Room 113 Pressure Differential 0.1" H₂O Alarm

Red Light On and Personnel Check Alarm

Scrams and Bldg. Alarm Reset Alarm

Source Inserted Alarm

Safety Withdrawn 27.02

Controls Set In 7.00 Out 7.00

Reflector Water ~ 5" above Be

Moderator Water 27.21

Exp 505

Purpose: Power dist. with 2 section control and 0.242 g Boron in Moderator

Inner	P-1	in	a-37
Outer	P-2		a-1
Outer	F-2		b-78
Outer	F-4		b-1

$15.1 / 106 = 2.5 / \mu$

Inner Outer Safety

13.80 13.80 27.02 27.21 + period w. source in!

10 ^{43:45} Start timing foil exposure 3.1×10^{-9} on IC-2

13.74 13.74 and @ 8.15×10^{-9} on IC-2

11 ^{03:45} Stop foil Exp $(4 \times 10^{-9} \text{ IC-3}) (1.45 \times 10^{-8} \text{ IC-4})$

July 30, 1962

Drained out 0.24 g/liter brown solution, sampled 8A and 8B. Moderator refilled with tap water to raise system. Reassembled roller guides after inserting fuel plates.

Vol of 5 ft tank (44L) $\frac{\pi}{4} \times 5^2 \times 3 = 58.9 \text{ ft}^3 \xrightarrow{28.3} 1667 \text{ L} \xrightarrow{3.785} 440 \text{ gal}$
 $\approx 46.37 \text{ inch}$

Instrument Check on 7-30-62 Source 10 mc Pu

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 10 \times 10^{-11}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 10 \times 10^{-12}$	Meter Trip	Scrammed Safety only		
IC-3		Calibration	See log		
IC-4		Calibration	See log		
CRM		Meter Trip			

Preliminary Check on 7-30-62

Room 113 Pressure Differential	0.1" H ₂ O
Red Light On and Personnel Check	C.E.
Scrams and Bldg, Alarm Reset	C.E.
Source Inserted	C.C.
Safety Withdrawn	C.E.
Controls Set	996, 998
Reflector Water	25 in above BR
Moderator Water	27.5 in

Exp # 506

Purpose: Position of controls with tap water and to raise fuel element of traces of brown.
 12.65 12.65 + with source returned
 Dropped safety & shutdown
 $\approx 4.25 \text{ f excess react.}$

3 IC-4)

July 30-31. Drained H₂O from 5' tank in order to remove the "cover" fissin counter. (and barrels and 30 in sphere for storage) A large amount of flocculent material drained out, probably Al(OH)₃. Filtered water when returned to tank after counter hole sealed with gasket and flange.

#13
ed. 12

Instrument Check on 7-31-62 Source 10 m

PM-1	Low Trip	<u>scrapped</u>	Alarm Trip	<u>OK</u>
PM-2			Alarm Trip	<u>OK</u>
IC-1	Meter Trip	<u>OK</u>	Fast Trip	<u>OK</u>
IC-2	Meter Trip	<u>OK</u>		
IC-3	<u>4x10⁻¹¹</u>	Calibration		
IC-4	<u>6x10⁻¹¹</u>	Calibration		
CRM	Meter Trip			

Preliminary Check on 7-31-62

Room 113 Pressure Differential	<u>OK</u>
Red Light On and Personnel Check	<u>cc</u>
Scrams and Bldg. Alarm Reset	<u>cc</u>
Source Inserted	<u>c.c.</u>
Safety Withdrawn	<u>28.0"</u>
Controls Set	<u>Inner 996.45 Outer 998.08"</u>
Reflector Water	<u>Approx 5 1/2" Above Bc</u>
Moderator Water	<u>Approx 27.5"</u>

Exp # 507 7-31-62

Position of Controls with Demineralized H₂O in fuel System

Inner	outer	Safety		
12.65	12.65	28.00	12.24	Pos Per
12.65	12.56	"	.09 = 1.36/in	level
12.60	12.60	"		level
Shut Down				

7-31-62

Sample 9498 taken from moderator H₂O
 10 " from Reflector H₂O

C.C.
 C.C.

Instrument Check on 8-1-62 Source 10mc X

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 >10 x 10⁻⁴ Meter Trip OK Fast Trip Scrammed
 IC-2 >10 x 10⁻¹² Meter Trip OK
 IC-3 Calibration Done
 IC-4 Calibration Done
 CRM Meter Trip

Preliminary Check on 8-1-62

Room 113 Pressure Differential OK
 Red Light On and Personnel Check C.C.
 Scrams and Bldg, Alarm Reset C.C.
 Source Inserted Response 2 3 4 4 Done
 Safety Withdrawn 28.0 Done
 Controls Set Inner 99644 Outer 99804
 Reflector Water Approx 5 1/2" Above BC
 Moderator Water Approx 27"

EXP 508 Cal cylinder at ^{21.0} 20.0 position (21.0) ⁻¹
 return fuel amount No Boron

Inner	Outer	Safety	New Safety	Cal. Cyl.	Pos	Per
12.85	12.85	28.00	21.0	20.0	11.4	Pos Per
12.85	12.775	"	21.0	20.0	11.4	1.52 level
12.81	12.81					level

EXP 509

12.60	12.60	28.00	21.0	20.0	See page 94-95 for pulsing details	
-------	-------	-------	------	------	---------------------------------------	--

10 ⁰³ AM

EXP # 510

8-1-62

	Inner	Outer	Safety	New Safety	
	13.00"	13.00"	28.0"	18"	13.14 Pas Per
	13.00"	12.90	"	"	#1.319/in level
	12.94	12.94	"	"	level
(EXPSI)	12.60	12.60	"	"	Subcrit Pulsing

EXP # 512

	Inner	Outer	Safety	New Safety	
	13.60	13.60	28.0"	15"	9.74 Pas Per
	13.60	13.52	"	"	1.08 = 1.21/in level

11²⁵ Magnet dropped safety - ~~failure~~ ^{airing from stopped also.} level

	13.56	13.56	28.00	15"	level
--	-------	-------	-------	-----	-------

EXP # 513

	12.60	12.60	28.00	15"	Sub crit
--	-------	-------	-------	-----	----------

EXP # 514

	14.32	14.32	28.00"	13	13.8 Pas Per
	14.32	14.20	"	"	= 1.15/in level
	14.27	14.27	"	"	level

EXP # 515

	12.60	12.60	28.0"	13	(Pulsing) Sub Crit
--	-------	-------	-------	----	--------------------

EXP # 516

	15.36	15.36	28.0"	11	+10.34 Pas Per
	15.29	15.36	"	"	07 level
	15.31	15.31	"	"	= 147/in "

Exp # 517

8-1-62

Inner	Outer	Safety	new safety	
16.77	16.77	28.0	9"	+10.54 Pos Per 05 level
16.69	16.77	"	"	"
16.71	16.71	"	"	= 13 1/2 level

shut Down

Exp # 518

Inner	Outer	Safety	new safety	
18.75	18.75	28.0"	7"	+10.64 Pos Per .25 level
18.75	18.50	"	"	"
18.67	18.67	"	"	= 42.4 #/in level

shut Down

Note
6" swgn
8-10-63

Exp # 519

Inner	Outer	Safety	new safety	
20.17	21.31	28.0"	5"	+0.8 Pos Per .72 level
20.17	20.59	"	"	= 15.0 #/in

4:20 PM

shut Down

Instrument Check on 8-2-62 Source 10 mc

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	OK
IC-1	$2/10 \times 10^{-11}$	Meter Trip	Screwed	Fast Trip OK
IC-2	$2/10 \times 10^{-12}$	Meter Trip	OK	
IC-3	5×10^{-11}	Calibration	swgn	
IC-4	6×10^{-11}	Calibration	swgn	

Preliminary Check on 8-2-62

Room 113 Pressure Differential	swgn
Red Light On and Personnel Check	C.C.
Scrums and Bldg, Alarm Reset	C.C.
Source Inserted	swgn Inst response OK
Safety Withdrawn	28.00"
Controls Set	INNER 10.14 Outer 998.08
Reflector Water	Approx 5 1/2" Above Be
Moderator Water	~ 270

Exit

v

8-2-62 EXP 520 Purpose: Power Distribution Meas
with 2 section controls and no boron in moderator

$$\left[\begin{array}{l} P-1 \text{ is } a-37, P-2 \text{ is } a-1 \\ F-2 \text{ is } b-78, F-4 \text{ is } b-1 \end{array} \right]$$

Scin. det moved from top of core!

Inner Outer Safety

IC-2

12.60 12.66 28.0 Pos Period + 12.7 s

9:05:20

12.62 12.61

level at

3.0×10^{-9} Start timing for exp.

9:25:20

8.1×10^{-9} Stop Fil.

$$\frac{12.7}{.045} = 282.9 \text{ /in}$$

8-2-62

EXP # 521

New Safety Removed

Pulsing AT Critical with H₂O in fuel Section

Inner Outer Safety

12.65 12.65 28.01 Pos Period + 12.7 s

12.55 12.65 28.01 Level .10

12.595 12.65 21.48 " = 130.9 /in

12.625 12.625 " Pulsed at crit.

level After PN - 408

EXP # 522 - 526 see p 94-95

527 - 531 see p 108-109

11
N

Aug 3, 1962 Time 2206

Instrument Check on 8-3-62 Source 10mc 8

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 710 x 10⁻¹¹ Meter Trip OK Fast Trip OK
 IC-2 710 x 10⁻¹² Meter Trip OK
 IC-3 4 x 10⁻¹¹ Calibration swm
 IC-4 5 x 10⁻¹² Calibration swm
 CRM Meter Trip

Preliminary Check on 8-3-62

Room 113 Pressure Differential OK
 Red Light On and Panel Check C.C.
 Screams and Bldg. Alarm Test C.C.
 Source Inserted Accelerator
 Safety Withdrawn 28.0"
 Controls Set Inner 12.60 Outer 998.08
 Reflector Water Approx 5 1/2" Above Be
 Moderator Water 27.21"

Exp # 532 8-3-62
 Inner Outer Safety New Safety
12.60 12.60 28.0" Removed level
 See page 108-109 for #533-537

Note

Drained H₂O Moderator and refilled with unknown
 brown solution < 0.45 g/liters (95%)
 Exp 538 Purpose crit pos with brown
solution in fuel.
 Inner Outer Safety
14.21 14.21 28.0 Pos Period + 10.84
14.21 14.12 28.0 level 09
 Shut Down = 1204/in

DATE	EXP.	INNER	OUTER	SAFETY	
8-2-62	527	10.60	12.60	28.0	TWO SECTION CONTROLS
	528	10.60	"	"	- NO BORON
	529	11.10	"	"	
	530	11.60	"	"	
	531	12.10	"	"	
8-3-62	533	12.60	12.60	18.0	
	4	"	"	16.0	
	5	"	"	14.0	
	6	"	"	12.0	
	7	"	"	10.0	
8-6-62	541	15.25	15.25	21.47	Boron em ~.5146 g/l Crit
	542	"	14.75	"	
	543	"	14.25	"	
	544		13.75	"	
	545		13.25	"	
8-7-62	548	15.26	12.75	"	
	549	"	12.25	"	
	550	"	11.75	"	
	551	14.75	15.26	"	
	552	14.25	"	"	
	553	13.75	"	"	
	554	13.25	"	"	
	555	12.75	"	"	
	556	12.25	"	"	
	557	11.75	"	"	
	558	14.75	14.75	"	
	559	14.25	14.25	"	
	560	13.75	13.75	"	
	561	13.25	13.25	"	

PN	CH μs	BKG	Delay	Quest	Rep Rate	Total	EST.		λ	S
							λ	S		
414	40	16	16	200	68	39491	-845	4.31	840 ± 3	4.16
415	40	8	16	200	68	51318	-709	3.46	714 ± 1.5	3.38
416	80	8	8	400	39	19345	-569	2.58	576 ± 1.7	2.54
417	80	8	8	400	39	18117	426	1.68	437 ± 1.	1.68
418	160	4	4	800	19	12208	298	.87	299 ± 0.9	.84
419	160	4	4	800	19	11418	258	.62	258 ± .9	.58
420	80	8	8	400	39	26109	368	1.31	366 ± .9	1.25
421	80	8	8	400	39	21804	522	2.28	514 ± 1.5	2.16
422	40	16	16	200	67	54579	698	3.39	690 ± 1.6	3.24
423	40	16	16	200	67	52044	853	4.37	863 ± 3	4.30
424	160	4	4	800	12	10002	130	0	200 (21.45) → 12.0	129.2
425	160	4	4	800	19	9331	213	.64	7.73944 = 0.58 Disc 2 ~ 2 no change	203.6 ± .7
426	80	8	8	400	39	24395	294	1.26	Bkg Ratio	-1.20 284 ± .8
427	80	8	8	400	39	20895	375	1.88		-1.85 368 ± 1
428	80	8	8	400	39		465	2.58		-2.51 454 ± 1.4
429	40	8	8	200	68	50438	565	3.35	(Disc 3 to improve bkg after Fil 554 ± 2	-3.29
430	40	8	8	200	68	40453	663	4.10	expand and crit Run (Disc 2) ± 2	-3.95 2.7 540
431	40	8	8	200	68	42870	737	4.67		-4.65 730 ± 2
432	160	4	4	800	19	10875	215	.65	Disc 2.4	-0.68 216.5 ± .6
433	80	8	8	400	38	30278	297	1.28		-1.34 302 ± .8
434	80	8	8	400	38	24913	394	2.03		-2.03 391 ± 1
435	80	8	8	400	38	19504	483	2.71		-2.76 486 ± 1.6
436	40	16	16	200	68	58379	583	3.48		-3.53 585 ± 2
437	40	16	16	200	68	65503	667	4.13		-4.28 682 ± 2
438	40	16	16	200	68	41087	794	5.11		-5.00 775 ± 3
439	80	8	8	400	38	19542	296	1.28		-1.24 296 ± .8
440	80	8	8	400	38	24628	453	2.48		-2.55 462 ± 1
441	40	16	16	200	68	62551	649	3.99		-3.95 640 ± 2
442	40	16	16	200	68	41742	808	5.21		-5.35 820 ± 5

"Note"

8-3-62 - Samples #10A-10B taken from Mod H₂O
 Added 100g Boric Acid to Mod H₂O system
 And mixed by circulating.

[10B] = 0.354 g/liter 8-7-62

Exp # 539

8-2-62

Inner - Outer

Safety

14.21 998.08

28"

15.28 15.28

..

+11.7

Pos Per

15.28 15.17

..

..

level

Shut Down

= 106.4 in

N.B. thru. Beam tube filled with H₂O

Exp # 540 Progress Measure react change

from flooding thru. Beam tube.

15.28 15.28

28.0

11.7

Pos Per

15.28 15.17

28.0

..

level

Shut Down

= 106.4 in

"Note"

8-6-62 - Samples #11A-11B taken from Mod. H₂O

(11B 0.566 g/liter 8-7-62)

Instrument Check on 8-6-62 Source 10 mc γ

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 5×10^{-11} Meter Trip OK Fast Trip OK
 IC-2 $> 10 \times 10^{-12}$ Meter Trip OK
 IC-3 4×10^{-11} Calibration Down
 IC-4 5×10^{-12} Calibration Down
 CRM Meter Trip _____

Preliminary Check on 8-6-62

Room 113 Pressure Differential Down
 Red Light On and Personnel Check OK
 Scrams and Bldg, Alarm Reset Down
 Source Inserted Acc
 Safety Withdrawn 28.0"
 Controls Set INNER 996.44 Outer 998.08
 Reflector Water Approx 5 1/2" Above Be
 Moderator Water Approx 27.0

Exp # 541

8-6-62

Check Crit Position of Controls

	INNER	Outer	Safety	New Safety
15.28	15.28	28.0"	Removed	7.04 Pos Per
15.28	15.215	"	"	06.25 level
15.24	15.24	"	"	1084/in level
15.255	15.255	21.47"	"	level

See page 108 preliminary @ Crit level After PN-424

542-545 on p 108-109

PM-1		Low Trip <u>Scrammed</u>	Alarm Trip	<u>OK</u>
PM-2			Alarm Trip	<u>OK</u>
IC-1	<u>710×10^{-9}</u>	Meter Trip	<u>OK</u>	Fast Trip <u>OK</u>
IC-2	<u>710×10^{-12}</u>	Meter Trip	<u>OK</u>	
IC-3	<u>40×10^{-11}</u>	Calibration	<u>OK</u>	<u>Done</u>
IC-4	<u>$5A 10^{-11}$</u>	Calibration	<u>OK</u>	<u>Done</u>
CRM		Meter Trip		

Preliminary Check on 8-7-62

Room IIS Pressure Differential OK
 Red Light On and Personnel Check DWM
 Scrams and Bldg. Alarm Reset CC
 Source Inserted Accelerator
 Safety Withdrawn 28.0
 Controls Set In = 15.0 Out 99808
 Reflector Water Approx $5\frac{1}{2}$ " Above Bc
 Moderator Water _____

Exp # 5468-7-62

foil Exposure

Inner	Outer	Safety	New Safety
15.34	15.34	28.00"	Removed +13.3" Pos Per

Start timing 20 min foil Exposure 3×10^{-9} on IC-2
 level at 8.1×10^{-9} on IC-2

15.27	15.27	28.00"	1.07 = 190 μ level
-------	-------	--------	------------------------

9:28

Shut Down - Scramed System

Exp # 5478-7-6210:30 AM

Purpose: Check Crit Pos After Power Run

15.31	15.31	21.48	Removed +10.0" Pos Per
-------	-------	-------	------------------------

15.26	15.26	"	1.05 = 200 μ level
-------	-------	---	------------------------

#548-561 See page 108-109

3:00 PM Checked Bldg alarm using source on PM-2!

Aug 7

Note Removed Boron solution of $N 0.5 - 0.6 \text{ g/l}$
 added ~ 45 liters of 1.16 g/l Boron solution
 Added $23\frac{1}{2}$ liters of $+ 163 \text{ g}$ of H_3BO_3 & Mix
 Instrument Check on 8-8-62 Source $10 \text{ m} \times$

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	OK
IC-1	$> 10 \times 10^{-11}$ (Noise) Meter Trip	OK	Fast Trip	OK
IC-2	$> 10 \times 10^{-12}$ Meter Trip	Scrammed		
IC-3	5×10^{-11} Calibration	SWM		
IC-4	6×10^{-11} Calibration	SWM		
CRM	Meter Trip			

Preliminary Check on 8-8-62

Room 113 Pressure Differential	OK	CC
Red Light On and Personnel Check	CC	
Serams and Bldg. Alarm Reset	CC	
Source Inserted	✓	
Safety Withdrawn	28.0	
Controls Set	INNER 996.45	Outer 998.08"
Reflector Water	Approx $5\frac{1}{2}$ "	Above Be
Moderator Water	$\sim 27\frac{1}{2}$	

Exp # 562

8-8-62

Purpose: Check Crit Pos of Controls After
 Charging Boron Conc. ($N 1.2 \text{ g/l}$) Target ass. installed

INNER	Outer	Safety	New Safety
20.18	23.05	28.0"	Removed $+6.54 \text{ pos}$ Per
20.18	21.76	"	$\frac{6.5}{1.121} = 5.9 \text{ level}$
20.18	23.05	20.46	" "
20.18	22.03	21.48	" level
19.834	23.05	28.00"	$\frac{6.5}{1.35} = 19.4 \text{ level}$

Exp # 563

8-8-62

Re-Check Crit Position in Exp # 562

Inner	Outer	Safety		
20.18"	23.05"	28.0"	+5.3	Pos Per
20.18	23.05	21.48"	+2.9	Pos For
20.18	22.26	21.48	21.79 =	level

Level after Pulsing PN-443

116

	ETP NO	INNER	OUTER	SAFETY	
8-8-62	563	20.18	22.26	21.48	BORAN N1.2 g/l CRIT.
	4	"	20.00	"	147K1 G5 S.F.
	5	"	19.00	"	
	6	"	18.00	"	
	7	"	17.00	"	
	8	"	16.00	"	
	9	"	15.00	"	
	570	"	14.00	"	
	1	"	13.00	"	
	2	19.00	22.26	"	
	3	18.00	"	"	
	4	17.00	"	"	
	5	16.00	"	"	
	6	15.00	"	"	
	7	14.00	"	"	
	8	13.00	"	"	
8-9-62	580	20.18	21.66	"	
	1	20.18	21.66	20.60	Not pulsed
	2	19.00	19.00	"	
	3	18.00	18.00	"	
	4	17.00	17.00	"	
	5	20.18	21.66	18.0	
	6	"	"	16.0	
	7	"	"	13.0	New Safety
8-10-62	589	20.18	21.71	28.00	15.0 (5.0)
	590	"	"	"	13.0 (7.0)
	591	"	"	"	18.0 (2.0)
	592	19.0	19.0	19.0	21.0

PM-1	Low Trip	071	Alarm Trip	070
PM-2			Alarm Trip	070
IC-1	>10x10 ⁻¹¹	Meter Trip	070	Fast Trip 070
IC-2	>10x10 ⁻¹¹	Meter Trip	070	
IC-3	5x10 ⁻¹¹	Calibration	Down	
IC-4	6x10 ⁻¹¹	Calibration	Down	
CRM		Meter Trip		

Preliminary Check on 8-9-62

Room 113 Pressure Differential	OK
Red Light On and Personnel Check	C.C.
Scrams and Bldg. Alarm Reset	C.C.
Source Inserted	C.C.
Safety Withdrawn	28.0"
Controls Set:	Inner 996.45 Outer 998.08"
Reflector Water	Approx 5 1/2" Above Be
Moderator Water	27.3"

Exp # 579

8-9-62

Check Critical Position of Controls

9:30 AM

Inner	Outer	Safety	+2.34 change of 3.04
20.18	23.05	28.0	Just Slightly Super crit
Shut Down - And Added 500 ML H ₂ O (And Mixed)			

Exp # 580

8-9-62

Check Crit Pos After Adding 500 ML to Mod H₂O

Inner	Outer	Safety		
20.18	23.05	28.0"	10.04	Pos Per level
20.18	21.44	28.0		level
20.18	21.66	21.48		level
level After PN-459				

Exp # 581

20.18	23.05	28.0	+8.6	Pos Period
20.18	22.26	28.0	+5.8	Pos Period
20.18	22.26	20.6		Crit level

8-9-62 Exp II 582 - 587 Pulsing PN - 460 - 465

Instrument Check on 8-10-62 Source 10 mc δ

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	7.10×10^{-11}	Meter Trip	OK	Fast Trip	OK
IC-2	7.10×10^{-12}	Meter Trip	OK		
IC-3	4×10^{-11}	Calibration	Down		
IC-4	5×10^{-11}	Calibration	Down		
CRM		Meter Trip			

Preliminary Check on 8-10-62

Room 115 Pressure Differential OK
 Red Light On and Personnel Check C.C.
 Scrums and Bldg. Alarm Reset CC
 Source Inserted Inst Response OK
 Safety Withdrawn 28.0"
 Controls Set INNER 995.60 Outer 998.08
 Reflector Water Approx 5 1/2" Above Be
 Moderator Water

Exp # 588 8-10-62

Check Crit Pos of Controls

	INNER	Outer	Safety	
	20.18	23.05	28.0"	+7.04 Pos Per
	20.18	21.71	28.0	level

Note Shut Down - Install New Safety

Exp # 589 8-10-62

	INNER	Outer	Safety	New Safety	
#589	20.18	21.71	28.0	15.0"	Sub crit

(P_{sub} C)

120

Exp # 592

8-10-62

	INNER	Outer	Safety	New Safety	
592	20.18	23.05-6.4	28.0"	21.0"	(A) sub crit
592	20.18	21.71-9.8	28.0"	21.0"	Neg Per (B)
		See p 116 for pulsing			
593	19.0	19.0	19.0	21.0	

"Note" 8-10-62 Samples # 12A-12B taken from mod H₂O
1.173

Instrument Check on 8-13-62 Source 10 mc

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	OK
IC-1	> 10 x 10 ⁻¹²	Meter Trip	Scrammed	Fast Trip OK
IC-2	> 10 x 10 ⁻¹²	Meter Trip	OK	
IC-3	5 x 10 ⁻¹²	Calibration	OK	
IC-4	6 x 10 ⁻¹²	Calibration	OK	
CRM	Meter Trip			

Preliminary Check on 8-13-62

Room 113 Pressure Differential	OK	CC
Red Light On and Personnel Check	CC	
Scrams and Bldg. Alarm Reset	CC	
Source Inserted	Response	OK
Safety Withdrawn	28.0"	
Controls Set	INNER 12.0"	Outer 998.08"
Reflector Water	Approx 5 1/2"	Above Bc
Moderator Water	Approx 27.0"	

"Note" 8-13-62 - Added 250 ML H₂O to fuel system and mixed
9³⁰ AM Add 500 ML

Exp # 593

8-13-62

	INNER	Outer	Safety	
	20.18	23.05	28.0"	Slightly Super Crit

8-13-62

"Note" Add 500 ml H₂O to Fuel H₂O System AND Mix

Foil Exposure: P-1 in a-37
 P-2 in a-37
 F-2 in b-78
 F-4 in b-1

EXP # 594

8-13-62

	INNER	Outer	Safety	Pas	Per
10 ⁰³	20.18	22.60	28.00"		

Start timing 20 min foil Exposure At 3×10^{-9} on IC-2

10 ²⁸	20.18	21.15	28.00"	8.1×10^{-9}	on IC-2 level
------------------	-------	-------	--------	----------------------	---------------

Scram System to shut Down

"Note" Sample #13 - Crud that was collected from Island Refl H₂O when it was drained to Remove Counter suction

8-13-62 Samples #14A-14B taken from Mod H₂O
 1153

"Note" 8-30-62 - H₂O Samples for Spec Analysis should be taken to (Pritchard) Spec lab in Bldg 4500-5 E-159.

Mean of 3 action controls (plated grey)

	inner	outer		inner	outer
TD Top	18.036	18.018	—	17.317	17.321
PenTex	18.056	18.035	—		
Bottom	18.038	18.033	—	17.285	17.256

Mixed

2

†

Sept 6, 1962

Mechanics installed 3 section controls with plated grey sections $4 \frac{3}{4}$ in.

Outer Control		Inner Control	
Upper	27.49	Down	27.81
Grey inter core	24.75	Grey inter core	24.75
Blk inter core	20.00	Blk inter core	20.00
Blk Blk @ Mid	10.00	Blk Mid	10.00
Blk inner	998.63	Upper	998.04

N.B. Keithley Repaired IC-1

E-H electrometer replaced with linear Beckman on IC-2


thickness miss on 4 pc of stripped Ag plate from outside of inner ^{Control}

21.0	18.6	13.4	14.5
22.5	18.0	13.4	14.9
17.8	13.5	13.5	14.9
14.5	13.1	17.1	19.2
15.5	15.8	17.2	16.6

4-23-63

My memory says that the black tip of the $3/4$ overlapping grey and blk sections was at the top of fuel when selenium read 20.0.

Dr. Magnuson



Instrument Check on 9-6-62 Source 10 mc/8

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	2×10^{-12}	Meter Trip	OK	Fast Trip	OK
IC-2	2×10^{-12}	Meter Trip	Drop Safety		
IC-3	2×10^{-11}	Calibration	Down		
IC-4	6×10^{-11}	Calibration	Down		
CRM		Meter Trip			

Preliminary Check on 9-6-62

Room 113 Pressure Differential Down
 Red Light On and Personnel Check C.C.
 Scrams and Bldg. Alarm Reset C.C.
 Source Inserted Down
 Safety Withdraw 28.0"
 Controls Set Inner 24.81 Outer 998.63
 Reflector Water Approx 5 1/2" Above Be
 Moderator Water 27.385"

Exp #595 (Time Reads 2240 hrs)
 Purpose: Det crit po. with 1.17 g ²³⁵U/Brom/Liter.

Inner	Outer	Safety		
24.81	25.05	28.01	+10.64	Pos Per
24.81	24.40	"	.65	→ 16.3% level
24.56	24.56	"		level

Exp #596 (9-6-62)
 Purpose: Reproduce Exp #595

Inner	Outer	Safety		
24.56	25.00"	28.01	9.8	Pos Per
24.56	24.49	"	.51	= 19.2% level
24.51	24.51	"		"

3:45 PM Shut Down

Instrument Check on 9-7-62 Source 10 mc Y

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 710 x 10⁻¹² Meter Trip OK Fast Trip OK
 IC-2 710 x 10⁻¹² Meter Trip OK
 IC-3 4 x 10⁻¹¹ Calibration down
 IC-4 5.5 x 10⁻¹¹ Calibration down
 CRM Meter Trip

Preliminary Check on 9-7-62

Room 113 Pressure Differential down
 Red Light On and Personnel Check C.C.
 Scrums and Bldg, Alarm Reset C.C.
 Source Inserted C.C.
 Safety Withdrawn 28.0"
 Controls Set Inner 998.05 Outer 998.62
 Reflector Water Approx 5 1/2" Above Be
 Moderator Water 27.02"

9-7-62 Exp # 597 - Check Critical

Inner	Outer	Safety	
24.51	25.10	28.0"	+6.4 # Pos Per
24.51	24.67	"	/43 = 14.9 g/in level
24.61	24.61	"	level

See p 126-127 for exp 597-691
 Shut down by using acc source to trip IC-2

Instrument Check on 9-10-62 Source 10 mc Ra @ Y

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 710 x 10⁻¹² Meter Trip OK Fast Trip OK
 IC-2 710 x 10⁻¹² Meter Trip OK
 IC-3 4.5 x 10⁻¹¹ Calibration OK down
 IC-4 5.0 x 10⁻¹¹ Calibration OK down
 CRM Meter Trip

Preliminary Check on 9-10-62

Room 113 Pressure Differential OK
 Red Light On and Personnel Check C.C.
 Scrums and Eldg, Alarm Reset C.C.
 Source Inserted Response OK
 Safety Withdrawn 28.0"
 Controls Set Inner 24.61 Outer 998.62
 Reflector Water Approx 5 1/2" Above Be
 Moderator Water _____

Exp # 612 Pulse @ Critical 9-10-62

Inner	Outer	Safety		
24.61	25.45	28.0"	7.94	Pos Per
24.61	24.84	28.0"		61 = 13.0 #/in level
24.61	25.18	20.76		level
24.81	25.03	20.76		level

Started pulsing - limit stop became erratic shut down and found limit switch mount twisted.

Checked safety position, found relay reading +0.31 when top of safety even with top of central water hole tube which is 10 in above the fuel. Therefore at +0.31 calcium tip is 4 in above the fuel.

Reset relay to read ~~0.25~~ 0.25.

Up limit switch is now stopping at reading of ~~998.05~~ 998.35
 Down " " " " " " " " " 998.35

Exp # 613 Pulse @ Critical

Inner	Outer	Safety		
24.81	26.00	21.11	11.64	Pos Per
24.81	24.93	21.11	1.07	= 10.8 #/in level
24.81	24.93	21.11		level After PU 487

	EXP No	INNER	OUTER	SAFETY	
9-7-62	597	24.61	24.61	28.00	Not Pulsed ~1.16 g B / liter
	598		23.61	"	press 1.5×10^{-5} GEISA 2 100 v
	599	"	22.61		147 K U pulsed ~6 v max
	600		21.61		Disc 2.5
	601		20.61		
	602		19.61		
	603		18.61		
	604		17.61		
	605		16.61		
	606	22.61	24.61		
	607	20.61			
	608	18.61			
	609	16.61			
	610	22.61	22.61		
	611	20.61	20.61		
9-10-62	612	24.81	25.03	20.76	
	613	24.81	24.93	21.11	
9-11-62	615	14.97	14.97	28.00	Crit Not Pulsed No Boron
	616	"	14.47	"	
	617	"	13.97	"	
	618	"	12.97	"	
	619	"	11.97	"	
	620	"	12.47	"	
9-17-62	623	14.98	14.98	21.10	CRIT (pulsed)
	624	14.97	14.97	21.31	
	625	14.47	"	"	
	626	13.97	"	"	
	627	13.47	"	"	

P N	CH μs	BKG	Delay	BU R μs	REP RATE CPS	TOTAL CYCLES	Value						
472	320	4	4	1600		3851							
472	320	4	4	1600	10	3851	119	119.6	± 5.5	0.16	115	± 1	
3	320	4	4	1600	10	5833		150.2	± 6.6	0.52	150	± 2	
4	160	8	8	800	20	14520		190.8	± 5	0.93	191	± 2	
5	160	8	8	800	20	13043		244.6	± 6	1.48	245	± 2	
6	80	8	8	400	39	24353		309.1	± 7	2.13	309	± 3	
7	80	8	8	400	39	20944		384	± 1	2.89	384	± 4	
8	40	16	16	200	65	51131		474	± 1	3.80	474	± 5	
9	40	16	16	200	65	36745		570	± 2	4.77	570	± 6	
480	320	4	4	1600	10	7986		139.7	± 5	0.41	139	± 2	
1	160	8	8	800	20	10629		218.5	± 5	1.22	219	± 2	
2	80	8	8	400	39	37446		345.2	± 7	2.49	345	± 3	
3	40	16	16	200	65	63041		522	± 1	4.28	522	± 5	
4	160	8	8	800	20	14571		194.0	± 5	0.96	191	± 2	
5	80	8	8	400	39	11		372.0	± 7	2.77			
486	320	4	4	1600	10	2386		98.0	± 5		98.8	± 1.0	(10/21)
487	320	4	4	1600	10			99.5	± 3				
488	160	4	4	800	21	11601		263.5	± 8	.61	264	± 3	
9	80	8	8	400	39	24321		356	± 8	1.17	356	± 4	
490	40	8	8	200	71	43397		541	± 1	2.30	541	± 6	11
1	40	8	8	200	71	36172		723	± 2	3.41	723	± 9	
2	40	8	8	200	71	42391		634	± 1	2.87	4.634	± 6	
493	160	4	8	800	18	10001		163.8	± 4	.00610	Tape	163.8	± 1.6
494	160	8	8	800	18	9519		267	± 7	.63	Tape	267	± 3
495	80	8	8	400	39	20412		374	± 8	1.28	No Tape		
496	80	8	8	400	39	23313		475	± 1	1.90	No Tape		

128

Instrument Check on 9-11-62 Source 10 mc γ

PM-1 Low Trip OK Alarm Trip OK
 PM-2 Alarm Trip OK
 IC-1 > 3x10⁻¹¹ Meter Trip Scrammed Fast Trip OK
 IC-2 > 3x10⁻¹² Meter Trip OK
 IC-3 3x10⁻¹¹ Calibration DW²
 IC-4 5x10⁻¹¹ Calibration DW²
 CRM Meter Trip _____

Preliminary Check on 9-11-62

Room 113 Pressure Differential OK
 Red Light On and Personnel Check C.C.
 Screens and Bldg, Alarm Reset C.C.
 Source Inserted ✓ C.C.
 Safety Withdrawn 28.0"
 Controls Set INNER = 998.05 Outer = 998.62
 Reflector Water Approx 5 1/2" Above Bc
 Moderator Water APPROX 27.0"
 EXP 614 Purpose: Crit for no beam

INNER OUTER SAFETY

INNER	OUTER	SAFETY		Pos. Per.
15.08	15.08	28.01	14.94	
15.08	14.95	"	$1.12 = 1.11/2$	Level
14.98	14.98	"	1.12	Level
14.88	15.08	"	$1.12 = 75^{\circ}$	Level

Assembly quite unstable on
 controls are sticking and rubbing. Assembly
 difficult to level. Drain H₂O in fuel assembly.
 EXPERIMENT #615 Repeat 614

14.96	15.08	28.0"	12.3	Pos Per
14.96	14.975	28.0"	$1.1 = 1.123/2$	level
14.85	15.08	28.0"	$1.11 = 1.12/2$	level
14.965	14.965	28.0"		level

Exp # 621

9-11-62

129

Purpose: Control Calibration

Inner	Outer	Safety	
14.97	15.06	28.0"	+11.1 Pos Per
14.97	14.96	"	1.1 = 111/2 level
15.89	14.00	"	"
16.965	13.00	"	"
18.29	12.00	"	"
19.92	11.00	"	"
22.44	10.00"	"	"
24.81	9.52	"	"
14.04	16.00"	"	"
13.23	17.00"	"	"
12.52	18.00"	"	"
11.92	19.00	"	"
11.38	20.00"	"	"
10.48	22.00"	"	"
9.94	24.00"	"	"
9.70	26.00	"	"
9.56	27.49	"	"

322

Shut Down

Instrument Check on 9-13-62 Source 10mc ✓

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$>10 \times 10^{-11}$	Meter Trip	OK	Fast Trip	OK
IC-2	$>10 \times 10^{-12}$	Meter Trip	OK		
IC-3	4×10^{-11}	Calibration	Down		
IC-4	5×10^{-11}	Calibration	Down		
CRM		Meter Trip			

130

Preliminary Check on 9-13-62

Room 113 Pressure Differential OK
 Red Light On and Personnel Check C.C.
 Scrams and Bldg. Alarm Reset C.C.
 Source Inserted Response OK
 Safety Withdrawn 28.0"
 Controls Set INNER 10.54 Outer 998.62
 Reflector Water Approx 5 1/2" Above Be
 Moderator Water 27.4"

Exp. 622 Power Dist with new plated silver control plates and no boron in moderator. Plates P-1 and F-2 only in a-37 and b-78 resp. Each plate has six extra foils for add. power dist data

± INNER Outer Safety
 15.00 15.06 28" 17.3" Pas Per

923 start timing 20 MIN foil Exposure at 3×10^{-9} on IC-2

14.94 14.94 IC-2 8.1×10^{-9} level

943 Scram System to Shut Down

$17.3 / 12.5 = 1.384$ 142 1/2 in

9-14-62 Checked control plates for sticking or rubbing and no apparent difficulties noted.

Instrument Check on 9-17-62 Source 10 mci r

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	OK
IC-1	Meter Trip	OK	Fast Trip	OK
IC-2	Meter Trip	OK		
IC-3	Calibration	swgn		
IC-4	Calibration	swgn		
CRM	Meter Trip			
	Room 113 Pressure Differential		swgn	
	Red Light On and Personnel Check		C.C.	
	Scrams and Bldg. Alarm Reset		C.C.	
	Source Inserted		swgn	Response OK
	Safety Withdrawn		28.0"	
	Controls Set		INNER 14.95	Outer 998.63
	Reflector Water		Approx 5 1/2"	Above Be
	Moderator Water		27.5"	

Exp #No 623, No Boron in Moderator.

Purpose: Pulse at critical.

INNER Outer Safety

14.94	15.10	28.0"	15.64 Pos Per
14.94	14.96	28.0"	1/4 = 11 1/2 level
14.98	14.98	21.10"	level

Pulsed at crit level after run

EXP 624 14.97 14.97 21.31 Level

EXP 625-627 see p 126-127 PV

Instrument Check on 9-18-62 Source 10 mc

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	7.0×10^{-11}	Meter Trip	OK	Fast Trip	OK
IC-2	7.0×10^{-12}		OK		
IC-3	3×10^{-4}	Calibration	OK		
IC-4	6×10^{-11}	Calibration	OK		
CRM	Meter Trip				

Preliminary Check on 9-18-62

Room 113 Pressure Differential OK
 Red Light On and Personnel Check C.C.
 Scrums and Bldg, Alarm Reset C.C.
 Source Inserted down
 Safety Withdrawn Inner 14.97 28.0 cc
 Controls Set Tuner 14.98 Outer 998.62
 Reflector Water C.C. ~ 5" above Be on 27
 Moderator Water C.C. ~ 27 1/2

EXP 628 Check Crit Position before pulsing.

In	Out	Safety		
14.97	15.05	28.0	$\frac{24}{08} = 100\%$	13.24 + Per A
14.97	14.97	28.0		5.24 + Per B
"	"	21.64		level

132

DATE	EYP	Inner	Outer	Safety	
9-18	628	14.97	14.97	21.64	Crit (Not Pulsed)
	629	12.97	"	"	
	630	12.47	"	"	
	631	11.97	"	"	
	632	14.97	13.47	"	
	633	14.47	14.47	"	
	634	13.97	13.97	"	
	635	13.47	13.47	"	
9-19-62	636	16.16	16.16	21.10	Pulsing at Crit. 0.249/R Acc arced at 6400 cycles
	638	16.16	15.66	21.10	
	639	"	15.16	"	
	640	"	14.66	"	
	641	"	14.16		
	2	"	13.66		
	3	"	13.16		
	644	15.66	16.16		
	5	15.16			
	6	14.66			
	7	14.16			
	8	13.16			
9-20-62	649	16.15 _s	16.15 _s	21.10	Crit
	50	15.65 _s	15.65 _s	"	
	1	15.15 _s	15.15 _s	"	
	2	14.65 _s	14.65 _s	"	
	3	14.15 _s	14.15 _s	"	
	4	13.65 _s	16.16	"	

PN No	Channel width MS	BKG	DELAY	BURST WIDTH MS	REP RATE CPS	TOTAL CYCLES			
497	80	8	8	400	39	25985	2.48	570 ± 1.5	570 ± 6
498	40	8	8	200	70	51180	3.12	675 ± 2	675 ± 8
499	40	16	8	200	70	51896	4.76	780 ± 2	780 ± 9
500	80	8	8	400	39	28576	1.77	453 ± 1	453 ± 8
501	80	8	8	400	39	25278	1.20	type 360 ± 1	360 ± 4
2	80	8	8	400	39	22522	2.31	542 ± 1.5	542 ± 6
3	40	16	8	200	70	50002	3.119	type 735 ± 7	735 ± 9
504	160	4	4	800	20	6402	148.9 ± 6	0	
<p>and HV now gone! (Please cap off V_i in HV.P.S.)</p>									
505	160	4	4	800	20	11576	247 ± 1	0.65	
506	80	8	4	400	39	23088	343 ± 8	1.30	
507	80	8	4	400	39	23054	443 ± 1	1.97	
508	40	8	4	200	71	46492	544 ± 2	2.64	
509	40	8	4	200	71	59031	640 ± 2	3.29	
510	40	8	4	200	71	52411	730 ± 2	3.88	
511	160	4	4	800	20	13258	247 ± 7	.64	
512	80	8	4	400	39	23959	355 ± 8	1.38	521
513	80	8	4	400	39	20301	450 ± 1	2.01	264
514	40	8	4	200	71	56076	560 ± 2	2.75	257
515	40	8	4	200	71	49325	760 ± 2	4.09	
516	160	4	4	800	20	12802	149.5 ± 4	0	
517	80	8	4	400	39	21877	352 ± 1	1.36	
518	40	8	4	200	71	50154	540 ± 2	2.62	
519	40	8	4	200	71	55412	733 ± 2	3.91	
520	40	8	4	200	71	46814	905 ± 5	5.06	
521	40	8	4	200	71	50872	668 ± 2	3.47	

"Note"

Drained H_2O from fuel H_2O System, AND Added Boron Soln 0.24 g/l

2¹⁷ PM

Exp # 636

9-18-62

Purpose: Check Crit Position of controls with 0.24 g/l Boron in fuel H_2O system

Inner	Outer	Safety	
16.20	16.20	28.0	13.04 Pos Per (A)
16.20	16.08	28.0	$\frac{1}{2}$ = 108% level
16.05	16.20	28.0	$\frac{1}{5}$ = 87% "

2³⁹

Dump fuel H_2O AND Repete

16.20	16.20	28.0	13.74 Pos Per (B)
16.20	16.09	28.0	$\frac{1}{11}$ = 125% level

Shut DOWN

"Note"

9-18-62 Samples # 15A-15B taken from ~~Deminer~~ ^{2/17/62} H_2O Demineralized H_2O Drained from fuel H_2O System. 0.022 g/liter 9-26-62

9-18-62 Samples # 16A-16B taken from fuel H_2O System Approx 0.24 g/l Boron 0.244 g/liter 9-26-62

Instrument Check on 7-19-62 Source 10 mc δ

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	7.6×10^{-11}	Meter Trip	OK	Fast Trip	OK
IC-2	7.10×10^{-12}	Meter Trip	Scrammed Safety		
IC-3	4.5×10^{-4}	Calibration			
IC-4	6×10^{-11}	Calibration			
CRM		Meter Trip			

Preliminary Check on 7-19-62

135

Room 113 Pressure Differential C.C.
 Red Light On and Personnel Check C.C.
 Scrams and Bldg, Alarm Reset C.C.
 Source Inserted C.C.
 Safety Withdrawn 28.0"
 Controls Set Inner 16.12 Outer 998.63
 Reflector Water Approx 5 1/2" Above Be
 Moderator Water Approx 27.25"

Exp # 637 9-19-62

Purpose: Check Critical (Pulse At Crit)

	Inner	Outer	Safety	
	16.20	16.20	28.0"	45.67 Pas Per
	16.13	16.13	28.0"	107 = 2234/in level
	16.157	16.157	21.10"	level

Exp 638 - 648 pulsing at various control settings see p 132-133.

Instrument Check on 7-20-62 Source 10m.

PM-1	0 = 350	Low Trip	OK	Alarm Trip	OK
PM-2				Alarm Trip	OK
IC-1	> 10 x 10 ⁻¹¹	Meter Trip	OK	Fast Trip	Scrambled Safety
IC-2	> 10 x 10 ⁻¹²	Meter Trip	OK		
IC-3	5 x 10 ⁻¹¹	Calibration	Down		
IC-4	6 x 10 ⁻¹¹	Calibration	Down		
CRM		Meter Trip			

Preliminary Check on 7-20-62

Room 113 Pressure Differential D.W.M.
 Red Light On and Personnel Check C.C. - D.W.M.
 Scrams and Bldg, Alarm Reset D.W.M.
 Source Inserted Inserted D.W.M. Inst Response.
 Safety Withdrawn to 21.10 D.W.M.
 Controls Set Inner 16.20 Outer 998.62
 Reflector Water Approx 5 1/2" Above Be
 Moderator Water 27.5"

EXP # 649 : Repeat crit position, and critical decay constant.

INNER	Outer	Safety	
16.20	16.20	21.10	+8.74 Pos Per
16.15 ₅	16.15 ₅	21.10	

11¹² AM level After Pulsing

See pages 132-133 for EXP 650-654

Instrument Check on 10-21-62 Source _____

PM-1	zero 240	Low Trip	OK	Alarm Trip	OK
PM-2				Alarm Trip	OK
IC-1	5×10^{-4}	Meter Trip	Screen Safety	Test Trip	OK
IC-2	7×10^{-12}	Meter Trip	OK		
IC-3	5×10^{-11}	Calibration	Down		
IC-4	6×10^{-11}	Calibration	Down		
IRM		Meter Trip			

Preliminary Check on 9-21-62

Room 113 Pressure Differential	C.C.
Red Light On and Personnel Check	C.C.
Serams and Bldg, Alarm Reset	C.C.
Source Inserted	C.C.
Safety Withdrawn	28.0"
Controls Set	INNER 16.20 Outer 998.62
Reflector Water	APPROX 5 1/2" Above Be
Moderator Water	27.0+

EXP # 655 : Purpose - Power Dist. p.1 in a 37
p.2 in b 78

16.20	16.20	28.00	+ Period
8 ⁴⁶ AM	"	"	TC-2 = 3.0×10^{-9} start exp time
	Level at		TC-2 = 8.1×10^{-9}
16.13	16.13	28.0	+14.74 level
8 ⁴⁸ AM	Screens and insert insert to 12 outer 99.07 = 2104/in		

9-21-62 137

"Note"

Drained Boron Soln 0.24 g/l from fuel H₂O system, AND Added Boron Soln 0.566 g/l

Exp # 655⁶ 9-21-62

Purpose: Check Critical Position of Controls with 0.566 g/l Boron Soln in fuel H₂O system

INNER	outer	Safety		
17.90	17.90	28.0"	16.14	Pos Per (A)
17.90	17.755	28.0"	111 1/2	level
17.74	17.90	28.0"	101 1/2	level
17.84	17.84	28.0"	268 1/2	level
Dump H ₂ O And Repeat ^{at}				
17.90	17.90	28.0"	13.24	Pos Per (B)
17.90	17.77	28.0	101 1/2	level

310

Shut Down

Instrument Check on 9-24-62 Source

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	OK
IC-1	10x10" Meter Trip	OK	Fast Trip	OK
IC-2	10x10" Meter Trip	OK		
IC-3	5x10" Calibration	Done		
IC-4	10x10" Calibration	Done		
CRM	Meter Trip			

Preliminary Check on 9-24-62

Room 113 Pressure Differential	C.C.
Red Light On and Personnel Check	C.C.
Scrams and Bldg, Alarm Reset	C.C.
Source Inserted	C.C.
Safety Withdrawn	28.0"
Controls Set	INNER 17.90 Outer 998.62
Reflector Water	APPROX 5" Above Bc
Moderator Water	27.0"

9-24-62

Exp # 65⁷/₆ Purpose: Power Dist.

P-2 in - a-37, F4 - b-78

Inner Outer Safety
17.92 17.92 28.0" 14.7 μ Pas Per

Start timing 26' foil Exposure 3×10^{-9} on IC-2
level 8.1×10^{-9}

17.84 17.84 28.0" 184 μ /in level

9³⁶/₆

Scram System to Shut Down

Checked Control Positions

Inner @ 10.00 min. 31 $\frac{1}{16}$ " above Be.

Outer @ 10.00 " 15 $\frac{3}{8}$ " " "

Note 9-24-62 Samples #17A-17B taken from
fuel star H₂O system approx 0.57 g/l Boron

9-26-62 0.553 g/liter

Instrument Check on 9-27-62 Source 10mc γ

PM-1	Zero 340	Low Trip	OK	Alarm Trip	OK
PM-2				Alarm Trip	OK
IC-1	$> 10 \times 10^{-11}$	Meter Trip	OK	West Trip	OK
IC-2	$> 10 \times 10^{-12}$	Meter Trip	OK		
IC-3	4×10^{-11}	Calibration	Down		
IC-4	5×10^{-11}	Calibration	Down		
CRM		Meter Trip			

Preliminary Check on 9-27-62

Room 113 Pressure Differential Down

Red Light On and Personnel Check CC Down

Scrams and Bldg. Alarm Reset Down

Source Inserted Down

Safety Withdrawn Down 28.0

Controls Set Inner 12.53 Outer 998.63

Reflector Water ~27 in

Moderator Water ~27 in

EXP. 658: Power Dist. with controls asymmetric
 (Inner - Outer) = 3.0 in. and with 0.55 g Boron
 per liter of Moderator. P-1 in a-37, F-2 in b-78

Inner Outer Safety

16.56 19.56 28.0" Pos Per

9⁵³ start timing 20' Exposure 3×10^{-9} on IC-2
 level 8.1×10^{-9} on IC-2

16.46 19.46 28.0" level

9^{23:22} Scram and insert Inner & Outer.

2⁴⁰

Exp # 659

9-27-62

Purpose: Check Critical (Pulsing Sub Crit)

Inner Outer Safety

17.91 17.91 28.0" Pos Per

17.84 17.84 28.0" level

Instrument Check on 9-28-62 Source 10 mc ✓

PM-1	Zero: 2.75	Low Trip	OK	Alarm Trip	OK
PM-2				Alarm Trip	OK
IC-1	$> 10 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 10 \times 10^{-12}$	Meter Trip	OK		
IC-3	3×10^{-4}	Calibration	OK		
IC-4	5×10^{-4}	Calibration	OK		
CRM		Meter Trip			

Preliminary Check on 9-28-62

Room 113 Pressure Differential	C.C.
Red Light On and Personnel Check	C.C.
Scrams and Bldg. Alarm Reset	C.C.
Source Inserted	C.C.
Safety Withdrawn	28.0"
Controls Set	Inner 17.86 Outer 998.62
Reflector Water	Approx 5 1/2" Above Bc
Moderator Water	27.23

140

DATE	EXP	INNER	OUTER	SAFETY	
9-27-62	659	17.84	17.84	28.00	Not Pulsed Crit
	660	"	17.34	"	
	661	"	16.84	"	
	662	"	16.34	"	
	663	"	15.84	"	
9-28-62	664	17.84	17.84	"	Not Pulsed Crit
		17.87	17.87	21.11	Crit Pulsed
	665	17.34	17.84	28.00	
	6	16.84	"	"	
	7	16.34	"	"	
	8	15.84	"	"	
	9	15.34	"	"	
	670	14.84	"	"	
	1	17.34	17.34	"	
	2	16.84	16.84	"	
	3	16.34	16.34	"	
	4	17.84	15.34	"	
	5	"	14.84	"	

PN	CH μs	BKG μs	DEL μs	BURST μs	REP RATE CPS	TOTAL CYCLES		
521								
522	160	4	4	800	20	11639	199.8 ± 1.6	0.54
523	80	4	4	400	39	24967	276.5 ± 1.7	1.13
524	80	4	4	400	39	26670	356 ± 1.7	1.74
525	40	4	4	200	71	54785	438 ± 1	2.37
526	320	4	4	1600	10	6800	129.9 ± 1.4	1.000 g = 0.
7	160	4	4	800	20	13438	199.7 ± 1.6	0.54
8	160	4	4	800	20	12093	278 ± 1.7	1.14
9	80	4	4	400	39	25704	358 ± 1.8	1.76
530	80	4	4	400	39	30374	442 ± 1	2.40
1	40	4	4	200	71	40309	528 ± 1.5	3.06
2	40	4	4	200	71	40823	615 ± 2	3.73
3	160	4	4	800	20	10088	281 ± 1.7	1.16
4	80	4	4	400	39	29161	429 ± 1.0	2.30
5	40	4	4	200	71	60577	585 ± 1.5	3.50
6	40	4	4	200	71	62256	530 ± 1.5	3.08
7	40	4	4	200	71		615 ± 2	3.73

142

9-28-62

Exp # 664

(Pulsing at crit)

INNER	Outer	Safety	Pos Per
17.92	17.92	28.0"	level
17.84	17.84	28.0"	level
17.87	17.87	21.11	level

Insert Safety.

17.87	17.87	21.11	level after pulsing PN 526
-------	-------	-------	----------------------------

Time = 22 86

Oct 24, 1962

Calculations of Sb-Be neutron source

Muir and Fowler saturated to ϕ of 10^{12} 1230 curies gave 1.3×10^{10} n/secor 10^7 n/sec per curie

this source is not described.

Neutron energy is 31 kev (th)

$$\sigma(\sigma, n) = 20 \times 10^{-28} \text{ cm}^2$$

If the above efficiency can be obtained by putting

Sb in a hole in the beryllium then a

1 curie Sb pellet should be adequate. The

 1.5×10^7 Pu Be gave a count rate of $\frac{2757}{300} = 9.19$ %/sec

a 2 curie Sb pellet should be adequate.

Safe distance for 10 mc Ra = 40 in.

$$\text{" " " 2 C Ra} = \frac{x^2}{40^2} = \frac{2000}{10}$$

$$x = 40 \sqrt{200} = 566 \text{ in}$$

$$\text{Safe time at 40 in} = \frac{1}{200} \times 8 \text{ hrs} = \frac{8}{200}$$

$$= .04 \text{ hrs or } .24 \text{ min or } 15 \text{ sec}$$

A 2 curie Sb source could be handled safely if on the proper stick in the proper shield before transfer to the HEIRCE#2 Be.

Isotope book says 3.5 curies in an Sb-Be source gives 4×10^6 n/sec

Apex 176 $\mu^{(Be)} = 0.079 \text{ cm}^{-1}$, $1/64 = .44 \text{ cm}$ $\mu x = .035$

Therefore 100% Be may increase yield by factor of 30!

February 25, 1964

Preparations to remove HFIRCE #2 core
and installation of HFIRCE #3 core.

Be Smear Result on Beryllium

2/17/64 Top - 17 and 19 μgr

Side - 12 and 3 μgr

Cross scrubbed surfaces with Fab detergent

2/24/64 Top - 10.6 and 17.4 μgr

Side 21.3 and 15. μgr

(Time 2525)

2286

JT Thomas 239 → 30 days @ 8 hr each