

BOOK74R

Notes:

"Bk#5 2% & 3%" on front

"U(2) F₄ H/X = 614

U(3) F₄ H/x = 279" on spine

Please note that in order to "pick-up" the light red pencil markings, this logbook had to be copied on the darkest toner available. Therefore, there is a lot of dark background on the majority of pages.

Blank pages: page opposite page 1, 3, 24, 62, 72, 73, 89, 90, 92, 96, 106, 112, 114, 120, 174-186, 232-249, 262-265, 298, 300, inside back cover sheets

- pages 86, 87, 122, 124, 250, and 251 each have 1 sheet taped to it
- page 159 has 1 (8.5x11) graph sheet taped
- pages 161/162 has a paper clip at top
- pages 209 and 215 has 1 half sheet taped to each
- page 222 has 1 sheet taped to it
- page 265 has 3 sheets taped to it

Scanned by:

Sheila Finch

RSICC /Oak Ridge National Lab.

August 26, 1999

E-13



Standard Blank Book

No. 38

Journals Double \$ and Cts. no Units

S. E. Ledgers " " "

D. E. Ledgers Full Page Form "

Records with Margin Line

In 150 and 300 Pages

Made in U.S.A.

TO REORDER THIS BOOK, SPECIFY
NUMBER, RULING AND THICKNESS
AS INDICATED ON BACKBONE OF BOOK

A BOORUM & PEASE PRODUCT

U(2) F₄ and C₂H₅ blocks.

Analyses of materials received:

Reg #	Blend #	gU/g	% CH ₂	Net U/g	Assay	U ²³⁵ kg
378142	1	.60043	20.78	64.856	2.01	1.304
3	2	.600241	20.81	65.306	2.01	1.313
4	3	.593023	21.76	62.754	2.01	1.255
6	4	.595819	21.39	68.936	2.02	1.393
7	5	.603266	20.41	65.816	1.99	1.310
8	6	.595290	21.46	64.768	2.00	1.295
9	7	.599880	20.86	65.267	2.00	1.305
378150	8	.594346	21.59	76.195	1.99	1.516
1	9	.594739	21.54	66.046	2.00	1.321
Averages		0.59769 ± 0.0185 ± .3%	21.178	MT 599.646	2.0033	12.012

sp gr. from 144 samples $2.88299 \pm .00009$ (95% confidence)

$$g/cc = 1.72313$$

$$\frac{N^{238}}{N^{235}} = \frac{235}{238} \left(\frac{100}{2.0033} - 1 \right) = 4830028$$

$$\frac{N^U}{N^{235}} = \frac{N^{238}}{N^{235}} + 1 = 4930028$$

$$\frac{N^{235}}{N^U} = 0.020284$$

$$g/cc = (21178 \times 2.88299 \frac{500}{352}) = .52035$$

$$\frac{N^{238}}{N^U} = 0.979716$$

$$\frac{N^C}{N^{238}} = \frac{.52035 \times 237.94}{12 \times 1.72313} = 5.98775$$

$$\frac{N^H}{N^U} = \frac{N^C}{N^U} \cdot \frac{N^H}{N^C} = 5.98775 \times \frac{52}{25} = 12.45452$$

$$\frac{N^H}{N^{235}} = \frac{N^U}{N^{235}} \cdot \frac{N^H}{N^U} = 614.0132$$

$$\frac{N^F}{N^U} = 4.0000$$

UG) F₄ and C₂₅H₅₂ blocks

Analysis of materials received.

Req. No.	Batch No.	$\frac{9^U}{9}$	% Paraffin	$\frac{9^U}{9}^{235}$	Net Wt. (g)
378215	1	0.64155	15.36	2.98	74,575
378216	2	.64254	15.23	2.98	85,275
378218	3	.64166	15.35	2.99	70,925
378220	5	.63992	15.58	3.01	81,900
378222	6	.63995	15.572	3.01	60,750
378223	7	.64069	15.474	2.98	60,075
378224	8	.64121	15.405	2.97	61,025
378225	9	.64183	15.324	2.97	61,000
378226	10	.64045	15.493	2.99	59,175
378227	11	.64323	15.138	2.93	60,410
378230	14	.64319	15.144	3.01	59,875
378231	15	.64068	15.474	2.99	56,450
378233	17	.64119	15.41	2.98	60,075
378234	18	.64154	15.36	2.99	60,625
378234	19	.64195	15.31	3.00	62,200
avg		$.64144 \pm .00097$	avg = 15.375	$2.98533 \pm .02997$	
		$\pm .15\%$			

$$p = 3.44 \frac{9^U}{9} / \text{cc}; \quad p(U) = 2.20998 \frac{9^U}{9} / \text{cc}; \quad \% U F_4 = 84.625$$

$$\frac{N^{28}}{N^{25}} = \frac{235}{238} \left(\frac{100}{2.985} - 1 \right) = 32.09115$$

$$\frac{N^U}{N^{25}} = 33.09115$$

$$\frac{N^{25}}{N^U} = 0.03022$$

$$\frac{N^{28}}{N^U} = 0.96978$$

$$\frac{9^C}{9^U} = .15375 (3.4454) (0.95227) = 0.45147$$

$$\frac{N^C}{N^U} = \frac{0.45147}{12} \left(\frac{237.91}{2.20998} \right) = 4.05016$$

$$\frac{N^H}{N^U} = \frac{N^C}{N^U} \cdot \frac{N^H}{N^C} = 4.05016 \left(\frac{52}{25} \right) = 8.42433$$

$$\frac{N^H}{N^{25}} = \frac{N^H}{N^U} \cdot \frac{N^U}{N^{25}} = 8.42433 (33.09115) = 278.7708$$

$$\frac{N^F}{N^U} = 4.00$$

4

k_{eff} = 0.147 rev/sec

Expt. 1. Purpose Determine k_{eff} for near cube geometry.
Check reactivity on $26 \times 26 \times 16$ " stack.

Expt. 2. Stack now $26 \times 26 \times 24$ "

Expt. 3. Put sheet of Plexiglas $15\frac{1}{2} \times 13\frac{1}{4} \times 1$ on south face of stack as in Expt. 2. Use to raise neutron level and measure negative period. TMC 5 sec time interval

Expt. 4. Moved $\frac{1}{4}$ " BF_3 to top of table support structure and placed 2" BF_3 in pit.
Stack same as Expt. 3.

Expt. 5. added $\frac{1}{4}$ " $\times 12$ " $\times 12$ " to top of stack

U(2) F₇

1/x = 0.14

U(2)

Expt. 1.

Instrument Check on 10-13-65 Source 10-mel

PM-1	Low Trip	OK	High Trip	OK	
PM-2	Low Trip	OK	High Trip	OK	
PM-3	> 3x10 ⁻¹¹	Water Trip	OK	East Trip	OK
PM-4	> 3x10 ⁻¹¹	Water Trip	OK		Red light ✓
PM-5	Responds	JII			Bldg Alarm ✓
PM-6	Responds	JII			Press. Diff. 0.1K"

Only slight change in neutron level above background
k << 1.

Expt. 2.

k < 1 multiplication from Lu N ~ 20.

Expt. 3.

k > 1 serum on low level PM.

Reut; tubes together k > 1; removed Plexiglas - Measure
negative period with TMC.

Expt. 4

2:05 PM

tubes together k > 1; Measured pos. period

Removed Plexiglas and meas. neg period

TMC

~~0.2~~

~~0.2~~

Expt. 5

added 1/4" x 12" x 12" to top of stack.

tubes together no reflector k > 1

Expt. 6 Removed top $\frac{1}{4}$ " addition have now $26 \times 26 \times 24$ " stack.
 Examine count rate from ~~four~~ ^{three} counters to be used
 in period measurements. Have 3 detectors feeding TMC.
 2 - 2" BF₃ and 1 - $\frac{1}{4}$ " BF₃

Expt. 7.

$26 \times 26 \times 24$ " stack.

Reg. per. on TMC - V2-1 (5 sec. ltr.)

Expt. 8.

$26 \times 26 \times 24 \frac{1}{4}$ " less $\frac{1}{4} \times 2 \times 6$ " on one top corner S.E.
 and $\frac{1}{4} \times 2 \times 4$ " on other top corner S.W.

of stationary table

Reg. per. on TMC - V2-2 (5 sec. ltr.)

$T_{DN} = 84.687 \text{ sec} \rightarrow 11.230 \phi$ $T_{MC} = 85.626 \text{ sec} \rightarrow 11.137 \phi$

Expt. 6
Instrument Check on 10-14-65 Source 10mc 8

FM-1		Low Trip	OK	Alarm Trip	OK
FM-2				Alarm Trip	OL
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	FAST TRIP	OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	Red light	OK
IC-3	Response	Calibration	JH	alarm	OK
IC-4	Response	Calibration	JH	Resdiff	0.19"
CRM		Meter Trip			

Expt 7

Table together $k > 1$ with Plexiglas
Removed plexiglas, $k < 1$, key pin on TMC.

Expt 8 Table together $k > 1$ no plexiglas.

Evaluate $1/4"$ sh.
 Expt. 9 $26 \times 26 \times 24$ stack with $1/4"$ layer added. There is an overhang on east side at S.E. corner $2 \times 8 \times 1/4$ and on South side in SW corner of $2 \times 4 \times 1/4$.


$b > 1$ U2-3 (5 sec ch) $L_{IN} = 80.605 \text{ sec} \rightarrow 11.657 \phi$; TMC = 78.889 sec

Expt. 10 Stack same as Expt. 9

U2-4 (1 sec ch)

$L_{IN} = 77.912 \text{ sec} \rightarrow 11.956 \phi$; TMC = 80.293 sec $\rightarrow 11.690 \phi$

Expt. 11 Top $1/4"$ layer as in diagram shaded area absent.



U2-5 (5 sec)


$L_{IN} = 80.084 \text{ sec} \rightarrow 11.713 \phi$ TMC = 78.911 $\rightarrow 11.843 \phi$

Expt. 12 Same as 11, U2-6 (1 sec ch)

TMC = 79.207 $\rightarrow 11.810 \phi$

Expt. 13 $25 \times 25 \times 25"$ stack with plexiglass refl piece as above


Expt. 14 $25 \times 25 \times 25 \frac{1}{2}"$ keep edges as shown on top



$b > 1$ U2-7 (5 sec ch) $L_{IN} = 277.231 \rightarrow 4.185 \phi$
 TMC = 273.240 $\rightarrow 4.239 \phi$

$b < 1$ U2-8 (5 sec ch) $L_{IN} = -111.592 \rightarrow -20.743 \phi$
 TMC = -111.086 $\rightarrow -20.960 \phi$

Expt. 15 $25 \times 25 \times 25 \frac{1}{2}"$ with "overhang" on two sides of top $1/2"$ layer



$b < 1$ U2-9 (1 sec ch)

$L_{IN} = -115.088 \rightarrow -19.386 \phi$ TMC = -110.583 $\rightarrow 24.180 \phi$

Expt. 9.

Expt. 10.

Expt. 11.

Expt. 12.

Expt. 13.

Expt. 14.

Expt. 15.

Expn. 9
Instrument Check on 10-15-65 Source comet

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip	OK	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Response	Calibration			Red light OK
IC-4	Response	Calibration			alarm OK
CRM		Meter Trip			Press diff 0.14"

Expn 9. Tables Together $k > 1$
 $k = 1$ Table sep. = .072" (1.9mm) 1
 Check counting rate at 0.9 on IC-3

Expn 10. Tables Together $k > 1$

Expn 11. Tables Together $k > 1$

Expn 12. " " $k > 1$

Expn 13. Tables Together $k < 1$

Expn 14. Tables Together $k > 1$ with plexiglass

Removed plexiglass $k < 1$

Expn 15. Tables Together $k > 1$ with plexiglass

Removed plexiglass $k < 1$


Expt 16

25 x 25 x 26" stack

b > 1 V2-10 (5 sec ch)

$L_N = 94.676 \rightarrow 10.313\phi$ TMC = 93.931 $\rightarrow 10.375\phi$

higher than rest of stack



Expt 17

25 x 25 x 25 3/4" stack, shaded area

26" high (Measured with meter stick (65.737 x 63.961) x 63.975 cm)

b < 1 V2-11 (10 sec ch)

$L_N = -560.238 \rightarrow -2.492\phi$ TMC = -581.412 $\rightarrow -2.395\phi$

Expt 1

Expt 18

24 x 26 x 26"

b < 1 V2-12 (10 sec ch)

$L_N = -534.181 \rightarrow -2.623\phi$ TMC = -554.930 $\rightarrow -2.518\phi$

Expt

Expt

Expt 19

24 x 26 x 26 1/4" (Meter stick 66.567 x 61.390 x 66.995 cm)

b > 1 V2-13 (5 sec ch)

$L_N = 98.150 \rightarrow 10.28\phi$ TMC = 98.889 $\rightarrow 9.970\phi$

Expt

Instrument Check on 10-18-65 Source 10 mCr

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	73x10"	Meter Trip	OK	West Trip
IC-2	73x10"	Meter Trip	OK	Red light
IC-3	Response	Calibration	S/R	Alarm
IC-4	Response	Calibration	S/R	Pres. dif. 0.14"
CRM	Meter Trip			

Expt 16
 b = 1 table separ. ~ 3.5 rev. IC-3 = .05 Bq. count check
 b = 1 " " " IC-3 = 1.0 Counter check.
 b > 1 tables together no plexiglass

Expt 17
 b > 1 tables together with plexiglass refl.
 b < 1 " " no plexiglass

Expt 18
 Restacked. 24x26" base 8x26" on movable table
 26" high

b > 1 table together with plexiglass refl.
 b < 1 " " no plexiglass

Expt 19
 b > 1 table together no plexiglass

19.5 cm)

Exp 20 took stack down and restacked

24x26x26 1/4" (Metric stick 61.217 x 66.503 x 67.008 cm)

$k > 1$ U2-14

$L_N = 60.801 \rightarrow 14.314 \phi$ TMC = 61.864 \rightarrow 14.139 ϕ

Repeat above.

$k > 1$ U2-15

$L_N = 61.458 \rightarrow 14.206 \phi$ TMC = 62.074 \rightarrow 14.105 ϕ

Repeat above

$k > 1$ U2-16 (1 sec ch.)

$L_N = 59.932 \rightarrow 14.461 \phi$ TMC = 61.361 \rightarrow 14.221 ϕ

Exp

Exp 21 24x26x26"

$k < 1$ U2-17

$L_N = -1042.304 \rightarrow -1.296 \phi$ TMC = -1047.965 \rightarrow -1.289 ϕ

Exp

Counting ch #1, 1/4" BF₃

L_N cable rack, south of stack

Ch #2, 2" BF₃ - 94 1941, Presamp No. , Amp. No. Y140347

On ledge SW corner of room

Ch #3, 1/4" BF₃ thin tube

\sim 6 1/2' above floor, west of stack, \sim 5' west of edge of table

Ch #4, 2" BF₃ - 94 1938,

On platform near N.E. corner.

Instrument Check on 10-19-65 Source 10mcr

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	7.3×10^{-4}	Meter Trip	OK	Rest Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Red light	OK
IC-3	Response	Calibration	S/P.	Alarm	OK
IC-4	Response	Calibration	S/P.	Press. dif.	0.14"
RM		Meter Trip			

Expt 20 Reattached 24×26 " base $\frac{1}{2}$ on each table
 $b = 1$ Table separ. ~ 2.25 rev. Check counter
 add 4th counter $\frac{1}{4}$ " BF₃ and adjust
 count rate \sim others.
 $b > 1$ Table together no plexiglass

Expt 21 Removed $\frac{1}{4}$ " from top
 $24 \times 26 \times 26$ "
 $b > 1$ Table together with plexiglass
 $b < 1$ table together no plexiglass

Photomultiplier screamed table on first try
 Probably loosened up stack so this data is
 questionable.

14

Expt 22 24 x 26 x 26"

Repeat Expt 21

471 U2-18

$\ln N = 1157.392 \rightarrow 1.0934$

Expt 21

Instrument Check on 10-20-65 Source 10m.c.K

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2				
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Alarm Trip OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	Red light OK
IC-3	Response	Calibration	S.P.R.	Alarm OK
IC-4	Response	Calibration	S.P.R.	Pres. dif. 0.14"
CRM		Meter Trip		

Expt 22 tightened up stack and reran Expt 21.
 $k=1$ with plexiglass table sep. ~ 2.85 rev. Check counter
 $k>1$ table together no plexiglass

TMC dropped several points on the print out
 shut down to have it checked.

Eppr 23

24x26x26¹/₄" stack

Same as Eppr 20 except stack was tightened
as much as possible

 $p > 1 \quad V2 - 19 \quad (1 \text{ sec})$
 $L_n N = 59.498 \rightarrow 14.534 \quad TMC = 60.044 \rightarrow 14.442$

Eppr 24

24x26x26"

 $p > 1 \quad V2 - 20 \quad (1 \text{ sec}) \text{ with flexiglass}$
 $L_n N = 24.755 \rightarrow 25.353 \text{¢} \quad TMC = 24.897 \rightarrow 25.272 \text{¢}$

Eppr 25

24x26x26" with flexiglass

 $p > 1 \quad V2 - 21 \quad (1 \text{ sec})$
 $L_n N = 27.143 \rightarrow 24.050 \text{¢} \quad TMC = 27.225 \rightarrow 24.008 \text{¢}$

Eppr 26

24x26x26" no flexiglass

 $p > 1 \quad V2 - 22 \quad (5 \text{ sec})$
 $L_n N = 1817.788 \rightarrow 0.703 \text{¢} \quad TMC = 1867.864 \rightarrow 0.684 \text{¢}$

Eppr

Eppr

Eppr

Eppr

Eppr

Instrument Check on 10-22-65 Source 10 mcr

PM-1	Low Trip	OK	Hi Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	3×10^{-11}	Water Trip	OK	Fast Trip	OK
IC-2	3×10^{-11}	Water Trip	✓		Red light on ok
IC-3	Response OK	Calibration			Alarm ABC OK
IC-4	Response OK	Calibration			Pres Dif 0.14
CRM		Meter Trip			

- Expt. 23 24x26x26 1/4" Stack
 $b = 1$ Table separation ~ 2.24
 $b > 1$ Table together *no plexiglass*
 Chromel P - alumel thermocouple R-2 P-2
 Temp 1.028 mV = 78.53°F
- Expt. 24 24x26x26" Stack A
 $b > 1$ Table together with plexiglass
- Expt. Took data on TMC to plot for to determine dead time con. Had to screen to prevent setting off alarms. This loosened up the stack so that it had to be packed together again.
- Expt. 25 $b > 1$ Table together with plexiglass
- Expt. 26 $b > 1$ Table together *no plexiglass*
 $k = 1$ (0.97 news) Temp 1.0223 mV = 78.30°F

Expt 27 24x26x26" steel with all bases on $\frac{3}{4}$ " steel plate on Top
 $b > 1$ U2-23 (1 sec) no flexglass
 $L_N = 64.710 \rightarrow 13.693 \phi$ TMC = 64.987 \rightarrow 13.651 ϕ

Expt 28 24x26x26" no flexglass still have resistnut used to support all bases
 $b > 1$ U2-24 (5 sec)
 $L_N = 212.152 \rightarrow 5.301 \phi$ TMC = 214.558 \rightarrow 5.249 ϕ

Expt 29 24x26x26" no flexglass removed resistnut
 $b > 1$ U2-25 (5 sec)
 $L_N = 217.147 \rightarrow 5.194 \phi$ TMC = 220.551 \rightarrow 5.124 ϕ

Expt 30 24x26x26 $\frac{1}{4}$ " no flexglass
 $b > 1$ U2-26 (1 sec)
 $L_N = 44.949 \rightarrow 17.595$ TMC = 46.034 \rightarrow 17.320 ϕ

Expt 31 24x26x26" no flexglass
 $b > 1$ U2-27 (5 sec)
 $L_N = 217.147 \rightarrow 5.194$ TMC = 219.819 \rightarrow 5.139 ϕ

Expt 32 24x26x26 $\frac{1}{4}$ " no flexglass
 $b > 1$ U2-28 (1 sec)
 $L_N = 44.732 \rightarrow 17.652$ TMC = 45.756 \rightarrow 17.390

Expt 33 24x26x26" no flexglass $b > 1$ U2-29 (5 sec)
 $L_N = 215.627 \rightarrow 5.226$ TMC = 220.460 \rightarrow 5.126

Expt 34 24x26x26 $\frac{1}{4}$ " no flexglass $b > 1$ U2-30 (1 sec)
 $L_N = 44.732 \rightarrow 17.652$ TMC = 45.126 \rightarrow 17.550

Instrument Check on 10-25-65 Source 10 m cY

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	7.3×10^{-4}	Meter Trip	OK	Fast Trip OK
IC-2	7.3×10^{-4}	Meter Trip	OK	Red light OK
IC-3	Response	Calibration	S.P.R.	alarm OK
IC-4	Response	Calibration	S.P.R.	Pos Dif 0.14
CRM		Meter Trip		

Apr 27 24x26x26" Stack A with ^{3' x 4' x 4'} al boxes and steel plate on top
 b > 1 no plexiglass tables together.
 11 AM Temp 0.8818 mv.

Apr 28 24x26x26" Stack A removed al boxes and steel plate
 but left al support the instrument on table.
 b > 1 Table together no plexiglass 12²⁵ Temp 0.9112 mv.

Apr 29 24x26x26" Stack A removed instrument used to support
 al boxes on top of stack
 b > 1 Table together no plexiglass 1⁰⁰ PM Temp 0.9185 mv.

Apr 30 24x26x26 1/4" Stack B 1⁴⁸ PM Temp 0.9273 mv.
 b > 1 Table together no plexiglass

Apr 31 24x26x26" Stack A 2²⁵ Temp 0.9380 mv.
 b > 1 Table together no plexiglass

Apr 32 24x26x26 1/4" Stack B 2⁵⁰ PM Temp 0.9340 mv
 b > 1 Tables together no plexiglass

Apr 33 24x26x26" Stack A 3²⁵ PM Temp 0.9378 mv
 b > 1 Tables together no plexiglass

Apr 34 24x26x26 1/4" Stack B 4⁰⁰ PM Temp 0.9385 mv
 b > 1 Tables together no plexiglass
 b = 1 table repair ~ 2.2 rev.

Exp	Expn 35	24x26x26 1/4" no flexiglass		
		b > 1 U2-31 (1 sec)		
		L _N = 41.258 → 18.607 φ	TMC = 42.351 → 18.295 φ	
Exp	Expn 36	24x26x26"		
		b > 1 U2-32 (5 sec)		
		L _N = 188.266 → 5.878 φ	TMC = 193.941 → 5.730 φ	
Exp	Expn 37	24x26x26 1/4"		Exp
		b > 1 U2-33 (1 sec)		
		L _N = 42.995 → 18.116 φ	TMC = 43.197 → 18.061 φ	
Exp	Expn 38	24x26x26"		Exp
		b > 1 U2-34 (5 sec)		
		L _N = 190.003 → 5.832 φ	TMC = 192.055 → 5.778 φ	Exp
Exp	Expn 39	24x26x26 1/4"		Exp
		b > 1 U2-35 (1 sec)		
		L _N = 43.429 → 17.997 φ	TMC = 43.518 → 17.973 φ	
Exp	Expn 40	24x26x26"		Exp
		b > 1 U2-36 (5 sec)		
		L _N = 205.638 → 5.446 φ	TMC = 203.505 → 5.496 φ	Exp
Exp	Expn 41	24x26x26 1/4"		
		b > 1 U2-37 (1 sec)		
		L _N = 43.429 → 17.997 φ	TMC = 44.291 → 17.767 φ	Exp
Exp	Expn 42	24x26x26 ^{Stack A} By meter sticks (61.302 x 66.545 x 66.362 cm)		Exp
		b > 1 U2-38 (5 sec)	(24.134 x 26.199 x 26.127 in.)	
		L _N = 206.289 → 5.432 φ	TMC = 209.905 → 5.350 φ	
Exp	Expn 43	24x26x26 1/4" ^{Stack B} By meter sticks (61.302 x 66.545 x 67.115 cm)		Exp
		b > 1 U2-39 (1 sec)	(24.134 x 26.199 x 26.423 in.)	
		L _N = 44.298 → 17.766 φ	TMC = 45.025 → 17.576 φ	
		Avg worth of 1/4" of fuel from Expn's U2-25 → U2-39 = 12.314 ± 0.116 φ		

Instrument Check 62 10-26-65 Source 10mcr

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	7.3×10^{-4}	Meter Trip	OK	East Trip	OK
IC-2	2.3×10^{-4}	Meter Trip	OK	Red light	OK
IC-3	Responds	Calibration	S.F.R.	Alarm	ASOK ^{B hole}
IC-4	Responds	Calibration	S.F.R.	Pre-Set	0.14
CRM		Meter Trip			

Exp 35 24x26x26 1/4" "Stack B"
 b=1 table sep ~2.29 sec. ^{9:14}
 b>1 table together no plexiglass Temp 0.8554mV

Exp 36 24x26x26" Stack A
 b>1 table together no plexiglass

Exp 37 24x26x26 1/4" Stack B
 b>1 table together no plexiglass

Exp 38 24x26x26 Stack A
^{11:30} b>1 table together no plexiglass

Exp 39 24x26x26 1/4 Stack B
^{12:55} b>1 table together no plexiglass

Exp 40 24x26x26 Stack A
^{1:27} PM. b>1 table together no plexiglass

Exp 41 24x26x26 1/4 Stack B
^{2:12} PM b>1 table together no plexiglass

Exp 42 24x26x26 Stack A
^{2:46} PM b>1 table together no plexiglass

Exp 43 24x26x26 1/4 Stack B
^{3:30} PM b>1 table together no plexiglass

Stack C

Expt 44. 24x26x25³/₄ By meter sticks (61.302 x 66.545 x 65.732 cm)
 24.134 x 26.199 x 25.878

b < 1 U2-40 (5 sec)

$L_N = -270.782 \rightarrow -5.6234$ $TMC = -276.008 \rightarrow -5.4984$

Expt 45 24x26x26

b > 1 U2-41 (5 sec)



$L_N = 145.488 \rightarrow 7.3074$ $TMC = 147.157 \rightarrow 7.2384$

Expt 46 24x26x25³/₄

b < 1 U2-42 (5 sec)

$L_N = -266.439 \rightarrow -5.7334$ $TMC = -271.283 \rightarrow -5.6114$

Stack C



Instrument Check on 10-27-65 Source 10 mCi

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Test Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Red light OK
IC-3	Responds	Calibration	S.P.R.	alarm A+C OK ^{B dose} not trip
IC-4	Responds	Calibration	S.P.R.	Pro. dif 0.14
CRM	Meter Trip			

Exp 44 24 x 26 x 25³/₄" Stock C
 10²⁵ AM b < 1 tables together no plexiglass

Exp 45 24 x 26 x 26" Stock D
 10⁵⁴ AM b > 1 tables together no plexiglass

Exp 46 24 x 26 x 25³/₄" Stock C
 1³³ PM b < 1 tables together no plexiglass

Exp 47 24 x 26 x 25³/₄" Stock C
 To find plexiglass shim that can be used on drive
 to shim for critical mass
 1/2 x 26 x 3³/₄" plex. b < 1
 1 x 26 x 6" b < 1
 1 x 26 x 29" b > 1

Instrument Check on 10-28-65 Source 10mCr

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	7.3×10^{-4}	OK	Alarm Trip	OK
IC-2	7.3×10^{-4}	OK	Redlight	OK
IC-3	Responds	S.F.R.	Alarm	OK
IC-4	Responds	S.F.R.	Pres. dif	0.14
CRM	Meter Trip			

Expt 48 To check worth of and operation of plexiglass shim on rod drive. ^{Stack C 24 x 26 x 25 3/4"} 1 x 12 x 26" piece of Plexiglass

b > 1 Tables together and shim all the way in.

b = 1 Shim ~ 2" from stack.

b = 1 shim all the way in. Table separ. = 1.5 rev.

Expt 49 To check worth of foil stringer

b > 1 tables together, shim all the way in

b = 1 " " , shim ~ 2" from stack

Placed 7 Cd. foil covers in all stringer

b > 1 tables together, shim all the way in

b = 1 " " , shim ~ 1/4" from stack

Expt 51 *11 bare gold foils across center of stack*
(2 mil, 7/16 dia, 48.7 mg)

	-10"	-8"	-6"	-4"	-2"	0	+2"	+4"	+6"	+8"	+10"
<i>H₃₀</i>	H 30	H 19	H 1	H 21	H 16	H 8	H 18	H 10	H 14	H 7	H 11
<i>Ratio F₃₀/ N</i>	0.44295	0.63200	0.78050	0.89582	0.98684	1.0	0.96521	0.89705	0.76431	0.61221	0.42657

Ex

Ex

Instrument Check on 10-29-65 Source 10 mcr

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	Redlight	OK
IC-3	Responds	Calibration	S/R	alarm	OK
IC-4	Responds	Calibration	S/R	Pres dif	0.14
CRM		Meter Trip			

Stack C 24x26x25 $\frac{3}{4}$ "

Expt 50 To determine power level for foil activation runs.
1 gold foil (2 mil, $\frac{5}{16}$ " dia, 48.7 mg) at center of stack

9 $\frac{33}{AM}$ b=1 Power = 10. on IC-3
9 $\frac{52}{AM}$ shut down.

Foils counted ~7800 on one counter and ~8300 on other in 1 min.

Expt 51 11 bare gold foils

11:14.5 Start time at 37.0 on IC-3

b=1 100 on IC-3, 2.6×10^{-7} on IC-2, + 0.35×10^{-7} on IC-1

11:39.5 shut down.

Expt 52 11 bare gold foils (2 mil, $\frac{5}{16}$ " dia, 48.7 mg)

-10	-8	-6	-4	-2	0	+2	+4	+6	+8	+10
H-7	H22	H15	H13	H6	H24	H12	H3	H23	H25	H-9
0.43553	0.62843	0.77956	0.89782	0.98522	1.0 0.96483	0.96483	0.89204	0.76695	0.61485	0.42305

Expt 53 11 bare gold foils (2 mil, $\frac{5}{16}$ " dia, 48.6 mg)

G5	G18	G1	G13	G10	G26	G9	G7	G16	G11	G17
0.43993	0.63049	0.77513	0.90133	0.98174	1.0	0.96663	0.88851	0.76332	0.61437	0.42381

Expt 54 7 Ed. covered ~~to~~ gold foils (2 mil, $\frac{5}{16}$ " dia, 48.6 mg)

-9	-6	3	0	+3	+6	+9
G28	G20	G6	G15	G22	G24	G23
0.52955	0.77785	0.95111	1.0	0.94354	0.78293	0.53803

Instrument Check on 11-1-65 Source 10 mCf

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Beam Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK		
IC-3	Responds	Calibration	S.F.B.	Redlight	OK
IC-4	Responds	Calibration	S.F.B.	Alarm	OK
CRM		Meter Trip		Pres. Trip	0.15"

Stack C 24 x 26 x 25 ³/₄"

Exp 52 11 bare gold foils.

9:05, 20mc Start time at 37.0 on IC-3

b=1 100 on IC-3, 2.6×10^{-8} on IC-2.

9:30, 10mc Started to exp. Table with screen. Opened 3 rev. (in 30 sec).

Shut down at 9:35

Exp 53 11 bare gold foils

11:26, 45 Start time at 37.0 on IC-3

b=1 100 on IC-3, 2.6×10^{-8} on IC-2

11:51, 45mc Shut down.

Exp 54 7 Cd covered gold foils

2:24, 34mc Start time at 37.0 on IC-3

b=1 100 on IC-3, 2.6×10^{-8} on IC-2

2:49, 34mc Shut down.

Expt 55

7 Ed covered gold foils (2 mil, $\frac{5}{16}$ dia., 48.6 mg)

-9"	-6"	-3"	0	+3"	+6"	+9"
G27	G8	G2	G19	G12	G21	G3
0.53081	0.77718	0.94848	1.0	.94790	0.78391	0.53855

Expt 56

7 Ed covered gold foils (2 mil, $\frac{5}{16}$ dia., 48.8 mg)

J3	J4	J10	J16	J17	J11	J6
0.52563	0.77306	0.93664	1.0	0.94493	0.78583	0.53870

Instrument Check on 11-2-65 Source 10 mcr

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Redlight OK
IC-3	Responds	Calibration	2 f R	Alarm OK
IC-4	Responds	Calibration	1 f R	Pres. dif. 0.15
CRM		Meter Trip		

Stack C

Expt 55

7 Cd covered gold foil

9:13, 10mc Start time at 37.0 on IC-3

b=1 100 on IC-3 and 2.6×10^{-3} on IC-2.

9:38, 10mc Shut down.

Expt 56

7 Cd covered gold foil

1:01, 23mc Start time at 37.0 on IC-3

b=1 100 on IC-3 and 2.6×10^{-3} on IC-2.

Exp 58 11 bare file 2% V in paraffin

-10"	-8"	-6"	-4"	-2"	0	+2"	+4"	+6"	+8"	+10"
C-2	C-6	C-4	C-11	C-18	C-24	C-21	C-5	C-16	C-40	C-31
0.42480	0.62164	0.77270	0.90363	0.98406	1.0	0.95376	0.89548	0.75918	0.60782	0.42483

Exp

Exp 59 11 bare file 2% V in paraffin

C-1	C-3	C-7	C-9	C-10	C-12	C-13	C-14	C-15	C-17	C-19
C-19	C-17	C-15	C-14	C-13	C-12	C-10	C-9	C-7	C-3	C-1
0.43430	0.62907	0.78259	0.90806	0.99176	1.0	0.97118	0.90156	0.76373	0.61431	0.42271

Exp

V(2)F₄ H/K = 617

Instrument Check on 11-3-65 Source 10 m cY

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Test Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Redlight OK
IC-3	Responds	Calibration	S/R	Alarm OK
IC-4	Responds	Calibration	S/R	Pres diff 0.15"
CRM		Meter Trip		

Stack C

Expt 57 1 bare 2% U in paraffin
 10:54 Start time at 3.7 on IC-3
 b=1 10 on IC-3, 2.98 on IC-2
 11:05 Shut down.


Expt 58 11 bare fuel 2% U in paraffin
 1:11, 52 sec Start time at 3.7 on IC-3
 b=1 7 on IC-3, 2.55 on IC-2
 1:21, 52 sec Shut down.

Expt 59. see page 32 for data

Expt 60 11 bare foils of 2% Enriched U in paraffin

-10"	-8"	-6"	-4"	-2"	0	+2"	+4"	+6"	+8"	+10"
C-20	C-25	C-29	C-34	C-37	C-39	C-38	C-36	C-32	C-27	C-22
0.43125	0.63283	0.77912	0.89121	0.99460	1.0	0.96015	0.90099	0.77206	0.61475	0.41845

Eff

Expt 61
 Top
 E  2 Cd covered and 2 bare Au. foils
 (2 mil, 7/16 dia, 48.8mg)

Eff

	Position 1	2	3	4
	J-8 Bare	J-12 Cd.	J-2 Bare	J-13 Cd.
Cd Ratio = $\frac{1}{4}$	3.63020		$\frac{3}{2}$	3.66336
$\frac{1}{2}$	3.59451		$\frac{3}{4}$	3.67629

Eff

avg Cd Ratio = 3.64109 for 2 mil au

Instrument Check on 11-4-65 Source 10 mCF

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	East Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Red light	OK
IC-3	Response	Calibration	S/O.R.	Alarm	OK
IC-4	Response	Calibration	S/O.R.	Pres. Trip	0.14"
CRM		Meter Trip			

Stack C

Expt 59 11 bare foils 27% Enriched U in paraffin.
 8:47,9 Start time at 7.4 on IC-3
 $k=1$ 20 on IC-3, 5.6×10^{-9} on IC-2
 8:57,9 Shut down


Expt 60 11 bare foils of 27% Enriched U in paraffin
 10:48,22 sec Start time at 7.4 on IC-3
 $k=1$ 20 on IC-3,
 10:58,22 sec Shut down.

Expt 61 the meas. Cd ratios. 2 Cd covered and 2 bare Au. foils.
 1:27 PM Start time at 37 on IC-3
 $k=1$ 100 on IC-3 and 2.6^+ on IC-2
 1:52 PM Shut down

Expt 62 11 Base foils of 2% Enriched U in paraffin

-10"	-8"	-6"	-4"	-2"	0	+2"	+4"	+6"	+8"	+10"
B-1	B-2	B-3	B-5	B-7	B-0	B-10	B-9	B-8	B-11	B-12
0.43456	0.62207	0.80259	0.88131	0.98268	1.0	0.97606	0.89437	0.78296	0.62052	0.43093

Expt 63



2 Cd covered and 2 bare In foils (9 mil, $\frac{5}{16}$) 9.3% In alloy

Pos. 1	2	3	4
Foil 11 Bare	12 Cd	22 Bare	13 Cd
$\frac{1}{4} = 2.24501$		$\frac{3}{2} = 2.25156$	
$\frac{1}{2} = 2.23453$		$\frac{3}{4} = 2.26157$	

avg Cd ratio for In = 2.24816

Expt 64 2 Cd covered and 2 bare gold foils (5 mil, $\frac{5}{16}$, 4)

512 Bare	510 Cd	511 Bare	504 Cd
$\frac{1}{4} = 4.50276$		$\frac{3}{2} = 4.48310$	
$\frac{1}{2} = 4.48426$		$\frac{3}{4} = 4.51147$	

avg Cd ratio for 5 mil Au = 4.49539

Stack C U(2)F₄ H/X = 614

37

Instrument Check on 11-5-65 Source 10mct

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	7.3×10^{-4}	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Red light OK
IC-3	Responds	Calibration	S.P.R.	Alarm OK
IC-4	Responds	Calibration	S.P.R.	Prec. dif 0.15"
CRM		Meter Trip		

data from Foils in positions +2" and -2" show up to 3.5% asymmetry. For this reason the 4" x 4" blocks in this region were changed on both tables.

Expt 62 11 bare foils of 2% enriched U in paraffin
 9:28, 40am Start time at 7.5 on IC-3
 b=1 20 on IC-3 and 5.6×10^{-9} on IC-2
 9:38, 40 Shutdown

Expt 63 To meas. Cd ratios for Indium
 11:49 Start time at 7.5 on IC-3
 b=1 20 on IC-3 and 5.6×10^{-9} on IC-2
 11:59 Shutdown

Expt 64 To meas. Cd ratios for 5mil gold foils
 1:30, 33am Start time at 11 on IC-3
 b=1 30 on IC-3 and 7.3×10^{-9} on IC-2
 1:55, 33 Shutdown

Expt 65 2 Cd covered and 2 bare U -al foil

Pro (see Expt 63)	1	2	3	4
	1 bare	2 Cd	3 Bare	4 Cd
	$\frac{1}{4} = 22.99238$		$\frac{3}{2} = 22.09494$	
	$\frac{1}{2} = 22.26399$		$\frac{3}{4}$	

Expt 6

Expt 66 Repeat of Expt 65

	1 bare	2 Cd	3 Bare	4 Cd.
	$\frac{1}{4} = 22.94792$		$\frac{3}{2} = 22.18480$	
	$\frac{1}{2} = 22.52356$		$\frac{3}{4} = 22.01609$	
Avg of Expt 65 and 66	$\frac{1}{4} = 22.97015$		$\frac{3}{2} = 22.13987$	
	$\frac{1}{2} = 22.39377$		$\frac{3}{4} = 22.01609$	

Expt 6

Avg Cd Ratio = 22.37997 for U -al

Expt 67 2 Cd covered and 2 bare gold foil
(1 mil, $\frac{5}{16}$ ")

Expt 1

Red ^{reference} foil	402 Bare	406 Cd	407 bare	408 Cd.
Comp for foil wt.	$\frac{1}{4} = 3.05265$		$\frac{3}{2} = 3.00581$	
	$\frac{1}{2} = 3.01495$		$\frac{3}{4} = 3.03047$	
	3.05266		3.04978	
	3.02380			
	Avg Cd ratio for 1 mil Au = 3.02584			
	3.03864 ± 0.0133			

Instrument Check on 11-8-65 Source 10 mcf

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	Red light OK
IC-3	Responds	Calibration	A/B	Alarm OK
IC-4	Responds	Calibration	A/B	Pre slip 0.15^{-2}
CRM		Meter Trip		

Stack C

Expt 65

To meas. Cd ratio for 9 mil U-235 foil.

9:47, 38 sec Start time at 37 on IC-3

b = 1 at 100 on IC-3 and 3.0×10^{-8} on IC-2

10:07, 38 sec Shut down

Expt 66

Repeat of Expt 65

12:39, 5 sec Start time at 37 on IC-3

b = 1 at 100 on IC-3 and 3.0×10^{-8} on IC-2

12:57, 5 sec Shut down

Expt 67


To meas. Cd ratio for 1 mil gold foil

2:59, 30 sec Start time at 37 on IC-3

b = 1 at 100 on IC-3 and 3.1×10^{-8} on IC-2

3:24, 30 sec Shut down

Expt 69-



U^{238} detector in top position (painted with red lipstick)

Expt 69 Ch #1 with U^{238} = 5855/30min 1166.655
 Ch #2 with U^{235} = 6830765/30min

Expt #70 Ch #1 with U^{235} = 706610.5/30min 1232.102
 Ch #2 with U^{238} (on top) = 5735/30min

Expt #71 Ch #1 with U^{235} (on top) = 7175315/30min 1257.724
 Ch #2 with U^{238} = 5705/30min

Expt 72 Ch #1 with U^{238} = 5885/30min 1210.963
 Ch #2 with U^{235} (on top) = 7126515/30min

Not corr. for dead time → Avg 1216.861
 U^{235} detector — No. 5-3, 97.34% U^{235} , 0.3379 mg U^{235}

U^{238} detector — No. 8-2, ~ 7 ppm of U^{235} , 0.3989 mg U

See pp. 80 + 82

Expt
 Expt
 Expt
 Expt

Instrument Check on 11-10-65 Source 10mCf

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	7.3×10^{-4}	Meter Trip	OK	Alarm Trip
IC-2	7.3×10^{-4}	Meter Trip	OK	Red light OK
IC-3	Response	Calibration	SfA.	Pres. sig 0.15
IC-4	Response	Calibration	SfA.	Alarm OK
CRM		Meter Trip		

Stack E $24 \times 26 \times 25 \frac{3}{4}$ "

Expt 68 Have restacked top with $\frac{1}{4}$ of stack and put a $\frac{1}{4}$ " U^{235} fissile ch. and a $\frac{1}{4}$ " U^{238} fissile ch. in center of stack. separated vert. by 2".

Counting channel #1 - Amp. Y102542, Scalar Y120248, Pre Amp 696
 " " #2 - Amp. Y102541, Scalar Y120242, Pre Amp 694

Check counter { Ch #1 with U^{235} = 1274035/5min
 Ch #2 with U^{238} = 1035/5min

Switch Amp. → power = 5.4 on 3×10^{-9} scale on IC-2

{ Ch #1 with U^{238} = 1035/5min
 Ch #2 with U^{235} = 1253105/5min
 → power = 5.35 on 3×10^{-9} scale on IC-2

Expt 69 Power = 5.0 on 3×10^{-9} scale IC-2

Expt 70 Power = 5.0 on 3×10^{-9} scale IC-2

Expt 71 Power = 5.0 on 3×10^{-9} scale IC-2

Expt 72 Power = 5.0 on 3×10^{-9} scale IC-2

Expt 73 24x26x24" high plus 6" polyethylene on top.
 $k < 1$

Expt 74 24x26x24 1/4" high plus 6" poly. on top.
 $k < 1$

Expt 75 24x26x24 1/2" high plus 6" poly. on top.
 $k > 1$


$$\ln N = 1057.504 \rightarrow 1.1924$$

Expt 76 24x26x24 1/2" high plus 6" ~~poly~~ paraffin on top
 $k > 1$ (paraffin ~ 1/2" narrower than poly in 24" diam)

$$\ln N = 2813.244 \rightarrow 0.4574$$

Density of polyethylene coils from diam. and weight of one block = 0.91997 g/cc

Density of stack shown below =



$$0.91484 \text{ g/cc}$$

Instrument Check on 11-11-65 Source 10 mct

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	7.3×10^{-11}	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	Red light	OK
IC-3	Response	Calibration	S.F.R.	Alarm	OK
IC-4	Response	Calibration	S.F.R.	Pres. def	0.15"
CRM		Meter Trip			

Expt 73 Tables Together $b < 1$ Expt 74 Tables Together $b > 1$ with plexiglass shield $b < 1$ no plexiglass

Expt 75 Tables Together no plexiglass

 $b > 1$

Expt 76 Tables Together no plexiglass

 $b > 1$

Expt 77 22 x 24 x 22" high stack plus 6" of polyethylene on top
and sides and 6" of plexiglass on bottom.
k >> 1

Expt 78 22 x 24 x 21³/₄" plus poly. and plexiglass refl as above.
k >> 1

Expt 79 22 x 24 x 21¹/₂" plus poly. and plexiglass refl as above
k > 1 + 20.274 φ
L_N = 36.046 → 20.274

Expt 80 22 x 24 x 21¹/₄" plus poly. and plexiglass refl as above.
k > 1 + 6.532 φ

→ Stack F measured with meterstick (56.315 x 61.287 x 54.377 cm)
(22.171 x 24.128 x 21.408 in)

Instrument Check on 11-12-65 Source 10 mCK

PF-1	Low Trip	OK	Alarm Trip	OK	
PF-2			Alarm Trip		
IE-1	$> 3 \times 10^{-4}$	Motor Trip	OK	Best Trip	OK
IE-2	$> 3 \times 10^{-4}$	Motor Trip	OK		
IE-5	Responds	Calibration	S.P.R.		Redlight OK
IC-4	Responds	Calibration	S.P.R.		alarm OK
CRM		Motor Trip			Pres. diff 0.15"

Expt 76 Tables ~~together~~ separated by ~ 4 rev.
b > 1

Expt 78 Tables separated by ~ 1.2 rev.
b > 1

Expt 79 Tables together
b > 1

Expt 80 Tables together Stack F
b > 1

.377 cm
.408 cm

Expt 81 22 x 22 x 22" high stack plus 6" of polyethylene on top
and sides and 6" of plexiglass on bottom
 $b \ll 1$

Expt 82 22 x 22 x 23" high stack plus 6" of polyethylene
stack on top and sides and 6" of plexiglass on bottom
 $b > 1$ + 4.638¢

Measured with meter stick $(56.298 \times 56.293 \times 58.77 \text{ cm})$
 $(22.165 \times 22.163 \times 23.138 \text{ in.})$

Expt

Expt

Instrument Check on 11-15-65 Source 10 mck

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	Red light	OK
IC-3	Responds	Calibration	S.G.R.	alarm	OK
IC-4	Responds	Calibration	S.G.R.	Pres. Trip	0.15"
SEM		Meter Trip			

Exp 81 Have restacked piped table to get 10 x 22 x 22.
 With 12 x 22 x 22 on movable we have a 22 x 22 x 22" stack
 Tables Together
 $b << 1$

Exp 82 Tables Together Stack G
 $b > 1$

Expt 83 22x22x40" high base studs.

$b < 1$

Expt 84 22x22x42" high

$b > 1$

$\ln N = 46.317 \rightarrow 17.2504$

Ex

Ex

U(2) F₄ H/x = 614

49

Instrument Check on 11-16-65 Source 10 m c r

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Red light	OK
IC-3	Responds	Calibration	S/O	alarm	OK
IC-4	Responds	Calibration	S/O	Pres dif	0.15"
CRM		Meter Trip			

Exp 83 Tables Together
 $b < 1$

Exp 84 Tables together
 $b > 1$

$b = 1$ table separated 2.9 rev.

50

Exp 87 21x21x66" high

b > 1

$L_N = 629.725 \rightarrow 1.9604$

Exp
Exp
Exp

U(2) F₄

H/K = 614

51

Instrument Check on 11-17-65 Source 10 m.c.r

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	✓ Alarm Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Red light OK
IC-3	Responds	Calibration	S/O.	alarm OK
IC-4	Responds	Calibration	S/O.	Pre dif 0.15"
CRM		Meter Trip		

Expt 85 21x21x52" high Tables together b < 1

Expt 86 21x21x60" high Tables together b < 1

Expt 87 21x21x66" high
Tables together b > 1

52.

Exp 77

21 X 22 X 50"

b > 1 V2-88 (5 sec)

$L_N = 178.929 \rightarrow 6.139 \phi$

$TMC = 178.942 \rightarrow 6.139 \phi$

Exp

U(2)F₄ H/x = 614

53

Instrument Check on 11-18-65 Source 10mCr

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	73×10^{-4}	Meter Trip	OK	Fast Trip	OK
IC-2	73×10^{-4}	Meter Trip	OK	Red light	OK
IC-3	Respond	Calibration	S/O.	alarm	OK
IC-4	Responds	Calibration	S/O.	Pres dif	0.15"
CRM		Meter Trip			

Exp. 88

21 x 22 x 50" high stack - Stack H

Check 4 counters connected to TMC and
position so ~ same count rate in each counter.
6 > 1 Tables together no Plexiglas

Stack H

Exp 89 21 x 22 x 50" stack (53.842 x 56.345 x 127.546 cm)
 b > 1 V2-89 (5 sec) (21.198 x 22.173 x 50.215 cm)

$$L_N = 143.751 \rightarrow 7.380 \text{ f} \quad TMC = 141.460 \rightarrow 7.479 \text{ f}$$

Exp 90 21 x 22 x 49" measured with meter stick (53.842 x 56.345 x 125.006 cm)
 b < 1 V2-90 (10 sec) (21.198 x 22.173 x 49.215 cm)

$$L_N = -1825.002 \rightarrow -0.729 \text{ f} \quad TMC = -1909.152 \rightarrow -0.696$$

Exp 91 21 x 22 x 50"
 b > 1 V2-91 (5 sec)

$$L_N = 144.185 \rightarrow 7.362 \text{ f} \quad TMC = 146.057 \rightarrow 7.283 \text{ f}$$

Exp 92 21 x 22 x 49"
 b < 1 V2-92 (10 sec)

$$L_N = -742.642 \rightarrow -1.847 \text{ f} \quad TMC = -759.706 \rightarrow -1.803 \text{ f}$$

Exp 93 21 x 22 x 50"
 b > 1 V2-93 (5 sec)

$$L_N = 160.689 \rightarrow 6.724 \text{ f} \quad TMC = 162.520 \rightarrow 6.661 \text{ f}$$

Exp 94 21 x 22 x 49"
 b < 1 V2-94 10 sec

$$L_N = -896.816 \rightarrow -1.516 \text{ f} \quad TMC = -940.344 \rightarrow -1.442 \text{ f}$$

Instrument Check on 11-19-65 Source 10mc r

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Red light	OK
IC-3	Responds	Calibration	S/P/R	Alarm	OK
IC-4	Responds	Calibration	S/P/R	Pres. dif	0.15"
CRM		Meter Trip			

Expt 89 21 x 22 x 50" stack
 b = 1 ^{separated ~ 2.2 rev.} Check counters
 Tables together b > 1 no plexiglass

Expt 90 21 x 22 x 49" stack
 b < 1 Tables together no plexiglass

Expt 91 21 x 22 x 50" stack
 b > 1 Tables together no plexiglass

Expt 92 21 x 22 x 49" stack
 b < 1 Tables together no plexiglass

Expt 93 21 x 22 x 50" stack
 b > 1 Tables together no plexiglass

Expt 94 21 x 22 x 49" stack
 b < 1 Tables together no plexiglass

Eggs 95

21x22x49"

 $b > 1$ V2-95 (5 sec)Log N — $T = 1233.50 \text{ sec}$, $P = 1.0274$ TMC = 1226.864 \rightarrow 1.033 ϕ

Eggs 96

21x22x50"

 $b > 1$ V2-96 (5 sec)Log N — $T = 112.916 \text{ sec}$, $P = 8.9804$ TMC = 113.358 \rightarrow 8.952 ϕ

Eggs 97

21x22x49"

 $b < 1$ V2-97 (10 sec)Log N — $T = -8687.07 \text{ sec}$, $P = -\frac{197}{2275} \phi$ TMC = -7298.957 \rightarrow -0.180 ϕ

Eggs 98

21x22x50"

 $b > 1$ V2-98 (5 sec)Log N — $T = 137.888 \text{ sec}$, $P = 7.6384$ TMC = 138.175 \rightarrow 7.625 ϕ

Eggs 99

21x22x49"

 $b < 1$ V2-99 (5 sec) Log N $\rightarrow T = -2034.19 \text{ sec}$, $P = -0.6524$ TMC = -2153.021 \rightarrow -0.616

Eggs 100

21x22x50"

 $b > 1$ V2-100 (5 sec) Log N $\rightarrow T = 144.837 \text{ sec}$, $P = 7.3344$ TMC = 146.992 \rightarrow 7.245

Eggs 101

21x22x50" plus machine of support structure on top.

 $b > 1$ V2-101 (5 sec) Log N $\rightarrow T = 153.088 \text{ sec}$, $P = 7.0034$ TMC = 155.744 \rightarrow 6.903

Eggs 102

21x22x50" $b > 1$ V2-102 (5 sec) Log N $\rightarrow T = 196.735 \text{ sec}$, $P = 5.6594$ TMC = 201.812 \rightarrow 5.536 ϕ

Instrument Check on 11-22-65 Source 10 mCr

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	7.3×10^{-4}	Meter Trip	OK	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Red light OK
IC-3	Response	Calibration	S/R	alarm OK
IC-4	Response	Calibration	S/R	Pre-dif 0.15°
CEM		Meter Trip		

Expt 95 21 x 22 x 49" Stack
 $b = 1$ tables together ~ 4.0 rev. with plexiglass.
 check counter.

Expt 96 21 x 22 x 50" Stack
 $b > 1$ tables together no plexiglass

Expt 97 21 x 22 x 49"
 $b < 1$ tables together no plexiglass

Expt 98 21 x 22 x 50"
 $b > 1$ tables together no plexiglass

Expt 99 21 x 22 x 49"
 $b < 1$ tables together no plexiglass

Expt 100 21 x 22 x 50"
 $b > 1$ tables together no plexiglass

Expt 101 21 x 22 x 50" added 4 boxes and $3/4$ " x 4' x 4' steel plate
 on top to simulate support structure.

Expt 102 21 x 22 x 50" Removed 4 boxes
 $b > 1$ tables together no plexiglass

Angular width of 1" offset on 21 x 22" stack from Expts 99-100 = 8.277 ± 0.456

7.6524



34 4

03 4

735 arc

59 4

Expt 103



fil of center of stock
in vertical direction

Expt 104

9 bare foils 2% Enriched U in paraffin

-8"	-6"	-4"	-2"	0"	+2"	+4"	+6"	+8"
B-20	B-10	B-11	B-34	B-0	B-2	B-37	B-40	B-3
0.46555	0.68765	0.87273	0.97189	1.0	0.96277	0.85527	0.67868	0.43705

Expt

Expt

Instrument Check on 11-23-65 Source 10 mC V

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	$> 3 \times 10^{-8}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-8}$	Meter Trip	OK	Redlight	OK
IC-3	Responds	Calibration	S.P.O.	Alarm	OK
IC-4	Responds	Calibration	S.P.O.	Pres. Lit	0.15"
CRM		Meter Trip			

Expt. 103 To determine stack to run foil in and to adjust
plexiglass ^{shim} on rod drive.

21 x 22 x 49 1/2" less 1/2" x 1" x 22" on top in 21" dimension.

produces a stack that can be held critical with
shims and with the Al foil stringer with 9 U(235)-paraffin
foils in stack.

k = 1 Table together plexiglass shim ~ 3" from stack.

Expt. 104 9 bare foils 2% Enriched U in paraffin

12:52 Start time at 7.4 on IC-3

k = 1 2.0 on IC-3, 8.3 on 3×10^{-8} on IC-2

1:02 shut down

Expt 105 7 bare foils 2% U in paraffin

-6"	-4"	-2"	0	+2"	+4"	+6"
B-15	B-33	B-31	B-8	B-17	B-30	B-29
0.69798	0.85630	0.97174	1.0	0.97999	0.83817	0.66702

Expt 106 7 bare foils 2% U in paraffin

Expt

B-7	B-22	B-44	B-26	B-9	B-13	B-12
0.68786	0.85483	0.97370	0.96755 1.0	0.96455	0.84875	0.67420

Expt

Expt 107 7 bare foils 2% U in paraffin

B-1	B-32	B-21	B-24	B-27	B-5	B-38
0.71079	0.87303	0.99796	1.0	0.97401	0.85915	0.68179

Expt

Expt 108 7 bare foils 2% U in paraffin

Expt

C-32	C-36	C-38	C-34	C-20	C-37	C-27
0.69842	0.86845	1.05709	1.0	0.96906	0.85318	0.67897

Instrument Check on 11-24-65 Source 10 mCr

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	7.3×10^{-4}	Meter Trip	OK	Fast Trip	OK
IC-2	7.3×10^{-4}	Meter Trip	OK	Redlight	OK
IC-3	Respond	Calibration	S.P.O.	Alarm	OK
IC-4	Responds	Calibration	S.P.O.	Pres. dif	0.15°
CRM		Meter Trip			

21 x 22 x 49 1/2" stack (see Expt 103)

Expt 105 9 bare foils 2% U in paraffin

8:52 start time at 7.4 on IC-3

b=1 20 on IC-3 ~ 8.4 on 3×10^{-8} on IC-2

9:02 shut down

Expt 106 7 bare foils 2% U in paraffin

10:20 start time at 7 on IC-3

b ≈ 1 10 on IC-3

10:27.30 sec. shut down

Expt 107 1:16 start time at 7.5 on IC-3

b ~ 1 20 on IC-3

1:23 shut down.

Expt 108 7 bare foils 2% U in paraffin

2:44 start time at 7 on IC-3

b ~ 1 20 on IC-3

2:51 shut down.

Instrument Check on 11-26-65 Source 10m ct

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Red light OK
IC-3	Response	Calibration	S.F.R.	Alarm OK
IC-4	Response	Calibration	S.F.R.	Press. dif 0.15"
CRM		Meter Trip		

Expt 109 40x40x16" stack
b << 1

Expt 100 40x40x17"
b > 1 Table separation = 7.8 rev.
b = 1 Table separation = 8.7 rev.

Expt 111 40x20x16 $\frac{1}{2}$ " on one table 40x20x16 $\frac{1}{4}$ " on other table.
b > 1 with plexiglass skin
b > 1 no plexiglass.

Expt 112 40x20x16 $\frac{1}{2}$ " on one table, 40x20x16" on other
b < 1 with plexiglass skin

Exp 115 $40 \times 44 \times 16'' + \frac{1}{4}''$ on $\frac{1}{2}$ of top.
 $b > 1$ U2-115 (1 sec)

$$L_N = 42.713 \rightarrow 18.196 \quad TMC = 43.565 \rightarrow 17.960 \phi$$

Exp 116 $40 \times 44 \times 16'' + \frac{1}{4}''$ on SW $\frac{1}{4}$ of top
 $b > 1$ U2-116 (5 sec)

$$L_N = 165.466 \rightarrow 6.561 \phi \quad TMC = 165.499 \rightarrow 6.560 \phi$$

Exp 117 $40 \times 44 \times 16''$ Stack I

$b < 1$ U2-117 (10 sec)

$$L_N = -312.696 \rightarrow -4.754 \quad TMC = -316.717 \rightarrow -4.684$$

Stack I

Meas. with metric stick (102.273 x 112.633 x 40.836 cm high)
 (and steel tape) (40.265 x 44.344 x 16.077 in)

V274


H/K = 517

Instrument Check on 11-30-65 Source 10mct

65

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Red light	OK
IC-3	Responds	Calibration	S/O.	alarm	OK
IC-4	Responds	Calibration	S/O.	Base dif	0.15"
CRM		Meter Trip			

- Expt. 113 40x42x16"
b < 1 with plexiglass skin.
- Expt. 114 40x44x16" Stack I (20x44x16" on each table)
b > 1 with plexiglass skin
b < 1 no plexiglass
- Expt. 115 40x44x16" plus 1/4" on 1/2 of top
b > 1 no plexiglass.
Check ~~and~~ detectors and meas. per. on T.M.C.
- Expt. 116 40x44x16" plus 1/4" on SW 1/4 of top.
b > 1
- Expt. 117 40x44x16"
b < 1 let decay down to ~ background level.
- Expt. 118 40x44x16" plus 1/4" x 20x12" on SW corner of top
b < 1 to check by level.
- Expt. 119 40x44x16" plus 1/4" on top as
b ≈ 1



Expn 120 40x44x16" + 1/4" on SW 1/4 of Top

b > 1 V2-120 (5 sec)

$$L_N = 152.871 \rightarrow 7.012 \quad TMC = 150.678 \rightarrow 7.097$$

Expn 121 40x44x16" + 1/4" on SW and NE 1/4

b > 1 V2-121 (1 sec)

$$L_N = 40.541 \rightarrow 18.819 \quad TMC = 40.814 \rightarrow 18.758 \phi$$

Expn 122 40x44x16" + 1/4" on NE 1/4 of Top

b > 1 V2-122 (5 sec)

$$L_N = 141.145 \rightarrow 7.492 \phi \quad TMC = 132.992 \rightarrow 7.868 \phi$$

Expn 123 40x44x16

b < 1 V2-123 (10 sec)

$$L_N = -410.407 \rightarrow -3.498 \quad TMC = -417.142 \rightarrow -3.436 \phi$$

Expn 124 40x44x16" + 1/4" on NE 1/4 of Top

b > 1 V2-124 (5 sec)

$$L_N = 132.459 \rightarrow 7.894 \phi \quad TMC = 132.747 \rightarrow 7.880 \phi$$

Expn 125 40x44x16" + 1/4" on SW and NE 1/4 of Top

b > 1 V2-125 (1 sec)

$$L_N = 41.258 \rightarrow 18.607 \phi \quad TMC = 41.570 \rightarrow 18.517 \phi$$

Expn 126 40x44x16" + 1/4" on SW 1/4 of Top

b > 1 V2-126 (5 sec)

$$L_N = 142.448 \rightarrow 7.436 \quad TMC = 141.599 \rightarrow 7.472$$

V2/Fy

H/K 614

Instrument Check ^{6/24} -12-1-65 Source

67


PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	3×10^{-11}	Meter Trip	OK	Alarm Trip OK
IC-2	3×10^{-11}	Meter Trip		
IC-3	Response OK	Calibration	S & R	Red light OK
IC-4	Response OK	Calibration	S & R	Alarm OK
CRM		Meter Trip		Press Dif. .15"

Expr 120 40" x 44" x 16" + 1/4" covering 1/4 of stack on SW corner



b > 1

Expr 121 40 x 44 x 16" + 1/4" on SW and NE 1/4 of top



b > 1

Expr 122 40 x 44 x 16 + 1/4" on NE 1/4 of top



b > 1

Expr 123 40 x 44 x 16

b < 1

Room Temp 21.6°C at 2:00 PM.

Expr 124 40 x 44 x 16 + 1/4" on NE 1/4 of top



b > 1

Expr 125 40 x 44 x 16" + 1/4" on SW and NE 1/4 of top



b > 1

Expr 126 40 x 44 x 16" + 1/4" on SW 1/4 of top



b > 1

Expt. 127

40x44x16"

 $b < 1$ U2-127 (10 sec)

$$L_N = -362.635 \rightarrow -4.016 \text{ ¢} \quad TMC = -370.527 \rightarrow -3.920 \text{ ¢}$$

Expt. 128

40x44x16" + 1/4" on NW 1/4 of Top

 $b > 1$ U2-128 (5 sec)

$$L_N = 134.284 \rightarrow 7.806 \text{ ¢} \quad TMC = 132.907 \rightarrow 7.872 \text{ ¢}$$

Expt. 129

40x44x16"

 $b < 1$ U2-129 (5 sec)

$$L_N = -377.835 \rightarrow -3.835 \text{ ¢} \quad TMC = -386.546 \rightarrow -3.739 \text{ ¢}$$

Expt. 130

40x44x16" + 1/4" on NW 1/4 of Top

 $b > 1$ U2-130 (5 sec)

$$L_N = 140.429 \rightarrow 7.524 \text{ ¢} \quad TMC = 140.428 \rightarrow 7.524 \text{ ¢}$$

Expt. 131

40x44x16"

 $b < 1$ U2-131 (5 sec)

$$L_N = \frac{-353.949}{-4.128} \rightarrow -4.128 \text{ ¢} \quad TMC = -358.265 \rightarrow -4.072 \text{ ¢}$$

Expt. 132

40x44x16" + 1/4" on SE 1/4 of Top

 $b > 1$ U2-132 (5 sec)

$$L_N = 148.528 \rightarrow 7.182 \text{ ¢} \quad TMC = 149.679 \rightarrow 7.136 \text{ ¢}$$

Expt. 133

40x44x16"

 $b < 1$ U2-133 (5 sec)

$$L_N = -340.920 \rightarrow -4.306 \text{ ¢} \quad TMC = -345.170 \rightarrow -4.247 \text{ ¢}$$

Expt 127 40x44x16"
b < 1



Instrument Check on 12-2-65 Source 10mcr

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	7.3×10^{-4}	Meter Trip	OK	Exp Trip OK
IC-2	7.3×10^{-4}	Meter Trip	OK	Red light OK
IC-3	Responds	Calibration	S/R.	alarm OK
IC-4	Responds	Calibration	S/R.	Pres. def 9.15"
CRM		Meter Trip		

Expt 128 40x44x16" + 1/4" on NW 1/4 of top
b > 1



Expt 129 40x44x16"
b < 1



Expt 130 Same as 128



Expt 131 Same as 129



Expt 132 40x44x16" + 1/4" on SE 1/4 of top
b > 1



Expt 133 40x44x16"
b < 1



Expt 134 40x44x16" + 1/4" on SE 1/4 of top
 b > 1 U2-134 (5 sec)

$$\ln N = 152.871 \rightarrow 7.0124$$

$$TMC = 155.118 \rightarrow 6.9274$$

Expt 135 40x44x16

b < 1 U2-135 (5 sec)

$$\ln N = -328.760 \rightarrow -4.4894$$

$$TMC = -333.234 \rightarrow -4.4194$$

-
Exp 134

40x44x16

+ 1/4" on SE 1/4 of top



b > 1

+
Exp 135

40x44x16

b < 1



Exp. 136

40x44x16"

b < 1 U2-136 (5 sec)

$$L_N = -307.045 \rightarrow -4.855 \quad TMC = -315.048 \rightarrow -4.713 \phi$$

Exp. 137

40x44x16" + marking of all boxes and table on top.

b > 1 U2-137 (1 sec)

$$L_N = 11.574 \rightarrow 37.384 \phi \quad TMC = 12.017 \rightarrow 36.743 \phi$$

Exp. 138

40x44x16" + all boxes and 3/4" x 4' x 4" steel plate on top

b > 1 U2-138 (1 sec)

$$L_N = 11.617 \rightarrow 37.321 \quad TMC = 12.171 \rightarrow 36.527 \phi$$

Exp. 139

40x44x16"

b < 1 U2-139 (5 sec)

$$L_N = -272.085 \rightarrow -5.592 \quad TMC = -281.346 \rightarrow -5.375$$

Exp.

Exp.

Exp.

Exp.

Instrument Check on 12-3-65 Source _____

FM-1	Low Trip	OK	Hi	Alarm Trip	OK
FM-2				Low Trip	
IC-1	3×10^{-4} "	Meter Trip	OK	Press Trip	OK
IC-2	3×10^{-4} "	Meter Trip	OK		
IC-3	Response OK	Calibration		Red light	OK
IC-4	Response OK	Calibration		Alarm	OK
CRM		Meter Trip		Press Dif. 15"	

Expr 136 40 x 44 x 16
 $R < 1$

Expr 137 40 x 44 x 16 Added Al Boxes AND $\frac{3}{4}$ " x 4' x 4'
 steel plate on top to simulate support structure
 $R > 1$ steel plate on top may have been displaced Δ
slightly before measurement

Expr 138 Same as 137
 $R > 1$

Expr 139 40 x 44 x 16"
 $R < 1$

76

Exp 140A

Exp 141

Foil Position

-18"	C-3	0.33759	B-1	0.33443
-16"	C-4	0.46572	B-2	0.45351
-14"	C-5	0.58329	B-3	0.57332
-12"	C-7	0.69420	B-5	0.66667
-10"	C-8	0.77398	B-6	0.77313
-8	C-11	0.84601	B-7	0.83508
-6	C-13	0.91829	B-8	0.91182
-4	C-14	0.97163	B-9	0.96301
-2	C-15	0.98002	B-10	0.97826
0	C-1	1.0	B-0	1.0
+2	C-16	0.98214	B-11	0.99411
4	C-17	0.97741	B-12	0.94801
6	C-19	0.90831	B-13	0.90935
8	C-22	0.85331	B-14	0.85670
10	C-24	0.77141	B-15	0.77910
12	C-25	0.69091	B-17	0.68290
14	C-29	0.58589	B-20	0.57038
16	C-30	0.46701	B-21	0.46077
18	C-31	0.34737	B-23	0.34352

Exp

Exp

Exp

Instrument Check on 12-6-65 Source 10mcK

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	3×10^{-11}	Meter Trip	OK	Fail Trip	OK
IC-2	3×10^{-11}	Meter Trip	OK	Red light	OK
IC-3	Response	Calibration	S.P.D.	Alarm	OK
IC-4	Response	Calibration	S.P.D.	Press dif	0.15"
CRM		Meter Trip			

Expn 140 40x44x16" stack plus 11-4x4x $\frac{1}{4}$ and 20-2x2x $\frac{1}{4}$ pieces
 along north edge of top.
 19 foils 2% U in paraffin $\sim \frac{3}{8}$ " above center line
 9:04 start time at 10 on IC-3.

k=1 at 29 on IC-3

Shut down at 9:12, 30 sec. Were shut down early
 because of loss of air pressure.

Expn 140 A Foils in run 140 were not activated enough. Will
 reexpose same foils in same positions.

10:30, 30 sec start time at 10 on IC-3

k=1 at 30 on IC-3

10:40, 30 sec shut down

Expn 141 40x44x16" stack as above

19 foils 2% U in paraffin

1:10 start time at 22 on IC-3

k=1 at 64 on IC-3

1:20 shut down

Ford Position

-18	B-35	0.33423	C-2	0.33135
-16	B-25	0.45564	C-10	0.46386
-14	B-38	0.57839	C-12	0.58371
-12	B-41	0.67221	C-20	0.67942
-10	B-32	0.76876	C-23	0.77393
-8	B-26	0.84969	C-27	0.84913
-6	B-42	0.91742	C-32	0.91382
-4	B-33	0.95380	C-34	0.98744
-2	B-24	0.98183	C-35	0.99903
0	B-40	1.0	C-43	1.0
+2	B-28	1.01171	C-36	1.02115
4	B-37	0.96136	C-37	0.97550
6	B-31	0.90307	C-38	0.90123
8	B-34	0.85136	C-39	0.85441
10	B-29	0.77996	C-40	0.76821
12	B-27	0.68047	C-41	0.67544
14	B-36	0.58340	C-42	0.58222
16	B-30	0.45940	C-44	0.46683
18	B-22	0.34462	C-45	0.34797

Exp

Exp

Instrument Check on 12-7-65 Source 10 mCr

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	3×10^{-11}	Motor Trip	OK	OK
IC-2	3×10^{-11}	Motor Trip	OK	Red light OK
IC-5	Responds	Calibration	S+R.	Alarm OK
IC-4	Responds	Calibration	S+R.	Press diff. 0.15"
CRM	Meter Trip			

Expt 142 40 x 44 x 16" stack (see Expt 140)
 19 foils - 270 V in paraffin.
 8:42 start time at 22 on IC-3
 $b=1$ at 60 on IC-3
 9:02 shut down.

Expt 143 40 x 44 x 16" stack same as above.
 19 foils - 270 V in paraffin
 11:12, 35 sec start time at 22 on IC-3
 $b=1$ at 70 on IC-3
 11:22, 35 sec shut down

Expt 144 See page 40 for figure
 V^{238} is painted with red glyptol

$$\text{Ch \#1; } V^{238}, \text{ top pos.} = 6125/30 \text{ min} \quad 1214.861$$

$$\text{Ch \#2; } V^{235}, \text{ bottom} = 7441,025/30 \text{ min}$$

$$\text{Expt 145 Ch \#1, } V^{235}, \text{ bottom} = 7429,665/30 \text{ min} \quad 1205.136$$

$$\text{Ch \#2, } V^{238}, \text{ top} = 6165/30 \text{ min}$$

$$\text{Expt 146 Ch \#1, } V^{235}, \text{ top} = 7,402,525/30 \text{ min} \quad 1183.457$$

$$\text{Ch \#2, } V^{238}, \text{ bottom} = 6255/30 \text{ min}$$

$$\text{Expt 147 Ch \#1, } V^{238}, \text{ bottom} = 6365/30 \text{ min} \quad 1179.388$$

$$\text{Ch \#2, } V^{235}, \text{ top} = 7,506,805/30 \text{ min}$$

$$\text{avg} \quad 1195.710$$

$$V^{235} \text{ detector - } \text{No. 5-3, } 97.34\% V^{235}, .3379 \text{ mg } V^{235}$$

$$V^{238} \text{ detector - } \text{No. 8-2, } \sim 7 \text{ ppm of } V^{235}, .3889 \text{ mg } V$$

Instrument Check on 12-9-65 Source 10mcY

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	7.3×10^{-4}	Water Trip	OK	OK
IC-2	7.3×10^{-4}	Water Trip	OK	Red light OK
IC-3	Responds		S/P.R.	alarm OK
IC-4	Responds		S/P.R.	Press dif 0.15"
IC-5		Water Trip		

See page 40

Expt 144 Have restacked stack E $24 \times 26 \times 25 \frac{3}{4}$ "
 with a $\frac{1}{4}$ " V^{235} fission Ch and a $\frac{1}{4}$ " V^{238}
 fission Ch in center of stack separated vertically by 2".
 Counting channel #1 - Amp Y-140347, scaler Y120248, Preamp 696
 Counting Ch. #2 - Amp Y102541, scaler Y120242, Preamp 694
 Counting Ch's adjusted to have same sensitivity to fission pulses.

Tables together. $k = 1$ Power = 5 on IC-3; 0.77×10^{-7} on IC-2

Expt 145 tables together

$k = 1$ Power = 5 on IC-3, 0.77×10^{-7} on IC-2


Expt 146 tables together

$k = 1$ Power = 5 on IC-3, 0.77×10^{-8} on IC-2

Expt 147 tables together

$k = 1$ Power = 5 on IC-3, 0.77×10^{-8} on IC-2

Exp 149 $24 \times 26 \times 26''$ stack + $\frac{1}{4}'' \times 8'' \times 26''$ across center of top.



$$\begin{aligned} \text{Ch \#1, } V^{238}, \text{ top pro.} &= 4565 / 30 \text{ min} & 15.54.610 \\ \text{Ch \#2, } V^{235}, \text{ bottom} &= 7,096,795 / 30 \text{ min} \end{aligned}$$

$$\begin{aligned} \text{Exp 150 Ch \#1, } V^{235}, \text{ bottom} &= 7,150,975 / 30 \text{ min} & 1700.589 \\ \text{Ch \#2, } V^{238}, \text{ top pro} &= 4205 / 30 \text{ min} \end{aligned}$$

$$\begin{aligned} \text{Exp 151 Ch \#1, } V^{235}, \text{ top} &= 7,649,085 / 30 \text{ min} & 1639.675 \\ \text{Ch \#2, } V^{238}, \text{ bottom} &= 4665 / 30 \text{ min} \end{aligned}$$

$$\begin{aligned} \text{Exp 152 Ch \#1, } V^{238}, \text{ bottom} &= 4695 / 30 \text{ min} & 1664.642 \\ \text{Ch \#2, } V^{235}, \text{ top} &= 7,815,495 / 30 \text{ min} \end{aligned}$$

$$\text{avg } 1639.879$$

Instrument Check on 12-10-65 Source 10 mC/K

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Red light	OK
IC-3	Responds	Calibration	S.P.O.	Alarm	OK
IC-4	Responds	Calibration	S.P.O.	Pres. dif	0.15"
CRM		Meter Trip			

Since the ratio of 235:238 counts is considerably larger than expected we have placed 2 parallel plate detectors fabricated at ORNL in stack and will check ratio. Det. identification - FC-7, ^{5.0}mg of U ^{4-6 ppm U²³⁵} 99.97%
 FC-10 5.0mg of U ^{U²³⁵} 99.9%

Ampl. and pre-amps same as in Expts. 144-147

Expt. 148 Tables Together, $b=1$, power ~ 0.6 on IC-3
 Check counters. Ch #2 pulse is ragged.

Expt. 149 Have replaced amp. in Ch #2 now using Y-140346
 Tables together

$b=1$ Power = 0.5 on IC-3 and 0.78×10^{-9} on IC-2

Expt. 150 Tables together

$b=1$ Power = 0.55 on IC-3 and $\sim 0.78 \times 10^{-9}$ on IC-2

Expt. 151 tables together

$b=1$ Power \sim same as above.

Expt. 152 same as above.

FM-1 Low Trip OK Hi OK
 FM-2 _____
 IC-1 3×10^{-11} OK OK
 IC-2 3×10^{-11} OK
 IC-3 Response OK Red light OK
 IC-4 Response OK Alarm OK
 CRM _____ Press Dif. 0.07


Expr time Purpose check stack (24x26x25 2% U_{F4} & Paraffin)
 153 9¹⁵ for Reactivity AND Alignment
 9³⁵ tables together w/Plexygles 24"x19"^{3/8} R>1 w/Plexyg
 10⁰⁶ separate tables p<<1 without Plexi.
 10²⁵ fuel stack 24x26x25.5" U_{F4} AND Paraffin
 cond table sep Plexyglass
 R>1 1.8 Rev with
 R<1 0.0 Removed
 11⁰⁰ Shut Down

Expr

Expr

154

Expr 154
 Movable table



V21 F7

H/X = 614

Instrument Check on 1-3-66 Source

85

PM-1	Low Trip	OK	Hi Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	3×10^{-11}	Meter Trip	OK	Fast Trip	OK
IC-2	3×10^{-11}	Meter Trip	OK	2" Away	
IC-3	Response OK	Calibration		Red light	OK
IC-4	Response OK	Calibration		Alarm	OK
CRM		Meter Trip		Press D.F. 15"	

see p. 97

Barritt)
 #153 Purpose: Check Counters

Instrument Check on 4-5-66 Source

PM-1	Low Trip	OK	Hi Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	3×10^{-11}	Meter Trip	OK	Fast Trip	OK
IC-2	3×10^{-11}	Meter Trip	OK		
IC-3	Response	Calibration	S.G.R	Red light	OK
IC-4	Response	Calibration	S.G.R	Alarm	OK
CRM		Meter Trip		Press. D.F. 07"	

(W.F.H.)
 Purpose: Check stack for Reactivity $24 \times 26 = 25.75$ (for Pulsing)

Expr time	Cond.	table Sep	Plexyglass
154 9 ⁴⁰	$R < 1$	0.0	5'x5" with
10 ⁰⁴			Separate tables to 16" (Add 1/4" to half of stack)
10 ¹⁶	$R < 1$	0.0	with
10 ⁵⁰			Separate Add ^{fuel} to make 2/3 of stack 26" High
11 ⁰⁰	$R > 1$	0.0	without
11 ²⁰			Separate - Remove 2 1/4 x 4 x 4 Pcs from spaces marked X
11 ²⁴	$R > 1$	0.0	w/o
11 ³³			Separate - Remove 2 1/4 x 4 x 4" from spaces marked X
11 ³⁸	$R = 1$	0.0	Adjust with Plexy glass Shim
3 ⁴⁰			Shut Down

PM-1	Low Trip	OK	Hi	Alarm Trip	OK
PM-2					
IC-1	3×10^{-11}	Meter Trip	OK	Test Trip	OK
IC-2	5×10^{-11}	Meter Trip	OK		
IC-3	Response OK	Calibration		Red light	OK
IC-4	Response OK	Calibration		Bldg Alarm	OK
CRM		Meter Trip		Press Dif.	0.07"

Purpose: Pulse at Crit (UF₆ 3% stack) 24x26x26" ;

Less 1/4" Removed from spaces marked X

X	X					X	X	X	X

Exi

15.

Expr time on movable table

155 9¹⁰ AM COND table Sepr. Plexiglass Shim

R > 1 0.0 out

9²⁴ Separate tables 30 Rev to Adjust fuel 2 pos 1/4x2x2 Remove

check) 9³⁰ K=1 0.0 With shim out

crit) 12⁰⁰ K=1 0.0

" 2¹⁵ K < 1 ~ -0.008 0.0 Adjust shim to make R=1


" 3⁵⁸ K < 1 ~ -0.054 0.0


4¹⁹ Shut Down

Pulsing data: Chwidth = 70 msec ; Bratio = 4 ; Delay ratio = 2

Burstwidth = 450 msec ; Rate = 35 CPS. ; 135 KV. ; Avg Beam I = 1 μA

meas. λ_c from computer fit = -137.16 ± 55 sec⁻¹





measured
 (61.255 x 66.587 x 66.347 cm)
 24 x 26 x 26 Less 1/4" Removed from 5 Places Marked X

V21 F4

PM-1	Low Trip	OK	Hi Alarm Trip	OK		
PM-2			Alarm Trip			
IC-1	3×10^{-11}	Meter Trip	OK	Fast Trip	OK	
IC-2	3×10^{-11}	Meter Trip	OK			
IC-3	Response	OK	Calibration	S.G.R.	Red light	✓
IC-4	Response	✓	Calibration	S.G.R.	Alarm	✓
CRM		Meter Trip			Press Dif	0.07"

Purpose: Revup of Exp # 155 (No change in stack)

Expr time	COND	table	sepr.	Plexyglass Shim
-----------	------	-------	-------	-----------------

156 8³⁰ K < 1 0.0 out

8⁵⁰ K < 1 0.0 with

lower Power to Add fuel 1 Pc (1/4 x 4 x 4).

24 x 26 x 26 less 1/4" Removed from spaces marked X

9⁵⁰ K < 1 0.0 with

Add 2 Pcs (1/4 x 4 x 4) 24 x 26 x 26 Less

9²⁰ 1/4" Removed from spaces marked X

K < 1 0.0 with

Added 1 Pc 1/4 x 4 x 4 2 Pc 1/4 x 2 x 2

9⁴⁰ K < 1 0.0 with

9⁵⁵ Added 4 Pcs (1/4 x 2 x 2)

10¹⁵ K = 1 0.0 Adjust with shim

10²⁸ start Pulsing -8 Rev to 0

12⁴⁵ K < 1 (6.113) 0.0 Adjust with shim to make slightly pos

4¹⁹ check Critical ~~to~~ b < 1 (-0.164)

4³⁵ Shut down

Pulsing data: Ch width = 80 μsec; B_y ratio = 4; Delay ratio = 2

Burst width = 450 μsec; Rate = 35 cps; 135 KV; Avg Beam I = 1 Amp

Mean dc from computer fit = -139.93 ± 0.32 sec⁻¹

88

See p. 250 for continuation of 270 Effo's

Instrument Check on 12-15-65 Source 10mCK

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	3×10^{-4}	Meter Trip	OK	Fast Trip	OK
IC-2	3×10^{-4}	Meter Trip	OK	Red light	OK
IC-3	Responds	Calibration	S/R	alarm	OK
IC-4	Responds	Calibration	S/R	Pres. dif	0.15"
CRM		Meter Trip			

Expt. 1 Purpose - to determine dimensions of critical cube.

Stack $24 \times 24 \times 12$ half on each table

$b \ll 1$

Expt. 2 Stack $24 \times 24 \times 20$

$b > 1$ table separ. $\sim 2.5"$

Expt. 3 Stack $22 \times 22 \times 20$

$b > 1$ table separ. $\sim 1.5"$

Instrument Check on 12-16-65 Source 10 mCr

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	7.3×10^{-4}	Meter Trip	OK	Ext. Trip	OK
IC-2	7.3×10^{-4}	Meter Trip	OK	Red light	OK
IC-3	Responds	Calibration	S/O	alarm	OK
IC-4	Responds	Calibration	S/O	Pre. dif	0.15"
CRM		Meter Trip			

Expt 4 Stack 20x20x20
 $k > 1$ Table span ~ .5"
 $k = 1$ Table span .53"

Expt 5 Stack 20x20x19" high
 $k > 1$ Table span ~ 5 rev.
 $k = 1$ Table span 5.9 rev.

Exps 8, 9, + 10 to meas. subcritical multiplication
and B_g .

Exp 8 $19 \times 20 \times 18 \frac{3}{4}$ " high
 $b < 1$ -13.662ϕ from $\log N$
 $B_g = 2 \times 10^{-12}$ on IC-2, 1×10^{-12} on IC-1, 0.0016 on IC-3, 0.0018 on IC-4

Exp 9
 $b < 1$ -1.776ϕ from $\log N$
 $B_g = 1.6 \times 10^{-11}$ on IC-2, 0.5×10^{-11} on IC-1, 0.01 on IC-3, 0.01 on IC-4

Exp 10

$b < 1$ Table separation = 0.8 rev.
 $B_g = 3.15 \times 10^{-11}$ on IC-2, 0.95×10^{-11} on IC-1, 0.021 on IC-3, 0.016 on IC-4

Instrument Check on 12-17-65 Source 10mcY

PM-1	Low Trip	OK 2"	Alarm Trip	OK	Contact
PM-2			Alarm Trip		
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Contact	Fast Trip
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK 2"	Red light	OK
IC-3	Responds	Calibration	S/R	alarm	OK
IC-4	Responds	Calibration	S/R	Pro dip	0.15"
CRM		Meter Trip			

Expt 6 Stack 19x19x19" high

b < 1 Tables together + plexiglass

Expt 7 Stack 19x19x20" high

b > 1 Tables together no plexiglass $L_N = 42.778 \text{ sec}$
= 18.1764

Expt 8 Stack 19x20x18 3/4" high

b < 1 Tables together no plexiglass
10x19" base on which table

Expt 9 Stack 19x20x18 3/4" high

b < 1 Tables together no plexiglass + 1/4x4x16" on center of top

Expt 10 Stack Same as Expt 9 + 4 - 1/4x4x4 pins

~ in middle of 4 quadrants

b > 1 Tables together

b ≈ 1 table separ = 0.7 rev.

19 x 20 x 18 3/4" high

370 J

97

Instrument Check on 1-3-66 Source 10m cK

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	73 x 10"	Meter Trip	OK	Fast Trip	OK
IC-2	73 x 10"	Meter Trip	OK	Red light	OK
IC-3	Response	Calibration	1/2 R.	alarm	OK
IC-4	Response	Calibration	1/2 R.	Press Dif.	0.15"
CRM		Meter Trip			

Expt. 11 th Check instruments and adj. proc. to get same c. rate.

b = 1 with pleiglass, table separ. = 2.9 rev.

Check count rates on 4 counters
shut down to move counter

b = 1 table separ. = 2.9 rev. with pleiglass.

after checking reflector worth in Expt 13., decided to only open table on screw (min. of 25 rev.) while making perturbation change

Expt 14 $19 \times 20 \times 18\frac{3}{4} + \frac{1}{4}$ on N half of stack
 $b > 1$ V3-14 (5 sec) 20 4 counters ganged.
 $L_N = 151.786 \rightarrow 7.054\phi$ TMC = 153.763 \rightarrow 6.978 ϕ

Expt 15 $19 \times 20 \times 19$ "
 $b > 1$ V3-15 (1 sec) 10
 $L_N = 31.703 \rightarrow 21.938\phi$ TMC = 31.850 \rightarrow 21.876 ϕ

Expt 16 $19 \times 20 \times 19$ "
 $b > 1$ V3-16 (1 sec)
 $L_N = 30.401 \rightarrow 22.498\phi$ TMC = 31.065 \rightarrow 22.208 ϕ

Expt 17 $19 \times 20 \times 18\frac{3}{4}$ "
 $b < 1$ V3-17 (5 sec)
 $L_N = -225.833 \rightarrow -7.006\phi$ TMC = -229.071 \rightarrow -6.883 ϕ

Expt 18 $19 \times 20 \times 18\frac{3}{4} + \frac{1}{4}$ on S $\frac{1}{2}$ of stack
 $b > 1$ V3-18 (5 sec)
 $L_N = 137.671 \rightarrow 7.647\phi$ TMC = 139.224 \rightarrow 7.578 ϕ

Expt 19 $19 \times 20 \times 18\frac{3}{4}$
 $b < 1$ V3-19 (5 sec)
 $L_N = -218.667 \rightarrow -7.294\phi$ TMC = -223.175 \rightarrow -7.110 ϕ


Expt 20 $19 \times 20 \times 18\frac{3}{4} + \frac{1}{4}$ on S $\frac{1}{2}$ of stack
 $b > 1$ V3-20 (5 sec)
 $L_N = 150.048 \rightarrow 7.122\phi$ TMC = 152.170 \rightarrow 7.039 ϕ

~ 70° F night before Warmed up to 74° to 75° F during day
 Instrument Check on 1-4-66 Source
 U3) F₄ $\frac{H}{X} = 279$


PM-1 Low Trip OK Hi Alarm Trip OK
 PM-2 Alarm Trip
 IC-1 3x10" Meter Trip OK Fast Trip OK
 IC-2 3x10" Meter Trip OK
 IC-3 Response Calibration S & R Red light OK
 IC-4 Response Calibration S & R Alarm OK
 CRM Meter Trip Press Diff 0.15"


19x20x19" high

Expt 12 $b=1$ Table separ ~ 4.2 rev. with plexi. Check counter.


$b>1$ Table Together no plexi. $\frac{1}{2} + \frac{1}{4} + \frac{1}{4}$ 


Expt 13 $b=1$ Table separ ~ 4.95 rev. with 6x12x16" poly on breads.
 To check reflector width of man working on bread.


Expt 14 19x20x18 $\frac{3}{4}$ " + $\frac{1}{4}$ on half of stack. $b>1$ Table Together no plexi.
 1" piece $\frac{1}{2} + \frac{1}{4}$ pieces 


Expt 15 19x20x19" $b>1$ Table Together
 1" piece $\frac{1}{2} + \frac{1}{4} + \frac{1}{4}$ 

Expt 16 19x20x19" ~~table~~ Top in. all 1" thick pieces.
 12:04 $b>1$ Table Together

Expt 17 19x20x18 $\frac{3}{4}$ " $b<1$ Table Together 

Expt 18 19x20x18 $\frac{3}{4}$ " + $\frac{1}{4}$ on 5 $\frac{1}{2}$ $b>1$ Table Together
 3:05 $\frac{1}{2}$ in. $\frac{1}{4} + \frac{1}{2}$  19" high

Expt 19 19x20x18 $\frac{3}{4}$ " $b<1$ Table Together 

Expt 20 19x20x18 $\frac{3}{4}$ " + $\frac{1}{4}$ on 5 $\frac{1}{2}$ $b>1$ Table Together
 4:11  Same as Expt 18

Expt 22 ~~U3-22A (5 sec)~~ To obtain data to check Computer code and Td

U3-22A (1 sec)

Removed
2-1/2 x 4 x 4 piece
from N 1/2

U3-22B (5 sec)

U3-22C (5 sec)

U3-22D (5 sec)

U3-22E (5 sec)

U3-22F (1 sec)

Expt 23 19 x 20 x 18 3/4" + 1/4" on S 1/2

b > | U3-23 (5 sec)

$L_N = 231.261 \rightarrow 4.9164$
 $TMC = 232.686 \rightarrow 4.8894$

Expt 24 19 x 20 x 18 3/4

b < | U3-24 (5 sec)

$L_N = -178.929 \rightarrow -9.4704$ $TMC = -179.874 \rightarrow -9.4034$

Expt 25 19 x 20 x 18 3/4 + 1/4" on S 1/2

b > | U3-25 (5 sec)

$L_N = 237.776 \rightarrow 4.7974$ $TMC = 243.074 \rightarrow 4.7044$

Expt 26 19 x 20 x 18 3/4

b < | U3-26 (5 sec)

$L_N = -174.260 \rightarrow -9.8194$ $TMC = -177.465 \rightarrow -9.5774$

Stack U3-A
 19 x 20 x 18 3/4" high

Mens $\left(\begin{array}{l} 48.590 \times 51.145 \times 47.932 \text{ cm} \\ 19.130 \times 20.136 \times 18.811 \text{ in.} \end{array} \right)$

74°F night before 75°F during day
 UG) F₁ $\frac{H}{X} = 279$ Instrument Check on 1-5-66 Source 10 mCt

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	Redlight OK
IC-3	Responds	Calibration	S/O	alarm OK
IC-4	Responds	Calibration	S/O	Pres. Dif 0.15"
CRM		Meter Trip		

Expt 21 19x20x18 $\frac{3}{4}$ " + $\frac{1}{4}$ " on $5 \frac{1}{2}$

Check ~~Count~~ Counter + Bq.

This stack was subcritical by ~ 13.5 & today.

Tightened and straightened stack as much as possible and made stack ~ 4.0 & positive.

Expt 22 19x20x18 $\frac{3}{4}$ " + $\frac{1}{4}$ " on $5 \frac{1}{2}$ and $\frac{1}{4}$ " x 8x8 in center of $N \frac{1}{2}$
 10:45 b > 1 Tables Together Bladed area 19" high →

Expt 23 19x20x18 $\frac{3}{4}$ " + $\frac{1}{4}$ " on $5 \frac{1}{2}$
 1:23 b > 1 Table Together

Expt 24 19x20x18 $\frac{3}{4}$ " V3-A
 b < 1

Expt 25 19x20x18 $\frac{3}{4}$ " + $\frac{1}{4}$ " on $5 \frac{1}{2}$ V3-B
 b > 1

Expt 26 19x20x18 $\frac{3}{4}$ " V3-A
 b < 1

← Lane
 as 18

Expn 27 $19 \times 20 \times 18 \frac{3}{4}$ high
 $b < 1$ V3-27 (5 sec) $L_N = -194.346 \rightarrow -8.4839$
 $TMC = -197.308 \rightarrow -8.3174$

Expn 28 $19 \times 20 \times 18 \frac{3}{4}$ + $\frac{1}{4}$ on $S \frac{1}{2}$
 $b > 1$ V3-28 (5 sec) $L_N = 166.117 \rightarrow 6.5394$
 $TMC = 167.383 \rightarrow 6.4974$

Expn 29 $19 \times 20 \times 18 \frac{3}{4}$
 $b < 1$ V3-29 (5 sec) $L_N = -202.489 \rightarrow -8.042$
 $TMC = -204.590 \rightarrow -7.936$

Expn 30 $19 \times 20 \times 18 \frac{3}{4}$ + $\frac{1}{4}$ on $S \frac{1}{2}$
 $b > 1$ V3-30 (5 sec) $L_N = 162.426 \rightarrow 6.664$
 $TMC = 164.144 \rightarrow 6.605$

Expn 31 $19 \times 20 \times 18 \frac{3}{4}$
 $b < 1$ V3-31 (5 sec) $L_N = -200.861 \rightarrow -8.126$
 $TMC = -205.089 \rightarrow -7.912$

Expn 32 $19 \times 20 \times 18 \frac{3}{4}$ + $\frac{1}{4}$ on $S \frac{1}{2}$
 $b > 1$ V3-32 (5 sec) $L_N = 168.940 \rightarrow 6.4464$
 $TMC = 171.740 \rightarrow 6.3584$

Expn 33 $19 \times 20 \times 18 \frac{3}{4}$
 $b < 1$ V3-33 (5 sec) $L_N = -197.603 \rightarrow -8.3004$
 $TMC = -200.622 \rightarrow -8.1394$

Expn 34 $19 \times 20 \times 18 \frac{3}{4}$ + $\frac{1}{4}$ on $S \frac{1}{2}$
 $b > 1$ V3-34 (5 sec) $L_N = 175.455 \rightarrow 6.242$
 $TMC = 178.939 \rightarrow 6.139$

Expn 35 $19 \times 20 \times 18 \frac{3}{4}$
 $b < 1$ V3-35 (5 sec) $L_N = -201.404 \rightarrow -8.098$
 $TMC = -206.824 \rightarrow -7.826$ \downarrow From TMC

Only worth $\frac{1}{4}$ of fuel on $\frac{1}{2}$ of 19×20 that from Expn 23-35 = 14.378 ± 0.2224

75°-76° F

U(3) F₄

#X = 279

103

Instrument Check on 1-6-66 Source 10 mcK

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Red light	OK
IC-3	Responds	Calibration	S.P.	alarm	OK
IC-4	Responds	Calibration	S.P.	Press dif	0.15"
CRM		Meter Trip			

Exp 27 19x20x18^{3/4}" high

b=1 table top = with piping check counters.

b<1 tables together no piping

Exp 28 19x20x18^{3/4}" + 1/4" on 5 1/2

b>1 tables together

Exp 29 19x20x18^{3/4}"

b<1 tables together

Exp 30 19x20x18^{3/4}" + 1/4" on 5 1/2

b>1

Exp 31 19x20x18^{3/4}"

b<1

Exp 32 19x20x18^{3/4}" + 1/4" on 5 1/2

b>1

Exp 33 19x20x18^{3/4}"

b<1

Exp 34 19x20x18^{3/4}" + 1/4" on 5 1/2

b>1

Exp 35 19x20x18^{3/4}"

b<1

TMC

Expt 36 $19 \times 20 \times 18 \frac{3}{4}$ "
 $b < 1$ U3-36 (5 sec) $L_N = -144.185 \rightarrow -12.949 \text{¢}$
 $TMC = -146.982 \rightarrow -12.568 \text{¢}$

Expt 37 $19 \times 20 \times 18 \frac{3}{4}$ " plus al holes and steel plate on top.
 $b > 1$ U3-37 (5 sec) $L_N = 181.100 \rightarrow 6.077 \text{¢}$
 $TMC = -180.984 \rightarrow 6.080 \text{¢}$

Expt 38 $19 \times 20 \times 18 \frac{3}{4}$ "
 $b < 1$ U3-38 (5 sec) $L_N = -144.403 \rightarrow -12.923 \text{¢}$
 $TMC = -144.936 \rightarrow -12.845 \text{¢}$

Expt 39 $19 \times 20 \times 18 \frac{3}{4}$ " plus al holes and steel plate on top.
 $b > 1$ U3-39 (5 sec) $L_N = 183.489 \rightarrow 6.009 \text{¢}$
 $TMC = 184.316 \rightarrow 5.986 \text{¢}$

Expt 40 $19 \times 20 \times 18 \frac{3}{4}$ "
 $b < 1$ U3-40 (5 sec) $L_N = -138.974 \rightarrow -13.731 \text{¢}$
 $TMC = -143.956 \rightarrow -12.981 \text{¢}$

From TMC

Avg. Worth of support thrust on 19×20 stack = $18.843 \pm 0.123 \text{¢}$

U(3) F4

H/x = 279

Instrument Check on 1-7-66 Source 10 mct

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	3×10^{-4}	Meter Trip	OK	Fast Trip	OK
IC-2	2.3×10^{-4}	Meter Trip	OK		
IC-3	Responds	Calibration	A/O.	Red light	OK
IC-4	Responds	Calibration	A/O.	Alarm	OK
CRM		Meter Trip		Press dif.	0.15"

Expt 36 $19 \times 20 \times 18 \frac{3}{4}$ "

~ 11:20 AM b < 1



Expt 37 $19 \times 20 \times 18 \frac{3}{4}$ " plus al boxes and steel plate on top.

1:40 PM b > 1

Expt 38 $19 \times 20 \times 18 \frac{3}{4}$ "

b < 1

Expt 39 $19 \times 20 \times 18 \frac{3}{4}$ " plus al boxes and steel plate on top

b > 1

Expt 40 $19 \times 20 \times 18 \frac{3}{4}$ "

b < 1


37:U

Instrument Check on 1-10-66 Source 10 mcr


107


PM-1	Low Trip	OK	Hi Trip	OK	
PM-2			Alarm Trip		
IC-1	3×10^{-11}	Water Trip	OK	Fast Trip	OK
IC-2	3×10^{-11}	Water Trip	OK		
IC-3	Response	Calibration		Red light	OK
IC-4	Response	Calibration		Alarm	OK
CRM		Water Trip		Press Dif	.15"


To ~~check~~ measure subcritical background,

Expr # 41 19x20x18³/₄ plus 2 - 1/4 x 4 x 4 pieces on top 


b=1 with Plexiglas Check counters at ~ 1 on IC-3.

b < 1 no Plexiglas Tables Together $L/N = -0.709\phi$ 

Expr 42 19x21x20" high with 1" of foam glass in center 


b << 1 Tables Together 

Expt 43



1" foam glass
 (1" x 23 5/8" x 18" high)
 Note foam glass 3/8" narrow on one edge.

Expt 47



(1 x ~ 25 5/8" x 18") foam glass.


Expt
 Expt
 Expt
 Expt
 Expt
 Expt

UCI F₁ H/K = 77

PM-1	Low Trip	OK	Hi Trip	OK
PM-2				
IC-1	3×10^{-11}	OK		OK
IC-2	3×10^{-11}	OK		
IC-3	Response	SfR.		Red light OK
IC-4	Response	SfR.		Bldg Alarm OK
CRS				Press Dif. 0.15


- Expt 43 $b < 1$ with plexiglass $24 \times 25 \times 16$ " high with 1" foam glass in center
- Expt 44 $b > 1$ $24 \times 25 \times 18$ " high with 1" foam glass in center
 Table separ. = 2 revs no plexiglass
- 45 $24 \times 25 \times 17\frac{3}{4}$ " high + $\frac{1}{4} \times 12 \times 24$ on south $\frac{1}{2}$ foam glass in center
 $b > 1$ Table separ. = 0.9 rev. no plexiglass
- Expt 46 $24 \times 25 \times 17\frac{3}{4}$ " with 1" foam glass in center.
 $b > 1$ Table together no plexiglass $L_N = 9.413\phi$
- Expt 47 $24 \times 25 \times 17\frac{3}{4}$ " Same as 46 except added $1 \times 2 \times 18$ "
 $b > 1$ $L_N = 9.289\phi$ piece of foam glass on edge that was ^{short} 1" foam glass in center
- Expt 48 $24 \times 25 \times 17\frac{1}{2}$ " high + $\frac{1}{4} \times 12 \times 24$ on south $\frac{1}{2}$ foam glass in center
 $b < 1$ $L_N = -11.181\phi$
- Expt 49 $24 \times 25 \times 17\frac{3}{4}$ " high Same as Expt 47.
 $b > 1$ Table together no plexiglass $L_N = 9.462\phi$
 $b = 1$ Table separation = 1.48 rev.
- Expt 50 Same as Expt 49 except there is no foam glass.
 $b = 1$ Table separation = 9.95 rev.

Expt 51



← 2" of foam glass. Strips up above to ~3"

Expt 55+56



← 3" of foam glass.

56.119 cm high

Red figures meas. with meter stick.

Instrument Check on 1-12-66 Source 10 mCr

PM-1	Low Trip	OK	Hi Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	3×10^{-4}	Meter Trip	OK	Fast Trip	OK
IC-2	3×10^{-4}	Meter Trip	OK	Red light	OK
IC-3	Responds	Calibration	S/R	Alarm	OK
IC-4	Responds	Calibration	S/R	Pres Dif.	0.15
CRM		Meter Trip			

Expr 51 24 x 26 x 20" high with 2" of foam glass in center
 $b > 1$ Tables together no plexiglass $L_N = 7.789 \phi$

Expr 52 24 x 26 x 20" high less 1/4" on N 1/2
 $b < 1$ Tables together no plexiglass $L_N = -5.123 \phi$

Expr 53 Same as Expr 52 except foam glass was removed
 $b = 1$ Table separation 12.00 rev.

Expr 54 To check amount of material that may be stacked on one table

24 x 26 x 12" high all green blocks.
 + 6" x 22" x 12" polyethylene on one end and 1" x 13" x 15" plexiglass shim on other

$b < 1$ tables together

Expr 55 24 x 27 x 22" high with 3" of foam glass in center.

$b \approx 1$ tables together no plexiglass $L_N = 0.276 \phi$

$b = 1$ Table separation = 0.7 Rev

Expr 56 Same as Expr 55 except foam glass was removed

$b = 1$ Table separation = 14.78

73.5°F night before to 74°F during day
 Instrument Check on 1-13-66 Source 10mct
 U31F4 $1/x = 279$ 113

PM-1	Low Trip	Alarm Trip	OK
PM-2		Alarm Trip	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK
		Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK
		Red light	OK
IC-3	Responds	Calibration	S/O
		alarm	OK
IC-4	Responds	Calibration	S/O
		Press Dif	0.15"
CRM	Meter Trip		

Expt 57 16 x 16 x 30" high + 6" x 16" x 30" of polyethylene on N face
 K > 1 Tables together with ^{1 x 13 x 15"} plexiglass on S face
 K < 1 Table together no plexiglass

Expt 58 16 x 16 x 36" high
 K < 1 Tables together with plexiglass

Expt 59 16 x 16 x 40" high
 K < 1 Tables together with plexiglass

Expt 60 16 x 16 x 44" high
 K < 1

Expt 61 16 x 16 x 45" High tables together with Plexiglass
 K < 1 Plexiglass Removed

Expt 62 16 x 16 x 46" High tables together with Plexiglass
 K < 1 Plexiglass Removed
 $L_N = -340.269 \rightarrow -4.316 \text{ f}$

PM-1	Low Trip <u>OK 1"</u>	Hi <u>Alarm Trip OK Contact</u>
PM-2		<u>Alarm Trip</u>
IC-1	<u>3 x 10⁻¹¹</u>	<u>Meter Trip OK Contact Fast Trip OK Contact</u>
IC-2	<u>3 x 10⁻¹¹</u>	<u>Meter Trip OK @ 2"</u>
IC-3	<u>Response Calibration S.G.R</u>	<u>Red light OK</u>
IC-4	<u>Response Calibration S.G.R</u>	<u>Alarm OK</u>
CRM	<u>Meter Trip</u>	<u>Press Dif at 0.15"</u>

3% V_F

Expr. 63 16 x 16 x 47 = tables together ✓

K > 1 L_N = 293.148 → 3.9874

Expr 64 Separate tables AND Re-Run # 63

K > 1 L_N = 276.428 → 4.1964

Expr 65 Separate tables AND Re-Run # 63

K > 1 L_N = 273.605 → 4.2344

11 66 Separate tables AND Re-Run # 63

K > 1 L_N = 275.776 → 4.2054

Expt 68 16x16x47" high

 $b > 1$

V3-68 (1 sec)

$$L_N = 67.533 \rightarrow 13.279 \phi$$

$$TMC = 69.011 \rightarrow 13.072 \phi$$

Expt 69 16x16x46" + 1" on N half

 $b > 1$

V3-69 (1 sec)

$$L_N = 134.631 \rightarrow 7.789 \phi$$

$$TMC = 136.655 \rightarrow 7.694 \phi$$

Expt 70 16x16x46" high

 $b > 1$

V3-70 (1 sec)

$$L_N = 310.520 \rightarrow 3.778 \phi$$

$$TMC = 314.923 \rightarrow 3.731 \phi$$

Expt 71 16x16x45" high

 $b < 1$

V3-71 (1 sec)

$$L_N = -234.518 \rightarrow -6.682 \phi$$

$$TMC = -233.811 \rightarrow -6.712 \phi$$

Expt 72 16x16x46" high

 $b > 1$

V3-72 (1 sec)

$$L_N = 317.686 \rightarrow 3.702 \phi$$

$$TMC = 322.621 \rightarrow 3.650 \phi$$

Expt 73 16x16x45" high

 $b < 1$

V3-73 (1 sec)

$$L_N = -237.124 \rightarrow -6.598 \phi$$

$$TMC = -243.908 \rightarrow -6.374 \phi$$

Expt 74 16x16x46" high

 $b > 1$

V3-74 (1 sec)

$$L_N = 318.337 \rightarrow 3.695 \phi$$

$$TMC = 324.663 \rightarrow 3.679 \phi$$

74°F early evening night before
 74.7 during day

Instrument Check on 2-1-66 Source 10 mCr

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	Redlight OK
IC-3	Responds	Calibration	S/O	alarm OK
IC-4	Responds	Calibration	S/O	Press Dif 0.08"
CRM		Meter Trip		

Expt 67 16x16x47" high To check counter position
 $b = 1$ Table sep. = 2.25 cm. no plexiglass

Expt 68 16x16x47" high
 $b > 1$ Table together no plexiglass

Expt 69 16x16x46" + 1" on north half.
 $b > 1$

Expt 70 16x16x46" V3-D Table together no plexiglass
 $b > 1$

Expt 71 16x16x45" high V3-C
 $b < 1$ Table together no plexiglass

Expt 72 16x16x46" high V3-D $b > 1$

Expt 73 16x16x45" high V3-C
 $b < 1$ Table together no plexiglass

Expt 74 16x16x46" high
 $b > 1$ Table together no plexiglass

Perturbation mess on tall stack V(3) F4

74.5°F night before to 72° during day.

Instrument Check on 2-2-66 Source 10mCv

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Redlight	OK
IC-3	Responds	Calibration	N/A	Alarm	OK
IC-4	Responds	Calibration	N/A	Probe dist	0.08"
CRM		Meter Trip			

Expt 75 16x16x46" high
 $b=1$ Table sep. = 1.23 cm, no Plexiglas, check counter
 $b > 1$ Table together no Plexiglas
 U3-75 (1 sec) $L_N = 411.493 \rightarrow 2.921 \phi$
 $TMC = 421.174 \rightarrow 2.858 \phi$

Expt 76 ^{V3-6} 16x16x45" high (mass 40.900 cm x 40.934 cm x 114.667 cm)
 (dim. 16.102 cm x 16.116 cm x 45.145 cm)
 $b < 1$ Table together no Plexiglas
 U3-76 (1 sec) $L_N = -211.718 \rightarrow -7.597 \phi$
 $TMC = -218.037 \rightarrow -7.320 \phi$

Expt 77 ^{V3-D} 16x16x46" high (mass 40.900 x 40.934 x 111.218)
 (dim. 16.102 cm x 16.116 cm x 46.149 cm)
 $b > 1$ Table together no Plexiglas
 U3-77 (1 sec) $L_N = 424.522 \rightarrow 2.837 \phi$
 $TMC = 435.272 \rightarrow 2.773 \phi$

Exp 78

16x16x45" high

b < 1 Table together no plexiglass

U3-78 (1 sec)

$$\ln N = -216.604 \rightarrow -7.381 \phi$$

$$TMC = -214.244 \rightarrow -7.484 \phi$$

Exp 79

16x16x46" high

b > 1 Table together no plexiglass

U3-79 (1 sec)

$$\ln N = 445.151 \rightarrow 2.715 \phi$$

$$TMC = 437.281 \rightarrow 2.761 \phi$$

Exp 80

16x16x45" high

b < 1 Table together no plexiglass

U3-80 (1 sec)

$$\ln N = -210.089 \rightarrow -7.672 \phi$$

$$TMC = -212.907 \rightarrow -7.543 \phi$$

Exp 81

16x16x46" high

b > 1 Table together no plexiglass

U3-81 (1 sec)

$$\ln N = 420.179 \rightarrow 2.865 \phi$$

$$TMC = 439.753 \rightarrow 2.746 \phi$$

Exp 82

16x16x45" high

b < 1 Table together no plexiglass

U3-82 (1 sec)

$$\ln N = -199.058 \rightarrow -8.222 \phi$$

$$TMC = -212.770 \rightarrow -7.550 \phi$$

avg worth of 1" off fuel on a 16x16" stack from Exps 70-82 = $10.227 \pm 0.132 \phi$

From TMC.

U3 H/x 279

Instrument Check on 5-23-66 Source

121


~72.3°F during day

PM-1	Low Trip	<input checked="" type="checkbox"/>	Hi Alarm Trip	<input checked="" type="checkbox"/>
PM-2			Alarm Trip	
IC-1	3×10^{-11}	Motor Trip	Fast Trip	<input checked="" type="checkbox"/>
IC-2	3×10^{-11}	Motor Trip		<input checked="" type="checkbox"/>
IC-3	Response <input checked="" type="checkbox"/>	Calibration S & R	Red light	<input checked="" type="checkbox"/>
IC-4	Response <input checked="" type="checkbox"/>	Calibration S & R	Bldg Alarm	<input checked="" type="checkbox"/>
CRM	Motor Trip		Press Diff	0.07

Purpose - Check Crit on (uF, 3' dia) stack 19" x 19" x 18"

Expr time	Condition	Table Separation	
83 12 ⁵⁰	K < 1	0.0	w/ Plexyglass
1 ¹⁰	Separate	Add 1 1/2" to HT of Stack	19 x 19 x 19 1/2
1 ²⁸	K > 1	2.15	with
1 ⁴²	K < 1	0.0	w/o
1 ⁴⁴	Separate	Add 1/4" (short ~ 1" on 2 sides of 1/4" mat.)	
2 ⁰³	K > 1	2.8	with
2 ²⁰	K < 1	0.0	w/o
2 ⁵⁵	Separate	added fuel to make 19 x 19 x 19 3/4 plus 1/4" on south side and 1" on 2 sides East side	
3 ¹⁵	K > 1	2.2	with (Approx 1" out)
3 ¹⁸	K = 1	use Plexyglass Shim to maintain Crit	
3 ²⁶	K < 1	with shim out	Approx 7"
3 ²⁶	Separate	Position Counter & added 1/4" x 2 x 4 on north edge	
3 ³⁹	K > 1	2.1	with
3 ⁵⁵	K = 1	0.0	Shim out Approx 1"
4 ⁰⁰	Shut Down		

122 U-3 H/x 279



S
 19" x 19" x 19 3/4" high
 plus 1/4" on shaded
 areas

U-3 H
 ~71.6° F
 PM-
 PM-
 IC-
 IC-
 IC-
 IC-
 CRU
 Pu

Time	Code
1 25	
1 45	
1 50	Se
2 05	A
2 25	S
2 33	A
2 40	X
2 55	A
4 15	S

122 U-3 H/x 279

Instrument Check on 5-24-66 Source
 ~ 71.7°F might have to ~ 72.3°F during day

PM-1	Low Trip	✓	Hi Alarm Trip	✓	
PM-2			Alarm Trip		
IC-1	3×10^{-11}	Meter Trip	✓	Fast Trip	✓
IC-2	3×10^{-11}	Meter Trip	✓		
IC-3	Response	✓	Calibration S. G. R.	Red light	✓
IC-4	Response	✓	Calibration S. G. R.	Bldg Alarm	✓
CRM		Meter Trip		Press. Dif. 0.07"	

Purpose: Pulse at critical (UE, 3%) stack

Expr time	condition	table separation		Expr
8H 9 ⁰⁰	K < 1	0.0	Plexyglass shim out 2"	85
12 ⁴⁵	K > 1 ~ 0.3 ⁴	0.0		
1 ¹⁰	Adjust crit with Plexyglass Shim			
4 ¹⁵	check Critical			
	K < 1 ~ 0.14	0.0		
4 ²⁷	Shut Down			

meas. Mach → 48.541 x 48.554 x 50.446 in high + 0.635 in on phedat
 use phor
 plates

Pulsing beta: Ch width = 80 mac; B ratio = 2; Delay ratio = 2

Burst width = 500 mac; Rate = 35 cps; 150 KV; Avg Beam I ≈ 1 mAmp

18 K < 1 0.0

~~Separate~~


meas. λ_c from Computer fit = $-242.427 \pm 0.577 \text{ sec}^{-1}$

U-3 H/4 279 Instrument Check on 5-25-66 Source 123
 ~71.6° F night before to 72.4° F during day

PM-1 Low Trip Hi Alarm Trip
 PM-2 Alarm Trip
 IC-1 3×10^{-11} Meter Trip Test Trip
 IC-2 3×10^{-11} Meter Trip
 IC-3 Response Calibration S.A.R. Red light
 IC-4 Response Calibration S.A.R. Bldg Alarm
 CRM Meter Trip Press. D.F. 0.07"

Purpose: Check Critical on stack (UF₆ 3%)
 16x16x16 Reflected with 6" Polyethylene
 on sides and top and 6" Plexyglass on Bottom.


Expr time	Condition	Table Separation	
85 1 ²⁵	b > 1	2.9 rev	
1 ⁴⁵	b = 1	3.7 rev	
1 ⁵⁰	Separate Remove 1/2" Stack Now 16x16x15 1/2		Reflected AS Above
2 ⁰⁵	K > 1	0.0	
2 ²⁵	Separate Removed 1/4 x 4 x 4 from both NE & NW corners		
2 ³⁵	b < 1	0.0	
2 ⁴⁰	Separate added (1/4 x 2 x 4) 2		
2 ⁵⁵	K < 1	0.0	
4 ¹⁵	Shut Down		



124

U 3 H/x 279

~ 72°F



check on 5-26-66 Source

Trip Hi Alarm Trip
 Alarm Trip
 Trip Fast Trip
 Trip
 Trip Red light
 Trip Bldg Alarm
 Trip Press Dif 0107

16 x 16 x 15 1/2 Less 1/4"
ON Spaces Marked X

+ (REF. 3%) stack Reflected with 6"
and top with 6" Plexiglass on Bottom see sketch Ex

Expr time	Condition	Table Separation	
86 8 ³⁵	K < 1	0.0	87
8 ⁵⁰	Separate		88
8 ⁵⁸	K < 1	0.0	
9 ¹⁵	Separate Add 1/4 x 2 x 2 to NE corner		89
9 ²¹	K < 1 ~ 0.09	0.0	
9 ⁵³	start Pulsing		90
1 ¹⁸	K < 1	0.0	
	Separate Add 1/4 x 2 x 2 to NE corner		9
1 ²⁵	Start Pulsing		
3 ⁵⁸	Check Critical		90
	K < 1	0.0	
H ¹⁰	Shut Down		

Pulsing Data: Ch. width = 80 nsec; Rq ratio = 2; Delay ratio = 2
 Burst width = 200 nsec; Rate = 35 cps.; 150KV; Steady Beam = 30M

Meas. λ_c from Computer fit = $-207.709 \pm 0.248 \text{ sec}^{-1}$

U3 H/x 279

Instrument Check on 5-27-66 Source _____

71.7 °F night before to ~ 72.5 °F during day

PM-1	Low Trip	✓	Hi Alarm Trip	✓	
PM-2			Alarm Trip		
IC-1	3 x 10 ⁻¹¹	Meter Trip	✓	Fast Trip	✓
IC-2	3 x 10 ⁻¹¹	Meter Trip			
IC-3	Response	Calibration	J/A	Red light	✓
IC-4	out	Calibration		Bldg Alarm	✓
CRM		Meter Trip		Press Dif 0.07"	

Purpose: Ht Perturbation Meas on Stack 16x16x15 1/2 (U.F., 3/0)
 Reflected with 6" Polyethylene on sides & top with 6" Plexiglass on Bottom

Sketch	Expr Time	Condition	Table Separation	
	87 9 ⁵⁰	K > 1	0.0	
	10 ¹⁷	Separate	Remove 1/4" From 1/4 of Stack	NW Corner
	88 10 ³³	K < 1	0.0	
	10 ⁵⁸	Separate	Add 1/4" to 1/4 of Stack	NW Corner
	89 11 ¹³	K > 1	0.0	
	11 ⁴⁰	Separate	Remove 1/4"	
	90 12 ³⁷	K < 1	0.0	
	1 ⁰¹	Separate	Add 1/4"	
	91 1 ¹³	K > 1	0.0	
	1 ³⁹	Separate	Remove 1/4"	
	92 1 ⁵⁰	K < 1	0.0	
	2 ¹⁵	Shut Down		

2.5 hr op time

Stack U3-E 16x16x15 1/2 high

Measured (40.814 x 40.796 x 39.569 cm high)

n = 300
 arch

Instrument Check on 1-66 Source 10-mc K

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Redlight	OK
IC-3	Response	Calibration	1.7	alarm	
IC-4	Out	Calibration		Press dif.	.07"
CRM		Meter Trip			

To build ^(mean cubic) stack for irradiation of foils

- Apr 93 $19 \times 20 \times 18 \frac{3}{4}$ high $10''$ on movable table
 $9 \frac{40}{55}$ $k=1$ & $9''$ on fixed table
- $9 \frac{55}{55}$ $k=1$ foils in and no Plexyglass
 Shut Down to add plexyglass ^{$1 \times 8 \times 20''$} shim on rod drive.
- $12 \frac{30}{30}$ $k > 1$ Shim all the way in
- $12 \frac{47}{47}$ $k=1$ Using plexyglass shim to adjust approx 2" out
 $k < 1$ ~~shim~~ $2 \times 6 \times 6$ inch shim $5 \frac{1}{4}$ out
 Shut Down Add $\frac{1}{4} \times 2 \times 20''$ of fuel on movable table $10''$

7 bare foils of 2% U in paraffin.

12:58 Start timing at 7.5 on IC-3
 $k=1$ at 23 on IC-3

1:08 PM Shut down.

Expr 94 $2 \frac{05}{18}$ 7 Bare foils of 2% U in Paraffin

$2 \frac{18}{18}$ Start timing at 7.5 on IC-3

$k=1$ at 25 on IC-3

$2 \frac{29}{29}$ Shut Down

Exp 93 7 Bare foils of 27. V in paraffin

← F				W →		
-6"	-4"	-2"	0	+2"	+4"	+6"
B-34	B-72	B-29	B-10	B-32	B-35	B-28
0.644628	0.673573	0.871008	1.0			
0.644628	0.871008	0.974762	1.0	0.971287	0.864610	0.673573

Exp 94 7 Bare foils of 27. V in paraffin

-6"	-4"	-2"	0	+2"	+4"	+6"
B-30	B-26	B-2	B-1	B-27	B-17	B-14
0.652122	0.862486	0.971744	1.0	0.968171	0.861034	0.667518

2" out

Stack measures $51.038 \text{ cm} \times 48.529 \text{ cm} \times 1.834 \text{ cm}$ (nominal)
 Dimensions in which bushing is measured

2.0"
S

3%

H/ 279

Instrument Check on 6-2-66 Source


PM-1	Low Trip	✓	Hi Alarm Trip	✓	
PM 2			Hi Alarm Trip		
IC-1	3×10^{-11}	Meter Trip	✓	Fast Trip	✓
IC-2	3×10^{-11}	Meter Trip	✓		
IC-3	Response	✓	Calibration S.G.R.	Red light	✓
IC-4	out	Calibration		Bldg Alarm	✓
CRM		Meter Trip		Press Dic. 0.07"	

Purpose: foil Exposure in stack U_F, 3% $19 \times 20 \times 18 \frac{3}{4} \frac{1}{4} \times 20$
 Using Plexyglass Shim to adjust crit. $1' \times 8' \times 20''$

Expt time Temp in cell = 66°F down ~10°F from yesterday
 Removed absorber $\frac{1}{4} \times 2 \times 20$ of fuel from movable table.
 95 9¹⁰ 7 Bare foils of 2% U in Paraffin
 9²⁰ start timing at 7.5 on IC-3
 K > 1 ~4.4% did not have enough shim to level.

9^{24.5} shut down - power level at 82.0 on IC-3
 Removed $\frac{1}{4} \times 2 \times 20$ of fuel from N side of stack on movable table.

96 10¹³ 7 Bare foils of 2% U in Paraffin shaded area 18 1/2" high
 10⁵⁴ start timing at 7.5 on IC-3
 K > 1 ~3.2%



97 11⁰¹ Shut Down
 1⁰⁰ removed $\frac{1}{4} \times 2 \times 20$ of fuel. shaded area 18 1/2" high
 7 Bare foils of 2% U in Paraffin
 1¹¹ start timing at 7.5 on IC-3



1²¹ K=1 at 68 on IC-3
 Using Plexyglass Shim to Adjust
 Shut Down

98 2⁴⁰ 7 Bare foils of 2% U in Paraffin
 2⁵¹ K > 1 start timing at 7.5 on IC-3
 3⁰¹ Shut Down

Tried to adj thermostat. Temp fluctuated considerably during day

Expt 95 7 Bare foils of 2% V in paraffin

-6"	-4"	-2"	0	+2"	+4"	+6"
B-20	B-31	B-3	B-24	B-38	B-33	B-40
0.659422	0.856915	0.97069 0.979411	1.0	0.963365	0.857392	0.667925

Expt 96 7 Bare foils of 2% V in paraffin

-6	-4	-2	0	+2	+4	+6
B-0	B-12	B-36	B-6	B-5	B-11	B-17
0.658400	0.846222	0.992808	1.0	0.973275	0.868411	0.666979

Expt 97 7 Bare foils of 2% V in paraffin

-6	-4	-2	0	+2	+4	+6
B-21	B-15	B-41	B-25	B-7	B-22	B-13
0.664220	0.869053	0.976352	1.0	0.976224	0.845490	0.663697

Expt 98 7 Bare foils of 2% V in paraffin

-6	-4	-2	0	+2	+4	+6
C-4	C-5	C-16	C-29 C-29	C-8	C-24	C-7
0.657709	0.835379	0.962443	1.0	0.963252	0.829901	0.650303

Instrument Check on 6-3-66 Source 10mCK

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	Red light	OK
IC-3	Responds	Calibration	S/O	Bld. Alarm	OK
IC-4	Out	Calibration		Pres Diff.	0.07"
CRM		Meter Trip			

Purpose: Foil exposure. Stack $19 \times 20 \times 18 \frac{3}{4}$ " high
Using plexyglass shim $1 \times 8 \times 20$ " to adjust critical.

Expr time condition

99 10^{50} K > 1 with Plexyglass in

11⁰² start timing at 7.5 on IC-3

K = 1 with Plexyglass out Approx 2.5" ^{24 on} IC-3

11¹² shut down

100 1^{10} 7 Bare 2% u Paraffin foils

K > 1 with Plexyglass in

1²⁵ start timing at 7.5 on IC-3

1³⁵ K = 1 with plexyglass shim out 2.75" ^{24 on} IC-3

shut down

101 2^{33} 7 Bare 2% u Paraffin foils

2⁴¹ K > 1 with Plexyglass in

2⁴⁷ start timing at 7.5 on IC-3

K = 1 with Plexyglass shim out 3" ^{24 on} IC-3

2⁵⁷ shut down

Expt 99 7 Bare foils of 2% V in paraffin

-6"	-4"	-2"	0	+2"	+4"	+6"
C-22	C-35	C-13	C-11	C-2	C-12	C-36
0.645676	0.845544	0.966191	1.0	0.971810	0.854605	0.660111

Expt 100 7 Bare foils of 2% V in paraffin

-6	-4	-2	0	+2	+4	+6
C-34	C-39	C-15	C-37	C-10	C-31	C-14
0.652542	0.845406	0.952196	1.0	0.949694	0.840732	0.652886

Expt 101 7 Bare foils of 2% V in paraffin

-6	-4	-2	0	+2	+4	+6
C-40	C-20	C-32	C-27	C-41	C-19	C-45
0.654293	0.846677	0.971499	1.0	0.955073	0.823019	0.651538

132 3% H/x 279


Instrument Check on 6-6-66 Source 10 mck

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	7.3×10^{-4}	Meter Trip	OK	Fast Trip	OK
IC-2	7.3×10^{-4}	Meter Trip	OK	Red light	OK
IC-3	Responds	Calibration	S.P.O.	Bld. alarm	OK
IC-4	Out	Calibration		Press. dif	0.07
CRM		Meter Trip			

Temp in cell $\sim 70^\circ\text{F}$
 Purpose: Foil exposure to measure extrapolation distance

Ex 9
 Exp 102 13 bare gold foils

Tightened up stack for thinner foils and removed some fuel

Stack now $19 \times 20 \times 17\frac{1}{2}$ " high + $\frac{1}{4}$ " on shaped area
 Shim with $1 \times 8 \times 20$ " piece of plexiglass. foil plane. 

10¹⁰ Start timing at 37 on IC-3

k=1 at ~ 105 on IC-3. Shim ~ 4 " out.

10³⁵ Shut Down

103 1¹⁵ 13 bare gold foils

1²⁵ start timing at 37 on IC-3 (30 min exposure)

k=1 with shim in

10 1³⁰ k=1 with shim out Approx 3" at 107 on IC-3

1⁵⁵ Shut Down

Expt 102

13 Bare gold foils
2 mil, 5/16" dia, 48.3mg

Expt 103

13 Bare gold foils
2 mil, 5/16" dia, 48.3mg

Foil Position	Foil Ident.	(Foil/N)avg.	Foil Ident.	(Foil/N)avg.
-6"	D-1	0.657911	D-3	0.657955
-5"	D-22	0.751050	D-7	0.748447
-4"	D-31	0.841458	D-24	0.837106
-3"	D-9	0.905319	D-23	0.917295
-2"	D-20	0.958604	D-32	0.960266
-1"	D-6	0.999247	D-2	0.999955
0	D-8	1.0	D-14	1.0
+1"	D-16	0.988778	D-26	0.988759
+2"	D-11	0.954981	D-12	0.952999
+3"	D-18	0.898281	D-28	0.900006
+4"	D-5	0.836693	D-15	0.834500
+5"	D-30	0.754948	D-33	0.753679
+6"	D-17	0.648445	D-19	0.645162

134 3% H/x 279

Instrument Check on 6-7-66 Source 10mcr

PM-1	Low Trip	OK	Alarm Trip	
PM-2			Alarm Trip	
IC-1	Respond ^{3x10⁻¹¹}	Meter Trip	OK	Fast Trip OK
IC-2	3x10⁻¹¹	Meter Trip	OK	Redlight OK
IC-3	Responds	Calibration		Bl. alarm OK
IC-4	Out	Calibration		Pres. dif. 0.06"
CRM		Meter Trip		

Temp in cell ~ 70°F

Stack same as Exp 102-103

Exp. 104 9²⁰ 13 Bare Gold foils

K > 1 Shim in

9³⁰ start timing At 37 on IC-3

K=1 with shim out Approx 3" at 110mTC-3

10⁰⁰ shut down

105 1⁵⁰ 13 Bare foils (Gold)

K > 1 Shim in

2¹⁰ start timing At 37 on IC-3

K=1 with shim out Approx. 3.5" At 110 on IC-3

2⁴⁰ shut down

Extn 104
13-Bar gold foil
2 mil, $\frac{5}{16}$ " dia, 48.2 mg.

Extn 105
13-Bar gold foil
2 mil, $\frac{5}{16}$ " dia, 48.4 mg.

Foil Position	Foil Ident.	(Foil/N) avg.	Foil Ident.	(Foil/N) avg.
-6"	C-2	0.664623	E-3	0.657868
-5"	C-1	0.763893	E-1	0.750647
-4"	C-13	0.842701	E-14	0.843834
-3"	C-7	0.918135	E-23	0.914662
-2"	C-12	0.963924	E-5	0.959080
-1"	C-9	0.997721	E-12	0.991485
0	C-5	1.0	E-15	1.0
+1"	C-20	0.984371	E-25	0.988430
+2"	C-6	0.954931	E-9	0.951076
+3"	C-19	0.906163	E-8	0.903501
+4"	C-18	0.838867	E-21	0.839033
+5"	C-16	0.763070	E-2	0.745698
+6"	C-11	0.642031	E-20	0.642945

136 3% HX 279 Instrument Check on 6-8-66 Source _____

PM-1	Low Trip	✓	Alarm Trip	
PM-2			Alarm Trip	
IC-1	3 x 10 ⁻¹¹	Meter Trip	✓	Fast Trip
IC-2	3 x 10 ⁻¹¹	Meter Trip	✓	
IC-3	Response	Calibration		Red light
IC-4		Calibration		Bldg Alarm
CRM		Meter Trip		Press Dif. 0.06"

Foil Pa

~ 70° F Purpose: Foil Exposure
 Added some fuel to compensate for Cd. filter cover
 Stock is 19 x 20 x 18 1/2" high
 + 1/4" on shaded area

Expr time 7 Cd Covered Gold foils
 106 9²⁰ K > 1 Shim in
 9⁴⁴ start timing At 37 on IC-3
 K=1 with shim out Approx 3" At 125 on IC-3
 10⁰⁴ Shut Down



107 1⁰³ 7 Cd Covered Gold foils
 K > 1 with shim in
 1¹⁷ start timing At 37 on IC-3
 K=1 with shim out Approx 3 1/4" At 120 on IC-3
 1³⁷ Shut Down

-6"
 -4"
 -2"
 0
 +2"
 +4"
 +6"

Expt 1.0.6

7 Ed Covered gold foil
 2 mil, $\frac{7}{16}$ " dia, 48.4 mg.
 20 mil Ed.

Expt 1.0.7

7 Ed Covered gold foil
 2 mil, $\frac{7}{16}$ " dia, 48.0 mg.
 20 mil Ed

Foil Position	Foil Ident.	(Foil/N) avg.	Foil Ident.	(Foil/N) avg.
-6"	E-4	0.653481	A-11	0.651793
-4"	E-13	0.842465	A-8	0.846499
-2"	E-7	0.960884	A-16	0.965558
0	E-22	1.0	A-4	1.0
+2"	E-24	0.960991	A-5	0.960796
+4"	E-18	0.845849	A-12	0.836552
+6"	E-11	0.650720	A-19	0.643357

138 3% H/x 279

Instrument Check on 6-9-66 Source _____

PM-1	Low Trip	<input checked="" type="checkbox"/>	Alarm Trip	
PM-2			Alarm Trip	
IC-1	3×10^{-11}	Meter Trip	<input checked="" type="checkbox"/>	Fast Trip <input checked="" type="checkbox"/>
IC-2	3×10^{-11}	Meter Trip	<input checked="" type="checkbox"/>	
IC-3	Response	Calibration	<input checked="" type="checkbox"/>	Red light <input checked="" type="checkbox"/>
IC-4	out	Calibration	-	Bldg Alarm <input checked="" type="checkbox"/>
CRM		Meter Trip		Pres. Dif. 0.06"

Fai

Purpose: Foil Exposure in ufy 3%

~ 70°F

Stack Same AS Expr 106-107

Expr time 7 cd Covered Gold foils

8²⁵ K > 1 with shim in
 8⁴³ start timing at 37 ON IC-3
 R=1 with shim out Approx 3.5" at 105 ON IC-3
 9⁰³ shut down

109 1¹⁰ 7 cd Covered Gold foils

R > 1 Shim in

1¹⁹ start timing at 37 ON IC-3

R=1 with shim out Approx 3 1/2" at 108 ON IC-3

1³⁹ shut down

Effer 108

7 Ed Covered gold foil
 2 mil, $\frac{5}{16}$ " dia, 48.0 mg.
 20 mil Ed.

Effer 109

7 Ed Covered gold foil
 2 mil, $\frac{5}{16}$ " dia, 48.5 mg.
 20 mil Ed.

Foil Position	Foil Ident	(Foil/N) avg.	Foil Ident	(Foil/N) avg.
-6"	A-6	0.650449	F-2	0.656538
-4"	A-18	0.845274	F-4	0.844472
-2"	A-14	0.963645	F-6	0.960029
0	A-3	1.0	F-1	1.0
+2"	A-13	0.957717	F-7	0.955330
+4"	A-15	0.839333	F-5	0.842851
+6"	A-10	0.650911	F-3	0.650598

140

Instrument Check on 6-10-66 Source _____

370 V

H_x = 279

PM-1	Low Trip	<input checked="" type="checkbox"/>	Alarm Trip
PM-2			Alarm Trip
IC-1	3×10^{-11}	Meter Trip <input checked="" type="checkbox"/>	Fast Trip <input checked="" type="checkbox"/>
IC-2	3×10^{-11}	Meter Trip <input checked="" type="checkbox"/>	
IC-3	Response	Calibration S.G.R	Red light OK
IC-4	Response	Calibration S.G.R	Bldg Alarm <input checked="" type="checkbox"/>
CRM	Meter Trip		Press Dif 0.06"

N 70° F

Purpose: foil Exposure on stack U_F 3%
Same as Expr 108-109 Less 1/4" x 8" x 20"


Expr time 2 cd covered Gold foils AND 2 Bare Gold foils

110 9³⁰ K > 1 Shim in

9⁵⁵ start timing at 37 on IC-3

K = 1 Shim out APPROX AT 110 ON IC-3

10¹⁰ Shut Down



111 12⁵⁵ 2 cd covered ~~Gold~~ ^{U-al alloy} foils AND 2 Bare ~~Gold~~ ^{U-al alloy} foils

K > 1 Shim in

1¹⁰ start timing at 37 on IC-3

K = 1 Shim out approx 4" At 220 on IC-3

1³⁰ Shut Down



Eppm V(3)-110

2 Ed covered and 2 bare gold foil
2 mil, $\frac{5}{16}$ " dia, 48.0 mg.

Pos. 1	2	3	4
A-7 Ed	A-1 Bare	A-9 Ed.	A-17 Bare.
	$\frac{2}{1} = 2.395000$		$\frac{4}{1} = 2.398155$
	$\frac{2}{3} = 2.389903$		$\frac{4}{3} = 2.382183$

avg Ed ratio = 2.391310

Eppm - 111

2 Ed covered and 2 bare U-al alloy (10% U) foil
 $\frac{5}{16}$ " dia,

Pos 1	2	3	4
C-2 Ed	C-3 Bare	C-4 Ed.	C-1 Bare
	$\frac{2}{1} = 11.749814$		$\frac{4}{1} = 12.364487$
	$\frac{2}{3} = 11.564234$		$\frac{4}{3} = 11.855443$

avg Ed ratio = 11.883495

142: V(3)F₄

$\frac{H}{X} = 279$

Instrument Check on 6-14-66 Source 10mcf

PM-1	Low Trip	OK	Alarm Trip
PM-2			Alarm Trip
IC-1	73×10^{-4}	Meter Trip	OK East Trip OK
IC-2	73×10^{-4}	Meter Trip	OK Red light OK
IC-3	Responds	Calibration	8% R. Bldg. alarm OK
IC-4	Responds	Calibration	8% R. Pres dif 0.07"
CRM	Meter Trip		


70 of

Purpose: foil exposure to determine Cd ratios for ²³⁵U metal
 Stacks same as Expt 111


Expt 112

2 Cd covered and 2 bare ²³⁵U metal foils

- 11⁰⁰ to 1 Per. to foil to center with shim. Separate and
 remove $\frac{1}{4} \times 4 \times 20$ from moveable table. Now $19 \times 20 \times 10$
 plus $\frac{1}{4}$ on shaded area
- 11¹⁵ to 1 Start timing at 6 on IC-3
- to 1 Shim out ~ 2" at 20 on IC-3
- 11³⁵ Shut down



Pos	1	2	3	4
	U-1 Cd	U-2 Bare	U-3 Cd	U-4 Bare
		$\frac{2}{1} = 9.337965$		$\frac{4}{1} = 9.221216$
		$\frac{2}{3} = 9.411023$		$\frac{4}{3} = 9.322087$
Avg Cd Ratio = 9.323073				



~ 70°F

U.S.F. 4/2 - 79

Instrument Check on 6-15-66 Source 10 mCr

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	> 3x10 ⁻⁴	Meter Trip	OK	Fast Trip	OK
IC-2	> 3x10 ⁻⁴	Meter Trip	OK	Red light	OK
IC-3	Responds	Calibration	S/O.	Bldg alarm	OK
IC-4	Responds	Calibration	S/O.	Pres dif	0.06"
CRM		Meter Trip			

Purpose: foil exposure to determine Cd Ratio for ²³⁵U metal.
 Made same as Expt 112.

Expt 113 2 Cd covered and 2 bare ²³⁵U metal foils.

9³⁸ p > 1 Shim in
 9⁴⁴ Start timing at 3.7 on IC-3
 p = 1 at 10 on IC-3 Shim out ~ 1 3/4"
 9⁵⁴ Shut down

Pos	1	2	3	4
	U-12 Cd	U-16 Bare	U-19 Cd	U-21 Bare
		2/1 = 9.785813		4/1 = 9.725392
		2/3 = 9.186458		4/3 = 9.159938
	Avg Cd Ratio = 9.464400			

144

V(3) F₁ $\frac{H}{X} = 279$ Instrument Check on 6-21-66 Source 10m CV

PM-1	Low Trip	OK	Alarm Trip
PM-2			Alarm Trip
IC-1	73×10^{-11}	Meter Trip	OK
IC-2	73×10^{-4}	Meter Trip	OK
IC-3	Response	Calibration	Std.
IC-4	Response	Calibration	Std.
CRM		Meter Trip	

Red light OK
Bl. Alarm OK
Press diff 0.06"

Purpose: foil irradiation to determine Cd Ratio for .001" Au
Stack same as Expt 113.

Expt 113 2 Cd covered and 2 bare .001" gold foils. $\frac{5}{16}$ " dia.

9³⁰ b=1

9²⁵ Start timing at 37. on IC-3

b=1 at 100 on IC-3 Show ~ 2" out

9⁵⁰ Shut down

Pro	1	2	3	4
	406 Cd	407 Bare	408 Cd	402 Bare
		$\frac{2}{1} = \frac{2.090493}{2.072895}$		$\frac{4}{1} = \frac{2.096719}{2.071996}$
		$\frac{2}{3} = \frac{2.061089}{2.048049}$		$\frac{4}{3} = \frac{2.055584}{2.055584}$

Avg Cd Ratio = 2.06713 ✓ 2.075895

Red values corrected for variation in foil mt.

CRM	Meter Trip	
IC-4	Calibration	
IC-3	Calibration	
IC-2	Meter Trip	
IC-1	Meter Trip	
PM-2	Alarm Trip	
PM-1	Low Trip	

70° F

Instrument Check on 6-22-66 Source 10 mCk

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	73x10"	Meter Trip	OK	Alarm Trip
IC-2	73x10"	Meter Trip	OK	Fast Trip
IC-3	Responds	Calibration	OK	Red light OK
IC-4	Responds	Calibration	OK	Red alarm OK
CRM	Meter Trip			Pressure 0.06

Foils irradiation to determine Cd Ratios for In. Stock some Exp 113

Exp. 115 2 Cd covered and 2 bare In-Al alloy foils 10% In
 2³⁴ k > 1

2³² Start Timing at 15 on IC-3

k = 1 at 40 on IC-3 Shim ~ 2 out.

2⁴⁷ Shut Down

Pos	1	2	3	4
	13 Cd	12 Bare	11 Cd	22 Bare
		$2/1 = 1.688639$		$4/1 = 1.695095$
		$2/3 = 1.681933$		$4/3 = 1.680187$

Avg Cd Ratio = 1.686464

70°F

Instrument Check on 6-23-66 Source 10 mCr

PM-1	Low Trip	OK	Alarm Trip
PM-2			Alarm Trip
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK Fast Trip OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK Red light OK
IC-3	Responds	Calibration	S.J. R. Bld. Alarm OK
IC-4	Responds	Calibration	S.J. R. Press. Dif. 0.06"
CRM	Meter Trip		

Foil irradiation to determine G Factor for In.
Stack same as Expt. 113.

Expt. 116 2 Cd covered and 2 bare In(10) - all alloy foils 0.010" x $\frac{5}{16}$ " dia.

10⁵⁹ k > 1

11⁰² Start timing at 15 on IC-3

k = 1 at 42 on IC-3 Shim out ~ 2"

11¹² Shut Down

Expt. 117 Repeat of Expt. 116. One of the foils in Expt. 116 was lost before it could be counted.

12⁵² k > 1

1⁰⁰ Start timing at 15 on IC-3

k = 1 at 42 on IC-3 Shim out ~ 2 $\frac{1}{2}$ "

1¹⁰ Shut down

Expt. 118 2 Cd covered and 2 bare Sld foils 0.001" x $\frac{5}{16}$ " dia.

2¹⁰ k > 1

2¹⁷ Start timing at 70 on IC-3

k = 1 at 220 on IC-3 Shim out ~ 2 $\frac{3}{4}$ "

2³⁵ Shut Down

Expt. 117

2 Cd covered and 2 Bare In (10) - all fails $0.010'' \times \frac{5}{16}''$ dia

Pos	1	2	3	4
	J1 Cd	J2 Bare	J10 Cd.	J4 Bare
		$\frac{2}{1} = 1.712672$		$\frac{4}{1} = 1.712227$
		$\frac{2}{3} = 1.738207$		$\frac{4}{3} = 1.726397$
		Avg Cd. Ratio = 1.722376		

Expt 118

2 Cd. covered and 2 Bare Cold fails $0.001'' \times \frac{5}{16}''$ dia.

Pos	1	2	3	4
	401 Cd	404 Bare	405 Cd.	400 Bare
		$\frac{2.099494}{2/1} = 1.825833$		$\frac{2.150636}{4/1} = 2.150676$
		$\frac{2.067251}{2/3} = 1.862813$		$\frac{2.073678}{4/3} = 2.148000$
		Avg Cd. Ratio = 1.996831 2.097912		

Red values corrected for variation in print mt.

148

V(3) F₁ H_{1/2} = 279Instrument Check on 6-24-66 Source 10 mcr

PM-1	Low Trip	OK	Alarm Trip
PM-2			Alarm Trip
IC-1	> 3 x 10 ⁻⁴	Meter Trip	OK Fast Trip OK
IC-2	> 3 x 10 ⁻⁴	Meter Trip	OK Redlight OK
IC-3	Response	Calibration	S/P, Old alarm OK
IC-4	Response	Calibration	S/P, 0.05" Pres. sf.
CRM	Meter Trip		

Foil Irradiation to determine Cd. Rates for Gold
Stack same as Expr 113

Expr 119 2 Cd covered and 2 Bare Gold foils 0.005" x $\frac{5}{16}$ " dia.

9²⁴ K > 1

9³¹ Start timing at 37 on IC-3

K=1 at 100 on IC-3 Shim out ~ 2 $\frac{3}{4}$ "

9⁵¹ Shut down.

Expr 120 11⁰⁵ 2 Cd covered AND 2 Bare Gold foils 0.005" x $\frac{5}{16}$ " DIA

11¹⁰ K > 1

11¹⁶ Start timing AT 37 ON IC-3

K=1 AT 108 ON IC-3 Shim out Approx.

11³⁶ Shut Down

Expr 121 1¹⁵ 2 Cd Covered AND 2 Bare Gold Foils 0.002" x $\frac{5}{16}$ " DIA

1¹⁵ K > 1

1²⁶ start timing AT 55 ON IC-3

K=1 AT 155 ON IC-3 Shimout Approx 2 $\frac{1}{2}$ "

1⁴⁶ Shut Down

Expt 119

2 Cd covered and 2 Bare Gold foils $0.005'' \times \frac{5}{16}'' \text{ dia}$

Pos 1	2	3	4
513 Cd.	502 Bare	507 Cd	501 Bare
	$\frac{2}{1} = 2.860442$		$\frac{4}{1} = 2.849185$
	$\frac{2}{3} = 2.821367$		$\frac{4}{3} = 2.806651$

Avg Cd Ratio = 2.834411

Expt 120

2 Cd covered and 2 Bare Gold foils $0.005'' \times \frac{5}{16}'' \text{ dia}$

Pos 1-503 Cd.	2-505 Bare	3-511 Cd	4-512 Bare
	$\frac{2}{1} = 2.857620$		$\frac{4}{1} = 2.877252$
	$\frac{2}{3} = 2.820568$		$\frac{4}{3} = 2.825895$

Avg Cd Ratio = 2.845334

Expt 121

2 Cd covered and 2 Bare Gold foils $0.002'' \times \frac{5}{16}'' \text{ dia}$

Pos 1	2	3	4
E16 Cd	E17 Bare	E10 Cd	E19 Bare
	$\frac{2}{1} = 2.385726$		$\frac{4}{1} = 2.419150$
	$\frac{2}{3} = 2.387170$		$\frac{4}{3} = 2.387478$

Avg Cd Ratio = 2.394881

150

(3) F₄ ^{N/X-279} Instrument Check on 6-27.6⁶ Source _____

PM-1	Low Trip	✓	Alarm Trip	
PM-2			Alarm Trip	
IC-1	3×10^{-11}	Meter Trip	✓	Alarm Trip
IC-2	3×10^{-11}	Meter Trip	✓	
IC-3	Response	✓	Calibration	Red light ✓
IC-4	Response	✓	Calibration	Bldg Alarm ✓
CRM		Meter Trip		Press Diff. 0.06"

~65.4 to 69°F on wall and to 70°F during day on 27th.

Purpose: Foil irradiation to Determine Cd Ratio
for U-Al stack same as 121

Expr time: 2 Cd Covered AND 2 Bare U-Al foils $0.005" \times \frac{5}{16}"$, 16.6mg

122 9²⁰ K > 1

9³¹ start timing at 70 ON IC-3

9³⁵ K=1 AT 220 ON IC-3 Shim out ~ 3"

9⁵¹ Shut Down

Pos 1	2	3	4
C-4 Cd	C-2 Bare	C-1 Cd	C-3 Bare
	$\frac{2}{1} = 11.410698$		$\frac{4}{1} = 12.053914$
	$\frac{2}{3} = 11.887976$		$\frac{4}{3} = 11.818145$

avg Cd Ratio = 11.792658

Expr t
123³

Expr time Purpose: Arrange Stack w/ 3% for temp
123-3⁰² Coef Measurement

3¹¹ K > 1

3¹⁸ Separate to Adjust Counters AND Stack

3³³ K > 1

3⁴⁷ Separate

~~3⁵⁵~~

3⁵⁵ K > 1

4⁰⁶ Separate - Shut Down

6.64y

4

14

15

152

U(3) F₄ $\frac{1}{K} = 279$ Instrument Check on 6-28-66 Source 5 mck

U(3) 1

PM-1 Low Trip ✓ Alarm Trip
 PM-2 _____
 IC-1 10 x 10⁻¹² Meter Trip ✓
 IC-2 10 x 10⁻¹² Meter Trip ✓
 IC-3 Response ✓ 5 & f Red light ✓
 IC-4 Response ✓ 5 & f Bldg Alarm ✓
 CRM _____ Meter Trip _____ Press Dif. 0.06"

Purpose: temp Coef Measurement
 Room Thermostat setting = 74°F

Therm from meter
 m 24h records
 C temp F

Expr time

124	9 ⁰⁰	K > 1	V3-124	20.75	70° F	Expr 127
	9 ¹⁶	Separate to lower Power				128
125	9 ²²	K > 1	V3-125			128
	9 ⁴⁰	Separate to lower Power ✓				129
126	9 ⁵⁷	K > 1	V3-126	20.73°C	70° F	130
	10 ¹⁰	Separate Shut Down				
		Raised thermostat setting to 74°F				
		Placed two large table top fans on top of return air duct to help circulate the air in the cell.				
	2 ³⁰			25.47°C	78° F	
	3 ²⁰			25.00	77.5	
	4 ²⁰			25.05	78.5° F	77.5

Stack is nominally 19" x 25" x ~18 3/4" high. Height is uneven and was adjusted to give ~14 ft pass at this temp. Stack will not be touched until temp coef measurements are completed.

U3/F4

1/2 x = 279

Instrument Check on 6-29-66 Source

5427

153

PM-1	Low Trip	<input checked="" type="checkbox"/>	Alarm Trip	
PM-2			Alarm Trip	
IC-1	3×10^{-11}	Meter Trip <input checked="" type="checkbox"/>	Fast Trip	<input checked="" type="checkbox"/>
IC-2	3×10^{-11}	Meter Trip <input checked="" type="checkbox"/>		
IC-3	Response <input checked="" type="checkbox"/>	Calibration 5 g R	Red light	<input checked="" type="checkbox"/>
IC-4	Response <input checked="" type="checkbox"/>	Calibration 5 g R	Bldg Alarm	<input checked="" type="checkbox"/>
CRM	Meter Trip		Press Dif 0.86"	

Purpose; temp Coef Measurement

Recorder

Expr time	Cond	Temp C	Temp F
127 9 ¹⁰	K > 1	25.4	77.5 - 79
10 ¹³	Separate to Lower Power		
128 10 ¹³	K > 1		
11 ¹³	Separate 512"	25.45	77.5 - 79
129 12 ²⁵	K > 1	25.40	77.5 - 79
1 ²⁰	Separate to lower Power	25.45	78 - 79
130 2 ⁵⁵	K > 1	25.40	78 - 78
4 ⁰⁷	Shut Down	25.30	78 - 78.5

10
 11
 12
 13
 14
 15
 16
 17
 18
 19
 20
 21
 22
 23
 24
 25
 26
 27
 28
 29
 30
 31
 32
 33
 34
 35
 36
 37
 38
 39
 40
 41
 42
 43
 44
 45
 46
 47
 48
 49
 50
 51
 52
 53
 54
 55
 56
 57
 58
 59
 60
 61
 62
 63
 64
 65
 66
 67
 68
 69
 70
 71
 72
 73
 74
 75
 76
 77
 78
 79
 80
 81
 82
 83
 84
 85
 86
 87
 88
 89
 90
 91
 92
 93
 94
 95
 96
 97
 98
 99
 100

154

V(3) F4

H/X = 279

Instrument Check on 6-30-66 Source 5 mcr

PM-1	Low Trip	OK	Alarm Trip
PM-2			
IC-1	$> 3 \times 10^{-11}$	Water Trip	OK
IC-2	$> 3 \times 10^{-11}$		OK
IC-3	Response		s/d.
IC-4	Response		s/d.
CFM			

Redlight OK
 Obj. Alarm OK
 Pres. dif 0.06"

Temp Coef. Measurement

Expr. time		C	Temp #1	F #2	Expr
131 9 ⁰⁰	K > 1	25.45	78	79	133
9 ²²	Start counting at 0.75 on IC-3				7
10 ²⁷	Separate to lower Power				134 1
132 10 ⁴⁵	K > 1 Shut Down	25.50	78	79	1
132 12 ⁴²	K > 1	25.50	78	79	1
1 ⁰⁰	Start counting At .76 on IC-3				
2 ²³	Shut Down	25.20	78	79	
4 ¹⁸	→	25.40	78	79	

PM-1	Low Trip	✓	Alarm Trip	
PM-2			Alarm Trip	
IC-1	3 x 10 ⁻¹¹	Meter Trip	✓	Fast Trip
IC-2	3 x 10 ⁻¹¹	Meter Trip	✓	
IC-3	Response	✓		Red light
IC-4	Response	✓	Calibration	Bldg Alarm
CRM		Meter Trip		Press Dif 0.06"

Temp Coef Measurement

Expr time		C	Temp F	
			#1	#2
133 8 ⁵⁵	K > 1	25.4	77.5	78 ⁺
9 ⁰¹	Start counting 1.8 on IC-3			
10 ⁰³	Separate			
134 10 ¹⁷	K > 1			
10 ³¹	start counting At 1.1 on IC-3			
11 ⁴⁰	Separate Shut Down	25.2	77.5	78

temp
Change Control from 84° to 90°

10 ⁴		27.55	82	83
	Change temp Control from 90° to 94°			
1 ⁴⁵		28.30	82.5	84
3 ⁴⁵		28.70	83.5	84 ⁺
4 ¹⁸		28.80	84	84.5

9 ²⁰ PM	3 July 66	29.2	84.5	86.3
--------------------	-----------	------	------	------

156 $\sqrt{3} F_4$ $H/K = 2.79$ Instrument Check on 7-5-66 Source 5 Mcv

PM-1	Low Trip	<input checked="" type="checkbox"/>	Alarm Trip	
PM-2				
IC-1	3×10^{-11}	<input checked="" type="checkbox"/>	Test Trip	<input checked="" type="checkbox"/>
IC-2	3×10^{-11}	<input checked="" type="checkbox"/>		
IC-3	Response	<input checked="" type="checkbox"/>	5gR	Red light <input checked="" type="checkbox"/>
IC-4	Response	<input checked="" type="checkbox"/>	5gR	Bldg Alarm <input checked="" type="checkbox"/>
CRM	Motor			Press Dif <input checked="" type="checkbox"/>

Purpose: temp. Coef Measurement

Exp. time		a	Temp #1	Recorders	
135 9 ¹⁵	K > 1	29.2	85	86.5	Exp. 9
9 ³⁰	$\frac{641}{5}$ Start counting At 20 on IC-3				
9 ⁴⁰	Separate				138 10
136 9 ⁵⁰	K > 1	29.2			
10 ⁰⁰	$\frac{641}{5}$ Start counting At 30 on IC-3				
10 ¹⁴	Separate				139
137 10 ¹⁹	K > 1	29.4	85	86.3	
10 ³⁰	$\frac{641}{5}$ Start counting At 35 on IC-3				
10 ⁴⁴	Separate - Shut Down				140
10 ⁴⁰	Set temp Control ON 86° 87°				
4 ⁰⁰	5 July 66	27.3	81.0	82.2	
8 ¹⁵	6 July 66	27.2	81.0	82.0	
4 ²⁰	6 July 66	27.0	80.8	82.0	

V(3) F₄ H_A = 279

157

Instrument Check on 7-7-66 Source 10mcY

PM-1	Low Trip	OK	Alarm Trip
PM-2			Alarm Trip
IC-1	$> 3 \times 10^{-11}$	Water Trip	OK
IC-2	$> 3 \times 10^{-11}$	Water Trip	OK
IC-3	Responds	Calibration	S/O.
IC-4	Responds out	Calibration	
CRM		Meter Trip	

Red light OK
Oldy alarm OK
Pulse diff. 0.05"

Temp Control Measurement

Expn Time
9⁵⁰

8 ¹⁰ AM	°C (the)	Rec. 1	Rec. 2
	27.0	81	82
	27.2	80.9°F	82.0°F

138 10⁰⁵ K > 1

10¹³ K < 1 Start counting at 30 on IC-3

10³⁷ Separate

139 10⁴⁸ K > 1

10⁵² K < 1 Start counting at ~32 on IC-3

11¹³ Separate

140 11¹⁸ K > 1

11²⁸ K < 1 Start counting at ~34 on IC-3

11⁵⁰ Shut Down

27.0 81°F 82°

11⁵⁷ Change temp control from 87° to 82°

2⁰⁰ PM operating for Public Relations movie.

3⁰⁰ K > 1

3²⁰ Shut down.

3⁵⁰ Change Temp control from 82° to 80°F

158

V(8) F4 H_k = 279

Temp

		°C	Rec #1	Rec #2
7-8-66	9 ¹⁵ AM	23.23	75.2	76
	12 ⁰⁰	23.5	75.4	76.2
	3 ⁴⁰ PM	23.4	75.0	76.1

Instrument Check on 7-11-66 Source 10 mCi

PM-1	Low Trip	OK	Alarm Trip	
PM-2			Alarm Trip	
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Red light OK
IC-3	Responds	Calibration	S.P.R.	Oldy. Alarm OK
IC-4	Out	Calibration		Para diff. 0.05"
CRM		Meter Trip		

Expn Time Temp Conf. measurement

		°C (ther)	Temp °F Rec #1	Rec #2
141	8 ³² K > 1	23.2	74.5	76.0

start counting at 0.7 on IC-3

8⁵⁵ Separate

142 9⁰⁰ K > 1

start counting at 0.15 on IC-3

9 ¹⁹	Separate - check temp	23.3	74.5	76.0
-----------------	-----------------------	------	------	------

143 9²¹ K > 1

9²⁶ start counting at 0.6 on IC-3

9⁴⁷ Separate

144 10⁰⁰ K > 1

10⁰¹ start counting at .5 on IC-3

10⁰³ Separate Shut Down


11 ⁰⁸		23.3	74.5	76.0
------------------	--	------	------	------

EUGENE DIETZEN CO.


Temp. Coef. $V(3) F_y$ in Paraffine $H/250V = 278.8$
 (Exp. 124 → 144)

EUGENE DIETZGEN CO.
 MADE IN U. S. A.

NO. 340-M DIETZGEN GRAPH PAPER
 MILLIMETER



160



Expt 145 Ch #2 with V^{235} (Top Pro) Pre Amp 696 = $9,239,295 / 45 \text{ min}$ 623.645
 Ch #4 with V^{238} , Pre Amp 694, (Bot. Pro) = $14,815 / 45 \text{ min}$ 16.03477×10^{-4}

Expt 146 Ch #2 with V^{238} (Bot. Pro) Pre Amp 696 = $14,135 / 45 \text{ min}$ 645.400
 Ch #4 with V^{235} (Top Pro) " " 694 = $9,122,735 / 45 \text{ min}$ 15.49426×10^{-4}

Expt 147 Ch #2 with V^{238} (Top Pro) = $14,555 / 45 \text{ min}$ 647.923
 Ch #4 with V^{235} (Bot Pro) = $9,386,855 / 45 \text{ min}$ 15.56573

Expt 148 Ch #2 with V^{235} (Bot Pro) = $9,306,185 / 45 \text{ min}$ 625.206
 Ch #4 with V^{238} (Top Pro) = $14,885 / 45 \text{ min}$ 16.99474

avg =
 $19.096 \text{ cm} \times 20.091 \text{ cm} \times 18.852 \text{ cm high}$
 Meas. Stack dimensions = $48.505 \text{ cm} \times 51.030 \text{ cm} \times 47.884 \text{ cm high}$

~ 75°F on Rec #2

V(3)F4 H/A #279

161

Instrument Check on 7-18-66 Source

10mK

PM-1	Low Trip	OK	Alarm Trip
PM-2			Alarm Trip
IC-1	7.3×10^{-4}	Meter Trip	OK
IC-2	7.3×10^{-4}	Meter Trip	OK
IC-3	Response	Calibration	S.P.R.
IC-4	out	Calibration	
CRM		Meter Trip	

Red light OK
Bldg alarm OK
Press diff. 0.06"

Purpose: To meas V^{235}/V^{238} fission ratios in center of cube.

Expn 145: Rone reattached top half of stack on fixed table and placed a $1/4$ " V^{235} fission ch. and a $1/4$ " V^{238} fission ch. in driving plane as shown on p. 160.
 Det #5-3 Det #8-2
 see p 40

Counting channel #2 - Amp. Y-140347, scalar Y-120247, Pre Amp. 696
" " #4 - Amp. Y-102541, scalar Y-120248, Pre Amp. 694

11⁰⁷ Start counting Power = 38.4 on 3×10^3 chs IC-2, 9.7 on IC-3

11⁵² Shut down

Expn 146: Swapped ~~the detectors~~ ^{Counting channels on detectors} left detector in same pos.
Ch #2 Pre AMP = 694 Ch #4 Pre AMP = 694

12³² start counting Power = 3.75 on 3×10^8 chs IC-2 9.8 on IC-3

1¹⁷ Shut down

Expn 147: Swapped detector pos.

1⁴⁴ start counting Power = 3.85 on 3×10^8 IC-2 10 on IC-3

2³⁰ Shut Down

Expn 148: Swapped counting ch. on detectors. Left det. in same pos.

3⁰² start counting Power = 3.82 on 3×10^8 IC-2 10 on IC-3

3⁴⁷ Shut Down

Used Plexiglas drive $7/8" \times 5 \times 5 1/2"$; ~ 1.5" out for b=1

162

V(3)F4 4/x = 279

Instrument Check on 7-21-66 Source 10mCv

PM-1	Low Trip	OK	Alarm Trip
PM-2			Alarm Trip
IC-1	3x10"	Meter Trip OK	East Trip OK
IC-2	3x10"	Meter Trip OK	Red light OK
IC-3	Response	Calibration 1/0	Old alarm OK
IC-4	Response	Calibration 1/0	Pres Diff. 0.05"
CRM	Meter Trip		

Purpose: To reassemble the stack used in Expts 72-82 and adjust detectors in preparation for measuring growth of support structure on this assembly.

Expt 149²¹⁵ 16x16x44" high
 b<1 w/o shims

2³⁰ Separate to Add Fuel 2" 16"x16"x46"
 b<1 ~7.4g
 3¹⁰ Separate Shut Down

15
15
15
15

Instrument Check on 7-22-66 Source 10 m_{CV}

PM-1	Low Trip	OK	Alarm Trip
PM-2			Alarm Trip
IC-1	> 3 x 10 ⁻¹¹	Meter Trip	OK
IC-2	> 3 x 10 ⁻¹¹	Meter Trip	OK
IC-3	Responds	Calibration	A/R
IC-4	Responds	Calibration	A/R
CRM		Meter Trip	

Purpose to measure width of support structure on tall desk

9 ¹⁵	16 x 16 x 46"			
9 ⁰⁸	b < 1	w/o shim		
9 ¹⁹	shut down to add 1" of fuel			
9 ³⁵	stack 16" x 16" x 47"			
9 ⁴⁷	R < 1 table sep 3.4" with shim			
	R > 1 " " 0.0" w/o shim			
9 ⁵⁰	Separate to move counters			Resistivities are averages of 3 counters and 1 h _N .
10 ¹²	b > 1 w/o shim 16 x 16 x 47"			P = 5.0834
10 ¹⁹	Start counting at 1.2 on IC-3.			
10 ³⁰	Separate			
10 ⁴⁵	b > 1 16 x 16 x 47" high + Al. boxes and steel plate on top			
	Start counting at .5 on IC-3			P = 6.8874
10 ⁴⁴	Separate to Remove Al Boxes AND Steel Plate			
10 ²⁰	R > 1 w/o shim			P = 4.3374
	Start counting at .5 on IC-3			
10 ⁴⁶	Separate			
10 ²⁵	R > 1 16" x 16" x 47" + Al Boxes AND steel 11" on top			P = 5.2084
10 ⁴⁹	Separate to Remove Al Boxes AND Steel Plate			
10 ¹⁰	R > 1 w/o shim			P = 4.4724
10 ³⁵	Shut Down Avg width of support structure = 1.4904 ± 0.737			

Instrument Check on 29 July 66 Source 10mCr

PM-1	Low Trip	OK	Alarm Trip
PM-2			Alarm Trip
IC-1	$> 3 \times 10^{-11}$	Meter Trip OK	Fast Trip OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip OK	Red light OK
IC-3	Response	Calibration	ply alarm OK
IC-4	Response	Calibration	Pres diff. 0.05"
CRM	Meter Trip		

Purpose to check counters and counting rates. Plan
 Expt 156 to run experiments in investigation of effect of Cd and paraffin
 shields on data from BF₃ detectors. Have 2 - 2" BF₃
 det. covered with Cd and paraffin and a 3rd 1/4" BF₃
 det. that will be used ~~run~~ with various Cd + paraffin
 shields.

- 1 ⁴⁵ b > 1 16x16x47" stack with plexiglass stem 15
- 2 ⁵⁰ b ≈ 1 sep. = 3.4 rev. " 15
- 2 ¹⁷ separate to add paraffin + Cd R x C-1 15
- 2 ²³ b > 1 15
- 2 ³² b ≈ 1 sep. = 3.4 rev. 16c
- 2 ³⁸ shut down

Expt
15
15
16c
16
16
16

V(3) F₄

H_X = 279

165

Instrument Check on 1 Aug 66 Source 10 m c_r

PM-1	Low Trip	OK	Alarm Trip
PM-2			Alarm Trip
IC-1	73×10^{-11}	Meter Trip OK	Fast Trip OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip OK	Red light OK
IC-3	Responds	Calibration S/O.	Chk down OK
IC-4	Responds	Calibration S/O.	Pres diff 0.05"
CRM	Meter Trip		

To check effect of Cd+ paraffin on period mean with DE₃ det.

Exp 15-7 9⁰⁰ AM $k > 1$ 16x16x47" stack with plexiglass above

check counters.

9¹⁹ start counting at 0.5 on IC-3 Det 1 in Cd lined paraffin
 shut down to check scaler on Ch. 2. Replaced scaler.

158 10⁴² start counting at ~0.7 on IC-3 Det 1 in Cd lined paraffin

159 11¹⁰ $k > 1$

11¹⁷ start counting at ~0.53 on IC-3 Det 1 bare

11³⁰ shut down Det. 1 may have moved during run

160 12⁴² $k > 1$ Det 1 in Cd lined paraffin

12⁵⁷ start counting at ~0.5 on IC-3

1¹⁰ shut down

161 1²⁵ $k > 1$ Det 1 bare

1³¹ start counting at ~0.5 on IC-3

1⁴³ shut down

162 1⁵⁰ $k > 1$ Det 1 in Cd lined paraffin.

2⁰⁰ start counting ~0.5 on IC-3

2¹² shut down

163 2²⁵ $k > 1$ Det 1 bare.

2³⁶ start counting ~0.5 on IC-3

2⁴⁷ shut down

Instrument Check on 2 Aug 66 Source 10m cK

PM-1	Low Trip	OK	Alarm Trip
PM-2			Alarm Trip
IC-1	> 3x10 ⁻¹¹	Meter Trip	OK
IC-2	> 3x10 ⁻¹¹	Meter Trip	OK
IC-3	Responds	Calibration	S/O
IC-4	Responds	Calibration	S/O
GRM		Meter Trip	

Have restacked blocks to make 32"x32"x12" high assembly

Exp

164 12⁴⁶ b < 1 with 8 1/2 x 15 1/2 x 1" plexiglass shim.
 added 1/4" on SW and NE quadrants



165 1¹⁰ b > 1 } with 8 1/2 x 15 1/2 x 1" plexiglass
 b > 1 } sep ~ 1.7 rev. w/o plexiglass

b > 1 Table closed w/o plexiglass
 166 1⁴⁵ b > 1 removed 1/4" from NE quadrant
 with plexiglass



2¹¹ b < 1 w/o plexiglass

Shut down to change plexiglass shim

167 2²⁵ K > 1 with Plexyglass

2³² K < 1 w/o Plexyglass

2⁵⁰ Shut Down

168

169

170

171

V(3) F₄ $k/x = 279$


167


Instrument Check on 5 Aug 66 Source 10 mck


PM-1	Low Trip	OK	Alarm Trip
PM-2			Alarm Trip
IC-1	73×10^{-11}	Meter Trip	OK
IC-2	73×10^{-11}	Meter Trip	OK
IC-3	Response	Calibration	N/A.
IC-4	Response	Calibration	N/A.
CRM		Meter Trip	

St. Perturbation meas. on short stack.


added $\frac{1}{4}$ " to NE quad. $32 \times 32 \times 12$ + $\frac{1}{4}$ " in shaded area

168 9^{40} $k > 1$ with large flexiplas 
 $k = 1$ separ. \sim check counters

169 10^{70} 1^{35} $k > 1$ Shut Down moved det on C-2 + C-4 down to assembly
 Start counting at ~ 0.5 on IC-3 

170 1^{50} 2^{00} $K < 1$ Shut Down $P = 10.7204$ Avg of 2 counters + 1 h.N.
 Removed $\frac{1}{4}$ " from SW quad. 

7 Start counting at ~ 35 on IC-3 $P = -12.7384$

171 2^{28} 3^{35} $k > 1$ Shut Down added $\frac{1}{4}$ " on SW quad.
 Start counting at ~ 0.5 on IC-3 

3^{50} Shut Down $P = 10.6576$

168

v(3) F_y H/x = 279


Instrument Check on 8 Aug 66 Source 10 mCk

PM-1	Low Trip	OK	Alarm Trip
PM-2			Alarm Trip
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK
IC-3	Response	Calibration	s/p R. Red light OK
IC-4	Response	Calibration	s/p R. Rly Alarm OK
CRM		Meter Trip	Priso. Diff. 0.05"


HT Perturbation Meas. on short stack

32" x 32" x 12" + 1/4" on shaded quadrants


N

172 $\frac{9^{14}}{36}$ $b > 1$ $P_1 = 9.839$ $P_2 = 10.074$ $P_3 = 10.070$ $P_4 = 10.063$ } $P_{avg} = 10.012$ 

Separate

173 $\frac{9^{28}}{36}$ $b > 1$ with shim $P_1 = -13.091$ $P_2 = -13.872$ $P_3 = -13.675$ $P_4 = -13.662$ } $P_{avg} = -13.578$ 


$b < 1$ start counting at ~ 68.45 on IC-3

174 $\frac{10^{06}}{17}$ $b > 1$ $P_1 = 8.910$ $P_2 = 9.102$ $P_3 = 9.218$ $P_4 = 9.264$ } $P_{avg} = 9.124$ 


$b > 1$ start counting at ~ 0.5 on IC-3

175 $\frac{10^{32}}{47}$ $b > 1$ with shim $P_1 = -13.775$ $P_2 = -13.996$ $P_3 = -14.326$ $P_4 = -14.089$ } $P_{avg} = -14.044$ 


$b < 1$ start counting at ~ 49 on IC-3

176 $\frac{11^{04}}{25}$ $K > 1$ $P_1 = 8.483$ $P_2 = 8.657$ $P_3 = 8.779$ $P_4 = 8.980$ } $P_{avg} = 8.724$ 

$b > 1$ start counting at ~ 0.5 on IC-3

177 $\frac{11^{32}}{40}$ $K > 1$ with shim $P_1 = -14.507$ $P_2 = -14.677$ $P_3 = -15.013$ $P_4 = -15.190$ } $P_{avg} = -14.847$ 

$b < 1$ start counting at ~ 40 on IC-3

178 $\frac{12^{29}}{50}$ $K > 1$ with shim $P_1 = -14.507$ $P_2 = -14.677$ $P_3 = -15.013$ $P_4 = -15.190$ } $P_{avg} = -14.847$ 

Separate

178


179


180


181


182


Temp ~ 74.1 °F from therm by 12" from top
 ~ 75 °F on recorder in NW corner of room. 169

178 1⁰⁵ K > 1 $P_1 = 7.149$ $P_3 = 7.918$
 1¹⁴ b > 1 Start counting at ~ 0.5 on IC-3 $P_2 = 7.002$ $P_N = 7.034$ 
 1²³ Separate

179 1³⁵ b > 1 with shim
 1⁵⁴ b < 1 Start counting at ~ 40 on IC-3 
 2⁰⁴ Separate $P_1 = -15.995$ $P_3 = -15.429$
 $P_2 = -15.822$ $P_N = -15.435$

180 2¹⁵ K > 1 $P_1 = 7.246$ $P_3 = 7.235$
 2²⁶ b > 1 Start counting at ~ 0.5 on IC-3 $P_2 = 7.295$ $P_N = 7.380$ 
 2³⁷ Separate

181 2⁴⁵ K > 1 with shim $P_1 = -15.719$ $P_3 = -15.926$
 b < 1 Start counting at ~ 40 on IC-3 $P_2 = -16.341$ $P_N = -15.759$ 
 3¹⁹ Separate

182 3³⁵ b > 1 $P_1 = 7.166$ $P_3 = 7.122$
 3⁴³ b > 1 Start counting at ~ 0.5 on IC-3 $P_2 = 7.222$ $P_N = 7.244$ 
 3⁵⁴ Separate Shut Down

Stab (3) - F $32.168m \times 72.149m \times 12.23cm$
 Measured Stab Dimensions $\rightarrow (81.706cm \times 81.658cm \times 30.556cm)$
 cm high

170 Temp ~ 75°F on recorder in NW corner

U(3) F₄ H_{1/2} = 279

Instrument Check on 9 Aug 66 Source 10 mct

PM-1	Low Trip	OK	Alarm Trip
PM-2			Alarm Trip
IC-1	> 3x10 ⁻⁴	Meter Trip	OK
IC-2	> 3x10 ⁻⁴	Meter Trip	OK
IC-3	Responds	Calibration	1/4 R. Bldg alarm OK
IC-4	Responds	Calibration	1/4 R. Pres Diff. 0.05"
CRM		Meter Trip	

To mess worth of support structure on 32"x32"x12" stack.

Eff.

183

10²²

k > 1

P_i = 7.140

P_s = 7.4129

P_N = 7.329

P_N = 7.1739

12 1/4" fuel. on shaded areas.

Start counting at ~ 0.5 on IC-3



10³⁹

Separate


184

11²⁵

Remove 1/4" from 1/2 of stack and add Al Boxes + 1" steel P.

11³⁵

K > 1 Start counting at ~ 0.5 on IC-3



11⁴⁰

Shut Down

P_i = 37.228

Repeat P_i = 36.929

P_N = 37.780

P_N = 37.441

185

12⁴²

Same as 184

k > 1 Start counting at ~ 0.5 on IC-3

k = 1 Table sep. = 2.9 rev.

186


1⁴²

Removed support mock-up and added 1/4" of fuel on 2 prod.

k > 1 Start counting at ~ 0.5 on IC-3

1⁵²

Table screamed because IC-2 was not advanced as power increased.



2¹⁰

k > 1 Start counting at ~ 0.5 on IC-3

P_i = 7.258

P_s = 7.273

P_N = 7.326

P_N = 7.436

2²⁸

Separate


187

2⁵⁰

removed 1/4" fuel from 2 prod. K > 1 Start counting at .5 on IC-3

P_i = 37.642


P_N = 38.127



2⁵⁴

Separate

188 3¹⁰ K > start counting at 0.5' on LC-3
 3¹⁵ Shut Down (188) same as 187, $P_1 = 37.650$
 $P_N = 37.790$

189 3³⁵ Removed Al Boxes and steel Plate, Added 
 1/4" fuel to 2 quad. $b > 1$
 3⁵⁵ Shut Down $P_1 = 6.681$ $P_3 = 6.601$
 $P_2 = 6.693$ $P_N = 6.786$

Instrument Check on 11 Aug 66 Source 10 mcT

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Red light	OK
IC-3	Repeats	Calibration	1/2	Bldy alarm	OK
IC-4	Repeats	Calibration	1/2	Press diff.	0.06"
CRM		Meter Trip			

To meas react. no. Table separation for hazards analysis report.

190 9³³ 32x32x12" plus 1/4" on shaded area
 b>1 Table closed start counting at 0.5 on IC-3.



9⁵⁰ Separate

191 10⁰⁵ Remove 1/4" from NE quad. And Add 1/4" to SW quad.
 b>1 Table closed



1/2" blocks on top

10²⁸ Separate


192 10⁴⁰ Add 1/4" to NE quad
 10⁴⁴ Table closed. b>1 start counting at 0.5 on IC-2



b>1 separate =
 R=1 Table Sep. 3.30 rev.


10⁵⁷ Separate

193 11¹³ b>1 Add 1/4" to SE quad.
 b=1 Table Sep. = 3.52 rev.



11³⁰ Separate

194 add 1/4" fuel to NW quad
 1⁰⁰ b>1 Table sep = 3.52 rev.
 b=1 " " = 4.50 rev.



1" separate

195 Removed 1/4" from NE quad and replaced with 1/2"

1:25 b > 1 table sep. = 4.5 rev

b = 1 table sep. = 5.35 rev

N	
+1/4	+1/2
+1/2	+1/4

1:37 Separate

196 1:50 Removed 1/4" from NW quad and Replaced with 1/2"

b > 1 table sep = 5.35 rev.

b = 1 table sep = 6.30 rev.

N	
+1/2	+1/2
+1/2	+1/4

~~197~~ 2:05 Separate

197 added 1/4" to SE quad.

2:18 b > 1 table sep = 6.30 rev.

b = 1 table sep = 7.11 rev.

N	
+1/2	+1/2
+1/2	+1/2
	+3/4

← var sized pieces

2:31 Separate

198 added 1/4" to NE quad

2:41 b > 1 table sep = 7.11 rev.

b = 1 table sep = 7.98 rev.

+1/2	+1/2
+1/2	+1/4
+1/2	+3/4

2:56 Separate

199 added 1/4" to SW quad

3:10 b > 1 Table sep. = 7.98 rev

b = 1 Table sep. = 8.70 rev.

b > 1 to increase power

b < 1 table sep = 9.00 rev.

+1/2	+1/2 + 1/4
+1/2 + 1/4	+1/2
	+3/4

3:45 Shut Down

Instrument Check on 3 Nov. 67 Source: 10. m. scat

PM-1	Low Trip	OK	Alarm Trip	Would not trip at 8.50V
PM-2	Alarm Trip			
IC-1	Meter Trip	OK 1"	Fast Trip	OK 1/2"
IC-2	Meter Trip	OK 1"	Red light	OK
IC-3	Calibration	OK JT	Bld. alarm	OK
IC-4	Calibration	OK JT	Press. Diff.	0.1"
CRM	Meter Trip			

Temp 21.6 °C

82

Stack same as Expt 79
2 Cd covered and 2 bare 1 mil gold foils10²⁹ AM

Start timing at 10 on IC-3

k=1 at 30 on IC-3

10⁵⁹ AM

Shut down

Position	1	2	3	4
	401 Cd	403	404 Cd	409
		2/1 = 3.95469		4/1 = 3.87520
		2/3 = 3.93950		4/3 = 3.81938

avg Cd Ratio = 3.89719

83

Stack same as Expt 79
15 bare 2 mil gold foils1⁰² PM

Start timing at 3.5 on IC-3

4

k=1 at 10.5 on IC-3

1³² PM

Shut down

Instrument Check on 2-19-67 Source 10 mct

PM-1	Low Trip	OK	1/2"	Alarm Trip	OK	Cont.
PM-2				Alarm Trip		
IC-1	Meter Trip	OK	1"	Fast Trip	OK	1/2"
IC-2	Meter Trip	OK	1"			
IC-3	Response	Calibration	S/O	OK	Red light	OK
IC-4	Response	Calibration	S/O	OK	Red Alarm	OK
CRM	Meter Trip				Press Dif	0.13"

84 Stock same as Expt 79.

2 cd covered and 2 bare. 2 mil gold foil

9⁰³ AM Start timing at 5.5 on IC-3

h=1 at 16 on IC-3

9⁴³ AM Shut down.

Position	1	2	3	4
	G-2 cd	G-3	G-4 cd	G-8
		2/1 = 4.71995		4/1 = 4.67770
		2/3 = 4.70610		4/3 = 4.67115
		Avg cd Ratio = 4.69372		

85 Same as Expt 84

2⁰² Start timing at 5.5 on IC-3

h=1 at 16 on IC-3

2⁴² Shut down

1	2	3	4
G-13 cd	G-14	G-21 cd	G-25
	2/1 = 4.72859		4/1 = 4.70854
	2/3 = 4.72409		4/3 = 4.64801

avg cd Ratio = 4.70231

Instrument Check on 22 Nov. 67 Source 10³ mCt

PM-1 Low Trip OK 1/2" Alarm Trip OK Contact
 PM-2 Alarm Trip OK Contact
 IC-1 Meter Trip OK 1" Fast Trip OK 1/2"
 IC-2 Meter Trip OK 1"
 IC-3 Responds Calibration OK S.F.R. Red light OK
 IC-4 Responds Calibration OK S.F.R. Rddy alarm OK
 CRM Meter Trip OK S.F.R. Pass. d/y 0.12"

22.0 °C

86 Stack same as Expt 79

15 bare 2 mil gold foils across center

9⁰⁰ AM Start timing at 3.5 on IC-3

k=1 at 10.5 on IC-3

9³⁰ AM. Shut down

87 Stack same as Expt 79

2 cd covered and 2 bare 5 mil gold foils

1⁰⁹ PM. Start timing at 3.5 on IC-3

k=1 at 10 on IC-3

1³⁹ PM. Shut down

Position	1	2	3	4
	504 cd	502	503 cd	505
		$\frac{2}{1} = 5.88444$		$\frac{4}{1} = 5.81029$
		$\frac{2}{3} = 5.87214$		$\frac{4}{3} = 5.81920$

avg. cd Ratio = 5.84652

190

U(2) F₄ - 6

Instrument Check on 24 Nov 67 Source 10 mc V

PM-1	Low Trip	OK - 1/2"	Alarm Trip	OK - Cont
PM-2				
IC-1	Meter Trip	OK - 1"	Fast Trip	OK - 5/12"
IC-2	Meter Trip	OK - 1"		
IC-3	Response	Calibration OK - 1/2"	Red light	OK
IC-4	Response	Calibration OK - 1/2"	Bkg alarm	OK
CRM	Meter Trip		Press Def	0.12"

21.8°C

88 Stack same as Expt 79

2 Cd covered and 2 bare 5 mil gold foils

9²⁰ AM Start timing at 3.5 on IC-3
b=1 at 10 on IC-39⁵⁰ AM Shut down

Position	1	2	3	4
	504 Cd	507	509 Cd	510
		2/1 = 5.92270		4/1 = 5.84150
		2/3 = 5.84596		4/3 = 5.78603

Avg Cd Ratio = 5.84905

89. Stack same as Expt 79

15 bare 2 mil gold foils

1²⁵ PM Start timing at 3.5 on IC-3

b=1 at 10 on IC-3

1⁵⁵ PM Shut down

Instrument Check on 27 Nov. 67 Source 10mCi

PM-1	Low Trip	OK 1/2"	Alarm Trip	OK Cont.
PM-2			Alarm Trip	
IC-1	Meter Trip	OK 1"	Fast Trip	OK 1/2"
IC-2	Meter Trip	OK 1"	Red. light	OK
IC-3 <i>Response</i>	Calibration	OK S/R.	Bldg Alarm	OK
IC-4 <i>Response</i>	Calibration	OK S/R.	Pressure	0.12"
CRM	Meter Trip			

21.9 °C

90 ~~90a~~ Have restacked material on fixed table and inserted a 1/4" dia V²³⁵ fission detector No. 5-3, and a 1/4" dia V²³⁸ fission detector No. 8-2 on vertical axis of assembly separated vertically by 3 1/2" of fuel.

Trial run to check reactivity. Stack 32x34x34 on fixed ^{34x4 on movable.}

k < 1

90b added 1/4" less 1/4 x 4 x 20' on fixed table.

k = 1 with shim out ~ 5"

90c Have counter connected. Start up to check counters.

^{k=1} V²³⁵ counter not working. Shut down.

90d ~~90d~~ Start up to check counters:

k = 1 at 0.5 on IC-3


Both counters working. ~ 2000 cpm on V²³⁵ fission U at this power. Shut down.

Instrument Check on 307 Nov. 67 source 10 mCi

PM-1	Low Trip	OK	1/2	Alarm Trip	OK	S-Cond.
PM-2						
IC-1	Meter Trip	OK	1"	Fast Trip	OK	1/2"
IC-2	Meter Trip	OK	1"	Red light	OK	
IC-3	Calibration	OK	JTT	Bldg. Alarm	OK	
IC-4	Calibration	OK	JTT	Pulse Diff	MSD	0.12"
CRM	Meter Trip					

21.1 °C

91 To measure U^{235} to U^{238} fission ratios
 by 1/4" fission detector 5-3 and 8-2 in central plane
 of assembly on vert. axis as shown in sketch below



Channel #4 PreA. 696 → Amp. Y102541 → scaler Y120243
 Channel #2 PreAmp. 694 → Amp. Y140347 → scaler Y120247

Stack 32 x 34 x 34" high + 1/4 x 8 x 34 across center of top.

$h=1$ at 0.55 on IC-3; $24 \text{ m} \times 10^{-9}$ scale on IC-2 193

Exp 91a

$$\left. \begin{array}{l} \text{Ch \# 2 - } V^{235} \text{ on top} = 10,311,025 / 75 \text{ min} \\ \text{Ch \# 4 - } V^{238} \text{ on bottom} = 6,095 / 75 \text{ min} \end{array} \right\} \text{Ratio} = 1691.719$$

91b

$$\left. \begin{array}{l} \text{Ch \# 4 - } V^{235} \text{ on top} = 10,170,975 / 75 \text{ min} \\ \text{Ch \# 2 - } V^{238} \text{ on bottom} = 6,095 / 75 \text{ min} \end{array} \right\} = 1668.741$$

91c

$$\left. \begin{array}{l} \text{Ch \# 2 - } V^{238} \text{ on top} = 4,535 / 60 \text{ min} \\ \text{Ch \# 4 - } V^{235} \text{ on bottom} = 7,778,265 / 60 \text{ min} \end{array} \right\} = 1715.163$$

91d

$$\left. \begin{array}{l} \text{Ch \# 4 - } V^{238} \text{ on top} = 4,975 / 60 \text{ min} \\ \text{Ch \# 2 - } V^{235} \text{ on bottom} = 8,365,925 / 60 \text{ min} \end{array} \right\} = 1681.593$$

Background $\sim \frac{55}{937 \text{ min}}$ on V^{235} ch
 $\sim \frac{9}{937 \text{ min}}$ on V^{238} ch.

Avg Ratio = 1689.3

7

Top

Instrument Check on 1 Dec 67 Source 10 mCk

PM-1	Low Trip <u>OK 1/2"</u>	Alarm Trip <u>OK Cont</u>
PM-2		Alarm Trip
IC-1	Meter Trip <u>OK 1"</u>	Fast Trip <u>OK 1/2"</u>
IC-2	Meter Trip <u>OK 1"</u>	Red light <u>OK</u>
IC-3 <u>Responds</u>	Calibration <u>OK 1/R</u>	Bldg alarm <u>OK</u>
IC-4 <u>Responds</u>	Calibration <u>OK 1/R</u>	Ratio Diff. <u>0.12"</u>
CRM	Meter Trip	

21.0°C

Epp

92 Stop
Same as Epp 91. Repeat of V^{235} : V^{238} fixation ratio meas.
K=1 at 0.9 on IC-3 and 35.5 on 3×10^{-9} scale on IC-2

92a Ch #4 - V^{238} on top = 8625/70min } 1668.405
Ch #2 - V^{235} on bottom = 14,389,995/70min }

92b Ch #2 - V^{238} on top = 8585/70min } 1677.0
Ch #4 - V^{235} on bottom = 14,397,095/70min }

92c Ch #4 - V^{235} on top = 14,584,035/70min } 1675.4
Ch #2 - V^{238} on bottom = 8705/70min }

92d Ch #2 - V^{235} on top = 13,564,715/65min } 1679.8
Ch #4 - V^{238} on bottom = 8075/65min }

Avg Ratio = 1675.75 -

Data from run 91 probably better because there would be fewer lost counts in ^{235}V detector at lower power.

Instrument Check on 8 Dec 67 Source 10 m c Y

PM-1	Low Trip	OK $\frac{1}{2}$ "	Alarm Trip	OK Cont.
PM-2			Alarm Trip	
IC-1	Meter Trip	OK $\frac{1}{2}$ "	Fast Trip	OK Cont.
IC-2	Meter Trip	OK 1"	Red light	OK
IC-3	Calibration	OK Conf. for repair	Chg Alarm	OK
IC-4	Responds	Calibration OK S/O.	Press Diff	0.12"
CRM	Meter Trip			

21.9°C

- Expt. 93 Have restacked material with a 30"x30" base
 16" on moveable table and 14" on fixed table.
 44" high $b \approx 1$ with 2 pieces of plexiglas.
 $b < 1$ no plexiglas
- 94 46" high $b > 1$ with 2 piece of plexiglas
 $b < 1$ w/o plexiglas ~-326 sec.
- 95 47" high $b > 1$ no plexiglas
- Check counters
 C-1 \rightarrow U²³³ det. near center on east side
 C-3 \rightarrow $\frac{1}{2}$ " BF₃ Cd, Pappin Shields, on balcony.
 C-4 $\frac{1}{4}$ " BF₃ in cable rack
- 96 47" high 30"x30" base
 $b > 1$
- 97 30x30x46" high
 $b < 1$
- 98 30x30x47" high
 $b > 1$
- 99 30x30x46" high
 $b < 1$

8 Dec 67 Cont.

100 30 x 30 x 47" high

p > 1

Instrument Check on 11 Dec 67 Source 10mc

PM-1	Low Trip	OK 1/2	Alarm Trip	OK Contact
PM-2			Alarm Trip	
IC-1	Meter Trip	OK 1/2"	Fast Trip	OK Cont.
IC-2	Meter Trip	OK 1"	Red Light	OK
IC-3	Response Out	for repair	Blk Alarm	OK
IC-4	Response	Calibration OK	Pure Diff	0.12"
CRM	Meter Trip			

22.5 °C

101 30 x 30 x 47" high

Have lost ~ 2% reactivity from run 100 because of increase in temp. Shut down to add 1/4" of fuel.

102 30 x 30 x 46 1/4" high

p < 1

103 30 x 30 x 47 1/4" high

p > 1

104 30 x 30 x 46 1/4" high

p < 1

11:25 AM
22.5 °C

105 30 x 30 x 47 1/4" high

p > 1

106 30 x 30 x 46 1/4" high

p < 1

107 30 x 30 x 47 1/4" high

p > 1

108 30x30x46¹/₄" high
b < 1

109 30x30x47¹/₄" high
b > 1

110 30x30x46¹/₄" high
b < 1

111 30x30x47¹/₄" high
b > 1

Instrument Check on 12 Dec 67 Source 10 mCt

PM-1	Low Trip	OK 1/2"	Alarm Trip	OK Contact
PM-2			Alarm Trip	
IC-1	Meter Trip	OK 1/2"	Fast Trip	OK Cont.
IC-2	Meter Trip	OK 1"	Red light	OK
IC-3	Calibration		Redy alarm	OK
IC-4	Calibration	OK 1/2"	Press Dif.	0.12"
CRM	Meter Trip			

21.9°C

112 30x30x47 1/4" high

b > 1

113 30x30x46 1/4" high

b < 1

114 30x30x47 1/4" high

b > 1

115 30x30x46 1/4" high

b < 1

116 30x30x47 1/4" high

b > 1

117 30x30x46 1/4" high

b < 1

118 30x30x47 1/4" high

b > 1

119 30x30x46 1/4" high

b < 1

nom. 30x30x46 1/4"

9 Mes Dims 76.500 x 76.450 x 117.571 cm high

10:30
21/5

Instrument Check on 13 Dec 67 Source East District

PM-1	Low Trip	OK $\frac{1}{2}$ "	Alarm Trip	OK Cont.
PM-2			Alarm Trip	S-42
IC-1	Meter Trip	OK $\frac{1}{2}$ "	Fast Trip	OK Cont-31
IC-2	Meter Trip			Red light-310K
IC-3	<u>Responds</u> Calibration			Red alarm-310K
IC-4	<u>Responds</u> Calibration			Press Diff-310.12"
CRM	Meter Trip			350

21.2°C

120 30x30x46 $\frac{1}{4}$ " + support mock-up on top (mock-up consists of $\frac{1}{8}$ " of Al, 5 layers of Al tape and 1" stuffed)

b < 1

10:30 AM
21:50

121 Removed support mock-up. 30x30x46 $\frac{1}{4}$ "

b < 1

122* 30x30x46 $\frac{1}{4}$ " Replaced support mock-up.

b < 1

123 30x30x46 $\frac{1}{4}$ " Removed support mock-up.

b < 1

124* 30x30x46 $\frac{1}{4}$ " Replaced s. mock-up.

b < 1

125* ~~125~~ 30x30x46 $\frac{1}{4}$ " Removed s. mock-up.

b < 1

* Some blocks were moved slightly each time mock-up was placed on stack. No adjustments were made between runs 120-121, 122-123, or 124-125.

The stack was tightened up at points marked *

Instrument Check on 14 Dec 67 Source ^{new} 10 m.c.f

PM-1	Low Trip	OK $\frac{1}{2}$ "	Alarm Trip	OK Cont
PM-2			Alarm Trip	S-M7
IC-1	Meter Trip	OK $\frac{1}{2}$ "	Fast Trip	OK I-31
IC-2	Meter Trip	OK 1"	Red light	OK
IC-3	Response Calibration	OK 1/4"	Bldg alarm	OK
IC-4	Response Calibration	OK 1/4"	Probe dif.	0.12"
CRM	Meter Trip			

126 Have removed fuel down to 36" and reflected with 6" of plexiglas in top under assembly and 6" of polyethylene on side and top.
 Moved IC-2 to just outside refl at SW corner.
 Placed V^{233} counter inside refl 3" from bottom.
 BF₃ det on top of refl at side.
 $b > 1$ at ~ 6.45 rev.

127 30x30x35" high refl.
 $b > 1$ at 6.0 rev.
 $b = 1$ at 7.1 rev.

Instrument Check on 15 Dec 67 source 10 m c r

PM-1	Low Trip	OK $\frac{1}{2}$ "	Alarm Trip	OK Conf.
PM-2			Alarm Trip	
IC-1	Meter Trip	OK $\frac{1}{2}$ "	Fast Trip	OK
IC-2	Meter Trip	OK 6" from band	Red light	OK
IC-3	Responds Calibration	OK 1/2"	Bldg. Alarm	OK
IC-4	Responds Calibration	OK 1/2"	Press Dif	"0.12"
CRM	Meter Trip			

21.6° C

128 30x30x34" high Refl as in #126.

h > 1 at 3.3 rev.

h = 1 at 5.3 rev.

129 30x30x33" high Reflected

h > 1 stable load

130 30x30x32 $\frac{3}{4}$ " high Reflected

h > 1

131 30x30x32 $\frac{1}{2}$ " high Reflected

h > 1

21.6° C at 4:30 PM

Nominal dimen 30x30x32 $\frac{1}{2}$ "

9 Meas dimen = 76.508 x 76.444 x 82.577 cm high

Instrument Check on 18 Dec 67 Source 1.0 mCi

PM-1	Low Trip	OK $\frac{1}{2}$ "	Alarm Trip	OK Comp
PM-2			Alarm Trip	OK
IC-1	Meter Trip	OK $\frac{1}{2}$ "	Fast Trip	OK 1-2
IC-2	Meter Trip	OK 1"	Red light	OK
IC-3	Responds	Calibration OK 1 P.A.	Oldy alarm	OK
IC-4	Responds	Calibration OK 1 P.A.	Pres diff	0.12'
CRM	Meter Trip			

21.5°C

- 132 Have reattached fuel.
Now 40" x 40" base 26" high Base
 $b > 1$
- 133 40 x 40 x 26" high less $\frac{1}{4}$ " on $\frac{1}{2}$ "
 $b < 1$
- 134 40 x 40 x 26" + $\frac{1}{4}$ " on $\frac{1}{2}$ "
 $b > 1$

Instrument Check on 19 Dec 67 Source 10mCr

PM-1	Low Trip	OK $\frac{1}{2}$ "	Alarm Trip	OK Cont.
PM-2	High		Alarm Trip	
IC-1	Meter Trip	OK $\frac{1}{2}$ "	Fast Trip	OK
IC-2	Meter Trip	OK 1"	Red Light	OK
IC-3	Responds	Calibration OK 1/4 R	Old Alarm	OK
IC-4	Responds	Calibration OK 1/4 R	Pres Diff	0.12"
CRM	Meter Trip			

22.4°C

135 40x40x26 + $\frac{1}{4}$ " on S half.

b > 1

136 40x40x26 less $\frac{1}{4}$ " on S half.

b < 1

137 40x40x26 + $\frac{1}{4}$ " on S half.

b > 1

138 40x40x26 less $\frac{1}{4}$ " on S half.

b < 1

139 40x40x26 + $\frac{1}{4}$ " on S half.

b > 1

140 40x40x26 less $\frac{1}{4}$ " on S half.

b < 1

141 40x40x26 + $\frac{1}{4}$ " on S half.

b > 1

142 40x40x26 less $\frac{1}{4}$ " on S half.

b < 1

22.6°C

4:30 PM

Instrument Check on 20 Dec 67 Source 70 mcr

FM-1	Low Trip	OK $\frac{1}{2}$ "	Alarm Trip	OK - Cont.
FM-2			Alarm Trip	OK
IC-1	Meter Trip	OK $\frac{1}{2}$ "	Fast Trip	OK
IC-2	Meter Trip	OK 1"	Red light	OK
IC-3	Responds	Calibration OK 1/R	Blk Alarm	OK
IC-4	Responds	Calibration OK 1/R	Press Dif	0.12"
CRM	Meter Trip			

22.9°C

- 143 40x40x26" + $\frac{1}{4}$ " on S. half.
b > 1
- 144 40x40x26 less $\frac{1}{4}$ " on S half.
b < 1
- 145 40x40x26 + $\frac{1}{4}$ " on S half.
b > 1
- 146 40x40x26 less $\frac{1}{4}$ " on S half.
b < 1
- 147 40x40x26 + $\frac{1}{4}$ " on S half.
b > 1
- 148 40x40x26 less $\frac{1}{4}$ " on S half.
b < 1
- 149 40x40x26 + $\frac{1}{4}$ " on S half.
b > 1
- 150 40x40x26 less $\frac{1}{4}$ " on S half.
b < 1

22.9°C

Nominal Dimens 40x40x26'
 Meas Dimens 101.971 x 101.850 x 66.057 Cms

Instrument Check on 21 Dec 67 Source 10mck

PM-1	Low Trip	OK $\frac{1}{2}$	Alarm Trip	OK Cont
PM-2			Alarm Trip	
IC-1	Meter Trip	OK $\frac{1}{2}$ "	Fast Trip	OK
IC-2	Meter Trip	OK 1"		Red light OK
IC-3	<u>Response</u> Calibration	OK S.P.R.		Bldg alarm OK
IC-4	<u>Response</u> Calibration	OK S.P.R.		Pres. Dif 0.12"
CRM	Meter Trip			

22.7°C

- 151 40x40x26 less $\frac{1}{4}$ " on N half.
Have added support brace up on top of assembly
b > 1
- 152 40x40x26 less $\frac{1}{4}$ " on N half (Removed S.S.)
b < 1
- 153 40x40x26 less $\frac{1}{4}$ " on N half + S.S.
b > 1
- 154 40x40x26 less $\frac{1}{4}$ " on N half. (Removed S.S.)
b < 1

Instrument Check on 28 Dec 67 Source 10 mct

PM-1 Low Trip OK $\frac{1}{2}$ " Alarm Trip OK Cont
 PM-2 Alarm Trip 1-21
 IC-1 Meter Trip OK $\frac{1}{2}$ " Fast Trip OK-M7
 IC-2 Meter Trip OK 1" Red-light OK
 IC-3 Response Calibration OK 11R Bldg Alarm OK
 IC-4 Response Calibration OK 14R Pres Dif. 0.12
 CRM Meter Trip

~19°C at 9 AM ~20.3°C at set of 155

155 ¹⁵⁴ Have restacked 32" x 34" base with a 2 x 5 x 6" cavity in center of fixed table.

Placed 2 parallel flat plexiglass in cavity with 1 1/4" x 4" x 6" of fuel behind them.

34" high.

b > 1 with plexiglass (one piece)

b < 1 without

156

34" high + 1/4" on half.

b > 1 with plexi. (2 pieces)

b < 1 w/o plexi. ~ -11.9¢


157

added 1/2"

Now 32 x 34 x 34 1/2" high + 1/4 x 16 x 34" across center of top.

b > 1 w/o plexi. ~ 3.6¢ pos.

Restacked to 32 x 34" base fifth two fusion counters
in assembly



TOP VIEW

cavity 6" wide x 3/4" deep

1/4" Top layer 8" x 16"

PRE
AMP

AMP

C-1 FC-7 (238) - Y

Y102542

X64 x 24

Top.

Instrument Check on 1-2-68 Source 10 mC

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	Meter Trip	OK	Fast Trip	OK
IC-2	Meter Trip	OK	Run Press	-0.14" H ₂ O
IC-3	Calibration	3×10^{-11}	Red Light	(On)
IC-4	Calibration	8×10^{-11}	Temp	21°C
CRM	Meter Trip		Bld. Alarm	A OK B OK C OK

158 L

excess react (init period with ~~both~~ both pleuriges skims 4167.95 → 650)

11⁴⁰ Start count for 1 hr

	C-1 - FC-7(238)	C-2 - FC-9(235)	@ -400 V NICE
PHS 300	5473 (109)	9697 190	300
300	4631 (300)	9111.725 (300)	1967.6
200	4783	10386.535	2161.1
100	5212	10468.835	2008.6

Jan 3 9¹⁵ Background counts in 20 minutes

PHS	100	127 or 6.35 MIN	20.5	
		3	5	
		381	6.5	
		4831	10,468.200	2166.9
9 ⁴⁰	200	000	15	
	150			

PHS	C-1(238-7)	Bh ₁	C-4(235-9)	#160	C ₃	C _{1/C₃}	C _{1/C₂}
100 200 300	5212 - 391 = 48231		10,468,835				2167
	4783 - 0		10,336,535				2161
	4631 - 0		9,111,725				1968
	C ₄ 235-9		C ₁ 238-7			C _{1/C₃}	
100	45,377.775		23,355 - 95	23,260	10,123.85 - 109 =	.02298	
150	43,800.495		22,663 - 12	22,651	984.115 - 109	.02319	
200	42,502.200		22,167 - 0	22,161	976.995 - 109	.02268	
	235-9		238-7			C _{1/C₃}	
100	19,996.15 - 95		X		20,465 - 109 = 20,356	.49.11	2137 ✓
150	10,431.65		X		22,415 - 109	46.77	2017
200	10,341.15		X		22,875 - 109 = 22,766	45.43	2003
	238-		C ₁ (235)			.03003	
100	22,584 - 7		44,038.735 - 829		987.185 - 109	.02287	
150	22,065 - 0		73,596.225 - 15		999.975 - 109	.02206	
200	21,122 - 0		43,019.905 - 15		1013.575 - 109	.02084	
100			903,385 - 828 = 902,557		18605 - 109 = 18496	48.80	2134 ✓
150			958,945 - 15 = 958,930		20225 - 109 = 20116	47.67	2161
200			970,365 - 15 = 970,350		20965 - 109 = 20856	46.53	2233

660

Instrument Check on 1-3-68 Source 10mcr

PM-1	Low Trip	OK $\frac{1}{2}$ "	Alarm Trip	OK	Cont
PM-2			Alarm Trip		
IC-1	3×10^{-4}	Meter Trip	OK $\frac{1}{2}$ "	Fast Trip	OK Cont
IC-2	3×10^{-4}	Meter Trip	OK $\frac{1}{2}$ "	Red light	OK
IC-3	Reps	Calibration		Bldy alarm	OK
IC-4	Reps	Calibration		Pres Dif	0.12
CRM		Meter Trip			

$T = \sim 21.4^\circ C?$

Place $\frac{1}{2}$ " BF_3 counter in tray at south edge of fixed table (dist $\sim 2'$)
 $\sim 4'$ from top edge of assembly in small counter paraffin pig
 counter is wrapped with cadmium except for a $\sim \frac{1}{8}$ " slit

+1500 V	Hammer	- A10 gain	@ 16 x 1.0 sec. delay line
+	PHS	cts	eq. source again at side of pig
3'	200	18940	
"	150	20570	
"	100	21190	
"	50	21790	

19'17" 150 140 cts $\rightarrow 7.26$ ct/min $\times 15 = 109$

#159 mean react with bath plexiglas skin + 210.7 sec $\rightarrow 5.3 \phi$

Added 8cc $\frac{1}{4} \times 4 \times 4$ to each half (4 x 32 strip on each half)

#160 etc react on start up + sec $\rightarrow \phi$ T = 21.7°C

IC-3	PHS	C ₁ (238)	C ₃ (BF_3 Norm)	C ₄ (235)
~ 1.0	200	22167-0	976995-109	42502200 -11
15' count	150	22663-	984115-109	43800480-
Time	100	23355-95	1012385-109	45377770-150

N.O. 2	100	559-95	20465-109	999615
	150	440-	22415-109	1043165
	200	486-0	22875-109	1034895

T = 21.9

Exchange positions of 235 and 238 counters (each ^{scale as that} _{238 scale x 1})

IC-3	PHS	C ₁ (235) #9	C ₃ (BF ₃)	C ₇ (238) #7
"	200	430 1990 ₅	101 357 ₅ -109	211 22
"	150	43 596 22 ₅	99 997 ₅ -109	220 65
3 ³⁰⁻⁴⁵ PM	100	440 3873 ₅	98 718 ₅ -109	225 84

Lower Power

IC-3	.02	100	903 38 ₅	1860 ₅ -109	412
"	"	150	958 94 ₅	2022 ₅ -109	415
"	"	200	970 36 ₅	2096 ₅ -109	431

Bkg 200 015 165 4 (Turned air off probably added counts)

(N30 each half of time interval)

start 5 ⁰⁰ PM	100			
stop 8 ¹¹ AM		5024 ₅	473 ₅	411 = 0.45
15m 10'		910	910	910 x 15
		55.21 x 15 = 828	52.5	5 = 78

Shut down @ 4:45

Jan 4, 68	100	265	85	5
Bkg	150	15	75	0
		C ₄ (235-9)		C ₁ (238-7)

Exchange counters (235 is on C₄)

Bkg	150	15'	12	75	5
Bkg	100	5'	36		25

Remove 235-9 - Install 235-D on C₄

EM

C₄ 1

Instrument Check on 1-4-68 Source 10 mCr

PM-1	Low Trip	OK $\frac{1}{2}$	Alarm Trip	OK Contact
PM-2			Alarm Trip	
IC-1	3×10^{-4}	Meter Trip	OK $\frac{1}{2}$	Fast Trip OK Cont.
IC-2	3×10^{-4}	Meter Trip	OK $\frac{1}{2}$	Red light OK
IC-3	Responde	Calibration	OK $\frac{1}{2}$	Bldy Alarm OK
IC-4	Responde	Calibration	OK $\frac{1}{2}$	Press Dif = 0.12'
CRM		Meter Trip		

Temp 21.6°C

Exp 161

Fission counter at -400V.

11¹⁹ start 15' count U-238-7 - C-1 x ~~32~~ x 1.0 DL 28152 + 1662 = 29814
 TMC H: Level Input Baseline 51 (17 ch) 15' ^{live} Time (~20 sec longer than C₃)
 $C_3 = 993055 - 109 \approx 992950$ $C_1/C_3 = .03003$
 C_1 (PHS @ 100) 27595

11⁴⁷ start 15' count U-235-9 - C4 x 32 x 1.0 DL $\frac{1276269 + 62191 = 1338460}{1276269 + 62191 = 1338460}$
 TMC H: Level Input Baseline 51 (17 ch) 14.16 ^{live} Time 94427
 $C_3 = 24865 - 109 \approx 24760 \times 94427 = .23380$
 C_4 (PHS @ 100) 1347765 x 94427 = 1272654
 $C_4/C_3 = \frac{57.25}{.23380} = 244.8$
 $C_4/C_1 = \frac{1906}{.03003} = 63466$

Exp 162

By on U-238 = 4 m TMC ← Exchanged positions of 235 & 238 counter in stack

1⁵³ start 15' count U-238 - C4 x 32 x 1.0 DL. Baseline 51 15' live Time (~0.2 sec longer)
 C_4 (PHS @ 100) = 27755 $C_3 = 1177605 - 105 = 1177500$
 C_1 (PHS @ 100) = 51433435 TMC Int 27736 + 1380 = 29116
 $C_4/C_3 = .02473$

12²² PM Start 15' count U-235-9 C-1 32x1.0DL Live Time = 14.41125 / 15 = 960.25

Baseline 51 (17d)

C₁(100) 101942.5

TMC (hr) 997.037

C₄(100) 47.5

+ 54563

C₃(150) 2135.5 - 105 = 2125.0

1051.600 $\frac{imc}{C_3} = 49.49$

~ 225 sec after shutdown start 2' count for background on C₃ → 20 cts in 2' 17"

30 cts in 3' 55"

$$\frac{49.49}{0.2473} = 200\%$$

#163 Added $\frac{5}{16}$ " RSA - counter to Channel 2 for another Norm Counter counted on rise to power for ~ 8'

C₂ = 24735

C₃ = 13765

Shutdown

C₃

403 20 cts in 1' 13"

404+

East wing to Power

2' Min count C₂

1290

noise from power

C₃ ~~0.5~~ 0.5?

Stopping

Set up on Ch-2, $\frac{5}{16}$ BF₃ RSN - counter DD 2 preamp
and AMP Y-134495 (0.5 ps DL) Gain 100 x 1

Recorded PHS data on TMC @ Baseline 51, some low channels
show high counts (Noise in low ch)

With Baseline at 75, Ch 5-6-7 are still high

With Baseline at 100, Ch 5-6 are high

With C₂ gain 50 x 1.0 Max HV = 1575 $\frac{9}{16}$ " Counter

C₃ gain 16 x 1.0 Max HV = 1575 $\frac{1}{2}$ " Counter

PHS on TMC @ 0.75

Found bad tube in C-4 scaler - not passing zero Y-140343

Found loose connection in C-1 scaler Y-120247

after soldering - dead - not found bad x10 driver stage

Jan 8 ^{Battery} -600V - AID (Y102542) C-1 gain 32 x 1 U-235-9

-600V - AID (Y102541) C-4 gain 32 x 1 U-238-9

$\frac{1}{2}$ BF₃ @ 1650 (Harmer) C-3 AID (140347) 16 x 1 PHS = 1.00

(RSN-) $\frac{5}{16}$ BF₃ @ 1750⁺ (NICC) C-2 DD 2 (140345) 20 x 1.1 Max PHS = 1.00

15' Bkg C-2 = 75 C-3 = 75

5' Bkg + 10 ke δ in Pig @ 14 25 35

5' Bkg 35 35 + 10 ke δ in Pig

214

Instrument Check on Jan 8 Source 10 mc

PM-1	Low Trip <u>OK</u> $\sim 1/2$ "	Hi Alarm Trip <u>OK</u>	Contact
PM-2		Alarm Trip	
IC-1	Meter Trip <u>OK</u> ~ 1 "	Fast Trip <u>OK</u>	
IC-2	Meter Trip <u>OK</u> ~ 2 "		Bldg A <u>OK</u> (sluggish)
IC-3	8×10^{-11} Calibration <u>Down</u>		B <u>OK</u>
IC-4	3×10^{-11} Calibration <u>Down</u>		C <u>OK</u>
CRM	Meter Trip		

T = 20.3°C

$\sim 11^{45}$
 11^{50} Start Approach to Crit
 Tables together + period

15' Count

#164

A

$IC-2 = .475 \times 10 \times 10^{-9}$	C_3	$103647 \underline{5}$
$3 = 1.05 [\times 10^{-9}]$	C_2	$120911 \underline{5}$
$4 = 4.8 [\times 10^{-9}]$	(235) C_4	92770
(235) Hi level TMC Baseline 75 Int. 24895		
31 each $+ 1960$		
26612		
26855		

N.B. C_4 scales observed to count in burst during run, but not observed as pulses on Scope. TMC output appears normal.

B

Same as A on
~~IC-2~~ $3, 4$

C_3	$106549 \underline{5}$
C_2	$121671 \underline{5}$
C_4	$5381 \underline{5}$
235 Hi level TMC Baseline 75 Int = 25012	
(31)	1819
26831	

164

15 min counts

	A	B	C	D
	$V^{238} \rightarrow TMC$	$V^{238} \rightarrow TMC$	$V^{235} \rightarrow TMC$	$V^{235} \rightarrow TMC$
IC-1			4.5×10^{-11}	5.0×10^{-11}
IC-2	4.75×10^{-9}	same as A	9.45×10^{-11}	1.05×10^{-10}
IC-3	1.05	↓	0.022	0.025
IC-4	4.8	↓	0.09	0.10
C ₂	1209115	1216715	23685-75	26815-75
C ₃	1036475	1065495	23225-75	30925-75
C ₄	92770	53815	$C_1^{(235)} = 1086785$	$C_1 = 1,222,605$
TMC $R_{i,level}$, Baseline = 75				
			14.34978 ^{min} _{line}	14.27600 ^{min} _{line}
Net Count	24895	25012	1,016,099	1,137,254
Exp. to $R_{i,level}$ (31) + 1960	+ 1819	+ 1819	+ 83138	+ 92322
Background			+ 2000	+ 2000
Total	26855	26831	1,101,237	1,231,576
Net Count Cor. for line time			1,151,136	1,294,034
$^{238}/C_2$	0.02221	0.02205		
$^{238}/C_3$	0.02591	0.02518		
$^{235}/C_2$			48.76	48.39
$^{235}/C_3$			49.73	41.95
$(^{235}/^{238})_{C_2}$	(2195) _{CA}	(2211) _{CA}	(2179) _{DA}	(2195) _{DB}
$(^{235}/^{238})_{C_3}$	(1919) _{CA}	(1875) _{CA}	(1619) _{DA}	(1666) _{DB}
$(^{235}/^{238})_{C_3}$	data not acceptable. C3 normalize data bad.			

Changed Power Level.

C

IC-2 = $0.315 (3 \times 10^{-10})$
 3 = 0.022 ~~4.10~~
 4 = 0.09
 1 = 4.5×10^{-4}

15' count.

C₃ = 23225-75
 C₂ = 23685-75
 C₁(235) = 1086745

(235) Hi level TMC Baseline 75 Det. 1,016,099
 14.34978 min live time (31) + 83,138
 $\times \frac{1}{15} = .956652$ 1099,237

Est overflow 2,000
 1701237

D

IC-1 = $.50 \times 10 \times 10^{-10}$
 IC-2 = $.35 \times 3 \times 10^{-10}$
 IC-3 = .025
 IC-4 = .10

C₃ = 30925-75
 C₂ = 26815-75
 C₁(235) = 1222605

(235) H. level TMC Baseline 75 Det 1,137,254
 14.27600 min live time (31) + 92,322
 $\times \frac{1}{15} = 0.95173$ 1,229,576

Est overflow 2,000
 1,238,576

3:17 PM 5 min Bq. C₃ = 1010 counts.

Jan 9 Overwrite counter C₃ with 5/16" RSN-1055 detector showed bad data - Connector dirty
 Found bad scaler C₃, replaced. Replaced tubes in C₄ AID
 Cleaned connector on RSN-1055 H
 and checked got in counter and caused excessive counts.

C ₁	DDAID Y102542	x32 x 1.0 max	-600V	235-9	Jan 12 Found tube PHS = 100
C ₂	DD2 Y140345	x20 x 1.1 max	1800	NICC	PHS = 100
C ₃	AID Y140347	x32 x 1.0 max	1750	Hammer Y118715	PHS = 100
C ₄	AID Y102541	x32 x 1.0 max	-600V	238-7	

216

with source 1' counts

	C ₁	C ₂	C ₃	C ₄	
1700	6437.5	6437.5	9371.5		IC
		6488.5	9352.5		IC
		6498.5	9400.5		IC
1750		6686.5	9426.5		IC
		6713.5	9399.5		T
		6766.5	9457.5		C
1800		6833.5	9579.5		C
		6821.5	9557.5		C
		6791.5	9514.5		TM

Use C₂ @ 1800 and C₃ @ 1750 (235)

15' Bkg C₅ 7.5 7.5 8 (TM @ 51)

Instrument Check on 9 Jan 68 Source 10 mC/K

PM-1	Low Trip	OK 1/2"	Alarm Trip	OK Contact	235
PM-2			Alarm Trip		235
IC-1	Meter Trip	OK 1'	Fast Trip	OK	235
IC-2	Meter Trip	OK 2"	Red light	OK	235
IC-3	Respart Calibration	OK 1/R	Bldg. alarm	OK	235
IC-4	Respart Calibration	OK 1/R	Press. diff.	0.12"	(235)
CRM	Meter Trip				(235)

Temp 20.6°C

Added 16 on 1/4 x 1/4 x 1/4 (slightly less than 6 di per decade)

#165 + Period of 6 di/decade not controllable!

Remove 16 on 1/4 x 1/4 x 1/4 (now source is 1.64)

#166 + Period

45
PM
9 Jan

166

217

	A $U^{238} \rightarrow TMC$	B $U^{235} \rightarrow TMC$	C $U^{235} \rightarrow TMC$	D $U^{235} \rightarrow TMC$
IC-1	2.55×10^{-9}	2.51×10^{-9}		4.6×10^{-11}
IC-2	5.25×10^{-9}	5.15×10^{-9}	6.6×10^{-10}	9.6×10^{-11}
IC-3	1.2	1.1	0.018	0.024
IC-4	5.5	5.4	0.067	0.082
TMC				
C ₂	1,265,745-75	1,230,305-75	16345-75	20145-75
C ₃	1,087,265-75	1,040,425-75	14405-75	20705-75
C ₄	28475-8	27355-8	C ₁ = 783805	C ₁ = 1113625
TMC	Slightly Pos. period	Pos Period	Pos PER.	Pos. Per
TMC	~ 2 sec longer counting		14.47802 TMC hr	14.29364 TMC hr
Hi level	ht.c. = 28503	ht.c. = 27402	ht.c. = 755,965	ht.c. = 705,958
Baseline	(23) + 1412	(230k) + 1370	230k + 38,880	(230k) + 54,882
	29,915	28,772	Overflow + 1200	Overflow + 2530
$^{238}/C_2$	0.023636	0.023387	796,045	1,116,990
$^{238}/C_3$	0.027516	0.027656	Con. = 823,607	Con. = 1,172,189
$^{235}/C_2$			50.6212	50.810
$^{235}/C_3$			57.474	56.820
$(^{235}/^{238})C_2$	(2141.7)C _A	2164.5)C _B	2149.7)D _A	2172.6)D _B
$(^{235}/^{238})C_3$	2088.7)C _A	2078.2)C _B	2065.0)D _A	2054.5)D _B

Still suspect C₃ normalization data. Tracking scales

Bq after run 15' count C₁=75, C₂=75, C₃=95

avg $(\frac{^{235}}{^{238}})C_2 = 2157.1$

Interchanged 235 & 238 fusion ch in stack. Now 235 on C₄
 238 on C₁
 Background C₃ = 5135 = 80.4/15min C₄ = TMC @ S1 = 82212
 T.M.C @ 75 (as 8d) = 14279

218

Jan 10

C₁ DMT C₂ DMT C₃ DMT C₄

15' Bkg

85 075 2570

n. 2k in burst

TMC @ 51 = 812

" @ 75 = 52

15' Bkg

TMC @ 51 = 3 85 95

Observed noise bursts in C₄ AID. ERR suspects contact on D.L. (R.T) switch -- switched it many times to clear. Since AID is used only on D.L., plan to remove switch!

Instrument Check on 10 Jan 68 Source 10mCr

PM-1

Low Trip OK 1/2" Alarm Trip OK Contact

PM-2

Alarm Trip

IC-1

Meter Trip OK 1" Fast Trip OK

IC-2

Meter Trip OK ~2" Redlight OK

IC-3

Response Calibration OK 1/0. Oldy alarm OK

IC-4

Response Calibration OK 1/0. Pres d/d 0.12"

CRM

Meter Trip

Temp 20.6°C

#167

Removed 4 x 32 x 1/4" of fuel from movable table

Added a 13 x 22 x 1" piece of plexiglas for getting to power.

10¹⁰ AM

b > 1

10³⁰

b ≈ 1 slightly too.

12⁰⁵

Shut down.

FC-7 was on C₁ in the east position and FC-9 was on C₄ in the west position

IC-

IC

IC

IC

C

C

C

TM

Integr

Extrac

One

Total

235

235

235

235

235

235

235

235

235

235

235

235

235

235

235

235

235

235

#167

219

	$V^{238A} \rightarrow TMC$	$V^{238B} \rightarrow TMC$	$V^{235C} \rightarrow TMC$	$V^{235D} \rightarrow TMC$
IC-1	2.45×10^{-9}	2.45×10^{-9}	$.53 \times 10 \times 10^{-11}$	5.45×10^{-11}
IC-2	5.01×10^{-9}	5.05×10^{-9}	$.37 \times 3 \times 10^{-10}$	$.382 \times 3 \times 10^{-10}$
IC-3	1.2	0.9	.021	0.0285
IC-4	3.6	3.4	.076	0.077
C ₂	1219,885 - 85	1,231,385 - 85	27183 - 85	28235 - 85
C ₃	1,090,875 - 85	1,099,675 - 85	24405 - 85	25185 - 85
C ₁ (scale)	$24505 - 3$	27115	C ₄ 1304085	C ₄ 1253165
! TMC - 9th Level; Baseline = 51 Pop. Period				
TMC line time	15.00	15.0	$\frac{15}{14.10144} = 1.0637$	14.06807
Integral Counts	26210	26769	1,230,681	1,223,951
Extrapolated peak	1443	1421	52301	54055
Overflow Est	100	100		
	27753	28290	1282,982	1328,006
	3	3	- 812	812
Total Counts	27750	28287	1,282,170	1,327,194
Total line time			1,363,871	1,415,113
$^{235}C_2$	0.022750	0.022973		
$^{235}C_3$	0.025440	0.025725		
$^{235}C_2$			50.327	50.270
$^{235}C_3$			56.080	56.379
$\left(\frac{^{235}}{^{238}}\right)_{C_2} \frac{FC-9}{FC-7}$	2212.2 (CA)	2190.7 (CB)	2209.7 (DA)	2188.2 (DB)
$\left(\frac{^{235}}{^{238}}\right)_{C_3} \frac{FC-9}{FC-7}$	2204.4 (CA)	2180.0 (CB)	2216.2 (DA)	2191.6 (DB)
Avg. $\left(\frac{^{235}}{^{238}}\right)_{C_2} = 2200.2 \leftarrow \left(\frac{FC-9}{FC-7}\right) \rightarrow \left(\frac{^{235}}{^{238}}\right)_{C_3} = 2198.0$				
Overall average $\frac{FC-9}{FC-7} = 2199.12 \pm 12.32$				
F.C. 7 - 238U - 5.0 mV - 99.99% ^{238}U - 4-6 ppm ^{235}U				
F.C. 9 - 235U - 5.2 mV - 99.92% ^{235}U				
2199.12 ± 12.32 $\frac{^{235}}{^{238}} = 2199.12$				

220

c₁ c₂ c₃ c₄

mC(75) = 8

Bkg 15'

85

85

425

#168 ~ 2:00 PM removed 4x32x4 fuel from fired table + Period

~ 4:00 PM Shut down

Replaced FC-9 by FC-10 on C₄

~ calibrated IC-3 & 4

FC-10 - 235U - 5.0 mgU - 99.9% U²³⁵

510

	168	A	B	C	D
IC-1		.242 x 10 ⁻⁹	.248	.53 x 10 ⁻⁹	.575
2		.446 x 10 ⁻⁹	.503	.37 x 3 x 10 ⁻¹⁰	.40
3		1.1	1.15	.028	.029
4		4.8	5.0	.015	.11
C-1 #7		26685	26935	X	X
C2 #8		1210.835-75	1224.025-75	2697.5-85	2930.5-85
C3 #9		1083.935-75	1096.125-75	2427.5-85	2647.5-85
C4 #10		X	X	1249.285	1373.865
T Live time		15.0	15.0	14.11986	14.03920
M Cor Factor		1.00	1.00	1.062333	1.0
C Int. CF		25.803	25.986	116.2321	1270.692
B Extr. Zero (314)		19.41	19.09	5944.2	65036
A - Overkill		50	~ 150	1,221,763	1,385,927
S (75) Total		277.94	279.95	1,297,919	1,427,141
L ²³⁵ /C ₁		0.022956	0.022832	²³⁵ /C ₁ = 48.268	48.841
I ²³⁵ /C ₃		0.025644	0.025496	²³⁵ /C ₃ = 53.655	54.078
N ^(235/238) C ₂		2102.6 (CA)	2114.0 (CB)	2127.6 (DA)	2139.1 (DB)
^(235/238) C ₃		2092.3 (CA)	2104.4 (CB)	2108.8 (DA)	2121.1 (DB)
FC-10		Avg ^(235/238) C ₂ = 2120.8	11.08	Avg ^(235/238) C ₃ =	2106.6
FC-7		Overall avg = 2113.7	No mass loss needed		

#17

c1

4:45 PM 15' Bkg C₁ = 15 C₂ = 75 C₃ = 25 C₄ TIC = 8

4:45 PM PO fan Replaced FC-7 by FC-8 on C₁

5:10 → 6:10 PM 10 fan B₁ C₁ = 0 ; C₂ = 345/60min ; C₃ = 325/60min ; TMC = 39/60min
= 8 1/15 min = 9 1/15 min = 10 1/15 min

Instrument Check on 11 Jan 68 Source 10mCT

FM-1	Low Trip	OK 1/2"	Alarm Trip	OK
FM-2			Alarm Trip	
IC-1	Meter Trip	OK 1"	Fast Trip	OK
IC-2	Meter Trip		Redlight	OK
IC-3	Response	Calibration OK s/a.	Old alarm	OK
IC-4	Response	Calibration OK s/a.	Probe Diff	0.12"
CRM	Meter Trip			

Temp 20.9°C

#169

8:45 b > 1

Found that detector FC-8 was no good. Shut down.

#170

Replaced FC-8 by FC-9 or FC-9 (235U) on C₁ and FC-10 (235U) on C₂. FC-9 on East side, FC-10 on West side.

9:42 AM b > 1

9:50 b = 1 IC-2 = 0.33 x 3 x 10⁻¹⁰ ; IC-3 = 0.027

~ 11:05 Shut down

11:20 Changed positions of 235 Fiss ch in assembly.

Now FC-10 on East side on C₁ and FC-9 on West side on C₂

#171

11:30 b > 1

1:00 PM Shut down

#172

b > 1 ~ 2:00 PM

Shutdown ~

Replaced FC-10 and 9 by FC-17+18. (No 237 fiss ch)

222

170

10 min counts

	A	B	C	D	
FC-1	—	4.4×10^{-4}	4.7×10^{-4}	4.96×10^{-4}	I
2	9.66×10^{-4}	9.45×10^{-4}	9.96×10^{-4}	1.065×10^{-10}	
3	0.0236	0.023	0.024	0.0255	
4	0.097	0.094	0.1	0.107	
C ₁	753115	722205	766845	817895	C
C ₂	733825	706865	747875	797405	
TMC - Hi Level - Baseline = 75					
TMC line time	9.55468	9.49399	9.55455	9.43119	T
TMC on Integral	C ₁ (FC-9)	C ₂ (FC-10)	C ₁ (FC-9)	C ₂ (FC-10)	TMC
Integral Ct.	705735	662416	718298	743208	TMC
Extrap. to zero	57582	33291	59152	37062	Extrap
Overflow	1000	695707	1000		On
Total Ct.	764,317		778,450	780,270	Total
Total Ct. Cor. for line time	799,940	732,787	814,743	827,329	Total Cor.
FC-9/C ₁	1.06218	$\frac{FC-10}{C_1} = 1.01465$	$\frac{FC-9}{C_1} = 1.06246$	$\frac{FC-10}{C_1} = 1.01153$	FC
FC-9/C ₂	1.09080	$\frac{FC-10}{C_2} = 1.03667$	$\frac{FC-9}{C_2} = 1.08941$	$\frac{FC-10}{C_2} = 1.03753$	
$\frac{(FC-9)}{(FC-10)} C_1$	1.04684 (AB)	1.05007 (AD)	1.04711 (CB)	1.05034 (CD)	$\frac{(FC-9)}{(FC-10)}$
$\frac{(FC-9)}{(FC-10)} C_2$	1.05154 (AB)	1.05066 (AD)	1.05087 (CB)	1.05000 (CD)	$\frac{(FC-9)}{(FC-10)}$

$$\text{East/West} = \left(\frac{FC-9}{FC-10} \right)_{\text{avg.}} = 1.04968 \pm 0.00159$$

171

10 min counts

223

	A	B	C	D
IC-1	5.1×10^{-11}	5.4×10^{-11}	5.25×10^{-11}	5.4×10^{-11}
-2	1.095×10^{-10}	1.155×10^{-10}	1.119×10^{-10}	1.155×10^{-10}
-3	0.027	0.028	0.028	0.026 ⁺
-4	0.11	0.115	0.110	0.11 ⁺
C ₁	830995	758715	834495	858075
C ₄	873145	903455	875725	998875
TMC	Hi Level	Baseline = 75		
TMC on	C ₁ FC-10	C ₄ FC-9	C ₁ FC-10	C ₄ FC-9
TMC live time	9.46852	9.39917	9.46787	9.40625
TMC Integral Ct.	769246	838458	772509	834561
Extrapolated to zero pulse rate	47245	52329	47803	52508
Overflow	4200		4200	
Total Ct.	820691	890787	824512	887,069
Total Ct Cor. for live time	866,757	947,729	870,853	943,063
FC-9	$\frac{FC-10}{C_1} = 1.04304$	$\frac{FC-9}{C_1} = 1.10366$	$\frac{FC-10}{C_1} = 1.04357$	$\frac{FC-9}{C_1} = 1.09904$
	$\frac{FC-10}{C_4} = 0.99268$	$\frac{FC-9}{C_4} = 1.04901$	$\frac{FC-10}{C_4} = 0.99444$	$\frac{FC-9}{C_4} = 1.04916$
D)	$\left(\frac{FC-9}{FC-10}\right)_{C_1}$	1.05812 (BA)	1.05758 (BC)	1.05369 (DA)
D)	$\left(\frac{FC-9}{FC-10}\right)_{C_4}$	1.05675 (BA)	1.05488 (BC)	1.05690 (DA)
				1.05503 (DC)

$$\frac{w_{int}}{count} = \left(\frac{FC-9}{FC-10}\right)_{avg} = 1.05576 \pm 0.00172$$

224

#172
N_p 237

C₁ - FC-18 - 2.1 mg - (East) - A1D x16 PHS = 75

C_y - FC-17 - 1.7 mg - (West) - A1D x16 PHS = 75

C₂ - RSN-1055 - same position as Expts 166-171 DD-2 x20, mag. 1.1 → PHS =

	A	B	C	D
Rkg all less than 0.1%		2,496,625	2,478,165	2,503,015
C ₁	95685	94205	94505	95255
C _y	66715	66415	65615	66905
TMC - 4i level - Baseline 60				
TMC m	C ₁ (FC-18)	C ₁ (FC-18)	C _y (FC-17)	C _y (FC-17)
TMC duration	10.0000	10.11326	10.00753	10.00000
TMC Integral Counts	95322	94990	65390	66651
Extrap to zero pulse	1725	1725	670	670
Cor. total	97047	96715	66060	67321
Total Cor. for line time	97,047	95,632	66,070	67,321
	$\frac{FC-18}{C_1} = 1.01423$	$\frac{FC-18}{C_1} = 1.01515$	$\frac{FC-17}{C_1} = 0.69848$	$\frac{FC-17}{C_1} = 0.70675$
	$\frac{FC-18}{C_y} = 1.45465$	$\frac{FC-18}{C_y} = 1.43992$	$\frac{FC-17}{C_y} = 1.00602$	$\frac{FC-17}{C_y} = 1.00622$
$\frac{FC-18}{FC-17} C_1$	1.45205 (AC)	1.43506 (AD)	1.45337 (BC)	1.43636 (BD)
$\frac{FC-18}{FC-17} C_y$	1.44595 (AC)	1.44566 (AD)	1.43130 (BC)	1.43102 (BD)
		Avg $\frac{FC-18}{FC-17} = 1.44135$	1.43930 ± 0.00914	
		$\frac{FC-18}{C_2} = 0.0383045$	$\frac{FC-17}{C_2} = 0.0266366$	$\frac{FC-17}{C_2} = 0.0269960$
$\frac{FC-18}{FC-17} C_2$		1.43804 (BC)	1.42417 (BD)	Avg = 1.43110
		Avg $\frac{FC-17}{C_2} = 0.0267663$	Avg $\frac{FC-17}{C_2}$ from #167A+B and 167A+B = 0.022979	
Not Cor for masses in Det.	$\frac{FC-17}{FC-7} =$			
	$\frac{FC-18}{FC-7} =$			

Instrument Check on 12 Jan 68 Source 10kcr

= 75
75
may 1 → PHS = 100

PM-1	Low Trip	OK 1/2"	Alarm Trip	OK Contact
PM-2			Alarm Trip	
IC-1	Meter Trip	OK 1"	Fast Trip	OK
IC-2	Meter Trip	OK 2"		Red light OK
IC-3	Responds	Calibration OK 1/B		Red alarm OK
IC-4	Responds	Calibration OK 1/B		Press Dif. 0.12"
CRM	Meter Trip			

Temp 20.9°C

-17)

#173 Replaced No. ²³⁷ det. by ²³⁴ det FC-14, East; FC-13 ⁶⁴ West.

~ 9:30 k > 1

~ 11:00 Shut down

#174 1⁰¹ PM → period k > 1 Now have V²³⁶ F Ch. in assembly.
2⁴⁰ PM Shut down

2

D)

D)

760

0

979

226 #173

V234

C₁ - FC-14 - East - 4.6mp - A1D x 32 x 1.0max PHS = 150

C₄ - FC-13 - West - 4.4mp - A1D x 32 x 1.0max PHS = 150

C₂ - RSN-1055 same as Exp 166-172 - DD2 x 20 x 1.1max PHS = 100

10min Counts	A	B	C	D	
C ₂	298185 - 65	301445 - 65	302735 - 65	297665 - 65	
C ₁	219845 - 4980	221645 - 4980	222685 - 4980	218705 - 4980	
C ₄	172845 - 7620	174665 - 7620	174375 - 7620	172365 - 7620	
TMC	→ Baseline = 150				
TMC on	C ₁ FC-14	C ₁ FC-14	C ₄ FC-13	C ₄ FC-13	T1
TMC Limit	10.23045	10.00292	10.00580	10.00000	TM
TMC Integral Counts	195875	192823	148469	146496	TMC
Extrapol. to zero	32065	32160	30952	30925	En
Overflow Bkg	~ 100 - 21	100 - 21	- 75	- 75	
Com total	228019	225062	179346	177346	Ta
Com for limit	222883	224996	179242	177346	Ta
	$\frac{FC-14}{C_2} = 0.74763$	$\frac{FC-14}{C_2} = 0.74655$	$\frac{FC-13}{C_2} = 0.59220$	$\frac{FC-13}{C_2} = 0.59592$	
	$\frac{FC-14}{C_1} = 1.03732$	$\frac{FC-14}{C_1} = 1.03845$	$\frac{FC-13}{C_1} = 0.82333$	$\frac{FC-13}{C_1} = 0.82979$	
	$\frac{FC-14}{C_4} = 1.34897$	$\frac{FC-14}{C_4} = 1.34692$	$\frac{FC-13}{C_4} = 1.07488$	$\frac{FC-13}{C_4} = 1.07649$	
$\left(\frac{FC-14}{FC-13}\right)_{C_2}$	1.26246 (AC)	1.25458 (AD)	1.26064 (BC)	1.25277 (BD)	$\left(\frac{FC-14}{FC-13}\right)_{C_2}$
$\left(\frac{FC-14}{FC-13}\right)_{C_1}$	1.25991 (AC)	1.25010 (AD)	1.26128 (BC)	1.25146 (BD)	$\left(\frac{FC-14}{FC-13}\right)_{C_1}$
$\left(\frac{FC-14}{FC-13}\right)_{C_4}$	1.25500 (AC)	1.25312 (AD)	1.25309 (BC)	1.25121 (BD)	$\left(\frac{FC-14}{FC-13}\right)_{C_4}$

Avg $\frac{FC-14}{FC-13} = 1.25546 \pm 0.00421$

174
U 236

C₁ - FC-12 - 4.8mg - AID x32 x1.0 PHS = 100
 C_y - FC-11, 5.0mg, AID x32 x1.0 PHS = 100
 C₂ - RSN-1055, DD2 x20 x1.1 PHS = 100

227

10min Counts	A	B	C	D
C ₂	301015 - 65	306065 - 65	306375 - 65	304395 - 65
C ₁	151575 - 30	154265 - 30	155485 - 30	154175 - 30
C _y	123215 - 25	126515 - 25	126945 - 25	124595 - 25
TMC →	Baseline = 75			
TMC on	C ₁ FC-12	C _y FC-11	C ₁ FC-12	C _y FC-11
TMC live time	9.90423	9.91949	9.94697	9.92111
TMC Integral Counts	148684	124995	153280	123150
Extrac to zero overflow	6308	12748	6357	11945
Bkg.	750		750	
	-10	-14	-10	-14
Total	155732	137129	150774 160377	135081
Total Counts live time	157238	138242	161232	136155
	$\frac{FC-12}{C_2} = 0.52247$	$\frac{FC-11}{C_2} = 0.45177$	$\frac{FC-12}{C_2} = 0.52637$	$\frac{FC-11}{C_2} = 0.44739$
	$\frac{FC-12}{C_1} = 1.03757$	$\frac{FC-11}{C_1} = 0.89631$	$\frac{FC-12}{C_1} = 1.03716$	$\frac{FC-11}{C_1} = 0.88329$
	$\frac{FC-12}{C_y} = 1.27639$	$\frac{FC-11}{C_y} = 1.09291$	$\frac{FC-12}{C_y} = 1.27034$	$\frac{FC-11}{C_y} = 1.09300$
) $\frac{FC-11}{FC-12} C_2$	0.86468 (BA)	0.85827 (BC)	0.85630 (DA)	0.84995 (DC)
) $\frac{FC-11}{FC-12} C_1$	0.86385 (BA)	0.86420 (BC)	0.85131 (DA)	0.85164 (DC)
) $\frac{FC-11}{FC-12} C_y$	0.85625 (BA)	0.86033 (BC)	0.85632 (DA)	0.86040 (DC)

Avg $\frac{FC-11}{FC-12} = 0.85779 \pm 0.00488$

Instrument Check on 15 Jan 68 Source 10 mct

PM-1	Low Trip	OK 1/2"	Alarm Trip	OK Contact
PM-2			Alarm Trip	
IC-1	Meter Trip	OK 1"	Fast Trip	OK
IC-2	Meter Trip	OK 2"	Red light	OK
IC-3	<u>Responds</u>	Calibration	OK S.P.O.	Bldg Alarm OK
IC-4	<u>Responds</u>	Calibration	OK S.P.O.	Pres. Dif. 0.12"
CRM	Meter Trip			

Temp 21.0 °C

Exp. # 175 Have placed 1/4" dia. fine. Ch. in assembly. ^{Removed 4x34x1/4" from each side.}

235 U # 5-3 on C₁ -- EAST @ 20.5/8" norm above Table Sym above
 237 V # 8-2 on C₄ -- WEST @ " " " " m-s plate

b>1 38.24 sec period with 3 plexiglass shims.

P too high to level. Shut down.

176 Removed ^{32x34x1/4"} 1/2" fuel + 8x34x1/4" stack now 32x34x34" high
 Also moved BF₃ det. C₂ + C₃ to approx. 13" above stack.

b>1 P-OK Count rates on C₂ + C₃ too high.
 Shut down and moved C₂ + C₃ det. to cable rack.

177 b>1 BF₃ det on C₂ giving intermittent noise and finally lost pulses completely. Cf. rates on C₃ still too high
 shutdown. Cleaned connections on C₂.
 Placed Cd (20mil) around both C₂ + C₃ det. ^{det. in cable rack} opposite stack.

12⁴⁵ 178 b>1
 A+B b=1 at 14 on IC-3

2³⁰ PM Reduced power to ~ 0.3 on IC-3

C+D

3¹⁵ PM Shutdown.

#178
15 min
Counts

C_1 - 235U, $\frac{1}{4}$ " 00, #5-3, AID x 32 x 1.0, PHS = 50
 C_2 - 235U, $\frac{1}{4}$ " 00, #8-2, AID x 32 x 1.0, PHS = 50
 C_3 - RSN-1055 $\frac{5}{16}$ " BF₃, Cd covered, DD2 x 32 x 1.1, PHS = 100, HV = 1800
 C_3 - RSN-1055 $\frac{5}{16}$ " BF₃, Cd covered, AID x 32 x 1.0, PHS = 100, HV = 1750V

229-

	A	B	C	D
C_1	41186685-835	39,197,215-835	987,855-835	1,003,535-835
C_4	27,645-10	26,025-10	585-10	645-10
C_2	did not start	1,210,855-5	27,375-5	27,975-5
C_3	1,905,565-15	1,795,365-15	40,405-15	41,515-15
IC-2	6×10^{-9}	5.8×10^{-8}	1.38×10^{-9}	1.38×10^{-9}
IC-3	14	13.8	0.3	0.3
TMC \rightarrow	Baseline =	50		\rightarrow
TMC on	C_4 (8-2)	C_4 (8-2)	C_1 (5-3)	C_1 (5-3)
TMC live time	15.0	15.0	14.54446	14.53439
TMC Integral Count	26944	25354	928719	943342
Extrapolate to zero overflow and Bkg	17927	1788	111,6707	112,6297
	6.65%	7.05%	12.02%	11.94%
Total Counts	28736	27142	1,040,389	1,055,971
Total Cor for live time	28736	27142	1,072,975	1,089,799
$\frac{8-2}{C_2}$	—	$\frac{8-2}{C_2} = 0.022416$	$\frac{5-3}{C_2} = 39.2026$	$\frac{5-3}{C_2} = 38.9631$
$\frac{8-2}{C_3} = 0.015080$		$\frac{8-2}{C_3} = 0.015118$	$\frac{5-3}{C_3} = 26.5654$	$\frac{5-3}{C_3} = 26.2602$
$\left(\frac{5-3}{8-2}\right) C_2$		1748.87 (CB)		1738.18 (DB)
$\left(\frac{5-3}{8-2}\right) C_3$	1761.63 (CA)	1757.20 (CB)	1741.39 (DA)	1737.02 (DB)

Avg $\frac{5-3}{8-2} = 1747.38 \pm 9.39$

CRM	
IC-4	Overhaul OK 1/10
IC-3	Overhaul OK 1/10
IC-2	Meter Trip OK 2"
IC-1	Meter Trip OK 1"
PM-2	Alarm Trip OK
PM-1	Low Trip OK 1/2"
	Alarm Trip OK
	Fast Trip OK
	Overhaul OK
	Overhaul OK
	Overhaul OK
	Overhaul OK

Instrument Check on 16 Jan 68 Source 10 mCi
Temp 21.1°C

#179
 Detector #'s 5-3 + 8-2 same as Run 178
 Assembly same as Run 178. Normalizing BF₃ det. same as 178.
 Have interchanged amplifier strings at detector
 so that C₁ is now on Det 8-2 on West side
 and C₂ is on Det 5-3 on East side.
 9¹⁰ b > 1
 b = 1 at ~ 15 on IC-3
 10²⁵ b < 1 Reducing power for runs on 235- det.
 b = 1 at ~ 0.3 on IC-3
 11⁵⁰ Shut down

#1
 151
 Ca
 TM
 TM
 TMC
 TMC
 Ept
 Over
 tot
 tot
 5-3
 8-2
 5-3
 8-2

#179
15 min
Counts

C₁ - 235V, 1/4" O.D., #8-2, AID #Y102542, x32 x 1.0 max, PHS=50 V=135V
 C₄ - 235V, 1/4" O.D., #5-3, AID #Y102541, x32 x 1.0 max, PHS=50
 C₂ - RSN1055, 5/16" DF₂, Cd covered, DD2 #Y140345, x20 x 1.1 max, PHS=100 HV=1820
 C₃ - " " " " AID #Y140347, x32 x 1.0 max, PHS=100 HV=1751

231

	A	B	C	D
IC-2	6.3×10^{-8}	6.1×10^{-8}	1.446×10^{-9}	1.515×10^{-9}
IC-3	15.0	14.2	0.32	0.33
C ₁	28745-5	27425-5	595-5	685-5
C ₄	—	—	1070995-3060	1,114,875-3060
C ₂	1,396,095-5	1,342,355-5	30,053-5	31,865-5
C ₃	1,967,415-15	1,889,585-15	42,515-15 C ₃ .10705	44,295-15 C ₃ .71951
TMC →	Baseline =	50		
#178. TMC on	C ₁ (8-2)	C ₁ (8-2)	C ₄ (5-3)	C ₄ (5-3)
TMC live time	15.0	15.0	14.43667	14.40569
TMC integral counts	28050	26782	1,003,765	1,042,764
Extrapol. to zero overflow and Chp.	2394 8.53%	2378 8.88%	94,470 9.41%	97,786 9.37%
total counts	30,444	29,160	1,098,235	1,140,550
total live time	30,444	29,160	1,141,089	1,187,604
	$\frac{8-2}{C_2} = 0.0218066$	$\frac{8-2}{C_2} = 0.0217231$	$\frac{5-3}{C_2} = 37.9730$	$\frac{5-3}{C_2} = 37.2757$
	$\frac{8-2}{C_3} = 0.0154742$	$\frac{8-2}{C_3} = 0.0154321$	$\frac{5-3}{C_3} = 26.8492$	$\frac{5-3}{C_3} = 26.8203$
$\left(\frac{5-3}{8-2}\right)_{C_2}$	1741.35 (CA)	1748.05 (CB)	1709.38 (DA)	1715.95 (DB)
$\left(\frac{5-3}{8-2}\right)_{C_3}$	1735.09 (CA)	1739.83 (CB)	1733.23 (DA)	1737.96 (DB)

avg $\frac{5-3}{8-2} = 1732.60 \pm 12.34$

FC-7, $\sqrt{238}$, 5.0 mg U, 4-6 ppm ^{235}U	FC-13, 4.6 mg U, 97.81% ^{234}U
FC-8, No prod	FC-14, 4.4 mg U, 97.81% ^{234}U
FC-9, 5.2 mg U, 99.9% ^{235}U	FC-17, 1.7 mg Np^{237} } < 10 ppm ^{234}U
FC-10, 5.0 mg U, 99.9% ^{235}U	FC-18, 2.1 mg Np^{237} } ^{234}U
FC-11, 5.0 mg U, 98.55% ^{236}U	5-3, 0.3471 mg U, 97.34% ^{235}U ,
FC-12, 4.8 mg U, 98.55% ^{236}U	8-2, 0.3989 mg U, ~7 ppm ^{235}U

Expt #	167 10 Jan 68	168 10 Jan 68	170 11 Jan 68	171 11 Jan 68	172 11 Jan 68	173 12 Jan 68
East	C ₁ → FC-7	C ₁ → FC-7	C ₁ → FC-9	C ₁ → FC-10	C ₁ → FC-18	C ₁ → FC-14
West	C ₄ → FC-9	C ₄ → FC-10	C ₄ → FC-10	C ₄ → FC-9	C ₄ → FC-17	C ₄ → FC-13
$\frac{FC-7}{C_2}$	0.022862	0.022894				
$\frac{FC-9}{C_2}$	50.2985					
$\frac{FC-10}{C_2}$		48.5545				
$\frac{FC-11}{C_2}$						
$\frac{FC-12}{C_2}$						
$\frac{FC-13}{C_2}$						0.59406
$\frac{FC-14}{C_2}$						0.74709
$\frac{FC-17}{C_2}$					0.026766	
$\frac{FC-18}{C_2}$					0.038304	
$\frac{(FC-9)}{(FC-7)}$ avg C ₂ & C ₃	2199.12 ± 12.32					
$\frac{(FC-10)}{(FC-7)}$ avg C ₂ & C ₃		2113.74 ± 14.08				
$\frac{(FC-9)}{(FC-10)}$ avg C ₁ & C ₄			1.04968 ± 0.00159	1.05576 ± 0.00172		
$\frac{(FC-11)}{(FC-12)}$ avg C ₁ , C ₂ & C ₄						
$\frac{(FC-13)}{(FC-14)}$ avg C ₁ , C ₂ & C ₄						1.25596 ± 0.00421
$\frac{(FC-17)}{(FC-18)}$ avg C ₁ , C ₂ & C ₄					1.43930 ± 0.00914	
$\frac{(5-3)}{(8-2)}$ avg C ₂ & C ₃						

97.81% ^{235U} } 1.49% ^{235U} + 0.63% ^{238U}
 97.81% ^{234U} } 0.07% ^{236U}

.37 } < 10ppm Heavy
 .37 } elements cont.

97.34% ^{235U}, 0.3379% ^{236U}
 ~ 7ppm ^{235U}

173 12 Jan 68	174 12 Jan 68	178 15 Jan 68	179 16 Jan 68
C ₁ → FC-14	C ₁ → FC-12		
C ₂ → FC-13	C ₂ → FC-11		

0.44958
 0.52442

0.59406
 0.74709

766
 104

0.85779
 ± 0.00438

1.25546
 ± 0.00421

30
 14

1747.38 ± 9.39 1732.60 ± 12.34

250

Cont. from p. 88
2% V Fy in paraffin $H/x = 614$

Instrument Check on 4/21/66 Source 1.0 mCr

PM-1	Low Trip	OK	Alarm Trip	OK	
PM-2			Alarm Trip		
IC-1	$> 3 \times 10^{-4}$	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-4}$	Meter Trip	OK	Redlight	OK
IC-3	Respond	Calibration	S/O.	Alarm	OK
IC-4	Respond	Calibration	S/O.	Press diff.	0.16"
CRM		Meter Trip			

Apr 157 To build a stack reflected with 6" of polyethylene on side and top and 6" of plexiglass on bottom and adj mass to get $k = 1$.

Stack 22" x 22" x 23" high reflected as above.

time condition table Separation

8⁴⁰ $K < 1$ ($\sim -3\%$) 0.0

9⁰¹ Shut Down Add 9 Pcs $\frac{1}{4} \times \frac{1}{4} \times \frac{1}{4}$ " to movable table (marked X)

9⁴⁰ $K > 1$ ($\sim +2.2\%$) 0.0

9⁵¹ Shut Down Remove 6 Pcs $\frac{1}{4} \times \frac{1}{4} \times \frac{1}{4}$ " (marked Y)

10³⁰ $K > 1$ 0.0

10⁵³ Shut Down to Adjust Inst.

11¹² $K > 1$ 0.0

12¹⁵ Check Crit - Shut Down (Removed 2x4x4 marked Z)


12⁴⁰ $K \sim 1$ 0.0


12²² start Pulsing

2¹⁵ Scram (Neutron Burst with Accelerator)

Expr

158





U2F4

 $\frac{1}{2}x = 614$

Instrument Check on H-22-106 Source

251

PM-1	Low Trip	✓	Hi Alarm Trip	✓
PM-2				
IC-1	3×10^{-11}	✓	Fast Trip	✓
IC-2	3×10^{-11}	✓		
IC-3	Response ok	S.P.	Red light	✓
IC-4	Response ok	S.P.	Alarm	✓
CRM	Master Trip		Press Dif. 0.065	

Purpose: Pulse at critical stack $22" \times 22" \times 23"$
 + $\frac{1}{4}"$ indicated by X (see sketch) U_{F4} 2%, Reflected
 with 6" of Polyethylene on sides and top and 6"

Expr time of Plexyglass on Bottom

158 8³⁰ condition table separation

$K < 1$ 0.0

8⁵⁰ shut down Added 1 pc $\frac{1}{4} \times 4 \times 4$ marked γ

9⁰⁶ $K < 1$ (~ -0.5539) 0.0

9²⁶ shut down Added 1 pc $\frac{1}{4} \times 2 \times 4$ marked β

9³⁸ $K < 1$ (~ -0.2639) 0.0

10⁰⁰ shut down Added 3 pc $\frac{1}{4} \times 2 \times 2$ marked w

10⁰⁹ $K > 1$ 0.0

10³⁰ start Pulsing

11⁰⁰ shut down because mentioned source pulse too small.
 Trouble with pulse generator.

252

U₂₃₅ #X = 614Instrument Check on 26 April Source 10mcr

PM-1	Low Trip	OK	Alarm Trip
PM-2			Alarm Trip
IC-1	$> 3 \times 10^{-11}$	Meter Trip	OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK
IC-3	Responds	Calibration	OK
IC-4	Responds	Calibration	OK
CRM	Meter Trip		Press. diff. 0.06"

Purpose: Check Crit And Count Rate on stack

Have placed BF₃
detector on top
of fuel inside reflector.

22" x 22" x 23" + 1/4" indicated on sketch (see P251)
 U₂₃₅ 2% Reflected with 6" of Polyethylene on
 sides and top with 6" Plexyglass on Bottom.

Expt time condition

table Separation

159 12²²K_{eff} 1

0.0

1²⁰

lower Power to check Accelerators

1³⁰K_{eff} 1

0.0

#26

Shut Down

Pulsed for ~ 2.5 hrs.

Pulsing data: Ch width = 160 nsec; B_g ratio = 2; Delay ratio = 2

Burst width = 900 nsec; Rate = 12 cps; 135 KV;

Steady beam current ≈ 20 namps, Avg pulsing I below meter sens.

Meas. λ_c from Computer fit = -137.49 ± 0.34

PM-1	Low Trip	✓	Hi
PM-2			Alarm Trip
IC-1 3×10^{-11}	Meter Trip	✓	Alarm Trip
IC-2 3×10^{-11}	Meter Trip	✓	Fast Trip
IC-3	Response ok Calibration		
IC-4	Response ok Calibration		Red light
CRM	Meter Trip		Alarm
			Press Dif 0.06"

Purpose: Pulse At Critical Stack $22" \times 22" \times 23"$
 $\frac{1}{4}"$ indicated on sketch (see p. 251) U.F.H. 2%
 Reflected with 6" of Polyethylene on Sides
 And top with 6" Plexyglass on Bottom

251)
 on
 u,

Expr time	condition	table Separation	
160	9 ⁰⁵ K > 1	0.0	Probably done to check comp. of P. w/40F. ^{low than previous day.}
	9 ³¹ shut down		Remove $\frac{1}{4}" \times 2" \times 4"$ see (sketch) p 251
	9 ⁴⁴ K > 1	0.0	
	10 ¹⁰ shut down		Remove $\frac{1}{4}" \times 2" \times 4"$ Ⓞ
	10 ¹⁷ K > 1	0.0	
	10 ³¹ shut down		Remove 3 pcs $\frac{1}{4}" \times 2" \times 2"$ Ⓞ
	10 ⁴³ K > 1 slightly	0.0	
	11 ⁰⁰ shut down		Remove 1 pc $\frac{1}{4}" \times 2" \times 2"$ □
	11 ¹⁰ K ~ 1	0.0	
	11 ²⁵ start Pulsing		check critical ~ 0.114 posit.
	4 ¹⁸ shut down		

Pulsing data same as Expt. V2-159, p. 252.

Meas. λ_c from Computer fit = -136.572 ± 0.266

254

V(29) Fy in paraffin $H/x = 614$

Instrument Check on 5-3-66 Source 10mcr

PM-1	OK	Low Trip	OK	Alarm Trip	OK
PM-2				Alarm Trip	
IC-1	73×10^{-11}	Meter Trip	OK	Fast Trip	OK
IC-2	$> 3 \times 10^{-11}$	Meter Trip	OK	Redlight	OK
IC-3	Out from instrument	Calibration	—	Alarm	OK
IC-4	Responds	Calibration	1/2 -	Press Diff.	0.06
CRM		Meter Trip			

Purpose: To do hit. perturbation meas. on tall stack
see pp. 53-57

Expt 161
None stacked $21 \times 22 \times 48$ " high
b > 1 with plexiglass ($19 \frac{1}{2} \times 24 \times 1$)
b < 1 no plexiglass

Expt 162
 $21 \times 22 \times 49$ " high
b > 1 with plexiglass
b < 1 no plexiglass

405
Let decay down to background $\rightarrow \sim 3.5$ on 3×10^{-11} meter IC-2 and 0.013 m.
Shut Down

Exp
163
164
165
166
167

PM-1	Low Trip <input checked="" type="checkbox"/>	Hi Alarm Trip <input checked="" type="checkbox"/>
PM-2		
IC-1	3 x 10 ⁻¹¹ <input checked="" type="checkbox"/>	Fast Trip <input checked="" type="checkbox"/>
IC-2	3 x 10 ⁻¹¹ <input checked="" type="checkbox"/>	
IC-3		Red light <input checked="" type="checkbox"/>
IC-4	Response OK <input checked="" type="checkbox"/>	Alarm <input checked="" type="checkbox"/>
CRM	Meter Trip	Press Dif 0.06"

Purpose: Ht Perturbation Meas on table
 stack 21" x 22" x ⁴⁹48" High

Expr time	Condition	table Separation	Plexyglass 19 1/2 x 24 x 1
163 9 ⁰²	R > 1	0.0	with
9 ¹⁷	Shut Down to Adjust Counters		
9 ⁴⁸	R > 1	0.0	w
10 ¹³	R < 1		w/o
10 ²²	Separate to Add fuel 1" to HT ¹⁵⁰ high		
IC-1 013 m 164 10 ³⁶	R > 1	0.0	w/o
	4.4364	4.3724	4.4664
	Separate to Remove fuel 1" 49" high		
165 11 ¹⁵	R < 1	0.0	w/o
	-3.7624	-3.8604	-3.898
11 ³⁹	Separate to Add fuel 1" to Top		
166 12 ⁴⁵	R > 1	0.0	w/o
	4.2464	4.2054	4.2954
109	Separate to Remove fuel 1"		
167 1 ²¹	R < 1	0.0	w/o
	-4.1254	-4.1154	-4.2764
158	Separate to Add fuel 1"		
168 2 ¹⁴	R > 1	0.0	w/o
	3.7674	3.7444	3.8524
2 ⁴⁰	Separate to Remove fuel 1"		
169 2 ⁵⁴	R < 1	0.0	w/o
	-4.547	-4.531	-4.716
2 ²²	Separate to Add fuel 1"		
2 ³⁷			
170 3 ⁻	R > 1	0.0	w/o
	3.346	3.360	3.392
4 ⁰⁵	Shut Down		

256

V(2)F4

H/x = 614

Instrument Check on 5-5-66 Source _____

Ue

PM-1	Low Trip	✓	Hi	Alarm Trip	✓
PM-2				Alarm Trip	
IC-1	3×10^{-11}	Meter Trip	✓	Fast Trip	✓
IC-2	3×10^{-11}	Meter Trip	✓		
IC-3	Response			Red light	✓
IC-4		Calibration		Alarm	✓
CRM		Meter Trip		Press Dif 0.06	

Purpose: Rerun of Exp # 163-170 see p. 255

Exp. time	Condition	21x22x50" high table Separation	Plexyglass 19x24x49"	EXP
171 8 ³⁵	K > 1	0.0	w/o	180
9 ⁰³	Separate to Remove fuel	3.9089g 3.897g	1" from top	
172 9 ²⁰	K < 1	0.0	w/o	181
9 ⁴⁷	Separate to Add fuel	-4.167g -4.137g -4.186g	1"	
173 10 ⁰⁵	K > 1	0.0	w/o	182
10 ³⁸	Separate to Remove fuel	3.960g 3.924g	1"	
174 10 ⁵⁵	K < 1	0.0	w/o	183
11 ²⁵	Separate to Add fuel	-4.266g -4.244g -4.428g -4.428g	1"	
175 12 ⁴¹	K > 1	0.0	w/o	184
1 ²¹	Separate to Remove fuel	3.650g 3.611g	1"	
176 1 ³⁶	K < 1	0.0	w/o	185
2 ⁰⁴	Separate to Add fuel	-4.649g -4.585g -4.754g -4.754g	1"	
177 2 ²⁵	K > 1	0.0	w/o	
2 ⁵⁶	Separate to Remove fuel	3.389g 3.358g	1"	
178 3 ⁰¹	K < 1	0.0	w/o	
3 ³⁵	Separate to Add fuel	-4.911g -4.871g -4.994g -4.994g	1"	Ang
179 3 ⁵⁰	K > 1	0.0	w/o	
4 ²⁵	Shut Down	3.143g 3.121g	3.216g 3.216g	

U(2) F4

H/x = 614

Instrument Check on 5-6-66 Source

257

PM-1	Low Trip <input checked="" type="checkbox"/>	Hi Alarm Trip <input checked="" type="checkbox"/>
PM-2		Alarm Trip <input type="checkbox"/>
IC-1	2×10^{-11}	Fast Trip <input checked="" type="checkbox"/>
IC-2	3×10^{-11}	
IC-3	Response <input checked="" type="checkbox"/> 5g R	Red light <input checked="" type="checkbox"/>
IC-4	Response <input checked="" type="checkbox"/> 5g R	Bldg Alarm <input checked="" type="checkbox"/>
CRM	Water Trip	Press Dif 0.06"

Purpose: Return of Expt # 163-179 (See P 255-)

Exp time	Condition	table	Separation	Plexyglass
180 10 ⁵⁵	b > 1	0.0		w/o
11 ⁵⁵	Separate to Remove fuel	1.991g	1.986g 2.006g	2.006g 1" from PaP
181 12 ¹³	R < 1	0.0		w/o
12 ³⁸	Separate to Add fuel	-6.369g	-6.356g -6.561g	-6.517g
182 12 ⁵³	R > 1	0.0		w/o
1 ³⁶	Separate to Remove fuel	1.736g	1.764g 1.754g	1.785g
183 1 ⁵³	R < 1	0.0		w/o
2 ¹⁸	Separate to Add fuel	-6.627g	-6.585g -6.819g	-6.788g
184 2 ³⁵	R > 1	0.0		w/o
3 ¹⁴	Separate to Remove fuel	1.542g	1.528g 1.544g	1.518g
185 3 ²⁹	R < 1	0.0		w/o
H ⁵⁴	Shut Down	-6.957g	-6.973g 7.151g	7.177g

Measured stack (53.804cm x 56.302cm x 124.948cm)

avg weight of 1" of fuel on 21x22" stack from Expts 163-185 = 8.2297 ± 0.183g

258

U(2) F₄ H/x=614

Instrument Check on 5-9-66 Source

U(2)

PM-1	Low Trip	✓	Hi Alarm Trip	✓	
PM-2			Alarm Trip		
IC-1	3×10^{-11}	Motor Trip	✓	Fast Trip	✓
IC-2	3×10^{-11}				
IC-3	Response	✓	Calibration 5g R	Red light	✓
IC-4	Response	✓	Calibration 5g R	Bldg Alarm	✓
IC-5		Motor Trip		Press Dif 0.07"	

Purpose: Check Critical on stack 40x44x16" U_F 2%

Expr time	Condition	Table Separation	Plexyglass	Expr
186 1 ⁵⁰	K > 1	0.0	w	187
2 ⁰⁵	Separate	Add 1/4" to 1/4 of stack	sw corner	188
2 ²¹	K < 1	0.0	w/o	189
3 ⁰⁵	Shut Down			190

Expr time	Condition	Table Separation	Plexyglass	Expr
3 ³⁰	Separate	Add Fuel		191
196 3 ⁴³	K > 1	0.0	w/o	192
4 ⁰⁵	Shut Down			193

Room temp Approx 78°F

4¹⁵ Reduce thermostat From 74° to 70°

194
195

PM-1	Alarm Trip	✓	Hi	Alarm Trip	✓
PM-2	Alarm Trip			Alarm Trip	
IC-1	3×10^{-11}	✓		Fast Trip	✓
IC-2	3×10^{-11}	✓			
IC-3	Response	✓	S&R	Red light	✓
IC-4	Response	✓	S&R	Bldg Alarm	✓
CRM				Press Dif 0.08"	

Purpose: Ht. Perturbation Meas on stack 40" x 44" x 16"
 (wt_H 2%) + 1/4" to ht on 1/4 of stack

Expr time	condition	table	Separ.	Plexyglass	2 Res	Shade cell area 16 1/4" high
187 8 ⁴⁰	K < 1	40 x 44 x 16" + 1/4" m SW 1/4 of stack	0.0	w/o		5
9 ²²	Separate	-4.3674	-4.3844	1/4 of	-4.4834	-4.5144
188 9 ³⁵	K > 1	40 x 44 x 16" + 1/4" m SW and NE quadrant of stack	0.0	w/o		
9 ⁵⁵	Separate	6.5824	6.5914		6.7244	6.7094
189 10 ⁰⁹	K < 1		0.0	w/o		
10 ⁵¹	Separate	-4.5774	-4.5314		-4.7164	-4.6784
190 11 ⁰⁶	K > 1		0.0	w/o		
11 ²⁷	Separate	6.4134	6.4054		6.5034	6.3844
191 11 ⁴¹	K < 1		0.0	w/o		
12 ²³	Separate	-4.7354	-4.7474		-4.8114	-4.8114
192 12 ⁴¹	K > 1		0.0	w/o		
1 ⁰¹	Separate	6.212	6.204		6.3644	6.2894
193 1 ¹⁶	K < 1		0.0	w/o		
1 ⁵⁸	Separate	-4.9364	-4.9114		-5.0494	-5.0704
194 2 ¹³	K > 1		0.0	w/o		
2 ³⁵	Separate	6.0464	6.0384		6.1844	6.1524
195 2 ⁴⁸	K < 1		0.0	w/o		
	(See P 2-58)	-5.1054	-5.0704		-5.2594	-5.2134

260

V(2)F₁

H/x = 614

Instrument Check on 5-11-66 Source

PM-1	Low Trip	<input checked="" type="checkbox"/>	Hi Alarm Trip	<input checked="" type="checkbox"/>	
PM-2			Alarm Trip		
IC-1	3 x 10 ⁻¹¹	Meter Trip	<input checked="" type="checkbox"/>	Fast Trip	<input checked="" type="checkbox"/>
IC-2	3 x 10 ⁻¹¹	Meter Trip	<input checked="" type="checkbox"/>		
IC-3	Response	Calibration		Red light	<input checked="" type="checkbox"/>
IC-4	Response	Calibration		Bldg Alarm	<input checked="" type="checkbox"/>
CRM		Meter Trip		Press Dif 0.68"	

Purpose: Re-run of Expts. 187-196 see P. 259

Temp → 8⁰⁰ AM 78°F 4²⁰ 78.5°F Hatched Area 16 1/4 high

Expt time	Condition	table Separation				2 Res Plexyglass	
197 8 ³⁰	K > 1	40x44x16 + 1/4" on NE & SW quadrants of stack				w/o	<input checked="" type="checkbox"/>
9 ⁰⁰	Separate	4.8714	4.9474	4.9484	4.9774	Remove fuel (1/4 from 1/4 of stack)	
198 9 ¹⁴	K < 1	40x44x16 + 1/4" on SW 1/4 of stack				w/o	<input checked="" type="checkbox"/>
9 ⁵⁷	Separate	-6.1694	-6.1034	-6.2614	-6.3764	Add fuel	
199 10 ¹³	K > 1	0.0				w/o	<input checked="" type="checkbox"/>
10 ³⁷	Separate	4.7554	4.8474	5.0064	4.9614	Remove fuel	
200 10 ⁵²	K < 1	0.0				w/o	<input checked="" type="checkbox"/>
11 ⁵²	Separate	-6.1954	-6.1314	-6.5964	-6.4674	add fuel	
201 11 ⁴⁹	K > 1	0.0				w/o	<input checked="" type="checkbox"/>
12 ¹⁴	Separate	4.8474	4.8014	4.9244	4.9074	Remove fuel	
202 12 ²⁸	K < 1	0.0				w/o	<input checked="" type="checkbox"/>
1 ⁰⁷	Separate	-6.324	-6.301	-6.517	-6.474	Add fuel	
203 1 ²⁵	K > 1	0.0				w/o	<input checked="" type="checkbox"/>
1 ⁴⁷	Separate	4.7474	4.7244	4.8674	4.8164	Remove fuel	
204 2 ⁰²	K < 1	0.0				w/o	<input checked="" type="checkbox"/>
2 ⁴¹	Separate	-6.4674	-6.4104	-6.5984	-6.5904	Add fuel	
205 2 ⁵⁶	K > 1	0.0				w/o	<input checked="" type="checkbox"/>
3 ²²	Separate	4.5444	4.5304	4.6654	4.6264	Remove fuel	
206 3 ³⁴	K < 1	0.0				w/o	<input checked="" type="checkbox"/>
		-6.6134	-6.5684	-6.6074	-6.7654	4 ¹⁴ Shut Down	

Measured stacks used in Exps 186 → 206
(102.284 cm x 112.636 cm x 40.759 cm)

Avg Width of $\frac{1}{4}$ " or $\frac{1}{4}$ " of top of 40x44" stack from
Exps. 187-206 = $11.177 \pm 0.082 \phi$

2% Assay U_{F4} + CH₂ (Final Blends) 6th Dilution

4410-28

Blend#	Batch#	Net (g)	Req#	G.U/G	W/o U-235	U-(g)	U-235 (g)	W/o U _{F4}	W/o CH ₂	Comments
2	2-130	79,550	378326	.5339	2.11	42,472	896	70.44	29.56	1. Blends No. 1, 4, 9, 11, 16, and 20 were cross blended into blends 20, 21, 22, 33, 34 and 35.
3	2-129	81,250	327	.5355	2.03	43,509	883	70.65	29.35	
5	2-127	80,325	328	.5378	2.01	43,199	868	70.95	29.05	
6	2-6129	77,900	329	.5306	2.04	42,375	865	70.00	30.00	
7	2-6130	80,770	330	.5280	1.99	42,647	849	69.65	30.35	
8	2-6131	79,000	331	.5276	2.03	41,680	846	69.60	30.40	
10	2-6133	82,350	332	.5297	1.98	43,621	864	69.89	30.11	
12	2-6135	71,200	333	.5306	2.05	37,779	774	70.01	29.99	
13	2-6136	81,125	334	.5369	2.01	43,556	875	70.84	29.16	
14	2-6137	82,350	335	.5269	1.94	43,390	842	69.52	30.48	
17	2-6140	80,975	337	.5323	2.07	43,103	892	70.23	29.77	
23	2-6146	69,250	342	.5375	2.03	37,222	756	70.91	29.09	
24	2-6147	71,400	343	.5347	1.99	38,178	760	70.54	29.46	
33	2-6152	79,125	322	.5281	2.04	41,786	852	69.68	30.32	
34	2-6153	80,000	323	.5356	2.04	42,848	874	70.66	29.34	
35	2-6154	79,700	324	.5283	2.04	42,106	859	69.70	30.30	
36	2-6157	78,500	344	.5264	2.04	41,322	843	69.45	30.55	
37	2-6158	76,500	357	.5291	2.04	40,476	826	69.80	30.20	
38	2-6161	77,900	355	.5399	2.04	42,058	858	71.23	28.77	
39	2-6162	79,075	347	.5291	2.04	41,839	854	69.81	30.19	
40	2-6163	77,500	356	.5337	2.04	41,362	844	70.41	29.59	
41	2-6164	76,000	353	.5362	2.04	41,824	853	70.74	29.26	
42	2-6165	77,400	350	.5324	2.04	41,208	841	70.23	29.77	
43	2-6166	78,300	351	.5401	2.04	42,290	863	71.26	28.74	
44	2-6167	74,700	352	.5268	2.04	39,352	803	69.50	30.50	
Totals and averages		1,256,145		.532281	2.03	1,041,222	21,140	70.228	29.78	<p>Total Vol = 764,034.9 cm³</p> <p>Avg overall density = 2.302 g/cm³</p> <p>Based on assumed assay of 2.00 w/o ²³⁵U in U</p> <p> $\frac{g U^{235}}{g} = 0.01064$ $H/U = 19.678$ $H: ^{235}U = 971.7$ $^{235}U = 0.6276 \times 10^{20}$ $^{238}U = 30.3630 \times 10^{20}$ $H = 609.842 \times 10^{20}$ $C = 293.193 \times 10^{20}$ $F = 123.762 \times 10^{20}$ </p>
Correction for purity (blends 33 through 44)				.531910	$\pm .004248$ $\pm .8\%$	1,040,494	21,125	$\pm 0.55\%$ $\pm .8\%$		
*Material transferred to ORNL		1,258,592				935,412	18,990	70.17	29.83	
*The average g/g (.531910) and the average % U-235 (2.03) are used to determine the uranium and U-235 transferred to ORNL on WB 76-84-165										

UF-1 (2% Enriched) + CH₂ Blocks For OPNL 6th Dilution

4410-28

Batch#	Box#	Part Numbers	Net(g)	Date	Batch#	Box#	Part Numbers	Net(g)	Date	
2-6183	1	6B 1/4 1 thru 44	1,735	6-29-67	2-6209	9	6A4 235 thru 261		6-20-67	
2-6184	2	6B 1/2 1 " 46	3,602	"	2-6210	7	6A4 262 " 288		"	
2-6183	1	6B1 1	5,300	"	2-6211	5	6A4 289 " 315	1,355,515	"	
2-6184	2	6B1 2 thru 34		"	2-6172	6	6A4 316 " 342		6-27-67	
2-6183	1	6B4 1 " 13	7,819	"	2-6173	8	6A4 343 " 369		"	
					2-6175	10	6A4 370 " 396		"	
2-6184	2	6A 1/4 1 thru 8		6-29-67	2-6177	7	6A4 397 " 423		"	
2-6185	3	6A 1/4 9 " 70	17,574	"	2-6178	5	6A4 424 " 450		"	
2-6186	4	6A 1/4 71 " 114		"	2-6179	11	6A4 451 " 477		"	
2-6186	4	6A 1/2 1 " 9		"	2-6215	6	6A4 478 " 504		"	
2-6187	5	6A 1/2 10 " 41		"	2-6217	9	6A4 505 " 531		6-29-67	
2-6188	6	6A 1/2 41 " 73	33,880	"	2-6218	12	6A4 532 " 558		"	
2-6189	7	6A 1/2 74 " 105		"	2-6220	5	6A4 559 " 582		"	
2-6190	8	6A 1/2 106 " 111		"						
2-6190	8	6A1 1 " 13		"		5	6B4 14 thru 26	7,848	7-7-67	
2-6191	9	6A1 14 " 29		"						
2-6192	10	6A1 30 " 45	75,641	"						
2-6193	11	6A1 46 " 61		"						
2-6195	12	6A1 62 " 77		"						
2-6196	1	6A1 78 " 112		"						
2-6196	1	6A2 1 " 42		"						
2-6197	2	6A2 43 " 109	249,678	"						
2-6198	3	6A2 110 " 176		"						
2-6200	4	6A2 177 " 207		"						
2-6200	4	6A4 1 " 18		"						
2-6201	5	6A4 19 " 45		6-13-67						
2-6202	6	6A4 46 " 72		"						
2-6203	7	6A4 73 " 99		"						
2-6204	8	6A4 100 " 126		"						
2-6205	9	6A4 127 " 153		"						
2-6206	10	6A4 154 " 180		"						
2-6207	11	6A4 181 " 207		6-20-67						
2-6208	12	6A4 208 " 234		"						
					Summary Data					
					Part Size	No.	Net(g)	U(g)	U-235(g)	
					6B 1/4 2x2x1/4	44	1,735	923	19	
					6B 1/2 2x2x1/2	46	3,602	1,916	39	
					6B1 2x2x1	34	5,300	2,819	57	
					6B4 2x2x4	26	15,667	8,333	169	
					6A 1/4 4x4x1/4	114	17,574	9,348	190	
					6A 1/2 4x4x1/2	111	33,880	18,021	366	
					6A1 4x4x1	112	53,241	40,234	817	
					6A2 4x4x2	207	249,678	132,866	2,696	
					6A4 4x4x4	562	1,355,515	721,012	14,637	
					Totals	1256	1,753,592	935,412	18,990	

PLANT	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	
Lot	378279	378280	378281	378282	378283	378284	378285	378286	378287	378288	378289	378290	378291	378292	378293	378294	378295	378296	378297	378298	378299	378300	378301	378302	378303
Al	25	10	40	20	15	12	15	12	8	6	12	30	15	10	2	<1	10	20	6	6	1	15	60	15	
B	<.1	<.1	<.1	<.1	.1	<.1	<.1	<.1	1.0	1.0	.2	.5	.8	<.1	<.1	<.1	1.5	.1	<.1	<.1	<.1	<.1	<.1	<.1	<.1
Be	<.01	<.01	<.01	.05	.01	<.01	<.01	<.01	<.01	<.01	<.01	<.01	<.01	<.01	<.01	<.01	.01	.02	<.01	<.01	<.01	<.01	<.01	<.01	<.01
Ca	50	60	50	70	50	45	50	65	35	50	100	150	150	100	30	40	60	1.25	40	70	70	30	100	60	
Cd	.4	.4	<.1	.2	.2	<.1	<.1	.4	4.0	5.0	.6	.2	.1	.2	.1	.2	.4	<.1	.2	.3	.2	.1	.3	.4	
Co	1	1	<1	1	1	1	1	2	1	2	5	3	3	18	15	4	1	1	6	2	1	10	25	5	
Cr	175	175	150	175	125	150	175	200	200	175	200	200	200	300	300	150	150	225	250	200	200	350	800	275	
Cu	8	8	6	6	4	7	6	6	4	5	5	6	4	3	3	3	5	5	4	40	6	10	8	5	
Fe	400	400	200	400	115	175	200	150	90	80	175	500	175	200	175	150	140	190	175	150	150	250	350	700	
Li	<.2	<.2	<.2	<.2	<.2	<.2	<.2	<.2	<.2	<.2	<.2	<.2	<.2	<.2	<.2	<.2	<.2	<.2	<.2	<.2	<.2	<.2	<.2	<.2	<.2
Mg	50	40	25	40	18	25	25	45	35	35	40	50	40	30	20	25	40	60	60	60	55	80	60	50	
Mn	15	15	10	15	8	10	10	12	12	15	20	20	20	25	18	15	15	15	18	20	15	30	40	15	
Na	6	15	10	8	30	15	10	10	90	100	100	40	30	30	30	20	100	100	50	100	150	45	50	30	
Ni	75	125	70	125	50	75	60	300	80	100	200	100	90	300	300	150	45	75	400	300	150	800	1200	350	
P	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100
Si	15	15	<10	15	30	15	15	10	10	10	15	20	20	18	10	<10	<10	<10	<10	<10	<10	50	200	55	
V	4	5	2	4	3	4	5	5	5	5	2	6	6	6	6	2	4	5	3	3	3	4	6	3	
As	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10
Au	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
Ba	4	6	4	5	5	4	3	4	2	3	<2	4	2	2	2	2	2	3	<2	2	<2	<2	<2	<2	<2
Bi	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
Cs	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100
Ga	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
Ge	<.4	<.4	<.4	<.4	<.4	<.4	<.4	<.4	<.4	<.4	<.4	<.4	<.4	<.4	<.4	<.4	<.4	<.4	<.4	<.4	<.4	<.4	<.4	<.4	<.4
Hf	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100
In	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2
K	<6	<6	<6	<6	<6	<6	<6	<6	<6	<6	<6	<6	<6	<6	<6	<6	<6	10	<6	<6	<6	<6	<6	<6	<6
Mo	60	60	40	40	30	40	40	40	25	20	60	60	90	90	70	60	10	10	15	4	4	40	100	15	
Nb	<4	<4	<4	<4	<4	<4	<4	<4	<4	<4	<4	<4	<4	100	4	<4	<4	<4	60	<4	<4	<4	<4	<4	<4
Pb	4	2	2	4	2	2	2	8	2	2	<1	8	4	3	3	2	5	3	6	4	5	6	6	3	
Pd	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
Pb	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20
Sb	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2
Sn	2	3	2	2	4	2	4	4	2	2	2	5	5	4	4	4	2	3	4	5	4	10	30	4	
Sr	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20
Ti	10	6	<4	10	8	4	6	6	<4	<4	<4	4	4	<4	<4	<4	5	15	10	6	4	4	6	4	
Tl	<4	<4	<4	<4	<4	<4	<4	<4	<4	<4	<4	<4	<4	<4	<4	<4	<4	<4	<4	<4	<4	<4	<4	<4	<4
W	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100	100	100	<100	<100	<100	<100	<100	<100	<100	<100	<100	<100
Zn	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	50	<10	<10	<10	<10	<10	<10	<10
Zr	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20	<20
Total																									

266

V(2)

$H/X = 972$

Instrument Check on 30 June 67 Source 10 mct

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2		OK	Alarm Trip	
IC-1	Meter Trip	OK	Fast Trip	OK
IC-2	Meter Trip	OK		
IC-3	Calibration	S/P.R. OK	Red light	OK
IC-4	Calibration	S/P.R. OK	Bld alarm	OK
CRM	Meter Trip		Press Diff.	0.11"

$1/4$ " Al plate on top of Al box on table.

- Expt 1 Approach to critical for 32 x 34" base assembly.
- 2 24" high Tables closed \rightarrow buff $\ll 1$, No multipliers
 - 2 32" high Tables closed \rightarrow buff $\ll 1$, slight multipl.
 - 3 34" high Table closed buff < 1 , 9mult. ~ 3
 - 4 35" high Tables closed $b > 1$ $T = 52.98 \text{ sec} \rightarrow 15.75 \mu\text{f}$
 - 5 34 $3/4$ " high + 1" x 19 $3/4$ " x 24" plexiglas on one side $b > 1$ $T = 25.68 \text{ sec}$
 $24.82 \mu\text{f}$
 $34 \text{ } 3/4$ " high Removed plexiglas $b > 1$ $T = 90.116$ $10.711 \mu\text{f}$
 - 6 34 $1/2$ " + $1/4$ " on half with plexiglas $b > 1$ $T = 31.486$
 $22.029 \mu\text{f}$
 w/o plexiglas $b > 1$ $T = 129.9$ $P_2 = 14.0 \mu\text{f}$
 $8.021 \mu\text{f}$
 - 7 34 $1/2$ " high $b > 1$ with plexiglas $T = 58.495$
 $19.471 \mu\text{f}$
 $b > 1$ w/o plexiglas $T = 211.5$ $P_2 = 14.16 \mu\text{f}$
 $5.315 \mu\text{f}$
 - 8 34" high + $1/2$ " on half of top. ~~$b > 1$~~ $b > 1$ w/o pl. $T = 64.71$
 $13.694 \mu\text{f}$ $P_2 = 14.34 \mu\text{f}$
 $b < 1$ w/o pl. $T = -2.070.3 \text{ sec}$
 $-0.641 \mu\text{f}$

V(2)F₄ $\frac{H}{X} = 972$

267

Instrument Check on 7 Sept 67 Source 10 mCi Y

AM-1	Low Trip	OK	Alarm Trip	OK
AM-2			Alarm Trip	
IC-1	Meter Trip	OK	Fast Trip	OK
IC-2	Meter Trip	OK		
IC-3	Responds	Calibration S/R. OK	Redlight	OK
IC-4			Only Alarm	OK
CRM			Price Diff.	0.06

$\frac{1}{8}$ " Al plate on top of 5 layers of Al boxes on table

Expts 9 Have stacked 32x34x32" high assembly. 16"x34" base on each table. $b_{eff} \ll 1$

10 Stack now 32x34x34" high + $\frac{1}{2}$ " on N half of top.

$b > 1$ with Plexiglas same as Expt 5.

$b < 1$ w/o Plexiglas

Opened Table 1.75 rev. and let power decay to ($P = -4.01 \phi$)

background. $B_g \sim 0.0045$ on IC-3 and ~ 0.0055 on IC-4

Closed tables

after 72 min power still increasing. Nearly count period $\therefore b \geq 1$

Shut down.

4:12 PM

3: PM.

Expts

1.

1544

6884

9

2

1544

268

U(2)F₄-6

Temp = 19.7°C

Instrument Check on 8 Sept 67 Source 10 m c f

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	Meter Trip	OK	Fast Trip	OK
IC-2	Meter Trip	OK		
IC-3	Response	Calibration		Red light OK
IC-4	Response	Calibration		Red Alarm OK
CRM	METER TRIP			Press diff 0.06"

Time Eppor.

9:00 11 Stack room 32x34x34 1/2 high

To check and adjust counters for h_f perturbation measurement.

Moved IC-3 from under table to balcony which reduced

sens. about a factor of 4. Will take all data above

0.1 on IC-3 or ~ 1.5 decades above background.

10:15 12 32x34x34 1/2"

b > 1

12:05 13 32x34x34"

b < 1

1:15 14 32x34x34 1/2"

b > 1

2:05 15 32x34x34"

b < 1

2:55 16 32x34x34 1/2"

b > 1

3:30 17 32x34x34"

b < 1

3.00

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	Meter Trip	OK	Fast Trip	OK
IC-2	Meter Trip	OK	Red light	OK
IC-3	<i>Response</i>	Calibration	<i>S.f.R.</i>	<i>Bldg alarm OK</i>
IC-4	<i>Response</i>	Calibration	<i>S.f.R.</i>	<i>Pres diff 0.06"</i>
CRM	Meter Trip			

To adjust stack to $k=1$ and check out ~~also~~
 pulsing ^(in source) equipment for prompt neutron decay const. meas.

x.

3.00PM	18	32 x 34 x 34" + 1/2" on N half.	$k > 1$
	19	32 x 34 x 34 1/4" high	$k > 1$

270

U(2)F₄-6

Temp ~ 20.1°C

Instrument Check on Sept 18, 67 Source 10mCf

EM-1	Low Trip	OK	Alarm Trip	OK
EM-2			Alarm Trip	
IC-1	Neutron Trip	OK	Fast Trip	OK
IC-2	Meter Trip	OK		
IC-3	Respond	Calibration OK S.J.P.	Red light	OK
IC-4	Respond	Calibration OK S.J.P.	Bldg Alarm	OK
CRM	Meter Trip		Pres Diff	0.06"

To finish adjusting assembly and to pulse at critical.

Time Exp

10:AM 20 32x34x34 1/4" legs 1/4x4"x4" piece on each corner

Have a 1"x6"x6" piece of plexiglas on rod shims on south face of stack for control element.

4>1

12:10 21 Pulsing 32x34x34" legs 1/4x4x8 on each corner
 $k \approx 1$; $T \approx 2655 \text{ sec}$; $\rho = 0.48 \phi$ 1/2" BF₃ detector on top surface of stack

near center. Pulsed source ~ 5" from center of side of stack.

Pulsing Data: Ch Width = 160 nsec; B_g ratio = 4; Delay ratio = 8.Burst width = 700 nsec; Rate = ~~4~~ ^{Control at 35 cps} cps; 147 KV; Avg Beam I = 6 μ amps.

Take data for 300 pulses and then separate table to

9 run to reduce power in assembly and repeat.

4:10 Check critical $T \approx 4830 \text{ sec}$ $\rho \approx 0.27 \phi$

4:25 Shut down

Estimate from hand that $\alpha = \frac{\rho}{\Lambda} = -102.6 \text{ sec}^{-1}$ From computer $\alpha = \frac{\rho}{\Lambda} = -103.8 \pm 2 \text{ sec}^{-1}$

V2 Fy-6

Temp ~ 20.3 °C

271

Instrument Check on Sept 19, 67 Source 10 mCr

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	Meter Trip	OK	Fast Trip	OK
IC-2	Meter Trip	OK	Redlight	OK
IC-3	Responds	Calibration OK	S/R	Red alarm OK
IC-4	Responds	Calibration OK	S/R	Press diff 0.06"
CRM	Meter Trip			


To pulse the base assembly of V(2) Fy-6 at critical.

Eppn.

9:30 22 Stack same as Eppn 21 $b > 1$ $p \approx 0.7 \phi$

Removed fuel from N + S edges of stack.

10:30 AM. Flow 32 x 34 x 34" less 1/2 x 4 x 34" on north and south side of top.



$b \approx 1$ $T \approx 10,800 \text{ sec}$ $p \approx 0.1 \phi$

Pulsing data: Ch width = 320 Msec; B_y ratio = 2; Delay ratio = 2
Burst width = 1500 Msec; Rate = 21/sec (Rate control set at 11 cps)

HV = 147 KV; Avg Beam I = 8.5 μamp.

Collect data for 200 pulses per cycle.

3:15 PM

Check critical

$b = 1$

Estimate from hand plot $\lambda = \frac{B}{c} = -104.5 \text{ sec}^{-1}$

From Computer $\lambda_{SC} = \frac{B}{c} = -106.4$

Avg Eppn 021 & 22
 $\lambda_{SC} = -105.1 \pm 1.5 \text{ sec}^{-1}$

3:30

23

Pulsing above stack with table separated

Ch width = 160 Msec; B_y ratio = 4; Delay ratio = 8

Burst width = 700 Msec; Rate = 42 cps; 147 KV;

From Computer $\lambda = -184.9$

$f = 1 - \frac{\lambda}{\lambda_{SC}} = -75.9 \phi = -75.9 \phi$

4:16 PM

Shut down.

Nominal Dimensions 32 x 34 x 34" high
Meas. Dimts 81.56 x 86.77 x 86.44 cm high

272 UZ)F4-6

Instrument Check on 20 Sept 67 Source 10 mCr

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	Meter Trip	OK	Fast Trip	OK
IC-2	Meter Trip	OK	Red light	OK
IC-3 <i>Responds</i>	Calibration	OK	Bly alarm	OK
IC-4 <i>Responds</i>	Calibration	OK	Press Dip	0.06"
CRM	Meter Trip			

To find critical assembly reflected with 6" of polyethylene.
 2:20 PM 24 Have stacked 30"x32" x 28" high assembly reflected with
 6" of polyethylene.
 Moved IC-2 and IC-3 to positions just outside refl.
 on fixed table.
 b << 1
 12 Add 2" fuel 30"x32" x 30" b < 1
 Add 1/2" fuel 30"x32" x 31 1/2" b > 1 at ~0.5 rev.

Instrument Check on 21 Sept 67 source 10 m c F

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	Meter Trip	OK	Fast Trip	OK
IC-2	Meter Trip	OK	Red light	OK
IC-3	Responds	Calibration OK	19 R	Red alarm OK
IC-4	Responds	Calibration OK	1 & R	Press dip 0.06"
CRM	Meter Trip			

25 30x32x31" high refl. 6" polyethylene
 $b > 1$ $T = 136.8 \text{ sec}$ $\rho \approx 7.687 \phi$

26 30x32x30³/₄" + 1/4" on south half.
 $b > 1$ $T = 234.5 \text{ sec}$ $\rho \approx 4.856 \phi$

27 30x32x30³/₄" high
 $b > 1$ $T = 912.0 \text{ sec}$ $\rho \approx 1.375 \phi$

28 30x32x30³/₄" less 1/4" x 12 x 16 on east side of movable table.
 Detector inside refl on surface of fuel ~ middle of S face.
 1/2" x 10" BF₃ $b = 1$ $\rho \approx 0.09 \phi$

Pulsing: Ch Width 320 μsec ; B/ratio = 2; Delay ratio = 4

Burst width = 1 μsec ; Rate 21 pps (control set at 11)

HV = 148 KV Avg Beam I = 2 μamp

$b = 1$ $\rho \approx -0.06 \phi$

From Computer $\lambda = \frac{\rho}{\tau} = -106.5 \text{ sec}^{-1}$

Critical height = $78.20 - \frac{0.635}{6.31} (1.375) = 78.06 \text{ cm}$

see p. 30 \uparrow

274

U(2)F₄-6 Temp ~ 20°CInstrument Check on 22 Sept 67 Source 10 m.c.f.

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	Meter Trip	OK	Fast Trip	OK
IC-2	Meter Trip	OK	Redlight	OK
IC-3	<u>Responds</u> Calibration	OK	<u>S.P.A.</u>	<u>Blk Alarm</u> OK
IC-4	<u>Responds</u> Calibration	OK	<u>S.P.A.</u>	<u>Pres Dif.</u> 0.06'
CRM	Meter Trip			

Puff

29 Stack same as Expt 28. Changed to 1/4" min BF₃

Detector

b < 1 ~ 144 Count rate too low on 1/4" det.

30 added 1/4 x 6 x 16" fuel. Replaced 1/2 x 10" BF₃ det. at upper edge of core.

30 x 32 x 30 3/4 high less 1/4 x 6 x 16" on top.

k ≈ 1 T = 2741 sec P ≈ 0.479

Pulsing: Ch. width = 320 nsec; B_g ratio = 2; Delay ratio = 4

Burst width = 1500 nsec; Rate = 21 cps (Control at 11)

HV = 147 KV Avg Beam I = 9.5 mAmps.

Check Critical T = 3246 sec P ≈ 0.404

4:15 PM

Shut down

From Computer $\lambda = -107.9 \text{ sec}^{-1}$ Avg of Expts 28 & 30 $\lambda = -107.2 \pm 1.0 \text{ sec}^{-1}$ Meas. Dimensions 76.53 x 81.63 x 78.20 cm high
(Nominally 30" x 32" x 30 3/4")

V(2)-6

Temp 24.1°C

V(2) Fy-6 275

Instrument Check on 26 Sept 67 Source 10mct

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	Meter Trip	OK	Fast Trip	OK
IC-2	Meter Trip	OK	Red light	OK
IC-3	Responds Calibration	OK S.F.R.	Bld. Alarm	OK
IC-4	Responds Calibration	OK S.F.R.	Press Dif	1.0"
CRM	Meter Trip			

9:35 AM ^{Expo} 31 Have stacked 32" x 32" base assembly 29" high reflected with 6" of polyethylene. Meas dimen (81.52 x 81.60 x 73.63 cm) _{high}
 $b < 1$

32 32 x 32 x 29" + 1/4 on ^{length} half of top $b > 1$ C-1 → C-1 → 1" BF₃ det in ed-shield in cable rack.

33 32 x 32 x 29 1/4" high $b > 1$ C-3 → 1/2" BF₃ det in ed-shield on balcony

34 32 x 32 x 29" + 1/4 on North half of top $b > 1$ C-4 → 1/4" BF₃ det in cable rack.

35 32 x 32 x 29 1/4" $b > 1$

36 32 x 32 x 29" + 1/4 on South half of top $b > 1$

Temp at 4:15 PM 25.2°C

276

V(2) F₄ - 6Instrument Check on 4 Oct 67 Source 10mCr

FM-1	Low Trip	OK	Alarm Trip	OK
FM-2			Alarm Trip	
IC-1	Meter Trip	OK	Fast Trip	OK
IC-2	Meter Trip	OK	Redlight	OK
IC-3	Responds	Calibration <u>1/2</u>	OK	Delay alarm OK
IC-4	Responds	Calibration <u>1/2</u>		Probe Pip. 0.09"
CRM	Meter Trip			

Time	Exp		Time
11:05		Have reattached 32x34x34" high assembly <u>96 Refl</u>	
	37	32x34x34" $b < 1$ with plexiglas	10:4
		Temp ~ 24°C overnight. Temp ~ 20.8°C at 11:30	
	38	32x34x34 + 1/2" on south half. $b < 1$	12:2
		$T_{LN} = -176.7 \text{ sec}$	
2:15	39	32x34x34 1/2" 1/2" on north half $b < 1$	1:1
		Temp = 22.5°C $T_{LN} = -488.6$	
	40	32x34x35" $b > 1$	2:5
		$T_{LN} = 124.2$	
	40A	32x34x34 3/4" + Plexiglas (1" x 19 5/8" x 24") $b = 1$ at 4.1 rev.	3:1
	40B	Same as 40A + 6" x 16" x 36" of polyethylene ~ 14" from side of stack $b = 1$ at 4.3 rev.	3:5
	40C	Same as 40A + 6" x 16" x 36" of poly against side of stack $b = 1$ at 6.5 rev.	4:4

Instrument Check on 50267 Source 10mCi

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	Meter Trip	OK	Fast Trip	OK
IC-2	Meter Trip	OK	Red light	OK
IC-3	<u>Response</u> Calibration	<u>J.R.</u> OK	<u>Redy alarm</u>	OK
IC-4	<u>Response</u> Calibration	<u>J.R.</u> OK	<u>Previdif 0.09"</u>	
CRM	Meter Trip			

Time Exp

10:45 41 32x34x34¹/₂" high; T_{LN} = -1695 sec; Temp = 22.3°C
b < 1

12:20 42 32x34x34¹/₄" high; T_{LN} = -243.9
b < 1

1:10 43 32x34x34³/₄" high; T_{LN} = 224.7
b > 1

2:50 44 32x34x34¹/₄" high; T_{LN} = -241.5
b < 1

2:35 45 32x34x34³/₄" high; T_{LN} = 223.7
b > 1

3:10 46 32x34x34¹/₄" high; T_{LN} = -241.0
b < 1

3:55 47 32x34x34³/₄" high; T_{LN} = 218.2
b > 1

4:35 Temp = 22.1°C

278

U(2) Fy-6

Instrument Check on 6 OCT 67 Source 10mct

PM-1	Low Trip	OK	Alarm Trip	OK
PM-2			Alarm Trip	
IC-1	Meter Trip	OK	Fast Trip	OK
IC-2	Meter Trip	OK		
IC-3	Calibration	S/A OK	Red light	OK
IC-4	Calibration	S/A OK	Bldy Alarm	OK
CRM	Meter Trip		Press. Dif.	0.09"

Time Exp.

Temp = 22.3°C

8:25

48

32 x 34 x 34 ³/₄"T_{LN} = 185.7

11:10 AM

b > 1

49

32 x 34 x 34 ¹/₄"T_{LN} = -273.0

b < 1

50

32 x 34 x 34 ³/₄"T_{LN} = 185.0

b > 1

51

32 x 34 x 34 ¹/₄"T_{LN} = -272.1

b < 1

11:20

52

32 x 34 x 34 ³/₄"Temp = 21.9°C
T_{LN} = 188.9

b > 1

53

32 x 34 x 34 ¹/₄"T_{LN} = -275.8

b < 1

54

32 x 34 x 34 ³/₄"T_{LN} = 185.9

b > 1

55

32 x 34 x 34 ¹/₄"T_{LN} = -272.7

b < 1

56

32 x 34 x 34 ³/₄"T_{LN} = 185.7

b > 1

9 Meas. Dimension = 81.45 x 86.70 x 88.32 cm.

Nominal Dimension = 32 x 34 x 34 ³/₄" high

Instrument Check on 11 DT67 Source 10mct

PM-1	Low Trip	OK 1/2"	Alarm Trip	OK Contact
PM-2			Alarm Trip	
IC-1	Meter Trip	OK 1"	Fast Trip	OK 1/2"
IC-2	Meter Trip	OK 1"	Red light	OK
IC-3	Responds	Calibration S/R. OK	Red light	OK
IC-4	Responds	Calibration S/R. OK	Chy alarm	OK
GRM	Meter Trip		Press Def.	0.09"

Temp = 21.9°C

11:10 AM 57

32 x 34 x 34 1/4" stack with support mock-up on top.
 Mock-up consists of 1/2" x 24" x 48" al + 5 layers 3" al
 bolts and 1" x 24" x 48" iron on each side.

b < 1

58 Removed support mock-up. 32 x 34 x 34 1/4"

b < 1

59 32 x 34 x 34 1/2" with support mock-up on top.

b > 1

60 32 x 34 x 34 1/2" Removed support mock-up.

b > 1

Temp = 22.1°C

280 U(2) F4-6

CRM	Meter Trip	OK 1"
IC-1	Meter Trip	OK 1"
IC-2	Meter Trip	OK 1"
IC-3	Meter Trip	OK 1"
IC-4	Calibration	OK 1"
PM-1	Low Trip	OK 1/2"
PM-2	Alarm Trip	OK 1/2"

Instrument Check on 12.01.67 Source 10mct
Temp = 21.9°C

Exp
61

32 x 34 x 34 1/2" Stack

11:11 AM

Have positioned 1" x 12" x 26" plexiglas shim on rod shims against bottom of fourth face to use for fins coated during foil irradiation.

15 foils 2% U in paraffin across center of stack.

Using extra plexiglas shim on side to get up to power.

11:15

Start timing at 2 on IC-3

k ≈ 1 at 5.5 on IC-3 Shim out = 6"

11:25

shut down

Exp #62

Foil Exposure same as #61 (with Diff foils)

12:55

10 Min Exposure Start timing at 2 on IC-3

k ≈ 1 At 5.5 to 6 on IC-3

63

Same as #61

2:43

Start timing at 2 on IC-3

k ≈ 1 at 4.5 on IC-3

2:53

shut down.

Foil Position	Epp. 61		Epp. 62		Epp. 63	
-14"	D-31	0.33290	D-9	0.34374	E-3	0.33402
-12	D-35	0.51032	D-7	0.51270	E-5	0.50706
-10	D-33	0.63825	D-17	0.64449	E-7	0.62899
-8	D-21	0.77143	D-3	0.79114	E-9	0.77210
-6	D-38	0.84876	D-20	0.87732	E-11	0.85628
-4	D-37	0.91076	D-14	0.93052	E-13	0.90704
-2	D-29	0.97651	D-24	0.99830	E-15	0.97449
0	D-36	1.00000	D-11	1.00000	E-1	1.00000
+2	D-32	0.98326	D-22	0.99081	E-14	0.98655
4	D-26	0.93508	D-25	0.94098	E-12	0.92846
6	D-30	0.86935	D-34	0.86616	E-10	0.85230
8	D-13	0.75868	D-40	0.75958	E-8	0.74494
10	D-23	0.62961	D-39	0.63728	E-6	0.62426
12	D-16	0.50546	D-6	0.50288	E-4	0.49538
14	D-28	0.33811	D-12	0.34751	E-2	0.33028

Traverse across center of stack in nominal 34" diameter
 Meas. width = 86.65 cm

282

U(2) Fy - 6

Instrument Check on 13 Oct 67 Source 10mcY

PM-1	Low Trip	OK $\frac{1}{2}$ "	Alarm Trip	OK Contact
PM-2			Alarm Trip	
IC-1	Meter Trip	OK 1"	Fast Trip	OK $\frac{1}{2}$ "
IC-2	Meter Trip	OK 1"		Red light OK
IC-3	Responds	Calibration OK 1/4 R		Blk. Alarm OK
IC-4	Responds	Calibration OK 1/4 R		Pres. Dif. .09"
CRM	Meter Trip			

EPR

Temp 21.5°C

9:20 64 32 x 34 x 34 $\frac{1}{2}$ less $\frac{1}{4}$ x 4 x 34 on N side of top.

15 foils of U(2) Fy in Paraffin.

9:39 Start timing at 2 on IC-3

K = 1 at 5 on IC-3

9:49 Shut down

EXPR

65 32 x 34 x 34 $\frac{1}{2}$ less $\frac{1}{4}$ x 4 x 34 on N side of top

12³⁰ 15 foils of U(2) Fy in Paraffin

start timing at 2 on IC-3

K = 1 At 5 on IC-3

1:04 Shut down

V(2)F₄ in Paraffin foils

V(2)F₄-6 283

Foil Position

Expn 64

Expn 65

Expn 66

-14"	C-3	0.34628	C-22	0.34078	B-15	0.33848
-12	C-5	0.51462	C-24	0.52162	B-3	0.51607
-10	C-7	0.64010	C-28	0.64075	B-20	0.64124
-8	C-17	0.79004	C-30	0.77536	B-27	0.78039
-6	C-11	0.86119	C-32	0.87144	B-26	0.85764
-4	C-13	0.91746	C-35	0.91995	B-5	0.92534
-2	C-15	0.99462	C-38	0.99971	B-21	0.99325
0	C-1	1.00000	C-19	1.00000	B-12	1.00000
+2	C-14	0.99702	C-37	1.00171	B-28	0.98666
4	C-12	0.96027	C-34	0.95450	B-17	0.93936
6	C-10	0.84836	C-31	0.85756	B-42	0.85596
8	C-8	0.74512	C-29	0.74785	B-34	0.75436
10	C-16	0.63740	C-25	0.63986	B-40	0.64232
12	C-4	0.51255	C-23	0.50963	B-8	0.51455
14	C-2	0.34207	C-20	0.33712	B-11	0.33979

284

V(2) F₄-6

Instrument Check on 17 Oct 67 Source 10 mCi

PM-1	Low Trip	OK 1/2"	Alarm Trip	OK Contact
PM-2			Alarm Trip	
IC-1	Meter Trip	OK 1"	Fast Trip	OK 1/2"
IC-2	Meter Trip	OK 1"	Red light	OK
IC-3	Response Calibration	OK S.P.A.	Chk alarm	OK
IC-4	Response Calibration	OK "	Press Dif	0.09"
CRM	Meter Trip			

Temp 22.5°C

66 32x34x34 1/2 less 1/4 x 4 x 34 on N side of top.

15. foils of V(2) F₄ in Paraffin

Start turning at 2 on IC-3

1:51 4.7 at 4.7 on IC-3

2:01 Shut down.

U(2) Fy-6 285

Instrument Check on 18 Oct 67 Source 10mcK

PM-1	Low Trip	OK 1/2"	Alarm Trip	OK Contact
PM-2			Alarm Trip	
IC-1	Meter Trip	OK 1"	Fast Trip	OK 1/2"
IC-2	Meter Trip	OK 1"	Red light	OK
IC-3	<u>Response</u>	Calibration	OK 1/2"	Blky Alarm OK
IC-4	<u>Response</u>	Calibration	OK 1/2"	Pres Dif 0.1"
CRM	Meter Trip			

Temp 22.2°C

67

Stack ~~same as~~ 32x34x34 1/2" + 1/4 x 16 x 34 on center of top. ~~64-66~~

15 Cd covered 2mil gold foils

9:46

Start timing

b = 1 at 25 on IC-3

10:06

Shut down.

286

Cd covered 2 mil gold

U(2) Fy-6

Foil Position

Expt 67

Expt 69

Expt 70

-14"	H-14	0.34122	G-15	0.34278	J-14	0.34268
-12"	H-4	0.50030	G-24	0.50048	J-12	0.50436
-10"	H-11	0.63973	G-10	0.64284	J-10	0.63760
-8"	H-18	0.76254	G-5	0.75139	J-8	0.76260
-6"	H-9	0.86093	G-18	0.85946	J-6	0.86038
-4"	H-13	0.94000	G-6	0.93106	J-4	0.93720
-2"	H-23	0.99947	G-22	0.98826	J-2	0.99801
0	H-6	1.00000	G-20	1.00000	J-1	1.00000
+2	H-12	0.99122	G-7	0.98515	J-3	0.98357
4	H-3	0.94555	G-23	0.93198	J-5	0.94818
6	H-25	0.85794	G-11	0.86934	J-7	0.87276
8	H-7	0.76584	G-9	0.76402	J-9	0.76798
10	H-24	0.64880	G-17	0.64986	J-11	0.66171
12	H-15	0.50561	G-28	0.50950	J-13	0.50257
14	H-22	0.34546	G-1	0.34599	J-15	0.34064

Expt 72

-14"	C-3	0.33756	+6	C-10	0.85793
-12"	C-5	0.49423	+8	C-8	0.76859
-10"	C-7	0.63116	+10	C-6	0.64420
-8"	C-9	0.75390	+12	C-4	0.50476
-6"	C-11	0.85848	+14	C-2	0.34595
-4"	C-13	0.92752			
-2"	C-15	0.98021			
0.0	C-1	1.00000			
+2"	C-14	0.97749			
+4"	C-12	0.94874			

Instrument Check on 19 Oct 67 Source: ~~replac~~ m/cap

68 ~~PM-1~~ ~~Alarm Trip OK 1/2~~ ~~Alarm Trip OK~~ ~~Control~~
 36 ~~PM-2~~ ~~Alarm Trip~~ ~~Alarm Trip~~ ~~S-21~~
 60 ~~IC-1~~ ~~Meter Trip OK 1"~~ ~~Post Trip OK 1/2~~
 60 ~~IC-2~~ ~~Meter Trip OK 1"~~ ~~Red light OK~~
 60 ~~IC-3~~ ~~Responds~~ ~~Calibration OK S/R~~ ~~Bldg Alarm OK~~
 38 ~~IC-4~~ ~~Responds~~ ~~Calibration OK S/R~~ ~~Press Diff 0.1"~~
 CRM ~~Meter Trip~~

Temp 22.0°C

01 68 Stack 32x34x34 1/2
 000 2 cd. covered and 2 bare In (93) - al foil
 357 206 Start timing at 4 on IC-3
 718 b = 1 at 9.5 on IC-3
 76 9¹⁶ Shut down

98 69 Stack same as Expt 67
 171 15 cd covered 2 mil gold foil
 257 11:36 Start timing at 18 on IC-3
 064 b = 1 at 43 on IC-3
 12⁰⁶ Shut down

Expt 68 data	1	2	3	4
In Foil	11 cd	12	13 cd	22
		$\frac{2}{11} = 2.72570$		$\frac{4}{11} = 2.74998$
		$\frac{2}{13} = 2.77960$		$\frac{4}{13} = 2.72080$
	Avg Cd. Ratio = 2.74402			

288

U(2) Fy-6

Instrument Check on 20 Oct 67 Source 3440 mick

PM-1	Low Trip	OK $\frac{1}{2}$ "	Alarm Trip	OK	Control
PM-2	High Trip		Alarm Trip		S-M
IC-1	Meter Trip	OK $\frac{1}{2}$ "	"fast" Trip	OK $\frac{1}{2}$ "	
IC-2	Meter Trip	OK $\frac{1}{2}$ "	Redlight	OK	
IC-3	Response	Calibration	S/A. not needed	Bldg Alarm	OK
IC-4	Response	Calibration	S/A. not needed	Pres Diff	0.7"
CRM	Meter Trip				

Apr 70 Stock same as Apr 67

15' Cd covered 2 mil gold foil

1³⁴ PM.

Start timing at 16 on IC-3

b ≈ 1 at 43 on IC-3

2⁰⁴

Shut down

10

10⁵

2⁰⁰

2³⁰

Instrument Check on 23 Oct 67 source 140 mK

PM-1	Low Trip	OK 1/2"	Alarm Trip	OK Contact
PM-2			Alarm Trip	OK
IC-1	Meter Trip	OK 1"	Fast Trip	OK 1/2"
IC-2	Meter Trip	OK 1"		
IC-3	Responds	Calibration 140 OK	Red-light	OK
IC-4	Responds	Calibration 140 OK	Red-light	OK
CRM	Meter Trip		Press Diff	0.1"

Temp 21.7°C

Exp 71 Stack 32 x 34 x 34 1/2

2 ed. covered & 2 bars In(10) - all foil.

10⁴⁵ AM

Start timing at 4 on IC-3

b slightly greater than 1

Max power = 14 on IC-3

10⁵⁴ AM

Shut down

Pos	1	2	3	4
In Foil	J-1 ed	J-2	J-4 ed	J-10
		2/1 = 2.84449		4/1 = 2.70336
		2/3 = 2.84431		4/3 = 2.72914

Avg Ed Ratio = 2.78032

Exp 72 Stack 32 x 34 x 34 1/2 + 1/4 x 12 x 34 across middle of top

15 ed covered 2 mil gold foil

2:02 PM

Start timing at 18 on IC-3

b = 1 at 42 on IC-3

2³² PM

Shut down

290

U(2) F₄-6

Instrument Check on 25 Oct 67 Source - 10 mCr

PM-1	Low Trip	OK $\frac{1}{2}$ "	Alarm Trip	OK Contact
PM-2			Alarm Trip	
IC-1	Meter Trip	OK $\frac{1}{2}$ "	Fast Trip	OK $\frac{1}{2}$ "
IC-2	Meter Trip	OK $\frac{1}{2}$ "	Red light	OK
IC-3 Responds	Calibration	OK S.P.R.	Bld. alarm	OK
IC-4 Responds	Calibration	OK S.P.R.	Pres. def. set	
CRM	Meter Trip			

Temp = 21.9°C

73 Stack 32 x 34 x 34 $\frac{1}{2}$ " less $\frac{1}{4}$ " x 4 x 34 from Neide of top.
2 Cd covered and 2 bare U(92) metal foils

9¹² AM Starts timing at 4 on IC-3

b ≈ 1 at 10 on IC-3

9¹⁷ AM Shut down

~~73~~ Foils too hot when counted. Data does not look good.

74 Stack same as Expt 73

15 Bare 2 mil gold foils

2³⁰ PM Start timing at

b slightly greater than 1, could not level. Max count =

2⁴⁵ PM Shut down

34 on IC-3

Instrument Check on 26 Oct 67 Source: 102 Cr

PM-1	Low Trip OK $\frac{1}{2}$ "	Alarm Trip OK	Contact
PM-2		Alarm Trip	S-M
IC-1	Meter Trip OK $\frac{1}{2}$ "	Fast Trip OK $\frac{1}{2}$ "	
IC-2	Meter Trip OK 1"	Red light - OK	
IC-3	Responds Calibration OK $\frac{1}{2}$ "	Red Alarm OK	
IC-4	Responds Calibration OK $\frac{1}{2}$ "	Press Def 0-0.1"	
CRM	Meter Trip		0.25

75 Stack 32 x 34 x 34 $\frac{1}{4}$ + 16 x 34 x $\frac{1}{4}$ on center of top.

2 Cd covered and 2 bare V(92) metal foils, 4 mil

944

Start timing at 3.6 on IC-3

b = 1 at 10 on IC-3

944

Shut down

4 mil, V(92) metal Cd Rater

Pos.	1	2	3	4
	V-14 Cd	V-10	V-9 Cd	V-6
		$\frac{2}{1} = 22.18264$		$\frac{4}{1} = \frac{22.23054}{\cancel{22.18264}}$
		$\frac{2}{3} = 22.61069$		$\frac{4}{3} = 22.25696$

Avy Cd Ratio = 22.32021

Instrument Check on 31 Oct 75 Source 10mCk

PM-1 850V Low Trip OK Alarm Trip Did not trip Reported A. D. Rohr
 PM-2 850V Low Trip OK Alarm Trip Did not trip
 IC-1 850V Meter Trip OK 1/2" Fast Trip OK Control
 IC-2 850V Meter Trip OK 1" Red light OK
 IC-3 Responds Calibration OK 1/P Bldg alarm OK
 IC-4 Responds Calibration OK 1/P Press Diff 0.1"
 CRB Meter Trip OK

Temp = 21.9°C

77 Stack same as Expt 75

2 ed covered and 2 bare V(92) metal foils

8⁴⁹/_{AM}

Start timing at 7.5 on IC-3

b = 1 at 2 on IC-3

8⁵⁴/_{AM}

Shut down

4 mil, V(92) metal Cd Ratio

Position	1	2	3	4
	V-1 ed	V-3	V-10 ed	V-11
		$2/1 = 22.31804$		$4/1 = 21.98214$
		$2/3 = 22.20046$		$4/3 = 22.09669$

avg Cd Ratio = 22.14933

78 Stack same as Expt 75

15 bare 2 mil gold foils

1²⁹/_{PM}

Start timing at 3.6 on IC-3

b slightly > 1

Max count 29 on IC-3 ; avg P ≈ 20

1⁴⁷/_{PM}

Shut down

294 U(2)F4-6

Instrument Check on 19 Nov. 67 Source 10 mCr

PM-1	Low Trip	OK	Alarm Trip	Would not trip at 850V
PM-2			Alarm Trip	1-31
IC-1	Meter Trip	OK 1"	Fast Trip	OK 1/2"
IC-2	Meter Trip	OK 1"	Redlight	OK
IC-3	Responds	Calibration OK JT	Bldg alarm	OK
IC-4	Responds	Calibration OK JT	Press. Dif.	OK
CRM	Meter Trip			

Temp 22.3°C

79 Stack 32x34x34 1/4 + 1/4 x 8 x 34" in center.
 10²⁸ AM Stack 15 bare gold foils 2 mil.
 Start timing at 3.60 on IC-3
 b = 1 at 10 on IC-3
 10⁵⁸ AM Shut down

80 Stack same as Expt 79
 2 ed covered and 2 bare 10% U(93)-al foils 5 mil thick
 3⁰⁴ PM Start timing at 5.5 on IC-3
 b ≈ 1 at 12 on IC-3 (slightly neg)
 3¹⁹ PM Shut down

5 mil, 10% U(93)-al alloy Cd Ratio

Pos	1	2	3	4
	P-1 Cd	P-2	P-3 Cd	P-4
		2/1 = 31.16023		4/1 = 30.40286
		2/3 = 30.31876		4/3 = 29.73827

avg Cd Ratio = 30.40286

Instrument Check on 29 Nov. 67 Source 10 mCK

925V
7850V

PM-1 Low Trip OK Alarm Trip Source 19m
 PM-2 Alarm Trip
 IC-1 Meter Trip OK "1" Fast Trip OK 1/2"
 IC-2 Meter Trip OK "1" Red light OK
 IC-3 Responds Calibration OK JT Old alarm OK
 IC-4 Responds Calibration OK JT Pres Dif. 0.1"
 CRM Meter Trip

81 Stack same as Expt 79

2 cd covered and 2 bare 10% V(93)-al foil, 5 mil thick.

12⁵⁴ PM Start timing at 5.5 on IC-3

t=1 at 13 on IC-3

1⁰⁹ PM Shut down

5 mil, 10% V(93)-al alloy Cd Ratio

Position	1	2	3	4
	P-5 cd	P-6	P-7 cd	P-8
		$2/1 = 31.81092$		$4/1 = 30.53266$
		$2/3 = 31.23470$		$4/3 = 30.43942$

Avg Cd Ratio = 31.00442

10286
73827

296

U(2)F₄-6

Bare Gold

2 mil thick

Foil Pos:	Expn 74		Expn 78		Expn 79		
-14"	D-23	0.34504	D-2	0.34466	B-16	0.34322	A
-12"	D-28	0.51431	D-20	0.51388	B-4	0.51208	A
-10"	D-7	0.64100	D-25	0.64920	B-7	0.64592	A
-8"	D-9	0.77206	D-29	0.77542	B-8	0.77551	A
-6"	D-22	0.86228	D-4	0.86060	B-11	0.86136	A
-4"	D-26	0.92694	D-12	0.92877	B-9	0.92556	A
-2"	D-30	0.99502	D-16	0.99203	B-3	0.99248	A
0	D-11	1.00000	D-3	1.00000	B-1	1.00000	A
+2	D-17	0.98120	D-32	0.98578	B-15	0.98158	A
4	D-31	0.94370	D-25	0.93650	B-6	0.94466	A
6	D-8	0.85279	D-33	0.84948	B-10	0.85295	A
8	D-19	0.74686	D-15	0.74782	B-5	0.74822	A
10	D-14	0.64016	D-5	0.63892	B-13	0.63598	A
12	D-18	0.50514	D-13	0.50566	B-14	0.50406	A
14	D-6	0.34322	D-27	0.33788	B-12	0.34222	A

Exp 73

Exp 86

Exp 89

297

322	A-19	0.34130	F-8	0.34030	E-21	0.34862
208	A-7	0.50846	F-10	0.50979	E-8	0.51518
592	A-17	0.63924	F-12	0.63906	E-14	0.64712
51	A-13	0.76400	F-14	0.76728	E-2	0.77760
136	A-11	0.85593	F-16	0.85686	E-11	0.86099
556	A-5	0.91840	F-18	0.92477	E-4	0.92762
48	A-3	0.98546	F-20	0.99005	E-3	0.99733
000	A-1	1.00000	F-21	1.00000	E-12	1.00000
158	A-16	0.97896	F-19	0.98432	E-15	0.98662
66	A-4	0.94205	F-17	0.94798	E-22	0.94383
295	A-6	0.84826	F-15	0.85374	E-24	0.84762
22	A-8	0.75180	F-13	0.75030	E-23	0.75300
98	A-10	0.63870	F-11	0.63870	E-7	0.64000
106	A-12	0.50466	F-9	0.50672	E-13	0.50921
222	A-14	0.34300	F-7	0.34106	E-18	0.33969

See p. 187 for continuation
of U(2) F₄ L₆ experiments.

Date	Sample No	Paraffin Description	Req No.	Analysis Results
5-17-66	1	Original, Used in Green Blocks	593131	
"	2	Stores Stock	593132	
"	3	Fisher Lab in Storage cet #03-723-5010	593133	
"	4	Esso in storage	593134	
6-2-66	2A	Stores Stock		