

BOOK96R

Notes:

"UO₂F₂ Solution #6" on spine

Blank pages: inside front cover, page opposite page 1, 27, 119-308, inside back cover sheets

-1 half sheet between blank and page 1

-pages 25/26 have paperclip at top

-pages 38/39 have calendar sheet (11/1/72) between pages

Scanned by:

Sheila Finch

RSICC /Oak Ridge National Lab.

September 9, 1999

14-2-1



PIONEERS SINCE 1831

Account Book

No. S 149

NO UNITS

Journal

Ledger, Single Entry . .

Ledger, Double Entry .

Record Ruled (27 Lines)

Made in 150, and 300 Pages

MADE IN U. S. A.

TO REORDER, SPECIFY NUMBER,
RULING AND THICKNESS INDICATED
ON BACKBONE OF THIS BOOK.

Plastic Cross in size

Nom. 11.250 in. ID p. 80

Nom. 11.0 in. ID p. 78

Nom. 10.750 in. ID p. 58

" 10.50 in. ID p. 41

" " " p. 25

Ø1 tank: 37.75 ID x 35.75 lin p. 2

[Spec. 119 of Log #5 for vessel diagram]

Int. rgt. p. 7, p. 15

" w/ rgt p. 20? (spec. 22)

Log #6 U(5) O₂ F₂ Salin

37.750" I.D. x 35.750" ht.

at Tanks.

See p 119 Log book # 5. for diagram of vessel.

Solution zero = 12.7 cm

H₂O zero = 0.0 cm: outside bottom of tanks.

Solutions

1/2" feed rate = .9 cm/min

1/2" drain rate = 1.5 cm/min

3" dump rate = 35.0 cm/min

H₂O

1.5" feed rate = 9.8 cm/min

3" dump = 10.5 cm/min

3" drain = 10.7 cm/min

added ~ 170 l of 774 g/l: Drain the 796 g/l from manifold.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter <input checked="" type="checkbox"/>	3"	<input checked="" type="checkbox"/>	3×10^{-12}
	"	Fast <input checked="" type="checkbox"/>	1"	<input checked="" type="checkbox"/>	"
K-2	"	Meter <input checked="" type="checkbox"/>	3"	<input checked="" type="checkbox"/>	"
	"	Fast <input checked="" type="checkbox"/>	1"	<input checked="" type="checkbox"/>	"
R-1					
R-2					
PM-1	700V	Alarm <input checked="" type="checkbox"/>	15"	<input checked="" type="checkbox"/>	500V
PM-2	1200V	Low <input checked="" type="checkbox"/>	14"	<input checked="" type="checkbox"/>	900V
	"	Alarm <input checked="" type="checkbox"/>	2"	<input checked="" type="checkbox"/>	"

LOG N CALIBRATE OPERATE SOURCE No. B-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by I.D.C. Personnel check by I.D.C.

Instruments and safeties checked and reset by A.X.H.

Source in checked by A.X.H. Source No. M-93

Emergency equipment in control room checked by I.D.C.

Instruments in trip circuit: K-1-2 PM-1-2

Red light on by A.X.H. Time 0930

Start-up OK'd by I.D.C. A.X.H. Date 9-16-70

4

37.750" al Tent.

111.2 Solution ht = 39.60 cm Water ht = 89.70 cm
 System sub critical
 Crain: (all solution in manifold).

added ~ 25 l of very dilute solution (Working
 from K-25 30%.)

INSTRUMENT CHECK

INSTRUMENT	RANGE	TAP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter ✓	3"	✓	3×10^{-12}
"	"	" ✓	1"	✓	"
K-2	"	Meter ✓	3"	✓	"
"	"	Foot ✓	1"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	.5"	✓	500V
PM-2	1200V	Low ✓	14"	✓	900V
"	"	Alarm ✓	2"	✓	"
LOG IN CALIBRATE		✓	OPERATE		✓
JUMP WELL FROGE LIGHT		✓	SOURCE No.		D-80

START-UP CHECK LIST

Equipment checked by F.I.C. Personnel check by F.I.C.Instruments and safeties checked and reset by AKMSource in checked by AKM Source No. M-43Emergency equipment in control room checked by F.I.C.Instruments in trip circuit: K-1-2 P.M-1-2Red light on by AKM Time 0830Start-up OK'd by F.I.C., AKM Date 9-17-70

Solution ht = 36.65^{65} cm Water ht = 89.70 cm
 + Per $H_2O \text{ Temp} = 25.5^\circ$

$$G = 128.21 \text{ new} = 8.1 \text{ f} =$$

1034 Solution ht = 36.65 cm Water ht = 89.70 cm
 System just critical
 Drain

1400 Added ~ 25 l of very dilute solution.
 (Washing from storage bottles.)

9-24-70 added ~ 25 l of H_2O :

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE RANGE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter ✓	2"	✓	3×10^{-12}
"	"	Fast ✓	.5"	✓	"
K-2	"	Meter ✓	2"	✓	"
"	"	Fast ✓	.5"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	.5"	✓	500V
PM-2	1200V	Low ✓	14"	✓	900V
"	"	Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. B-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by F.P.C. AKM Personnel check by F.P.C.

Instruments and safeties checked and reset by AKM

Source in checked by AKM Source No. M-43

Emergency equipment in control room checked by F.P.C.

Instruments in trip circuit: K-1-2 PM-1-2

Red light on by AKM Time 0800

Start-up OK'd by F.P.C. R.K.R. Date 9-25-70

Solution Temp^o = 25.0^o. Removed
thermocouples # 3 & 4 from vessel.

$\Delta h = .10 \text{ cm}$

Solution ht = 41.10 cm Water ht = 89.90 cm
+ Per H₂O Temp = 25.5^o

$C = 106.4 \text{ sec} = 9.4 \text{ d}$

1020 Solution ht = ± 41.00 cm Water ht = 89.90 cm
System just critical

$\Delta h = .05$

Solution ht = 41.30 cm Water ht = 29.90 cm
+ Per

$C = 182.53 \text{ sec} = 6.0 \text{ d}$

1110 Solution ht = ± 41.25 cm Water ht = 29.90 cm
System just critical
Drain.

$\Delta h = .10 \text{ cm}$

Solution ht = 41.30 cm Water ht = 49.60 cm
+ Per H₂O Temp = 25.5^o

$C = 104.30 \text{ sec} = 9.6 \text{ d}$

1132 Solution ht = ± 41.20 cm Water ht = 49.60 cm
System just critical
Drain H₂O.

1140 Solution ht = 41.20 cm No H₂O: Reflector
System sub-critical
Drain.

over:

Installed thermocouple #3 & 4:

Solution Temp = 25.0°C

Drain solution:

Solution sample taken:

#2 - 37.75 g/L

Y-12 Reg II

684607

C = 170.0 g/L = 344361

T = 20.2 sp.gr = 1.6467

N = 149.8 Temp = 25°C
= 567.1

avg = 568.7

X-10 Reg II

A-5481

C = 170.6 g/L = 3449

T = 20.4 Density = 1.6491
= 1.6536

N = 150.2 sp.gr = 1.6536
= 570.39 g/L Temp °C = 20.0°C

1600 added ~ 125 L H₂O:

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3-X10 ⁻¹²	Meter ✓	2"		
"	"	Fast ✓	5"		
K-2	"	Meter ✓	2"		
"	"	Fast ✓	5"		
R-1					
R-2					
PM	7005	Alarm ✓	5"		
PM	12005	Low ✓	14"		
"	"	Alarm ✓	2"		

LOG IN CALIBRATE OPERATE SOURCE No. B-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by FIDC Personnel check by FIDC
 Instruments and safeties checked and reset by BKKL
 Source in checked by BKKL Source No. 14-43
 Emergency equipment in control room checked by FIDC
 Instruments in trip circuit: K-1-2 P09-1-2
 Red light on by BKKL Time 0930
 Start-up OK'd by FIDC, BKKL Date 9-29-70

Solution Temp ° = 24.0° C Removed thermocouples #3 & 4 from well.

91
26
36
0

$$\begin{aligned} \text{c/l} &= 46.60 \text{ cm} \\ &= 18.35'' \end{aligned}$$

1230 Solution ht = 59.30 cm Water ht = 89.80 cm
 system not critical $\text{H}_2\text{O Temp}^\circ = 24.2^\circ$
 Drain H_2O . Installed thermocouples #3 & 4.
 1245 Solution Temp $^\circ = 25.0^\circ$

Solution sample taken
 #3

Y-12 Reg II

684610

$$G = 156.2 \text{ g } \rho/g = 1.271030$$

$$T = 19.9 \text{ g } \text{density} = 1.4489$$

$$\begin{aligned} W &= 136.3 \text{ g } \text{Temp} = 25^\circ \\ &= 392.79 \text{ g/l} \end{aligned}$$

X-10 Reg II

A-5482

$$G = 175.4 \text{ g } \rho/g = 1.2707$$

$$T = 20.0 \text{ g } \text{density} = 1.4499$$

$$\begin{aligned} N &= 155.4 \text{ g } \rho/g = 1.4528 \\ &= 393.3 \text{ g/l} \end{aligned}$$

$$\text{avg} = 393.09 \text{ g/l} \checkmark$$

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter ✓	2"	✓	3×10^{-12}
"	"	Fast ✓	5"	✓	"
K-2	"	Meter ✓	2"	✓	"
"	"	Fast ✓	5"	✓	"
R-1					
R-2					
PH	700V	Alarm ✓	5"	✓	500V
PH	1400V	Low ✓	19"	✓	900V
"	"	Alarm ✓	1"	✓	"
LOG-N CALIBRATE		✓	OPERATE	✓	SOURCE No. <u>B-80</u>
DUMP WELL PROBE LIGHT		✓			

START-UP CHECK LIST

Equipment checked by F.I.D.C. Personnel check by F.I.D.C.
 Instruments and safeties checked and reset by AKIV
 Source in checked by AKIV Source No. M-93
 Emergency equipment in control room checked by F.I.D.C.
 Instruments in trip circuit: K-1-2 PH-1-2
 Red light on by AKIV Time 12:00
 Start-up OK'd by F.I.D.C. AKIV Date 10-15-70

Checks of last run: p-10

1.515 Solution ht = 59.40 cm Water ht = 89.80 cm
 System sub critical
 Drain:

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3 X 10 ⁻¹²				
	"				
K-2	"				
	"				
R-1					
R-2					
PM-1	700 V				
PM-2					

Alarm

LOG N CALIBRATE OPERATE SOURCE No.

DUMP WELL FREE LIGHT

START-UP CHECK LIST

Equipment checked by ZID.C Personnel check by ZID.C

Instruments and safeties checked and reset by A.K.M.

Source in checked by A.K.M. Source No. M-93

Emergency equipment in control room checked by ZID.C

Instruments in trip circuit: K-1-2 P-1-2

Red light on by A.K.M. Time 0945

Start-up OK'd by ZID.C A.K.M. Date 10-16-70

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter ✓	2"	✓	3×10^{-12}
"	"	Fast ✓	5"	✓	"
K-2	"	Meter ✓	2"	✓	"
"	"	Fast ✓	5"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	5'	✓	500V
PM-2	1300V	Low ✓	14"	✓	900V
"	"	Alarm ✓	2"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. B-8C

DUMP WELL PROBE LIGHT

added ~ 100 l H₂O:

$$q/k = 60.50 \text{ cm} = 23.82''$$

1510

Solution ht = 73.20 cm

Water ht = 89.80 cm

System sub critical
Chain

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3 x 10 ⁻¹²	Meter ✓	2"	✓	3 x 10 ⁻¹²
"	"	Fast ✓	5.5"	✓	"
K-2	"	Meter ✓	2.9"	✓	"
"	"	Fast ✓	1.5"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	1.5"	✓	600V
PM-2	1200V	Low ✓	1.4"	✓	900V
"	"	Alarm ✓	1"	✓	"
LOG N CALIBRATE		✓	OPERATE		✓
DUMP WELL PROSE LIGHT		✓	SOURCE No. B-80		

START-UP CHECK LIST

Equipment checked by ^{F.P.C.} ~~A.H.H.~~ Personnel check by ~~F.P.C.~~ ~~A.H.H.~~

Instruments and safeties checked and reset by ~~A.H.H.~~

Source in checked by ~~A.H.H.~~ Source No. 100-93

Emergency equipment in control room checked by ~~F.P.C.~~

Instruments in trip circuit: R-1-2 A-1-2

Red light on by ~~A.H.H.~~ Time 0930

Start-up OK'd by ~~F.P.C.~~ ~~A.H.H.~~ Date 10-19-70

added ~ 125 L H₂O and ~ 55 L of ~
9.10 g/l to manifold.

1537 Stopped niping:

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter ✓	2"	✓	3×10^{-12}
"	"	Fast ✓	1.5"	✓	"
K-2	"	Meter ✓	2"	✓	"
"	"	Fast ✓	1.5"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	15"	✓	500V
PM-2	1200V	Low ✓	14"	✓	900V
"	"	Alarm ✓	1"	✓	"
LOG N CALIBRATE		✓	OPERATE	✓	SOURCE No. B-80
DUMP WELL PROCSE LIGHT		✓			

095

START-UP CHECK LIST

Equipment checked by ^{F.D.C.} AKK Personnel check by F.D.C.

Instruments and safeties checked and reset by AKK

Source in checked by AKK Source No. M-23

Emergency equipment in control room checked by F.D.C.

Instruments in trip circuit: K-1-2 PM-1-2

Red light on by AKK Time 0800

Start-up OK'd by F.D.C. AKK Date 10-20-70

Solution Temp^o = 23.8^o. Removed
thermoouples # 3 & 4 from vessel.

0935 Solution level = 56.70 cm found solution
leak in manifold # 2. Drain:

An estimate of amount of solution that leaked
is ~ 20 cc, of which ~~at~~ over 90% was
contained in drip pans. Leak was found to
be in a swagelok tubing fitting connecting the
manometer tube to # 2 manifold. The
fitting was checked and re-tightened and # 2
manifold put back in service.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE RANGE	SET	START-UP RANGE
K-1	3x10 ⁻¹²	Meter ✓	2"	✓	3x10 ⁻¹²
"	"	Fest ✓	1"	✓	"
K-2	"	Meter ✓	2"	✓	"
"	"	Fest ✓	1"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	.5"	✓	500V
PM-2	1200V	Low ✓	14"	✓	900V
"	"	Alarm ✓	1"	✓	"
LOG N CALIBRATE ✓		OPERATE ✓		SOURCE No. <u>B-80</u>	
DUMP WELL PROBE LIGHT		<u>✓</u>			

START-UP CHECK LIST

Equipment checked by F.I.D.C. Personnel check by F.I.D.C.
 Instruments and safeties checked and reset by ARKM
 Source in checked by ARKM Source No. M-43
 Emergency equipment in control room checked by F.I.D.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by ARKM Time 0810
 Start-up OK'd by F.I.D.C. ARKM Date 10-21-70

Solution Temp $^{\circ}$ = 23.6 $^{\circ}$, Remond thermocouples #
3 & 4 from vessel.

sol. = .50 cm

Solution ht = 80.20 cm Water ht = 89.90 cm
+ Per $C = 58.67 \text{ cm} = 14.64 = 29.29 / \text{cm}$ H_2O Temp $^{\circ}$ = 22.4 $^{\circ}$
 $q_k = 67.0 \text{ cm} = 26.4''$

1058 Solution ht = 79.70 cm Water ht = 89.90 cm
system just critical
Drain.

Solution Temp $^{\circ}$ = 23.5 $^{\circ}$

Sample taken from vessel:
4

Reg #
Y-12

684612

$C = 172.5$

$T = 20.3$

$N = 152.2$

out for

1. $g^2/g = 1.264790$

2. sp. gr. = 1.43479

3. density

4. Temp $^{\circ}$

Reg #
X-10

A-5483

$C = 161.1$

$T = 20.3$

$N = 140.8$

out for phone

1. $g^2/g = .2651 = 381.9$
70K

2. sp. gr. = 1.4388

3. density = 1.4369

4. Temp $^{\circ}$

out:

Solution temp $\circ = 23.5\circ$. Removed thermometer
#3 & 4 from vessel.

$$\Delta h = 130 \text{ cm}$$

Solution ht = 86.50 cm.

$$^2 + \text{Per } \bar{v} = 171.67 \text{ cm} = 634 = 21.0 \text{ f/cm}$$

$$\%h = 73.50 \text{ cm} = 28.94''$$

15.33. Solution ht = \pm 86.20 cm

System just critical

Drain: No H_2O .

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter ✓	2"	-	3×10^{-12}
	"	Fast ✓	.5"	-	"
K-2	"	Meter ✓	2"	-	"
	"	Fast ✓	.5"	-	"
R-1					
R-2					
P.M. 1	700V	Alarm ✓	.5"	-	500V
P.M. 2	1200V	Lcw ✓	14"	-	900V
	"	Alarm ✓	1"	-	"
LOG N CALIBRATE		✓	OPERATE	✓	SOURCE No. B-80
DUMP WELL PROBE LIGHT		✓			

START-UP CHECK LIST

Equipment checked by A.K.W. Personnel check by I.D.C.

Instruments and safeties checked and reset by A.K.W.

Source in checked by A.K.W. Source No. 14-93

Emergency equipment in control room checked by I.D.C.

Instruments in trip circuit: K-1-2 P.M. 1-2

Red light on by A.K.W. Time 0920

Start-up OK'd by I.D.C. A.K.W. Date 10-29-70

22

Repeat of exp (see p 19-20)

Solution temp $^{\circ}\text{C} = 24.2^{\circ}\text{C}$. Remained
chromocouple #3 & 4 from vessel.

1290 Solution ht = 97.90 cm
System sub critical.
No H_2O

1310 Solution ht = 97.90 cm Water ht = 89.90 cm
System sub critical
Drain.

Temp $^{\circ}\text{C}$ $\text{H}_2\text{O} = 20.9^{\circ}\text{C}$

Sample taken from vessel:

Y-12 Reg 684613

#5

X-10 Reg 25484

 $\bar{G} = 156.3\text{g}$ $\bar{G} = 159.7\text{g}$ $T = 20.2$ $T = 20.4$ $N = 136.1$ $N = 139.3$

sub for:

1. $\text{g}/\text{g} = 1.227880$

sub for

1. $\text{g}/\text{g} = 1.2281$ 2. $\text{sp. gr.} = 1.353$ 2. $\text{sp. gr.} = 1.3577$

3. density

3. density = 1.3539

4. Temp $^{\circ}\text{C}$ 4. Temp $^{\circ}\text{C}$

5. assay.

6. Paper 40

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1		Meter			
		Fast			
K-2	3×10^{-12}	Meter	2"		3×10^{-12}
"	"	Fast	5"		"
R-1					
R-2					
PM-1	700V	Alarm	5"		500V
PM-2	1200V	Low	14"		900V
		Alarm	1"		"
LOG N CALIBRATE		OPERATE	SOURCE No. <u>P-80</u>		
DUMP WELL PROBE LIGHT					

START-UP CHECK LIST

Equipment checked by I.P.C. Personnel check by I.P.C.
 Instruments and safeties checked and reset by A.K.M.
 Source in checked by A.K.M. Source No. M-43
 Emergency equipment in control room checked by I.P.C.
 Instruments in trip circuit: K-2 PM-1-2
 Red light on by A.K.M. Time 14:00
 Start-up OK'd by I.P.C. A.K.M. Date 11-4-70

added 2.0 l ~~to~~ H_2O to system.
 Miping;

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1		Meter			
		Fast			
K-2	3 X 10 ⁻¹²	Meter ✓	2"	✓	3 X 10 ⁻¹²
	"	Fast ✓	1.5"	✓	"
B-1					
B-2					
PM1	700V	Alarm ✓	1.5"	✓	500V
PM2	1200V	Low ✓	14"	✓	900V
	"	Alarm ✓	2"	✓	"

LOG N CALIBRATE _____ OPERATE _____ SOURCE No. B-80
 DUMP WELL PROBE LIGHT _____

START-UP CHECK LIST

Equipment checked by ^{F.P.C.} A.K.C. Personnel check by A.K.P.
 Instruments and safeties checked and reset by A.K.C.
 Source in checked by A.K.C. Source No. M-42
 Emergency equipment and all reset checked by F.P.C.
 Instruments in trip size: K-2 PM-1-2
 Red light on by A.K.C. Time 0800
 Start-up OK'd by F.P.C., A.K.C. Date 11-5-70

0800 Continued seeping:

1526 Solution ht = 93.75 cm
System sub critical
Dues:

Water ht = 89.90 cm

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1		Meter			
		Fast			
K-2	3 X 10 ⁻¹²	Meter	2"	✓	3 X 10 ⁻¹²
	"	Fast	1.5	✓	"
R-1					
R-2					
PM-1	7005	Alarm	1.5"	✓	5005
PM-2	12005	Low	19"	✓	9005
	"	Alarm	1"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. B-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by ~~AKK~~^{F.P.C.} Personnel check by BZC
 Instruments and safeties checked and reset by AKK
 Source in checked by AKK Source No. M-93
 Emergency equipment in control room checked by F.P.C.
 Instruments in trip circuit: K-2 PM-1-2
 Red light on by AKK Time 0820
 Start-up OK'd by F.P.C. AKK Date 11-6-70

0800 Continued mixing.

1300 Samples taken: One from vessel #6 and one from manifold #6-A.

Y-12 Reg # 684619

X-10 Reg # A-5485

sample #6

sample #6-A

C = 152.0

C = 147.2

T = 18.9

T = 18.8

N = 133.6

N = 128.9

obs for:

g/g. 0.221353

g/g = 0.2215

sp. gr.

sp. gr. = 1.3492

density = 1.339

296.4 g/l

density = 1.3412

Temp ° 25°C

297.1 g/l

INSTRUMENT CHECK

INSTRUMENT	RANGE	TEST	SET	START-UP RANGE
K-1	3 X 10 ⁻¹²	✓	9"	3 X 10 ⁻¹²
"	"	✓	1"	"
K-2	"	✓	9"	"
"	"	✓	1"	"
R-1				
R-2				
PA 1	7000	Alarm ✓	15"	5000
PA 2	1200	Low ✓	12"	9000
"	"	Alarm ✓	1"	"

LOG IN CALIBRATE OPERATE SOURCE No. B-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by F.D.C. Personnel check by F.D.C.

Instruments and safeties checked and reset by B.H.H.

Source in checked by B.H.H. Source No. M-93

Emergency equipment in place and checked by F.D.C.

Instruments in line circuit: 7K-1-2 PM-1-2

Red light on by B.H.H. Time 0825

Start-up OK'd by F.D.C. B.H.H. Date 2-18-71

Plastic Cross:

10.50" I.D.

Solution zero = 7.9 cm (see p 35 for new zero)
 H₂O zero = 22.0 cm (on side scale). This is outside
 bottom of vessel. (see p 35 for new zero.)

Solution feed rate = 7.5 cm/min
 " 1/2" Drain rate = 18.6 cm/min.
 " 3" Drain rate = 35.6 cm/15 sec

H₂O feed rate = 4.6 cm/min
 " 3" Drain = 10.2 cm/min
 " 3" Dump = 12.0 cm/min.

Added ~ 250 l of ~ 910 g/l solution
 to manifold.

Solution ht = 141.05 cm
 System sub critical (No H₂O reflector).
 Drain.

Added ~ 75 l of ~ 910 g/l solution
 to manifold

see:

Solution ht = 216.0 cm
System sub critical (No H_2O reflector,
Drain:

Note: "When solution ht = 216.0 cm solution
is even with bottom of top flange on
"plastic vessel."

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter <input checked="" type="checkbox"/>	9"	-	3×10^{-12}
"	"	Fest <input checked="" type="checkbox"/>	1"	-	"
K-2	"	Meter <input checked="" type="checkbox"/>	9"	-	"
"	"	Fest <input checked="" type="checkbox"/>	1"	-	"
R-1					
R-2					
PM-1	700V	Alarm <input checked="" type="checkbox"/>	15"	-	500V
PM-2	1200V	Low <input checked="" type="checkbox"/>	12"	-	900V
"	"	Alarm <input checked="" type="checkbox"/>	1"	-	"
LOG N CALIBRATE <input checked="" type="checkbox"/>		OPERATE <input checked="" type="checkbox"/>		SOURCE No. <u>B-80</u>	
DUMP WELL PROBE LIGHT <input checked="" type="checkbox"/>					

START-UP CHECK LIST

Equipment checked by F.D.C. Personnel check by F.D.C.

Instruments and safeties checked and reset by A.K.K.

Source in checked by A.K.K. Source No. M-43

Emergency equipment in control room checked by F.D.C.

Instruments in trip circuit: K-1-2 PM-1-2

Red light on by A.K.K. Time 0905

Start-up OK'd by F.D.C. A.K.K. Date 2-19-76

1015 Selection ht = 216.10 cm. H₂O ht = 131.40 cm 10
 System just critical.

$c/h = 115.3 \text{ cm} = 45.39$

1043 Selection ht = 123.20 cm H₂O ht = 140.80 cm 1
 System just critical
 Drain.

These were
 support inside
 but
 void

(H₂O 2nd: 22.3 cm (side scale) outside bottom
 23.5 cm inside bottom)

1420 Soln 124.0 cm H₂O { #1 23.2
 #2 23.2
 H₂O 143.2 cm
 Close to critical; a little + Soln { #3 25.5
 #4 25.5

1425 H₂O 140.85
 Draining Soln Is ≈ 110 cm
~~Removed~~ Removed 2nd & 3rd couplers from soln.

1430 H₂O 140.8 cm H₂O { #1 23.2
 #2 23.2
 Soln 124.5 cm + Point #1
 8.54/cm

1500. Soln 123.4 cm = 115.5 cm
 H₂O 140.8 cm = 117.5 cm
 Mechanical
 level indicates
 Soln high in
 respect to H₂O
 i. add H₂O,
 remove soln

em

1508

H₂O = 141.7 cm

mechanical level

solu = 123.35 cm

indicates same height.

Critical.

em

1525

H₂O = 152.6 cm (6" reflector lateral)

solu = 123.0 cm

Critical.

Drain

em

23.7

23.2

cal

icutes

v.

D

bu

INSTRUMENT-CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3X10 ⁻¹²	Meter ✓	4"	✓	3X10 ⁻¹²
"	"	Fast ✓	1"	✓	"
K-2	4	Meter ✓	4"	✓	"
"	"	Fast ✓	1"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	5"	✓	500V
PM-2	1200V	Low ✓	18"	✓	900V
"	"	Alarm ✓	1"	✓	"
LOG N CALIBRATE		✓	OPERATE	✓	SOURCE No. 13-80
DUMP WELL PROBE LIGHT		✓			

START-UP CHECK LIST

Equipment checked by ^{F.D.C.} AKH Personnel check by F.D.C.
 Instruments and safeties checked and reset by AKH
 Source in checked by AKH Source No. 19-43
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by AKH Time 0830
 Start-up OK'd by F.D.C. AKH Date 2-22-71

Using mechanical level

{ Solution zero = 6.0 cm "
 { H₂O level with solution = 23.5 cm "

Thermocouples in solution and H₂O

{ H₂O 43.4 cm 19.9
 { Solution 26.1 cm 20.1

{ H₂O 62.9 cm 39.4
 { Solution 45.2 cm 39.2

{ H₂O 78.6 cm 55.3
 { Solution 61.0 cm 55.0

{ H₂O 93.0 cm 69.5
 { Solution 75.35 cm 69.35

10:00 { H₂O 104.2 cm 80.7
 { Solution 86.6 cm 80.6

{ 21 23.0
 { 22 23.0
 { 23 24.2
 { 24 24.2

{ H₂O 110.0 cm 86.5
 { Solution 92.25 cm 86.25

{ 12 23.1
 { 13 24.4
 { 14 24.6

Thermocouples removed from vessels

over

H₂O = 117.15

1522

Solution ht = 123.15 cm H₂O = 140.80 cm
 System just critical

117.3

d₂ = 1.15

Solution ht = 124.35 cm H₂O = 140.80 cm
 + Per H₂O Temp °C
 C = 67.36 sec = 13.14 = 11.64/cm 23.1 °C

1535

Solution ht = 123.20 cm H₂O = 140.80 cm
 System just critical
 Drain: H₂O
 Solution Temp °C = 25.0 °C

H₂O = 117.15

117.3

Sample taken from vessel #1

7-12 Reg # 684624

X-10 Reg # A5486

ask for

1. g/g = .442345

1. g/g = .443795

2. sp. gr. = 2.0190

2. sp. gr. = 2.0194

3. density = 2.0130

3. density = 2.0167

4. Temp = 25 °C

4. Temp = 25.5 °C

#1

= 897.194/l

#1 - A

855.0

C = 296.5 g

C = 286.9 g

T = 28.3

A = 856.184/l

T = 28.2

N = 268.7 g

ρ = 1.015

N = 253.7

2-23-70

Drain the ~910 g/l from manifold:

added ~96 l of $\overset{897.1}{910}$ g/l and ~207 l
 of $\overset{796.7}{910}$ g/l. This results in an
 estimate of 323 l at a
 concentration of 828.5 g/l.

3/24/71

Calc. of above experiment (Bob Hinton)
 w. Homan, Royal cross sections

$$K = 0.5521 + 0.0049 \rightarrow$$

486

7.5

4

7

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	Secondary RANGE
K-1	3 x 10 ⁻¹¹	Meter ✓	4"	✓	10 x 10 ⁻¹¹
"	"	✓	1"	✓	"
K-2	"	Meter ✓	8"	✓	"
"	"	Test ✓	1"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	5"	✓	500V
PM-2	1200V	Low ✓	12"	✓	900V
"	"	Alarm ✓	1"	✓	"
LOG N CALIBRATE		✓	OPERATE	✓	SOURCE No. <u>B-80</u>
DUMP WELL PROBE LIGHT <u>✓</u>					

START-UP CHECK LIST

Equipment checked by F.I.C. Personnel check by F.I.C.
 Instruments and safeties checked and reset by B.K.A.
 Source in checked by B.K.A. Source No. M-43
 Emergency equipment in control room checked by F.I.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by B.K.A. Time 0905
 Start-up OK'd by F.I.C., B.K.A. Date 7-29-71

WEDNESDAY

1972 NOVEMBER 1972						
S	M	T	W	T	F	S
				1	2	3
5	6	7	8	9	10	11
12	13	14	15	16	17	18
19	20	21	22	23	24	25
26	27	28	29	30		

1

NOV. 1972

950100001
579000001
11/1/72
306 WED., NOVEMBER 1, 1972 60

~ 10:30

Found that the plastic cover was floating in tank.

Drain solution and H_2O .

1330

Water samples taken from Bil hid dump tank: one from top surface and one from drain on outside tank.

Top of tank

Reg # 694401

ask for

$g/g = .00001057$

Bottom of tank

Reg # 694402

ask for

$g/g = .00001020$

2-26-71

Repeat of water sample: sampled tank

7-12 Reg # 694403

ask for

$g/g = .00001056$

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3 X 10 ⁻¹²	Meter ✓	4"	✓	3 X 10 ⁻¹⁰
"	"	Fast ✓	1"	✓	"
K-2	"	Meter ✓	4"	✓	10 X 10 ⁻¹²
"	"	Fast ✓	1"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	5"	✓	500V
PM-2	1200V	Low ✓	12"	✓	900V
"	"	Alarm ✓	2"	✓	"
LOG N CALIBRATE ✓		OPERATE ✓		SOURCE No. B-80	
DUMP WELL PROCSE LIGHT ✓					

START-UP CHECK LIST

Equipment checked by F.D.C Personnel check by F.D.C
B.K.K.
 Instruments and safeties checked and reset by B.K.K.
 Source-in checked by B.K.K. Source No. M-43
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1-2 PM 1-2
 Red light on by B.K.K. Size 1005
 Start-up done by F.D.C. B.K.K. Date 3-17-71

Scop.
10.D.C.
all
with
S.S.G.
7h
up
10.D.

Plastic Cross:

10.50" F.O.

Solution zero = 6.8 cm

H₂O zero = 23.0 cm (on side scale) This is outside bottom of vessel.

Solution feed rate = 8.5 cm³/min in lower section

" 1/2 drain rate = 21.5 cm³/min

" 3" dump rate = 50.3 cm³/15 sec
= 361.2 cm³/min
{ 31.2 cm³/min from filter

H₂O feed rate = 4.1 cm³/min

" 3" ~~drain~~ ^{drain} rate = 12.3 cm³/min

" 3" dump rate = 12.4 cm³/min

Scope:

Water at 235.1 cm (side scale).

10.0 cm when

Solution (est. p. 37) added to end of

all empty and 2nd check and leave check. Cross how

with H₂O up leads 55 guy cables from gussets to both

9.9 cm with top & bottom of side (4 each). Meter stick

H₂O & Soln at top of cross, viewed thru south

up. Window with telescope to check movement

10.0 empty.

of cross and/or stretching of cables.

None observed with H₂O up and cross empty.

1455

Solution 217.1 cm, effectively same height as water. Very sub critical.

1510

Measured drain & dump rates. Drain

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	3x10 ⁻¹⁰
"	"	Fast ✓	1"	✓	"
K-2		Meter			
		Fast			
R-1					
R-2					
PM-1	700V	Alarm ✓	5"	✓	500V
PM-2	1200V	Low ✓	12"	✓	900V
"	"	Alarm ✓	2"	✓	"
LOG IN CALIBRATE		✓	OPERATE	✓	SOURCE No. B-80
DUMP WELL PROBE LIGHT		✓			

START-UP CHECK LIST

Equipment checked by F.D.C. Personnel check by F.D.C.
A.K.H.
 Instruments and safeties checked and reset by A.K.H.
 Source in checked by A.K.H. Source No. M-43
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1 P19-1-2
 Red light on by A.K.H. Time 1245
 Start-up OK'd by F.D.C. A.K.H. Date 3-19-75

0900

Removed ~ 75 l of 828 g/l and added ~
25 l of 897 g/l. To manifold.

1438

Solution ht = 217.5 cm

Water ht = 235.1 cm

System sub critical

Drain.

h_{cap} = 9.9 cm

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3x10 ⁻¹²	None ✓	2"	—	3x10 ⁻¹⁰
"	"	Fast ✓	1"	—	"
K-2		Master			
		Fast			
R-1					
	700V	Alarm ✓	5"	—	500V
	21200V	Low ✓	14"	—	1900V
	"	Alarm ✓	1"	—	"
LOG N CALIBRATE		✓	OPERATE	✓	SOURCE No. B-80
DUMP WELL FROSE-LIGHT		✓			

START-UP CHECK LIST

Equipment checked by ^{F.O.C.} AKM Personnel check by R.K.H.

Instruments and safeties checked and reset by AKM

Source in checked by AKM Source No. 04-93

Emergency equipment in control room checked by F.O.C.

Instruments in this circuit: K-1 - P14-1-2

Red light on by AKM Time 1220

Start-up OK'd by F.O.C. & AKM Date 3-22-71

1000 Removed ~ 75 l of ~ 835.3 g/l and added
 ~ 75 l of 897 g/l to manifold.

1428 Solution ht = 217.1 cm Water ht = 235.1 cm
System sub critical $h_{cap} = 9.8$ cm.
Drains.

1520 Removed ~ 75 l of 853.3 g/l and added
 ~ 75 l of 897.0 g/l to manifold.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter ✓	8"	✓	3×10^{-10}
"	"	Fct ✓	1"	✓	"
K-2	"	Meter ✓	3"	✓	"
"	"	Fct ✓	1"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	15"	✓	500V
PM-2	1200V	Alarm ✓	12"	✓	900V
"	"	Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. B-80
 RED LIGHT

START-UP CHECK LIST

Equipment checked by Filo Personnel check by Filo
 Instruments and safeties checked and reset by ARK
 Source in checked by ARK Source No. M-43
 Emergency equipment in control room checked by Filo
 Instruments in trip circuit: K-1 PM-1-2
 Red light on by ARK Sigs 1005
 Start-up OK'd by Filo ARK Date 3-23-71

1400 Solution ht = 217.2 cm
System sub-critical
Crain.

Water ht = 235.1 cm
h_{cap} = 9.8 cm

1515 Remained ~ 75 l of ~ 806.2 g/l and added
~ 75 l 897.0 g/l. to manifold.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3x10 ⁻¹²	Motor ✓	9"	—	3x10 ⁻¹²
"	"	Fast ✓	1"	—	"
K-2		Motor			
		Fast			
R-1					
R-2					
PM-1	700V	Alarm ✓	15"	—	500V
PM-2	1200V	Low ✓	14"	—	900V
"	"	Alarm ✓	1"	—	"

LOG IN CALIBRATE OPERATE SOURCE No. B-80

DUMP WELL PRQGE LIGHT

START-UP CHECK LIST

Equipment checked by F.D.C. Personnel check by F.D.C.

Instruments and safeties checked and reset by A.K.M.

Source is checked by A.K.M. Source No. M-93

Emergency equipment in control room checked by F.D.C.

Instruments in trip circuit: M-1 PM-1-2

Red lights on by A.K.M. Time 0939

Start-up Order by F.D.C. A.K.M. Date 3-28-76

Solution ht = 147.40 cm

Water ht = 235.1 cm

+ Per

heq = 9.9 cm

N.G.

ht = 130.7 cm = 53.5"

1117

~~1117~~ Solution ht = 147.90 cm

Water ht = 235.1 cm

System just critical

Drain

Solution ht = 147.95 cm.

Water ht = 235.1 cm

+ Per

heq = 9.9 cm

N.G.

1424 Solution ht = 143.80 cm

Water ht = 235.1 cm

System just critical

1435 Solution height = 143.8 cm; Water ht = 161.7 cm
Critical.

1446 Drain: Solution and H₂O. Level is drifting up.
winds: hum's that solution is not mixed;
Drain and continued mixing solution.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	ST	START-UP RANGE
K-1	3 X 10 ⁻¹²	Alarm ✓	4"	✓	3 X 10 ⁻¹⁰
"	"	Alarm ✓	1"	✓	"
K-2		Meter			
		Alarm			
R-1 ²					
PM-1	700V	Alarm ✓	5"	✓	500V
PM-2	1200V	Low ✓	14"	✓	900V
"	"	Alarm ✓	1"	✓	"
LOG N CALIBRATE ✓		OPERATE ✓	SOURCE No. B-80		
DUMP WELL PROBE LIGHT ✓					

START-UP CHECK LIST

Equipment checked by FIDC Personnel check by FIDC
~~to KAD~~
 Instruments and safeties checked and reset by A KAD
 Source in checked by A KAD Source No. 17-43
 Emergency equipment in control room checked by FIDC
 Instruments in trip circuit: K-1 PM-10V
 Red light on by A KAD Time 0910
 Start-up OK'd by FIDC, A KAD Date 3-25-71

after more mixing:

Solution ht = 148.30 cm Water ht = 235.1 cm

Flow 104.4 cm = $\frac{5.54}{7.16}$ = 1.044 slope = 9.9 cm

1126 Solution ht = 141.20 cm Water ht = 235.1 cm

system just critical
Drain:

Solution ht = 151.90 cm Water ht = 235.1 cm

Flow 110.6 cm = $\frac{5.14}{4.64}$ = 1.074 slope = 9.9 cm

1430 Solution ht = 142.60 cm Water ht = 235.1 cm

system just critical
Drain H₂O:

H₂O Temp °C

1 = 23.2°C

2 = 23.2°C

1445 Measured solution Temp

#3 = 26.0°C

#4 = 26.0°C

1451 Drain solution:

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SET	START-UP RANGE
K-1	3A10-12	✓	9"	3A10-10
"	"	✓	1"	"
K-2				
R-1				
R-2				
PM-1	700V	✓	15"	500V
PM-2	1200V	✓	14"	900V
"	"	✓	1"	"

LOG N CALIBRATE OPERATE SOURCE No. B-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

- Equipment checked by E.D.C. Personnel check by I.V.C.
- Instruments and safeties checked and set by A.K.C.
- Source in checked by A.K.C. Source No. M-13
- Emergency equipment in control room checked by E.D.C.
- Instruments in trip circuit: K-1 PM-1-2
- Red light on by A.K.C. Time 0900
- Start-up OK'd by E.D.C. A.K.C. Date 3-26-71

0945 solution ht = 98.10 solution temp = #3 = 24.2°C and
 #4 = 24.5°C. Remained thermocouple #3 & 4.
 H₂O temp #1 = 23.2°C #2 = 23.5°C

solution ht = 147.8 cm d = 6.6 cm Water ht = 235.1 cm
 + Por height = 9.9 cm
 G = 102.0 mm = 9.6 ft = 1.24 mm

1030 solution ht = 140.80 cm Water ht = 235.1 cm
 system just critical

ht = 136.20 cm

1053 solution ht = 141.00 cm Water ht = 158.8 cm
 system just critical height = 9.9 cm
 Drain solution to 107.5 cm. installed thermocouple
 #3 & 4.

solution temp °C	water temp °C
#3 = 24.9°C	#1 = 23.1°C
#4 = 24.9°C	#2 = 23.1°C

1108 Drains:

solution sample taken from vessel: #2

Y-12 Reg # 694409

X-10 Reg # A-5487

ubs for:

1. g wt = 434.273

1.94g = 433.2

2. sp. gr = 1.9740 = 857.2

2. sp. gr 1.9752

3. density = 1.9682

2.9e 3. density 1.9712

4. Temp = 25.0°C

4. Temp 20°C

#2

G = 189.0

T = 18.9

N = 165.12 mm

#2A

G = 222.2

T = 19.4

N = 202.8 mm

= 855.6 g/cc

3-29-71 Drain - 275 l of ~ 875.0 g/l from
manifold and added ~ 275 l of
~ 897.0 g/l to manifold.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3A10-12	Meter ✓	4"	✓	3A10-10
	"	Fast ✓	1"	✓	"
K-2		Meter			
		Fast			
R-1					
R-2					
PM-1	700V	Alarm ✓	10"	✓	500V
PM-2	1200V	Low ✓	14"	✓	900V
	"	Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. B-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by J.D.C. Personnel check by F.V.C.
 Instruments and safeties checked and reset by B.K.M.
 Source in checked by B.K.M. Source No. M-13
 Emergency equipment in control room checked by F.V.C.
 Instruments in trip circuit: K-1 PM-1-2
 Red light on by B.K.M. Time 0912
 Start-up OK'd by F.V.C. B.K.M. Date 3-30-71

Solution ht = 105.0 cm Solution Temp's #3 = 24.0°C
 #4 = 24.0°C. Removed thermocouples #3 & 4.
 H₂O Temp #1 = 22.7°C #2 = 22.7°C

ΔL = 1.05 cm

Solution ht = 123.40 cm

Water ht = 235.1 cm

+ Rev

loop = 10.0 cm

$t = 56.60 \text{ sec} = 15.04 = 14.3 \frac{1}{4} \text{ min}$

1041 Solution ht = 122.35 cm

Water ht = 235.1 cm

System just critical

1110 Solution ht = 122.80 cm

Water ht = 190.40 cm

System just critical

Drain:

Drain solution to 104.50 cm and installed

thermocouples #3 & 4.

Solution Temp °C

Water Temp °C

#3 = 24.2°C

#1 = 22.6°C

#4 = 23.0°C

#2 = 22.6°C

1125 Drain solution.

Solution ht = 105.0 cm, Solution Temp's #3 = 25.6°C

#4 = 25.6°C. Removed thermocouple #3 & 4.

H₂O Temp #1 = 22.7°C #2 = 22.7°C

$a_2 = 1.0 \text{ cm}$

Solution ht = 123.50 cm

Water ht = 235.1 cm

 $^2 + P_{ev}$ h_{cap} = 9.9 cm $E = 60.8 \text{ cm} = 19.3 \text{ ft} = 19.24 \text{ cm}$

1400 Solution ht = 122.50 cm

Water ht = 235.1 cm

System just critical

1418 Solution ht = 122.90 cm

Water ht = 140.50 cm

System just critical.

Drain solution to 108.0 cm and installed thermocouples #3 & 4

Solution Temp °C

Water Temp °C

#3 = 25.7°

#1 = 22.7°

#4 = 25.7°

#2 = 22.7°

Sample taken from vessel #3

Y-Req # 694405

K-10 Req # A-5488

only for:

1. $\rho_{18} = 1.446783$ 1. $\rho_{18} = 1.4470$

2. Sp. gr. = 2.0287

2. Sp. gr. = 2.0210

3. Density = 2.0227

3. Density = 2.0176

4. Temp °C = 25.0

4. Temp °C = 19.0

= 906.3 g/L

= 903.4 g/L

G = 214.8

G = 219.4

T = 19.5

T = 19.0

N = 195.3 grams

N = 200.6 grams

Plastic Cross

Non 10.750" I.D.

4-22-71 Solution zero = 6.9 cm
H₂O zero = 23.1 cm = to outside
bottom of vessel.
When H₂O = 23.5, 10 cm H₂O is even
with bottom of top flange on plastic
cross.
slope zero = 10.0 cm: No solution or
H₂O in or around vessel.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3A10 ⁻¹²	Meter ✓	4"	✓	3X10 ⁻¹²
"	"	Fast ✓	1"	✓	"
K-2	"	Meter			
	"	Fast			
R-1					
R-2					
PM-1	700V	Alarm ✓	5"	-	500V
PM-2	1200V	Low ✓	14"	✓	900V
"	"	Alarm ✓	1"	✓	"

LOG IN CALIBRATE OPERATE SOURCE No. B-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by F.P.C. Personnel check by F.P.C.

Instruments and safeties checked and reset by B.K.M.

Source in checked by B.K.M. Source No. 19-83

Emergency equipment in control room checked by F.P.C.

Instruments in trip circuit: K-1 DM-1-2

Red light on by B.K.M. Time 0915

Start-up OK'd by F.P.C. B.K.M. Date 4-23-71

Solution ht = 98.0 cm Solution Temp °C =
 #3 = 25.2°C #4 = 25.2°C; Remained there
 no couples #3 & 4 from used. H₂O temp °C
 #1 = 23.0°C #2 = 23.0°C

LA = .65 cm

Solution ht = 117.30 cm Water ht = 235.1 cm
 + Per Leaf = 9.9 cm
 $\sigma = 52.50 \text{ cm} = 15.1 \phi = 23.2 \text{ H/cm}$

1105 Solution ht = 116.66 cm Water ht = 235.1 cm

System just critical.

Drain solution to ~105.0 cm; installed thermo-
 couples #3 & 4.

Solution Temp °C Water Temp °C

#3 = 25.2°C

#1 = 22.7°C

#4 = 25.7°C

#2 = 23.0°C

Drain solution:

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	3x10 ⁻¹²
	"	Fast ✓	1"	✓	"
K-2		Alarm			
		Fast			
R-1					
R-2					
PM-1	700V	Alarm ✓	Cont	✓	500V
PM-2	1200V	Low ✓	16"	✓	900V
	"	Alarm ✓	2"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. D-80
 DUMP WELL PROBE LIGHT

START-UP CHECK LIST

FIDC
 Equipment checked by ATK Personnel check by FIDC
 Instruments and safeties checked and reset by ATK
 Source in checked by ATK Source No. M-43
 Emergency equipment in control room checked by FIDC
 Instruments in trip circuit: K-1 PM-1-2
 Red light on by ATK Time 0910
 Start-up OK'd by FIDC ATK Date 4-26-71

Solution ht = 103.20 cm; solution temp °C
 = #3 = 23.7° #4 = 24.2° H₂O temp °C
 #1 = 23.0° #2 = 23.2°. Removed thermo-
 mographs #3 & 4 from vessel.

D.L. = 1.5 cm

Solution ht = 117.0 cm Water ht = 235.1 cm
 + Per slope = 10.0 cm
 $\sigma = 86.92 \text{ mm} = 11.0 \text{ ft} = 22.0 \text{ ft cm.}$

1040 Solution ht = #116.5 cm Water ht = 235.1 cm
 → system just critical

1103 Solution ht = #117.50 cm Water ht = 135.1 cm
 system just critical
 Drain solution to 107.0 cm and installed
 thermographs #3 & 4 in vessel.

solution temp °C	H ₂ O temp °C
#3 = 24.2°	#1 = 23.2°
#4 = 24.7°	#2 = 23.0°

Drain:

solution sample taken from vessel:

Sample # 4

~~out for~~

Y-12 Reg # 694406

X-10 Reg # A-5489

oil for

1 = $\frac{W}{V} = .446735$

1 = $\frac{W}{V} = .446$

2 = $\frac{W}{V} = 2.0292$

2 = $\frac{W}{V} = 2.032$

3 = density = 2.0232

3 = density = 2.028

4 = Temp °C

4 = Temp °C = 20.8°C

G = 195.8g

906.5g_{4L}

G = 196.3g

906.3g_{4L}

T = 19.5°C

T = 19.2g

N = 176.3g

526.4g

N = 177.1g

$\rho = 2.325$

4 ²⁴/₂₇/71 Drains ~ 275L of ~ 906g_{4L} from manifold
and added ~ 275L of ~ 857g_{4L} to
manifold.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3R10 ⁻¹²	Meter ✓	4"	✓	3R10 ⁻¹²
"	"	Fast ✓	1"	✓	"
K-2		Meter			
R-1					
R-2					
PM 1	700V	Alarm ✓	600	✓	500V
PM 2	1200V	Low ✓	12"	✓	900V
"	"	Alarm ✓	1"	✓	"
LOG N CALIBRATE		✓	OPERATE	✓	SOURCE No. B-80
DUMP WELL PROBE LIGHT		✓			

START-UP CHECK LIST

Equipment checked by A.K.M. Personnel check by E.V.C.
 Instruments and safeties checked and reset by A.K.M.
 Source in checked by A.K.M. Source No. M-93
 Emergency equipment in control room checked by E.V.C.
 Instruments in trip circuit: K-1 PM-1-2
 Red light on by A.K.M. Time 1230
 Start-up OK'd by E.V.C. A.K.M. Date 4-27-70

solution ht = 105 cm; solution temp ° = #3 = 24.1 °
 #4 = 25.2 °; ~~Removed~~ Removed thermocouples
 #3 & 4 from vessel. H₂O temp ° = #1 = 22.7 °
 #2 = 23.0 °.

$\Delta t = 1.0$

solution ht = 123.45 cm Water ht = 235.1 cm
 #1 & #2 height = 10.6 cm

$D = 58.67 \text{ cm} = 14.64 = 14.64 \text{ cm}$

1904 solution ht = 122.45 cm Water ht = 235.1 cm

system just critical

Drain solution to 109 cm and installed
 thermocouples #3 & 4 in vessel.

solution temp °	H ₂ O temp °
#3 = 24.2 °	#1 = 22.7 °
#4 = 25.1 °	#2 = 22.7 °

Drain:

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3 x 10 ⁻¹²	Meter ✓	4"	✓	3 x 10 ⁻¹²
"	"	Est ✓	1"	✓	"
K-2		Meter			
		Est			
R-1					
R-2					
PM-1	700V	Alarm ✓	cont ✓		500V
PM-2	1200V	Low ✓	12" ✓		900V
"	"	Alarm ✓	1" ✓		"
LOG N CALIBRATE		✓	OPERATE	✓	SOURCE No. B-80
DUMP WELL PROBE LIGHT		✓			

START-UP CHECK LIST

Equipment checked by F.D.C. Personnel check by F.D.C.

Instruments and safeties checked and reset by A.K.A.P.

Source in checked by A.K.A.P. Source No. M-43

Emergency equipment in control room checked by F.D.C.

Instruments in trip circuit: K-1 DM-1-2

Red light on by A.K.A.P. Time 0900

Start-up OK'd by F.D.C., A.K.A.P. Date 9-28-71

Solution ht = 105.0 cm; Solution Temp: $\#3 = 23.7^\circ\text{C}$
 $\#4 = 24.9^\circ\text{C}$. Removed thermocouples $\#3$ & $\#4$ from
 vessel. H_2O Temp: $\#1 = 23.1^\circ\text{C}$ $\#2 = 23.2^\circ\text{C}$

$\Delta L = 1.2 \text{ cm}$

Solution ht = 123.65 cm Water ht = 235.1 cm
 + Pex ~~to~~ slope = 10.0 cm

$C = 45.63 \text{ cm} = 17.4\% = 14.5\% \text{ / cm}$

1044 Solution ht = ~~122.45~~ 122.45 cm Water ht = 235.1 cm
 → System just critical

1102 Solution ht = $\#122.95 \text{ cm}$ Water ht = 140.60 cm

→ System just critical

Drain solution to ~ 105 cm and installed
 thermocouples $\#3$ & $\#4$ in vessel.

Solution Temp: H_2O Temp:

$\#3 = 24.5^\circ\text{C}$ $\#1 = 22.7^\circ\text{C}$

$\#4 = 25.0^\circ\text{C}$ $\#2 = 23.0^\circ\text{C}$

Drain:

Solution sample taken from
 vessel. see p 68. Sample $\#5$

Sample #5

Y-12 Reg # 694907

X-10 Reg # 5490

act for

1. $g/g = .434732$

1. $g/g = 0.433$

2. $sp. gr. = 1.9753$

2. $sp. gr. = 1.977$

3. $density = 1.9695$

3. $density = 1.973$

4. $Temp^{\circ}C = 855.79^{\circ}K$

4. $Temp^{\circ}C$

$G = 198.3g$

$C = 187.5g$

$856.9^{\circ}K$

$T = 18.6g$

$T = 18.3g$

$N = 179.7g$

$N = 169.2g$

$857.3^{\circ}K$

1.521

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3x10 ⁻¹²	Meter ✓	3"	✓	3x10 ⁻¹²
"	"	Fast ✓	1"	✓	"
K-2		Meter			
		Fast			
R-1					
R-2					
PM-1	7005	Alarm ✓	cont	✓	5005
PM-2	12005	Low ✓	12"	✓	9005
"	"	Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. B-80
 DUMP WELL PROBE LIGHT

START-UP CHECK LIST
 Equipment checked by AKK Personnel check by F.R.C.
 Instruments and safety checked and reset by AKK
 Source in checked by AKK Source No. MA-83
 Emergency equipment in control room checked by F.R.C.
 Instruments in trip operate: K-1 PM-1-2
 Red light on by AKK time 0905
 Start-up OK'd by F.R.C. AKK Date 5-14-71

Plastic Cross

Nom 11.0" I.D.

Solution zero = 7.0 cm

 H_2O zero = 23.2 cm to outside bottom
bottom of vessel.When $H_2O = 285.2$ cm H_2O is even with
bottom of top flange on plastic cross

Scale zero = 10.0 cm

1101

1125

1150

See

Solution ht = 92.5 cm solution temp ° #3 = 24.0°
 & #4 = 24.0°. Removed thermocouples #3 & 4
 from vessel. H₂O temp ° #1 = 23.0° #2 = 23.0°

Solution ht = 117.20 cm ^{sl = 1.2 cm} Water ht = 235.2 cm
 + Per scope = 10.0 cm

$$\epsilon = 152.1 \mu = 7.0\% = 35.0 \text{ \#}/\text{cm.}$$

1101 Solution ht = 117.0 cm ^{sl = 110.00 cm} Water ht = 235.2 cm
 = 43.3" System just critical

1125 Solution height = 117.95 cm Water ht = 135.8 cm
 Critical (Soln & H₂O same ht) Scope = 9.5 cm

Drain solution & install thermocouples #3 & 4.

#1 = 23.0° #2 = 23.0° (H₂O Temp)
 #3 = 24.6° #4 = 24.6° (Solution Temp)

1150 Drain for solution sample.

Solution sample taken from vessel
 Sample #6 see p 72

Sample # C

Y-12 Reg # 694408

X-10 Reg # A-5491

arb form

1. $g/g \approx 4405190$

1. $g/g \approx 435$

2. sp. gr. = 1.9741

2. sp. gr. = 1.9778

3. density = 1.9683

3. density = 1.9744

4. temp = $25^{\circ}C$
 $\approx 876.3 g/g$

4. temp. = $20.5^{\circ}C$
 $\approx 860.3 g/g$

avg = 868.3

E = 194.1

G = 197.6

F = 19.3

F = 19.0

N = 174.8 g

N = 178.6 g

5-17-71

~ 275 l
 Drain the 858.7 g/l and added ~ 275 l of
 906.2 g/l to manifold.

INSTRUMENT CHECK

91

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3x10 ⁻²	Meter ✓	3"	✓	3x10 ⁻²
"	"	Foot ✓	1"	✓	"
K-2		Meter			
		Foot			
R-1					
R-2					
PM-1	700V	Alarm ✓	cont	✓	500V
PM-2	1200V	Low ✓	12"	✓	900V
"	"	Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. 12-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by Z.P.C. Personnel check by F.V.C.

Instruments and safeties checked and reset by A.K.H.

Source in checked by A.K.H. Source No. M-43

Emergency equipment in control room checked by F.V.C.

Instruments in trip circuit: K-1 114-1-2

Red light on by A.K.H. Time 0900

Start-up OK'd by F.V.C. A.K.H. Date 5-18-71

Solution ht = 102 cm. Solution Temp #3 = 24.7°
 #4 = 24.7°. Removed thermocouples #3 & 4 from
 vessel. H₂O Temp °. #1 = 23.6° #2 = 23.2°

Solution ht = 113.5 cm dh = 1.2 cm Water ht = 235.2 cm

7 Per

5 = 106.5 cm = 9.34 = 46.54/cm

11.00 Solution ht = ~~113.3~~ ^{113.3 cm} ^{4.2 = 106.3 cm} Water ht = 235.2 cm
 = 41.85" slope = 10.0 cm

System just critical

11.18 Solution ht = 114.9 cm Water ht = 132.5 cm

System just critical

Drain solution to ~ 102 cm and installed
 thermocouples #3 & 4.

Solution Temp °

H₂O Temp °

#3 = 24.2°

#1 = 23.0°

#4 = 25.0°

#2 = 23.2°

Drain solution after taking sample #7
 from vessel.

Sample #7.

V-12 Reg # 698409

A-10 Reg # A-5492

orb for.

1 - $\rho^2/g = .946892$

1.74g = .444

2. $\rho_p/g = 2.022$

2 - $\rho_p/g = 2.0306$

3. density = 2.0223

3. density = 2.0266

4. Temp $^{\circ}C = 25.0$

4 Temp $^{\circ}C = 20.5$

= 903.6g

= 901.6g

$\sigma = 202.5$

922.6

$\sigma = 192.7$

$\tau = 18.6$

2.0-44

$\tau = 19.2$

N = 183.9g

N = 173.5g

5-19-76

Drains the ~ 906 g/l and added about
 300 l of ~ ⁹¹⁴ 825 g/l to manifold.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3X10 ⁻¹²	Alarm ✓	3"	✓	3X10 ⁻¹²
"	"	Fail ✓	1"	✓	"
K-2		Alarm			
		Fail			
R-1					
R-2					
PM-1	700V	Alarm ✓	cont ✓	✓	500V
PM-2	1200V	Low ✓	12" ✓	✓	900V
"	"	Alarm ✓	1" ✓	✓	"
LOG N CALIBRATE		✓	OPERATE	✓	SOURCE No. 0-80
DUMP WELL PROBE LIGHT		✓			

10

11

START-UP CHECK LIST

Equipment checked by Fiduc Personnel check by Fiduc
 Instruments and safeties checked and reset by ATK
 Source in checked by ATK Source No. 19-43
 Emergency equipment in control room checked by Fiduc
 Instruments in trip circuit: K-1 PM-1-2
 Red light on by ATK Time 0905
 Start-up OK'd by Fiduc ATK Date 5-29-71

Solution ht = ~102 cm; Solution Temp °C
 #3 = 24.5°C ~~#4 = 24.9°C~~ #4 = 24.9°C, Remained
 thermocouples #3 + 4 from vessel. H₂O temp °C
 #1 = 23.2°C #2 = 23.5°C

^{ht = 124.9 cm}
 Solution ht = 124.9 cm Water ht = 235.2 cm
 + Per slope = 10.0 cm
 S = 84.7 m = 11.1 ft = 12.3 ft/cm

1049 Solution ht = 124.0 cm ^{ht = 117.0 cm} Water ht = 235.2 cm
 = 96.06"
 System just critical

1105 Solution ht = 124.50 cm ^{ht = 117.5 cm} Water ht = 192.2 cm
 System just critical

Drain solution to ~108 cm and installed
 thermocouples #3 + 4.

Solution Temp °C	H ₂ O Temp °C
#3 = 24.9°C	#1 = 23.9°C
#4 = 25.0°C	#2 = 23.7°C

Drain solution

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter ✓	3"	✓	3×10^{-12}
"	"	Foot ✓	1"	✓	1
K-2		Meter			
		Foot			
R-1					
R-2					
PM-1	700V	Alarm ✓	Cont	✓	500V
PM-2	1200V	Low ✓	12"	✓	900V
		Alarm ✓	1"	✓	1"
LOG N CALIBRATE		✓	OPERATE	✓	SOURCE No. <u>B-80</u>
DUMP WELL PROCSE LIGHT		✓			

START-UP CHECK LIST

Equipment checked by F.D.C. Personnel check by F.D.C.

Instruments and safeties checked and reset by R.K.M.

Source in checked by R.K.M. Source No. M-93

Emergency equipment in control room checked by F.D.C.

Instruments in trip circuit: K-1 PM-1-2

Red light on by R.K.M. Time 0900

Start-up OK'd by F.D.C., R.K.M. Date 5-21-71

Solution ht = 102 cm, solution temp ° #3 = 24.9°
 #4 = 24.0°, Removed thermometer #3 & 4
 from vessel, H₂O temp ° #1 = 23.4° #2 = 23.6°

0.2 = 1.85 cm

Solution ht = 124.85 cm Water ht = 235.2 cm
 + Per slope = 10.0 cm

C = 91.3 m = 10.6 φ = 12.54/cm

1015 Solution ht = ± 124.0 cm ^{0.16 = 1.17 cm} Water ht = 235.2 cm

System just critical

Drain to ~ 108 cm and installed thermocouples
 #3 & 4 in vessel.

Solution temp °	H ₂ O temp °
#3 = 24.9°	#1 = 23.5°
#4 = 25.0°	#2 = 23.5°

Sample #8 taken from vessel:

Y-12 mg # 694410

X-10 mg # 5493

1 - g⁴/_g = .472157

1 - g⁴/_g = .4207

2. sp. gr. = 1.9239

2. sp. gr. = 1.9258

3. density = 1.9182 1.52

3. density = 1.9220

4. Temp ° = 25°
 = 812.2 g/l

4. Temp ° = 20.5°
 = 810.2 g/l

C = 199.7

C = 183.1

T = 20.0 811.5

T = 19.3

N = 168.9

N = 163.8

Plastic Crown

Nom 11.250" I.O.

Solution zero = 7.0 cm

 H_2O zero = 23.1 cm to outside bottom
of vessel.When H_2O = 235.1 cm H_2O is even with
bottom of top flange on plastic crown.

Seape zero = 10.0 cm.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
13	10 ⁻¹²	✓	8"	✓	3x10 ⁻¹²
"	"	✓	1"	✓	"
		Motor			
		Alarm			
	700V	Alarm ✓	60"	✓	500V
	1200V	Low ✓	20"	✓	900V
	"	Alarm ✓	2"	✓	"
LOST ONE POINT		✓	OPERATE	✓	SOURCE No. <u>B-80</u>
DUMP WELL PROBE LIGHT		✓			

START-UP CHECK LIST

Equipment checked by I.D.C. Personnel check by E.D.C.

Instruments and safeties checked and reset by AKK

Source in checked by AKK Source No. M-23

Emergency equipment in control room checked by I.D.C.

Instruments in trip circuit: K-1 PM-1-2

Red light on by AKK Time 0915

Start-up OK'd by I.D.C. AKK Date 6-10-71

Solution ht = 93.50 cm. Solution temp ° C #3 = 25.6°
 #4 = 26.0°. Removed thermocouple #3 + 4 from
 vessel. H₂O temp ° C #1 = 28.0° #2 = 28.2°

b₄ = 1.30 cm

Solution ht = 118.30 cm Water ht = 235.1 cm
 + Per slope = 10.0 cm

$$C = 141.2 \text{ sec} = 7.44 = 24.74 / \text{cm.}$$

1100 Solution ht = 118.0 cm ^{ht = 111.0 cm} 43.7" Water ht = 235.1 cm

system just critical

h₂ = 111.9 cm

1117 Solution ht = 118.90 cm Water ht = 136.8 cm
 system just critical

Drain solution to ~ 105 cm end installed
 thermocouple #3 + 4

Solution temp ° C	H ₂ O Temp ° C
#3 = 26.5°	#1 = 27.7°
#4 = 26.5°	#2 = 28.0°

Drain solution after taken sample #9
 from vessel.

Sample # 9

Y-12 Rep # 699411

X-10 Rep # A-5498

1 - g 4g = .422460

1 - g 4g = .422

2 - sp. gr = 1.9248

2 - sp. gr = 1.9257

3 - density 1.9187

3 - density 1.9229

4 - Temp ° 25°C. = 912.98742

4 - Temp 21.0°C

E = 214.3 g

E = 203.3 g 812.64

T = 19.5 g

T = 19.5 g

N = 199.8 g.

N = 183.8 g

avg 812.81

1.9228

1500

added 10 l of H₂O to system:

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE No.	SET	START-UP RANGE
K-1	3x10 ⁻⁰²	Meter -	9"	-	3x10 ⁻⁰²
"	"	F -	1"	-	"
K-2		Fast			
	700V	Alarm ✓	cont	-	500V
	1200V	Low ✓	14"	-	900V
"	"	Alarm ✓	2"	-	"

LOG IN CALIBRATE OPERATE SOURCE No. B-80
 DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by F.I.C. Personnel check by F.I.C.
 Instruments and safeties checked and reset by A.K.L.
 Source in checked by A.K.L. Source No. M-93
 Emergency equipment in control room checked by F.I.C.
 Instruments in trip circuit: K-11 PC-1-2
 Red light on by A.K.L. Time 0905
 Start-up OK'd by F.I.C. A.K.L. Date 6-11-71

0905 continued nixing:

1010 solution ht = 122.2 cm; dumped solution to continued nixing:

solution ht = 95.0 cm. solution temp ° #3 = 27.5°
#4 = 27.5°. Remained thermocouple #3 & 4
from used. H₂O temp ° #1 = 27.6 #2 = 28°
o.l. = 9 cm

solution ht = 123.25 cm Water ht = 235.1 cm
+ Pes height = 10.0 cm
E = 67.9 mm = 13.3% = 16.6% em

1919 solution ht = 122.95 cm ^{H₂O = 115.45} Water ht = 235.10 cm

System just critical
Drain solution to 100.0 cm and installed thermo-
macouple #3 & 4 in used.

solution temp °	H ₂ O temp °
3 = 27.5°	1 = 27.6°
4 = 27.5°	2 = 29.0°

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Alarm ✓	4"	✓	3×10^{-12}
"	"	✓	1"	✓	"
K-2					
P-1					
P-2					
PM-1	700V	Alarm ✓	15"	✓	500V
PM-2	1200V	Low	18"	✓	900V
"	"	Alarm	2"	✓	"
LOG-N CALIBRATE		✓	OPERATE	✓	SOURCE No. B-80
DUMP WELL PROBE LIGHT		✓			

START-UP CHECK LIST

Equipment checked by ^{F.V.C.} A.K.M. Personnel check by F.V.C.

Instruments and safeties checked and reset by A.K.M.

Source in checked by A.K.M. Source No. 19-43

Emergency equipment in control room checked by F.V.C.

Instruments in trip circuits: K-1 - P-1-1-2

Red light on by A.K.M. Time 0900

Start-up OK'd by F.V.C., A.K.M. Date 6-19-71

solution ht = 98.0 cm, solution temp #3 = 25.5°
 #4 = 25.6°. Removed thermocouples #3 + 4 from
 vessel. H₂O temp ° #1 = 27.0° #2 = 27.5°

$\sigma = 1.7 \text{ mm}$
 solution ht = 122.90 cm Water ht = 235.1 cm
 + per slope = 10.0 cm
 $\sigma = 89.1 \text{ cm} = 10.8 \text{ ft} = 15.4 \text{ ft/cm}$

1032 solution ht = 122.20 cm Water ht = 235.1 cm
 system just critical
 Drain.

Repeat of above:

$\sigma = 1.5 \text{ ft}$
 solution ht = 122.90 cm Water ht = 235.1 cm
 + per slope = 9.8 cm
 $\sigma = 97.9 \text{ cm} = 10.0 \text{ ft} = 20.0 \text{ ft/cm}$ H₂O = 15.4

solution ht = 122.90 cm Water ht = 235.1 cm
 system just critical

1400 solution ht = 122.95 cm Water ht = 140.6 cm
 system just critical
 Drain solution to 103 cm and installed
 thermocouples #3 + 4.

solution temp ° H₂O temp °
 #3 = 27.1° #1 = 27.2°
 #4 = 27.5° #2 = 27.5°

over.

Solution sample #10 Taken from record.

Y-12 Rep # 694412

X-10 Rep # 5495

1. $\rho_{4g} = .415049$

1. $\rho_{4g} = .416$

2. $\rho_{1g} = 1.896$

2. $\rho_{1g} = 1.8987$

3. Density = 1.890 786.93

3. Density = 1.8946 785.95

4. Temp $^{\circ}C = 25^{\circ}$

4. Temp $^{\circ}C = 20^{\circ}$

$G = 200.12$

$G = 211.0 g$

$T = 19.4$ Avg 786.35

$T = 19.5$

$N = 180.7$

$N = 191.5$

Resample of sample #6 page 72.

Y-12 Rep # 694413

X-10 Rep # 5496

1. $\rho_{4g} = .434470$

1. $\rho_{4g} = .435$

2. $\rho_{1g} = 1.968$ 857.64

2. $\rho_{1g} = 1.9782$ 860.52

3. Density = 1.968

3. Density = 1.9740

4. Temp $^{\circ}C = 25^{\circ}$

4. Temp = 20 $^{\circ}$

$G = 204.7g$ Avg (2)

$G = 205.1g$

$T = 19.0$ 856.5

$T = 19.5$

$N = 185.7$ Avg (4) 1.9712

$N = 185.6$

Resample of sample #7 page 75

Y-12 Rep # 694414

X-10 Rep # 5497

1. $\rho_{4g} = .446134$

1. $\rho_{4g} = .447$ 907.77

2. $\rho_{1g} = 2.028$ 904.70

2. $\rho_{1g} = 2.0308$

3. Density = 2.022

3. Density = 2.0264

4. Temp $^{\circ}C = 25^{\circ}$ Avg (4)

4. Temp $^{\circ}C = 20^{\circ}$

$G = 219.1$ Avg (4)

$G = 219.5g$

$T = 19.5$ 902.43

$T = 19.5$

$N = 199.6$

$N = 199.0$

6/14/71 added 10L of H₂O to system.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter <input checked="" type="checkbox"/>	4"	<input checked="" type="checkbox"/>	3×10^{-12}
		Fast <input checked="" type="checkbox"/>	1"	<input checked="" type="checkbox"/>	"
K-2		Meter			
		Fast			
R-1					
R-2					
PM-1	700V	Alarm <input checked="" type="checkbox"/>	cont	<input checked="" type="checkbox"/>	500V
PM-2	1200V	Low <input checked="" type="checkbox"/>	12"	<input checked="" type="checkbox"/>	900V
"	"	Alarm <input checked="" type="checkbox"/>	1"	<input checked="" type="checkbox"/>	"
LOG N CALIBRATE <input checked="" type="checkbox"/>		OPERATE <input checked="" type="checkbox"/>		SOURCE No. B-80	
DUMP WELL PROBE LIGHT <input checked="" type="checkbox"/>					

START-UP CHECK LIST

Equipment checked by FID.C Personnel check by FID.C

Instruments and safeties checked and reset by AKK

Source in checked by AKK Source No. M-23

Emergency equipment in control room checked by FID.C

Instruments in trip circuit: K-1 PM-1-2

Red light on by AKK Time 1220

Start-up OK'd by FID.C, AKK Date 6-15-71

Solution ht = 100 cm. Solution Temp ° #3 = 27.7°
 #4 = 28.0°. Removed thermocouples #3 & 4 from
 vessel. H₂O Temp ° #1 = 27.2° #2 = 27.5°

Solution ht = 132.3 cm ^{Δh = 1.4 cm} Water ht = 235.1 cm
 + Per slope = 9.8 cm

$$S = 115.1 \text{ cm} = 88\phi = 6.3\phi/\text{cm}$$

1953 Solution ht = 130.9 cm ^{h₀ = 123.9} Water ht = 235.1 cm

System just critical

Drain solution to ~ 105 cm and installed
 thermocouples #3 & 4 in vessel.

Solution Temp °

$$\#3 = 28.0^\circ$$

$$\#4 = 28.1^\circ$$

H₂O Temp °

$$\#1 = 27.5^\circ$$

$$\#2 = 27.6^\circ$$

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter ✓	9"	✓	3×10^{-12}
	"	Fast ✓	1"	✓	"
K-2		Meter			
R-1					
R-2					
PM	700V	Alarm ✓	cont	✓	500V
PM	1200V	Low ✓	14"	✓	900V
		Alarm ✓	1"	✓	"

LOG N CALIBRATE ✓ OPERATE ✓ SOURCE No. B-80
 DUMP WELL PROBE LIGHT ✓

START-UP CHECK LIST

Equipment checked by F.I.D.C. Personnel check by F.I.D.C.
~~A.K.R.~~
 Instruments and safeties checked and reset by A.K.R.
 Source in checked by A.K.R. Source No. M-93
 Emergency equipment in control room checked by F.I.D.C.
 Instruments in trip circuit: K-1 PM-1-2
 Red light on by A.K.R. Time 0855
 Start-up OK'd by F.I.D.C. A.K.R. Date 6-16-71

Solution ht = 97.0 cm. Solution temp ° #3 = 27.2°
 #4 = 26.5°. Removed thermocouples #3 & 4 from
 vessel. H₂O temp ° #1 = 27.5° #2 = 27.8°

Solution ht = 131.75 cm ^{Δh = 2.75 cm} Water ht = 235.1 cm
 + Per slope = 9.8 cm
 C = 80.4 m = 11.7 ft = 4.2 ft/m

1030 Solution ht = 129.0 cm Water ht = 235.1 cm

System just initiated

Drain solution to ~ 104 cm and installed
 thermocouples #3 & 4 in vessel.

Solution Temp °	H ₂ O Temp °
#3 = 27.2°	#1 = 27.5°
#4 = 27.0°	#2 = 27.8°

1300 Drain H₂O: Purpose is to check thermocouples
 #1, 2, 3, 4, to see if they are responding to
 changes in temperature.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter -	2"	✓	3×10^{-12}
	"	Fast ✓	1"	✓	"
K-2		Meter			
		Fast			
R-1					
R-2					
PM-1	700V	Alarm ✓	cont	✓	500V
PM-2	1800V	Low ✓	14"	✓	900V
	"	Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. B-80
 DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by F.P.C. Personnel check by F.P.C.
 Instruments and safeties checked and reset by AKN
 Source is checked by AKN Source No. M-93
 Emergency equipment in control room checked by F.P.C.
 Instruments in trip circuit: K-1 PM-1-2
 Red light on by AKN Time 0855
 Start-up OK'd by F.P.C., AKN Date 6-17-71

Repeat of last run see p-92.

Solution ht = 97.0 cm solution temp ° #3 = 25.5
 #4 = 25.7° Remained thermocouples #3 & 4 from
 vessel. H₂O temp ° #1 = 27.0° #2 = 27.5°

Δh = 2.1 cm

Solution ht = 131.75 cm Water ht = 235.10 cm
 't per head = 10.00 cm
 5 = 6.5, 2 in = 13.6 ft = 6.54 ft cm.

1017 Solution ht = 129.65 cm Water ht = 235.10 cm

System just critical

Drain solution to 106 cm and installed
 thermocouples #3 & 4 in vessel.

Solution temp °	H ₂ O temp °
#3 = 25.8°	#1 = 27.0°
4 = 26.0°	2 = 27.1°

INSTRUMENT

INSTRUMENT	RANGE	TRIP	SOURCE	SET	START-UP RANGE
K-1	3×10^{-12}	Motor <input checked="" type="checkbox"/>	4"	<input checked="" type="checkbox"/>	3×10^{-12}
	"	Fast <input checked="" type="checkbox"/>	1"	<input checked="" type="checkbox"/>	"
K-2		Motor			
		Fast			
R-1					
R-2					
PM-1	700V	Alarm <input checked="" type="checkbox"/>	cont	<input checked="" type="checkbox"/>	500V
PM-2	1200V	Low <input checked="" type="checkbox"/>	18"	<input checked="" type="checkbox"/>	800V
	"	Alarm <input checked="" type="checkbox"/>	1"	<input checked="" type="checkbox"/>	"
LOG N CALIBRATE <input checked="" type="checkbox"/>		OPERATE <input checked="" type="checkbox"/>		SOURCE No. B-80	
DUMP WELL PROBE LIGHT <input checked="" type="checkbox"/>					

START-UP CHECK LIST

Equipment checked by I.D.C. Personnel check by F.D.S.
 Instruments and safeties checked and reset by A.K.W.
 Source in checked by A.K.W. Source No. M-43
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1 - PM-1-2
 Red light on by A.K.W. Time 0907
 Start-up OK'd by I.D.C. A.K.W. Date 6-18-71

Repeat of last run 1-99.

Solution h₅ = 99 cm, Solution Temp ° #3 = 25.2°

#4 = 25.5°. Remained Thermocouples #3 & 4

from vessel. H₂O Temp ° = #1 = 26.9° #2 = 27.2°

$$\Delta h = 1.35 \text{ ft}$$

Solution h₅ = 131.0 cm

Water h₅ = 235.1 cm

+ Per

h₅ = 10.0 cm

$$h = 109.3 \text{ cm} = 9.5 \text{ ft} = \nabla$$

0955 Solution h₅ = 129.65 cm Water h₅ = 235.1

System just critical

1008 Solution h₅ = 130.15 cm Water h₅ = 147.8 cm

System just critical

Drain solution to 106 cm and installed

Thermocouples #3 & 4 in vessel.

Solution Temp °

H₂O Temp °

$$\#3 = 26.0^\circ$$

$$\#1 = 26.7^\circ$$

$$\#4 = 26.0^\circ$$

$$\#2 = 27.0^\circ$$

Solution sample #11 taken from vessel.

Calculation sample #11

Y-12 Reg # 692415

N-10 Reg # A-5498

1. $g/g = 1.408500$

1. $g/g = 1.408$ 765.00

2. $sp. gr = 1.869$ 763.45

2. $sp. gr = 1.8750$

3. density 1.864

3. density $= 1.8676$

4. Temp $^{\circ}C = 25^{\circ}$

4. Temp $^{\circ}C = 20.5^{\circ}$

$\sigma = 187.1g$ by 764.24g = 188.0g

$T = 18.7$ 1.8658 $T = 19.6$

$N = 168.4$

$N = 168.4$

1245 added 10 l H_2O to system.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE	SET	START-UP RANGE
K-1	3 x 10 ⁻²	Meter ✓	4"	✓	3 x 10 ⁻²
"	"	Fast ✓	1"	✓	"
K-2					
R-1					
R-2					
PM-1	700V	Alarm ✓	cont ✓	✓	500V
PM-2	1200V	Low ✓	10"	✓	900V
"	"	Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. 13-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by E.D.C. Personnel check by E.D.C.

Instruments and safeties checked and reset by A.K.A.

Source in checked by A.K.A. Source No. M-43

Emergency equipment in control room checked by E.D.C.

Instruments in trip circuit: K-1 PM-1-2

Red light on by A.K.A. Time 0855

Start-up OK'd by E.D.C., A.K.A. Date 6-21-76

solution wt = 100 gm, solution temp $^{\circ}\text{C}$ $T_3 = 25^{\circ}$
 $T_4 = 25.1^{\circ}$. Remained thermocouples T_3 & T_4
 from vessel, H_2O temp $^{\circ}\text{C}$ $T_1 = 26.2^{\circ}$ $T_2 = 26.6^{\circ}$

1120 solution wt = 217.1 gm Water wt = 235.1 gm
 system sub critical height = 10.0 cm
 Drain.

added ≈ 1.0 l of 576.6 g/l solution to
 vessel.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE RANGE	SET	START-UP RANGE
K-1	3x10 ⁻¹²	Meter ✓	8"	✓	3x10 ⁻¹²
"	"	Fast ✓	1"	✓	"
K-2		Meter			
		Fast			
R-1					
R-2					
PM-1	700V	Alarm ✓	cont ✓	✓	500V
PM-2	1200V	Low ✓	12" ✓	✓	900V
"	"	Alarm ✓	1" ✓	✓	"
LOG N CALIBRATE		✓	OPERATE	✓	SOURCE No. B-80
DUMP WELL PROBE LIGHT		✓			

START-UP CHECK LIST

Equipment checked by ^{EUC} ~~AKK~~ Personnel check by FIDC

Instruments and safeties checked and reset by AKK

Source in checked by AKK Source No. M-43

Emergency equipment in control room checked by FIDC

Instruments in trip circuit: K-1 PM-1-2

Red light on by AKK Time 0900

Start-up OK'd by FIDC, AKK Date 6-22-76

solution ht = 100 cm, solution temp ° #3 = 25.5°
 #4 = 25.5°, removed thermometer #3 & 4
 from vessel. H₂O temp ° #1 = 26.5° #2 = 26.6°

1107 solution ht = 217.1 cm water ht = 235.1 cm
 system sub critical h_{cap} = 10.0 cm
 Drain.

1230 added ~ 1.0 l of ~906 g/l solution to vessel.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE	SET	START-UP RANGE
K-1	3x10 ⁻¹²	Meter	4"	✓	3x10 ⁻¹²
	"		1"	✓	"
K-2		Meter			
		Fast			
R-1					
R-2					
PM-1	700V	Alarm	lent	✓	500V
PM-2	1200V	Low	12"	✓	900V
	"	Alarm	12"	✓	"
LOG. N. CALIBRATE		✓	OPERATE		✓
DUMP WELL PROBE LIGHT		✓	SOURCE No.		B-80

START-UP CHECK LIST

Equipment checked by FID.C Personnel check by AKM

Instruments and safeties checked and reset by AKM

Source in checked by AKM Source No. M-83

Emergency equipment in control room checked by FID.C

Instruments in trip circuit: K-1 PM-1-2

Red light on by AKM Time 0955

Start-up OK'd by FID.C. AKM Date 6-23-71

Solution ht = 100 cm. Solution Temp^o # 3 = 25.7^o
4 = 25.5^o. Removed thermocouples # 3 + 4 from
well. H₂O Temp^o # 1 = 26.5^o. # 2 = 26.5^o.

1035 Solution ht = 215.2 cm Water ht = 235.1 cm
System sub critical
Drain.

Added 2 L of ~90% H₂O solution to well.

104

INSTRUMENT	RANGE	TRIP	SOURCE	SET	START-UP RANGE
K-1	3x10 ⁻¹²	✓	4"	✓	3x10 ⁻¹²
"	"	✓	11"	✓	"
K-2					
R-1					
R-2					
PM-1	700v	✓	18"	✓	500v
PM-2	1200v	✓	14"	✓	900v
"	"	✓	11"	✓	"
LOG IN CALIBRATE		✓	OPERATE		✓
SOURCE No.					D-80
DUMP WELL PROBE LIGHT					

START-UP CHECK LIST

Equipment checked by F.D.C. / A.M.W. Post-check by F.D.C.

Instruments and cables in start up checked by A.K.M.

Source in checked by A.K.M. Set of No. M-43

Emergency equipment in case of rock checked by F.D.C.

Instruments in trip checked: M-1 - PM-1-2

Red light on by A.K.M. Time 0905

Start-up OK'd by F.D.C. A.K.M. Date 6-29-71

solution ht = 101 cm, solution temp °C #3 = 25.5°
 #4 = 25.5°. Removed thermocouples #3 & 4 from
 vessel. H₂O Temp °C #1 = 26.0°, #2 = 26.2°

1040 solution ht = 217.4 cm water ht = 235.1 cm
 system sub critical
 Drain.

1100 added 2 L of 906 % solution to vessel.

1400 solution ht = 217.2 cm water ht = 235.1 cm

1430 added 2 L of 906 % solution to vessel.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	3x10 ⁻¹²
"	"	Foot ✓	1"	✓	"
K-2		Meter			
		Foot			
R-1					
R-2					
PM-1	700V	Alarm ✓	.5"	✓	500V
PM-2	1200V	Low ✓	14"	✓	900V
	1'	Alarm ✓	1"	✓	"
LOG N CALIBRATE		✓	OPERATE	✓	SOURCE No. B-80
DUMP WELL PROB LIGHT		✓			

14

START-UP CHECK LIST

Equipment checked by F.D.C. Personnel check by F.D.C.
 Instruments and safeties checked and reset by AKM
 Source in checked by AKM Source No. 14-43
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1 PM-1-2
 Red light on by AKM Time 0905
 Start-up OK'd by F.D.C. AKM Date 6-25-71

Solution = 100 cm. Solution Temp °C #3 = 25.0°
 #4 = 25.2°. Remained thermocouples #3 & 4
 from vessel. H₂O temp °C #1 = 26.0° #2 = 26.2°

1028 Solution ht = 217.1 cm Water ht = 235.1 cm
 System super critical. h_{gap} = 9.8 cm
 Drain and continued refilling.

Solution ht = 217.1 cm Water ht = 235.1 cm
 - Per h_{gap} = 9.8 cm
 $\epsilon = -820 \text{ mm} = 1.5\%$

1483 Drain.

Solution Temp °C	H ₂ O Temp °C
#3 = 27.1°	#1 = 26.0°
#4 = 27.2°	#2 = 26.2°

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter ✓	4"	✓	3×10^{-12}
"	"	Fast ✓	10"	✓	"
K-2		Meter			
		Fast			
P-1					
P-2					
PM-1	7000	Alarm ✓	cont	✓	5000
PM-2	12000	Low ✓	14"	✓	9000
		Alarm ✓	1"	✓	"

LOG IN CALIBRATE OPERATE SOURCE No. B-20
 DUMP WELL PROCBE LIGHT

START-UP CHECK LIST

Equipment checked by FIDOC Personnel check by FIDOC
 Instruments and safeties checked and reset by ARKM
 Source in checked by ARKM SOURCE No. R-93
 Emergency equipment in control room checked by FIDOC
 Instruments in trip circuit: K-1 PM-1-2
 Red light on by ARKM Time 0905
 Start-up OK'd by FIDOC ARKM Date 6-28-76

Solution ht = 102.0 cm Solution Temp ° #3 = 29.5°
 #4 = 29.7°. Removed thermocouples #3 & 4 from
 vessel. H₂O Temp ° #1 = 26.0° #2 = 26.2°

$$0.2 = 60.05 \text{ cm}$$

Solution ht = 217.1 cm Water ht = 235.1 cm
 + Per Slope = 9.8 cm

$$C = 291.2 \mu = 9.0 \text{ } \mu = .07 \text{ } \mu \text{ / cm.}$$

1020 Solution ht = 157.05 cm Water ht = 235.1 cm
 System just critical

1-3

1040 Solution ht = 157.05 Water ht = 174.9 cm
 System just critical
 Drain solution to 106.7 cm and installed
 thermocouples #3 & 4 in vessel.

Solution Temp °

H₂O Temp °

#3 = 25.5°

#1 = 26.0°

4 = 25.7°

2 = 26.5°

Solution sample #12 taken from vessel.

over

Sample #12

Y-12 Rep #

~~6~~ 694416

1. g/g = 402656

2. sp. gr. = 1.847

3. density = 1.842

4. Temp °C = 25°C = 743.7 g/l

G = 202.9 g

T = 19.2

W = 183.7

X-10 Rep #

A-5499

1. g/g = 14039

2. sp. gr. = 1.8474 46.16

3. density = 1.8451

4. Temp °C = 20°C

G = 194.2 g

T = 19.0

W = 175.2

Drain the 746 g/g and added ~ 275 l of 857 g/l to manifold.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3x10 ⁻¹²	Alarm ✓	4"	✓	3x10 ⁻¹²
"	"	✓	1"	✓	"
K-2					
R-1					
R-2					
PM-1	700v	Alarm ✓	cont	✓	500v
PM-2	1200v	Low ✓	14"	✓	800v
"	"	Alarm ✓	1"	✓	"
LOG N CALIBRATE		OPERATE	SOURCE No.	10-80	
DUMP WELL PROBE LIGHT		✓			

START-UP CHECK LIST

Equipment checked by ^{E.I.C.} AKK Personnel check by F.I.C.

Instruments and safeties checked and reset by AKK

Source in checked by AKK Source No. M-93

Emergency equipment in control room checked by F.I.C.

Instruments in trip circuit: K-1 PM-1-2

Red light on by AKK Time 0905

Start-up OK'd by F.I.C. AKK Date 6-30-71

solution ht = 94 cm. solution temp ° #3 = 25.6°
 #4 = 24.9°. Remained thermocouples #3 & 4
 from vessel. H₂O temp ° #1 = 26.1° #2 = 26.2°.

Δz = 1.25 cm

solution ht = 115.05 cm. water ht = 735.1 cm
 + P_{at} slope = 9.8 cm

$$C = 180.4 \text{ m} = 6.04 = 244/\text{cm}$$

1022 solution ht = ~~114.8~~ ^{114.8} cm water ht = 235.1 cm
 system just critical

10.00 solution ht = 116.0 cm water ht = 133.90 cm
 system just critical

Drain solution to 104 cm and installed
 thermocouples #3 & 4 in vessel.

solution temp ° H₂O temp °

$$\#3 = 26.0^\circ$$

$$\#1 = 26.2^\circ$$

$$\#4 = 25.4^\circ$$

$$\#2 = 26.5^\circ$$

solution sample #13 taken from vessel.

Sample # 13

Y-12 Rep # 694417

X-10 rep # A-5500

1. $\rho_{4g} = 1.433760$

1. $\rho_{4g} = 1.4334$

2. $\rho_{sp. gr.} = 1.971$ 854.54

2. $\rho_{sp. gr.} = 1.9727$

3. density = 1.965

3. density = 1.9683

4. temp $^{\circ}C = 25^{\circ}C$

4. temp $^{\circ}C = 20^{\circ}C$

G = 199.7 g C_{org} 854.55 G = 198.0 g = 854.9 g 4L

T = 19.1 1.5667 T = 18.9

N = 180.6

N = 179.1

7-1-71 Drain the 858 g 4L and added ~ 275 L of 906 g 4L.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE RANGE	SET	START-UP RANGE
K-1	3 x 10 ⁻¹²	Meter ✓	4"	✓	3 x 10 ⁻¹²
	"	Fast ✓	1"	✓	"
K-		Meter			
		Fast			
P-1					
PM-1	700 V	Alarm ✓	ext ✓	✓	500 V
PM-2	1200 V	Low ✓	14" ✓	✓	900 V
	"	Alarm ✓	1" ✓	✓	"
LOG N CALIBRATE		✓	OPERATE	✓	SOURCE No. B-80
DUMP WELL PROBE LIGHT		✓			

START-UP CHECK LIST

Equipment checked by ^{L.P.C.} ARKL Personnel check by E.P.C.

Instruments and safeties checked and reset by ARKL

Source in checked by ARKL Source No. M-43

Emergency equipment in control room checked by F.I.R.D.

Instruments in trip circuit: K-1 PM-1-2

Red light on by ARKL Time 0910

Start-up OK'd by F.I.D.C. ARKL Date 7-13-71

Solution ht = 90 cm. Solution Temp ° #3 = 24.5°
 #4 = 24.2°. Removed thermocouples #3 & 4
 from well. H₂O temp ° #1 = 25.7° #2 = 25.7°

Δ = 1.15 cm

Solution ht = 111.60 cm Water ht = 235.1 cm
 + Per slope = 9.8 cm

$\tau = 117.3 \mu = 8.7 \text{ f} = 584 \text{ /cm}$

1000 Solution ht = 111.45 cm Water ht = 235.1 cm
 system just critical

Δ = 2.0 cm

Solution ht = 111.65 cm Water ht = 235.1 cm
 27 Per

$\tau = 71.7 \mu = 12.7 \text{ f} = 63.5 \text{ /cm}$

1100 Solution ht = 111.45 cm Water ht = 235.1 cm
 system just critical

H_c = 135.7

1123 Solution ht = 112.70 cm Water ht = 130.4 cm
 system just critical

Drain: installed thermocouples #3 & 4

Solution temp °

H₂O temp °

#3 = 25.2°

#1 = 25.0°

#4 = 25.0°

#2 = 25.0°

7/20/78

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3 X 10 ⁻¹²	Meter ✓	3"	✓	3 X 10 ⁻¹²
	"	Fast ✓	1"	✓	"
K-2		Meter			
		Fast			
R-1					
R-2					
PM-1	700V	Alarm ✓	low ✓	✓	500V
PM-2	1200	Low ✓	10" ✓	✓	900V
	"	Alarm ✓	1" ✓	✓	"

LOG N CALIBRATE OPERATE SOURCE No. B-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by I.P.C. Personnel check by F.P.C.

Instruments and safeties checked and reset by A.K.H.

Source in checked by A.K.H. Source No. M-43

Emergency equipment in control room checked by I.P.C.

Instruments in trip circuit: K-1 PM-1-2

Red light on by A.K.H. Time 0825

Start-up OK'd by F.P.C., A.K.H. Date 7-15-71

solution ht = 92 cm. solution temp #3 = 24.0°
#4 = 23.7°. Removed thermocouples #3 & 4 from
vessel, H₂O temp #1 = 24.2° #2 = 24.5°.

10:00 solution ht = 182.90 cm Water ht = 100.6 cm
system sub critical
Water ht is at bottom of crown intersection.

10:10 solution ht = 182.90 cm Water ht = 102.9 cm
system sub critical
Water ht is at bottom of crown at the
end of crown.

10:25 solution ht = 182.90 cm Water ht = ^{110.4 cm} 107.3 cm
system just critical.
Drain installed thermocouples #3 & 4 in
vessel.

sol temp °	H ₂ O temp
#3 = 24.7°	#1 = 24.2°
#4 = 25.0°	#2 = 24.5°

solution sample to #14 taken from
vessel.

over

Sample # 14.

Y-12 Reg # 694418

X-10 = A5451

1-g/g = .446200

1-g/g = .447

2-hp. gr = 2.026

2-hp. gr. = 2.0283

3-density = 2.020

3-density = 2.0255

4-temp °C 53.33

4-temp °C = 19.5°

G = 202.4g

G = 193.3g

906.63g

T = 20.0g

T = 19.2g

N = 182.4g.

N = 174.1g

Reptector water from Big lid hold
tanks. sample taken:

Y-12 Reg # 694419

wt for

g/g = .00000665