

BOOK99R

Notes:

"U(4.9) rads #5" on spine

Blank pages: page opposite page 1, 1, 292-308, inside back cover sheets

-3 half sheets between front cover sheets

-the following pages each have 1 sticker and 1 drawing on each page: 4, 5, 6, 8, 29, 43, 44, 54, 56, 59, 61, 66, & 72

-pages 15/16, 33/34, 141/142, each have a paper clip at the top

-page 21 has small piece of paper - paper clipped at the top

-pages 52/53, 58/59, 72/73, 80/81 each have a small blank piece of paper between pages

-the following pages have 1 small drawing attached to each page: 90, 93, 149, 152, 154, 157, 159, 163, 166, 169, 171, 173, 174, 179, 183, 185, 186, 189, 191, 194, 195, 198, 199, 201, 202, 206, 207, 209, 212, 213, 215, 217, 223, 224, 227, 232, 235, 237, 242, 243, 246, 248, 250, 252, 254, 256, 259, 263, 266, 268, 270, 273, 275, 277, 278, 280, 282, 283, 285, 286, 288, 290, 291

-the following pages have (#) small drawings attached to that page: 83(2), 84(2), 86(4), 88(2), 89(3), 92(2), 95(2), 96(3), 97(3), 98(2), 100(3), 101(2), 103(2), 104(2), 105(2), 155(3), 176(2), 178(2), 219(3), 220(2), 229(3)

-pages 142 and 146 have 3 pieces of paper taped to each page

-pages 190/191 have 1 keypunch computer card between pages

Scanned by:

Sheila Finch

RSICC /Oak Ridge National Lab.

September 10, 1999

14-2-1



Account Book

No. S 149

NO UNITS

Journal

Ledger, Single Entry . .

Ledger, Double Entry .

Record Ruled (27 Lines)

Made in 150, and 300 Pages

MADE IN U. S. A.

TO REORDER, SPECIFY NUMBER,
RULING AND THICKNESS INDICATED
ON BACKBONE OF THIS BOOK.

↓ 1.30 sep

Pb backed by SS

Pb wall, Cd sheet sup in lattice 173

4 rods

2x2 clusters 173

4-rod B

9 rod clusters + Cd sheet in lat. 174

" + Boral " " " 176

+ " + 1 row vacant 178

Pb 4 side, Boral 1 side, 179

" "wall" Boral thru 4-rod-cluster lattice 183

" Cd & Boral thru regular lattice

Depleted U, 1 face 191

9-rod clusters 194

4 " " 195

2-rod rows vacant, 2 dia. 198

3-rod rows " " 199

4-rod clusters, SS plate ~~200~~ 201

9 " " " 202

Depl U + SS, 1 face 206

9-rod clusters 207

4 " " 209

Depl U spaced from lattice 212

4 clusters 215

Assorted clusters 220

↓ 2.05 sep.

Log #5 (cont)

0.3 rods in Hat

2.05 cm sep

4 clusters, 1 row sup 92

" " " " 95

5 " " " " 96

4 " " " " 101

1.3 cm sep.

4 clusters, ~~2~~ 2+3 row sup. 103

2 valves, 3 row sup. 103

64 4-rod clusters, 1 row sup. 104

Support rebuilt to support Pb

↳ Pb 107

8x10x16" Pb - one face 109

Trouble

Pb + Silastic 731 RTV (1 face) 135

Pb - 2 faces 135

Pb - 4 faces (diaphragms) 142

4-cluster, 1 row sup, 4-face Pb 149

2 row sup 152

3 " " 154

5x5 clusters, 1 row sup 155

5x5 " + "odd" rods, 1 row sup. 157

↳ lattice of 9-rod

4-rod clusters, 1 row sup -- 159

" " " + SS, 1 face 160



Log #5

2/2/70

0.2 g B/E

0.5" rods, 3.4 cm sep. 2

(2/18/70 = p.14)

(3/7/72) p.15

U²³⁵ or F₂ salt in 36" (nom) diam. tank 16

0.3" rods in salt (attack) 20

Rods in shrinkable poly olefin tubing, new fid sheaths 23

0.3 rods in salt 2.050 sep. 23

Plaxiflex top reflector - variable T 43-57

0.3", 2.453 cm sep ("4" sep fid?) 53

2.9 " " " " 58

0.5 rods 2.59 cm 61

3.40 65

3.94 68

0.3 rods 3.25 cm sep 75

2.5 " 4.4 " " 78

In Hat in Nell (beginning of "cluster" lattice)

0.3 rods, 1.300 cm 82

4 clusters, 1 row sup 83

4 " " " sep 88

9 " " " 1 row sup 90

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	Size described	SET	STARTUP RANGE
K-1	3 X 10 ⁻¹²	Micro ✓	2"	✓	3 X 10 ⁻¹²
"	"	Foot ✓	1"	✓	"
K-2	"	M ✓	2"	✓	"
"	"	Foot ✓	1"	✓	"
R-1					
R-2					
PM-1	700V	✓	.5"	✓	500V
PM-2	1200V	✓	10"	✓	900V
"	"	Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. B-80

DUMP WELL PRESS LIGHT

START-UP CHECK LIST

Equipment checked by F.O.C. Personnel check by F.P.C.
 Instruments and safeties checked and reset by A.K.V.
 Source in checked by A.K.V. Source No. M-43
 Emergency equip. checked and reset checked by F.O.C.
 Instruments to trip checked: K-1-2 PM-1-2
 Red light on by A.K.V. Time 0805
 Start-up OK'd by F.O.C. A.K.V. Date 2-2-70

.50" Rod.
 30 cm length.
 Rounded array's.
 Separation

Repeat of last experiment described on page 305. Log Book # 3

Have an 14 X 14 array, with 22 rods removed from each corner. Total of 108 rods.

Water ht = 27.90 cm

Temp °C
 24.5 °C

$t = 1195.15 \mu = 1.04$

0903

Water ht = 23.90 cm
 System just critical
 Drain.

Now have an 11 X 11 array, with 4 rods removed from each corner. Total of 105 rods.

0955

Water ht = 27.80 cm
 System sub critical
 Drain.

Temp °C
 24.7 °C

over

Added 2 rods, 1 each, to opposite corners. Now have an 11x11 array, with 3 rods removed from 2 corners and 9 rods removed from 2 corners. Total of 107 rods.

Water ht = 22.50 cm
3-Per

Temp °C
24.7°C

$C = 60.84 \text{ sec} = 14.3 \text{ f}$


1014 Water ht = 19.00 cm
System just critical
Drain.

Removed 1 rod. Now have an 11x11 array with 4 rods removed from 3 corners and 3 rods removed from 1 corner. Total of 106 rods.

1057 Water ht = 27.90 cm
System just critical
Drain.

Temp °C
24.8°C

2/2/70: 11x11 array with 4 rods removed from 3 corners & 3 removed from 1 corner. Total rods: 106. 0.50" rods 30 cm length. Separation 3.4 cm. C-C. p.4



Now have an 12x12 array. With 10 rods removed from 2 corners, and 9 rods removed from 2 corners. Total of 106 rods.

Water ht = 27.80 cm
3-Per

Temp °C
25.0°C

$C = -323.78 \text{ sec} = -4.6 \text{ f}$

1300 Drain:

Added 1 rod. Have now an 12x12 with 9 rods removed from 3 corners and 10 rods removed from 1 corner. Total of 107 rods.


Water ht = 20.20 cm.
4-Per

Temp °C
25.0°C

$C = 178.19 \text{ sec} = 6.2 \text{ f} = 6.5 \text{ f/cm}$

1324 Water ht = 19.25 cm
System just critical
Drain.

2/2/70: 12x12 array with 9 rods removed from 3 corners & 10 from 1 corner. Total rods: 107. 0.50" rods, 30 cm length. Separation 3.4 cm C-C p. 5



over!

Now have an 12x13 array, with 12 rods removed from 2 opposite corners, and 13 rods removed from 2 corners. Total of 106 rods.


Water ht = 27.90 cm

5-Res

$T = -295.53 \text{ m} = -5.1 \text{ f}$

1545 Drain:

2/2/70: 12x13 array with 12 rods removed from 2 opposite corners & 13 from 2 corners. Total rods: 106. 0.50" rods, 3.4cm separation C-C. 30-cm length. p.6



Temp $^{\circ}\text{C}$
25 $^{\circ}\text{C}$

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter -	2"	<input checked="" type="checkbox"/>	3×10^{-12}
"	"	Fast -	1"	<input type="checkbox"/>	"
K-2	"	Meter -	2"	<input type="checkbox"/>	"
"	"	Fast -	1"	<input type="checkbox"/>	"
R-1					
R-2					
M-1	700V	Alarm -	5"	<input type="checkbox"/>	500V
P-1	1200V	Low -	10"	<input type="checkbox"/>	900V
		Alarm -	1"	<input checked="" type="checkbox"/>	"
LOG IN CALIBRATE		<input type="checkbox"/>	OPERATE	<input checked="" type="checkbox"/>	SOURCE No. <u>B-80</u>
DUMP WELL FROGE LIGHT					

START-UP CHECK LIST

Equipment checked by F.D.C. Personnel check by R.K.B.
 Instruments and safeties checked and reset by R.K.B.
 Source in checked by R.K.B. Source No. M-93
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1-2 RM-1-2
 Red light on by R.K.B. Time 0830
 Start-up OK'd by F.D.C. R.K.B. Date 2-3-70

0.50" Rods.
30 cm length.
3.4 cm separation c-c.

Now have an 12x13 array: with 12 rods removed from 3 corners, and 13 rods removed from 1 corner. Total of 107 rods.


Water ht = 19.95 cm ^{ph = 7.5} Temp °C = 24.7 °C
+ Per

T = 202.09 sec = 5.54 = 7.24 sec

0913 Water ht = 19.20 cm.

System just critical
Drain

2/3/70: 12x13 array with 12 rods removed from 3 corners & 13 from 1 corner. Total rods: 107
0.50" rods 30 cm length
3.4 cm separation C-C
p. 8



INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3x10 ⁻¹²	Meter -	2"	-	3x10 ⁻¹²
"	"	Foot -	1"	-	"
K-2	"	Meter -	2"	-	"
"	"	Foot -	1"	-	"
R-1					
R-2					
PM-1	700V	Alarm -	5"	-	500V
PM-2	1200V	Low -	10"	-	900V
"	"	Alarm -	2"	-	"

LOG IN CALIBRATE OPERATE SOURCE No. D-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by F.D.C. A.K.V. Personnel check by F.D.C.
 Instruments and safeties checked and reset by A.K.V.
 Source in checked by A.K.V. Source No. 19-93
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by A.K.V. Time 1312
 Start-up OK'd by F.D.C. A.K.V. Date 2-18-70

.50" Rad.
30 cm length.
3.4 cm separations a-c.

Have an 12 x 12 array. 9 rods removed from
3 columns and 10 rods removed from 1 column.
Total of 107 rods.

Water ht = 21.60 cm
+ h_{er}.

Temp °C
25 °C

1412 Water ht = 19.15 cm
System just critical
Drain.

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	Meter	Fast			
K-2	Meter	Fast			
R-1					
R-2					
PM-1	Alarm				
PM-2	Low				
	Alarm				

INSTRUMENT CHECK

START-UP CHECK LIST

Equipment checked by _____ Personnel check by _____
 Instruments and safeties checked and reset by _____
 Source in checked by _____ Source No. _____
 Emergency equipment in control room checked by _____
 Instruments in trip circuit: _____
 Red light on by _____ Time _____
 Start-up OK'd by _____ Date _____

DUMP WELL PROBE LIGHT

LOG IN CALIBRATE OPERATE SOURCE No.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1		Meter			
K-2		Meter			
R-1					
R-2					
PM-1		Alarm			
PM-2		Low			
		Alarm			

LOG N CALIBRATE _____ OPERATE _____ SOURCE No. _____

DUMP WELL PROBE LIGHT _____

START-UP CHECK LIST

Equipment checked by _____ Personnel check by _____

Instruments and safeties checked and reset by _____

Source in checked by _____ Source No. _____

Emergency equipment in control room checked by _____

Instruments in trip circuit: _____

Red light on by _____ Time _____

Start-up OK'd by _____ Date _____

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter	2"		3×10^{-12}
"		Fast	1"		"
K-2	"	Meter	2"		"
"		Fast	1"		"
R-1					
R-2					
PM-1	700V	Alarm	5"		500V
PM-2	1200V	Low	10"		900V
"		Alarm	1"		"

LOG N CALIBRATE _____ OPERATE _____ SOURCE No. B-80

DUMP WELL PROBE LIGHT _____

START-UP CHECK LIST

Equipment checked by F.P.C. Personnel check by F.P.C.

Instruments and safeties checked and reset by A.K.H.

Source in checked by A.K.H. Source No. M-43

Emergency equipment in control room checked by F.P.C.

Instruments in trip circuit: R-1-2 PM-1-2

Red light on by A.K.H. Time 1930

Start-up OK'd by F.P.C. A.K.H. Date 7-19-70

4/22/72

.50 inch rods.
30 cm length.
3.4 cm separation c.c.

Have on 12 x 12 array. 9 rods removed from
3 corners. and 10 rods removed from 1
corner. Total of 107 rods.

Water ht = 21.40 cm
+ 1.2

Temp ^oC
25^oC

1541 Water ht = 19.20 cm
System just installed
& run.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3 x 10 ⁻¹²	Meter ✓	4"	✓	3 x 10 ⁻¹²
"	"	Fast ✓	4"	—	"
K-2	"	Meter ✓	3"	—	"
"	"	Fast —	1"	—	"
R-1					
R-2					
PM-1	700V	Alarm ✓	cont	—	500V
PM-2	1200V	Low ✓	8"	—	900V
"	"	Alarm ✓	1"	—	"

LOG IN CALIBRATE OPERATE SOURCE No. B-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

E.D.C.
 Equipment checked by A.K.L. Personnel check by E.D.C.
 Instruments and safeties checked and reset by A.K.L.
 Source in checked by A.K.L. Source No: M-43
 Emergency equipment in control room checked by E.D.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by A.K.L. Time 1315
 Start-up OK'd by E.D.C. A.K.L. Date 3-7-72

37.750 F.I.D X 35.750" ht. all tanks.

5% $V_{O_2}F_2$ solution and 5% metal rods.

Tanks is mounted 17.0" ~~from~~ from floor.

5% $V_{O_2}F_2$ solution: no rods. from floor to bottom of tank.

Mixing of solution:

Solution zero = 29.10 cm on scale.

1/2" Feed rate = 1.90 cm/min.

1/2" Drain rate = 2.0 cm/min.

3" Dump rate = 5.8 cm/15 sec = 23.2 cm/min.

1555 solution ht = 102.8 cm

System sub-critical
Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3X10 ⁻¹²	Meter <input type="checkbox"/>	3"	<input type="checkbox"/>	3X10 ⁻¹²
"	"	Fest <input type="checkbox"/>	1"	<input type="checkbox"/>	"
K-2	"	Meter <input checked="" type="checkbox"/>	3"	<input type="checkbox"/>	"
"	"	Fest <input type="checkbox"/>	1"	<input type="checkbox"/>	"
R-1					
R-2					
PM-1	700V	Alarm <input type="checkbox"/>	cont	<input type="checkbox"/>	500V
PM-2	1200V	Low <input type="checkbox"/>	8"	<input type="checkbox"/>	900V
"	"	Alarm <input type="checkbox"/>	1"	<input type="checkbox"/>	"

LOG IN CALIBRATE OPERATE SOURCE No. D-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by I.D.C. AXAL Personnel check by I.D.C.

Instruments and safeties checked and reset by AXAL

Source in checked by AXAL Source No. 19-93

Emergency equipment in control room checked by F.D.C.

Instruments in trip circuit: K-1-2 PM-1-2

Red light on by AXAL Time 0825

Start-up OK'd by F.D.C. AXAL Date 3-8-72

5% O_2/F_2 totalizer solution: no Prod.
 Miping of solution

Calculation h_t = 109.60 cm
 System sub critical
 Gross

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3 x 10 ⁻¹²	Meter ✓	3"	✓	3 x 10 ⁻¹²
"	"	Exp ✓	1"	✓	"
K-2	"	Meter ✓	3"	✓	"
"	"	Exp ✓	1"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	cont	✓	5000
PM-2	1200V	Low ✓	8"	✓	900V
"	"	Alarm ✓	1"	✓	"

LOG N CALIBRATE _____ OPERATE _____ SOURCE No. B-80

DUMP WELL PROBE LIGHT _____

START-UP CHECK LIST

Equipment checked by ^{F.D.C.} ARR Personnel check by FID.C.
 Instruments and safeties checked and reset by ARR
 Source in checked by ARR Source No. M-43
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by ARR Time 1945
 Start-up OK'd by F.D.C., ARR Date 3-20-72

.30" Rods.
2,050 cm separation c-c.
UO₂ F₂ solution.
30 cm length

Solution ht = 36.50 cm = bottom of rods.
Have a 12 x 12 array. Total of 144 rods.

1505 Solution ht = 65.0 cm Temp °C
System just critical 25.0 °C
Drain:

Removed 6 rods. Now have an 12 x 12 - 6 array. Total of 138 rods.

1535 Solution ht = 65.75 cm
System just critical
Drain.

Removed 6 rods. Now have an 11 x 12 array.
Total of 132 rods.

1551 Solution ht = 66.60 cm
System just critical
Drain.

3-21-72 Found that UO₂ F₂ solution had attacked UO₂ rods in grid plates. Solution sample taken:

ask for:
Sample #1.

- 1 - $\rho/\rho_0 = .220784$ $\rho = 296.42 \rho_0$
- 2 - sp. gr. = 1.3426
- 3 - density = 1.3386 (at 25°C) Density = 295.592 ρ_0
- 4 - pH = 2.568
- 5 - HF (free in solution) = ~~.052903 g/g~~ None
- 6 - F₂ or F (if present) = .032903 ρ/ρ_0
0.002363 shortage F in solution

Sample #1

- g = 169.9g
- T = 19.3g
- H = 150.6g = 33.2g

REQUISITION

694425 9
18
20

REPORT TO	<u>R. K. Reedy</u>
BUILDING NO.	<u>9213</u>
PHONE NO.	<u>35237</u>

220784		g U/g
		g Ay/g
13386	Density	g H/g
13426	Sp G	g Mo/g
		g F/g
2568	ph.	SPEC.
		ASSAY
032903	GF/g	
No. 64000		
003363	Multi	

OW	REPT. BY
4-4-72	DATE
	DEPT.

D.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3010 ⁻¹²	Meter ✓	1"	✓	3010 ⁻¹²
"	"	Fast ✓	1"	✓	"
K-2	"	Meter ✓	2"	✓	"
"	"	Fast ✓	1"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	cont	✓	500V
PM-2	1200V	Low ✓	8"	✓	900V
"	"	Alarm ✓	1"	✓	"

LOG IN CALIBRATE OPERATE SOURCE No. B-80
 DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by F.P.C. Personnel check by F.P.C.
A. K. R.
 Instruments and safeties checked and reset by A. K. R.
 Source in checked by A. K. R. Source No. M-93
 Emergency equipment in control room checked by F.P.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by A. K. R. Time 0815
 Start-up OK'd by F.P.C. A. K. R. Date 9-27-72

9-27-72 Continuing experiments with U(S) rods after cladding rods with a clear plastic, shrinkable irradiated polyolefin tubing. also made new plastic tube sheet with new dia holes for rods.

avg zero (top of Rods) . 30" Rods
 Solution ht = 66.80 cm 2.050 cm separation, a.c
 O₂ F₂ solution. 30 cm length
 Have an 11 x 11 array: total of 121 rods.
 $\Delta h = .05$

Solution ht = 68.75 cm Temp °C
 #3 = 25.0 °C
 #4 = 29.8 °C
 $\bar{v} = 113.0 \text{ cm} = 9.0 \text{ ft} = 180 \text{ ft/cm}$

1019 Solution ht = 68.70 cm
 System just critical
 Quin ~ 6.0 cm solution.
 Removed 6 rods; Now have an 11x11-6.
 115 rods, $\Delta h = .10$

Solution ht = 70.20 cm Temp °C
 #3 = 25.0 °C
 #4 = 29.8 °C
 $\bar{v} = 82.6 \text{ cm} = 11.9 \text{ ft} = 119.0 \text{ ft/cm}$

1048 Solution ht = 70.10 cm
 System just critical
 Quin ~ 6.0 cm

over!

Removed 5 rods. Now have an 10 X 11 array
Total of 110 rods.

$\Delta h = 1.30 \text{ cm}$
Solution ht = 71.70 cm Temp °C
3 + Per #3 = 25.0 °C
 $\bar{v} = 47.8 \text{ sec} = 16.9 \text{ f} = 56.3 \text{ f/cm}$ $\bar{v} = 29.8 \text{ f}$

1115 Solution ht = 71.40 cm
System just critical
Drain.

Removed 5 rods. Now have an 10 X 10 array
with 5 rods on 1 face. Total of 105 rods.

$\Delta h = 1.25$
Solution ht = 73.45 Temp °C
4 + Per #3 = 25.1 °C
 $\bar{v} = 69.5 \text{ sec} = 13.0 \text{ f} = 52.0 \text{ f/cm}$ #4 = 25.0 °C

1252 Solution ht = 73.20 cm
System just critical
Drain

Removed 5 rods. Now have an 10 X 10 array.
Total of 100 rods.

$\Delta h = 1.55 \text{ cm}$
Solution ht = 75.95 cm Temp °C
5 + Per #3 = 25.1
 $\bar{v} = 60.8 \text{ sec} = 13.0 \text{ f} = 26.0 \text{ f/cm}$ $\bar{v} = 25.0$

1300 Solution ht = 75.40 cm
System just critical
Drain.

Removed 5 rods. Now have an 10 X 10 - 5
array. Total of 95 rods.

$\Delta h = 1.80$
Solution ht = 79.90 cm Temp °C
6 + Per #3 = 25.5 °C
 $\bar{v} = 60.8 \text{ sec} = 14.3 \text{ f} = 17.9 \text{ f/cm}$ $\bar{v} = 25.5 \text{ f}$

1416 Solution ht = 79.10 cm
System just critical
Drain.

Removed 2 rods. Now have an 10 X 10 - 3
array. Total of 93 rods.

$\Delta h = 1.90$
Solution ht = 82.10 cm Temp °C
7 + Per #3 = 25.5 °C
 $\bar{v} = 71.7 \text{ sec} = 12.7 \text{ f} = 14.1 \text{ f/cm}$ $\bar{v} = 25.5 \text{ f}$

1506 Solution ht = 81.20 cm
System just critical
Drain.

over!

Removed 3 rods. Now have an 9X10 array. Total of 90 rods.

$d_4 = 1.5 \text{ cm}$
 Solution ht = 86.65 cm
 + Per

Temp
 # 3 = 25.5°C
 # 4 = 25.5°C

$t = 69.5 \text{ min} = 13.0 \text{ h} = 8.7 \text{ h}$

1555 Solution ht = ~~86.65~~ 85.15 cm
 System just critical
 Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3X10 ⁻¹²	Motor ✓	2"	✓	3X10 ⁻¹²
"	"	Fast ✓	"	✓	"
K-2	"	Motor ✓	2"	✓	"
"	"	Fast ✓	1"	✓	"
B-1					
B-2					
PM-1	700V	Alarm ✓	cont	✓	500V
PM-2	1200V	Low ✓	6"	✓	900V
"	"	Alarm ✓	cont	✓	"

LOG IN CALIBRATE OPERATE SOURCE No. B-80
 DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by T.P.C. Personnel check by E.P.C.
 Instruments and safeties checked and reset by A.K.R.
 Source in checked by A.K.R. Source No. M-43
 Emergency equipment in control room checked by T.P.C.
 Instruments in trip circuit: Z-1-2 PM-1-2
 Red light on by A.K.R. Time 0812
 Start-up OK'd by E.P.C., A.K.R. Date 4-28-72

.30" Rods.
 2.050 cm separation c-c.
 102 F₂ solution.
 30 cm length

Removed 3 rods. Now have an 9x9 array with 6 rods on 1 face. Total of 87 rods.

$\Delta L = 1.75 \text{ cm}$
 Solution ht = 92.75 cm Temp °C
 + Per #3 = 25.3
 $C = 1086 \text{ sec} = 9.2 \text{ f} = 5.3$ #4 = 25.5

1036 Solution ht = 91.00 cm
 System just critical
 Drain

Removed 3 rods. Now have an 9x9 array with 3 rods on 1 face. Total of 84 rods.

1136 Solution ht = 111.90 cm Temp °C
 - Per: N.G. #3 = 25.7°C
 Drain #4 = 25.9°C


Added 1 rod. Now have an 9x9 array with 4 rods on 1 face. Total of 85 rods.

$\Delta L = 1.7 \text{ cm}$
 Solution ht = 103.2 cm Temp °C
 + Per #3 = 26.0
 $C = 341.2 \text{ sec} = 3.5 \text{ f} = 2.1 \text{ f/cm}$ #4 = 26.0

1036 Solution @ 101.5 cm. Critical.
 Drain

K-v erratic again during drain.

4/28/72 - 9x9 array with 4 rods on 1 face. Total rods 85 .30 dia 2.050 cm sep. c-c p. 29



INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE RANGE	SET	START-UP RANGE
K-1	3 X 10 ⁻¹²	Motor ✓	2°	✓	3 X 10 ⁻¹²
"	"	Foot ✓	"	✓	"
K-2	"	Motor ✓	2°	✓	"
"	"	Foot ✓	"	✓	"
B-1					
B-2					
PA-1	700 V	Alarm ✓	Cont	✓	500 V
PA-2	1200 V	Low ✓	8"	✓	900 V
"	"	Alarm ✓	1"	✓	"

LOG IN CALIBRATE OPERATE SOURCE No. B-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by F.D.C. Personnel check by F.D.C.
RKA
 Instruments and safeties checked and reset by RKAN
 Source in checked by RKA Source No. 19-43
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by RKA Time 0810
 Start-up OK'd by F.D.C., RKA Date 5-10-72

.30" Rads
 2.050 cm separation c-c.
 O₂/F₂ solutions
 30 cm lengths

Now have an 10 X 10 - 5 array. Total of 95 nodes. Total of 95 nodes.

0949
 Solution ht = 78.95 cm
 + Per
 G = 84.7 μe = 11.2 f = 22.4 f/cm
 Solution ht = ± 78.45 cm
 System just critical
 Drain

Removed the 2 X 2 X 7/16 L support (standard steel) from bottom of array. Replaced it with 4 pc of 2.5" X 2" plexiglass tubes at each corner of 1.5" plexiglass support plate.

dh = 1.60 cm
 Solution ht = 78.50 cm
 + Per
 G = 71.7 μe = 12.7 f = 21.2 f/cm.
 Solution ht = ± 77.90 cm
 System just critical
 Drain. Removal of 2 X 2 X 7/16 L = 11.6 f

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE RANGE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter ✓	2"	✓	3×10^{-12}
"	"	Foot ✓	"	-	"
K-2	"	Meter ✓	10"	✓	"
"	"	Foot ✓	1"	✓	"
R-1					
R-2					
PM-1	700 V	Alarm ✓	Cont	✓	500 V
PM-2	1200 V	Low ✓	8"	✓	900 V
"	"	Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. 13-80
 DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by I.D.C. Personnel check by I.D.C.
 Instruments and safeties checked and reset by ARKV
 Source in checked by ARKV Source No. 19-43
 Emergency equipment in control room checked by I.D.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by ARKV Time 0805
 Start-up OK'd by I.D.C., ARKV Date 5-11-72

.30" hole
 2.050 cm aperture a.e., 30 cm length
 CO₂ F₂ solution.

Repeat of last experiment.

2.4 = .65 cm
 Solution ht = 78.55 cm Temp °C
 T Per #3 = 25.5 °C
 4 = 25.7 °C

10:00

I = 65.19 μA = 13.64 = 20.9 f/cm
 Solution ht = 77.90 cm.
 System just critical
 Drain.

Solutions sample taken

#1
 Y-12 Reg # 684631 X-10 Reg # A-5452
 G = 153.6 g G = 153.7 g
 T = 19.2 g T = 18.8 g
 H = 134.0 g = 29.8 g H = 134.9 g
 Y-12 out for. X-10
 1 - $\rho/g = 222.0$ 1 - $\rho/g = 222.3$
 2 - $\rho/g = 1.3448$ 2 - $\rho/g = 1.3448$
 3 - Density = 1.3408 3 - Density = 1.3420
 4 - Temp °C 4 - Temp °C = 20.0 °C

Waring = 298.33 g/l
 density

over:

array now raised 4.0" from bottom of tanks. Have 4 pc 2.5" x 4.0" plexiglass tubing at each corner of support plate. stainless steel support sill removed. (New zero at top of rods = 71.88 cm)

Salution ht = 81.20 cm $d_h = .60$ cm
 Temp $\rho = 26.0$ °C
 $\sigma = 49.98 \text{ au} = 16.4 \text{ f} = 27.3 \text{ f/cm}$
 $\rho = 26.1$ °C

1450

Salution ht = 80.60 cm
 system just critical
 Quin

Moving array 2.0" more from bottom of tank, giving 10.16 cm bottom reflector (solution). Reduced the thickness of the top reflector from last run at 2.0" bottom reflector a total of 2.38 cm.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter <input checked="" type="checkbox"/>	2"	<input checked="" type="checkbox"/>	3×10^{-12}
"	"	Foot <input checked="" type="checkbox"/>	"	<input checked="" type="checkbox"/>	"
K-2	"	Meter <input checked="" type="checkbox"/>	2"	<input checked="" type="checkbox"/>	"
"	"	Foot <input checked="" type="checkbox"/>	1"	<input checked="" type="checkbox"/>	"
R-1					
R-2					
PM-1	700V	Alarm <input checked="" type="checkbox"/>			
PM-2	1200V	Low <input checked="" type="checkbox"/>	8"	<input checked="" type="checkbox"/>	900V
"	"	Alarm <input checked="" type="checkbox"/>	1"	<input checked="" type="checkbox"/>	"

LOG IN CALIBRATE OPERATE SOURCE No. B-90
 DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by F.P.C. Personnel check by F.P.C.
 Instruments and safeties checked and reset by A.K.K.
 Source in checked by A.K.K. Source No. 19-43
 Emergency equipment in control room checked by F.P.C.
 Instruments in trip circuit: K-1-2 P-M-2
 Red light on by A.K.K. Time 0805
 Start-up OK'd by F.P.C., A.K.K. Date 5-12-72

Repeat of last run (5-11-72)

$\Delta h = 1.80 \text{ cm}$
 80.90 cm
 solution ht = ~~81.40~~ cm
 Temp °C
 #3 = 25.5°C
 #4 = 25.7°C

0950

$E = 86.92 \text{ sec} = 11.0 f = 36.7 f/cm$
 solution ht = 80.60 cm
 system just critical
 Drain

Removed 2 rods. Now have an 10x10 - 7 array. Total 93 rods.

$\Delta h = 1.55 \text{ cm}$
 solution ht = 82.65 cm
 Temp °C
 #3 = 25.7°C
 #4 = 26.0°C

1045

solution ht = 82.10 cm
 system just critical
 Drain

Removed 1 rod. Now have an 10x10 - 8 array, total of 92 rods.

$\Delta h = 1.65 \text{ cm}$
 solution ht = 83.50 cm
 Temp °C
 #3 = 25.8°C
 #4 = 26.0°C

1335 solution ht = 82.85 cm
system just critical
Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3X10 ⁻¹²	Meter ✓	2"	✓	3X10 ⁻¹²
"	"	Fest ✓	1"	-	"
K-2	"	Meter ✓	2"	✓	"
"	"	Fest ✓	1"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	Cont	✓	500V
PM-2	1200V	Low ✓	8"	✓	900V
"		Alarm ✓	1"	✓	"

LOG N CALIBRATE ✓ OPERATE ✓ SOURCE No. 0-80

DUMP WELL PROBE LIGHT ✓

.30" Rod
2.05° cm separation e-c
Voz Ev solutions
30 cm length
START-UP CHECK LIST

Equipment checked by F.I.C. Personnel check by R.K.H.
Instruments and safeties checked and reset by R.K.H.
Source in checked by R.K.H. Source No. 19-93
Emergency equipment in control room checked by F.I.C.
Instruments in trip circuits K-1-2 PM-1-2
Red light on by R.K.H. Time 0800
Start-up OK'd by F.I.C. R.K.H. Date 5-15-72

Repeat of last run. p-36-37.

$h = 83.35 \text{ cm}$
Temp °C
#3 = 25.0°C
#4 = 25.2°C
 $C = 91.27 \text{ m} = 10.6 \text{ g} = 23.5 \text{ g/cm}$

0945 solution $h = 82.90 \text{ cm}$
system just critical
Drain.

Added 3 rods. Now have an 10x10-5
array. Total of 95 rods.
Purpose is to repeat experiment on
p-34-36.

$h = 81.10 \text{ cm}$ Temp °C
#3 = 25.5°C
#4 = 25.7°C
 $C = 65.19 \text{ m} = 13.6 \text{ g} = 24.7 \text{ g/cm}$
1051 solution $h = 80.55 \text{ cm}$
system just critical
Drain.

Replaced the top tube sheet (.50" thickness)
with a (.250" thick tube sheet) now
have an 10x10-5 array. Total of 92 rods.

$h = 82.20 \text{ cm}$ Temp °C
#3 = 26.0°C
#4 = 26.2°C
 $C = 78.23 \text{ m} = 11.9 \text{ g} = 29.7 \text{ g/cm}$
solution $h = 81.80 \text{ cm}$
system just critical
Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE D. T. F.	SET	START-UP RANGE
K1	3x10 ⁻¹²	Meter ✓	2"	✓	3x10 ⁻¹²
"	"	Fast ✓	1"	✓	"
K2	"	Meter ✓	2"	✓	"
"	"	Fast ✓	1"	✓	"
P1					
P2					
PA-1	700V	Alarm ✓	cont	✓	500V
PA-2	1200V	Low ✓	89	✓	900V
"	"	Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. M-80
 DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by F.D.C. Personnel check by F.D.C.
 Instruments and safeties checked and reset by ARK
 Source in checked by ARK Source No. M-43
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: Z-1-2 PM-1-2
 Red light on by ARK Time 1010
 Start-up OK'd by F.D.C. ARK Date 5-16-72

.30" node
 2.050 cm separation c-e.
 No₂ F₂ solutions
 30 cm lengths.

Still have etc 10x10-8 array, total of 92 nodes. also have in contact on top of array 2 pc of plexiglass 1 that is 1"x24"x24" and 1 that is .50"x24"x24" making a total of 1.5" thick. This is a mach-up of the bottom support plate. also the top tube shut in the .250" thick one.

Solution ht = 112.50 cm Temp °C
 1 - Per #3 = 25.7 °C
 N.G. #4 = 26.0 °C

1408 Drain

Added 1 node. Now have an 10x10-7 array, total of 93 nodes.

dh = 3.45 cm
 Solution ht = 105.70 cm Temp °C
 2 + Per #3 = 25.8 °C
 #4 = 26.2 °C

1555 Solution ht = 102.25
 System just critical
 Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE	SET	START-UP RANGE
K-1	3K10 ⁻¹²	Meter ✓	2"	✓	3(10 ⁻¹²)
"	"	Fast —	"	✓	"
K-2	"	Meter —	2"	✓	"
"	"	Fast ✓	1"	✓	"
D-1					
D-2					
PM-1	700V	Alarm —	(Taken out of service)		
PM-2	1200V	Low ✓	8"	✓	900V
"	"	Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. 8-80
DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by F.D.C. Personnel check by F.D.C.
 Instruments and safeties checked and reset by B.K.M.
 Source in checked by B.K.M. Source No. 19-43
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1-2 PM-2
 Red light on by B.K.M. Time 1210
 Start-up OK'd by F.D.C. B.K.M. Date 5-17-72

43
 .30" rods.
 2.050 cm separation c.c.
 UO₂F₂ solution.
 30.0 cm length

Have an 10x10-7 array, total of 93 rods.
 also the 1.5" of plekaplast described
 on p-41 has been removed.

Solution ht = 81.55 cm $\Delta h = .30$ cm Temp °C
 #3 = 25.7 °C
 #4 = 25.7 °C


1329 $t = 91.27$ sec = 10.6% = 35.34/cm
 Solution ht = 81.25 cm
 System just critical
 Drain.

Repeat of above:

Solution ht = 81.20 cm $\Delta h = .45$ Temp °C
 #3 = 25.7 °C
 #4 = 25.7 °C

1512 $t = 73.88$ sec = 12.4% = 27.854/cm
 Solution ht = 80.75 cm
 System just critical
 Drain.

5/17/72 10x10 array w.
 7 rods removed from 1
 face. Total rods 93
 .30" dia. 2.050 cm sep
 c-c P, 43



INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE	SEE	START-UP
PM 1	3x10 ⁻¹²	Alarm	2"	✓	3x10 ⁻¹²
"	"	Fail	1"	✓	"
"	"	Alarm	2"	✓	"
"	"	Fail	1"	✓	"
PM 1	300V	Alarm	Cont	✓	500V
PM 2	1200V	Low	8"	✓	900V
"	"	Alarm	1"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. 3-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by F.D.C. Personnel check by F.D.C.
R.K.N.
 Instruments and safeties checked and reset by R.K.N.
 Source in checked by R.K.N. Source No. 14-43
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1-2 P09-1-2
 Red light on by R.K.N. Time 0935
 Start-up OK'd by F.D.C., R.K.N. Date 5-18-72

130" rods,
 2050 cm separation e-e.
 UO₂F₂ solution,
 30 cm length.

Repeat of last run # 93,
 $\Delta h = .40 \text{ cm}$
 Solution ht = 81.20 cm
 Temp °C
 #3 = 25.5 °C
 #4 = 25.7 °C
 $\sigma = 93.44 \mu\text{S} = 10.4 \text{ f} = 26.0 \text{ f/cm}$
 1135 Solution ht = 80.80 cm
 System just critical
 Drain.

Repeat of above:
 $\Delta h = .45 \text{ cm}$
 Solution ht = 81.25 cm
 Temp °C
 #3 = 25.5 °C
 #4 = 25.7 °C
 $\sigma = 76.05 \mu\text{S} = 12.2 \text{ f} = 27.11 \text{ f/cm}$
 1300 Solution ht = 80.80 cm
 System just critical
 Drain.

$\Delta h = .30 \text{ cm}$
 Solution ht = 81.10 cm.
 Temp °C
 #3 = 25.7 °C
 #4 = 25.7 °C
 $\sigma = 130.90 \mu\text{S} = 7.7 \text{ f} = 25.67 \text{ f/cm}$
 1330 Solution ht = 80.80 cm
 System just critical
 Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE	SET	START-UP RANGE
K-1	3X10 ⁻¹²	Meter ✓	2"	✓	3X10 ⁻¹²
"	"	Fast ✓	1"	-	"
K-2	"	Meter ✓	2"	✓	"
"	"	Fast ✓	"	-	"
R-1					
R-2					
PM-1	700 V	Alarm ✓	Cont ✓	✓	500 V
PM-2	1200 V	Low ✓	8" ✓	✓	900 V
"	"	Alarm ✓	1" ✓	✓	"

LOG N CALIBRATE OPERATE SOURCE No. B-80
 DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by RKL Personnel check by F.C. P.K.R.
 Instruments and safeties checked and reset by RKL
 Source in checked by RKL Source No. M-43
 Emergency equipment in control room checked by F.I.D.C.
 Instruments in trip circuit: K-1-2 P.N. 1-2
 Red light on by RKL Time 0920
 Start-up OK'd by F.I.C. P.K.R. Date 5-22-72

30" nodes
 2.050 cm separation e-o.
 0.2 F₂ selection
 30 cm length.

Repeat of last experiment (p-45)

2h = 3.5 cm

Selection ht = 81.15

Temp °

1 + Per

#3 = 25.2 °

C = 99.96 au = 9.9 f = 28.28 f/cm

4 = 25.5 °

1050 Solution ht = 80.80 cm

System just critical
 Drain.

I have an 10X10-7 array; total of 93 nodes.
 also have in contact on top of array 1 pc
 of plexiglas that is .50" X 24 X 24. Top tube
 sheet is .250" thick.

642.40 cm

Solution ht = 83.15 cm

Temp °

2 + Per

#3 = 25.5 °

C = 115.17 au = 8.8 f = 22.0 f/cm

4 = 25.7 °

Solution ht = 82.75 cm.

System just critical
 Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3x10 ⁻¹²	Meter ✓	2"	✓	3x10 ⁻¹²
"	"	Fast ✓	"	✓	"
K-2	"	Meter ✓	2"	✓	"
"	"	Fast ✓	1"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	cont	✓	500V
PM-2	1200V	Low ✓	8"	✓	900V
"	"	Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. B-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by A.K.M. Personnel check by F.D.C.
 Instruments and safeties checked and reset by A.K.M.
 Source in checked by A.K.M. Source No. M-93
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by A.K.M. Time 0805
 Start-up OK'd by F.D.C., A.K.M. Date 5-23-72

.30" rods
 2,050 cm separation c-c.
 No. F₂ solution
 30 cm length.

Have an 10x10-7 array. Total of 93 rods.
 also have in contact on top of array
 1 pc of plepiglow #.250" x 24" x 24" and
 1 pc .50 x 24" x 24". Making a total of .750"
 thick.

h₁ = .60 cm

Solution h₁ = 84.80 cm Temp °C
 #3 = 25.5 °C
 #4 = 25.7 °C
 C = 123.86 acc = 8.34 = 13.83 %/cm.

0945 Solution h₁ = 84.20 cm
 System just critical
 Drain.

added 1 pc of plepiglow .250" x 24" x 24" to above.
 Making a total of 1.0 thick.

h₁ = .90 cm

Solution h₁ = 87.10 cm Temp °C
 #3 = 25.6 °C
 #4 = 25.7 °C
 C = 106.48 acc = 9.44 = 10.44 %/cm

1120 Solution h₁ = 86.20 cm
 System just critical
 Drain.

copy:

added 1 pc plepiglar .250" X 24" X 24" to above,
making a total of 1.250" thick

$\Delta h = 1.8 \text{ cm}$
Solution ht = 92.70 cm. Temp °C
#3 = 26.0 °C
#4 = 26.1 °C

1330

$\epsilon = 112.99 \mu\text{m} = 9.0 \phi = 5.0 \phi/\text{cm}$
Solution ht = 90.90 cm
System just critical
Drain.

Now have only 1 pc of plepiglar on top
of array. It is .250" X 24" X 24"

$\Delta h = 1.50$
Solution ht = 82.80 cm Temp °C
#3 = 25.8 °C
#4 = 26.2 °C

1436

Solution ht = 82.30 cm
System just critical
Drain.

Now have 1 pc of plepiglar 1.0" X 24" X 24" and
1 pc .50" X 24" X 24" on top of array. Total
of 1.50"

$\Delta h = 3.0 \text{ cm}$ Temp °C
Solution ht = 99.80 cm #3 = 26.2
#4 = 26.5

1600 Solution ht = 96.30 cm
System just critical
Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3X10 ⁻¹²	Meter ✓	2"	✓	3X10 ⁻¹²
"	"	Fast ✓	1"	✓	"
K-2	"	Meter ✓	2"	✓	"
"	"	Fast ✓	1"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	Cont	✓	500V
PM-2	1200V	Low ✓	8"	✓	900V
"	"	Alarm ✓	1"	✓	"
LOG N CALIBRATE		✓	OPERATE	✓	SOURCE No. <u>B-80</u>
DUMP WELL PROBE LIGHT		✓			

START-UP CHECK LIST

Equipment checked by F.D.C. Personnel check by R.K.R.
 Instruments and safeties checked and reset by R.K.R.
 Source in checked by R.T.M. Source No. M-43
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: R-1-2 PM-1-2
 Red light on by R.K.R. Time 0800
 Start-up OK'd by F.D.C. R.K.R. Date 5-31-72

.30" rods.
 2,453 cm separation c.c.
 V₀₂ V₂ solution
 30 cm lengths.

Have an 9X10 array. Total of 90 rods.

$d_4 = 2.20$ cm

Solution ht = 78.05

Temp °C

1 + Per

#3 = 25.1 °C

$C = 108.65 \mu\text{m} = 9.3\phi = 46.5\phi/\text{cm}$

4 = 25.1 °C

0927 Solution ht = 77.85

system just critical
 Drain.

Removed 5 rods. Now have an 9X9+4 rods on 1 face. Total of 85 rods.

$d_4 = 2.25$ cm

Solution ht = 80.70 cm

Temp °C

2 + Per

#3 = 25.5 °C

$C = 104.30 \mu\text{m} = 9.5\phi = 27.1\phi/\text{cm}$

4 = 25.7 °C

1400 Solution ht = 80.35 cm

system just critical
 Drain.

Removed 4 rods. Now have an 9X9 array. Total of 81 rods.

$d_4 = 1.45$ cm

Solution ht = 83.40 cm.

Temp °C

3 + Per

#3 = 25.7 °C

$C = 108.65 \mu\text{m} = 9.3\phi = 20.7\phi/\text{cm}$

4 = 25.8 °C


1450 Solution ht = ± 82.95 cm
 System just critical
 Drain

added 1 rod. Now have an 9x9+1 array.
 Total of 82 rods.

Solution ht = 82.70 cm $\Delta h = .40$ cm
 $T_{emp} = 25.8^\circ C$
 $T = 104.30 \text{ sec} = 9.64 = 22.0\%$
 $\phi = 26.0^\circ C$

1531 Solution ht = ± 82.30 cm
 System just critical
 Drain

5/31/72 9x9 array + 1
 Total rods 82 - .30" dia
 2.453 cm - Sep. cc P.54



INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Motor <input checked="" type="checkbox"/>	2"	<input checked="" type="checkbox"/>	3×10^{-12}
"	"	Set <input checked="" type="checkbox"/>	1"	<input checked="" type="checkbox"/>	"
K-2	"	Motor <input checked="" type="checkbox"/>	2"	<input checked="" type="checkbox"/>	"
"	"	Set <input checked="" type="checkbox"/>	1"	<input checked="" type="checkbox"/>	"
R-1					
R-2					
PM-1	500V	Alarm <input checked="" type="checkbox"/>	Cont	-	500V
PM-2	1200V	Low <input checked="" type="checkbox"/>	8"	<input checked="" type="checkbox"/>	900V
"	"	Alarm <input checked="" type="checkbox"/>	1"	<input checked="" type="checkbox"/>	"

LOG IN CALIBRATE OPERATE SOURCE No. B-80
 DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by E.D.C. AKAL Personnel checked by AKAL
 Instruments and safeties checked and reset by AKAL
 Source in checked by AKAL Source No. M-43
 Emergency equipment in control room checked by AKAL
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by AKAL Time 0800
 Start-up OK'd by E.D.C. AKAL Date 6-1-72

.30" rods,
2.453 cm separation c.c.
UO₂ F₂ solution
30 cm lengths.

Repeat of last experiment. β - 54

ab = .25 cm

Solution ht = 82.45 cm

Temp °C

+ Per

#3 = 25.2 °C

$I = 149.94 \mu\text{A} = 7.1\% = 28.4 \mu\text{A/cm}$

$\phi = 25.2 \text{ } ^\circ\text{C}$

1000

Solution ht = 82.20 cm

System just critical
Drain.

Added 1 rod. Now have an 9x9 + 2 array.
Total of 83 rods.

ab = .35

Solution ht = 81.90 cm

Temp °C

+ Per

#3 = 25.5 °C


$I = 126.03 \mu\text{A} = 8.2\% = 23.4 \mu\text{A/cm}$

$\phi = 25.5 \text{ } ^\circ\text{C}$

Solution ht = 81.55 cm.

System just critical
Drain.

6/1/72 9x9 array + 2
Total rods 83 - .30" dia
2.453 cm - sep. cc P.56



INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K1 B 810 ⁻¹²		Master ✓	2"	-	3810 ⁻¹²
"		Fast ✓	1"	-	"
K2 "		Master -	2"	-	"
"		Fast -	1"	-	"
R1					
R2					
PA1 700 V		Alarm ✓	cont	-	500 V
PA2 1200 V		Low -	8"	-	900 V
"		Alarm -	1"	-	"

LOG N CALIBRATE OPERATE SOURCE No. B-80
DUMP WELL PROBE LIGHT

START-UP CHECK LIST

I. DeO
Equipment checked by P. K. A. L. Personnel check by I. DeO
Instruments and safeties checked and report by A. K. L.
Source is checked by A. K. L. Source No. M-43
Emergency equipment in control room checked by I. DeO
Instruments in trip circuit: Z-1-2 019-1-2
Red light on by A. K. L. Time 0935
Check-out OK'd by I. DeO Date 6-6-72

~~from tank~~
630 rods
2.900 cm separation c/c
CO₂ solution
30 cm lengths.

Have an 9x9 array: total of 81 rods.

Solution ht = 83.40 cm $d_h = .45$ cm Temp °C
1 + Per #3 = 25.6 °C
#4 = 25.7 °C
 $t = 117.34$ sec = 8.74 = 19.13 f/cm.

1106 Solution ht = 82.95 cm.
system just critical
Drain.

1220 added 1 rod. Have an 9x9+1 array: total of 82 rods.
system survived; K-2 zero knob
on moved when changing scales.

Solution ht = 82.85 cm $d_h = .45$ cm Temp °C
2 + Per #3 = 25.8 °C
#4 = 26.0 °C
 $t = 102.13$ sec = 9.74 = 21.5 f/cm

Solution ht = 82.40 cm
system just critical
Drain

added 1 rod. Have an 9x9+2 array: total of 83 rods.

Solution ht = 82.20 cm $d_h = .30$ cm Temp °C
3 + Per #3 = 26.0 °C
#4 = 26.2 °C
 $t = 97.78$ sec = 10.14 = 33.7 f/cm.

1347 Solution ht = 81.90 cm
system just critical
Drain.

Solution sample taken.

#2 Y-12 Reg #684632

= 161.6 grams

T = 19.0 °C

N = 142.6 " = 31.9

calc for.

1 - g/g = 1.223255

2 - sp. gr. = 1.3479


3 - density = 1.3440

4. Temp °C =

300.05 g U/L

300.24 g U/L av.

6/6/72: 9x9 array +2
Total rods 83 - .30"
dia - 2.90 cm - sep.
c-c p. 59



#2-A-X-10 Reg #
A-5453

= 162.6 grams

T = 18.9 °C

N = 143.7 "

calc for.

1 - g/g = 1.2235

2 - sp. gr. = 1.3474

3 - density = 1.3442

4. Temp °C = 20 °C

301.43 g U/L

INSTRUMENT CHECK

INSTRUMENT	RANGE	TIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Mid	2"	-	3×10^{-12}
"	"	Bot	1"	-	"
K-2	"	Mid	2"	-	"
"	"	Bot	1"	-	"
R-1					
R-2					
PM-1	700V	Alarm	cont	-	500V
PM-2	1200V	Low	8"	-	900V
"	"	Alarm	1"	-	"

LOG IN CALIBRATE OPERATE SOURCE No. B-90
 DUMP WELL PROBE LIGHT

START-UP CHECK LIST

I.D.C.
 Equipment checked by A.K.M. Personnel check by I.D.C.
 Instruments and safeties checked and reset by A.K.M.
 Source in checked by A.K.M. Source No. M-93
 Emergency equipment in control room checked by I.D.C.
 Instruments in trip circuit K-1-2 PM-1-2
 Red light on by A.K.M. Time 1255
 Start-up OK'd by I.D.C. A.K.M. Date 6-7-72

.516" Rods
 2.99 cm separation c-c.
 O₂ F₂ solution
 30 cm lengths.

Top of rods = 71.50 cm (avg)

Have an 6x7 array. Total of 47 rods.

Solution ht = 85.90 cm $\Delta h = .45 \text{ cm}$ Temp °C
 #3 = 26.0 °C
 #4 = 26.0 °C
 $t = 108.65 \text{ sec} = 9.37 = 20.7 \text{ f/cm}$


1443 Solution ht = 85.45 cm
 System just critical
 Drain.

Added 2 rods. Now have an 7x7-5 array.
 Total of 44 rods.

Solution ht = 82.60 $\Delta h = .40 \text{ cm}$ Temp °C
 #3 = 26.2 °C
 #4 = 26.2 °C
 $t = 86.92 \text{ sec} = 11.07 = 27.5 \text{ f/cm}$

1533 Solution ht = 82.20 cm
 System just critical
 Drain.

6/7/72 7x7 array-5
 total rods 44 - .516"
 dia, 2.99 cm sep.
 c/c p.61



INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter ✓	2"	✓	3×10^{-12}
"	"	Fast ✓	1"	✓	"
K-2	"	Meter ✓	2"	✓	"
"	"	Fast ✓	1"	✓	"
PM-1	700V	Alarm ✓	cont	✓	500V
PM-2	1200V	Low ✓	8"	✓	900V
"	"	Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. B-80
 DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by I.V.C. Personnel check by F.H.C.
 Instruments and safeties checked and reset by A.K.V.
 Sources in checked by A.K.V. Source No. M-23
 Emergency equip. checked by I.V.C.
 Instruments in trip checked 7-1-2 PM-1-2
 Rod light on by A.K.V. Time 0810
 Start-up OK'd by F.H.C. A.K.V. Date 6-8-77

1516" rods.
 2.99 cm separation c-c.
 402 F₂ solutions
 30 cm length.

added 1 rod. Now have an 7X7-A array.
 Total of 45 rods.

Solution ht = 81.00 cm. $d_4 = 1.35 \text{ cm}$
 + Per Temp °C
 #3 = 25.7 °C
 #4 = 25.9 °C
 0934 $t = 89.09 \text{ sec} = 10.24 = 30.9 \text{ f/cm}$
 solution ht = $\pm 80.65 \text{ cm}$
 System just critical
 Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	BK10-12	Meter ✓	2"	-	3K10-12
"	"	Fps ✓	1"	-	"
K-2	"	Meter ✓	2"	-	"
"	"	Fps ✓	1"	-	"
R-1					
R-2					
PM-1	700V	Alarm ✓	cont	✓	500V
PM-2	1200V	Fps ✓	8"	-	900V
"	"	Alarm ✓	1"	-	"

LOG IN CALIBRATE OPERATE SOURCE No. 0-80
 DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by F.P.C. AXL Personnel check by I.D.C.
 Instruments and settings checked and reset by AXL
 Source in checked by AXL Source No. 19-93
 Emergency equipment in control room checked by I.D.C.
 Instruments in trip circuit: K-1-2 PK-1-2
 Red light on by AXL Time 0920
 Start-up OK'd by I.D.C. AXL Date 6-19-72

1516 rods
 3.40 cm separation c.c.
 O₂ / C₂ solution
 30 cm length.

Have an 7x7 array; Total of 49 rods.

oh = 1.15 cm
 Solution ht = 75.15 cm Temp °C
 #3 = 25.5 °C
 #4 = 25.7 °C

1040
 E = 78.23 sec = 11.9 φ = 79.3 φ/cm
 Solution ht = ± 75.00 cm.
 System just critical
 Drain

Removed 4 rods. Now have an 7x7-4 array
 Total of 45 rods.

oh = 1.35 cm
 Solution ht = 78.10 cm Temp °C
 #3 = 26.0 °C
 #4 = 26.0 °C

1108
 E = 71.71 sec = 12.7 φ = 36.3 φ/cm
 Solution ht = 77.75 cm.
 System just critical
 Drain.


Removed 4 rods. Now have an 6x6+5 array.
 (5 rods on 1 face.) Total of 41 rods.

oh = 40 cm
 Solution ht = 82.30 cm Temp °C
 #3 = 26.0 °C
 #4 = 26.0 °C
 avr.

1313

Solution ht = 81.90 cm.
System just critical
Drain

6/19/72 6x6 array +
5 rods on 1 face Total
rods 41 .516 Dia
3.40 cm sep. P.65-66



Added 1 rod. Now have an 6x7 array.
Total of 42 rods.

Solution ht = 81.10 cm
4+Per

Δh = .50 cm

Temp °C

#3 = 26.2°

#4 = 26.2°

$t = 67.36 \text{ sec} = 13.3 \text{ } \phi = 26.6 \text{ } \mu\text{sec}$

1342

Solution ht = 80.60 cm
System just critical
Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter ✓	2"	✓	3×10^{-12}
"	"	Fast ✓	1"	✓	"
K-2	"	Meter ✓	2"	✓	"
"	"	Fast ✓	1"	✓	"
R-1					
R-2					
PM1	700V	Alarm ✓	cont	-	500V
PM2	1200V	Low ✓	8"	✓	900V
"	"	Alarm ✓	1"	-	"

LOG N CALIBRATE OPERATE SOURCE No. B-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by I.P.C. P.K.L. Personnel check by I.D.C.
 Instruments and safeties checked and reset by P.K.L.
 Source in checked by P.K.L. Source No. M-93
 Emergency equipment in control room checked by I.D.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by P.K.L. Time 1315
 Start-up OK'd by I.P.C. P.K.L. Date 6-20-72

516" rods
 3,94 cm separation c.c.
 No 2 F₂ solution
 30 cm length.

Have an 7x7 array. Total of 49 rods.

dh = 110
 Solution ht = 75.60 cm
 + Per

Temp °C

E = 134.73 sec = 7.84 = 78.4/cm

#3 = 25.7 °C

4 = 25.7 °C

1835 Solution ht = 75.50 cm
 System just critical
 Drain.

Removed 7 rods. Now have an 6x7 array.
 Total of 42 rods.

dh = 225 cm
 Solution ht = 81.00 cm
 + Per

Temp °C

E = 134.73 sec = 7.84 = 31.2/cm

#3 = 26.0 °C

4 = 26.0 °C

Solution ht = 80.75 cm.
 System just critical
 Drain

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3 X 10 ⁻¹²	Meter -	2"	-	3 X 10 ⁻¹²
"	"	Foot -	1"	-	"
K-2	"	Meter ✓	2"	-	"
"	"	Foot ✓	1"	-	"
R-1					
R-2					
PM-1	700 V	Alarm -	Cent	-	500 V
PM-2	1200 V	Low ✓	8"	-	900 V
"	"	Alarm -	1"	-	"

LOG IN CALIBRATE OPERATE SOURCE No. B-80
 DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by S.D.C. AKAL Personnel check by I.D.C.
 Instruments and safeties checked and reset by AKAL
 Source in checked by AKAL Source No. M-93
 Emergency equipment in control room checked by I.D.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by AKAL Time 0905
 Start-up OK'd by I.D.C. AKAL Date 6-21-72

1.516" Rods
 3.94 cm separation c-c.
 ^{235}U / ^{238}U solution
 30 cm lengths.

Removed 2 rods. Now have an 6x6+4 array. Total of 40 rods.

Solution ht = 83.60 cm
 A-b = 140 cm
 Temp °C

#3 = 25.5°C
 #4 = 25.7°C

1048 $t = 130.38 \text{ sec} = 8.04 = 20.0 \text{ off cm}$

Solution ht = 83.20 cm
 System just critical
 Drain

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Master ✓	2"	✓	3×10^{-12}
"	"	Fast ✓	1"	✓	"
K-2	"	Master ✓	2"	-	"
"	"	Fast ✓	1"	-	"
R-1					
R-2					
PA-1	700V	Alarm ✓	Cent	✓	500V
PA-2	1200V	Low ✓	8"	✓	900V
"	"	Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. B-8C

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by F.D.C. Personnel check by F.D.C.
 Instruments and safeties checked and reset by A.K.M.
 Source in checked by A.K.M. Source No. M-93
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1-2 PA-1-2
 Red light on by A.K.M. Time 0800
 Start-up OK'd by F.D.C., A.K.M. Date 6-22-72

.516" Rods
3.94 cm. separation c-c
UO₂ F₂ solution
30 cm. length

Repeat of last run. p = 70

d.c. = .40 cm

solution ht = 83.60 cm

Temp °C

+ Per

23 = 25.5°

L = 113.00 au = 9.0 f = 22.5 H/cm

q = 25.5°

0940 solution ht = 83.20 cm
system just critical
Drain.

Added 1 rod. Now have an 6x6+5
array. Total of 41 rods.

d.c. = .35 cm

solution ht = 82.10 cm

Temp °C

+ Per


23 = 25.5°

L = 97.78 au = 10.0 f = 28.6 H/cm

q = 25.7°

1016 solution ht = 81.75 cm
system just critical
Drain.

6/22/72 6x6 array + 5
rods on 1 face total
rods 41 .516 Dia. 3.94
cm sep. c-c p.72



6-22-72 solution sample taken.

#3

Y-12 Reg #684635

#3-A X-10 Reg #A-5454

W = 133.8 g

C = 120.6

T = 19.5

T = 18.9

N = 114.3 = 25.6 g

M = 107.7

calc for.

calc for.

g/g = .223930

g/g = 0.223

sp. gr. = 1.3456

sp. gr. = 1.3496

density = 1.3416

density = 1.3467

Temp °C

Temp °C = 20°

~ 301.32 g

~ 300.96 g

301.14 g U/A average

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE RANGE	SET	START-UP RANGE
K13	10^{-12}	Meter ✓	3"	✓	3.110^{-12}
"	"	Ext ✓	1"	✓	"
K2	"	Meter ✓	3"	✓	"
"	"	Ext ✓	1"	✓	"
P1					
P2					
PA1	700V	Alarm ✓	5"	✓	5000
PA2	1200V	Low ✓	8"	✓	900V
"	"	Alarm ✓	1"	✓	"

LOG IN CALIBRATE OPERATE SOURCE No.

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by F.D.C. Personnel check by F.D.C.
 Instruments and safeties checked and reset by ARKL
 Source in checked by ARKL Source No. M-43
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuits: K-1-2 PM 1-2
 Red light on by ARKL Time 0920
 Start-up OK'd by F.D.C. ARKL Date 7-15-72

.30" rods
 3.25cm separation c.e.
 U₂F₂ solution
 30 cm lengths

Have a 9x10 array: total of 90 rods.

$\Delta h = .30 \text{ cm}$
 Solution ht = 80.70 cm Temp °C
 #3 = 26.0°C
 #4 = 26.0°C
 $T = 82.57 \text{ m} = 11.44 = 32.0 \text{ f/cm}$
 1030 Solution ht = ± 80.40 cm
 System just critical
 Drain.

Removed 3 rods: Now have an 9x9+6 array:
 Total of 87 rods.

$\Delta h = .30 \text{ cm}$
 Solution ht = 82.00 cm Temp °C
 #3 = 26.0°C
 #4 = 26.0°C
 $T = 126.03 \text{ m} = 8.24 = 27.3 \text{ f/cm}$
 1109 Solution ht = ± 81.70 cm
 System just critical
 Drain.

Removed 1 rod. Now have an 9x9+5 array:
 Total of 86 rods.

$\Delta h = .25 \text{ cm}$
 Solution ht = 82.60 cm Temp °C
 #3 = 26.0°C
 #4 = 26.0°C
 $T = 126.03 \text{ m} = 8.24 = 32.8 \text{ f/cm}$
 arry.

1130

Solution $W = 82.35 \text{ cm}$
 System just critical
 Chain

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE GUARANTEE	SFT	START-UP RANGE
RT	3×10^{-12}	AMP ✓	3"	✓	3×10^{-12}
"	"	FM ✓	1"	✓	"
LD	"	AMP ✓	31	✓	"
"	"	RT ✓	1"	✓	"
DC					
DC					
PA1	700V	AMP ✓	5"	✓	500V
PA2	1200V	AMP ✓	10"	✓	900V
"	"	AMP ✓	cont	✓	"
LCS IN CALIBRATE ✓		OPERATE ✓	SOURCE No. B-80		
DUMP VCL. FROSE LIGHT ✓					

START-UP CHECK LIST

Equipment checked by FIDC Personnel check by FIDC
 Instruments and sockets checked and reset by ARKA
 Counts in control by ARKA Source No. M-43
 Emergency equipment in control room checked by FIDC
 In room's in 114 checked: K-1-2 PK9-12
 Test done on by ARKA Time 1235
 Source in 114 by FIDC, ARKA Date 7-26-72

.516" rods,
4.40 cm separation c-c,
No 2 F₂ solution
30 cm length.

Have on 6 x 7 array. Total of 42 rods.

Solution ht = 83.40 cm
+ Per Void
Temp °C
#3 = 26.0°C
#4 = 26.0°C

1409 System scanned by K-2 when changing
scaler from 3 x 10⁻¹² to 10 x 10⁻¹⁰

Δh = .45 cm
Solution ht = 83.40 cm
+ Per
Temp °C
#3 = 26.0°C
#4 = 26.0°C

1432 Solution ht = ± 82.95 cm
System just critical
Down.

Added 1 rod. Now have on 7 x 7 - 6 array.
Total of 43 rods.

Solution ht = 82.60 cm
+ Per
Temp °C
#3 = 26.2°C
#4 = 26.2°C

1505 Solution ht = 82.15
System just critical
Down.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DIPSWITCH	SET	START-UP RANGE
K-1	3 x 10 ⁻¹²	Meter ✓	3"	✓	3 x 10 ⁻¹²
"	"	Ext ✓	1"	✓	"
K-2	"	Meter ✓	3"	✓	"
"	"	Ext ✓	1"	✓	"
PM-1	300V	Alarm ✓	.54"	✓	500V
PM-2	1200V	Low ✓	10"	✓	900V
"	"	Alarm ✓	10"	✓	"

LOG IN CALIBRATE OPERATE SOURCE No. B-80
DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by A.T.G. Personnel check by F.D.C.
Instruments and safeties checked not least by ARKL
Square checked by ARKL Form No. 19-43
Ready for operation in control room checked by F.D.C.
Instruments in ready condition K-1-2 PM-1-2
Red light on by ARKL Time 0840
Starting data by F.D.C. ARKL Date 7-27-72

1.516" rods.
4.40cm separation c-c.
U₂F₂ solution
30 cm length.

Added 1 rad. Now have an 7x7-5 array.
Total of 44 rods.

Solution ht = 81.35cm
d₄ = 1.35cm
Temp °C
#3 = 26.0°C
#4 = 26.0°C

1008
C = 104.30cm = 9.6 ft = 27.4 f/cm.
Solution ht = ± 81.00cm
System just critical
Drain

#4 solution sample taken

Req # X-12 684636
G = 150.0g
T = 19.9g
N = 130.0g = 29.3%

X-10 Req # A-5455
G = 156.5g
T = 19.0g
N = 137.5g

g/g = 0.224610
sp. gr. = 1.70592 1.3492
density = 1.70080 1.3453
Temp °C = 25.0°C
303.042g/g

g/g = 0.2224
sp. gr. = 1.3502
density = 1.3474
Temp °C = 19.5°C
= 301.8g/g

Note see corrections
sheet attached to Rep sheet.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3 X 10 ⁻¹²	Meter ✓	4"	✓	3 A 10 ⁻¹²
"	"	Fast ✓	1"	✓	"
K-2	"	Meter ✓	4"	✓	"
"	"	Fast ✓	1"	✓	"
R-1					
R-2					
PM-1	700v	Alarm ✓	5"	✓	5000
PM-2	1200v	Low ✓	10"	✓	4000
"	"	Alarm ✓	1"	✓	"

LOG N CALIBRATE ✓ OPERATE ✓ SOURCE No. B-80
DUMP WELL PROBE LIGHT ✓

START-UP CHECK LIST

Equipment checked by F.D.C. Personnel check by R.K.M.
Instruments and safeties checked and reset by R.K.M.
Source in checked by R.K.M. Source No. M-43
Emergency equipment in control room checked by F.D.C.
Instruments in trip circuit: K-1, 2 PM-1, 2
Red light on by R.K.M. Time 0800
Start-up OK'd by F.D.C. R.K.M. Date 8-11-72

1.30" Rods (unclad) (762) cm
30 cm length.
1.300 cm separation c-c.
H₂O only:

Base plate in "Little Nell." 6" bottom reflector.

Feed rate = 4.6 cm³/min.
3" Drain = 27.60 cm³/min.
4" Dump = 37.50 cm³/min.

Top of rods: H₂O = 28.40 cm. (on back scale)

Have an 20x20 + 4 array: Total of 404 rods
s_h = 2.90 cm

Water ht = 38.30 cm
+ Per Temp °C
T = 60.84 sec = 14.37 = 4.9 f/cm
#1 = 25.0 °C
#2 = 25.0 °C


1016 Water ht = 35.40 cm
System just critical
Drain:

Removed 4 rods: Now have an 20x20 array: Total of 400 rods.

1033 Water ht = 43.95 cm
System sub critical
Drain:

1.30 cm separation c-c
30 cm length.

Added 1 rod: Now have array: Total of 401 rods



Water ht = 44.10 cm
+ Per
T = 230.34 sec = 4.97 = 7.5 f/cm
1113 Water ht = 37.60 cm
System just critical
Drain:


#1 = 25.0 °C
#2 = 25.0 °C

Removed 1 rod: Now have an 20x20 array: Total of 400 rods.

Water ht = 44.15 cm.
+ Per Temp °C
T = 1325.53 sec = -1.0 f
1130 Drain:

#1 = 25.0 °C
#2 = 25.0 °C

Now have an 21x21 array in 2 direction direction (attached diagram).
rod



Water ht = 28.90 cm
+ Per Temp °C
T = 152.11 sec = 7.04 = 14.0 f/cm
1512 Water ht = 28.85 cm
System just critical: Drain: arr:

#1 = 25.1 °C
#2 = 25.1 °C

P-83
 Top Board #5
 20x20 array
 Total of 401 rods
 30 cm long
 1.30 cm - c.c.

1.30 cm separation c-c
 30 cm length

added 1 rod; Now have an 20x20 + 1 array; Total of 401 rods;

d.b. = 6.5 cm

Water ht = 44.10 cm
 2 Per

Temp °C
 #1 = 25.0°C
 2 = 25.0°C

$\tau = 230.34 \text{ sec} = 4.9 \text{ f} = .75 \text{ f/cm}$

1113 Water ht = 37.60 cm
 System just critical
 Drain.

Removed 1 rod; Now have an 20x20 array.
 Total of 400 rods.

Water ht = 44.15 cm
 3 Per

Temp °C
 = 25.0°C
 = 25.0°C
 P-83
 Top Board #5
 21x21 array
 with 2 rows
 removed
 Total of
 400 rods.

$\tau = -1325.53 \text{ sec} = -1.0 \text{ f}$
 Drain.

1130

Now have an 21x21 array, with 11th row
 in 2 ~~direction~~ direction removed; (see
 attached diagram). Total of 400 rods

d.b. = 1.05 cm

Water ht = 28.90 cm
 4 Per

Temp °C
 #1 = 25.1°C
 2 = 25.1°C


$\tau = 152.11 \text{ sec} = 7.0 \text{ f} = 140.0 \text{ f/cm}$

1512 Water ht = 28.85 cm
 System just critical; Drain.

arr:

1.30 cm separation e-e.
30 cm length.

Removed 20 rods from 1
an 20x21 array. Total
(see diagram)




Water ht = 30.80 cm
5th Per

Temp °C
#1 = 25.1 °C
#2 = 25.1 °C

1424 Water ht = ± 30.70 cm.
System just critical
Drain.

Removed 19 rods from 1
an 20x20 array. Total of
(see diagram)



Water ht = 35.10 cm
6th Per

Temp °C
#1 = 25.1 °C
#2 = 25.1 °C

1502 Water ht = ± 34.30 cm
System just critical
Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3x10 ⁻¹²	Motor ✓	9"	-	3x10 ⁻¹²
"	"	Fast ✓	1"	-	"
K-2	-	Motor			
"	-	Fast			
R-1					
R-2					
PM-1	700 v	Alarm ✓	5"	-	500 v
PM-2	1200 v	Low ✓	10"	✓	900 v
"	"	Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. B-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by I.D.C. RKL Personnel check by I.D.C.
 Instruments and safeties checked and reset by RKL
 Source in checked by RKL Source No. M-43
 Emergency equipment in control room checked by I.D.C.
 Instruments in trip circuit: #1 P19-1-2
 Red light on by RKL Time 1310
 Start-up OK'd by I.D.C. RKL Date 8-19-72

1.30 cm penetration e.e.
30 cm length.

goal
08E to 277
time 10X00

Removed 20 rods from 1 face. Now have
an 20x21 array. Total of 380 rods.
(see diagram)

$h = 1.0 \text{ cm}$

Water ht = 30.80 cm
5 + Per

Temp °C
#1 = 25.1 °C
25.1 °C

$T = 93.99 \text{ sec} = 10.94 = 104.04 / \text{cm}$

1424 Water ht = ± 30.70 cm.
System just critical
Drain.

goal 178
to 277
time 02400
50 rods top

Removed ~~20~~ 19 rods from 1 face. Now have
an 20x20 array. Total of 360 rods.
(see diagram).

$h = 1.80 \text{ cm}$

Water ht = 35.10 cm
65 + Per


Temp °C
#1 = 25.1 °C
2 = 25.1 °C

$T = 102.13 \text{ sec} = 9.74 = 12.34 / \text{cm}$

1502 Water ht = ± 34.30 cm
System just critical
Drain.

1.30 cm separation e-c.
30 cm length


Remained 19 rods. Now
array: Total of 342 rods



1340 Water ht = 43.70 cm
System sub critical
Chain.

#1 = 25.0 °C
2 = 25.0 °C


Added 10 rods:
Total of 352 rods



Water ht = 44.50 cm
System sub critical
Chain.


Temp °C
#1 = 25.0 °C
2 = 25.0 °C

Added 8 rods:
Total of 360 rods



1510 Water ht = 44.0 cm
System sub critical
Chain.

Added 3 rods. Now have
Total of 363 rods.



Water ht = 44.10 cm
+ Per

Temp °C
#1 = 25.2 °C
2 = 25.2 °C

$\epsilon = 499.79 \text{ cm} = 2.44 = 2.54 / \text{cm}$

1550 Water ht = 39.65 cm
System just critical
Chain

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SSOURCE DISTANCE	SSHT	STARTUP RANGE
KK1	3x10 ⁻¹²	Water ✓	9"	✓	3x10 ⁻¹²
	"	Temp ✓	1"	✓	"
KK2		Water			
		Temp			
FR11					
FR22					
PM11	700V	Alarm ✓	0.5"	✓	500V
PM22	1200V	Low ✓	10"	✓	800V
	"	Alarm ✓	1"	✓	"

LOG IN CALIBRATE ✓ OPERATE ✓ SOURCE No. B-80

ALARM WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by AKM Personnel check by F.D.C.
 Instruments and safeties checked and reset by AKM
 Source in checked by AKM Source No. M-43
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1 DM-1-2
 Red light on by AKM Time 0758
 Start-up OK'd by F.D.C. AKM Date 8-15-72

86

1.30 cm separation e-c.
30 cm length

342 rods
to array
rows
19x20
has

Remained 19 rods; Now have an 19x20 array; Total of 342 rods.

1340

Water ht = 43.70 cm
System sub critical
Drain.

356
to array
rows
21x18


Temp °C
#1 = 25.0 °C
2 = 25.0 °C

Added 10 rods; Now have an 21x21 array; Total of 352 rods; (See diagram.)

Water ht = 44.50 cm
System sub critical
Drain.

Temp °C
#1 = 25.0 °C
2 = 25.0 °C


Added 8 rods; Total of 360 rods; (See diagram.)



1510

Water ht = 44.0
System sub critical
Drain.

Added 9 rods; Now have Total of 369 rods; (See diagram.)



Water ht = 44.10 cm
+ Per

Temp °C
#1 = 25.2 °C
2 = 25.2 °C


$I = 499.79 \text{ sec} = 2.47 = 254 \text{ /cm}$

87

86

1.30 cm separation c-c.
30 cm length,

Removed 19 rods; Now
array: Total of 342 rods




1340

Water ht = 43.70 cm
System sub critical
Chain.

Temp °C
#1 = 25.0 °C
2 = 25.0 °C

Added 10 rods;
Total of 352 rods



21 x 21 array:

Water ht = 44.0
System sub crit
Chain.

Pg 86
Log Bomb #5
21 x 21 array:

Temp °C
#1 = 25.0 °C
2 = 25.0 °C

Added 8 rods; Now have an 21 x 21 array;
Total of 360 rods. (see diagram).

Total of 360 rods

1510

Water ht = 44.00 cm
System sub critical
Chain.

Pg 86
Log Bomb #5
21 x 21 array;
Total of 368 rods.

Added 8 rods; Now have an 21 x 21 array;
Total of 368 rods. (see diagram).

Water ht = 44.10 cm;
+ Per

ht = 4.45 cm

Temp °C
#1 = 25.2 °C
2 = 25.2 °C

$\bar{v} = 499.79 \text{ cm} = 2.44 = 254 \text{ /cm}$

Pg 87

1.30 cm separation e-e.
30 cm length

Repeat of last run: (pg 86-87)

ch = 1.9 cm

Water ht = 44.10 cm
1 Per

Temp °C

#1 = 25.1 °C

2 = 25.1 °C

$C = 2824.9 \text{ sec} = .46 \text{ f} = .24 \text{ f/cm}$

0835 Water ht = 42.20 cm

System just critical
Drain

Removed 1 rod. Have an 2
36.7 rods. (See diagram).

Water ht = 44.20 cm
2 Per

$C = -234.68 \text{ sec} = -.67 \text{ f}$

0853 Drain:

Now have an 22 x 12
12 rods now removed
diagram). Total of

Water ht = 32.65 cm

3 Per

$C = 100.48 \text{ sec} = 9.9 \text{ f} = 37.6 \text{ f/cm}$

0948 Water ht = 32.40 cm

System just critical
Drain

1.30 cm separation e-e.
30 cm length

Removed 8 rods. Have
of 392 rods. (See diagram)

1040

Water ht = 43.80 cm
System sub critical
Drain

Added 2 rods. Have
Total of 394 rods.

Water ht = 43.80 cm

4 Per

$C = 328.12 \text{ sec} = 3.6 \text{ f} = .72 \text{ f/cm}$

1120

Water ht = 38.80 cm.
System just critical
Drain

Removed 1 rod. Have an
of 393 rods. (See diagram)

1130

Water ht = 44.10 cm
System sub critical
Drain

1.30 cm separation e-e.
30 cm length

Repeat of last run: (Pg 86-87)
oh = 1.9 cm

Water ht = 44.10 cm Temp °C
#1 = 25.1 °C
#2 = 25.1 °C
+ Per

$C = 2824.9 \text{ sec} = .46 \text{ ft} = .24 \text{ ft/cm}$

0835 Water ht = 42.20 cm
System just critical
Drain

Removed 1 rod. Have an 21x21 array. Total of 367 rods. (See diagram).

Water ht = 44.20 cm Temp °C
#1 = 25.1 °C
#2 = 25.1 °C
- Per

$C = -234.68 \text{ sec} = -6.7 \text{ ft}$
Total of 400 rods

0853 Drain: 22x22 array

Now have an 22x22 array. With the 11th & 12th rods removed in 2 directions. (See diagram). Total of 400 rods.

Water ht = 32.65 cm Temp °C
#1 = 25.1 °C
#2 = 25.1 °C
+ Per

$C = 100.48 \text{ sec} = 9.99 = 37.6 \text{ ft/cm}$

0948 Water ht = 32.40 cm
System just critical
Drain

1.30 cm separation e-e. 22x22 array
30 cm length. 22x22 array

Removed 8 rods. Have an 22x22 array. Total of 392 rods. (See diagram).

1040 Water ht = 43.80 cm Temp °C
#1 = 25.2 °C
#2 = 25.2 °C
System sub critical
Drain



Added #2 rods. New Total of 394 rods.

Water ht = 43.80 cm Temp °C
#1 = 25.2 °C
#2 = 25.2 °C
+ Per

1120 Water ht = 38.80 cm.
System just critical
Drain

Removed 1 rod. Have an array of 393 rods. (See diagram)

1130 Water ht = 44.10 cm Temp °C
#1 = 25.2 °C
#2 = 25.2 °C
System sub critical
Drain



1.30 cm separation c-c.
30 cm length

Repeat of last run: (pg 86-87)
b.h. = 1.9 cm

Water ht = 44.10 cm
+ Per Temp °C
#1 = 25.1 °C
#2 = 25.1 °C
 $C = 2824.9 \text{ sec} = .46 \text{ f} = .24 \text{ f/cm}$

0835 Water ht = 42.20 cm
System just critical
Drain

Removed 1 rod. Have an array of 367 rods. (See diagram).

Water ht = 44.20 cm
- Per Temp °C
#1 = 25.1 °C
#2 = 25.1 °C
 $C = -234.68 \text{ sec} = -6.7 \text{ f}$

0853 Drain:

Now have an 22x11 array of rods. (See diagram). Total of 242 rods.

Water ht = 32.65 cm
+ Per Temp °C
#1 = 25.1 °C
#2 = 25.1 °C
 $C = 106.48 \text{ sec} = 9.4 \text{ f} = 37.6 \text{ f/cm}$

0948 Water ht = 32.40 cm
System just critical
Drain

1.30 cm separation c-c.
30 cm length

Removed 8 rods. Have an array of 392 rods. (See diagram). Total of 392 rods.

1040 Water ht = 43.80 cm
System sub critical
Drain Temp °C
#1 = 25.2 °C
#2 = 25.2 °C
b.h. = 5.0 cm

Added 2 rods. Have an array of 394 rods. (See diagram).

Water ht = 43.80 cm
+ Per Temp °C
#1 = 25.2 °C
#2 = 25.2 °C
 $C = 328.12 \text{ sec} = 3.6 \text{ f} = .12 \text{ f/cm}$


1120 Water ht = 38.80 cm.
System just critical
Drain

Removed 1 rod. Have an 22x22 array. Total of 393 rods. (See diagram).

1130 Water ht = 44.10 cm
System sub critical
Drain Temp °C
#1 = 25.2 °C
#2 = 25.2 °C

1,30 cm separation, c.c.
30 cm lengths.

Now have an 20 x 20 array,
now removed in 2 depths being
on 3 x 3 array, with 36 rods.
Total of 324 rods. (See d, ^{4 & 19th})



Water ht = 44.00 cm
5 + Per

DL = 6.6 cm

Temp °C
#1 = 25.2°C
#2 = 25.2°C

C = 149.99 sec = 7.14 = 1.07 / sec.

1343 Water ht = 37.40 cm
System just critical
Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3x10 ⁻¹²	✓	4"	✓	3x10 ⁻¹²
"	"	✓	1"	✓	"
K-2		✓			
R-1					
R-2					
PM-1	700v	Alarm ✓	5"	✓	500v
PM-2	1200v	Low ✓	10.0"	✓	900v
"	"	Alarm ✓	10"	✓	"
LOG IN CALIBRATE ✓		OPERATE ✓		SOURCE No. B-80	
DUMP WELL PROBE LIGHT _____					

START-UP CHECK LIST

Equipment checked by ^{T.D.C.} AKM Personnel check by T.D.C.
 Instruments and safeties checked and reset by AKM
 Source in checked by AKM Source No. M-93
 Emergency equipment in control room checked by T.D.C.
 Instruments in trip circuit: K-1 PM-1-2
 Red light on by AKM Time 1320
 Start-up OK'd by T.D.C. AKM Date 8-16-72

90

1.30 cm separation c.c.
30 cm length.

total
total of 324
removed
in 2 directions
7th & 19th
rows
20x20 array

Now have an 20x20 array, with the 7th & 19th
rows removed in 2 directions, thus giving
an 3x3 array, with 36 rods in each square.
Total of 324 rods. (see diagram).


Water ht = 44.00 cm
5 + Per

Temp °C
#1 = 25.2°C
2 = 25.2°C

$C = 149.99 \text{ sec} = 7.17 = 1.07 \text{ / sec.}$

1343 Water ht = 31.40 cm
System just critical
Drain.

2,050 cm separation c-c.
30 cm length.
.30" rods. (incl. d.)
H₂O only.



Have an 14 X 14 array. (7 rods on right side.)
Total of 203 rods.

D_b = 6.15 cm

Water ht = 43.85 cm
+ Per


Temp °C

#1 = 25.5 °C
#2 = 25.7 °C

$\epsilon = 304.22 \text{ mm} = 3.87 = .62 \text{ f/cm}$

1358 Water ht = 37.70 cm

System just critical
Drain.



Now have an 17 X 17 array, with 10 rods removed in 2 directions. Total 256 rods.

D_b = 6.6 cm

Water ht = 43.80 cm
+ Per

Temp °C


#1 = 25.6 °C
#2 = 25.7 °C

$\epsilon = 197.74 \text{ mm} = 5.6 \text{ f} = .85 \text{ f/cm}$

1505 Water ht = 37.20 cm

System just critical
Drain.

2,050 cm separation c-c.
30 cm length



Removed 1 rod. Now a 14x14 array. Total of 255 rods. (See diagram)

Water ht = 44.00 cm

Temp °C

- Per

#1 = 25.3 °C

$\epsilon = -162.97 \text{ mm} = -10.8 \text{ f}$

#2 = 25.1 °C

2.050 cm separation c-c.
30 cm length.
.30" rods. (enclosed)
H₂O only.

page 92
Fig #5
14x14 array

Have an 14x14+7 array. (7 rods on 1 face.)
Total of 203 rods.

D.G. = 6.15 cm

Water ht = 43.85 cm
+ Per

Temp °C

#1 = 25.5 °C
#2 = 25.7 °C

$t = 304.22 \text{ sec} = 3.87 = .62 \text{ f/cm}$

1358 Water ht = 37.70 cm

System just critical
Drain.

page 95
Fig #5
57 array 20x11

Now have an 17x17 array, with the 9th row
removed in 2 directions. Total of 256
rods.

D.G. = 6.6 cm

Water ht = 43.80 cm
+ Per

Temp °C

#1 = 25.6 °C
#2 = 25.7 °C

$t = 197.74 \text{ sec} = 5.67 = .85 \text{ f/cm}$

1505 Water ht = 37.20 cm

System just critical
Drain.

2.050 cm separation c-c.
30 cm length

Fig Book #5
17x17 array
255 rods.

Removed 1 rod. (Row on 17x17 array). Total of
255 rods. (See diagram).

Water ht = 44.00 cm
- Per

Temp °C

#1 = 25.3 °C
#2 = 25.1 °C

$t = -162.97 \text{ sec} = -10.87$

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	3x10 ⁻¹²
"	"	Fast ✓	1"	✓	"
K-2		Meter			
		Fast			
R-1					
R-2					
PM-1	700V	Alarm ✓	5"	✓	500V
PM-2	1200V	Low ✓	10"	✓	900V
"	"	Alarm ✓	1"	✓	"


LOG N CALIBRATE OPERATE SOURCE No. B-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by F.D.C. Personnel check by R.K.M.
 Instruments and safeties checked and reset by R.K.M.
 Source in checked by R.K.M. Source No. M-93
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuits: K-1 PM 1-2
 Red light on by R.K.M. Time 0830
 Start-up OK'd by F.D.C. R.K.M. Date 8-17-72

2.050 cm separation e-e.
 30 cm length.



Have an 22x22 array, with
 now removed in 2 directions
 Total of 400 rods.

dg = 0.05 cm

Water ht = 31.80 cm

+ Per

C = 126.03 sec = 8.24 = 164.0 ppm


0910

Water ht = 31.75 cm

System just critical
 Drain.

#1 = 25.6 °C

2 = 25.7 °C



Removed 8 rods. Have
 of 392 rods. (see diagram)

dg = 8.25 cm

Water ht = 44.00 cm

+ Per

C = 71.71 sec = 12.74 = 1.54 ppm

0930

Water ht = 35.75 cm

System just critical
 Drain.

#1 = 25.6 °C

2 = 25.7 °C

Removed 2 rods. Have an 22x22 array.
 Total of 390 rods. (see diagram).

over:

PART-UP RANGE
 X10⁻¹²
 10⁰
 10¹
 10²
 10³
 10⁴
 10⁵
 10⁶
 10⁷
 10⁸
 10⁹
 10¹⁰
 10¹¹
 10¹²

2.050 cm spec
 30 cm length

400 rods
 for top of
 22x22 array
 5 # array top

Have an 22x22 array, with etc 11th & 12th etc.
 now removed in 2 direction (see diagram)
 Total of 400 rods.

$d_s = 0.05 \text{ cm}$

Water ht = 31.80 cm
 + per

Temp °C

#1 = 25.6 °C
 #2 = 25.7 °C

$C = 126.03 \text{ sec} = 8.24 = 164.04$

0910

Water ht = 31.75 cm
 system just critical
 Drain.

400 rods
 for top of
 22x22 array
 5 # array top
 5 # etc

Removed 8 rods: Have an 22x22 array, total
 of 392 rods. (see diagram).

$d_s = 8.25 \text{ cm}$

Water ht = 44.00 cm
 + per

Temp °C

#1 = 25.6 °C
 #2 = 25.7 °C

$C = 71.71 \text{ sec} = 12.74 = 1.54 \text{ cm}$

0930


Water ht = 35.75 cm
 system just critical
 Drain.

Removed 2 rods: Have an 22x22 array.
 Total of 390 rods. (see diagram).

over:


2.050 cm separation e-e
30 cm lengths

Water ht = 44.10 cm
3 - Per
E = -415.04 sec = -3.94




Added 1 rods: Have an 22x22 array. Total of 391 rods. (see diagram).
Δh = 6.1 cm

Water ht = 44.10 cm
4 + Per
E = 256.91 sec = 4.54 = 1.74 / cm



1024 Water ht = 38.00 cm.
System just critical
Drain.

Now have an 20x20 array, with 14 rods removed in 2 directions, removed an 3x3 array, with 36 rods in 3 directions.
Total of 324 rods. (see diagram).
Δh = .05 cm




Water ht = 29.90 cm
5 + Per
E = 197.74 sec = 5.64 = 112.0 / cm

Temp °C
#1 = 25.5 °C
2 = 25.5 °C

1325 Water ht = 29.85 cm
System just critical
Drain

2.050 cm separation e-e
30 cm lengths


Removed 12 rods: 3 from each side of 20x20 array. Total of 310 rods. (see diagram).
Δh = .05 cm



Water ht = 30.40 cm
6 + Per
E = 99.96 sec = 9.94 = 198.0 / cm
Water ht = 30.35 cm.
System just critical
Drain.

1340


Removed 20 rods, 5 from each side of 20x20 array. Total of 292 rods. (see diagram).
Δh = .20 cm



1400

Water ht = 32.30 cm
7 + Per
E = 126.03 sec = 9.24 = 41.04 / cm
Water ht = 32.10 cm
System just critical
Drain.

Removed 10 rods: 4 from each side of 20x20 array. Total of 276 rods. (see diagram).



Water ht = 44.20 cm
8 - Per
E = -219.47 sec = -7.34

avr:

2.050 cm separation e-e
30 cm lengths

Water ht = 44.10 cm
3 - Per
 $\tau = -415.04 \text{ mm} = -3.94$

Temp °C
#1 = 25.7 °C
2 = 25.7 °C

Added 1 row: Now an 22
of 391 rods. (see diagram).
 $\Delta h = 6.1 \text{ cm}$

96
Fog Bank #5
22 x 27 array
Total of 391
rods.

Water ht = 44.10 cm
4 + Per
 $\tau = 252.91 \text{ mm} = 4.54 = .74 \text{ g/cm}$

#1 = 25.7 °C
2 = 25.7 °C

1024 Water ht = 38.00 cm.
System just critical
Drain.

96
Fog Bank #5

Now have an 20x20 array, with the 7th & 14th
rows in 2 directions removed. Thus giving an
3x3 array, with 36 rods in each square.
Total of 324 rods. (see diagram)
 $\Delta h = .05 \text{ cm}$

96
Fog Bank #5

? Water ht = 29.90 cm
5 + Per
 $\tau = 197.74 \text{ mm} = 5.64 = 112.04 \text{ g/cm}$

Temp °C
#1 = 25.5 °C
2 = 25.5 °C

1325 Water ht = 29.85 cm
System just critical
Drain.

96
Fog Bank #5
22 x 27 array

2.050 cm separation e-e
30 cm lengths

Removed 12 rods: 3 from each corner.
20x20 array: Total of 312 rods. (see diagram).
 $\Delta h = .05 \text{ cm}$

97
Fog Bank #5
20 x 20 array

Water ht = 30.40 cm
6 + Per

Temp °C
#1 = 25.5 °C
2 = 25.6 °C

1340

$\tau = 99.96 \text{ mm} = 9.94 = 198.04 \text{ g/cm}$
Water ht = 30.35 cm.
System just critical
Drain.

97
Fog Bank #5
20 x 20 array

Removed 20 rods: 5 from each corner.
20x20 array: Total of 292 rods. (see diagram).
 $\Delta h = .20 \text{ cm}$

Water ht = 32.30 cm
7 + Per

Temp °C
#1 = 25.5 °C
2 = 25.6 °C

1400

$\tau = 126.03 = 8.24 = 41.04 \text{ g/cm}$
Water ht = 32.10 cm
System just critical
Drain.

97
Fog Bank #5
20 x 20 array

Removed 16 rods: 4 from each corner.
20x20 array: Total of 276 rods.

Water ht = 44.20 cm
8 - Per


Temp °C
#1 = 25.6 °C
2 = 25.7 °C

$\tau = -219.47 \text{ mm} = -7.34$

arr:

2050 cm separation c-c.
30 cm length

Added 2 rods. 1 each to oppo
an 20 X 20 array with #
2 corners and 15 rods in
Total of 278 rods (see a



Have
from
corners.

D.L. = 6.6 cm

Water ht = 44.00 cm
9+ per

Temp °C

#1 = 25.5


T = 302.05 mV = 3.94 = .59 f/cm

#2 = 25.7 °C

1502 Water ht = 37.50 cm

System just critical
Drain

Removed 1 rod. Have an 20
rods removed from 3 co
removed from 1 corner.
(see diagram)



12
11 rods
rods

Water ht = 44.50 cm
10+ per

Temp °C

#1 = 25.5 °C

T = -760.55 mV = -1.8 f

#2 = 25.7 °C

1522 Drain

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3 X 10 ⁻¹²	Meter <input checked="" type="checkbox"/>	4"	<input checked="" type="checkbox"/>	3 X 10 ⁻¹²
"	"	Fast <input checked="" type="checkbox"/>	1"	<input checked="" type="checkbox"/>	"
K-2		Meter			
		Fast			
R-1					
R-2					
PM-1	700V	Alarm <input checked="" type="checkbox"/>	5"	<input checked="" type="checkbox"/>	500V
PM-2	1200V	Low <input checked="" type="checkbox"/>	10"	<input checked="" type="checkbox"/>	900V
"	"	Alarm <input checked="" type="checkbox"/>	1"	<input checked="" type="checkbox"/>	"

LOG IN CALIBRATE OPERATE SOURCE No. P-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

FIDIC
Equipment checked by AKA Personnel check by AKA
Instruments and safeties checked and reset by AKA
Source in checked by AKA Source No. M-43
Emergency equipment in control room checked by AKA
Instruments in trip circuit: Z-1 PM-1-2
Red light on by AKA Time 0905
Start-up OK'd by I.D.C. AKA Date 8-18-72

98

2050 cm separation e-c.
30 cm length

278 rods
of 20x20
array

Added 2 rods. 1 each to opposite corners. Have
an 20x20 array, with ~~12~~ rods removed from
2 corners and ~~11~~ rods removed from 2 corners.
Total of 278 rods (see diagram).

$D_s = 6.6 \text{ cm}$

Water ht = 44.00 cm
9-per

Temp °C

#1 = 25.5

$$T = 302.05 \text{ sec} = 3.94 = .59 \text{ f/cm}$$

#2 = 25.7 °C

1502 Water ht = 37.50 cm
system just critical
Drain.

277 rods
of 20x20
array

Removed 1 rod. Have an 20x20 array, with 12
rods removed from 3 corners, and 11 rods
removed from 1 corner. Total of 277 rods
(see diagram)

Water ht = 44.50 cm
10-per

Temp °C


#1 = 25.5 °C

$$T = -760.55 \text{ sec} = -1.8 \text{ f}$$

#2 = 25.7 °C

1522 Drain

2.050 cm separation c.c.
30 cm length.

Have an 20x20 array, w.i.  added
Total of 308 rods. (See diagram)

Water ht = 33.80 cm

+ Per

$\epsilon = 158.63 \text{ sec} = 6.84 = 17.0 \text{ f/cm}$
33.40 cm

0941

Water ht = 33.45 cm

System just critical
Drain

Removed 8 rods. Have an 20x20 array
of 300 rods. (See diagram)

Water ht = 44.10 cm

+ Per

$\epsilon = 171.67 \text{ sec} = 10.0 \text{ f}$

Added 2 rods. Have an 22x22 array. Total of
302 rods. (See diagram)

Water ht = 44.10 cm

+ Per

$\epsilon = 397.66 \text{ sec} = 3.0 \text{ f} = .58 \text{ f/cm}$

1051

Water ht = 38.90 cm

System just critical
Drain

Removed ~~1~~ 1 rods.
Total of 301 rods. (See diagram)

Water ht = 44.60 cm

+ Per

$\epsilon = -299.87 \text{ sec} = -5.0 \text{ f}$

1115

Drain

30" rods.

1.300 cm separation c-c.

30 cm length.

H₂O Only

Have an 23x23 array, 11 rods
removed in 2 directions, To
(See diagram)

1904 Water ht = 44.10 cm

System sub critical
Drain

#1 = 25.7°C

#2 = 25.8°C

Temp °C

#1 = 25.6°C

#2 = 25.7°C

2.050 cm separation c.c.
30 cm length.

grat 80E
hous 02x02
5# grat top

Have an 20x20 array with 16 rods removed
Total of 308 rods. (see diagram.)

Water ht = 33.80 cm
+ Per

Temp °C
#1 = 25.5 °C
#2 = 25.5 °C

$\tau = 158.63 \text{ sec} = 6.84 = 17.04 \text{ /cm}$

0941

Water ht = 33.45 cm

grat 80E
hous 02x02
5# grat top

System just critical
Drain

Removed 8 rods. Have an 20x20 array. Total of 300 rods. (see diagram.)

Water ht = 44.10 cm
+ Per

Temp °C
#1 = 25.5 °C
#2 = 25.5 °C

$\tau = 171.67 \text{ sec} = 10.04$

grat 20E
hous 02x02
5# grat top
001 bot

Added 2 rods. Have an 20x20 array. Total of 302 rods. (see diagram.)

Water ht = 44.10 cm
+ Per

Temp °C
#1 = 25.6 °C
#2 = 25.7 °C

$\tau = 397.66 \text{ sec} = 3.04 = .58 \text{ /cm}$

1051

Water ht = 38.90 cm
System just critical
Drain

grat 10E
hous 02x02
5# grat top

Removed ~~1~~ rods. Have an 20x20 array.
Total of 301 rods. (see diagram.)

Water ht = 44.60 cm
+ Per

Temp °C
#1 = 25.7 °C
#2 = 25.8 °C

$\tau = -299.87 \text{ sec} = -5.04$

1115

Drain

30" rods.
1.300 cm separation
30 cm length.
H2O Only

grat 80E
hous 02x02
5# grat top

Have an 23x23 array, 11th, 12th, 13th row removed in 2 directions. Total of 400 rods. (see diagram.)

1404

Water ht = 44.10 cm
System sub critical
Drain

Temp °C
#1 = 25.7 °C
#2 = 25.8 °C

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-13	110-12	Meter ✓	4"	✓	3 A.10-12
"	"	Fast ✓	1"	✓	"
K-2		Meter			
		Fast			
R-1					
R-2					
PM-1	700 V ✓	Alarm ✓	15"	✓	500 V
PM-2	1200 V ✓	Low ✓	10"	✓	900 V
"	"	Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. 0-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by F.D.C. Personnel check by F.D.C.

Instruments and safeties checked and reset by AKM

Source in checked by AKM Source No. M-43

Emergency equipment in control room checked by F.D.C.

Instruments in trip checked: K-1 PM-1-2

Red light on by AKM Time 0920


Start-up OK'd by F.D.C. AKM Date 8-21-72

1.30 rods.
1.30 cm separation c-a.
30 cm length.
H₂O only.

Have an 22x23 array. 11th, 12, 13th row removed in one (1) direction, and the 11th & 12th row removed in the other. Total of 400 rods. (See diagram).


0953 Water ht = 44.00 cm
System sub critical
Drain

Temp °C
#1 = 25.5°
2 = 25.5°



Now have an 20x23 array, with the 11th & 12th row removed in one direction. Total of 400 rods. (See diagram).

Water ht = 44.30 cm
System sub critical
Drain.



act.

30 rods.
1.30 cm separation c-c.
30 cm length.
H₂O only.

Have an 22x23 array. 11th, 12, 13th row removed in one (1) direction, and the 11th & 12th row removed in the other. Total of 400 rods. (See diagram).

0953 Water ht = 44.00 cm
System sub critical
Drain

Temp °C
Log bank # 5 5.5°
23 x 22 array 5.5°
Total rods 400

Have an 20x23 array,
12th, 13th row removed.
Total of 400 rods. (See diagram)

11th row, 11th col.

Water ht = 44.30 cm
System sub critical
Drain.

α = 25.5°
α = 25.5°

etc.

1.30 cm separation c-c.
30 cm length

Now have an 23 x 23 array;
9th, 12th, 15th, 18th, & 21th
in 2 directions: total of
(see diagram).

$d_h = 1.0 \text{ cm}$

Water ht = 30.05 cm

then

$U = 169.49 \text{ w} = 6.44 = 64.0 \text{ f/cm}$

1403

Water ht = 29.95 cm
system just critical
Drain.

Removed 4 of the 2 x 2 clusters
(6 rods) see diagram: total

$d_h = 7.5 \text{ cm}$



Water ht = ~~43~~ 43.80 cm

+ Per

$U = 113.00 \text{ w} = 9.06 = 1.24 \text{ f/cm}$

1435

Water ht = 36.30 cm
system just critical
Drain.



Temp °C

#1 = 25.5 °C

2 = 25.5 °C

#1 = 25.2 °C

2 = 25.5 °C

1.30 cm separation c-c.
30 cm length.

Removed 2 rods (1/2 of
(see diagram) total of

Water ht = 44.20 cm

3-Per

N.G.

1450



Drain:

Added 1 rod, (see diagram) of 239 rods.

Water ht = 44.20 cm

4-Per

$U = -814.87 \text{ w} = -1.74$



25.2 °C

2 = 25.5 °C

Temp °C

#1 = 25.5 °C

2 = 25.5 °C

1.30 cm separation c-c.
30 cm length

25°C
Top of
23x23 array
5 # rods top
104

Now have an 23 x 23 array; with the 3rd, 6th,
9th, 12th, 15th, 18th, & 21st rows removed
in 2 directions; total of 256 rods.
(see diagram).

0.4 = 10 cm

Water ht = 30.05 cm

Temp °C

Per

#1 = 25.5°C
#2 = 25.5°C

$C = 169.99 \text{ cm} = 6.9 \text{ ft} = 64.0 \text{ off cm}$

1403

Water ht = 29.95 cm

System just critical
Drain.

Top of
23x23 array
240 # rods
25°C

Removed 4 of the 2x2 clusters of rods (total of
16 rods) see diagram. total of 240 rods.

0.4 = 7.5 cm

Water ht = ~~43~~ 43.80 cm

Temp °C

Per

#1 = 25.2°C
#2 = 25.5°C

$C = 113.00 \text{ cm} = 9.0 \text{ ft} = 1.2 \text{ ft/cm}$

1435

Water ht = 36.30 cm

System just critical
Drain.

1.30 cm separation c-c.
30 cm length.

25°C
Top of
23x23 array
5 # rods top

Removed 2 rods (1/2 of an 2x2 cluster).
(see diagram) total of 238 rods.

Water ht = 44.20 cm

Temp °C

Per

#1 = 25.2°C

N.G.

#2 = 25.5°C

1450

Drain:

Top of
23x23 array
239 # rods

Added 1 rod. (see diagram) total of 239 rods.

Water ht = 44.20 cm

Temp °C

Per

#1 = 25.5°C

$C = -814.87 \text{ cm} = -1.7 \text{ ft}$

#2 = 25.5°C

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter ✓	4"	✓	3×10^{-12}
"	"	Foot ✓	1"	✓	"
K-2		Meter			
		Foot			
R-1					
R-2					
PM-1	7000	Alarm ✓	5"	✓	5000
PM-2	12000	Alarm ✓	10"	✓	9000
"	"	Alarm ✓	1"	✓	"
LOG IN CALIBRATE		✓	OPERATE	✓	SOURCE No. <u>B-80</u>
DUMP WELL PROBE LIGHT _____					

START-UP CHECK LIST

Equipment checked by ^{F.D.C.} AKM Personnel check by F.D.C.

Instruments and safeties checked and reset by AKM

Source in checked by AKM Source No. M-43

Emergency equipment in control room checked by F.D.C.

Instruments in trip circuit: K-1 PM-1-2

Red light on by AKM Time 1300

Start-up OK'd by F.D.C. AKM Date 8-29-72

In Well (2 mi)

1.30 cm separation c-c. - 107
30 cm lengths
130" rods.
H₂O only.

Support for lat lines

Top of rods = 25.60 cm rebuilt to bulk Pb

Have an 20 x 20 array. Total of 40 rods.

$$A_h = 7.90 \text{ cm}$$

Water ht = 41.30 cm

1 + Per

$$T = 71.71 \text{ sec} = 12.7 \text{ f} = 1.6 \text{ f/cm}$$

1425 Water ht = 33.50 cm 790 cm. 2 f, 1 f 3

System just critical 3.1" reflector (top)
Drain.

Removed 2 rods. Have an 20 x 20 - 2 array.

Total of 398 rods.

$$A_h = 5.65 \text{ cm}$$

Water ht = 41.50 cm

2 + Per

Temp °C

$$\#1 = 25.0^\circ \text{C}$$

$$T = 359.54 \text{ sec} = 3.3 \text{ f} = 1.6 \text{ f/cm}$$

$$\#2 = 25.1^\circ \text{C}$$

1446 Water ht = 35.85 cm 9.25 cm

System just critical
Drain.

6" top reflector = 40.8 cm (manometer scale)

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3X10 ⁻¹²	Meter ✓ Fast ✓	3' 5'	✓	3X10 ⁻¹²
K-2		Meter Fast			
R-1					
R-2					
PM-1	900V	Alarm ✓	Cont ✓		500V
PM-2	200V	Low ✓			900V
"	"	Alarm ✓			"
LOG N CALIBRATE ✓		OPERATE ✓		SOURCE No. M-43	
DUMP WELL PROBE LIGHT ✓					

START-UP CHECK LIST

Equipment checked by ^{J.T.} AKR Personnel check by ^{J.T.} AKR
 Instruments and safeties checked and reset by AKR
 Source in checked by AKR Source No. M-43
 Emergency equipment in control room checked by AKR
 Instruments in trip circuit: K-1 PPE-1-2
 Red light on by AKR Time 0920
 Start-up OK'd by J.T.E.R.P. AKR Date 8-25-72

30" Rods.
 1.30 cm separation e-e,
 30 cm length.
 H₂O only; + Pb

1119

Have on 20 x 20 - 2 array. (see diagram). Total of 398 rods. Have on 1 face (spaced, 26.8 cm from face) on 8" x 10" x 16" lead reflector.

Water ht = $30.25 \text{ cm} + 1.40$
 $\pm 31.65 \text{ cm}$ Temp °C
 #1 = 25.0 °C
 #2 = 25.0 °C
 $\bar{v} = 78.23 \text{ sec} = 11.9 \text{ f} = 29.7 \text{ f/cm}$

1.15 Water ht = $\pm 29.85 \text{ cm} = 4.25 \text{ cm}$.
 System just critical
 Drain

Repeat of above:

Water ht = 30.95 cm Temp °C
 #1 = 25.0 °C
 #2 = 25.0 °C
 $\bar{v} = 91.27 \text{ sec} = 10.6 \text{ f} = 53.0 \text{ f/cm}$

Water ht = $30.75 \text{ cm} = 5.15 \text{ cm}$.
 System just critical
 Drain.

Repeat of above .05 ?

Water ht = 30.75 cm Temp °C
 #1 = 25.2 °C
 #2 = 25.5 °C
 $\bar{v} = 302.05 \text{ sec} = 3.9 \text{ f} = 78.0 \text{ f/cm}$

Water ht = $30.70 \text{ cm} = 5.10 \text{ cm}$.
 System just critical
 Drain.

ans.

Repeat:

$d_s = 60 \text{ cm}$

Water ht = 31.15 cm

* + pen

$L = 49.98 \text{ cm} = 16.94 = 27.39/\text{cm}$

Water ht = 30.55 = 4.95 cm

OK

System just critical
Drain:

Repeat:

$d_s = 20 \text{ cm}$

Water ht = 30.70 cm

OK
+ pen

$L = 102.13 \text{ cm} = 9.74 = 48.54/\text{cm}$

1525 Water ht = 30.50 = 4.90 cm

System just critical
Drain:

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter ✓	4"	✓	3×10^{-12}
	"	Fast ✓	1"	✓	"
K-2		Meter			
		Fast			
R-1					
R-2					
PM-1	700V	Alarm ✓	5"	✓	500V
PM-2	1200V	Low ✓	12"	✓	900V
	"	Alarm ✓	1"	✓	"
LOG N CALIBRATE ✓		OPERATE ✓		SOURCE No. B-80	
DUMP WELL PROBE LIGHT _____					

START-UP CHECK LIST

Equipment checked by ARKV Personnel check by F.D.C.
 Instruments and safeties checked and reset by ARKV
 Source in checked by ARKV Source No. M-43
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1 PM-1-2
 Red light on by ARKV Time 1440
 Start-up OK'd by F.D.C., ARKV Date 8-28-72

Backs of zero (top of rock) = 25.60 cm.

Repeat of last experiment P₀-109-110.

$r_b = 1.40$ cm

P_b over force

Water ht = 31.30 cm

Temp °C

OK

+ Per

$t_1 = 25.5$ s

$L = 123.86$ sec = $8.3 \phi = 20.7 \phi$ / cm

$t_2 = 25.5$ s

15:30

Water ht = 30.90 cm = 5.30 cm

system just critical
Drain

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3x10 ⁻¹²	Master ✓	3"	✓	3x10 ⁻¹²
"	"	Fast ✓	1"	✓	"
K-2		Master ✓			
		Fast ✓			
R-1					
R-2					
PM-1	700v	Alarm ✓	.5"	✓	500v
PM-2	1200v	Low ✓	10"	✓	900v
"	"	Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. B-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by I.D.C. [Signature] Personnel check by [Signature]

Instruments and safeties checked and reset by [Signature]

Source in checked by [Signature] Source No. M-43

Emergency equipment in control room checked by I.D.C.

Instruments in trip circuit: Z-1 PM-1-2

Red light on by [Signature] Time 0810

Start-up OK'd by I.D.C. [Signature] Date 8-29-72

Repeat of last run (p-112). Pb and fall
 $z_h = 40 \text{ cm}$

Water ht. = 31.10 cm

Temp °C

1 + Per

#1 = 25.1°

$L = 71.71 \text{ sec} = 12.7 \text{ ft} = 31.7 \text{ ft/cm}$

#2 = 25.1°

0847 Water ht. = 30.70 cm = 5.10 cm

System just critical
 Drain.

Repeat of experiment described on bottom
 of p-107. (20x20-v) N. Pb
 $z_h = 4.9 \text{ cm}$

Water ht. = 41.40 cm

Temp °C

2 + Per

#1 = 25.0°

$L = 321.60 \text{ sec} = 3.7 \text{ ft} = 1.8 \text{ ft/cm}$

#2 = 25.0°

1018 Water ht. = 37.00 cm (1.15 cm diff) = 11.40 cm

System just critical
 Drain.

Repeat of above:

$z_h = 5.9 \text{ cm}$

Water ht. = 41.40 cm

Temp °C

3 + Per

#1 = 25.1°

$L = 471.54 \text{ sec} = 2.6 \text{ ft} = .5 \text{ ft/cm}$

#2 = 25.1°

1513 Water ht. = 36.00 cm (1.0 cm diff) = 10.40 cm

System just critical
 Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3 x 10 ⁻¹²	Meter ✓	4"	-	3 x 10 ⁻¹²
"		Fast ✓	1"	✓	"
K-2		Meter			
		Fast			
R-1					
R-2					
PM-1	700 v	Alarm ✓	.5"	-	500 v
PM-2	1200 v	Low ✓	12"	-	900 v
"	"	Alarm ✓	1"	-	"
LOG N CALIBRATE		✓	OPERATE	✓	SOURCE No. <u>D-80</u>
DUMP WELL PROBE LIGHT _____					

START-UP CHECK LIST

Equipment checked by ^{F.I.D.C.} AKA Personnel check by F.I.D.C.

Instruments and safeties checked and reset by AKA

Source in checked by AKA Source No. M-43

Emergency equipment in control room checked by F.I.D.C.

Instruments in trip circuit: K-1 PM-1-2

Red light on by AKA Time 0820

Start-up OK'd by F.I.D.C. AKA Date 8-30-72

00
00

00
00

5.12
7.12

Repeat of last experiment ($p = 114$). (In Pb; 20×20)
 $d_1 = 4.8 \text{ cm}$

Water ht = 41.40 cm

Temp $^{\circ}\text{C}$

1 Per

#1 = 25.1 $^{\circ}$

$T = 562.81 \text{ sec} = 2.2 \phi = .46 \phi / \text{cm}$

#2 = 25.1 $^{\circ}$

0920

Water ht = 36.60 cm = 11.00 cm

OK

System just critical

Drain.

Removed 7 rods. Now have an $20 \times 20 - 9$
 array. (See diagram). Have on 1 face ~~rod~~
 (spaced 26.9 cm from face) an lead
 reflector $8" \times 10" \times 16"$.

Water ht = 41.40 cm $d_1 = 7.4 \text{ cm}$

Temp $^{\circ}\text{C}$

2 Per

#1 = 25.1 $^{\circ}$

$T = 102.13 \text{ sec} = 9.7 \phi = 1.3 \phi / \text{cm}$

#2 = 25.1 $^{\circ}$

Water ht = 34.00 cm = 8.40 cm

System just critical

Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter ✓	4"	✓	3×10^{-12}
	"	Fast ✓	1"	✓	"
K-2		Meter			
		Fast			
R-1					
R-2					
PM-1	700V	Alarm ✓	5"	-	500V
PM-2	1200V	Low ✓	12"	-	900V
	11	Alarm ✓	1"	-	"
LOG IN CALIBRATE ✓		OPERATE ✓	SOURCE No. B-80		
DUMP WELL PROBE-LIGHT _____					

10
10
10

START-UP CHECK LIST

Equipment checked by F.I.D.C. Personnel check by F.I.D.C.

Instruments and safeties checked and reset by R.K.N.

Source in checked by R.K.N. Source No. 1A-93

Emergency equipment in control room checked by F.I.D.C.

Instruments in trip circuit: R-1 PM-1-2

Red light on by R.K.N. Time 0810

Start-up OK'd by F.I.D.C. R.K.N. Date 8-31-72

10
10
10

Repeat of last run. (p-116.)

oh 7.0cm

(15x229)+16

Water ht = 41.50cm

Temp °

+ Res

#1 = 25.1°

$T = 123.86 \text{ sec} = 8.34 = 1.24/\text{cm}$

#2 = 25.1°

0.858 Water ht = 34.50 cm = 8.90 cm

System just critical
Chais.

START-UP CHECK LIST

INSTRUMENT	RANGE	PREPARED BY	SOURCE	SET	START-UP
INSTRUMENT	RANGE	TRIP	SOURCE	SET	START-UP
K-1					
K-2					
K-3					
K-4					
OUT					
RE-1		Alarm			
RE-2		Alarm			
RE-3		Alarm			
RE-4		Alarm			
LOG #		OPERATE	SOURCE No.		
LOG #		OPERATE	SOURCE No.		
DUAL WALL PROBE LIGHT					

START-UP CHECK LIST

Equipment checked by: _____

Equipment and safeties checked and reset by: _____

Safeties checked and reset by: _____

Source checked by: _____ Source No. _____

Geoprobe and control in control room checked by: _____

Instrument in trip circuit: _____

Start-up by: _____

Start-up by: _____

9/6/72

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	STARTUP RANGE
K-1	3x15 ^{-12"}	Meter ✓	3"	✓	3x12 ^{-12"}
		Fast ✓	1/2"	✓	
K-2	—	Meter ✗			
		Fast			
R-1	—				
R-2	—				
PM-1	700V	Alarm ✓	1/2"	✓	500V
PM-2	1200V	Low ✓	12"	✓	900V
		Alarm ✓	1"	✓	

LOG N CALIBRATE OPERATE SOURCE No. B-80

DIAGNOSTIC PROBE LIGHT

START-UP CHECK LIST

Equipment checked by IDC, EJ Personnel check by IDC

Instruments and safeties checked and reset by EJ

Source is checked by Source No. M-43

Emergency equipment in control room checked by IDC

Instruments in trip circuit: K-1, PM-1, PM-2

Red light on by EJ Time 1350

Start-up OK'd by EJ, IDC Date 9/6/72

9/6/72

Will try to repeat p. 118, then go on to evaluate the 7 rods removed since only H₂O reflected.

$$T = 22.3 \text{ m} \quad \mu = 3.6 \mu$$

1423

Water @ 44.6 + Period #1

$$T = 25.0^\circ \text{C} (102)$$

Attempted to level. Water @ 44.5 cm, 1st period.

Inspection of ring showed no visible air bubbles. Lowered water H \approx 40 cm, no further change in ref. period. Water up to 45 cm, no change in ref. period.

1450

Drain to \approx bottom of rods.

1530

Repeat

1540

Water @ 44.7 cm. Removed source. Level mark-1

dropped from \approx 30 (3×10^{-10}) H \approx 26 (3×10^{-10}). Newton pipe constant? Essentially a repeat of above. Same result, only difference was in source removal.

After \approx 7 min drifted up to \approx 29 mark-1. Log N agrees qualitatively, but level alone for 7-10 min. Slow upward drift. No change in water level.

Drain. Level started to decrease \approx 34 cm.

Inspection showed nothing \approx miss!

Did a rough check of water height from ring in tank. Confirmed an effectively infinite reflector.

122

9/8/72

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3 x 10 ⁻¹²	Mag ✓ Dist ✓	3'	✓	3 x 10 ⁻¹²
K-2	—	Mag Dist	Contact	✓	—
R-1	—	—	—	—	—
R-2	—	—	—	—	—
PM-1	700 V	Alarm ✓	1/2"	✓	700 V
PM-2	1200 V	Low ✓ Alarm ✓	12"	✓	1200 V

LOG N CALIBRATE OPERATE SOURCE No. B80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by IDC, EJ Personnel check by IDC
 Instruments and safeties checked and reset by EJ
 Source in checked by EJ Source No. M43
 Emergency equipment in control room checked by IDC
 Instruments in trip circuit: K-1, PM-1, PM-2
 Red light on by EJ Source M43
 Start-up OK'd by EJ, IDC Date 9/8/72

91

9

9/11/72

Same lattice as p. 121. Recheck.

1515

Water @ 37.5 cm; too low a point

1516

" @ 38.8 cm; + Period #1, 4.42. $T = 25.0^\circ\text{C}$

1527

Water @ 35.55 cm. Critical. $T = 27.5^\circ\text{C}$

1529

Drain water to 34.5 cm. Subcritical, too much for my point

1531

Dump.

By direct measurement of ring on tank, water was 52.2 cm from bottom of tank. Top of rods 43.7 from bottom of tank. \therefore By direct measurement, the top reflector was 8.3 cm and by manometer was 11.9 cm. \therefore trouble is in manometer line somewhere.

9/11/72

Removed 19 rods; 15 x 10 lattice.

Ran test in "well" checking reproducibility of H_2O ht., by reading manometer, and by direct measure (meter stick). Results showed no significant error in manometer reading. The greatest difference in direct reading .2 cm.

9-14-72

Installed and calibrated probe. To promote direct read-out of H_2O ht. Difference between probe reading + direct reading (meter stick) was less than .1 cm. These measurements can be found in activity log book page-20.

9/22/72

INSTRUMENT CHECK LIST

INSTRUMENT	RANGE	UNIT	TEST	SET	START-UP RANGE
K-1	3 x 10 ⁻¹²	MV	✓	4"	3 x 10 ⁻¹²
	"	FS	✓	1"	"
K-2	/	Met	✓		
		Fit			
R-1	/				
R-2	/				
PM-1	700V	Alarm	✓	2"	500V
PM-2	1200V	Low	✓	10"	900V
		Alarm	✓	1"	
LOG IN CALIBRATE		✓	OPERATE	✓	SOURCE No. B 20
DUMP WELL PROBE LIGHT		/			

START-UP CHECK LIST

Equipment checked by IDC, EQ check by IDC
 Instruments and safety checked and used by EQ
 Source in checked by EQ M-43
 Emergency equipment in IDC
 Instruments in test circuit K-1, PM-1, PM-2
 Red light on by 10:50 IDC 10:50
 Summary check by EQ, IDC 9/22/72

9/22/72

Restored rods removed 9/12 for checking manometer. Now have same lattice as reported last run, p. 123, on 9/8/72; i.e., 20x20-9 rods.

11:24 Water @ 41.5 cm. + Period #1 $T = 25.0^\circ C$
 Probe 37.73 in. $T = 356 \text{ gm} = 3.0 \phi$ $Z = 25.0^\circ C$
 }
 " 37.71 " (too deep)
 0 37.735 ← Use

11:40 Water @ 36.5 cm; Critical
 Probe 35.73 in. food⁰
 Dump

7:03p Box/20 Sleek water.

7:40p Water (manometer) 41.5 cm. Period #2
 Probe Conduct no conduct $E = 15 \mu / \text{sec}$
 37.61 in 37.78 = 1.0 ϕ
 57 72
 61 77
 62 82
 67 74
 61 74
 67 78
 37.62 in 37.78 in
 41.2 cm 41.5 cm

2:43p	Stop	Critical	Water (manometer) =	34.65 cm	Slightly Supr.	T ₁ = 25.0
		(Draw)		34.50 35.50	Slightly Sub.	
2:44		(add)		34.60	Slightly Supr.	T ₂ = 25.1
2:46		(Draw)		34.55	Critical	00

(Cont)

2:52p Critical Water (manometer) (no valve operation) 34.55 cm

Probe Contact no contact

34.93 in

34.98 cm

34.89

35.03

Diff 1.3

34.88

34.98

34.92

35.03

34.89 / 34.90

35.02

34.3 cm

35.00 cm

34.6 in

(no valve action) fi
Water
(manometer)

2:57p

34.55 cm

3:11p Added water. Critical H₁ (manometer) 34.60 cm

3:13p Drain to ~ 2/1 cm. (Not dump!). Source in.

3:15p Added water to ~ 34.5 cm (actual 34.80)

3:43 T₁ = 75.0 °C T₂ = 75.1 °C

ln N = 1.2 / 1.4

Removed power slowly. Slightly super

3:45 Drain to H_w = 34.5 34.65 cm super

3:46 Drain to = 34.50 cm sub

3:48 add to = 34.55 cm Critical fi

3:53 Actually slightly sub

3:58p Added water to 34.55 cm manometer

Probe Contact no contact

34.92 in

34.98 cm

34.86

34.97

34.87

34.99

34.91

35.03

34.90

35.02

34.89

35.00 cm

34.3 cm

34.6 in

3:59

Shut down - Drain water

9/25/72

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3 x 10 ⁻¹	Meter	4" low Contact high		3 x 10 ⁻¹
	✓	Fast			
K-2		Meter	4" low		3 x 10 ⁻¹
		Fast	7" high		
R-1					
R-2					
PM-1	700 ✓	Alarm	1/2 in		570 ✓
PM-2	1200 ✓	Low	10 in		900 ✓
		Alarm	1"		

LOG IN CALIBRATE _____ OPERATE _____ SOURCE No. B-80
 DUMP WELL PROBE LIGHT _____

START-UP CHECK LIST

Equipment checked by DC Personnel check by DC
 Instruments and safeties checked and reset by EJ
 Source in checked by DC Source No. M-3
 Emergency equipment in control room checked by DC
 Instruments in trip circuit: (EJ) PM-1, 2, K-1, 2
 Red light on by DC Time 2:30 p
 Start-up OK'd by DC Date 9/25/72

9/15/74

1:30 p

Sub water

2:55

$H_w = 42.7 \text{ cm}$

P_1

Some out.

$E = 279.4 \text{ cm}$

$T_1 = 24.5^\circ\text{C}$

$T_2 = 25.0^\circ\text{C}$

$= 4.2 f$

3:03

Drain

$H_w = 35.4 \text{ cm}$

monometer -

Sub.

Probe	contact	no contact
	35.11	-
	35.15	35.31
	35.15	35.29

3:09

$H_w = 35.50 \text{ cm}$

plenty out

Probe	35.19	35.44
	35.19	35.39
	35.29	35.42
	35.31	35.42
	35.29	35.42
	35.29	35.42
	35.29	35.42
	35.29	35.42

3:16

$H_w = 35.50 \text{ cm}$

monometer

3:17

$H_w = 35.60 \text{ cm}$

Control

Probe	35.21	35.45
	35.30	35.41
	35.28	35.41
	35.24	35.50
	35.32	35.47
	35.27	35.45

3:23

$H_w = 35.65 \text{ cm}$

plenty paper

Probe	35.26	35.40
	35.26	35.50
	35.28	35.43
	35.28	35.43
	35.27	35.41

Conversion of probe to Sight Glass:
 P(2.54) - 543 - 5.4 in cm

129
 Probe ~~46.325~~ = 46.325
 (Direct reading)

~ 3535 Drained to ~ 30 cm, shook grid plate

1550 Water @ 41.7 cm + Period #2

Probe:	In	OUT	$\bar{L} = 156.90 \text{ cm}$
	37.72	37.63	$= 6.9 f$
	.74	.63	
	.76	.84	
	.77	.82	
	.76	.80	
	.76	.80	
	.78	.80	
	<u>37.76</u>	<u>37.82</u>	
	41.61 cm		

1600 Water @ 34.65 cm. maintained

Probe 34.98 - 34.55 cm $T = 24.7^\circ \text{C}$
25.0

Water 34.65 cm
 Probe = 34.51

<u>In</u>	<u>OUT</u>
34.92	34.97
.91	.96
.91	.95
<u>34.92</u>	<u>34.96</u>

Slight lag

Water @ 34.65 cm Level

<u>In</u>	<u>OUT</u>
34.91	34.975
.94	.98
.92	.98
.92	.98
.92	.975
.92	.98
.93	.98

1615 Drain

$34.92 = 34.97$
 and 34.98

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3 x 10 ⁻¹²	Meter ✓	4"	✓	10 K 10 ⁻¹²
"	"	Fast ✓	5"	✓	"
K-2	"	Meter ✓	4"	✓	"
"	"	Fast ✓	1.0"	✓	"
R-1					
R-2					
PM-1	900 V	Alarm ✓	1.5"	✓	500 V
PM-2	1200 V	Low ✓	1.0"	✓	900 V
"	"	Alarm ✓	1.0"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. B-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by A.K.A. Personnel check by I.O.C.
 Instruments and safeties checked and reset by A.K.A.
 Source in checked by A.K.A. Source No. 19-43
 Emergency equipment in control room checked by I.O.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by A.K.A. Time 1410
 Start-up OK'd by I.O.C., A.K.A. Date 9-27-72

Repeat of last run: (Now have rods wedge in place with small pc of wood at top tube sheet.)

Water ht = 40.90 cm ^{probe} 37.48 Temp °C
 + Per 40.90 #1 = 25.0 °C
 T = 132.55 m = 7.9 f = 1.2 g/cm.

1505 Water ht = ± 34.40 cm ^{probe}
 system just critical 34.86 in.
 Drain 34.24 cm

Repeat of above:

Water ht = 40.90 cm ^{probe} Temp °C
 + Per 37.49 in #1 = 25.1 °C
 T = 82.57 m = 11.6 f = 1.6 g/cm. 40.92 cm #2 = 25.2 °C

1548 Water ht = ± 33.70 cm ^{probe}
 system just critical 34.59 in
 Drain 33.56 cm

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter ✓	4.0'	✓	3×10^{-12}
"	"	Fast ✓	.50"	✓	"
K-2	"	Meter ✓	4.0"	✓	"
"	"	Fast ✓	1.0"	✓	"
R-1					
R-2					
PM-1	700 V	Alarm ✓	5"	✓	500 V
PM-2	1200 V	Low ✓	10"	✓	900 V
"	"	Alarm ✓	1.0"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. B-80
 DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by RKL Personnel check by I.P.C.
 Instruments and safeties checked and reset by RKL
 Source in checked by RKL Source No. M-43
 Emergency equipment in control room checked by I.P.C.
 Instruments in trip circuit: R-1-2 PM-1-2
 Red light on by RKL Time 1710
 Start-up OK'd by I.P.C. RKL Date 9-28-72

1.30 cm separation e-e.
 30 cm lengths.
 .30" rods.
 H₂O only: (No Lead)

Repeat of experiment described on bottom of p-107 and 114. 20x20-2 orna; total of 398 rods. $\Delta h = 6.1 \text{ cm}$

Water ht = 40.90 cm Probe (in) Temp °C
 + Per 37.49 #1 = 25.0°C
 40.92 2 = 25.0°C
 $\epsilon = 193.90 \text{ ne} = 5.7 \mu = .9 \mu / \text{cm}$

1359 Water ht = 34.80 cm Probe (in) Temp °C
 system just critical 34.99 = 34.57
 Drain to ~ 26.20 cm. Shows grid plates. Some small air bubbles.

$\Delta h = 6.5 \text{ cm}$
 Water ht = 40.90 cm Probe (in) Temp °C
 + Per 37.45 #1 = 25.0°C
 40.82 2 = 25.0°C
 $\epsilon = 149.59 \text{ ne} = 7.1 \mu = 1.1 \mu / \text{cm}$

1430 Water ht = 34.40 cm Probe (in) Temp °C
 system just critical 34.87
 Drain all H₂O. 34.27
 Repeat of above:

$\Delta h = 6.05 \text{ cm}$
 Water ht = 40.90 cm Probe (in) Temp °C
 + Per 37.98 #1 = 25.0°C
 $\epsilon = 184.70 \text{ ne} = 6.0 \mu = 1.0 \mu / \text{cm}$
 2 = 25.0°C

1512 Water ht = 34.85 cm Probe (in) Temp °C
 system just critical
 Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3 X 10 ⁻¹²	Meter ✓	4"	-	10 X 10 ⁻¹²
"	"	" ✓	1"	-	"
K-2	"	Meter ✓	4"	-	10 X 10 ⁻¹²
"	"	" ✓	1"	-	"
R-1					
R-2					
PM-1	700V	Alarm ✓	5"	✓	500V
PM-2	1200V	Low ✓	10"	✓	900V
"	"	Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. D-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by F.D.C. AKM Personnel check by F.D.C.
 Instruments and safeties checked and reset by AKM
 Source in checked by AKM Source No. M-43
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by AKM Time 1408
 Start-up OK'd by F.D.C. AKM Date 10-5-72

1.30 cm separation e-e.
 30 cm length.
 .30" rods.

Have an 20 X 20 - 9 array. Total of 391 rods.
 Have on 1 face (spaced 269 cm from face) an
 8" X 10" X 16" lead reflector. (This is made by using
 2" X 4" X 8" lead bricks. all joints are filled
 with an "adhesive sealant." Trade name is
 Silastic 731 R.T.V. Made ~~by~~ by Dow Corning.
 Pb on west face.

D.H. = 2.0 cm
 Water ht = 90.90 cm Probe (in) Temp °C
 + Per 37.4-5 #1 = 24.0°C
 C = 1282.0 sec = .99 f = .49 f/cm. 2 = 24.5°C
 1535 Water ht = 38.90 cm Probe (in)
 system just critical 36.64
 Drain

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter ✓	4"	✓	3×10^{-12}
"	"	Fast ✓	1"	✓	"
K-2	"	Meter ✓	4"	✓	"
"	"	Fast ✓	1"	✓	"
R-1					
R-2					
PM-1	700 ✓	Alarm ✓	5"	✓	500 ✓
PM-2	1200 ✓	Low ✓	10"	✓	900 ✓
"	"	Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. B-80
 DUMP WELL PROBE LIGHT _____

START-UP CHECK LIST

Equipment checked by F.P.C. Personnel check by F.P.C.
 Instruments and safeties checked and reset by R.K.M.
 Source in checked by R.K.M. Source No. M-43
 Emergency equipment in control room checked by F.P.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by R.K.M. Time 0805
 Start-up OK'd by F.P.C. R.K.M. Date 10-6-72

Repeat of last run: P-135.

$D_4 = 1.9 \text{ cm}$

Water ht = 40.90 cm Probe (in) Temp °C

Per C = 738.82 m = 1.7 f 37.91 #1 = 29.5°

0920 Water ht = 39.00 cm 36.62 #2 = 24.5°

System just critical
 Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	10 ⁻¹²	Meter ✓	4"	-	10x10 ⁻¹²
"	"	Feet ✓	1"	✓	"
K-2	"	Meter ✓	4"	✓	"
"	"	Feet ✓	1"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	5"	✓	500V
PM-2	1200V	Low ✓	10"	✓	900V
"	"	Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. 17-80
 DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by F.P.C. AKM Personnel check by F.P.C.
 Instruments and safeties checked and reset by AKM
 Source in checked by AKM Source No. M-43
 Emergency equipment in control room checked by F.P.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by AKM Time 0820
 Start-up OK'd by F.P.C. AKM Date 10-9-72

1.30 cm separation c-c.
 30 cm lengths.
 .30" rods.

Have an 20x20-9 array; Total of 391 rods.
 Now have an 8" x 10" x 16" lead reflector on
 2 faces (spaced .269cm from face).
 Pb on west & north face.

$\Delta h = 1.00 \text{ cm}$
 Water ht = 30.80 cm Probe (in) Temp °C
 + Pb 33.53" #1 = 29.2°C
 $E = 145.59 \text{ m} = 7.3 \text{ f} = 70.0 \text{ f/cm}$ #2 = 29.2°C
 0920 Water ht = 30.70 cm Probe (in)
 System just critical 33.43"
 Drain.

Removed 5 rods; Have an 20x20-14 array;
 Total of 386 rods.
 $\Delta h = 1.45 \text{ cm}$
 Water ht = 34.90 cm Probe (in) Temp °C
 + Pb 35.10" #1 = 29.2°C
 $E = 134.73 \text{ m} = 7.8 \text{ f} = 5.4 \text{ f/cm}$ #2 = 29.2°C
 0945 Water ht = 33.45 cm Probe (in)
 System just critical 34.50"
 Drain.

Removed 3 rods; Have an 20x20-17 array;
 Total of 383 rods.

0958 Water ht = 46.20 cm Probe (cm) Temp °C
 System sub critical 37.60"
 Drain. $\beta = 29.20$
 $\alpha = 29.20$

added 1 rod. Now have an 20x20-16 array.
 Total of 384 rods.

1012 Water ht = 41.30 cm Probe (cm) Temp °C
 System just critical 37.60"
 Drain. $\beta = 29.30$
 $\alpha = 29.30$

Filled in the North West corner of lead
 reflector with lead bricks (2" x 8" x 10"). Three
 giving 8" thick reflector on this corner.

2425.3
 3 Water ht = 41.00 cm Probe (cm) Temp °C
 + Per 37.50 $\beta = 29.30$
 $\alpha = 24.50$

1450 Water ht = 35.70 cm Probe (cm)
 System just critical 35.72
 Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3 x 10 ⁻¹²	Meter ✓	4"	✓	10 x 10 ⁻¹²
"	"	Fast ✓	1"	✓	"
K-2	"	Meter ✓	4"	✓	"
"	"	Fast ✓	1"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	5"	✓	500V
PM-2	1200V	Low ✓	10"	✓	900V
"	"	Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. B-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by F.V.C. Personnel check by F.V.C.
 Instruments and safeties checked and reset by AKM.
 Source in checked by AKM Source No. M-93
 Emergency equipment in control room checked by F.V.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Rod light on by AKM Time 1225
 Start-up OK'd by F.V.C., AKM Date 10-11-72

1.30 cm separation c-c.
30 cm lengths.
130" rods.

Have an 19x19+4 array. Total of 365 rods. Each face of array has an 8"x10"x26" lead reflector (spaced .269cm from face). This is made by using 2"x4"x8" lab bricks. All joints are filled with an adhesive sealant. Trade name Silastic 731 R.T.V. Made by Dow Corning.

dl = .30 cm

Water ht = 32.50 cm
+ Per

$\bar{c} = 210.78 \mu\text{m} = 5.34 = 17.74 \mu\text{m}$

1330

Water ht = 32.20 cm
System just critical
Drain. Probe (in) 33.21"

Temp °C
#1 = 24.5°C
#2 = 24.7°C

Removed 4 rods. Now have an 19x19 array. Total of 361 rods. Lead reflectors spaced .269cm on 3 faces. ~~cm~~ 1.58cm on 1 face.

dl = 5.9 cm

Water ht = 40.90 cm
+ Per. Probe (in) 36.67"

$\bar{c} = 176.01 \mu\text{m} = 6.24 = 1.05 \mu\text{m}$

Temp °C
#1 = 24.6°C
#2 = 24.9°C

1358 Water ht = 35.00 cm
System just critical
Drain. Probe (in) 34.28"

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Motor ✓	4"	✓	10×10^{-12}
"	"	Fast ✓	1"	✓	"
K-2	"	Motor ✓	4"	✓	"
"	"	Fast ✓	1"	✓	"
R-1					
R-2					
PM-1	700 v	Alarm ✓	5"	✓	500 v
PM-2	1200 v	Low ✓	10"	✓	900 v
"	"	Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. B-80
DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by ^{21 P.C.} A.K.L. Personnel check by P.K.R.P.
Instruments and safeties checked and reset by A.K.L.
Source in checked by A.K.L. Source No. M-43
Emergency equipment in control room checked by F.D.C.
Instruments in trip circuit: K-1-2 PM-1-2
Red light on by P.K.R.P. Time 0800
Start-up OK'd by F.D.C. A.K.L. Date 10-12-72

Lead wt kg

North Face

259.1 kg

East Face

259.5 kg

South Face

259.0 kg


West Face

259.2 kg


Total = 1036.8 kg

Log #5
P-142


130cm SEPARATION O-C.
30cm LENGTH,
.30" Rods,
19x19 ARRAY, TOTAL OF 361 Rods.



LEAD REFLECTOR, 4 SIDES.



Log #5
P-142



Position of Rods to Lead Reflector.

Repeat of last run: P 142-143.

sh = 5.9

Water ht = 40.90 cm Probe (in)

Temp. °C

E = 171.68 sec = 6.4 ft = 1.08 ft/cm. 36.59 "

#1 = 29.5 °C

#2 = 29.5 °C

0850

Water ht = 35.00 cm Probe (in)

system just critical
 drains

34.25 "

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3110 ^{cr2}	Meter ✓	4"	✓	340-12
"		Fast ✓	1"	✓	"
K-2	"	Meter ✓	4"	✓	"
"		Fast ✓	1"	✓	"
R-1					
R-2					
PM-1	200 ✓	Alarm ✓	5"	✓	500 ✓
PM-2	1200 ✓	Low ✓	10"	✓	900 ✓
"		Alarm ✓	1"	✓	"

LOG IN CALIBRATE OPERATE SOURCE No. B-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by T.P.C. Personnel check by T.P.C.

Instruments and safeties checked and reset by A.K.L.

Source in checked by A.K.L. Source No. M-43

Emergency equipment in control room checked by T.P.C.

Instruments in trip circuit: K-1-2 PM 1-2

Red light on by A.K.L. Time 10:30

Start-up OK'd by T.P.C. A.K.L. Date 10-23-72

1.30 cm separation c-c.
 30 cm length.
 .30" rods.

H₂O + Lead reflector.

H₂O = 25.60 cm = Top of rods.

Now have on each face (for an 23x23 lattice) an lead reflector 8.0"x10.0"x28.2". The lead is spaced one half-cell width, i.e. 250". The 250" space will allow for insertion of stainless steel plates for some array's.

For bow run: Have an 19x19 array: Total of 361 rods.

1108 Water ht = 41.30 cm Probe (in) Temp °C
 system sub critical 37.62" #1 = 23.7°C
 Drain. #2 = 23.7°C

added 2 rods; now have an 19x19+2 array. Total of 363 rods.

Water ht = 41.60 cm Probe (in) Temp °C
 - Per 37.80" #1 = 24.0°C
 - 380.72 sec = 3.54 #2 = 24.0°C

1300 Drain:
 added 2 rods; now have an 19x19+4 array. Total of 365 rods.

dh = 7.3 cm

Water ht = 41.20 cm Probe (in) Temp °C
 2 + Per 37.59" #1 = 24.0°C
 C = 106.48 sec = 9.44 = 1.34 / cm #2 = 24.0°C

1333 Water ht = 33.90 cm Probe (in)
 system just critical 34.65"
 Drain.

Removed 1 rod; now have an 19x19+3 array. Total of 364 rods.

dh = 4.9 cm

Water ht = 41.10 cm Probe (in) Temp °C
 3 + Per 37.56" #1 = 24.0°C
 C = 454.16 sec = 2.74 = .55 / cm #2 = 24.0°C

1422 Water ht = 36.20 cm Probe (in)
 system just critical
 Drain


Repeat of last run:

dh = 4.8 cm

Water ht = 41.10 cm Probe (in) Temp °C
 4 + Per 37.46" #1 = 24.0°C
 C = 564.98 sec = 2.24 = .46 / cm #2 = 24.0°C

1505 Water ht = 36.30 cm Probe (in)
 system just critical 35.65"
 Drain.

Log #5
P-146



Lead wt. Kg.
North Face
290.3 Kg.
East Face
289.8 Kg.
South Face
289.7 Kg.
West Face
290.8 Kg.
Total = 1160.6 Kg.



Log #5
P-146

1.30 cm SEPERATION, E.C.

30 cm LENGTH,

.30" Rod's.

19x19+3 Array.



TYPICAL SIDE VIEW.

10-24-72 Water sample taken from Well:
0800

G = 1,650.0 grams
T = 102.0 grams
N = 1,548.0 grams
ask for
g/g.
Repro 40

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K1	3810-12	Meter ✓	4"	✓	10.610-12
"	"	Fast ✓	1"	✓	"
K2	"	Meter ✓	4"	✓	"
"	"	Fast ✓	1"	✓	"
R-1					
R-2					
EM	700 V	Alarm ✓	.5"	✓	500V
EM	1200 V	Low ✓	10.0"	✓	900V
"	"	Alarm ✓	1.0"	✓	"

LOG IN CALIBRATE _____ OPERATE _____ SOURCE No. B-80
DUMP WELL PROBE LIGHT _____

1.30 cm separation c-c.
30 cm length
30" rods.
START-UP CHECK LIST
7. P.C.

Equipment checked by A.M. Personnel check by F.D.C.
Instruments and safeties checked and reset by B.K.N.
Source in checked by A.M. Source No. M-43
Emergency equipment in control room checked by F.D.C.
Instruments in trip circuit: K-1-2 PM-1-2
Red light on by B.K.N. Time 1245
Start-up OK'd by F.D.C. A.M. Date 10-24-72


H₂O + Lead reflector (4 sides see p-146).

Now have an 21 x 21 array, with the 11th row removed in 2 directions. Total of 400 rods.

1300 Water ht. = 22.60 cm
System just critical
Drain

Temp °C
#1 = 24.2°C
#2 = 24.2°C

Now have an 19
array in 2 dir



10th row
4 rods.

Water ht = 41.30
+ Res.

Temp °C
#1 = 24.2°C
#2 = 24.2°C

$C = 493.27 \mu\text{m} = 2.54 =$

1449 Water ht = 36.15 cm (Probe in)
System just critical 35.52"
Drain.

1.30 cm separation c-c.
 30 cm lengths
 -30" rods.
 START-UP CHECK LIST
 F.I.D.C

149 ✓

Equipment checked by R.M.V. Personnel check by F.I.D.C.

Instruments and safeties checked and reset by R.M.V.

Source in checked by R.M.V. Source No. M-23

Emergency equipment in control room checked by F.I.D.C.

Instruments in trip circuit: K-102 PM 1-2

Red light on by R.M.V. Time 1245

Start-up OK'd by F.I.D.C. R.M.V. Date 10-29-72

H₂O + 2

5 # 9000 bag
 of Boron H₂S
 149

20 p-146)

Now have an 21
 removed in 2 di

removed 28 of 324 rods
 19x19 array

10th row
 0 rods.

1300

Water ht = 22.60 cm
 System just critical
 Drain

30" rods
 1.30 cm separation c-c

Temp °C

#1 = 29.2 °C
 2 = 29.2 °C

Now have an 19x19 array, with the 10th row
 removed in 2 directions. Total of 324 rods.

Water ht = 41.30 cm Probe (in)
 + Res. Δh = 5.15 cm 37.59"

Temp °C

#1 = 29.2 °C
 2 = 29.2 °C

C = 493.27 μs = 2.54 = .484/cm

1449

Water ht = 36.15 cm Probe (in)
 System just critical 35.52"
 Drain

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3K10 ⁻¹²	Alarm ✓	4"	✓	10 x 10 ⁻¹²
"	"	Set ✓	1"	✓	"
K-2	"	Alarm ✓	4"	✓	"
"	"	Set ✓	1"	✓	"
R-1					
R-2					
PM 1	700 V	Alarm ✓	15"	✓	500 V
PM 2	1200 V	Low ✓	10"	✓	900 V
"	"	Alarm ✓	1"	✓	"

LOG IN CALIBRATE OPERATE SOURCE No. B-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by I.D.C. Personnel check by BKM
 Instruments and safeties checked and reset by BKM
 Source in checked by BKM Source No. M-93
 Emergency equipment in control room checked by I.D.C.
 Instruments in trip circuit: K-1-2 PM 1-2
 Red light on by BKM Time 0800
 Start-up OK'd by F.D.C. BKM Date 10-25-72

1.30 cm separation c.c.
 30 cm length.
 .30" rods.
 H₂O + Lead inflector.

Repeat of last run p-149. Total of 324 rods.

0847 Water ht = 41.40 cm Probe (in) Temp °C
 System just critical 37.67" #1 = 29.0°C
 Drain. #2 = 29.2°C

Repeat of above.

Water ht = 41.30 cm Probe (in) Temp °C
 + Per 37.62" #1 = 29.0°C
 #2 = 29.2°C
 L = 1803.7 cm = .71 f = .25 f/cm.

1024 Water ht = 38.45 cm Probe (in)
 System just critical 36.45
 Drain

Have an 20 x 20 array, with the 10th & 11th row of rods removed in 2 directions. Total of 324 rods.

1338 Water ht = 41.60 cm Probe (in) Temp °C
 System sub critical 37.75" #1 = 29.2°C
 Drain. #2 = 29.2°C


arr.

Added 20 rods. 5 to each corner.
 Now have 22x22 array, with 11th + 12th
 row of rods removed in 2 directions
 Total of 344 rods.

1406 Water ht = 41.40 cm
 System sub critical
 Drain.

Temp °C
 #1 = 29.20
 #2 = 29.20

Added 8 rods. 2 to
 Have an 22x22 array
 row of rods removed
 Total of 352 rods.



Water ht = 41.30 cm
 + Per

Temp °C
 #1 = 29.20
 #2 = 29.30

$C = 232.49 \text{ sec} = 4.14 = .67 \text{ f/cm}$

1450 Water ht = 35.20 cm
 System just critical
 Drain.

Probe (in)
 35.19"

Repeat of above.

Water ht = 41.40 cm
 + Per.

Probe (in) Temp °C
 37.68" #1 = 29.30
 #2 = 29.30

$C = 247.72 \text{ sec} = 4.64 = .73 \text{ f/cm}$

1531 Water ht = 35.10 cm
 System just critical.
 Probe (in)
 35.11"

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3×10^{-12}	Meter <input checked="" type="checkbox"/>	4"	<input checked="" type="checkbox"/>	10×10^{-12}
"	"	Foot <input checked="" type="checkbox"/>	1"	<input checked="" type="checkbox"/>	"
K-2	"	Meter <input checked="" type="checkbox"/>	4"	<input checked="" type="checkbox"/>	"
"	"	Foot <input checked="" type="checkbox"/>	1"	<input checked="" type="checkbox"/>	"
R-1					
R-2					
PM-1	700 V	Alarm <input checked="" type="checkbox"/>	5"	<input checked="" type="checkbox"/>	500 V
PM-2	1200 V	Low <input checked="" type="checkbox"/>	10"	<input checked="" type="checkbox"/>	900 V
"	"	Alarm <input checked="" type="checkbox"/>	10"	<input checked="" type="checkbox"/>	"

LCS N CALIBRATE OPERATE SOURCE No. B-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by Z.P.C. Personnel check by E.P.C.
 Instruments and safeties checked and reset by B.M.H.
 Source in checked by B.M.H. Source No. M-23
 Emergency equipment in Control Room checked by F.P.C.
 Instruments in trap circuits K-1-2 PM-1-2
 Red light on by A.M.H. Time 0800
 System OK'd by F.P.C. B.M.H. Date 10-26-72

added 20 rods. 5 to each corner.
 Now have 22x22 or
 row of rods remain
 Total of 344 rods.
 agar 258 to top
 base 22x22

2th
0

1406 Water ht = 41.40 cm
 system sub critical
 Drain.
 agar " 98.
 30 cm length
 1.5 cm separation e.e.

1st
#1 = 29.2°
2 = 29.2°

added 8 rods. 2 to each corner.
 Have an 22x22 array, with the 1st & 12th
 row of rods removed in 2 directions.
 Total of 352 rods.

Water ht = 41.30 cm Probe (in) Temp °
 + Per 37.66" #1 = 29.2°
 C = 282.49 sec = 4.17 = .67 f/cm 2 = 29.3°

1450 Water ht = 35.20 cm Probe (in)
 system just critical 35.19"
 Drain.


Repeat of above.
 Water ht = 41.40 cm Probe (in) Temp °
 + Per 37.68" #1 = 29.3°
 C = 247.72 sec = 4.64 = .73 f/cm 2 = 29.3°

1531 Water ht = 35.10 cm Probe (in)
 system just critical: 35.11"

1.30 cm separation c-c.
 30 cm length.
 .30" rods.
 H₂O + lead reflector.

Have an 23 x 23 array, with the 11th, 12th & 13th row removed in 2 directions. Total of 400 rods.

0914 Water ht = 41.30 cm.
 System sub critical
 Drain.



Temp °C
 #1 = 24.2 °C
 #2 = 24.2 °C

Have an 23 x 23 array, with the 4th, 8th, 12th, 16th & 20th row removed in 2 directions. Total of 324 rods.

1035 Water ht = 420.80 cm
 System just critical
 Drain.


Probe (in) Temp °C
 29.63 #1 = 24.2 °C
 2 = 24.2 °C

Removed 1 column of rods. Total of 54 removed.
 Water ht = 26.0 cm
 System just critical
 Drain.

Probe (in) Temp °C
 31.67" #1 = 24.2 °C
 2 = 24.3 °C

Removed 3 clusters of rods from 1 face.
 Total of 27 rods. Now have a total of 243 rods. See diagram #1

1315 Water ht = 41.20 cm
 System sub critical
 Drain.




Temp °C
 #1 = 24.5 °C
 #2 = 24.5 °C

Added 2 rods. Now have
 See diagram #2

Water ht = 41.0 cm
 + Per


$I = 275.97 \mu = 4.24 = .69 \mu / \text{cm}$
 Water ht = 34.95 cm.
 System just critical



Temp °C
 #1 = 24.5 °C
 #2 = 24.5 °C

Removed 1 rod. Now have
 See diagram #3

Water ht = 41.40 cm
 System sub critical
 Drain.



Temp °C
 #1 = 24.5 °C
 #2 = 24.5 °C

Res:

1.30 cm
30 cm
30" rods
H₂O +
Have an 23x23 array
rows removed in

logs #5 p-154
Total of 400 rods
23x23 array
rows removed in

0914 Water ht = 41.30 cm Probe (in) Temp °C
 System sub critical 37.65" #1 = 24.2°C
 Drain 2 = 24.2°C

Have an 23x23 array. With the 4th, 8th, 12th, 16th & 20th row removed in 2 directions. Total of 324 rods.

1035 Water ht = 420.80 cm Probe (in) Temp °C
 System just critical 29.63" #1 = 24.2°C
 Drain 2 = 24.2°C


Removed 1 column of rods. Total of 54 removed.
 Water ht = 26.0 cm Probe (in) Temp °C
 System just critical 31.67" #1 = 24.2°C
 Drain 2 = 24.3°C

Removed 3 clusters of
 Total of 27 rods. Now
 rods. See diagram #1

1315 Water ht = 41.20 cm Probe (in) Temp °C
 System sub critical 37.60" #1 = 24.5°C
 Drain 2 = 24.5°C


Added 2 rods. Now have a total of 245 rods.
 See diagram #2

Water ht = 41.0 cm
 + Per
 I = 275.97 au = 4.24 = .69 #/cm
 Water ht = 34.95 cm
 System just critical



Removed 1 rod. Now have
 See diagram #3

Water ht = 41.40 cm
 System sub critical
 Drain




obs:

1.30 cm separation c-c.
30 cm length.
.30" rods.
H₂O + lead reflector.

Have an 23x23 array, w/ with the 11, 12th & 13th row removed in 2 directions. Total of 400 rods.

0914 Water ht = 41.30 cm.
System sub critical
Drain.



Temp °C
#1 = 24.2°C
#2 = 24.2°C

Have an 23x23 array. with the 4th, 8th, 12th, 16th & 20th row removed in 2 directions. Total of 324 rods.

1035 Water ht = 20.80 cm
System just critical
Drain.

Probe (in)	Temp °C
29.63	#1 = 24.2°C
	#2 = 24.2°C

Removed 1 column of rods. Total of 54 removed.
Water ht = 26.0 cm
System just critical
Drain.

Probe (in)	Temp °C
31.67"	#1 = 24.2°C
	#2 = 24.3°C

Fig #5 - p 155

Total of 243 rods

.30" rods

30 cm length

1.30 cm separation c-c.

Removed 3 clusters of
Total of 27 rods. Now
rods. See diagram

1315 Water ht = 41.20 cm
System sub critical
Drain.

Fig #5 - p 155

Total of 243 rods

.30" rods

30 cm length

1.30 cm separation c-c.

Added 2 rods. Now see
See diagram.

SA = 6.05 cm

Water ht = 41.0 cm
+ Per

Probe (in)	Temp °C
37.58"	#1 = 24.5°C
	#2 = 24.5°C


I = 275.97 au = 4.24 = .69 #/cm

Water ht = 34.95 cm.
System just critical

Probe (in)	Temp °C
35.06"	

Removed 1 rod. Now have
See diagram.

Water ht = 41.40 cm
System sub critical
Drain.




also:

1.30 cm separation c-c.
30 cm length.
.30" rods.
H₂O + lead reflector.

Have an 23 x 23 array, with the 11, 12th, 13th row removed in 2 directions. Total of 400 rods.

0914 Water ht = 41.30 cm.
System sub critical
Drain.



Temp °C
#1 = 24.2°
#2 = 24.2°

Have an 23 x 23 array, with the 4th, 8th, 12th, 16th & 20th row removed in 2 directions. Total of 324 rods.

1035 Water ht = 420.80 cm
System just critical
Drain.

Probe (in) Temp °C
29.63 #1 = 24.2°
2 = 24.2°

Removed 1 column of rods. Total of 54 removed.
Water ht = 26.0 cm
System just critical
Drain.

Probe (in) Temp °C
31.67 #1 = 24.2°
2 = 24.3°

for #5, p-155
Total of 243 rods.
.30" rods.
30 cm length.

Removed 3 clusters of
Total of 27 rods. Now
rods. See diagram

1315

Water ht = 41.20 cm
System sub critical
Drain.

for #5, p-155
Total of 245 rods.
.30" rods.
30 cm length.

Added 2 rods. Now see
See diagram.

1.30 cm separation c-c.
30 cm length.
.30" rods.

Water ht = 41.0 cm
+ Per

$I = 275.97 \mu = 4.24 = .69 \mu / \text{cm}$

Water ht = 34.95 cm.
System just critical

for #5, p-155
Total of 244 rods.
.30" rods.
30 cm length.

Removed 1 rod. Now have a total of 244 rods.
See diagram.

Water ht = 41.40 cm
System sub critical
Drain.

Probe (in) Temp °C
#1 = 24.5°
2 = 24.5°

also:

Now have an 19x19 array with the 4th, 8th, 12th & 16th row removed in 2 directions. Total of 225 rods.

1545 Water ht = 41.30 cm Probe (in) Temp °C
 System sub critical Drain. 37.74" #1 = 24.5°
 2 = 24.5°

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K1	3K10-12	Alarm ✓	4"	✓	10K10-12
"	"	Fail ✓	1"	✓	"
K2	"	Alarm ✓	4"	✓	"
"	"	Fail ✓	1"	✓	"
R-1					
R-2					
PM-1	700V	Alarm ✓	5"	✓	500V
PM-2	1200V	Alarm ✓	10"	✓	900V
"	"	Alarm ✓	1"	✓	"

LOG IN CALIBRATE OPERATE SOURCE No. B-80
 DUMP WELL PROBE LIGHT

1.30 cm separation e-e
 30 cm length.
 .30" rods.
 14.0 & lead reflector.
 START-UP CHECK LIST
 Z, D, C


Equipment checked by MM Personnel check by F.D.C.
 Instruments and safeties checked and reset by MM
 Source in checked by MM Source No. M-93
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1-2 PM 1-2
 Red Light on by MM Time 0820
 Start-up OK'd by F.D.C. MM Date 10-27-72

Now on 19x19 array, with the 4th, 8th, 12th & 16th row removed in 2 directions. Plus 4 rods on each corner. Total of 241 rods. See diagram.

Water ht = 41.40 cm Probe (in) Temp °C
 - Par 37.71" #1 = 24.0°
 N.G. 2 = 24.5°

0945 Drain. Added 2 rods. Now

1016 Water ht = 41.40 cm System just critical Drain. Temp °C



over:

1.30 cm separation e-e
30 cm length.
.30" node.
H₂O + lead reflector.
START-UP CHECK LIST

Equipment checked by WML Personnel check by F.D.C.
Instruments and safeties checked and reset by A.M.L.
Source in checked by A.M.L. Source No. 19-93
Emergency equipment in control room checked by F.D.C.
Instruments in trip circuit: K-1-2 PM 1-2
Red light on by A.M.L. Time 0820
Start-up OK'd by F.D.C., A.M.L. Date 10-27-72

at
24.5°
24.5°

Have on 19 X 19 array,
now removed in
on each corner.
See diagram. 2 sh 416 sh
4 nodes
Total of 243 nodes.
151-d 5 sh top
130" node.
30 cm length.
1.3 cm separation e.e.
Water ht = 41.40 cm
- Per
N.C. Temp °C
#1 = 24.0°
2 = 24.5°

0945 Drain.
added 2 nodes. Now have a total of 243 nodes.

1016 Water ht = 41.40 cm Probe (in) Temp °C
System just critical 37.71"
Drain.

over:

Now have an 17x17 array, with the 3rd, 6th, 9th, 12th, & 15th row removed in 2 directions. Total of 144 rods.

1315 Water ht = 41.50 cm Probe (in) Temp °C
 System sub critical 37.73" #1 = 29.5°
 Drain 2 = 29.5°

1350 added 52 rods. Now have an 20x20 array, with the 3rd, 6th, 9th, 12th, 15th & 18th row removed. Total of 196 rods.
 Water ht = 41.20 cm Probe (in) Temp °C
 System sub critical 37.55" #1 = 29.5°
 Drain 2 = 29.5°

Now have an 20x23 array, with 2 1/2 cluster of rods removed from 1 row: added a total of 18 rods. Total number of rods = 214 rods. see diagram.


1528 Water ht = 41.30 cm Probe (in) Temp °C
 Per 37.60 #1 = 29.9°
 Drain 2 = 29.9°
 $\tau = -297.7 \text{ sec} = -5.0 \text{ f}$

added 1 rod; Now see diagram:

Water ht = 41.50" + Per

$\tau = 106.98 \text{ sec} = 9.9 \text{ f} = 1$

1548 Water ht = 33.55 cm System just critical Drain 34.51"



5 rods

4°

1 = 29.5°

2 = 29.5°

Log #5 p-159
 Total of 215 rods
 130" Rods
 30 cm length
 1.30 cm separation e-e

159

added 1 rod; Now have a total of 215 ^{rods} ~~rods~~
 see diagram:

$d = 7.95 \text{ cm}$
 Water ht = 41.50" Probe (in) Temp °C
 + Per 37.71" #1 = 24.5°C
 $t = 106.98 \text{ mm} \approx 9.9 \text{ } \phi = 1.2 \text{ } \phi / \text{cm}$ 2 = 24.5°C
 1548 Water ht = 33.55 cm Probe (in)
 system just critical 34.51"
 Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	300-12	High ✓	9"	✓	10710"0
"	"	Low ✓	1"	✓	"
K-2	"	High ✓	9"	-	"
"	"	Low ✓	1"	-	"
R-1					
R-2					
PM-1	700 V	Alarm ✓	.5"	✓	500 V
PM-2	1200 V	Low ✓	10"	✓	900 V
"	"	Alarm ✓	1"	✓	"

LOG IN CALIBRATE OPERATE SOURCE No. B-80
 DUMP WELL PROBE LIGHT

START-UP CHECK LIST

I.P.C.
 Equipment checked by AKK Personnel check by I.P.C.
 Instruments and safeties checked and reset by AKK
 Source in checked by AKK Source No. M-43
 Emergency equipment in control room checked by I.P.C.
 Instruments in trip circuits: K-1-0 PM-1+2
 Red light on by AKK Time 0809
 Start-up OK'd by I.P.C., AKK Date 10-30-72

1,30 cm separation c.s.c.
 30 cm length.
 1.30" rods.
 H₂O + Lead Reflector.

Repeat of last run: p-159.

at 7.10 am

Water ht = 41.10 cm Probe (in) Temp °C
 + Per 37.59" #1 = 24.2°C

C = 145.59 cm = 7.37 = 1.03/cm

2 = 24.2°C

0900 Water ht = 34.00 cm Probe (in)
 system just critical 34.71"
 Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3K10 ⁻¹²	✓	4"	-	10X10 ⁻¹²
"	"	✓	1"	-	"
K-2	"	✓	4"	-	"
"	"	✓	1"	-	"
P-1					
P-2					
PM1	700V	Alarm ✓	5"	-	500V
PM2	1200V	Low ✓	10"	-	900V
"	"	Alarm ✓	1"	-	"


LOG N CALIBRATE OPERATE SOURCE No. 17-80

DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by I.P.C. P.K.V. Personnel check by I.P.C.
 Instruments and safeties checked and reset by P.K.V.
 Neutrons in checked by P.K.V. Source No. M-93
 Emergency equipment in control room checked by I.P.C.
 Instruments in trip circuits: K-1-2 PM1-2
 Red light on by P.K.V. Time 1325
 Start-up OK'd by I.P.C. P.K.V. Date 11-1-72

1.3cm separation c-c.
 30 cm length.
 130" rods.
 H₂O + Lead + .250" S.S.



Now have on each inner face
 2 - .250" x 10.0" x 12.27". 2 - .250"
 Type 304L Stainless Steel
 is spaced at half-cell.
 See diagram:

Have an 20x23 array with 2 decoder plates (rod removed from 1 row). Total of 215 rods. (See p-159 with out S.S.)

1352 Water ht = 41.10 cm Probe (in) Temp °C
 System sub critical 37.54" #1 = 24.3°
 Drain. 2 = 24.8°

added 9 rods. Now have a full 20x23 array.
 With the 3rd, 6th, 9th, 12th, 15th, 18th row removed
 in 1 direction, on the 3rd, 6th, 9th, 12th, 15th, 18th
 & 21st in 1 direction. Total of 224 rods.

1550 Water ht = 41.20 cm Probe (in) Temp °C
 System sub critical 37.68" #1 = 24.2°
 Drain. 2 = 24.2°

log # 5 p-163
 H₂O + Lead + S.S. plate
 30 cm length
 1.30 cm diameter

1.30 cm diameter
 30 cm length
 1.30" rods
 H₂O + Lead + .250" S.S. plate.

Now have on each inner face of Lead, type
 2 - .250" x 10.0" x 12.27". 2 - .250" x 10.0" x 11.77"
 Type 304L stainless steel plates. Each plate
 is spaced at half-cell width from array.
 See diagram.

Have an 20 x 23 array with a detector plus 1 rod removed
 from 1 row. Total of 215 rods. (See p-159 with out S.S.)

1352 Water ht = 41.10 cm Probe (in) Temp °C
 System sub-critical 37.54" #1 = 29.3 °C
 Drain. 2 = 29.0 °C

added 9 rods. Now have a full 20 x 23 array.
 with the 3rd, 6th, 9th, 12th, 15th, 18th row removed
 in 1 direction, on the 3rd, 6th, 9th, 12th, 15th, 18th
 & 21st in 1 direction. Total of 224 rods.

1550 Water ht = 41.20 cm Probe (in) Temp °C
 System sub-critical 37.63" #1 = 29.2 °C
 Drain. 2 = 29.2 °C

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3X10 ⁻¹²	—	2"	—	10 ⁻¹²
"	"	—	1"	—	"
K-2	"	—	2"	—	"
"	"	—	1"	—	"
R-1					
R-2					
PM-1	700V	Alarm	5"	—	500V
PM-2	1200V	Low	10"	—	900V
"	"	Alarm	1"	—	"

LOG N CALIBRATE OPERATE SOURCE No. B-80
 DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by I.P.C. Personnel check by F.P.C.
 Instruments and safeties checked and reset by R.K.M.
 Source in checked by R.K.M. Source No. M-23
 Emergency equipment in control room checked by F.P.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by R.K.M. time 0925
 Start-up OK'd by F.P.C. R.K.M. Date 11-2-72

1.30 cm separation c-c.
 30 cm length.
 30" rods.
 H₂O + lead & 1.25" S.S. plates.

Added 8 rods. Now have an 23x23 array, with 6 clusters of rods removed from 1 row. Total of 232 rods.

Water ht = 41.20 cm Probe (in) Temp °C
 1 - Per 37.53" #1 = 24.3°
 2 = 24.3°
 C = 130.38 sec = 15.24

1027 Drain.

Added 2 rods. Now have an 23x23 array, with 5 1/2 clusters of rods removed from 1 row. Total of 234 rods.

Water ht = 41.20 cm Probe (in) Temp °C
 2 + Per 37.53" #1 = 24.3°
 2 = 24.3°
 C = 76.05 sec = 12.14 = 1.54/cm.

1108

Water ht = 33.20 cm Probe (in)
 System just critical 34.30"
 Drain.

over

Removed 1 rad. Have
5 3/4 clusters of rods re
labeled of 2 33 rods.

Water ht = 41.40 cm
+ Pen

T = 847.47 sec = 1.5 f

1327

Water ht = 37.00 cm

System just critical
Drain.

Probe (in)

35.82"

Repeat of above:

Water ht = 41.40 cm

+ Pen

T = 825.74 sec = 1.5 f

1448

Water ht = 36.50 cm

System just critical
Drain.

Probe (in)

35.64"


Probe (in)

37.62"

Temp °C

#1 = 24.3°

#2 = 24.3°



INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3A10 ⁻¹²	Meter ✓	3"	-	10 x 10 ⁻¹²
"	"	Fast ✓	1"	-	
K-2	"	Meter -	4"	-	10 x 10 ⁻¹²
"	"	Fast ✓	1"	-	
K-3					
K-4					
PM-1	700V	Alarm ✓	1/2"	-	500V
PM-2	1200V	Alarm ✓	18"	-	500V
"		Alarm ✓	1"	-	

LOG H CALIBRATE OPERATE SOURCE No. B-80

DUMP WILL PROBE LIGHT

START-UP CHECK RECORD

Equipment checked by A.K.R. Instrument check by A.K.R.
 Instruments and settings checked and reset by E.B.T. A.K.R.
 Source is checked by A.K.R. Source No. M-93
 Emergency equipment as required was checked by A.K.R.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red Light on by A.K.R. Time 0914
 Start-up OK'd by E.B.T. A.K.R. Date 11-6-72

Removed 1 rod. Have an 23×23 array, with
 $5\frac{3}{4}$ clusters of rods removed from 1 ~~rod~~ row.
 Total of 233 rods.

	Water ht = 41.40 cm	Probe (in)	Temp °C
	³ +Pen	37.62"	#1 = 29.3°
	$C = 847.47 \text{ cc} = 1.5 \text{ f}$		2 = 29.3°

1327 Water ht = 37.60 cm Probe (in)
 system just critical 35.82"
 Drain.

Repeat of above.

	Water ht = 41.40 cm	Probe (in)	Temp °C
	⁴ +Pen	37.62"	#1 = 29.3°
	$C = 825.74 \text{ cc} = 1.5 \text{ f}$		2 = 29.3°

1448 Water ht = ~~35.6~~ ^{36.50 cm}
 system just critical Probe (in)
 Drain. 35.69"

791-A-5H top
 Hot fluid & S.S. ref.
 30" rods
 30 cm length
 1.30 cm separation c-c

1.30 cm separation c-e.
 30 cm lengths.
 30 rods.
 H₂O + lead and 1 s.s. plate central.
 in array: size s.s. plate = .250" x 10.0"

12.27"
 Have an 20 x 23 array: with the 3rd, 6th, 9th, 12th, 15th & 18th rows removed in 1 direction, and the 3rd, 6th, 9th, 12th, 15th & 21st row removed in 1 direction. With 1 cluster of rods removed in 1 row. Total of 220 rods.

0983 Water ht = 40.80 cm Probe (in) Temp °C
 System sub critical 37.58" #1 = 23.9 °C
 Drain. 2 = 24.1 °C

Added 12 rods. Now have an 23 x 23 array, with the 3rd, 6th, 9th, 12th, 18th & 21st row removed in 2 directions. With 6 clusters removed from 1 row. Total of 232 rods.

1010 Water ht = 41.60 cm Probe (in) Temp °C
 System sub critical 37.70" #1 = 24.0 °C
 Drain. 2 = 24.1 °C

Added 12 rods. Now have 3 clusters removed from 1 row. Total of 244 rods.

1040 Water ht = 41.60 cm Probe (in) Temp °C
 System sub critical 37.69" #1 = 24.0 °C
 Drain. 2 = 24.1 °C

Added 12 rods. Now have an full 23 x 23 array, with the 3rd, 6th, 9th, 12th, 15th, 18th & 21st row removed in 2 directions: total of 256 rods.

h = 6.65 cm

Water ht = 41.70 cm Probe (in) Temp °C
 + Per 37.71 #1 = 24.0 °C
 C = 239.03 cm = 4.94 = .724/cm. 2 = 24.0 °C


1120 Water ht = 35.05 cm Probe (in) Temp °C
 System just critical 35.00"
 Drain.

Repeat of above:

h = 6.6 cm

Water ht = 41.60 cm Probe (in) Temp °C
 + Per 37.67" #1 = 24.0 °C
 C = 239.03 cm = 4.84 = .731/cm. 2 = 24.1 °C

1325 Water ht = 35.00 cm Probe (in) Temp °C
 System just critical 35.0
 Drain.
 Removed 1 rod from corner number of rod = 255.



1337 Water ht = 41.60 cm Probe (in) Temp °C
 System just critical 37.6
 Drain.

S.S. PLATE

added 12 rods. Now have an full 23x23 array, with the 3rd, 6th, 9th, 12th, 15th, 18th + 21st now removed in 2 directions; total of 256 rods.

$s = 6.65 \text{ cm}$

Water ht = 41.70 cm Probe (in) Temp °C
+ Per 37.71 $\mu 1 = 24.0^\circ \text{C}$
 $\mu 2 = 24.0^\circ \text{C}$
 $C = 239.03 \text{ cm} = 4.94 = .72 \text{ f/cm}$

1120 Water ht = 35.05 cm Probe (in)
system just critical 35.
Drain.

255 rods
top 45 + 109

Repeat of above:

H₂O + head + 1.5 ft

Water ht = 41.60 cm Probe Temp °C
+ Per 37.6 $\mu 1 = 24.0^\circ \text{C}$
 $\mu 2 = 24.0^\circ \text{C}$
 $C = 239.03 \text{ cm} = 4.84 = .73 \text{ f/cm}$

1320 Water ht = 35.00 cm Probe (in)
system just critical 35.04"
Drain.

Removed 1 rod from corner cluster. Total number of rods = 255.

1337 Water ht = 41.60 cm Probe (in) Temp °C
system just critical 37.63" $\mu 1 = 24.0^\circ \text{C}$
Drain $\mu 2 = 24.0^\circ \text{C}$

INSTRUMENT CHECK

INSTRUMENT	RANGE	SOURCE	SET	START-UP RANGE
K1	3X10 ⁻¹²	4"	✓	10 ⁻¹⁰
"	"	1"	✓	"
K2	"	4"	✓	"
"	"	1"	✓	"
B1				
P1				
700V	✓	5"	✓	500V
1200V	✓	10"	✓	900V
"	✓	1"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. 13-80
 DUMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by AKK Personnel check by F.P.C.
 Instruments and safeties checked and reset by AKK
 Source in checked by AKK Source No. 12-93
 Emergency equipment in control room checked by F.P.C.
 Instruments in trip circuit: K-1-2 PM-2
 Red light on by AKK Time 0920
 Start-up CK'd by F.P.C. AKK Date 11-7-72

1.3 cm separation a-e.
 30 cm length.
 30" rods.

H₂O + Lead and 5.5 plate centered in array.
 size of s.s. plate = .250" x 10.00" x 12.27"


Have an 23 x 23 array, with the 4th, 8th, 12th,
 16th & 20th rows removed in 2 directions.
 plus 4 clusters of rods removed from 1 row.
 Total of 288 rods.

1006 Water ht = 41.50 cm Probe (in) Temp °C
 System sub critical 37.69" #1 = 24.2°C
 Drain. #2 = 24.2°C

Added 1 rod: total number of rods = 289.
 See diagram.

Water ht = 41.80 Probe (in) Temp °C
 + Per 37.74" #1 = 24.2°C
 T = 295.53 sec = 3.94 = .594/cm #2 = 24.2°C

1055 Water ht = 35.20 cm Probe
 System just critical
 Drain.



1.3 cm separation a.e.
 30 cm length.
 .30" rods.

H₂O + Lead and 1 S.S. plate centered in array.
 size of S.S. plate = 1.250" x 10.00" x 12.27"

Have an 23 x 23 array, with 4th, 8th, 12th, 16th & 20th rows removed in 2 directions, plus 4 clusters of rods removed from 1 row. Total of 288 rods.

1006 Water ht = 41.50 cm Probe (in) Temp °C
 System sub critical 3
 Drain.

Added 1 rod: label number, see diagram.

Water ht = 41.80 Probe
 + Per 37.

$\Gamma = 295.53 \text{ sec} = 3.94 = .594 / \text{cm}$

1055 Water ht = 35.20 cm Probe (in)
 System just critical 35.16"
 Drain.

289 rods
 888 # 5 P-171
 H₂O + Lead + 1 S.S. plate
 .30" Rods
 30 cm length
 1.30 cm separation

INSTRUMENT CHECK

INSTRUMENT	RANGE	TYPE	SOURCE DISTANCE	SET	START-UP RANGE
K13	10 ⁻¹²	Miner	4"	✓	10 x 10 ⁻¹²
"	"	"	1"	✓	"
K3	"	"	4"	✓	"
"	"	"	1"	✓	"
PA	700 V	Alarm	5"	✓	500 V
PA	1200 V	"	10"	✓	900 V
"	"	Alarm	1"	✓	"

LOG IN CALIBRATE OPERATE SOURCE No. B-80

BUMP WELL PROBE LIGHT

START-UP CHECK HERE


Equipment checked by I.D.C. Personnel check by I.D.C.
 Instruments and safeties checked and reset by AKM
 Source in checked by AKM Source No. M-43
 Emergency equipment in control room checked by I.D.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red Light on by AKM Time 1030
 Start-up OK'd by I.D.C. AKM Date 11-9-72

1.30 cm separation e-e,
 30 cm length,
 .30" rods.

H₂O + lead and 1 Cd sheet centered in array:
 Cd sheet size = .035" x 10.00" x 12.27" (Cd sheet is
 enclosed with 2 sheets of .056" x 10.00" x 12.27"
 plexiglas for strength.)

Have an 23 x 23 array, with the 3rd, 6th, 9th
 12th, 15th, 18th, 21st row removed in 2
 directions. Total of 256 rods.

1111 Water H₂O = 41.70 cm Probe (in) Temp °C
 System sub-critical 37.72" R1 = 29.0 °C
 Drain. R2 = 29.0 °C



AKM

1.30 cm separation e-e.
30 cm length.
30" rods.

173

H₂O + lead and 1 cd sheet centered in array.
Cd sheet size = 0.35" x 10.00" x 12.27" (Cd sheet is
enclosed with 2 sheets of .056" x 10.00" x 12.27"
plexiglas for strength.).

Have on 23 x 23 c
12th, 15th, 18th
directions. Tals

6th, 9th
2 in 2

11 11

Water hl = 41.70 cm
System sub-drill
Drain.

2.56 rods.
Log # 5 P-193
H₂O + lead + ICAD plate
1.30 cm. length
1.30 cm. separation


Temp °C
Z1 = 29.0 °C
Z2 = 29.0 °C

arr:

H₂O + lead and 1 Cd sheet (entered in array.)
 Have an 23x23 array, with the 4th, 8th, 12th,
 16th, + 20th row removed in 2 directions.
 Total of 324 rods.

1305. Water ht = 41.60 cm Probe (in)
 System sub critical 37.70
 Drain.

Temp °C
 #1 = 24.2 °C
 #2 = 24.2 °C



Cd SHEET

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3x10 ⁻¹²	High ✓	4"	-	3x10 ⁻¹²
"	"	Low ✓	1"	-	"
K-2	"	High ✓	4"	-	"
"	"	Low ✓	1"	-	"
R-1					
R-2					
PM-1	700V	Alarm ✓	15"	-	500V
PM-2	1200V	Low ✓	10"	-	900V
"	"	High ✓	1"	-	"

LOGS IN CALIBRATE OPERATE SOURCE No. B-80
 DUMP WILL PROVE LIGHT _____

START-UP CHECK LIST

E.P.C
 Equipment checked by AKM Personnel check by F.D.C.
 Instruments and safeties checked and reset by AKM
 Source in checked by AKM Source No. M-43
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip checked by K-1-2 PM-1-2
 Red light on by AKM Time 1215
 Start-up OK'd by F.D.C. AKM Date 12-9-72

H₂O + lead and
 Have an 23 x:
 16 ct, + 20 ct,
 Total of 324.

1315. Water ht = 41.
 System sub.
 Drain.

H₂O + lead + 1000 ct.
 130" water
 30 cm. length
 1.30 cm. depth

correct)
 8 ct, 12 ct,
 16 ct, 20 ct,
 24 ct.


Temp °C
 11 = 29.2°
 2 = 24.2°

1.3 cm separation e-e.
30 cm length.
30" Rods.

H₂O + Lead reflection: 1 boral sheet inserted
in array: Boral sheet = .250" x 100" x 12.27" (50%^{Boal}
boral).

Have an 20 x 23 array, with the 3rd, 6th, 7th, 9th,
12th, 15th, 18th, 21st row removed in 2
directions; Total of 756 rods.


1247. Water ht = 41.70 cm
System sub crit.
Drain.



Temp °C
#1 = 23.2°C
#2 = 23.2°C

H₂O + Lead and boral sheet: same as above.
Have an 23 x 23 array, with the 4th, 8th, 12th,
16th & 20th row removed in 2 directions.
Total rods 324.

1332 Water ht = 41.60 cm
System sub crit.
Drain.



Temp °C
#1 = 23.2°C
#2 = 23.2°C

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3 x 10 ⁻¹²	Meter <input checked="" type="checkbox"/>	4"	-	3 x 10 ⁻¹²
"	"	Fast <input checked="" type="checkbox"/>	19	-	"
K-2	"	Meter <input checked="" type="checkbox"/>	49	-	"
"	"	Fast <input checked="" type="checkbox"/>	1"	-	"
PM-1	700 V	Alarm <input checked="" type="checkbox"/>	15"	-	500 V
PM-2	1200 V	Low <input checked="" type="checkbox"/>	10"	-	900 V
"	"	Alarm <input checked="" type="checkbox"/>	1"	-	"

LOG IN CALIBRATE OPERATE SOURCE No. W-80
DWAR WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by F.I.C. Personnel check by F.I.C.
Instruments and safeties checked and reset by AKM
Source in checked by AKM Source No. M-93
Emergency equipment in control room checked by F.I.C.
Instruments in trip circuit: K-1-2 PM-1-2
Red light on by AKM Time 0925
Start-up OK'd by F.I.C. AKM Date 12-5-72

1.3 cm separation c-c.
30 cm length.
30" Rods.

H₂O + Lead reflector: 1 boron sheet centered
in array. Boron sheet = 2.2" x 1.0" x .27" (50% ^{D₂O} boron).

30" rods
30 cm length
1.3 cm sep. c-c

Have an 20 x 23 or
12 ch, 15 ch, 18 ch,
directions; Total

H₂O + lead reflector
1 boron sheet centered
in array.
log # 5 P-176
256 rods

3, 9 ch,
in 2

1247. Water ht = 41.70 cm
system sub critical
Drain.

Temp °C
#1 = 23.2°C
2 = 23.2°C

30" rods 30 cm length
1.3 cm sep. c-c

H₂O + Lead and boron
Have an 23 x 23 or
16 ch & 20 ch rows -
Total rods 324.

H₂O, lead, and 1 boron
sheet in center of array.
log # 5 P-176
324 rods

we:
8 ch, 12 ch
rows.

1332 Water ht = 41.60 cm
system sub critical
Drain.


Temp °C
#1 = 23.2°C
2 = 23.2°C

1.3 cm separation c-e.
30 cm length.
.30" rods.

H₂O + lead and bond sheet (centered in array.)


Have an 23 x 23 array, with the center row removed in 1 direction, and 3 rods removed from each corner. Total of 494 rods.
(Note this is all of un-clad rods.)

1000 Water ht = 41.50 cm Probe in) Temp °C
system sub critical 37.60"
Drain. #1 = 23.2°C
#2 = 23.2°C



Remained the same. Total of 472 rods. (see diagram).

Water ht = 41.50 cm .250" Bond Sheet. Temp °C
system sub critical 37.74"
Drain: (No enrichment) #1 = 23.2°C
#2 = 23.2°C



.250" Bond Sheet


Have an 20 x 20 array. With the .250" x 10.0" x 12.27" boron plate centered on 1 row next to 1 face of array. Total of 400 rods.

1523 Water ht = 41.80 cm Temp °C
system sub critical #1 = 23.5°C
Drain. #2 = 23.5°C

added 6 rods to 1 face: see diagram. Total of 406 rods.

Water ht = 42.80 cm Temp °C
+ Per. #1 = 23.5°C
#2 = 23.5°C
L = 206.43 mm = 5.4 ft

Water ht = 35.00 cm
system just critical
Drain.



1.3 cm separation c-c.
30 cm length.
.30" rods.

H₂O + lead and bond sheet (centered in array.)

Have an 23 x 23 array, with the center row removed in 1.30" rods 30 cm length from each so 1.3 cm sep. c-c to be removed

(Note this is all H₂O + lead and bond sheet centered in array. 23 x 23 array with center row removed in 1 direction 3 rods removed from each corner. Total rods 494.

1200


Water ht = 41. System sub-critical Drain.

Temp °C
#1 = 23.2 °C
#2 = 23.2 °C
log #5 Page 178

Removed the 12th row of rods. (see diagram). Total of 472 rods.

Water ht = 41.90 cm. Probe (in) System sub-critical Drain: (No enclosure) 37.74

Temp °C
#1 = 23.2 °C
#2 = 23.2 °C



.250" Bohr's Schematic

Have an 20 x 20 array with the .250" x 10.0" x 12.27" boron plate centered on 1 row next to 1 face of array. Total of 400 rods.

1523

Water ht = 41.80 cm System sub-critical Drain.

Temp °C
#1 = 23.5 °C
#2 = 23.5 °C

Added 6 rods to 1 face. See diagram. Total of 406 rods.

Water ht = 42.80 cm + Per.

E = 206.43 cm = 5.4 f

Water ht = 35.00 cm System just critical Drain.

.30" Rods 30 cm length
1.3 cm Sep. c-c
20 x 20 array + 6 rods on 1 face. Boron plate instead on 1 face
Total rods 406
log #5 P-179

5 °C
5 °C

1.3 cm separation c-c.
30 cm length.
.30" rods.

H₂O + lead and bond sheet (centered in array.)

Have on 23 x 23 array, with the center row removed in 1 .30" rods 30 cm length from each so 1.3 cm sep. c-c to removed 4 rods.

(Note this is all H₂O + lead and bond sheet centered in array. 23 x 23 array with center row removed in 1 direction 3 rods removed from each corner. Total rods 494. Log # 5 Page 178

1000

Water ht = 41. System sub-critical Drain. Temp °C #1 = 23.2° #2 = 23.2°

Removed the 12 .30" rods 30 cm length (see diagram). Total of 472 rods 1.3 cm sep. c-c H₂O + lead and bond sheet centered in array.

Water ht = 41.90 System sub-critical Drain: (No error) Temp °C #1 = 23.2° #2 = 23.2°


Have an 20 x 20 array. With the .250" x 10.0" x 12.27" boron plate centered on 1 row next to 1 face of array. Total of 400 rods.

1523 Water ht = 41.80 cm System sub-critical Drain. Temp °C #1 = 23.5° #2 = 23.5°

Added 6 rods to 1 face: see diagram. Total of 406 rods.

Water ht = 42.80 cm + Per. Temp °C #1 = 23.5° #2 = 23.5°

E = 206.43 cm = 5.9 f Water ht = 35.00 cm System just critical Drain.



INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3 X 10 ⁻¹²	✓	4"	✓	3 X 10 ⁻¹²
"	"	✓	1"	✓	"
K-2	"	✓	4"	✓	"
"	"	✓	1"	✓	"
F-1					
F-2					
SWL 7000		✓	15"	✓	5000
SWL 12000		✓	10"	✓	9000
"		✓	1"	✓	"

LOG IN CALIBRATE _____ OPERATE _____ SOURCE No. 0-80
 BUMP WELL FROSE LIGHT _____

START-UP CHECK LIST
 Equipment checked by AMAL
 Instruments and sensors checked and report by AMAL
 Report in checked by AMAL source No. M-43
 Emergency equipment in control room checked by F.H.C.
 Instruments in field checked by K-1-2 AMAL
 Red light on by AMAL time 0928
 Report-up OK'd by F.H.C. AMAL Date 12-6-72

1.30 cm separation e-e,
 30 cm length,
 130" rods.

Same array described on p-179.
 Remained 2 rods: Total of 404 rods.

Water ht = 42.0 cm Probe (in) Temp °C
 1 - Per 37.77" #1 = 23.5 °C
 2 - 319.43 cm = 4.6 f 2 = 23.5 °C

1052 Drain:

Added 1 rod: Total of 405 rods:

Water ht = 41.90 cm Probe (in) Temp °C
 2 - Per 37.69" #1 = 23.5 °C
 2 = 23.5 °C

1019 Drain:

START-UP CHECK LIST

Equipment checked by F.I.C. Personnel check by F.I.C.
 Instruments and safeties checked and reset by R.K.M.
 Source in checked by R.K.M. Source No. M-93
 Emergency equipment in control room checked by F.I.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red Light on by R.K.M. Time 1330
 Start-up OK'd by F.I.C., R.K.M. Date 12-11-72

INSTRUMENT CHECK


INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	3x10 ⁻¹²
"	"	Fast ✓	1"	✓	"
K-2	"	Meter ✓	4"	✓	"
"	"	Fast ✓	1"	✓	"
P-1					
P-2					
PM-1	900V	Alarm ✓	5"	✓	500V
PM-2	1200V	Fast ✓	10"	✓	900V
"	"	Alarm ✓	1"	✓	"
LAMP CALIBRATE ✓		OPERATE ✓		SOURCE No. <u>D-80</u>	
LAMP WELL ABOVE LIGHT _____					

130 cm separation c-s,
 30 cm length,
 130" rods.

Have an 23x23 array, with the 3rd, 6th, 9th, 12th, 15th, 18th, & 21st row removed in 2 directions. Have the 250"x10.0"x12.27" bond plate centered in the 6th row (see diagram) 256 rods.

1350

Water ht = 43.
 System sub critical
 Drain.



Now have an 23x23 array, with the 6th row removed in 1 direction (Bond plate centered in that row), and 3 rods removed from each corner. Total of 499 rods. (This is all of un-lead rods).

1440

Water ht = 30.40 cm
 System just critical
 Drain.

Temp °C
 #1 = 23.4°C
 2 = 23.5°C

over.

1.30 cm separation c-c,

183

3 7.30 cm sep--c c

3 130" rods 30 cm long

Have an 23 x 23

12th, 15th, 18th

2 directions. 1

plate centered

256 rods.

234 23 mm with Basin

plate in 6th row

Log 45 P-183

6th, 9th,

rod in

2.27" bore

(see diagram)

1350

Water ht = 43.00 cm

system sub critical

Drain.

Temp °C

#1 = 23.5 °C

2 = 23.5 °C

Now have an 23 x 23 array, with the 6th row removed in 1 direction (Borel plate centered in that row), and 3 rods removed from each corner. Total of 494 rods. (This is all of un-rod rods).

1440

Water ht = 30.40 cm

system just critical

Drain.

Temp °C

#1 = 23.4 °C

2 = 23.5 °C

over:

Removal 12 rods from 1 face: (see diagram)
 Now have a total of 482 rods.

1525 Water ht = 42.00 cm
 System sub critical
 Drain.

Temp °C
 #1 = 23.5 °C
 #2 = 23.5 °C

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	START-UP RANGE
K-1	3x10 ⁻¹²	Master ✓	4"	✓	3x10 ⁻¹²
	"	Fast ✓	1"	✓	"
K-2	"	Master ✓	4"	✓	"
	"	Fast ✓	1"	✓	"
R-1					
R-2					
RA-1	700 V	Alarm ✓	5"	✓	500 V
RA-2	1200 V	Low ✓	10"	✓	900 V
	"	Alarm ✓	1"	✓	"
LOG & CALIBRATE ✓		OPERATE ✓		SOURCE No. B-80	
DUMP WELL PROBE LIGHT _____					

START-UP CHECK SHEET

Equipment checked by ^{F.I.D.C.} BKM Personnel check by F.I.D.C.
 Instruments and safeties checked and reset by RKAJ
 Source is checked by BKM Source No. M-43
 Emergency equipment to be checked was checked by F.I.D.C.
 Instruments in trip circuit: R-1-2 RM-1-2
 Red light on by BKM Time 1043
 Start-up OK'd by F.I.D.C. BKM Date 12-12-72

Added 2 rods: total number of rods = 484.

Water ht = 42.10 cm Probe (in) Temp °C
 1-Per #1 = 23.2 °C
 N.G. #2 = 23.5 °C
 Drain


1105

Added 2 rods:

Water ht = 42.35 cm Temp °C
 2-Per #1 = 23.5 °C
 C = 315.08 cm = 3.9 ft #2 = 23.5 °C

1309

Water ht = 36.00 cm
 System just critical
 Drain.



avg.

STANDARD CHECK LIST

Equipment checked by ^{F.I.D.C.} AKM Personnel check by F.I.D.C.
 Instruments and safeties checked and reset by AKM
 Source is checked by AKM Source No. M-43
 Emergency equipment in school room checked by F.I.D.C.
 Instruments in trip checked: R-1-2 PM41-2
 Bell light on by AKM Date 10-43
 Starting date by F.I.D.C. AKM Date 12-12-72

23.5°
 23.5°

Added 2 rods: .36" rods 30cm length
 1.30 cm. sep. e.e.
 23 x 23 array with
 brown plate in 6th row
 Total rods 486
 Jags #5 P-185
 989.
 Water ht = 42.1
 1-Per
 N.E
 Drain
 1105
 Temp °C
 1 = 23.2°
 2 = 23.5°

Added 2 rods: Total number of rods = 486.

Water ht = 42.10 cm ^{dh = 6.1cm} Probe (in) Temp °C
 2-Per 37.73 #1 = 23.5°
 C = 315.08 _{new} = 3.74 2 = 23.5°

1309 Water ht = 36.00 cm
 System just initiated
 Drain.

avr:

Remained 1 rod: Total number of rods = 485.

Water ht = 42.40 cm Probe (in) Temp °C
 3-Per 37.85 $T_1 = 23.5^\circ$
 $T_2 = 23.5^\circ$
 $\epsilon = -230,33 \mu\text{m} = -6.84$

1330

Drain:

Now have an 23 x 23 array, with the 6th row removed in 1 direction (Bond plate centered in this row.) With 15 rods removed from 1 face. (see diagram). Total of 491 rods.

Water ht = 42.10 cm Temp °C
 4-Per $T_1 = 23.5^\circ$
 N.G. $T_2 = 23.5^\circ$

1430


Drain:

added 2 rods: To see diagram). 13 rods

Water ht = 42.80 Temp °C
 5+Per $T_1 = 23.5^\circ$
 $T_2 = 23.5^\circ$
 $\epsilon = 209,26 \mu\text{m} = 5.64$

1500

Water ht = 35.40
 System just critical
 Drain.



INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	SET	STARTUP RANGE
PM 1	3×10^{-12}	Alarm ✓	4"	✓	3×10^{-10}
"	"	Low ✓	1"	✓	"
"	"	Alarm ✓	4"	✓	"
"	"	Low ✓	1"	✓	"
PM 1	700 V	Alarm ✓	5"	✓	500 V
PM 2	1200 V	Low ✓	10"	✓	900 V
"	"	Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE SOURCE No. B-80
 CHAMP WELL PROBE LIGHT

START-UP CHECK LIST

Equipment checked by AKM Personnel check by F.D.C.
 Instruments and safeties checked and reset by AKM
 Source in checked by AKM Source No. M-43
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1-2 PM 1-2
 Red Light on by AKM Time 0824
 Start-up OK'd by F.D.C., A. X.M. Date 12-13-72

Removed 1 rod: Total number of rods = 485.

1330 Water ht = 42.90 cm Probe (in) Temp °C
 3-Per 37.85 #1 = 23.5°
 T = -230.33 cm = -6.8 f #2 = 23.5°
 Drain:

Now have an 23 x 23 array, with the 6th row removed in 1 direction (Bond plates centered in the 30" rods 30 cm long. removed from 1 face. (see 1.30 cm. sep. c-c 29 rods. 23 x 23 array with lower plate centered in 6th row. and 13 rods removed from 1 row. Total rods 493 log #5 P-186

1430 Water ht = 42.10 cm Temp °C
 4-Per #1 = 23.5°
 N.G. #2 = 23.5°
 Drain:

added 2 rods: Total number of rods = 493. (see diagram). 13 rods removed from 1 row.

Water ht = 42.80 cm ^{5.8 f} Probe (in) Temp °C
 5+Per 38.04 #1 = 23.5°
 T = 204.26 cm = 5.6 f #2 = 23.5°

1500 Water ht = 35.90 cm
 System just critical
 Drain.

Repeat of last run. p-186.

Water ht = 42.00 cm Probe (in) Temp °C
+ Per 37.77 #1 = 23.5°
C = 184.70 sec = 6.0 f 2 = 23.5°

0850 Water ht = 35.39 cm
System just critical
Drain

Removed 1 rod. Total number of rods = 492.

Water ht = 41.90 cm Probe (in) Temp °C
- Per 37.66 #1 = 23.5°
C = 325.95 sec = -4.5 f 2 = 23.5°

0910 Drain.

Now have an 23x23 array, with the 6th row removed in 1 direction. (.035" x 10.0" x 12.27" Cd sheet centered in this row). With 12 rods removed from 1 face. (see diagram) Total of 499 rods.

1302 Water ht = 26.10 cm Probe (in) Temp °C
System just critical 31.46 #1 = 23.5°
Drain 2 = 23.7°

Removed 34 rods. Now have an 21x23 array. Total of 460 rods.

1340 Water ht = 30.10 cm
System just critical
Drain.

Removed 15 rods. Now have an 21x22 array, plus 5 rods on 1 face. (see diagram). Total of 445 rods.


Water ht = 42.10 cm Probe (in) Temp °C
- Per 37.70 #1 = 23.7°
N.C. 2 = 23.7°

1405 Drain.

added 2 rods. So
Water ht = 42.2
+ Per.

C = 695.36 sec = 1.

1447 Water ht = 36.90
System just critical
Drain



Temp °C
#1 = 23.7°
2 = 23.7°

Removed 39 rods. Now have an 21x23 array.
Total of 460 rods.

1340 Water ht = 30.10 cm
System just critical
Drain.

Removed 15 rods: 30" rods 30 cm long
5 rods on 1 face. 1.30 cm separation c-c
21x22 array + 9 rods on
1 face total rods 447
Water ht = 42.10 cm
Now cd. sheet centered
in 6th row.
3 - Per. tag # 5 P- 189

array, plus
445 rods.
Temp °C
#1 = 23.7 °C
2 = 23.7 °C

N.G.
1805 Drain.

added 2 rods: Total of 447 rods.
Water ht = 42.20 cm ^{0.4 = 5.3 cm} Probe (in)
7 Per. 37.19
T = 695.36 sec = 1.84

Temp °C
#1 = 23.7 °C
2 = 23.7 °C

1447 Water ht = 36.90 cm Probe (in)
System just critical
Drain

23.5 °C
3.5 °C

92.

23.5 °C
23.5 °C

sheet
cd
rod.

23.5 °C
3.7 °C

INSTRUMENT CHECK					
INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3000 ⁻¹²	Meter ✓	4"	✓	10 K10 ⁻¹²
		Fast ✓	1"	✓	"
K-2	3000 ⁻¹²	Meter ✓	4"	✓	"
		Fast ✓	2"	✓	"
PM-1	700 V	Alarm ✓	5"	✓	500 V
PM-2	1200 V	Low ✓	10"	✓	900 V
		Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT
 RADIATION ALARM: A B C SOURCE NUMBER B-801

START-UP CHECK LIST

Equipment checked by I.V.C. AKK Personnel check by F.P.C.
 Instruments and safeties checked and reset by AKK
 Source in checked by AKK Source No. M-43
 Emergency equipment in control room checked by F.P.C.
 Instruments in trip circuit; K-1-2 PM1-2
 Red light on by AKK Time 0920
 Start-up OK'd by I.V.C. AKK Date 1-10-73

1.30 cm separation c.e.,
 30 cm length.
 130" rods.

H₂O = 25.60 cm = top of rods.

Now have on 1 face (west face) spaced .269 cm
 from array 1 pc of Depleted Uranium
 8.625" height x 10.1875" length x 23.875" Total mass = 640 kg.

Average of 4 measurements by M.E. 7/1/73
 78.55" (20.17m) x 10.24" (25.55m) x 23.7825" (60.4cm)
 Have an 20x20-2 array. Total 398 rods.
 DA = .60 cm


Water ht = 31.70 cm Temp °C
 + Per #1 = 23.0 °C
 T = 65.19 sec = 13.6 f = 22.74 / cm #2 = 23.0 °C

0955 Water ht = 31.10 cm
 System just critical
 Drain.

Removed 6 rods. Now have an 20x20-8 array.
 Total of 392 rods.

Water ht = 42.30 cm Probe
 + Per DA = 0.5 cm 37.
 C = 347.68 sec = 3.4 f = .52 f / cm

1033 Water ht = 35.80 cm
 System just critical
 Drain.



over

1.30 cm separation c-c,
 30 cm length,
 1.30" rods,

H₂O = 25.60 cm = top of rods.

Now have on 1 face (west face) spaced .269 cm
 from array 1 pc of Depleted Uranium

8.625" x 10.1875" x 23.875". Total mass = 640 kg.

Average of 4
 measurements
 by M.C. 7/11/75

8.55" (21.72 cm) x 10.24" (25.55 cm) x 23.7825" (60.4 cm)

Now an 20 x 20 - 2 array. Total 398 rods.

DA = .60 cm

Water ht = 31.70 cm

Temp °C

+ Per

#1 = 23.0 °C

C = 65.19 sec = 13.6 f = 22.74 / cm

0955 Water ht = 31.10 cm

System just critical
 Drain.

P = 191 - 2.0 °C
 20 x 20 array length 5
 Total 392 rods.
 1.30 cm sep. c-c
 30 cm. length
 1.30" dia.
 1 PC Depleted Uranium
 8.625" x 10.1875 x
 23.875, 640 kg.

Removed 6 rods. Now have an
 Total of 392 rods.

Water ht = 42.30 cm
~~47.30~~ Probe (in)

Temp °C

+ Per.

DA = 6.5 cm 37.83"

#1 = 23.2 °C

C = 347.68 sec = 3.9 f = 15.24 / cm.

#2 = 23.2 °C

1033 Water ht = 35.80 cm

Probe (in)

System just critical
 Drain.

35.23"

over:

Removed 1 rod. Now have an 20x20-9 array.
Total of 391 rods.

1050 Water ht = 41.90 cm
System sub critical
Over.

Temp °C
H1 = 23.2 °C
H2 = 23.2 °C

INSTRUMENT	RANGE	INSTRUMENT CHECK				STARTUP RANGE
		TRIP	SOURCE DISTANCE	RESET		
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	10x10 ⁻¹²	
		Fast ✓	1"	✓	"	
K-2	3x10 ⁻¹⁴	Meter -	4"	✓	"	
		Fast ✓	3"	✓	"	
PM-1	700 ✓	Alarm ✓	5"	✓	500 ✓	
PM-2	1200	Low ✓	10"	✓	700 ✓	
		Alarm ✓	1"	✓	"	

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT
RADIATION ALARM: A B C SOURCE NUMBER B-30

START-UP CHECK LIST

Equipment checked by F.V.C. / A.M.L. Personnel check by F.V.C.
Instruments and safeties checked and reset by A.M.L.
Source in checked by A.M.L. Source No. M-83
Emergency equipment in control room checked by F.V.C.
Instruments in trip circuit: K-1-2 PM-1-2
Red light on by A.M.L. Time 0840
Start-up OK'd by F.V.C. / A.M.L. Date 1-11-72

1.3 cm separation c-e
30 cm length.
30 Rods.

Depleted Uranium reflector.

Have an 19x23 array: will the 4th, 8th, 12th & 16th row removed in 1 direction and the 4th, 8th, 12th & 16th & 20th row in 1 direction. Have 1 cluster in 1 row removed and 3 rods in 1 cluster removed. Total of 258 rods.

Water ht = 35.30 cm Probe (in) Temp °C
+ Per 35.10" H1 = 23.0 °C
C = 71.71 sec H2 = 23.0 °C

0920 Water ht = 32.60 cm Probe (in) System just critical 34.00
Over.

Removed 2 rods. Total of 256 rods.


Water ht = 41.90 cm Probe (in) Temp °C
2-Per 37.65" #1 = 23.0°C
N.G. 2 = 23.0°C
0940 Drain.

Added 1 rod. Total of 257 rods.

4 rods in 1 cluster removed.

Water ht = 42.00 cm ^{Δh = 7.85 cm} Probe (in) Temp °C
3-Per 37.74" #1 = 23.0°C
E = 154.28 new. 6.9¢ 2 = 23.0°C

Water ht = 34.15 cm Probe (in)
System just critical 34.61"
Drain.



Now have an 20x23 array, with the 3rd, 6th, 9th, 12th, 15th, 18th, row removed in 1 direction and the 3rd, 6th, 9th, 12th, 15th, 18th & 21st row in 1 direction. Total of 224 rods.

1332 Water ht = 42.00 cm Probe (in) Temp °C
System sub-critical 37.65" #1 = 23.0°C
Drain. 2 = 23.0°C


Added 8 rods (2 clusters). Now have an 23x23 array or distribute above, with 6 clusters removed from 1 row. Total of 232 rods.

1350 Water ht = 41.90 cm Temp °C
System sub-critical #1 = 23.0°C
Drain. 2 = 23.0°C

Added 2 rods. Total of 234 rods.

Water ht = 42.30 cm ^{Δh = 7.11 cm} Probe (in) Temp °C
4-Per 37. #1 = 23.0°C
E = 310.74 new = 3.8¢ 2 = 23.0°C

1417 Water ht = 35.20 cm Probe (in)
System just critical 35.07"
Drain.



Removed 2 rods. Total of 256 rods.

Water ht = 41.90 cm Probe (in) Temp °C
 2-Per 37.65" #1 = 23.0°C
 N.G. 2 = 23.0°C
 Drain:

0940

Added 1 rod. Total of 257 rods.

4 rods in 1 cluster removed.
 Water ht = 42.00 cm ^{0.4 = 1.85 cm} Temp °C
 3-Per 19x23 array with 4th 8, 12, + 16th row removed in 1 direction and 4th 8th 12, 16, 20 row in 1 direction. Temp °C
 C = 154.28 sec. 6.9f 23.0°C
 Water ht = 37.15 cm 23.0°C
 System just critical
 Drain
 Total rods 257
 P-194 log #5

Now have an 20x23 array, with the 3rd, 6th, 9th, 12th, 15th, 18th, now removed in 1 direction and the 3rd, 6th, 9th, 12th, 15th, 18th & 21st now in 1 direction. Total of 224 rods.

1332 Water ht = 42.00 cm Probe (in) Temp °C
 System sub-critical 37.65" #1 = 23.0°C
 Drain. 2 = 23.0°C

Added 8 rod (2 clusters). Now have array as described above. from 1 row. Total of 23. 2³x23 array with 6 clusters removed from 1 face. Total rods 234. See page 195 log #5 removed

1350 Water ht = 41.90 cm System sub-critical Drain.

Added 2 rods. Total of 234 rods. (see diagram).
 Water ht = 42.30 cm ^{0.4 = 1.1 cm} Probe (in) Temp °C
 4-Per 37.90" #1 = 22.8°C
 C = 310.74 sec = 3.8f 2 = 23.0°C

1417 Water ht = 35.20 cm Probe (in)
 System just critical 35.07"
 Drain.

Removed 1 rod. Total of 233 rods.

1425 Water ht = 42.20 cm Probe (in) Temp °C
 System sub critical 37.80" #1 = 22.5°C
 Drain. 2 = 23.0°C

INSTRUMENT	RANGE	INSTRUMENT CHECK			
		TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3 x 10 ⁻¹²	Meter ✓	4"	✓	10 x 10 ⁻¹²
		Fast ✓	1"	✓	"
K-2	3 x 10 ⁻¹²	Meter ✓	4"	✓	"
		Fast ✓	2"	✓	"
PM-1	700 V	Alarm ✓	5"	✓	500 V
PM-2	1200 V	Low ✓	10"	✓	900 V
		Alarm ✓	10"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT
 RADIATION ALARM: A B C SOURCE NUMBER B-80

1.3 cm separation c-c.
 30 cm length.
 38 rods.

START-UP CHECK LIST

Equipment checked by F.I.D.C. Personnel check by AKM.
 Instruments and safeties checked and reset by AKM
 Source in checked by AKM Source No. M-43
 Emergency equipment in control room checked by F.I.D.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by AKM Time 0950
 Start-up OK'd by F.I.D.C. AKM Date 1-15-73

Have on 22 x 22 array. With the 11th & 12th row of rods removed in 2 directions. Plus 9 rods on each corner. Total of 360 rods.

Water ht = 41.40 cm Probe (in) Temp °C
 System sub critical 37.52" #1 = 22.5°C
 Drain. 2 = 22.5°C

Added 8 rods. 2 to each corner. Total of 368 rods.

1030 Water ht = 41.60 cm Probe (in) Temp °C
 System sub critical 37.64" #1 = 22.5°C
 Drain. 2 = 22.5°C

over.

added 8 rods. 2 to each corner: Total of 376 rods.


1055 Water ht = 41.90 cm Probe (in) Temp °C
System sub critical 37.71" #1 = 22.5 °C
Drain. 2 = 22.5 °C

added 8 rods. 2 to each corner: Total of 384 rods;

1300 Water ht = 42.10 cm Probe (in) Temp °C
1-Per 37.80" #1 = 22.5 °C
N.5. 2 = 22.5 °C
Drain.

added 2 rods: 1 to opposite corners: Total of 386 rods;

1328 Water ht = 42.20 cm
2+Per
5 = 462.85 new = 2.6 f
Water ht = 35.90 cm
System just critical
Drain.




Removed 1 rod from corner: Total of 385 rods:
Water ht = 42.40 cm Probe (in) Temp °C
3-Per 37.87" #1 = 22.5 °C
52 = 271.62 new = -5.6 f 2 = 22.7 °C

1350 Drain.

Now have an 23x23 array, with the 11th, 12th & 13th rows removed in 2 directions: Total of 400 rods.

1415 Water ht = 42.80 cm Probe (in) Temp °C
System sub critical 38.00" #1 = 22.5 °C
Drain. 2 = 22.7 °C



added 8 rods. 2 to each corner: Total of 376 rods.

1055 Water ht = 41.90 cm Probe (in) Temp °C
system sub critical 37.71" #1 = 22.5 °C
Drain. 2 = 22.5 °C

added 8 rods. 2 to each corner: Total of 384 rods;

1300 Water ht = 42.10 cm Probe (in) Temp °C
1-Per 22x22 array #1 = 22.5 °C
N.S. with 11 + 12 rows 2 = 22.5 °C
Drain. removed in 2 directions
Total rods 386

added 7 rods: 1 to opp. P. 198 log of 386 rods
dh = 6.3 cm

Water ht = 42.20 cm 1 rod (in) Temp °C
2+Per 37.87" #1 = 22.5 °C
E = 462.85 new = 2.6 f 2 = 22.5 °C

1328 Water ht = 35.90 cm Probe (in)
system just critical 35.32"
Drain.

Removed 1 rod from corner: Total of 385 rods:
Water ht = 42.40 cm Probe (in) Temp °C
3-Per 37.87" #1 = 22.5 °C
E = 471.62 new = -5.6 f 2 = 22.7 °C

1350 Drain.

Now have an 23x23 array with 11, 12 + 13th row removed. in 2 directions
Total rods 400

dh = 13.5 cm
400 rods.

1415 Water ht = 42.80 cm Temp °C
system sub critical #1 = 22.5 °C
Drain. 2 = 22.7 °C

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter	4"	✓	10x10 ⁻¹²
		Fast	1"	✓	"
K-2	"	Meter	4"	✓	"
		Fast	3"	✓	"
PM-1	7000	Alarm	.5"	✓	5000
PM-2	12000	Low	10"	✓	9000
		Alarm	1.0"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT
 RADIATION ALARM: A B C SOURCE NUMBER B-80


START-UP CHECK LIST

Equipment checked by F.I.C. Personnel check by AKK
 Instruments and safeties checked and reset by AKK
 Source in checked by AKK Source No. 18-93
 Emergency equipment in control room checked by F.I.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by AKK Time 1235
 Start-up OK'd by F.I.C., AKK Date 1-16-73

1.3 cm separation c-c,
 30 cm length,
 130 rods.

Have an 23x23 array, with the 3rd, 6th, 9th, 12th, 15th, 18th, 21st row removed in 2 directions. Total of 256 rods. Have centered in center row 1 pc of S.S. plate (.250" x 10.00" x 12.27"). See diagram.

Depleted Uranium
 8.625" x 10.1575" x 22.275"



1300 Water ht = 42.70 cm / System sub critical Drain.

Temp °C
 1 = 22.7 °C
 2 = 22.7 °C

Now have an 23x23 or 16th, 19th, 20th row removed. Total of 315 rods. 1 cluster of rods removed from 1 row. 2, plus 8th, 12th, 2, plus S.S. PLATE.

Water ht = 30.10 cm Probe (in) 33.04" Temp °C
 1 = 23.0 °C
 2 = 23.0 °C
 C = 54.32 cm = 15.5 ft

1440 Water ht = 29.60 cm Probe (in) 32.84" System just critical Drain.

Removed 1 cluster of rods. Total number of rods = 306.

over:

INSTRUMENT CHECK					
INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻²	Meter	4"	✓	10x10 ⁻¹²
		Fast	1"	✓	"
K-2	"	Meter	4"	-	"
		Fast	3"	✓	"
PM-1	7000	Alarm	.5"	✓	5000
PM-2	12000	Low	10"	✓	7000
		Alarm	1.0"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT
 RADIATION ALARM: A B C SOURCE NUMBER B-80

START-UP CHECK LIST

Equipment checked by Z.V.C. Personnel check by AKK
 Instruments and safeties checked and reset by AKK
 Source in checked by AKK Source No. 19-93
 Emergency equipment in control room checked by Z.V.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by AKK Time 1235
 Start-up OK'd by F.V.C., AKK Date 1-16-73

1.3 cm size
 30 cm dia 23x23 array, with
 130 rods. row 3, 6, 9, 12, 15, 18,
 + 21 removed in 2

directions. 55 plate
 15th, 18th, 21st row in center
 Total of 256 rods. 1 dia + total rods 256
 row 1 per of S.S. plate P-201
 see diagram.

1300 Water ht = 42.70 cm Probe (in)
 System sub critical 38.05"
 Drain.

Temp °C
 #1 = 22.7 °C
 2 = 22.7 °C

Now have an 23x23 array, with the 4th, 8th, 12th,
 16th, + 20th row removed in 2 directions, plus
 1 cluster of rods removed from 1 row.
 Total of 315 rods.

Water ht = 30.10 cm Probe (in)
 + Per 33.09"
 C = 54.32 row = 15.54

Temp °C
 #1 = 23.0 °C
 2 = 23.0 °C

1440 Water ht = 29.60 cm Probe (in)
 System just critical 32.84"
 Drain.

Removed 1 cluster of rods. Total number of
 rods = 306.


over:

Water ht = 42.60 cm Probe (in) Temp °C
 2-Per 37.99" H1 = 23.0 °C
 E = -193.40 now = -8.5 f 2 = 23.0 °C
 1500 Drain.

Added 1 rod. Total number of rods = 307.
 See diagram.

Water ht = 42.10 cm Probe (in) Temp °C
 3 + Per 37.79 H1 = 23.0 °C
 E = 254.24 now = 4.5 f 2 = 23.0 °C

1523 Water ht = 34.80 cm Probe (in)
 System just critical 34.90"
 Drain.



INSTRUMENT CHECK					
INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	10 x 10 ⁻¹²
		Fast ✓	1"	✓	4
K-2	"	Meter ✓	4"	✓	"
		Fast ✓	3"	✓	"
PM-1	700V	Alarm ✓	1.5"	✓	500V
PM-2	1200V	Low ✓	10"	✓	900V
		Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT
 RADIATION ALARM: A B C SOURCE NUMBER D-401

START-UP CHECK LIST

Equipment checked by F.I.C. Personnel check by F.I.C.
 Instruments and safeties checked and reset by A.K.A.
 Source in checked by A.K.A. Source No. M-43
 Emergency equipment in control room checked by F.I.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by A.K.A. Time 0950
 Start-up OK'd by F.I.C. A.K.A. Date 1-17-73

Water ht = 42.60 cm Probe (in) Temp °C
 2-Per 37.99" 41 = 23.0°C
 E = -193.40 cm = -8.5 f 2 = 23.0°C
 1500 Drain.

Added 1 rods. Total num 307.
 see diagram.

23x23 array with
 4, 8, 12, 16 + 20th row
 removed in 2 direction
 + 2 clustering of rods
 removed
 Total rods 307
 Page 202

Water ht = 42.10 cm Temp °C
 3-Per 41 = 23.0°C
 E = 254.24 cm = 4.5 f 2 = 23.0°C

1523 Water ht = 34.80 cm
 System just critical
 Drain.

INSTRUMENT CHECK					
INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	10x10 ⁻¹²
		Fast ✓	1"	✓	4
K-2	"	Meter ✓	4"	✓	"
		Fast ✓	3"	✓	"
PM-1	700V	Alarm ✓	5"	✓	500V
PM-2	1200V	Low ✓	10"	✓	900V
		Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT
 RADIATION ALARM: A B C SOURCE NUMBER P-901

START-UP CHECK LIST

Equipment checked by F.D.C. AKA Personnel check by F.D.C.
 Instruments and safeties checked and reset by AKA
 Source in checked by AKA Source No. M-43
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by AKA Time 0950
 Start-up OK'd by F.D.C. AKA Date 1-17-73

Repeat of last run, p-202.

Water ht = 42.10 cm
+ Per

Probe (in)
37.79"

Temp °C
#1 = 23.0°C
#2 = 23.0°C

E = 391.14 sec = 3.14 s

1030

Water ht = 35.50 cm
System just critical
Drain.

Probe (in)
35.18"

Repeat of above:

Water ht = 42.10 cm
+ Per

Probe (in)
37.79

Temp °C
#1 = 23.0°C
#2 = 23.0°C

E = 391.16 sec = 3.5 s

1120

Water ht = 35.30 cm
System just critical
Drain.

Probe (in)
35.11"

INSTRUMENT CHECK					
INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	10x10 ⁻¹²
		Fast ✓	1"	✓	"
K-2	3x10 ⁻¹²	Meter ✓	4"	✓	"
		Fast ✓	2"	✓	"
PM-1	700 ⁵	Alarm ✓	5"	✓	500 ⁵
PM-2	1200 ⁵	Low ✓	10"	✓	900 ⁵
		Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT
RADIATION ALARM: A B C SOURCE NUMBER B-801

START-UP CHECK LIST

Equipment checked by ^{F.I.C.} AKA Personnel check by PKR
Instruments and safeties checked and reset by AKA
Source in checked by PKR Source No. M-43
Emergency equipment in control room checked by F.I.C.
Instruments in trip circuit: K-1-2 PM-1-2
Red light on by AKA Time 0850
Start-up OK'd by F.I.C., AKA Date 1-19-73

1.3 cm separation c.c.
 30 cm length
 .30" rods
 Depleted Uranium + .250" S.S. plate

Have an 20x20-6 array: Total of 394 rods:
 S.S. plate on face of depleted uranium reflection.
 See diagram.

Water ht = 33.90 cm Probe (in) Temp °C
 + Per. 34.58" #1 = 23.5°
 C = 5432 rev = 15.5 f #2 = 23.5°

0933 Water ht = 32.10 cm Probe (in) Temp °C
 system just critical 33.83"
 Drain.




Remained 2 rods: Total of rods = 392.

Water ht = 42.30 cm Probe (in) Temp °C
 2 + Per. 23.5°
 C = 195.51 rev = 5.7 f 23.5°

0952 Water ht = 34.80 cm
 system just critical
 Drain.

Remained 1 rod: Total of
 Water ht = 43.10 cm
 3 - Per. 23.5°
 C = -441.12 rev = -3.2 f 2 = 23.5°

1005 Drain.



Have an 19x16 array: Total of 304 rods:
 8th, 12th, 16th rows removed in 1 direction.
 Have 1 cluster in 1 cluster
 251 rods.

Water ht = 41.90 cm Probe (in) Temp °C
 + Per. 37.68" #1 = 23.5°
 C = 102.13 rev = 9.7 f #2 = 23.7°

1450 Water ht = 33.45 cm Probe (in) Temp °C
 system just critical 34.37"
 Drain.

Remained 1 rod: Total of rods = 256

Water ht = 41.90 cm Probe (in) Temp °C
 5 - Per. 37.68" #1 = 23.7°
 C = -684.49 rev = -2.0 f #2 = 23.7°

1506 Drain.

1.3 cm separation c.c.
30 cm length
.30" rods
Depleted Uranium + .250" S.S. plate

Have an 20x20-6 array. Total of 394 rods.
S.S. plates on face of depleted uranium reflection.
see diagram.

Water ht = 33.90 cm
+ Per.

$\epsilon = 54.32 \text{ uw} = 15.5 \phi$

0933

Water ht = 32.10 cm
System just critical
Drain.

Probe (in) Temp °C
3 20x20 array - 23.5°
- 8 rods 3.5°
Total rods 392.
Reflected by depleted uranium, and S.S. plate.

Page 206

Removed 2 rods. Total of:

Water ht = 42.30 cm
+ Per

$\epsilon = 195.51 \text{ uw} = 5.7 \phi$

0952

Water ht = 34.80 cm
System just critical
Drain.

Probe (in) Temp °C
37.80" #1 = 23.5°
2 = 23.5°

Removed 1 rod. Total of rods = 391.

Water ht = 43.10 cm
+ Per

$\epsilon = -44.12 \text{ uw} = -3.2 \phi$

1005

Drain.

Probe (in) Temp °C
38.24 #1 = 23.5°
2 = 23.5°

19x23 array
4, 8, 12 & 16th
rows removed
Total rods 257
P-207

Have an 19x23 array. with the 4th, 8th, 12th
& 16th rows removed in 1 direction, and the 4th
8th, 12th, 16th & 20th rows removed in 1 direction.
Have 1 cluster in 1 row removed and 9 rods
in 1 cluster removed. Total of 251 rods.

Water ht = 42.30 cm
+ Per
 $\epsilon = 102.13 \text{ uw} = 9.7 \phi$
Water ht = 33.45 cm
System just critical
Drain

1450

Probe (in) Temp °C
37.89" #1 = 23.5°
2 = 23.7°
34.37"

Removed 1 rod. Total of rods = 250

Water ht = 41.90 cm
+ Per
 $\epsilon = -684.49 \text{ uw} = -2.0 \phi$
Drain.

1506

Drain.

INSTRUMENT CHECK					
INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	10x10 ⁻¹²
		Fast ✓	1"	-	"
K-2	3x10 ⁻¹²	Meter ✓	4"	✓	"
		Fast ✓	2"	-	"
PM-1	700V	Alarm ✓	5"	-	500V
PM-2	1200V	Low ✓	10"	-	900V
		Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT
 RADIATION ALARM: A B C SOURCE NUMBER B-80

START-UP CHECK LIST

Equipment checked by Z.O.C. AKL Personnel check by AKL
 Instruments and safeties checked and reset by AKL
 Source in checked by AKL Source No. M-43
 Emergency equipment in control room checked by F.H.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by AKL Time 0850
 Start-up OK'd by F.O.C. AKL Date 1-29-73

1.3 cm separation c-c.
 30 cm length.
 .30" rods.

Depleted Uranium 4.25" S.S. plate.

Have an 23x23 array, with the 3rd, 6th, 9th, 12th, 15th, 18th, & 21st rows removed in 2 directions. With 5 clusters & 2 rods from 1 cluster removed from 1 row. Total of 234 rods.

Water ht = 41.90 cm Probe (in) Temp °C
 1-Per 37.71 H₁ = 29.0°C
 T = 680.15 sec = 2.0 f H₂ = 29.1°C

0924


Drain...
 added 1 rod. Total number of rods = 235
 see diagram.

Depleted Uranium
 8.625" x 10.1875" x 23.875"
 .25" x 10.00" x 12.27"
 S.S. Plate.
 ↑ 26.9 cm ↓

0.4 = 7.45
 Water ht = 42.00 cm
 2+Per

0940

T = 191.22 sec = 5.8 f
 Water ht = 34.55 cm Probe
 System just critical
 Drain.



1.3 cm separation c-c.
 30 cm length.
 30" rods.

Depleted Uranium \pm .25" S.S. plate.

Have an 23 x 23 array, with the 3rd, 6th, 9th, 12th,
 15th, 18th, & 21st row removed in 2 directions.
 With 5 clusters & 2 rods from 1 cluster removed
 from 1 row. Total of 234 rods.

Water ht = 41.90 cm

1-Per

$T = 680, 15 \text{ sec} = 2.0 \text{ f}$

0924

Drain.

Added 1 rod. Total count
 see diagram.

f 23 x 23 array
 with 3, 6, 9, 12, 15, 18,
 21 row removed.
 in 2 directions, and
 5 clusters + 3 rods
 removed from 1
 cluster removed.
 from 1 row.
 Total rods 235

°C
 2.0°C
 .1°C

Water ht = 42.00 cm

2+Per

$T = 191.22 \text{ sec} = 5.8 \text{ f}$

0940

Water ht = 34.55 cm
 System just critical
 Drain.

P_{rod}(in)

37.76

P_{rod}(in)

34.75"

Temp °C

#1 = 29.2°C

#2 = 27.2°C

INSTRUMENT	RANGE	INSTRUMENT CHECK			
		TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	7"	✓	10x10 ⁻¹²
		Fast ✓	"	✓	"
K-2	3x10 ⁻¹²	Meter ✓	9"	✓	"
		Fast ✓	2"	✓	"
PM-1	700v	Alarm ✓	.5"	✓	500v
PM-2	1200v	Low ✓	10"	✓	900v
		Alarm ✓	1.0"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT
 RADIATION ALARM: A B C SOURCE NUMBER B-80

START-UP CHECK LIST

Equipment checked by E.P.C. Personnel checked by E.P.C.
 Instruments and safeties checked and reset by AKL
 Source in checked by AKL Source No. M-43
 Emergency equipment in control room checked by E.P.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by AKL Time 1420
 Start-up OK'd by E.P.C. AKL Date 2-2-73

~~2.050~~ cm separation c.e.
 30 cm length,
 .30" rods (unclad)

H₂O + Depleted Uranium reflection centered on 1 face of array. Reflection 1.02 cm from face of array.
 H₂O = 25.60 cm = Top of rods.
 Have an 14x14+2 array. Total of 198 rods.

Water ht = 31.50 cm Probe (in) Temp °C
 + Per 33.62" #1 = 23.5 °C
 C = 76.05 au = 12.2 f 2 = 23.5 °C

Water ht = 30.80 cm Probe (in) Temp °C
 System just critical 33.30"
 Drain

1450

Removed 5 rods. Now have an 14x14-3 total of 193 rods.

Water ht = 41.90 cm Probe (in) Temp °C
 2-Per 37.69" #1 = 23.2 °C
 C = -391.14 au = -3.7 f 2 = 23.2 °C

1510

Drain.

over.


added 1 rod: Now
Total of 194 rods.

Water ht = 42.00 cm
+ Per
C = 154.28 m = 6.9 f

1530 Water ht = 33.90 cm

System just critical
Drain 34.52"

Depleted Uranium
8.625 X 10.1575 X 22.975"



INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	✓	4"	✓	3x10 ⁻¹²
		Fast	1"	✓	"
		Meter	4"	✓	"
K-2	3x10 ⁻¹²	✓	4"	✓	"
		Fast	1"	✓	"
		Meter	4"	✓	"
PM-1	7000	✓	5"	✓	5000
		Alarm	5"	✓	5000
		Low	10"	✓	9000
PM-2	12000	✓	1"	✓	"
		Alarm	1"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER B-80


START-UP CHECK LIST

Equipment checked by F.D.C. Personnel check by F.D.C.
 Instruments and safeties checked and reset by R.K.V.
 Source in checked by R.K.V. Source No. 19-93
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by R.K.V. Time 1250
 Start-up OK'd by F.D.C. R.K.V. Date 2-6-73

Moved Depleted uranium reflector to left-cell width. Now .627 cm from face of array. Repeat of last run 14x14-2 array. Total of 194 rods.

Water ht = 42.00 cm Probe (in) Temp °C
 1- Per 37.75" #1 = 23.5 °C
 C = -475.89 m = -3.0 f #2 = 23.5 °C
 1330 Drain.

Depleted Uranium
8.625 X 10.1575 X 22.975"



Added 1 rod: Now an 19 rods.
195 rods.

Water ht = 42.10 cm Probe
 2+ Per 3: 37.25 cm
 C = 280.32 m = 4.1 f

1355 Water ht = 34.85 cm
 System just critical
 Drain 34.92"

2.050 cm d-c.
30 cm long.
130" rods.
14 X 14 - 2 array.
Total of 194 rods.
Log #5
P-212

added 1 rod: now have an 14 X 14 - 2 array.
Total of 194 rods.

Water ht = 42.00 cm Probe (in) Temp °C
7 Per 37.72" #1 = 23.5 °C
C = 154.28 m = 6.9 f 2 = 23.7 °C

1530 Water ht = 33.90 cm Probe (in)
System just critical 34.52"
Drain

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	0 X 10 ⁻¹²	✓	4"	-	3 X 10 ⁻¹²
		Fast	1"	-	"
		Meter	4"	-	"
K-2	3 X 10 ⁻¹²	✓	4"	-	"
		Fast	1"	-	"
		Meter	4"	-	"
PM-1	7000	✓	5"	-	5000
		Alarm	5"	-	5000
		Low	10"	-	9000
PM-2	12000	✓	10"	-	9000
		Low	10"	-	9000
		Alarm	10"	-	9000

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT SOURCE NUMBER B-80

START-UP CHECK LIST

Equipment checked by I.D.C. Personnel check by F.I.P.C.
 Instruments and safeties checked and reset by AKM
 Source in checked by AKM Source No. 19-93
 Emergency equipment in control room checked by F.I.P.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by AKM Time 1250
 Start-up OK'd by F.I.P.C. R. Alf Date 2-6-73

Moved Depleted uranium relative to
 left-cell width. Now .6
 of array. Report of lost.
 Total of 194 rods.

2.050 cm d-c.
30 cm long.
130" rods.
14 X 14 - 1 array.
Total of 195 rods.
Log #5
P-213

Water ht = 42.00 cm Probe (in) Temp °C
1 Per 37.77" #1 = 23.5 °C
C = 475.89 m = -3.0 f 2 = 23.5 °C
Drain

1330

Added 1 rod: now have an 14 X 14 - 1 array. Total of 195 rods.

Water ht = 42.10 cm Probe (in) Temp °C
2 Per 37.77" #1 = 23.5 °C
C = 280.32 m = 4.1 f 2 = 23.5 °C

1355 Water ht = 34.85 cm Probe (in)
System just critical 34.92"
Drain

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	10x10 ⁻¹²
		Fast ✓	1"	✓	4
K-2	3x10 ⁻¹²	Meter ✓	4"	✓	"
		Fast ✓	1"	✓	"
PM-1	700 ✓	Alarm ✓	5"	✓	500 ✓
PM-2	1200 ✓	Low ✓	10"	✓	900 ✓
		Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER B-80

START-UP CHECK LIST

Equipment checked by I.V.C. RKL Personnel check by RKL
 Instruments and safeties checked and reset by RKL
 Source in checked by I.V.C. Source No. M-43
 Emergency equipment in control room checked by I.V.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by RKL Time 0830
 Start-up OK'd by I.V.C. RKL Date 2-8-73

2.050 cm separation e-e.
 30 cm length.
 .30" rods.

Have an 17K17 array, with the 9th row removed in 2 directions: plus 8 rods remained at intersection: total of 248 rods.

0917 Water ht = 42.00 cm Probe (in) Temp °C
 System sub critical 37.77" #1 = 23.5 °C
 Chain. #2 = 23.5 °C

added 2 rods: total number of rods = 250
 Water ht = 42.00 cm Probe (in) Temp °C
 -Per 37.77 #1 = 23.7 °C
 #2 = 23.7 °C
 E = -149.94 sec = -12.2 f

0947 Drain.

added 1 rod. total number
 Water ht = 42.00 cm Probe
 2+Per 3
 E = 315.08 sec = 3.7 f

1020 Water ht = 35.20 cm Probe
 System just critical 3
 Chain.

Depleted Uranium
 3.1525' x 10.1515' x 22.815"
 6.27 cm

uvt.

2.05⁰ cm separation c.e.
 30 cm length.
 .30" rods.

Have an 17x17 array, with the 9th row removed in 2 directions: plus 8 rods removed at intersection: Total of 248 rods.

0917 Water ht = 42.00 cm Probe (in) Temp °C
 System sub critical 37.77" #1 = 23.5°
 Drain. 2 = 23.5°

added 2 rods: Total number of ^P - 250
 Water ht = 42.00 cm ^P .30" rods, 30 cm length
 - Per ^P 2.050 cm. separation c.e.
 3 17x17 array with 9th row removed in 2 directions and 5 rods removed at intersection

0947 Drain. $G = -149.94 \text{ sec} = -12.2 \text{ f}$

added 1 rod. Total number ^P total rods 251
 Water ht = 42.00 cm ^P Probe (in) Temp °C
 + Per 37.77" #1 = 24.0°
 $G = 315.08 \text{ sec} = 3.7 \text{ f}$ 2 = 24.0°

1020 Water ht = 35.20 cm Probe (in)
 System just critical 35.10"
 Drain.

over.

Now have an 22x22 array: with the 11th & 12th rows of rods removed in 2 directions. Plus 16 rods removed at intersections. Total of 384 rods.

Water ht = 33.60 cm Probe (in) Temp °C
 3-Per 34.50" #1 = 23.7 °C
 C = 143.42 mm = 7.4 f 2 = 23.7 °C

1325 Water ht = 32.75 cm. Probe (in) 34.10"
 system just critical
 Drain

Removed 4 rods. Total number of rods = 380.

Water ht = 42.00 cm Probe (in) Temp °C
 4-Per 37.78" #1 = 24.0 °C
 N.C. 2 = 24.0 °C

1345 Drain:

Added 1 rod: Total number of rods = 381.

Water ht = 42.10 cm Probe (in) Temp °C
 5-Per 37.80" #1 = 24.0 °C
 C = -239.03 mm = -6.5 f 2 = 24.0 °C


1400 Drain

Added 1 rod. Total number of rods = 382

A = 6.60 cm

Water ht = 42.10 cm Probe (in) Temp °C
 6-Per 37.80" #1 = 24.0 °C
 C = 706.22 mm = 1.8 f 2 = 24.0 °C

Water ht = 35.50 cm Probe (in) 35.20"
 System just critical
 Drain



712 st
less
384
0
23.7 °C
23.7 °C

added 1 rod. Total number of rods = 382

A 4 = 6.60 cm

Water ht = 42.10 cm

6 + Res

C = 706.22 res = 1.8 f

Water ht = 35.50 cm

System just critical

Drain

35" rods 30 cm long
2.050 cm. separation E-C
~~12~~ 22x22 array
with 11th + 12th row
removed in 2 directions
and 18 rods removed
at intersection
total rods 382
Res = 100

30.

mp °C
= 29.0 °C
= 29.0 °C

mp °C
= 29.0 °C
= 29.0 °C

INSTRUMENT CHECK					
INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3 x 10 ⁻¹²	Meter ✓	4"	✓	10 x 10 ⁻¹²
		Fast ✓	1"	✓	"
K-2	3 x 10 ⁻¹²	Meter ✓	4"	✓	"
		Fast ✓	1"	✓	"
PM-1	7000	Alarm ✓	5"	✓	5000
PM-2	12000	Low ✓	10"	✓	9000
		Alarm ✓	1"	✓	"

LOG CALIBRATE OPERATE DUMP WELL PROBE LIGHT
 RADIATION ALARM: A B C SOURCE NUMBER B-9

START-UP CHECK LIST

Equipment checked by F.D.C. AKK Personnel check by F.D.C.
 Instruments and safeties checked and reset by AKK
 Source in checked by AKK Source No. M-93
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by AKK Time 0810
 Start-up OK'd by F.D.C. AKK Date 2-9-73

2.050 cm separation c.e.
 30 cm length.
 .30" rods.

Depleted Uranium
 8.625 X 12.1525 X 22.875"
 ↑ 6.27 cm ↓

Have an 23 x 23 array, with
 row removed in 2 direction

0840

Water ht = 42.10 cm Probe in
 System sub critical 37.84"
 Drain.

Depleted Uranium
 8.625 X 12.1525 X 22.875"
 ↑ 6.27 cm ↓

Have an 23 x 23 array, with 2
 16th & 20th row removed
 Total of 324 rods.

0930

Water ht = 42.10 cm Probe in
 System sub critical 37.84"
 Drain.

Have an 23 x 23 array, with the 3rd, 6th, 9th, 12th,
 15th, 18th, & 21st row removed in 2 direction
 Total of 256 rods.

Depleted Uranium
 8.625 X 12.1525 X 22.875"
 ↑ 6.27 cm ↓

1013

Water ht = 42.10 cm Probe in
 System sub critical 37.84"
 Drain.

over:


.30" rods, 30 cm long
 2.050 cm separation
 23x23 array with
 11, 12, 13 row
 removed in 2 directions
 Total rods 400
 Page 219 log

2.050 cm separation
 30 cm length.
 .30" rods.

Have an 23x23 array, with the 11th, 12th, & 13th row removed in 2 directions. Total of 400 rods.


0840 Water ht = 42.10 cm Probe (in) Temp °C
 System sub critical 37.84" $T_1 = 23.5^\circ C$
 Drain. $T_2 = 23.5^\circ C$

Have an 23x23 array, with 2
 16th & 20th row removed in
 Total of 324 rods.



0930 Water ht = 42.10 cm Probe (in)
 System sub critical 37.84"
 Drain.

Have an 23x23 array, with the 3rd, 6th, 9th, 12th,
 15th, 18th, & 21st row removed in 2 directions
 Total of 256 rods.



1013 Water ht = 42.10 cm Probe (in)
 System sub critical 37.84"
 Drain.

over.

130" rods, 30 cm long
 2.050 cm separation
 23x23 array with
 11, 12, 13 row
 removed in 2 directions
 Total rods 400
 Page 219 log

2.050 cm separation
 30 cm length
 130" rods.

Have an 23x23 array, with the 11th, 12th, & 13th row removed in 2 directions

0840

Water ht = 42.10 cm Probe (in)
 System sub critical 37.84"
 Drain.

130" rods, 30 cm length
 2.050 cm separation
 23x23 array with
 4, 8, 12, 16 & 20th row
 removed in 2 directions
 Total rods 324

Have an 23x23 array, with 2, 16th & 20th row removed in 2 directions.
 Total of 324 rods.

0930


Water ht = 42.10 cm Probe (in)
 System sub critical 37.84"
 Drain.

Temp °C
 #1 = 23.7 °C
 2 = 24.0 °C

Have an 23x23 array, with the 3rd, 6th, 9th, 12th, 15th, 18th, & 21st row removed in 2 directions
 Total of 256 rods.

1013

Water ht = 42.10 cm Probe (in)
 System sub critical 37.84"
 Drain.



over

2.050 cm separation
30 cm length.
130" rods.

130" rods, 30 cm long
2.050 cm. separation
23x23 array with
11, 12, 13 row
removed in 2 directions
Total rods 400

Page 219 log

Have an 23x23 array, with the 11th, 12th, & 13th row removed in 2 directions

0840

Water ht = 42.10 cm Probe (in)
System sub critical 37.84"
Drain.

130" rods, 30 cm length
2.050 cm. separation
23x23 array with
4, 8, 12, 16 & 20th row
removed in 2 directions
Total rods 324

Have an 23x23 array, with 2, 16th & 20th row removed in 2 directions.
Total of 324 rods.

0930

Water ht = 42.10 cm Probe (in)
System sub critical 37.84"
Drain.

Temp °C

130" rods 30 cm length
2.050 cm. separation
23x23 array with
3, 6, 9, 12, 15, 18 & 21th

Have an 23x23 array, with the 15th, 18th, & 21st row removed in 2 directions
Total of 256 rods.

row removed in 2 directions
Total rods 256
Page 219 log

1013

Water ht = 42.10 cm Probe (in)
System sub critical 37.84"
Drain.

Temp °C


#1 = 23.7 °C
#2 = 24.0 °C

over:

Now have an 20 x 20
 19 rods removed in
 4 rods removed at
 Total of 292 rods.

1300

Water ht = 42.20 cm
 System sub critical
 Drain.



23.7°C
 24.0°C

Added 2 rods: 1 each to opposite faces.
 Total number of rods = 294.

Water ht = 42.10 cm
 -Per
 E = -199.92 sec = -8.24

Probe (in) Temp
 37.84" 23.7°C
 24.0°C


1334

Drain

Added 1 rod: Total number

1353

Water ht = 42.10 cm
 System just critical
 Drain



23.7°C
 24.0°C

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	10x10 ⁻¹²
		Fast ✓	1"	✓	"
K-2	3x10 ⁻¹²	Meter ✓	4"	✓	"
		Fast ✓	1"	✓	"
PM-1	700 ✓	Alarm ✓	.5"	✓	5000
PM-2	1200 ✓	Low ✓	10"	✓	9000
		Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER B-80

START-UP CHECK LIST

Equipment checked by RKM Personnel check by F.D.C.
 Instruments and safeties checked and reset by RKM
 Source in checked by RKM Source No. M-43
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by RKM Time 0915
 Start-up OK'd by F.D.C. RKM Date 2-19-73

7/14th rows removed
in 2 directions, 4 rods
at each intersection
log #5
p-20
20x20 array, with
2.050 cm e-c
30cm length
1.30" rods

Now have an 20 x 20 array, with the 1st & 19th rows removed in 2 directions, plus 4 rods removed at each intersection.
Total of 292 rods.

1300 Water ht = 42.20 cm Probe (in) Temp °C
System sub critical 37.84" #1 = 23.7°C
Drain 2 = 24.0°C

Added 2 rods: 1 each to each direction
Total number of rods = 294

log #5
p-20
removed in 2 directions
7/14th rows
20x20 array, with
1.30" rods
30cm length
2.050 cm e-c

Water ht = 42.10 cm
-Per
E = -199.92 sec = -8.24

1334 Drain

Added 1 rod: Total number of rods = 295

1353 Water ht = 42.10 cm Probe (in) Temp °C
System just critical 37.84" #1 = 23.7°C
Drain 2 = 24.0°C

2.050 cm separation c.c.
30 cm lengths.
30" rods.

Have an 20x18 array, with the 7th and 14th rows removed in 2 directions. Total number of rods = 284 rods.

$\Delta h = 1.5 \text{ cm}$
Water ht = 32.50 cm Probe (in) Temp °C
+ Per 34.04" #1 = 22.8°C
 $\epsilon = 34.77 \text{ m} = 20.7 \text{ f}$ 2 = 23.0°C

0855 Water ht = 31.00 cm Probe (in)
System just critical ?
Drain

Removed 4 rods. Total number of rods = 280.

$\Delta h = 2.6 \text{ cm}$
Water ht = 35.00 cm Probe (in) Temp °C
+ Per 35.04" #1 = 22.8°C
 $\epsilon = 67.36 \text{ m} = 13.3 \text{ f}$ 2 = 23.0°C

0921 Water ht = 32.40 cm Probe (in)
System just critical 33.95"
Drain

Removed 2 rods. Total number of rods = 278.


Depleted Uranium
5.625" x 10.1515" x 22.875"

$\Delta h = 1.6 \text{ cm}$

Water ht = 42.20 cm
3 + Per

$\epsilon = 215.13 \text{ m} = 5.2 \text{ f}$

0957 Water ht = 34.60 cm
System just critical
Drain



Temp °C
= 23.2°C
= 23.0°C

Removed 1 rod. Total number of rods = 277.

Water ht = 42.20 cm Probe (in) Temp °C
4 - Per 37.82" #1 = 22.8°C
 $\epsilon = 415.09 \text{ m} = 3.4 \text{ f}$ 2 = 23.0°C

1012 Drain.

Now have an 22x21 array; with the 11th & 12th rows removed in 2 directions. Total of 370 rods.

$\Delta h = 1.2 \text{ cm}$

Water ht = 33.40 cm Probe (in) Temp °C
5 + Per 34.39" #1 = 23.0°C
 $\epsilon = 97.78 \text{ m} = 10.1 \text{ f}$ 2 = 23.0°C

1313 Water ht = 32.20 cm Probe (in)
System just critical 33.86"
Drain

over

• 30" rods 30 cm by
 2.050 cm. Separator
 20 X 18 array with
 7th + 14th row
 removed in 2 direction
 Total rods 278
 Page # 222 +
 ... low break

$\Delta h = 1.6 \text{ cm}$
 Water ht = 42.20 cm Probe (in) Temp °C
 3 + Per 37.84" #1 = 22.8°C
 #2 = 23.0°C
 $t = 215.13 \text{ sec} = 5.2 \text{ f}$

0957 Water ht = 34.60 cm Probe (in)
 System just critical 34.84"
 Drain.

Removed 1 rod: Total number of rods = 277.

Water ht = 42.20 cm Probe (in) Temp °C
 4 - Per 37.82" #1 = 22.8°C
 #2 = 23.0°C
 $t = 415.09 \text{ sec} = 3.4 \text{ f}$
 1012 Drain.

Now have an 22 X 21 array; removed the 11th & 12th
 row removed in 2 directions: Total of 370 rods.

$\Delta h = 1.2 \text{ cm}$
 Water ht = 33.40 cm Probe (in) Temp °C
 5 + Per 34.39" #1 = 23.0°C
 #2 = 23.0°C
 $t = 97.78 \text{ sec} = 10.1 \text{ f}$

1313 Water ht = 32.20 cm Probe (in)
 System just critical 33.86"
 Drain.

over

Removed 2 rods. Total number of rods = 368.


$\Delta h = 9.75 \text{ cm}$

Water ht = 42.20 cm Probe (in) Temp °C
 + Per 37.84" #1 = 23.0°C

$C = 108.65 \text{ sec} = 9.3 \text{ f}$ 2 = 23.0°C

1330 Water ht = 33.75 cm Probe (in)
 System just critical 39.50"
 Drain

Depleted Uranium
 8.125 x 10.1515 x 22.315"



Removed 1 rod. Total number

$\Delta h = 6.7 \text{ cm}$

Water ht = 42.20 cm Probe (in) Temp °C
 + Per 3

$C = 338.99 \text{ sec} = 3.5 \text{ f}$

1353 Water ht = 35.50 cm Probe (in)
 System just critical 35.19"
 Drain

Removed 1 rod. Total number of rods = 366.

Water ht = 42.20 cm Probe (in) Temp °C
 + Per 37.84" #1 = 23.0°C

$C = 677.98 \text{ sec} = 2.0 \text{ f}$ 2 = 23.0°C

1907 Drain:

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3×10^{-12}	Motor <input checked="" type="checkbox"/>	9"	<input checked="" type="checkbox"/>	10×10^{-12}
		Fast <input checked="" type="checkbox"/>	1"	<input checked="" type="checkbox"/>	"
K-2	3×10^{-12}	Motor <input checked="" type="checkbox"/>	9"	<input checked="" type="checkbox"/>	"
		Fast <input checked="" type="checkbox"/>	1"	<input checked="" type="checkbox"/>	"
PM-1	700 ✓	Alarm <input checked="" type="checkbox"/>	15"	<input checked="" type="checkbox"/>	500 ✓
PM-2	1200 ✓	Low <input checked="" type="checkbox"/>	10"	<input checked="" type="checkbox"/>	900 ✓
		Alarm <input checked="" type="checkbox"/>	1"	<input checked="" type="checkbox"/>	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER B-80

START-UP CHECK LIST

Equipment checked by F.D.C. Personnel check by F.D.C.
 Instruments and safeties checked and reset by ATM
 Source in checked by ATM Source No. M-23
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by ATM Time 0835
 Start-up OK'd by F.D.C. ATM Date 2-15-73

Removed 2 rods. Total number of rods = 368.

$\Delta h = 9.75 \text{ cm}$

Water ht = 42.20 cm Probe 30' Rods 30 cm. length
 6 + Per 37 2.050 cm. separation. c.c.

$C = 108.65 \text{ sec} = 9.3 \text{ f}$

1330

Water ht = 33.75 cm Probe removed in 2 directions
 System just critical Total rods = 367
 Drain. Pass 224 log

22 x 24 array with 3.0°C
 11th + 12th rows 3.0°C

Removed 1 rod. Total number of rods = 367

$\Delta h = 6.7 \text{ cm}$

Water ht = 42.20 cm Probe (in) Temp °C
 7 + Per 37.84" #1 = 23.0°C

$C = 338.99 \text{ sec} = 3.5 \text{ f}$

2 = 23.0°C

1353

Water ht = 35.50 cm Probe (in)
 System just critical 35.19"
 Drain.

Removed 1 rod. Total number of rods = 366.

Water ht = 42.20 cm Probe (in) Temp °C
 8 - Per 37.84" #1 = 23.0°C

$C = -677.98 \text{ sec} = -2.0 \text{ f}$

2 = 23.0°C

1407

Drain.

Report of critical $\beta - 224$. 367 rods.

Water ht = 42.20 cm Probe (in) Temp °C
 + Per 37.89 #1 = 23.2°C
 T = 275.97 sec = 4.2 f 2 = 23.8°C

0920 Water ht = 35.30 cm Probe (in)
 System just critical 35.08"
 Drain.

Have an 17x17 array, with the 9th row removed in 2 directions. Have 10 rods removed from 1 face. Total of 246 rods.

dx = 9.1 cm
 Water ht = 42.20 cm Probe (in) Temp °C
 + Per 37.89 #1 = 23.8°C
 T = 65.19 sec = 13.6 f 2 = 23.2°C

1035 Water ht = 32.80 cm Probe (in)
 System just critical 34.10"
 Drain.


Removed 2 rods. Total number of rods = 244.

Water ht = 42.20 cm Probe (in) Temp °C
 3 - Per 37.89 #1 = 23.2°C
 T = -256.41 sec = -6.0 f 2 = 23.2°C
 1055 Drain

added 1 rod. Total number

dx = 7.1 f
 Water ht = 42.20 cm Probe (in)
 + Per 3
 T = 267.28 sec = 4.3 f

1113 Water ht = 35.10 cm Probe (in)
 System just critical
 Drain.



3.2°C
 3.2°C

• 30" rods 30cm long
• 2.050 cm spacing c-c

Water ht = 42.20 cm
3 Res

Probe 17x17 array with the
9th row removed in 2°C
2 directions. Done 11
rods removed from
1 face.
total rods 245

1055

$E = -256.41 \text{ m} = -6.0 \text{ f}$
Drain

added 1 rod. Total number of rods = 245

$DL = 7.1 \text{ f}$

Water ht = 42.20 cm Probe (in) Temp °C
+ Res 37.84" #1 = 23.2 °C
 $E = 267.28 \text{ m} = 4.3 \text{ f}$ 2 = 23.2 °C

1113

Water ht = 35.10 cm Probe (in)
Leakage joint asiticial 35.01"
Drain

INSTRUMENT CHECK					
INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	10x10 ⁻¹²
		Fast ✓	1"	✓	"
K-2	"	Meter ✓	4"	✓	"
		Fast ✓	1"	✓	"
PM-1	700v	Alarm ✓	5"	✓	500v
PM-2	1200v	Low ✓	10"	✓	900v
		Alarm ✓	1"	✓	"

LOG IN CALIBRATE OPERATE DUMP WELL PROBE LIGHT
 RADIATION ALARM: A B C SOURCE NUMBER B-80

START-UP CHECK LIST



Equipment checked by F.D.C. AKK Personnel check by F.D.C.
 Instruments and safeties checked and reset by AKK
 Source in checked by AKK Source No. M-43
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1-2 PM1-2
 Red light on by AKK Time 12:15
 Start-up OK'd by F.D.C. AKK Date 2-16-73

2.050 cm separation c-c.
 30 cm length.
 .30" rods.

Have an 23x23 array, with
 now removed in 2 levels
 Have centered in array. 1,
 Stainless steel plate .25


1250

Water ht = 42.20 cm
 System sub critical
 Drain.



1327


Water ht = 42.20 cm
 System sub critical
 Drain.



1400

Have an 23x23 array, with etc
 15th, 18th, & 21st now rema
 Total of 256 rods. S.S. plate.

Water ht = 42.20 cm
 System sub critical
 Drain.




30" rods 30 cm length
 2.050 cm separation c-c
 23 x 23 array with 11, 12,
 13th row removed in
 2 directions. 1 row centered
 in array. 1 pc of 304L
 S.S. plate .250" x 10.1875"

2.050 cm separation
 30 cm length
 .30" rods
 18.549"
 Total rods = 400
 Page 229 log

Have an 23 x 23 array, with the 11th, 12th, 13th
 row removed in 2 directions. Total of 400 rods.
 1 row centered in array. 1 pc of type 304L
 stainless steel plate .250" x 10.1875" x 18.549"

1250 Water ht = 42.20 cm Probe (in) Temp °C
 System sub critical 37.84" $\beta = 23.2^\circ$
 Drain.



Have an 23 x 23 array, with 16th & 20th row removed
 Total of 324 rods. S.S. plate
 130" rods, 30 cm long
 2.050 cm separation c-c
 23 x 23 array with 3, 6,
 9, 12, 15, 18, 21st rows
 removed in 2 direction
 Total rods 256
 Page 229 log.

1327 Water ht = 42.20 cm Probe Temp °C
 System sub critical 37.84" $\beta = 23.5^\circ$
 Drain.

Have an 23 x 23 array, with the 3rd, 6th, 9th, 12th,
 15th, 18th, & 21st row removed in 2 directions.
 Total of 256 rods. S.S. plate centered in array.

1400 Water ht = 42.20 cm Probe (in) Temp °C
 System sub critical 37.84" $\beta = 23.5^\circ$
 Drain $\beta = 23.5^\circ$

2.050 cm separation c-c.
 30 cm length.
 .30" rods.

Depleted Uranium
 5.425" X 10.187" X 18.549"
 6.275 cm

Have an 23 X 23 array, with
 row removed in 2 levels
 Have centered in array:
 Stainless steel plate .25

130" rods 30 cm long
 2.050 cm. separation c-c.
 23 X 23 array with 4, 8, 12,
 16, 20th rows removed
 in 2 directions
 5.5 plate centered in
 array
 Total rods 324

1250

Water ht = 42.20 cm
 System sub critical
 Drain.

Page 229

Have an 23 X 23 array, with the 4th, 8th, 12th,
 16th & 20th row removed in 2 directions
 Total of 324 rods. S.S. plates centered in array.


1327

Water ht = 42.20 cm (in)
 System sub critical
 Drain.

Temp
 #1 = 23.2°
 2 = 23.5°

Depleted Uranium
 5.425" X 10.187" X 18.549"
 6.275 cm

Have an 23 X 23 array, with the
 15th, 18th, & 21st row rema
 Total of 256 rods. S.S. plate



1900

Water ht = 42.20 cm
 System sub critical
 Drain

.250" X 10.187" X 18.549
 S.S. Plate

INSTRUMENT	RANGE	INSTRUMENT CHECK			
		TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	7"	-	10x10 ⁻¹²
		Fast ✓	1"	-	"
K-2	3x10 ⁻¹²	Meter ✓	7"	-	"
		Fast ✓	1"	-	"
PM-1	700V	Alarm -	1.5"	-	500V
PM-2	1200V	Low ✓	10"	-	900V
		Alarm ✓	1"	-	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT
 RADIATION ALARM: A B C SOURCE NUMBER 1-80

START-UP CHECK LIST

Equipment checked by F.D.C. Personnel check by F.D.C.
 Instruments and safeties checked and reset by ARKL
 Source in checked by ARKL Source No. M-93
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by ARKM Time 10:00
 Start-up OK'd by F.D.C. ARKL Date 2-20-70

2.050 cm operations e-e.
 30 cm length.
 130" rod.

Have an 23x23 array, with the 11th, 12th, 13th now removed in 1 direction. Have S.S. plates centered in the other direction.
 Total of 440 rods:

Water ht = 32.10 cm Probe (in) Temp °C
 + Per 33.91" #1 = 22.5 °C
 #2 = 22.5 °C
 T = 71.11 sec = 12.7 f

1055

Water ht = 31.75 cm Probe (in)
 System just critical 33.51
 Drain.

Removed 8 rods from 1 face. Total of 432 rods.

Water ht = 42.30 cm Probe (in) Temp °C
 + Per 37.83" #1 = 22.5 °C
 #2 = 22.5 °C
 T = 121.69 sec = 8.5 f

1110

Water ht = 33.95 cm Probe (in)
 System just critical 34.50"
 Drain.

avr.

Removed 2 rods. Total of 430 rods:

Water ht = 42.10 cm	Probe (in)	Temp °C
³ - Per	37.85"	#1 = 22.5 °C
$\tau = -1564.56 \text{ sec} = -85 \text{ f}$		#2 = 22.5 °C

1312 Drain


Added 1 rod. Total number of rods = 431

$D_h = 6.4 \text{ cm}$

Water ht = 42.20 cm	Probe (in)	Temp °C
⁴ + Per	37.85"	#1 = 22.5 °C
$\tau = 306.39 \text{ sec} = 3.8 \text{ f}$		#2 = 22.5 °C

1337 Water ht = 35.80 cm
System just critical
Drain.

Depleted Uranium
5.125" X 12.1515" X 22.315"
6.276 cm



.250" X 10.187" X 18.549"
S.S. Plate

Have an 19X21 array. With the S.S. plate centered in array. Total of 380 rods.

1445 Water ht = 20.50 cm	Temp °C
System just critical	#1 = 22.9 °C
Drain.	#2 = 22.9 °C

Removed 38 rods. Now have an 19X19 array, with S.S. plate centered in array. Total of 342 rods.

1505 Water ht = 23.10 cm	Temp °C
System just critical	#1 = 22.9 °C
Drain.	#2 = 22.9 °C

Now have an 17X18 array, with S.S. plate centered in array. Total of 288 rods.

1525 Water ht = 27.50 cm	Temp °C
System just critical	#1 = 22.9 °C
Drain.	#2 = 22.9 °C

arr.

Removed 2 rods. Total of 430 rods:

3 Water ht = 42.10 cm Probe (in) Temp °C
 - Per 37.85" #1 = 22.5 °C
 $T = -1564.56 \text{ sec} = -85 \text{ f}$ 2 = 22.5 °C
 1312 Drain

Added 1 rod: Total = 431

24
 Water ht = 42.20 cm Log 232 Log 232 Temp °C
 4 + Per from 1 force 431 #1 = 22.5 °C
 $T = 306.39 \text{ sec} = 3.8 \text{ f}$ other chas. removed
 1337 Water ht = 35.80 cm 55 plate control in 1 direction. 11.12.13 sec removed
 System just criticized
 Drains. 23 X 23 empty with 11.12.13

Removed 12 rods: Total of 276 rods.

Water ht = 29.10 cm
System just critical
Drain.

INSTRUMENT	RANGE	INSTRUMENT CHECK				STARTUP RANGE
		TRIP	SOURCE DISTANCE	RESET		
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	10x10 ⁻¹²	
		Fast ✓	1"	-	"	
K-2	3x10 ⁻¹²	Meter ✓	4"	✓	"	
		Fast ✓	1"	-	"	
PM-1	700V	Alarm -	5"	✓	500V	
PM-2	1260V	Low ✓	10"	✓	900V	
		Alarm ✓	1"	-	"	

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER 3-80

START-UP CHECK LIST

Equipment checked by F.P.C. Personnel check by A.M.L.
 Instruments and safeties checked and reset by A.M.L.
 Source in checked by A.M.L. Source No. M-93
 Emergency equipment in control room checked by F.P.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by A.M.L. Time 0830
 Start-up OK'd by F.P.C. A.M.L. Date 2-21-73


Removed 12 rods: Total of ²⁶⁴ rods:
 D1 = 8.55" diam

Water ht = 42.20 cm Probe (in) Temp °C
 + Per 37.84" #1 = 23.0°C
 C = 117.34 sec = 8.74" 2 = 23.0°C

0915 Water ht = 33.65 cm Probe (in)
 System just critical 34.40"
 Drain.

Removed 1 rod: Total of 263

0930 Water ht = 42.20 cm, P.m.
 System just critical 3;
 Drain.



START-UP CHECK LIST

Equipment checked by J.P.C. Personnel check by A.M.L.
 Instruments and safeties checked and reset by A.M.L.
 Source in checked by R.M.A. Source No. M-93
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1-2 P.M.1-2
 Red light on by A.M.L. Time 0830
 Start-up OK'd by F.D.C., R.M.A. Date 2-21-73

Removal 12 rods: total of $\frac{7}{2}$ 30" rods 30 cm length
 2.050^{cm} separation c-c
 17 X 17 array with
 9 rods removed from
 01 = 8.55 cm

Water ht = 42.20 cm Prod 1 face, + BS, plate
 + Rev 3 centered in array.
 C = 117.34 sec = 8.74 total rods 263

0915 Water ht = 33.65 cm Prod page 235 log
 System just critical 3
 Drain.

Removal 1 rod: total of 263 rods:

0930 Water ht = 42.20 cm. Prod (in) Temp °C
 System just critical 37.89" #1 = 23.0°C
 Drain. 2 = 23.0°C

2.050cm separation a-a.
30cm length.
.30" rod.

Now have an 17x19 array: with the 10th row removed in 1 direction and the 9th row removed in 1 direction. With s.s. plate centered in 9th row: (see diagram) Total of 288 rods.

1245 Water ht = 42.20 cm Probe (in) 37.84
system sub critical
Drain.

Added 20 rods: total number of rods = 298.

Water ht = 42.20 cm Probe (in) 37.84" Temp °C
2-Per #1 = 23.2 °C
#2 = 23.2 °C
L = 104.30 cm = 9.6 f

1405 Water ht = 33.55 cm Probe (in) 34.41"
system just critical
Drain.

Removed 1 rod: Total

0.4 = 6.8 cm

Water ht = 42.20 cm


3-Per

L = 430.25 cm = 2.8 f

1428 Water ht = 35.40 cm

system just critical

Drain.



Delete 1 row of rods from drawing.

Temp °C

#1 = 23.2 °C

#2 = 23.2 °C

Removed 1 rod: total number of rods = 296.

Water ht = 42.20 cm

Probe (in)

Temp °C

4-Per

37.84"

#1 =

L = 459.16 cm = 3.1 f

#2 =

1445 Drain.

30" rods 30cm length
 2.050 cm. sep. c-c.
 21 x 17 array
 with 10th row removed
 in 1 direction + 9th
 row removed in other
 direction with 55 plate
 centered in 9th row
 Total rods = 297

231

Removed 1 rod: Total number of rods = 297

$d_r = 6.8 \text{ cm}$

Water ht = 42.20 cm Probe (in) 37.84"

Delete 1 row
 of rods from
 drawing. G.W.
 Temp °C
 #1 = 23.2 °C
 2 = 23.2 °C

$\epsilon = 430.25 \text{ cm} = 2.8 \text{ f}$

1428

Water ht = 35.40 cm Probe (in) 35.17"
 System just critical
 Drain

Removed 1 rod: Total number of rods = 296.

Water ht = 42.20 cm Probe (in) 37.84" Temp °C #1 =

$\epsilon = 459.16 \text{ cm} = 3.1 \text{ f}$

1445

Drain.

el
 el
 plate
 tol

= 298.

Temp °C
 23.2 °C
 23.2 °C

INSTRUMENT CHECK					
INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	9"	✓	10x10 ⁻¹²
		Fast ✓	1"	✓	"
K-2	3x10 ⁻¹²	Meter ✓	9"	✓	"
		Fast ✓	1"	✓	"
PM-1	700v	Alarm ✓	5"	✓	500v
PM-2	1200v	Low ✓	10"	✓	900v
		Alarm ✓	2"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT
 RADIATION ALARM: A B C SOURCE NUMBER B-80

START-UP CHECK LIST

Equipment checked by ^{F.P.C.} AKA Personnel check by AKA
 Instruments and safeties checked and reset by AKA
 Source in checked by AKA Source No. M-93
 Emergency equipment in control room checked by F.P.C.
 Instruments in trip circuit: K-1-2 PM1-2
 Red light on by AKA Time 0905
 Start-up OK'd by F.P.C. AKA Date 2-22-73

21030 Terminated run.

INSTRUMENT CHECK					
INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	9"	✓	10x10 ⁻¹²
		Fast ✓	1"	✓	"
K-2	3x10 ⁻¹²	Meter ✓	9"	✓	"
		Fast ✓	1"	✓	"
PM-1	700v	Alarm ✓	5"	✓	500v
PM-2	1200v	Low ✓	10"	✓	900v
		Alarm ✓	2"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT
 RADIATION ALARM: A B C SOURCE NUMBER B-80

START-UP CHECK LIST

Equipment checked by ^{F.P.C.} AKA Personnel check by AKA
 Instruments and safeties checked and reset by AKA
 Source in checked by AKA Source No. M-93
 Emergency equipment in control room checked by F.P.C.
 Instruments in trip circuit: K-1-2 PM1-2
 Red light on by AKA Time 0810
 Start-up OK'd by F.P.C. AKA Date 2-23-73

Now have an 16 X 19 array. with the S.S. plate centered in array. (see diagram). Total of 276 rods.

Water ht = 28.70 cm
 System just critical
 Drain
 Temp °C
 #1 = 23.2 °C
 2 = 23.2 °C

Removed 20 rods: Now have an 16 X 19 array!
 Total of 256 rods.

0930 Water ht = 42.20 cm Probe (in) Temp °C
 System sub critical 37.84" #1 = 23.2 °C
 Drain. 2 = 23.2 °C

added 6 rods: Total number of rods = 262

1033 Water ht = 42.20 cm Probe (in) Temp °C
 System sub critical 37.84" #1 = 23.2 °C
 Drain. 2 = 23.2 °C

added 2 rods: Total number of rods = 264

Water ht = 42.20 cm Probe (in) Temp °C
 1-Per 37.84" #1 = 23.2 °C
 2 = 23.2 °C
 10-51 Drain
 C = -282.49 uV = -5.3 f

INSTRUMENT CHECK					
INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	10x10 ⁻¹²
		Fast ✓	1"	✓	"
K-2	3x10 ⁻¹²	Meter ✓	4"	✓	"
		Fast ✓	1"	✓	"
PM-1	700V	Alarm ✓	.5"	✓	500V
PM-2	1200V	Low ✓	10"	✓	900V
		Alarm ✓	2"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT
 RADIATION ALARM: A B C SOURCE NUMBER D-70

START-UP CHECK LIST.

Equipment checked by F.P.C. Personnel check by F.P.C.

Instruments and safeties checked and reset by AKM

Source in checked by AKM Source No. M-43

Emergency equipment in control room checked by F.P.C.

Instruments in trip circuit: K-1-2 PM-2

Red light on by AKM Time 0815

Start-up OK'd by F.P.C. AKM Date 2-26-73

2.050 cm separation c-c.
30 cm length. .30" rods.

added 1 rod. Total number of rods = 265;


64 = 8.7 cm

Water ht = 42.20 cm Probe (in) Temp °C
+ Per 37.84" #1 = 24.0°C
#2 = 24.0°C

E = 97.78 m = 10.14

0855 Water ht = 33.50 cm Probe (in)
System just critical 34.41"
Drain.

Depleted Uranium
8.125" X 10.1815" X 23.875"



1.250" X 10.181" X 18.549"
S.S. Plate

New have on 14 X 14 array; Total of 196 rods.
Have S.S. plate on face of depleted uranium reflector.
See diagram.

Water ht = 42.20 cm Probe (in) Temp °C
+ Per 37.84" #1 = 24.0°C
#2 = 24.0°C

E = -308.57 m = -4.8 f

1458 Drain:


added 1 rod. Total of 197 rods:

1514 Water ht = 42.20 cm Probe (in) Temp °C
System just critical 37.84" #1 = 24.0°C
#2 = 24.0°C
Drain.

Depleted Uranium
8.125" X 10.1815" X 23.875"

304
S.S. Plate
1.250" X 10.181" X 18.549"

↑ .627 cm ↓



START-UP CHECK LIST

Equipment checked by F.P.C. Personnel check by F.P.C.
 Instruments and safeties checked and reset by AMM
 Source in checked by AMM Source No. M-93
 Emergency equipment in control room checked by F.P.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by AMM Time 0815
 Start-up OK'd by F.P.C. AMM Date 2-26-73

2.050 cm separation c-c
 30 cm length .30" rods.

added 1 rod: Total number of rods = 265;

sh = 8.7 cm

Water ht = 42.20 cm 30" rods 30 cm long Temp °C
 + Per 2.050 cm separation c-c 24.0°C
 E = 97.78 μ = 10.14 18 x 16 array with 4 24.0°C

0855 Water ht = 33.50 cm rods removed in 1 row
 System just critical Have ss plate in 9th row
 Drain. Total rods 265
 Page 242 log.

Now have on 14 x 16 array: Total of 196 rods:
 Have S.S. plate on face of depleted uranium reflector.
 See diagram.

Water ht = 42.20 cm 30" rods 30 cm long Temp °C
 2-Per 2.050 separation c-c #1 = 24.0°C
 E = -308.51 μ = -4.8 μ 14 x 14 array + 1 rod 2 = 24.0°C
 in 1 row.

1458

Drain:

added 1 rod: Total of depleted uranium reflector.

total rods 197

1514

Water ht = 42.20 cm Temp °C
 System just critical Page 243 log. #1 = 24.0°C
 Drain. 2 = 24.0°C

INSTRUMENT CHECK					
INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	10x10 ⁻¹²
		Fast ✓	1"	✓	"
K-2	3x10 ⁻¹²	Meter ✓	4"	✓	"
		Fast ✓	1"	✓	"
PM-1	700 ✓	Alarm ✓	1.5"	✓	500 ✓
PM-2	1200 ✓	Low ✓	10"	✓	900 ✓
		Alarm ✓	2"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER B-80

START-UP CHECK LIST

Equipment checked by F.I.O.C. Personnel check by F.I.O.C.
 Instruments and safeties checked and reset by BKAN
 Source in checked by BKAN Source No. M-43
 Emergency equipment in control room checked by F.I.O.C.
 Instruments in trip circuit: K-1-2 PM1-2
 Red light on by BKAN Time 0820
 Start-up OK'd by F.I.O.C., BKAN Date 2-27-73

2.050 cm separation c.c.
 30 cm length.
 30" rods.

Repeat of last run:

0855^h Water ht = 42.20 cm Probe (in) Temp °C
 System just critical 37.84" #1 = 29.0°C
 Drain. 2 = 29.0°C

Have an 18x20 array. With 6 rods removed from 1 face. Total of 282 rods; 7 at +14th row removed in 2 directions.

Water ht = 34.70 cm Probe (in) Temp °C
 + Press 34.89" #1 = 29.6°C
 C = 80.40 cm = 11.7 f 2 = 29.2°C

1300 Water ht = 32.40 cm Probe (in)
 System just critical ~~33.97~~"
 Drain.

over:

Remained 2 rods: total number of rods = 280.

Water ht = 42.20 cm Probe (in) Temp °C
+ Per 37.84" #1 = 29.2°C
C = 156.46 sec = 6.9 f 2 = 29.2°C


1320 Water ht = 34.05 cm Probe (in)
system just critical 39.62"
Drain.

Remained 1 rod: total number of rods = 279.

1335 Water ht = 42.20 cm Probe (in) Temp °C
system just critical 37.84" #1 = 29.2°C
Drain 2 = 29.2°C

Depleted Uranium
8.125" x 10.1815" x 23.875"

304
S.S. Plate
1.250" x 10.181" x 18.549"



Now have an 21x22 array: with the th 11x12th row removed in 2 directions. Total of ³⁵⁰ 368 rods.

1437 Water ht = 42.20 cm Probe (in) Temp °C
system sub critical 37.84" #1 = 29.2°C
Drain 2 = 29.2°C

Added 2 rods: total number of rods = ~~370~~ 352.

1448 Water ht = 42.20 cm Probe (in) Temp °C
system sub critical 37.84" #1 = 29.2°C
Drain 2 = 29.2°C

Added 16 rods: total of 368 rods. (checked) 11/14

Water ht = 42.20 cm Probe (in) Temp °C
- Per 37.84" #1 = 29.2°C
C = -564.98 sec = -2.5 f 2 = 29.2°C

1517 Drain

over:

Remained 2 rods: Total number of rods = 280.

Water ht = 42.20 cm Probe (in)
 + Per 37.84"

Temp °C
 #1 = 29.2 °C
 2 = 29.2 °C

C = 156.46 mm = 6.9 f

1320 Water ht = 34.05 cm P.m.h. ()
 System just c. 30" rods 30 cm long
 Drain 2.050 cm. separation c.

18 x 20 array
 7th + 14th row
 removed in reduction

Remained 1 rod: and 9 rods removed
 from 1 face. $\phi = 279$.


1335 Water ht = 42.20 total rods 279
 System just c. Page 246 log.
 Drain

Temp °C
 #1 = 29.2 °C
 2 = 29.2 °C

added 1 rod. Total nu
 Ah = 6.1 cm
 Water ht = 42.20 cm
 + Per
 E = 499.79 nu = 2.1 f
 Water ht = 36.10 cm
 System just critical
 Drain.

Depleted Uranium
 8.125" x 10.1815" x 23.825"

304
 S.S. Plate,
 1.250" x 10.181" x 18.549"



9.
 temp °C
 = 29.2°C
 = 29.2°C

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	10x10 ⁻¹²
		Fast ✓	1"	✓	"
K-2	3x10 ⁻¹²	Meter ✓	4"	✓	"
		Fast ✓	1"	✓	"
PM-1	700 ✓	Alarm ✓	5"	✓	500 ✓
PM-2	1200 ✓	Low ✓	10"	✓	900 ✓
		Alarm ✓	2"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER B-80

2.050 cm separation e-e.
 30 cm length,
 130" rod.

START-UP CHECK LIST

Equipment checked by AKM Personnel check by F.D.C.
 Instruments and safeties checked and reset by AKM
 Source in checked by AKM Source No. M-43
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by AKM Time 0830
 Start-up OK'd by F.D.C., AKM Date 7-28-73

Repeat of last run:

Water ht = 42.20 cm Probe (in) Temp °C
 + Per 37.84" #1 = 23.7°C
 E = 521.52 nu = 2.3 f 2 = 24.0°C
 0913 Water ht = 36.00 cm Probe (in)
 System just critical 35.40"
 Drain.

ret.

30 rods 30 cm long
 2.050 cm separation c-c
 21 x 22 Gray
 with the 11th & 12th
 rods removed in
 2 directions.
 Total rods - 369
 Page 249 log.

Added 1 rod. Total number of rods = 369.

$\Delta h = 6.1 \text{ cm}$

Water h_l = 42.20 cm Probe (in) Temp °C
 + Per 37.84" #1 = 29.2°C
 $E = 499.79 \text{ sec} = 2.4 \text{ f}$ 2 = 29.2°C
 Water h_l = 36.10 cm Probe (in)
 System just critical 35.40
 Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	10x10 ⁻¹²
		Fast ✓	1"	✓	"
K-2	3x10 ⁻¹²	Meter ✓	4"	✓	"
		Fast ✓	1"	✓	"
PM-1	700 ✓	Alarm ✓	5"	✓	500 ✓
PM-2	1200 ✓	Low ✓	10"	✓	900 ✓
		Alarm ✓	2"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT


RADIATION ALARM: A B C SOURCE NUMBER B-80

Have an 17x17 array removed in 2 disks removed from 1 run. Total of 247 rods.

$\Delta h = 6.5 \text{ cm}$
 Water ht = 42.20 cm
 2 Per
 $t = 693.19 \text{ min} = 1.8 \text{ h}$
 1040 Water ht = 35.70 cm
 System just critical
 Drain

Depleted Uranium
 8.125" x 10.1875" x 23.875"

304
 S.S. Plate
 1.250" x 10.1875" x 18.549"



Temp °C
 $t_1 = 24.0^\circ \text{C}$
 $t_2 = 24.0^\circ \text{C}$

Removed 1 rod. Total number of rods = 246.

11:00 Water ht = 42.20 cm Probe (air) Temp °C
 3-Per 37.89" $t_1 = 24.0^\circ \text{C}$
 $t_2 = 24.0^\circ \text{C}$
 Drain

INSTRUMENT CHECK					
INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3×10^{-12}	Meter ✓	4"	✓	10×10^{-12}
		Fast ✓	1"	✓	"
K-2	3×10^{-12}	Meter ✓	4"	✓	"
		Fast ✓	1"	✓	"
PM-1	700V	Alarm ✓	5"	✓	500V
PM-2	1200V	Low ✓	10"	✓	900V
		Alarm ✓	2"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT
 RADIATION ALARM: A B C SOURCE NUMBER B-80

START-UP CHECK LIST

Equipment checked by AKA Personnel check by F.D.C.
 Instruments and safeties checked and reset by AKA
 Source in checked by AKA Source No. M-93
 Emergency equipment in control room checked by F.D.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by AKA Time 1235
 Start-up OK'd by F.D.C., AKA Date 3-1-73

250

130" rods 30cm long
2.050 cm. sep. - c-e
17x17 array with
the 9th row removed
in 2 directions
+ 9 rods removed
from 1 row.
Total rods 247
Page 250 log.

Have an 17x17 array, with the 9th row
removed in 2 directions, with 9 rods
removed from 1 row. (see diagram).
Total of 247 rods.

$\Delta h = 6.5 \text{ cm}$

Water ht = 42.20 cm Probe (in) Temp °C
2-Pen 37.89" #1 = 24.0°C
#2 = 24.0°C
 $E = 693.19 \text{ m} = 1.8 \text{ f}$

1040 Water ht = 35.70 cm Probe (in)
System just critical 35.31"
Drain

Removed 1 rod: Total number of rods = 246.

11:00 Water ht = 42.20 cm Probe (in) Temp °C
3-Pen 37.89" #1 = 24.0°C
#2 = 24.0°C
 $E = -299.89 \text{ m} = -6.2 \text{ f}$
Drain

2.250 cm separation c-c,
30 cm length,
.30" rod.

Have an 17x17 array, with the 9th row removed from 2 directions. Total of 256 rods. Now have 1 pu .250" x 10.187" x 18.549" 50% BqC bond plate on face of depleted Uranium reflector. See diagram.

1305 Water ht = 42.20 cm Probe (in) Temp °C
System sub critical 37.84" #1 = 23.7°C
Drain 2 = 24.0°C



Added 4 rods to 1 face. Total of 260 rods.

Water ht = 42.20 cm Probe (in) Temp °C
-les 37.84" #1 = 23.8°C
N.G. 2 = 24.0°C

1328

Drain.

Added 1 rod. Total of
Water ht = 42.20 cm
System just critical
Drain.



Temp °C
#1 = 23.8°C
2 = 24.0°C

Now have an 22x22 array, with the 11th & 12th rows removed in 2 directions. With 16 rods removed from 1 face. See diagram. Total of 384 rods.

Water ht = 42.20 cm Probe (in) Temp °C
System sub critical 37.84" #1 = 24.0°C
Drain 2 = 24.0°C

INSTRUMENT CHECK					
INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	10x10 ⁻¹²
		Fast ✓	1"	✓	"
K-2	3x10 ⁻¹²	Meter ✓	4"	✓	"
		Fast ✓	1"	✓	"
PM-1	700V	Alarm ✓	5"	✓	500V
PM-2	1200V	Low ✓	10"	✓	900V
		Alarm ✓	2"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER B-80

252

2.250 cm separation c.e.
30 cm length.
.30" rods.

Have an 17x17 array, with the 9th row removed from 2 directions. Total of 256 rods. Now have 1 ft .250" x 10.187" x 18.549" 50% B₄C bond plate on face of depleted Uranium reflector. See diagram.

1305	Water ht = 42.20 cm	17x17 array with 9th row removed in 2 directions. Now 1 ft .250" x 10.187" x 18.549" 50% B ₄ C bond plate	Temp °C
	System sub critical		= 23.7 °C
	Drain		= 24.0 °C
		Added 4 rods to 1 ft on face of depleted Uranium reflector	
	Water ht = 42.20 cm	Total rods 261	Temp °C
	Per		#1 = 23.8 °C
	N.G.		2 = 24.0 °C
1328	Drain:		

	Added 1 rod. Total of 261 rods.		
	Water ht = 42.20 cm	P-value (in)	Temp °C
	System just critical	37.84	#1 = 23.8 °C
	Drain		2 = 24.0 °C

START-UP CHECK LIST

Equipment checked by E.D.C. Personnel check by AKM
 Instruments and safeties checked and reset by AKM
 Source in checked by AKM Source No. M-43
 Emergency equipment in control room checked by E.D.C.
 Instruments in trip circuit: Z-1-2 PM-1-2
 Red light on by AKM Time 0810
 Start-up CK'd by E.D.C. AKM Date 3-2-73

2.05 cm repoll
 30 cm repoll
 130" repoll


added 4 rods: Total of 388 rods.

Water ht = 42.20 cm Probe (in) Temp °C
 1-Per 37.84" #1 = 23.7°C
 N.G. 2 = 24.0°C
 0905 Drain

added 2 rods: Total
Δh = 5.5 cm

Water ht = 42.20 cm
 2+Per
 T = 1043.04 sec = 1.2 f
 0940 Water ht = 36.70 cm
 System just critical
 Drain.

Depleted Uranium
 8.125" x 10.1875" x 23.875"
 Boron Sheet
 1.250" x 10.181" x 18.549"



Removed 1 rod: Total of 389 rods:

Water ht = 42.20 cm Probe (in) Temp °C
 3-Per 37.84" #1 = 23.7°C
 T = 200.76 sec = 5.9 f 2 = 23.7°C
 10:00 Drain

Now have an 19x20 array. ~~Total~~ With
 the 7th & 14th now removed in 2
 directions. Total of 300 rods.
 See diagram.

Water ht = 42.20 cm Probe (in) Temp °C
 4+Per 37.84" #1 = 24.0°C
 T = 56.50 sec = 1.51 f 2 = 24.0°C

1344 Water ht = 32.75 cm Probe (in)
 System just critical 34.03"
 Drain.

over.

START-UP CHECK LIST

Equipment checked by Z.H.C. Personnel check by A.K.H.
 Instruments and safeties checked and reset by A.K.H.
 Source in checked by A.K.H. Source No. M-93
 Emergency equipment in control room checked by Z.H.C.
 Instruments in trip circuit: Z-1-2 PM-1-2
 Red light on by A.K.H. Time 17410

Start-up CK'd by E.D.C. 130" rods 30cm long 13
 2.05cm. 2.050cm. adjustment
 30cm. 22x22 array with
 130" rods. 11th + 12th rows removed in 2 direction with 10 rods removed

Water ht = 42.20 from 1 face
 - Per Total rods 390
 N.G. Page 254 log

Temp °C
 #1 = 23.7°C
 #2 = 24.0°C

0905 Drain

added 2 rods. Total of 390 rods.
 ΔL = 5.5cm

Water ht = 42.20 cm
 2 + Per
 T = 1043.04 sec = 1,27

Probe (in) Temp °C
 37.89" #1 = 23.2°C
 #2 = 23.2°C

0940 Water ht = 36.70 cm
 system just critical
 Drain.

Probe (in)
 35.73"

Removed 7 rods.

Water ht = 42.20
5-Pr


E = 262.93 u = 4.4 f

1906 Water ht = 39.10

System just cycled
Drain.

Depleted Uranium
9.125" X 10.1815" X 23.875"

Borated Sheet
1.250" X 10.181" X 18.549"



6:

Temp °C

#1 = 24.0 °C

2 = 24.0 °C

Removed 1 rod: Total of 297 rods.

Water ht = 42.20 cm

6-Pr

E = -608.44 u = -2.0 f

1929 Drain.

Probe (in)

37.89"

Temp °C

#1 = 23.7 °C

2 = 23.7 °C

INSTRUMENT	RANGE	INSTRUMENT CHECK				STARTUP RANGE
		TRIP	SOURCE DISTANCE	RESET		
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	10x10 ⁻¹²	
		Fast ✓	1"	✓	"	
K-2	3x10 ⁻¹²	Meter ✓	4"	✓	"	
		Fast ✓	1"	✓	"	
PM-1	7005	Alarm ✓	5"	✓	5005	
PM-2	12005	Low ✓	10"	✓	9005	
		Alarm ✓	2"	✓	"	

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT
RADIATION ALARM: A B C SOURCE NUMBER B-80

START-UP CHECK LIST

Equipment checked by AKK Personnel check by F.P.C.
Instruments and safeties checked and reset by AKK
Source in checked by AKK Source No. M-43
Emergency equipment w/ control room checked by F.P.C.
Instruments in test circuits: K-1-2 PM1-2
Red light on by AKK Time 0915
Start-up OK'd by F.P.C. AKK Date 3-6-73

Removed 7 rods: Total of 298 rods:
 Total rods 298
 from 1 force
 and 2 rods removed
 removed in 2 direction
 7 ft + 14 ft
 force 256 kg

Removed 7 rods: Total of 298 rods:

$L = 1.5 \text{ cm}$

Water ht = 42.20 cm Probe (in) Temp °C
 5-Res 37.89" #1 = 29.0°C
 $E = 262.93 \text{ m} = 4.9 \text{ f}$ 2 = 29.0°C

1406 Water ht = 39.70 cm Probe (in)
 System just critical 34.88"
 Drain.

Removed 1 rod: Total of 297 rods.

Water ht = 42.20 cm Probe (in) Temp °C
 6-Res 37.89" #1 = 23.7°C
 $E = -608.44 \text{ m} = -2.0 \text{ f}$ 2 = 23.7°C

1429 Drain.

2.050 cm up motion c-c,
30 cm length.
.30" rods.

Have an 14x15-7 array: Total of 203 rods.

0930 Water ht = 42.20 cm Probe (in) Temp °C
System sub critical 37.84" #1 = 24.0°C
Drain. 2 = 29.0°C

Added 7 rods: Now have an 14x15 array:
Total of 210 rods.

Water ht = 33.00 cm Probe (in) Temp °C
+ Per 33.93" #1 = 24.0°C
E = 86.92 sec = 11.0 f 2 = 24.0°C

0955 Water ht = 31.75 cm Probe (in)
System just critical 33.70"
Drain.

Removed 3 rods from face: Total of 207 rods.

Water ht = 42.40 cm Probe (in) Temp °C
2-Per 37.85" #1 = 24.0°C
E = -402.00 sec = -3.6 f 2 = 24.0°C


1012 Drain

added 1 rod: Total of 208 rods.

Water ht = 42.30 cm Probe (in) Temp °C
+ Per 37.85" #1 = 24.0°C
E = 152.11 sec = 7.0 f 2 = 24.0°C

1041 Water ht = 33.95 Probe (in)
System just critical 34.55"
Drain.

Depleted Uranium
8.125" x 10.1875" x 23.875"
Boral Sheet
1.250" x 10.1875" x 18.549"



Added 1 rods. Total of 30" rods 30cm long
2.050 cm. sep. c-c
14 X 15 array

$\Delta L = 8.25 \text{ cm}$

Water ht = 42.30 cm

f with 2 rods removed
in 15th row

³+ Per

$G = 152.11 \text{ cm} = 7.0 \text{ f}$

Total rods 208

1091

Water ht = 33.95

Page 259 log.

System just critical
Drain.

$\text{temp } ^\circ\text{C}$
 $= 24.0^\circ\text{C}$
 $= 24.0^\circ\text{C}$

INSTRUMENT CHECK					
INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3×10^{-12}	Meter ✓	4"	✓	10×10^{-12}
		Fast ✓	1"	✓	"
K-2	3×10^{-12}	Meter ✓	4"	✓	"
		Fast ✓	1"	✓	"
PM-1	700V	Alarm ✓	1.5"	✓	500V
PM-2	1200V	Low ✓	10"	✓	900V
		Alarm ✓	2"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER 2-93

START-UP CHECK LIST

Equipment checked by J.D.C. Personnel check by F.C.C.

Instruments and safeties checked and reset by AKM

Source in checked by AKM Source No. M-93

Emergency equipment in control room checked by F.C.C.

Instruments in trip circuit: K-1-2 PM-1-2

Red light on by AKM Time 1320

Start-up OK'd by F.C.C. AKM Date 3-7-73

2.050 cm separation c-c.
30 cm length.
130" rod.

Have an 23 x 23 array, with the .250" bond sheet centered in array. Have 14 rods removed from 1 row, (on face). Total of 492 rods.

1405 Water ht = 21.50 cm
System just critical
Drain.

Temp °C
#1 = 24.0 °C
2 = 24.2 °C

Removed 30 rods. Now have an 22 x 22 array, with the bond plate centered in 12th row. Total of 462 rods.

1425 Water ht = 23.30 cm
System just critical
Drain.

Temp °C
#1 = 24.2 °C
2 = 24.2 °C

Removed 42 rods. Now have an 21 x 21 array, with the bond plate centered in 12th row. Total of 420 rods.

1446 Water ht = 24.80 cm
System just critical
Drain.

Temp °C
#1 = 24.2 °C
2 = 24.2 °C

Removed 40 rods. Now have an 20 X 20 array, with the bond sheet centered in 12th row. Total of 380 rods.

1507 Water ht = 26.30 cm
System just critical
Drawn

Temp °C
#1 = 29.2 °C
2 = 29.2 °C

Removed 38 rods. Now have an 19 X 19 array, with the bond sheet centered in 12th row. Total of 342 rods.


1530 Water ht = 28.70 cm
System just critical
Drawn

Temp °C
#1 = 29.3 °C
2 = 29.3 °C

Removed 18 rods. Now have an 18 X 19 array, with the bond sheet centered in the 12th row. Total of 324 rods.

1550 Water ht = 42.20 cm Probe (in)
System just critical 37.84"
Drawn

Temp °C
#1 = 29.3 °C
2 = 29.3 °C



INSTRUMENT	RANGE	INSTI TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	10x10 ⁻¹²
		Fast ✓	1"	✓	"
K-2	3x10 ⁻¹²	Meter ✓	4"	✓	"
		Fast ✓	1"	✓	"
PM-1	700v	Alarm ✓	1.5"	✓	500v
PM-2	1200v	Low ✓	10"	✓	900v
		Alarm ✓	2"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT
RADIATION ALARM: A B C SOURCE NUMBER 0380

Removed 18 rods with the bond
12th row. Total

There have an 18 x 19 array
130" rods 30cm long
2.050cm sep. e-e
18 x 19 array with
bond sheet centered
in 12th row -

1550

Water level = 42.20
System just over
Draw.

Total rods 324
Page 263

Temp C
1 = 24.3°C
2 = 24.3°C

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	10 x 10 ⁻¹²
		Fast ✓	1"	✓	"
K-2	3x10 ⁻¹²	Meter ✓	4"	✓	"
		Fast ✓	1"	✓	"
PM-1	7000	Alarm ✓	15"	✓	5000
PM-2	12000	Low ✓	10"	✓	9000
		Alarm ✓	2"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT
 RADIATION ALARM: A B C SOURCE NUMBER D-80

2.050 cm separation a-a.
30 cm length.
30 rods.

START-UP CHECK LIST

Equipment checked by PKM Personnel check by F.V.C.
Instruments and safeties checked and reset by PKM
Source in checked by PKM Source No. M-43
Emergency equipment in control room checked by F.V.C.
Instruments in trip circuit: 2-1-2 PKM-2
Red light on by PKM Time 0820
Start-up OK'd by F.V.C. PKM Date 3-8-73

Repeat of last run:

0859 Water ht = 42.20 cm Probe (in) Temp °C
System just critical 37.89" #1 = 24.0°C
Drain. 2 = 24.2°C

Have an 18x19 array, with the bore sheet centered in the 13th row. Total of 324 rods.

1002 Water ht = 27.15 cm Temp °C
System just critical #1 = 24.2°C
Drain. 2 = 24.2°C

Removed 18 rods: Now have an 18x18 array, with the bore sheet centered in the 13th row. Total of 306 rods.

1020 Water ht = 27.70 cm Temp °C
System just critical #1 = 24.2°C
Drain. 2 = 24.2°C

Removed 34 rods: Now have an 17x17 array, with the bore sheet centered in the 13th row. Total of 272 rods.

Water ht = 42.20 cm Probe (in) Temp °C
+ Per 37.89" #1 = 24.2°C
E = 228.16 cm = 5.0 f 2 = 24.2°C

1053 Water ht = 35.80 cm Probe (in)
System just critical 35.39"
Drain.

over:

Removed 4 rods for


$\Delta h = 4.35$

Water ht = 42.20 cm
+ Per.

$C = 869.20 \text{ sec} = 1.4 f$

1315 Water ht = 37.85

System just critical
Drain.



8 rods.
Temp °C
#1 = 29.2°C
#2 = 29.2°C
Boral Sheet
3451

Removed 1 rod: Total of 267 rods.

Water ht = 42.20 cm Probe (in) Temp °C
3 - Per 37.89" #1 = 29.2°C

$C = 1260.34 \text{ sec} = 1.1 f$

1535 Drain.

Now have an 15x16 array, with the boral sheet centered in the 14th row. Total of 224 rods.

Water ht = 42.20 cm Probe (in) Temp °C
4 + Per 37.89" #1 = 29.2°C
 $C = 706.22 \text{ sec} = 1.7 f$ #2 = 29.2°C

1515 Water ht = 36.10 cm Probe (in)
System just critical 35.46"
Drain.

Removed 2 rods from 1 face: Total of 222 rods.

Water ht = 42.20 cm Probe (in) Temp °C
5 - Per 37.89" #1 =

$C = 977.85 \text{ sec} = 1.4 f$ #2 =

1530 Drain.

over!

266

.30" rods 30cm. length
2.050cm. spacing c-c
17x17 array with
level sheet in the
13th row - and
4 rods removed on
1 face
Total rods 268

Removed 4 rods from 1 face, Total of 268 rods.
Page 266 log
 $h_1 = 4.35 \text{ cm}$

Water ht = 42.20cm Probe(in) Temp °C
2 - Per. 37.84 #1 = 29.2°C
 $C = 869.20 \text{ sec} = 1.4 \text{ f}$ 2 = 29.2°C

1315 Water ht = 37.85 Probe(in)
System just critical 36.16"
Drain.


Removed 1 rod; Total of 267 rods.

Water ht = 42.20cm Probe(in) Temp °C
3 - Per 37.84" #1 = 29.2°C
 $C = 1260.34 \text{ sec} = 1.1 \text{ f}$ 2 = 29.2°C
1535 Drain.

Added 1 rod. Total number of rods = 223.

1542 Water ht = 42.20 cm Probe (in)
 System just critical 37.84"
 Drain

Temp °C
 #1 = 24.3°C
 2 = 24.3°C



INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	10x10 ⁻¹²
		Fast ✓	1"	✓	"
K-2	3x10 ⁻¹²	Meter ✓	4"	✓	"
		Fast ✓	1"	✓	"
PM-1	7000	Alarm ✓	1.5"	✓	5000
PM-2	1-2000	Low ✓	10"	✓	9000
		Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT
 RADIATION ALARM: A B C SOURCE NUMBER B-80

START-UP CHECK LIST

F.P.C.
 Equipment checked by AKM Personnel check by F.P.C.
 Instruments and safeties checked and reset by P.K.A.B.
 Source in checked by AKM Source No. M-43
 Emergency equipment in control room checked by F.P.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by AKM Time 0820
 Start-up OK'd by F.P.C., AKM Date 3-9-73

Repeat of last run:

0847 Water ht = 42.20 cm Probe (in) Temp °C
 System just critical 37.84" #1 = 24.2°C
 Drain 2 = 24.2°C

Now have an 13x16 array, with the board sheet centered in the 15th row. (See diagram)
 Total of 208 rods.

Water ht = 30.10 cm Probe (in) Temp °C
 + Per 33.12" #1 = 24.5°C
 T = 110.82 cm = 9.1 f 2 = 24.5°C
 Water ht = 29.85 cm Probe (in)
 System just critical 32.98"
 Drain

over

Added 1 rod 30" rods 30cm long = 223.
 2.050 cm separation c-c
 15 X 16 array with
 bore sheet centered
 in 14th row - and
 1 rod removed from
 15th row -
 Total rods 223

1542 Water ht =
 System just
 Drain

Temp °C
 #1 = 24.3 °C
 2 = 24.3 °C

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	10x10 ⁻¹²
		Fast ✓	1"	✓	"
K-2	3x10 ⁻¹²	Meter ✓	4"	✓	"
		Fast ✓	1"	✓	"
PM-1	7000 ✓	Alarm ✓	1.5"	✓	5000 ✓
PM-2	12000 ✓	Low ✓	10"	✓	9000 ✓
		Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER B-80

Removed 8 rods.


Water ht = 42.20
+ Per

$E = 1673.21 \text{ mm} = 0.8 \text{ f}$

1027 Water ht = 38.8

System just critical
Drain.

Depleted Uranium
5.625" X 10.1875" X 22.315"



2.50" X 10.1875" X 18.549"
Borehole sheet

200 rods
Temp °C
#1 = 24.5°C
#2 = 29.5°C

Removed 1 rod. Total of 199 rods.

Water ht = 42.20 cm Probe (in) Temp °C

3-Per 37.84" #1 = 24.7°C

$E = -176.01 \text{ mm} = -9.7 \text{ f}$ #2 = 24.7°C

1300 Drain:

Now have an 18x19 array, with the borehole sheet centered in 11th row. Total of 324 rods.

Water ht = 42.20 cm Probe (in) Temp °C

System sub-critical 37.84" #1 = 24.7°C

Drain #2 = 24.7°C

added 18 rods. Now have an 19x19 array, with the borehole sheet centered in 11th row. Total of 342 rods.

1443 Water ht = 42.20 cm Probe (in)

System sub-critical 37.84"
Drain.

Temp °C
#1 = 24.7°C
#2 = 24.7°C

added 19 rods. Now have an 19x20 array with the borehole sheet centered in the 11th row. Total of 361 rods.

Water ht = 31.60 cm Probe (in) Temp °C

4-Per 33.71" #1 = 24.7°C

$E = 126.03 \text{ mm} = 8.2 \text{ f}$ #2 = 24.7°C

1522 Water ht = 31.25 cm Probe (in)

System just critical 33.51"
Drain.

Removed 10 rods. Total of 351 rods.

Water ht = 42.30 cm Probe (in) Temp °C

5-Per 37.84" #1 = 24.7°C

$E = -438.95 \text{ mm} = -3.2 \text{ f}$ #2 = 24.7°C

1546 Drain:

270

30 rods 30 cm. long
 2.050 cm. separation c-c
 13 x 16 array with
 head sheet centered in
 15th row. Have 8 rods
 removed from 1 face

Removed 8 rods from 1 face. Total of 200 rods.

$h_c = 3.4 \text{ cm.}$
 Water ht = 42.20 cm Probe (in) Temp °C
 2 + Per 37.89" #1 = 24.5°C
 2 = 24.5°C

1027 $U = 1673.21 \text{ su} = .8 \text{ f}$
 Water ht = 38.80 cm Probe (in)
 System just critical 36.53
 Drain.

Removed 1 rod. Total of 199 rods.

1300 Water ht = 42.20 cm Probe (in) Temp °C
 3 - Per 37.89" #1 = 24.7°C
 $U = -176.01 \text{ su} = -9.7 \text{ f}$ 2 = 24.7°C
 Drain.

Now have an 18 x 19 array, with the head
 sheet centered in 11th row. Total of 324 rods.

Water ht = 42.20 cm Probe (in) Temp °C
 System sub critical 37.89" #1 = 24.7°C
 Drain 2 = 24.7°C

154


INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	10 x 10 ⁻¹²
		Fast ✓	1"	✓	"
K-2	3x10 ⁻¹²	Meter ✓	4"	✓	"
		Fast ✓	1"	✓	"
PM-1	700 V	Alarm ✓	.5	✓	500 V
PM-2	1200 V	Low ✓	10"	✓	900 V
		Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT
 RADIATION ALARM: A B C SOURCE NUMBER B-80

START-UP CHECK LIST

Equipment checked by Fibc Personnel check by Fibc
 Instruments and safeties checked and reset by AKM
 Source in checked by AKM Source No. M-93
 Emergency equipment in control room checked by Fibc
 Instruments in trip circuit: K-1-2 PM-2
 Red light on by AKM Time 0815
 Start-up OK'd by Fibc, AKM Date 3-12-73



added 1 rod. $\Delta z = 6$
 Water ht = 42.10
 + Per
 $T = 325.95 \text{ new} = 3.1$
 0857 Water ht = 36.00
 System just critical 0841
 Drain.

250' x 10.187' x 9.549"
 Total sheet
 60
 24.2°C
 24.2°C

Have an 19x20 array, with 9 rods removed from 1 face. Have the bond sheet continued in the 10th row. Total of 352 rods.

1023 Water ht = 42.20 cm Probe (in) Temp °C
 System sub critical 37.84"
 Drain. #1 = 24.2°C
 2 = 29.2°C

added 3 rods: Total of 355 rods.

Water ht = 42.20 cm Probe (in) Temp °C
 2-Per 37.84" #1 = 24.2°C
 $C = 113.0 \text{ new} = 20.24$ 2 = 29.2°C

1045 Drain.

over

130 rods 30cm. long
 2.050 cm separation c-c
 19x20 array with
 bond sheet centered
 in 11th row.

273

Total rods 352

Page 273 has

added 1 rod. Total of 352 rods.

$$\Delta z = 6.1 \text{ cm}$$

Water ht = 42.10 cm Probe (in)

Temp °C

+ Per

37.84"

#1 = 24.2°C

$$C = 325.95 \text{ sec} = 3.6 \text{ f}$$

2 = 24.2°C

0857

Water ht = 36.00 cm Probe (in)

System just critical 35.41"
 Drain.

Have an 19x20 array, with 9 rods removed
 from 1 face. Have the bond sheet centered
 in the 10th row. Total of 352 rods.

1023 Water ht = 42.20 cm Probe (in)

Temp °C

System sub critical 37.84"

#1 = 24.2°C

Drain.

2 = 24.2°C

Added 3 rods. Total of 355 rods.

Water ht = 42.20 cm Probe (in)

Temp °C

² - Per

37.84"

#1 = 24.2°C

$$C = 113.0 \text{ sec} = 20.2 \text{ f}$$

2 = 24.2°C

1045

Drain.

over

added 1 rod: Total of 356 rods.

Water ht = 42.20 cm Probe (in)

3-Per 37.84

U = 143.42 mm = 13.0 f

1106 Drain:

Temp °C

#1 = 24.2 °C

2 = 24.2 °C

added 1 rod: Total of 357 rods.

Water ht = 42.20 cm Probe (in)

4-Per 37.84"

U = 202.09 mm = 8.1

1300 Drain:

Temp °C

#1 = 24.2 °C

2 = 24.2 °C

added 1 rod: Total of 358 rods.

Water ht = 42.20 cm Probe (in)

5-Per 37.84"

U = 360.72 mm = 4.0 f


1320 Drain

Temp °C

#1 = 24.5 °C

2 = 24.5 °C

Depleted Uranium
5.425 x 10.175 x 22.275"



added 1 rod

Water ht = 42.20 cm

6+Per

U = 2259.92 mm

1350

Water ht = 36.55

System just critical

Drain.

Temp °C

#1 = 24.5 °C

2 = 24.5 °C

Have an 19 x 20 array, with 2 rods removed from 1 face. Have boron sheet centered in the 9th row. Total of 359 rods.

Water ht = 29.70 cm Probe (in)

7+Per 32.98"

U = 57.32 mm = 15.5 f

1458

Water ht = 29.45 cm Probe (in)

System just critical 32.80

Drain.

Temp °C

#1 = 24.5 °C

2 = 24.5 °C

Removed 10 rods: Total of 349 rods.

Water ht = 42.20 cm Probe (in)

8-Per 37.84"

U = 160.80 mm = 11.0 f

1511

Drain:

Temp °C

#1 = 24.2 °C

2 = 24.2 °C

19x20 array with
boral sheet centered
in 10th row.

Total rods 359

Page 275 log.

275

added 1 rod: Total 359 rods.

$$\Delta h = 3.3 \text{ cm}$$

Water ht = 42.20 cm Probe (in)

6 + Per 37.84"

$$C = 2259.92 \text{ cm} = 1.6 \text{ f}$$

Temp °C

#1 = 24.5 °C

2 = 24.5 °C

Temp °C
#1 = 24.2 °C
#2 = 24.2 °C

1350

Water ht = 38.90 cm Probe (in)

System just critical 36.55

Drain.

Temp °C
#1 = 24.2 °C
#2 = 24.2 °C

Have an 19x20 array, with 2 rods removed
from 1 face. Have boral sheet centered in
the 9th row. Total of 359 rods.

Water ht = 29.70 cm Probe (in)

7 + Per 32.98"

$$C = 54.32 \text{ cm} = 15.5 \text{ f}$$

Temp °C

#1 = 24.5 °C

2 = 24.5 °C

1458

Water ht = 29.45 cm Probe (in)

System just critical 32.80

Drain.

Temp °C
#1 = 24.5 °C
#2 = 24.5 °C

Removed 10 rods: Total of 349 rods.

Water ht = 42.20 cm Probe (in)

8 - Per 37.84"

$$C = -160.80 \text{ cm} = -11.0 \text{ f}$$

Temp °C

#1 = 24.2 °C

2 = 24.2 °C

1517

Drain.

INSTRUMENT CHECK


INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter -	4"	-	10x10 ⁻¹²
		Fast -	4"	-	"
K-2	3x10 ⁻¹²	Meter -	4"	-	"
		Fast -	1"	-	"
PM-1	7000	Alarm -	15"	-	5000
PM-2	12000	Low -	10"	-	7000
		Alarm -	1"	-	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT
 RADIATION ALARM: A B C SOURCE NUMBER B-80

START-UP CHECK LIST

Equipment checked by F.I.C. Personnel check by F.I.C.
 Instruments and safeties checked and reset by AKK
 Source in checked by AKK Source No. 19-43
 Emergency equipment in control room checked by F.I.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by AKK Time 0915
 Start-up OK'd by F.I.C. AKK Date 3-13-73

Depleted Uranium
 S. 4.25 X 16.15 X 22.715"
 62.715"



added 1 rod.
 Water ht = 42.2
 + Per
 E = 630.17 u = 2.0
 0917 Water ht = 36.
 System just on
 Drain.

250" X 10.187" X 18.549"
 Boral Sheet

Temp °C
 = 29.2°
 = 29.2°

Now have an 19x19 array. Have boral sheet centered in the 8th row. Total of 392 rods.

Water ht = 33.80 cm Probe (in) Temp °C
 2 + Per 34.56" #1 = 24.3°
 E = 110.82 u = 9.1 f #2 = 24.3°

1021 Water ht = 32.60 cm Probe (in)
 System just critical 34.09"
 Drain.

Removed 4 rods from face. Total of 338 rods.

Water ht = 42.20 cm Probe (in) Temp °C
 3 - Per 37.84" #1 = 24.5°
 E = 289.01 u = 5.2 f #2 = 24.5°

1052 Drain

19x20 array with
Boral sheet centered
in 9th row, and
11 rods removed from

1 face
total rods 350
Page 277 log

277

added 1 rods. Total of 350 rods,

$\sigma_1 = 5.5 \text{ cm}$

Water ht = 42.20 cm	Probe (in)	Temp °C
+ Per	37.84"	#1 = 24.2 °C
$\tau = 630, 17 \text{ sec} = 2.0 \phi$		2 = 24.2 °C

0917

Water ht = 36.70 cm	Probe (in)
System just critical	35.69"
Drain.	

Now have an 19x19 array: Have boral sheet centered in the 8th row. Total of 342 rods.

Water ht = 33.80 cm	Probe (in)	Temp °C
² + Per	34.56"	#1 = 24.3 °C
$\tau = 110.82 \text{ sec} = 9.1 \phi$		2 = 24.3 °C

1021

Water ht = 32.60 cm	Probe (in)
System just critical	34.04"
Drain.	

Removed 4 rods from face: Total of 338 rods.


Water ht = 42.20 cm	Probe (in)	Temp °C
³ - Per	37.84"	#1 = 24.5 °C
$\tau = 289.01 \text{ sec} = 5.2 \phi$		2 = 24.5 °C

1052

Drain

add 1 rad
 Water ht = 42
 + Per
 C = 1173.42
 Water ht = 35
 System just critical
 Drain.

Depleted Uranium
 5.125 X 10.151 5" X 22.715"



.250" X 10.187" X 18.549"
 Boral sheet

Temp °
 = 29.5 °C
 = 29.5 °C

INSTRUMENT CHECK					
INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	9"	✓	10x10 ⁻¹²
		Fast ✓	1"	✓	"
K-2	3x10 ⁻¹²	Meter ✓	9"	✓	"
		Fast ✓	1"	✓	"
PM-1	7000	Alarm ✓	5"	-	5000
PM-2	12000	Low -	10"	-	9000
		Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT
 RADIATION ALARM: A B C SOURCE NUMBER P-80

START-UP CHECK LIST

Equipment checked by I.D.C. Personnel check by R.K.M.
 Instruments and safeties checked and reset by R.K.M.
 Source in checked by R.K.M. Source No. M-83
 Emergency equipment in control room checked by I.D.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by R.K.M. Time 0840
 Start-up OK'd by I.D.C., R.K.M. Date 3-14-73

Repeat of last run:

Water ht = 42.20 cm Probe (in) Temp °
 + Per. 37.84" #1 = 24.3 °C
 C = 386.79 uas = 3.1 f #2 = 24.5 °C
 0930 Water ht = 35.70 cm Probe (in)
 System just critical 35.33"
 Drain.
 Now have an 18x19 array, with the boron sheet centered in the 7th row. Total of 323 rods.
 Water ht = 42.20 cm Probe (in) Temp °
 System sub critical 37.84" #1 = 24.5 °C
 1039 Drain. #2 = 24.5 °C

278

19 x 19 array with
 bore sheet centered
 in 8th row. Some
 3 rods removed on
 face

total rods 339

added 1 rod: Total of 339 rods.

$\Delta h = 3.80m$

Water ht = 42.20 cm Probe (in) 37.84"

Temp °C
 #1 = 29.5 °C
 2 = 29.5 °C

$U = 1173.42 \text{ m} = 1.17$

Water ht = 38.90 cm Probe (in)

System just critical 36.73"
 Drain.

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	4"	✓	10x10 ⁻¹²
		Fast ✓	1"	✓	"
K-2	3x10 ⁻¹²	Meter ✓	4"	✓	"
		Fast ✓	1"	✓	"
PM-1	7000	Alarm ✓	5"	✓	5000
PM-2	12000	Low ✓	10"	✓	9000
		Alarm ✓	1"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER B-80

added 4 rods: Total of 327 rods.

Water ht = 33.60 cm Probe (in) Temp °C
 + Per 34.10" #1 = 29.3 °C
 C = 63.02 sec = 13.94 2 = 29.3 °C

1105 Water ht = 31.50 cm Probe (in)
 System just critical 33.61"
 Drain.

Removed 2 rods: Total of 325 rods.


Water ht = 42.20 cm Probe (in) Temp °C
 3-Per 37.84" #1 = 29.5 °C
 C = -286.84 sec = -5.34 2 = 29.5 °C

1256 Drain.

added 1 rod: Total of 326 rods.

Water ht = 42.20 cm
 4-Per 37.84" Temp °C
 C = 86.92 sec = 11.04 4.5 °C
 4.5 °C

1320 Water ht = 33.40 cm
 System just critical
 Drain.



250X1018X18.549 BORON SHEET

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter ✓	5"	✓	10x10 ⁻¹²
		Fast ✓	5"	✓	"
K-2	3x10 ⁻¹²	Meter ✓	5"	✓	"
		Fast ✓	5"	✓	"
PM-1	7000	Alarm ✓	5"	✓	5000
PM-2	12000	Low ✓	10"	✓	9000
		Alarm ✓	2"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT
 RADIATION ALARM: A B C SOURCE NUMBER B.80

START-UP CHECK LIST

Equipment checked by AKV Personnel check by Z.D.C.
 Instruments and safeties checked and reset by AKV
 Source in checked by AKV Source No. M-23
 Emergency equipment in control room checked by Z.D.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by AKV Time 0845
 Start-up OK'd by Z.D.C. AKV Date 3-10-73

added 4 rods: Total of 327 rods.

Water ht = 33.60 cm Probe (in) Temp °C
 2 + Per 34.10" #1 = 24.3 °C
 C = 63.07 sec = 13.94 2 = 24.3 °C

1105 Water ht = 31.50 cm Probe (in)
 System just critical 33.61"
 Drain

Removed 2 rods: Total of 325 rods.

Water ht = 42.20 cm Probe (in) Temp °C
 3 - Per --- 24.5 °C
 C = -286.89 sec = -5. 18 X 19 array with
 18 X 19 array with
 horizontal centered
 in 7th row. 24.5 °C

1256 Drain.

added 1 rod: Total rods 326
 Page 280 log
 Δt = 8.90

Water ht = 42.20 cm
 4 + Per 37.89" #1 = 24.5 °C
 C = 86.92 sec = 11.04 2 = 24.5 °C

1320 Water ht = 33.40 cm Probe (in)
 System just critical 34.39"
 Drain.


Now have an 18 X 18 array, with the bond plate centered in both rows.
Total of 306 rods.

Water ht = 30.50 cm Probe (in) Temp °C
+ Per 33.30" #1 = 24.3°
#2 = 24.3°
 $\tau = 84.75 \mu s = 11.2 \phi$

0935 Water ht = 30.20 cm Probe (in)
System just critical 33.13"
Drain.

Removed 6 rods: $\Delta h = 8.7 \text{ cm}$

Water ht = 42.20 cm
+ Per
 $\tau = 97.78 \mu s = 10.0 \phi$
1030 Water ht = 33.50 cm
System just critical
Drain.



Removed 1 rod: Total of 299 rods.

Water ht = 42.30 cm Probe (in) Temp °C
3-Per 37.84" #1 = 24.3°
#2 = 24.3°
 $\tau = 782.28 \mu s = -1.7 \phi$


1045 Drain:

Now have an 17 X 17 array, with the bond plate centered in the 5th row. Total of 272 rods.

1304 Water ht = 42.20 cm Probe (in) Temp °C
System sub critical 37.84" #1 = 24.5°
Drain #2 = 24.5°

Added 6 rods to 1 row: Total of 278 rods.

$\Delta h = 9.6 \text{ cm}$
Water ht = 42.20
+ Per
 $\tau = 56.50 \mu s = 15.1 \phi$
Water ht = 32.60
System just critical
Drain.



Removed 1 rod: Total of 277 rods.

Water ht = 42.30 cm Probe (in) Temp °C
5-Per 37.84" #1 = 24.7°
#2 = 24.7°
 $\tau = 2281.65 \mu s = -0.6 \phi$
1356 Drain

Now have an 18 X 18 array, with the head plate centered in 6th row. Total of 306 rods.

Water ht = 30.50 cm Probe (in) Temp °C
+ Per 29.3°
E = 84.75 μm = 11.2 φ 29.3°

0935 Water ht = 30.20 cm
System just critical
Drain.

Removed 6 rods: Δh = 8.7 cm

Water ht = 42.20 cm Probe (in) Temp °C
+ Per 37.84" #1 = 29.5°
E = 97.78 μm = 10.0 φ 2 = 29.5°

1030 Water ht = 33.50 cm Probe (in)
System just critical 34.40"
Drain.

Removed 1 rod: Total of 299 rods.

Water ht = 42.30 cm Probe (in) Temp °C
- Per 37.84" #1 = 29.3°
E = 782.28 μm = -1.7 φ 2 = 24.3°

1045 Drain:

Now have an 17 X 17 array, with the head plate centered in the 5th row. Total of 272 rods.

1304 Water ht = 42.20 cm Temp °C
System just critical 29.5°
Drain 29.5°

Added 6 rods Δh = 9.6 cm

Water ht = 42.20 cm Temp °C
+ Per 37.84" #1 = 29.7°
E = 56.50 μm = 15.1 φ 2 = 29.7°

Water ht = 32.60 cm Probe (in)
System just critical 34.00"
Drain.

Removed 1 rod: Total of 277 rods.

Water ht = 42.30 cm Probe (in) Temp °C
- Per 37.84" #1 = 29.7°
E = 2281.65 μm = -0.6 φ 2 = 29.7°

1356 Drain

INSTRUMENT CHECK					
INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3×10^{-12}	Meter ✓	4"	✓	10×10^{-12}
		Fast ✓	2"	✓	"
K-2	3×10^{-12}	Meter ✓	4"	✓	"
		Fast ✓	2"	✓	"
PM-1	200V	Alarm ✓	5"	✓	500V
PM-2	1200V	Low ✓	10"	✓	1200V
		Alarm ✓	2"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT
 RADIATION ALARM: A B C SOURCE NUMBER 0-83

START-UP CHECK LIST


Equipment checked by F.O.C. Personnel check by F.O.C.
 Instruments and safeties checked and reset by ARKM
 Source in checked by ARKM Source No. 19-43
 Emergency equipment in control room checked by F.O.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by ARKM Time 0940
 Start-up OK'd by F.O.C. ARKM Date 3-19-73

Have an 16x17 array with the central plate centered in the 4th row. Total of 256 rods.

Water ht = 42.20cm Probe (in) Temp °C
 1-Per 37.84 #1 = 29.2°
 N.G. 2 = 29.2°
 1010 Drain

added 2 rods to 1 face. Total of 258 rods.

Water ht = 42.20cm
 2-Per
 E = 89.09 sec = 10.8°
 1045 Water ht = 33.30cm
 System just airt.
 Drain



Removed 1 rod. Total of 257 rods.
 Water ht = 42.20cm Probe (in) Temp °C
 3-Per 37.84 #1 = 29.0°
 E = 278.14 sec = -5.4°
 1100 Drain

I have an 16x17 array, with the basal plate centered in the 4th row. Total of 256 rods.

	Water ht = 42.2	- P - 1. ()	Temp °C
1010	1-Per	16x17 array with	29.2 °C
	N.C.	basal plate in 4th row	9.2 °C
	Drain	Total rods 258	

Paged 65 by

added 2 rods to

$SL = 8.9 \text{ cm}$

	Water ht = 42.20 cm	1 row in	Temp °C
1085	2-Per	37.84	#1 = 24.2 °C
	$E = 89.09 \text{ mm} = 10.8 \text{ f}$		2 = 24.2 °C

1085 Water ht = 33.30 cm (Probe in)
 system just critical 34.29"
 Drain.

Removed 1 rod: Total of 257 rods:

	Water ht = 42.20 cm (Probe in)	Temp °C
1100	3-Per	37.84"
	$E = -278.14 \text{ mm} = -5.4 \text{ f}$	#1 = 24.0 °C
	Drain	2 = 24.0 °C

Have an 16x16 array, with the borehole sheet centered in 3rd row. Total of 240 rods.


1325 Water ht = 42.20 cm Probe (in) Temp °C
 System sub critical 37.84" #1 = 29.2°C
 Drain. 2 = 29.2°C

added 3 rods to 1 face. Total of 243 rods.

1348 Water ht = 42.20 cm Probe (in) Temp °C
 4-Per 37.84" #1 = 29.3°C
 Drain. E = -793.14 mV = -1.74 2 = 29.3°C

added 1 rod. Total of 244 rods.

1408 Water ht = 32.50 cm
 System just critical
 Drain. E = 54.32 mV = 15.54



Have an 15x16 array, with the borehole sheet centered in the 2nd row. Total of 225 rods.

Water ht = 42.20 cm Probe (in) Temp °C
 6-Per 37.84" #1 = 29.5°C
 E = -154.28 mV = -1.174 2 = 29.5°C

1530 Drain

INSTRUMENT CHECK

INSTRUMENT	RANGE	TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻²	Meter ✓	4"	✓	10x10 ⁻¹²
		Fast ✓	2"	✓	"
K-2	3x10 ⁻¹²	Meter ✓	4"	✓	"
		Fast ✓	2"	✓	"
PM-1	1000	Alarm ✓	15"	-	5000
PM-2	12000	Low ✓	10"	✓	9000
		Alarm ✓	2"	✓	"

LOG N CALIBRATE OPERATE DUMP WELL PROBE LIGHT
 RADIATION ALARM: A B C SOURCE NUMBER B-80

Have an 16x16 array, with the bond sheet centered in 3rd row. Total of 240 rods.

1325 Water ht = 42.20 cm Probe (in) Temp °C
 System sub critical 37.84" #1 = 24.2 °C
 Drain. 2 = 24.2 °C

added 3 rods to 1 face. Total of 243 rods.

Water ht = 42.20 cm Probe (in) Temp °C
 4-Per 4.3 °C

1348 C = -793.14 sec = -1.7; 16x16 array with Bond sheet centered in 3rd row, 12 rods missing on 1 face. Temp 4.3 °C
 Drain

added 1 rod. To total rods 244
 Dh = 9.1 cm Prop. 30.6 sec

Water ht = 42.20 cm
 5-Per 37.84" #1 = 24.3 °C
 C = 54.32 sec = 15.5 ft 2 = 24.3 °C

1408 Water ht = 32.50 cm Probe (in)
 System just critical 39.99"
 Drain.

START-UP CHECK LIST

Equipment checked by F.I.O.C. / RKM Personnel check by RKM
 Instruments and safeties checked and reset by RKM
 Source in checked by RKM Source No. M-83
 Emergency equipment in control room checked by F.I.O.C.
 Instruments in trip circuit: K-1-2 PM-1-2
 Red light on by RKM Time 0930
 Start-up OK'd by F.I.O.C. / RKM Date 3-20-73

added 1 rod to 1 fuel. Total of 226 rods.


$\Delta h = 8.6 \text{ cm}$

Water ht = 42.20 cm Probe (in) Temp °C
 + Per 37.89" #1 = 24.2°C
 #2 = 24.2°C

$E = 123.86 \text{ m} = 8.3 \text{ f}$

1055 Water ht = 33.60 cm Probe (in)
 System just critical 34.43"
 Drain

Depleted Uranium
 5.425 X 10.115" X 22.715"



250 X 10.187 X 18.549"
 1303A W. S. H. G. E. T.

Now have an 14x15 on way: will the
 lateral sheet in 1st row. Have 9 rods
 removed from 1 fuel. Total of 206 rods.

Water ht = 42.20 cm Probe (in) Temp °C
 + Per 37.89" #1 = 24.0°C
 #2 = 24.2°C
 $E = -165.15 \text{ m} = -10.6 \text{ f}$

1330

Drain:

INSTRUMENT	RANGE	INSTRUMENT CHECK			
		TRIP	SOURCE DISTANCE	RESET	STARTUP RANGE
K-1	3x10 ⁻¹²	Meter <input checked="" type="checkbox"/>	4"	<input checked="" type="checkbox"/>	10x10 ⁻¹²
		Fast <input checked="" type="checkbox"/>	2"	<input checked="" type="checkbox"/>	"
K-2	3x10 ⁻¹²	Meter <input checked="" type="checkbox"/>	4"	<input checked="" type="checkbox"/>	"
		Fast <input checked="" type="checkbox"/>	2"	<input checked="" type="checkbox"/>	"
PM-1	700V	Alarm <input checked="" type="checkbox"/>	15"	<input checked="" type="checkbox"/>	500V
PM-2	1200V	Low <input checked="" type="checkbox"/>	10"	<input checked="" type="checkbox"/>	900V
		Alarm <input checked="" type="checkbox"/>	2"	<input checked="" type="checkbox"/>	"

LOG CALIBRATE OPERATE DUMP WELL PROBE LIGHT

RADIATION ALARM: A B C SOURCE NUMBER B-80

START-UP CHECK LIST

Equipment checked by F.I.O.C. BKL Personnel check by BKL
 Instruments and safeties checked and reset by BKL
 Source in checked by BKL Source No. M-83
 Emergency equipment in control room checked by F.I.O.C.
 Instruments in trip circuit: K-1-2 PM1-2
 Red light on by BKL Time 0930
 Start-up OK'd by F.I.O.C. BKL Date 3-20-73

added 1 rod to 1 fuel. Total of 226 rods.

$D_h = 8.6 \text{ cm}$

Water ht = 123.86 m A 1055

+ Row 15 x 17 array with
 boraf sheet centered
 in 2nd row. and

1055 Water ht = 14 rods missing in
 system just 1 row.

Chain. Total rods 226
 Page 288 day

Temp. °C
 #1 = 29.2°C
 2 = 29.2°C

START-UP CHECK LIST

Equipment checked by ^{F.P.C.} AKM Personnel check by RKM
 Instruments and safeties checked and reset by AKM
 Source in checked by AKM Source No. M-93
 Emergency equipment in control room checked by AKM F.P.C.
 Instruments in trip circuit: R-1-2 PM-2
 Red light on by AKM Time 0235
 Start-up OK'd by F.P.C. AKM Date 3-21-73


Added 1 rod: Total of 207 rods.

$h = 6.9 \text{ cm}$

Water ht = 42.20 cm Probe (in) Temp °C
 + Per 37.8 °C #1 = 29.0 °C
 $T = 478.06 \text{ sec} = 2.5 \text{ f}$ 2 = 29.0 °C

1315 Water ht = 35.80 cm Probe (in)
 System just critical 35.31"
 Drain.

Depleted Uranium
 S. 1.25 X 10.1815 X 22.215"
 16.27 cm




Repeat of experiment described on P-213.
 14 X 14 - 1 array: Total of 195 rods.

Water ht = 42.20 cm Probe (in) Temp °C
 + Per 37.8 °C #1 = 29.0 °C
 $T = 506.31 \text{ sec} = 2.4 \text{ f}$ 2 = 29.0 °C

1493 Water ht = 35.70 cm Probe (in)
 System just critical 35.27"
 Drain. Diff from 2-0-10 by 114

Depleted Uranium
 S. 1.25 X 10.1815 X 22.215"
 16.27 cm



START-UP CHECK LIST

Equipment checked by ^{F.P.C.} AKM Personnel check by RKM
 Instruments and safeties checked and reset by AKM
 Source in checked by AKM Source No. M-93
 Emergency equipment in control room checked by AKM F.O.C.
 Instruments in trip circuit: R-1-2 PM1-2
 Red light on by AKM Time 0235
 Start-up OK'd by F.P.C. AKM Date 3-21-73

Added 1 rod. Total of 207 rods.

oh = 6.9cm

Water ht: 14x15 array with
1+Per hand sheet centered

T = 478.06 in 157. row. Hand

1315 Water ht = 3 rods removed from

system just 1 four

Drain. Total rods 207

Page 290

Temp °C

#1 = 24.0°C

2 = 24.0°C

Repeat of experiment described on P-213.
14x14 - 1 array. Total of 195 rods.

Water ht = 42.20 cm Probe (in) Temp °C
2+Per 37.8°C #1 = 24.0°C

T = 506.31 in 14x14 array
with 1 rod missing

1443 Water ht = in 1 row. No. 7"

system just bare plate

Drain. Total rods 195. Page 291 Log

(Repeat array)